

VOTE SHEET

SPECIAL COMMISSION CONFERENCE

DATE 5/25/90

RE: DOCKET NO. 900004-EU - Planning Hearings on Load Forecasts, Generation Expansion Plans, and Cogeneration Prices for Peninsular Florida's Electric Utilities. (Deferred from the April 17, 1990 Commission Conference)

Issue: Recommendation that the Commission should not alter its decision concerning the appropriate statewide avoided unit and subsequent cogeneration prices as set forth in Order No. 22341. The evidence contained in the record still supports the selection of a 385 MW combined cycle unit with an in-service date of 1993 as the first statewide avoided unit.

DENIED

The Commission altered its decision by designating a 11500 mw base load coal fired plant as the avoided unit for this annual planning process. A specific utility was not designated for this unit. The Commission also directed that the allocation process be eliminated and that subscription be retained.

COMMISSIONERS ASSIGNED: Full Commission

COMMISSIONERS' VOTES

APPROVED

APPROVED WITH MODIFICATIONS

DISAPPROVED

DEFER

_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

REMARKS/DISSENTING COMMENTS:

TO:

NOTE: The parameters included in staffs 9-8-89 memo for the 1996 coal unit were approved.

DOCUMENT NUMBER-DATE

FSC/RAR33 (5/90)

04 05 90 MAY 21 1990
(04075)

FPC-RECORDS/REPORTING

Staff was directed to propose a plan for incorporating Gulf Power Company's generation expansion projections into the statewide planning process.