

MACFARLANE AUSLEY FERGUSON & McMULLEN

ATTORNEYS AND COUNSELORS AT LAW

227 SOUTH CALHOUN STREET

P.O. BOX 391 (ZIP 32302)

TALLAHASSEE, FLORIDA 32301

(904) 224-9115 FAX (904) 222-7560

111 MADISON STREET, SUITE 2300

P.O. BOX 1531 (ZIP 33601)

TAMPA, FLORIDA 33602

(813) 273-4200 FAX (813) 273-4396

400 CLEVELAND STREET

P.O. BOX 1669 (ZIP 34617)

CLEARWATER, FLORIDA 34615

(813) 441-8966 FAX (813) 442-8470

May 20, 1994

IN REPLY REFER TO:

HAND DELIVERED

Tallahassee

Ms. Blanca S. Bayo, Director
Division of Records and Reporting
Florida Public Service Commission
101 East Gaines Street
Tallahassee, Florida 32399-0850

Re: Fuel and Purchased Power Cost Recovery Clause
with Generating Performance Incentive Factor;
FPSC Docket No. 940001-EI

Dear Mr. Tribble:

Enclosed for filing in the above docket, on behalf of Tampa
Electric Company, are fifteen (15) copies of each of the following:

- ACK 5
AFA
APP
CAF
CMU
CTR
EAG
LEG 1
LIN 3+ by test
CPC
RCH
SEC 1 writer.
WAS
OTH

Please acknowledge receipt and filing of the above by stamping
the duplicate copy of this letter and returning same to this
writer.

Thank you for your assistance in connection with this matter.

Sincerely,

James D. Beasley

RFT/EAT James D. Beasley
DOCUMENT NUMBER-DATE

04929 MAY 20 94

FPSC-RECORDS/REPORTING

RECEIVED & FILED

FPSC-BUREAU OF RECORDS

JDB/pp
encls.

cc: All Parties of Record (w/encls.)

Pennino
DOCUMENT NUMBER-DATE

04927 MAY 20 94

FPSC-RECORDS/REPORTING

Kelele
DOCUMENT NUMBER-DATE

04928 MAY 20 94

FPSC-RECORDS/REPORTING

Ms. Blanca S. Bayo  
May 20, 1994  
Page 2

CERTIFICATE OF SERVICE

I HEREBY CERTIFY that a true copy of the foregoing testimony and exhibits, filed on behalf of Tampa Electric Company, has been furnished by U. S. Mail or hand delivery (\*) on this 20<sup>th</sup> day of May, 1994 to the following:

Ms. Martha C. Brown\*  
Ms. Donna L. Canzano  
Division of Legal Services  
Florida Public Service  
Commission  
101 East Gaines Street  
Tallahassee, FL 32399-0863

Mr. James A. McGee  
Senior Counsel  
Florida Power Corporation  
Post Office Box 14042  
St. Petersburg, FL 33733

Mr. Joseph A. McGlothlin  
Ms. Vicki Gordon Kaufman  
McWhirter, Reeves, McGlothlin,  
Davidson & Bakas  
315 S. Calhoun St., Suite 716  
Tallahassee, FL 32301

Mr. Jack Shreve  
Office of Public Counsel  
Room 812  
111 West Madison Street  
Tallahassee, FL 32399-1400

Mr. Matthew M. Childs  
Steel Hector & Davis  
Suite 601  
215 South Monroe Street  
Tallahassee, FL 32301

Mr. John W. McWhirter  
McWhirter, Reeves, McGlothlin,  
Davidson & Bakas  
Post Office Box 3350  
Tampa, FL 33601

Ms. Suzanne Brownless  
Suzanne Brownless P.A.  
1546 Blairstone Pines Drive  
Tallahassee, FL 32301

Mr. Robert Goldman  
Messer, Vickers, Caparelli,  
Madson, Lewis, Goldman & McCZ  
Post Office Box 1876  
Tallahassee, FL 32301-1876

Mr. B. Kenneth Gatlin  
Gatlin, Woods, Carlson  
& Cowdery  
1709-D Mahan Drive  
Tallahassee, FL 32308

Mr. Jeffrey Stone  
Beggs & Lane  
Post Office Box 12950  
Pensacola, FL 32576

Mr. Richard A. Zambo  
Richard A. Zambo, P.A.  
598 S.W. Hidden River Avenue  
Palm City, FL 34990

Mr. Earle H. O'Donnell  
Ms. Zori G. Ferkin  
Dewey Ballantine  
1775 Pennsylvania Avenue, N.W.  
Washington, D. C. 20006-4605


Mr. David M. Kleppinger  
Post Office Box 1166  
Harrisburg, PA 17108-1166

Mr. Eugene M. Trisko  
Post Office Box 596  
Berkeley Springs, WV 25411

Mr. Mark K. Logan  
Bryant, Miller & Olive  
201 South Monroe Street  
Suite 500  
Tallahassee, FL 32301

Ms. Blanca S. Bayo  
May 20, 1994  
Page 3

Mr. Thomas J. Schmidt  
General Counsel  
Orgulf Transport Co.  
1400-580 Building  
Post Office Box 1460  
Cincinnati, OH 45201

  
ATTORNEY

ORIGINAL  
FILE COPY

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

DOCKET NO. 940001-EI  
TAMPA ELECTRIC COMPANY  
SUBMITTED FOR FILING 05/20/94  
(TRUE UP)

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION  
PREPARED DIRECT TESTIMONY  
OF  
GEORGE A. KESELOWSKY

Q. Will you please state your name, business address, and employer?

A. My name is George A. Keselowsky and my business address is Post Office Box 111, Tampa, Florida 33601. I am employed by Tampa Electric Company.

Q. Please furnish us with a brief outline of your educational background and business experience.

A. I graduated in 1972 from the University of South Florida with a Bachelor of Science Degree in Mechanical Engineering. I have been employed by Tampa Electric Company in various engineering positions since that time. My current position is that of Senior Consulting Engineer - Production Engineering.

1 Q. What are your current responsibilities?

2

3 A. I am responsible for testing and reporting unit performance, and the compilation  
4 and reporting of generation statistics.

5

6 Q. What is the purpose of your testimony?

7

8 A. My testimony presents the actual performance results from unit equivalent  
9 availability and station heat rate used to determine the Generating Performance  
10 Incentive Factor (GPIF) for the period October 1993 through March 1994. I will  
11 also compare these results to the targets established prior to the beginning of the  
12 period.

13

14 Q. Have you prepared an exhibit with the results for this six month period?

15

16 A. Yes. Under my direction and supervision an exhibit has been prepared entitled,  
17 "Tampa Electric Company, October 1993 - March 1994, Generating Performance  
18 Incentive Factor Results" consisting of 28 pages that was filed with this testimony  
19 (Have identified as Exhibit GAK-1).

20

21 Q. Have you calculated the results of Tampa Electric Company for its performance  
22 under the GPIF during this period?

23

24 A. Yes I have. This is shown on page 4 of my exhibit. Based upon +2.346 GPIF  
25 points, the result is a reward amount of \$406,404 for the period.

- 1 Q. Please proceed with your review of the actual results for the October 1993 - March  
2 1994 period.  
3
- 4 A. On page 3 of my exhibit, the actual average common equity for the period is shown  
5 on line 8 as \$852,420,095. This produces the maximum penalty or reward figure  
6 of \$1,732,329 as shown on line 15, page 3, and also on page 2 of my exhibit.  
7
- 8 Q. Would you please explain how you arrived at the actual equivalent availability  
9 results for the six units included within the GPIF?  
10
- 11 A. Yes I will. Operating data on each of our operating units is filed monthly with the  
12 Florida Public Service Commission on the Actual Unit Performance data form.  
13 Additionally, outage information is reported to the Commission on a monthly basis.  
14 A summary of this data for the six months provides the basis for the GPIF.  
15
- 16 Q. Are the equivalent availability results shown on page 6, column 2, directly  
17 applicable to the GPIF table?  
18
- 19 A. Not exactly. Adjustments to equivalent availability may be required as noted in  
20 section 4.3.3 of the GPIF Manual. The actual equivalent availability including the  
21 required adjustment is shown on page 6 of my exhibit.  
22
- 23 The necessary adjustments as prescribed in the GPIF Manual are further defined  
24 by a letter dated October 23, 1991, from Mr. J.H. Hoffsis of the Commission's  
25 Staff. The adjustments for each unit are as follows:

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

Gannon Unit No. 5

On this unit, 312 planned outage hours were originally scheduled to fall within the Winter 1993 period. The actual planned outage activities required 178.1 hours. Consequently, the actual equivalent availability of 90.2% is adjusted to 87.3% as shown on page 7 of my exhibit.

Gannon Unit No. 6

On this unit, 336 planned outage hours were originally scheduled to fall within the Winter 1993 period. Due to a cold reheat line failure, planned outage activities were moved forward from late 1994 and were accomplished during this period. Therefore, 1,280.2 planned outage hours fell within the period. Consequently, the actual equivalent availability of 62.7% is adjusted to 81.9% as shown on page 8 of my exhibit.

Big Bend Unit No. 1

On this unit, 168 planned outage hours were originally scheduled. Due to a revision of the outage schedule, this planned outage was deferred and did not occur within the period. Consequently, no planned outage hours fell within the Winter 1993 period and the actual equivalent availability of 85.5% is adjusted to 82.2% as shown on page 9 of my exhibit.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

Big Bend Unit No. 2

On this unit, 1,512 planned outage hours were originally scheduled to fall within the Winter 1993 period. This planned outage was rescheduled to occur after the end of the period and there were no planned outage activities within the period. Consequently, the actual equivalent availability of 92.7% is adjusted to 60.6%, as shown on page 10 of my exhibit.

Big Bend Unit No. 3

On this unit, 312 planned outage hours were originally scheduled. Actual planned outage activities required 283.5 hours. Consequently, the actual equivalent availability of 87.4% is adjusted to 86.8% as shown on page 11 of my exhibit.

Big Bend Unit No. 4

On the unit, 1,176 planned outage hours were originally scheduled to fall within the Winter 1993 period. The outage schedule was revised such that major outage activities were shifted to occur after the end of the period. Planned outage activities within the period were, therefore, reduced and required 223.9 hours. Consequently, the actual equivalent availability of 88.9% is adjusted to 68.5% as shown on page 12 of my exhibit.



1 Q. How did you arrive at the applicable equivalent availability points for each unit?

2

3 A. The final adjusted equivalent availabilities for each unit are shown on page 6,  
4 column 4, of my exhibit. This number is entered into the respective Generating  
5 Performance Incentive Point (GPIP) Table for each particular unit on pages 21  
6 through 26. Page 4 of my exhibit summarizes the equivalent availability points to  
7 be awarded or penalized.

8

9 Q. Would you please explain the heat rate results relative to the GPIP?

10

11 A. The actual heat rate and adjusted actual heat rate for Gannon and Big Bend Station  
12 are shown on page 6 of my exhibit. The adjustment was developed based on the  
13 guidelines of section 4.3.6 of the GPIP Manual. This procedure is further defined  
14 by a letter dated October 23, 1981, from Mr. J.H. Hoffsis of the FPSC Staff. The  
15 final adjusted actual heat rates are also shown on page 5 of my exhibit. This heat  
16 rate number is entered into the respective GPIP table for the particular unit, shown  
17 on pages 21 through 26. Page 4 of my exhibit summarizes the weighted heat rate  
18 and equivalent availability points to be awarded.

19

20 Q. What is the overall GPIP for Tampa Electric Company during this six month  
21 period?

22

23 A. This is shown on page 28 of my exhibit. Essentially, the weighing factors shown  
24 on page 4, column 2, plus the equivalent availability points and the heat rate points  
25 shown on page 4, column 4, are substituted within the equation. This resultant

1 value, +2.345, is then entered into the GPIF table on page 2. Using linear  
2 interpolation, a reward amount of \$406,404 is calculated.

3

4 Q. Does this conclude your testimony?

5

6 A. Yes, it does.

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

TAMPA ELECTRIC COMPANY  
OCTOBER 1993 - MARCH 1994  
GENERATING PERFORMANCE INCENTIVE FACTOR  
RESULTS  
TABLE OF CONTENTS

SCHEDULE

	<u>PAGE</u>
GPIF REWARD / PENALTY TABLE ACTUAL	2
GPIF CALCULATIONS OF MAXIMUM ALLOWED INCENTIVE DOLLARS	3
CALCULATIONS OF SYSTEM ACTUAL GPIF POINTS	4
GPIF UNIT PERFORMANCE SUMMARY, EQUIVALENT AVAILABILITY	5
GPIF UNIT PERFORMANCE SUMMARY, AVERAGE NET OPERATING HEAT RATE	5
GPIF UNIT PERFORMANCE DATA	6
GPIF ( EAF & HEAT RATE ) ADJUSTMENT COMPUTATIONS	7-18
PLANNED OUTAGE SCHEDULE - ACTUAL	19
CRITICAL PATH DIAGRAM	20
GENERATING PERFORMANCE INCENTIVE POINTS TABLES (ACTUAL)	21-26
COMPARISON OF GPIF TARGET VS ACTUAL PERFORMANCE	27
GENERATING PERFORMANCE INCENTIVE POINTS CALCULATIONS	28

TAMPA ELECTRIC COMPANY  
 GENERATING PERFORMANCE INCENTIVE POINTS TABLE  
 REWARD/PENALTY TABLE - ACTUAL  
 OCTOBER 1993 - MARCH 1994

<u>GENERATING PERFORMANCE INCENTIVE POINTS (GPIP)</u>	<u>FUEL SAVINGS/(LOSS) (\$000)</u>	<u>GENERATING PERFORMANCE INCENTIVE FACTOR (\$000)</u>
+10	4,509.7	1,732.3
+ 9	4,328.7	1,559.1
+ 8	3,847.8	1,385.9
+ 7	3,366.8	1,212.6
+ 6	2,885.8	1,039.4
+ 5	2,404.9	866.2
+ 4	1,923.9	692.9
+ 3	1,442.9	519.7
+ 2	961.9	346.5
+ 1	481.0	173.2
0	0.0	0.0
- 1	(784.6)	(173.2)
- 2	(1,569.3)	(346.5)
- 3	(2,353.9)	(519.7)
- 4	(3,138.6)	(692.9)
- 5	(3,923.2)	(866.2)
- 6	(4,707.8)	(1,039.4)
- 7	(5,492.5)	(1,212.6)
- 8	(6,277.1)	(1,385.9)
- 9	(7,061.8)	(1,559.1)
-10	(7,846.4)	(1,732.3)

← GPIP Points  
2,348

REWARD DOLLARS  
\$406,404 →

TAMPA ELECTRIC COMPANY  
 GENERATING PERFORMANCE INCENTIVE FACTOR  
 CALCULATION OF MAXIMUM ALLOWED INCENTIVE DOLLARS  
 ACTUAL  
 OCTOBER 1993 - MARCH 1994

Line 1	Beginning of period balance of common equity End of month common equity:	\$865,665,660
Line 2	Month of   October       1993	\$835,308,373
Line 3	Month of   November      1993	\$841,449,090
Line 4	Month of   December       1993	\$847,570,000
Line 5	Month of   January         1994	\$825,707,762
Line 6	Month of   February        1994	\$872,110,661
Line 7	Month of   March            1994	\$879,129,116
Line 8	(summation of line 1 through 7 divided by 7)	\$852,420,065
Line 9	25 Basis points	0.0025
Line 10	Revenue expansion factor	61.3738%
Line 11	Maximum allowed incentive Dollars (Line 8 times line 9 divided by line 10 times 0.5)	\$1,736,124
Line 12	Jurisdictional Sales	6,398,506 MWH
Line 13	Total Sales	6,412,522 MWH
Line 14	Jurisdictional Separation Factor (Line 12 divided by line 13)	99.78%
Line 15	Maximum Allowed Jurisdictional Incentive Dollars (Line 11 times Line 14)	\$1,732,329

TAMPA ELECTRIC COMPANY  
CALCULATION OF SYSTEM GPIF POINTS  
OCTOBER 1993 - MARCH 1994  
ACTUAL

<u>PLANT/UNIT</u>	<u>6 MO ADJ ACTUAL PERFORMANCE</u>	<u>WEIGHTING FACTOR %</u>	<u>UNIT POINTS</u>	<u>WEIGHTED UNIT POINTS</u>
GANNON 5	87.3 EAF	2.72%	10.000	0.272
GANNON 6	81.9 EAF	5.14%	10.000	0.514
BIG BEND 1	82.2 EAF	6.82%	1.011	0.069
BIG BEND 2	60.6 EAF	5.14%	10.000	0.514
BIG BEND 3	86.8 EAF	12.35%	10.000	1.235
BIG BEND 4	68.5 EAF	11.05%	10.000	1.105
GANNON 5	10384 ANOHR	8.87%	0.000	0.000
GANNON 6	10324 ANOHR	11.59%	-5.263	-0.610
BIG BEND 1	9990 ANOHR	9.83%	-5.000	-0.492
BIG BEND 2	9966 ANOHR	8.81%	-2.966	-0.261
BIG BEND 3	9589 ANOHR	9.95%	0.000	0.000
BIG BEND 4	9974 ANOHR	7.73%	0.000	0.000
		100.00%		2.346

GPIF REWARD:

\$406,404

TAMPA ELECTRIC COMPANY  
GPIF TARGET AND RANGE SUMMARY  
OCTOBER 1993 - MARCH 1994

EQUIVALENT AVAILABILITY

<u>PLANT/UNIT</u>	<u>WEIGHTING FACTOR (%)</u>	<u>EAF TARGET (%)</u>	<u>EAF MAX. (%)</u>	<u>RANGE MIN. (%)</u>	<u>MAX. FUEL SAVINGS (\$000)</u>	<u>MAX. FUEL LOSS (\$000)</u>	<u>EAF ADJUSTED ACTUAL %</u>	<u>ACTUAL FUEL SAVINGS/LOSS (\$000)</u>
GANNON 5	2.72%	80.2	89.0	74.3	131.0	(982.5)	87.3	332.2
GANNON 6	5.14%	77.1	80.4	70.1	247.4	(688.0)	81.9	359.9
BIG BEND 1	6.82%	82.0	85.0	75.9	327.8	(1,283.3)	82.2	32.8
BIG BEND 2	5.14%	57.2	60.6	50.5	247.0	(970.8)	60.6	247.0
BIG BEND 3	12.35%	80.0	82.9	74.1	594.0	(929.4)	86.8	1,392.8
BIG BEND 4	<u>11.05%</u>	64.7	67.7	58.7	<u>531.7</u>	<u>(883.5)</u>	68.5	673.5
GPIF SYSTEM	43.22%				2,078.9	(5,115.8)		

AVERAGE NET OPERATING HEAT RATE  
FOR  
GPIF COAL GENERATING UNITS

<u>PLANT/UNIT</u>	<u>WEIGHTING FACTOR (%)</u>	<u>TARGET ANOHR Btu/kwh</u>	<u>TARGET NOF</u>	<u>ANOHR TARGET RANGE</u>		<u>MAX. FUEL SAVINGS (\$000)</u>	<u>MAX. FUEL LOSS (\$000)</u>	<u>ACTUAL ADJUSTED AHOHR</u>	<u>ACTUAL FUEL SAVINGS/LOSS (\$000)</u>
				<u>MIN.</u>	<u>MAX.</u>				
GANNON 5	8.87%	10416	64.5	10013	10819	426.6	(426.6)	10384	12.8
GANNON 6	11.59%	10129	72.4	9828	10432	557.6	(557.6)	10324	(293.4)
BIG BEND 1	9.83%	9834	91.0	9597	10071	472.7	(472.7)	9990	(236.4)
BIG BEND 2	8.81%	9821	89.0	9510	10132	423.9	(423.9)	9966	(125.8)
BIG BEND 3	9.95%	9536	88.9	9299	9773	478.7	(478.7)	9589	0.0
BIG BEND 4	<u>7.73%</u>	9927	87.0	9700	10154	<u>371.3</u>	<u>(371.3)</u>	9974	0.0
GPIF SYSTEM	56.78%					2,730.8	(2,730.8)		

ACTUAL UNIT PERFORMANCE DATA  
TAMPA ELECTRIC COMPANY  
OCTOBER 1993 - MARCH 1994

<u>PLANT/UNIT</u>	<u>ACTUAL EAF %</u>	<u>ADJUSTMENTS (1) EAF %</u>	<u>EAF ADJUSTED ACTUAL %</u>
GANNON 5	90.2	-2.9	87.3
GANNON 6	62.7	19.2	81.9
BIG BEND 1	85.5	-3.3	82.2
BIG BEND 2	92.7	-32.1	60.6
BIG BEND 3	87.4	-0.6	86.8
BIG BEND 4	88.9	-20.4	68.5

<u>PLANT/UNIT</u>	<u>ACTUAL ANOHR Btu/kwh</u>	<u>ADJUSTMENT (2) TO ANOHR Btu/kwh</u>	<u>ANOHR ADJUSTED ACTUAL Btu/kwh</u>
GANNON 5	10266	118	10384
GANNON 6	10336	-12	10324
BIG BEND 1	10013	-23	9990
BIG BEND 2	9969	-3	9966
BIG BEND 3	9667	-78	9589
BIG BEND 4	9955	19	9974

(1) Documentation of adjustments to Actual EAF on pages 7-12

(2) Documentation of adjustments to Actual ANOHR on pages 13-18



TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO PERFORMANCE  
GANNON UNIT NO. 5  
OCTOBER 1993 - MARCH 1994

WEIGHTING FACTOR = 2.72%

	<u>6 MO. TARGET</u>	<u>6 MO. ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
P.H.	4369.0	4369.0	4369.0
E.A.F.	80.2	90.2	87.3
P.O.H.	312.0	178.1	312.0
F.O.H. + E.F.O.H	426.0	250.1	242.1
M.O.H. + E.M.O.H	130.0	0.0	0.0
P.O.F.	7.1	4.1	7.1
E.F.O.F.	9.8	5.7	5.5
E.M.O.F.	3.0	0.0	0.0

10.000 E. A. POINTS

## ADJUSTMENTS TO EAF:

$$\frac{\text{P.H.} - \text{TGT POH}}{\text{P.H.} - \text{ACT POH}} \times (\text{FOH} + \text{EFOH} + \text{MOH} + \text{EMOH}) = \text{ADJUSTED EUOH}$$

$$\frac{4369.0 - 312.0}{4369.0 - 178.1} \times (49.9 + 200.2 + 0.0 + 0.0) = 0.9680 \times 250.1 = 242.1$$

$$\frac{\text{POH} + \text{EUOH}}{\text{PH}} \times 100\% = \text{POF} + \text{EUOF} = \frac{312.0 + 242.1}{4369.0} = 12.7$$

$$100.0 - (\text{POF} + \text{EUOF}) = \text{EAF} = 100.0 - 12.7 = 87.3$$

PH = PERIOD HOURS  
EAF = EQUIVALENT AVAILABILITY FACTOR  
POH = PLANNED OUTAGE HOURS  
FOH = FORCED OUTAGE HOURS  
MOH = MAINTENANCE OUTAGE HOURS  
EUOH = EQUIVALENT UNPLANNED OUTAGE HOURS  
POF = PLANNED OUTAGE FACTOR  
EFOF = EQUIVALENT FORCED OUTAGE FACTOR  
EMOF = EQUIVALENT MAINTENANCE OUTAGE FACTOR  
EUOF = UNPLANNED OUTAGE FACTOR

**TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO PERFORMANCE  
GANNON UNIT NO. 6  
OCTOBER 1993 - MARCH 1994**

**WEIGHTING FACTOR = 5.14%**

	<u>6 MO. TARGET</u>	<u>6 MO. ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
P.H.	4369.0	4369.0	4369.0
E.A.F.	77.1	62.7	81.9
P.O.H.	336.0	1280.2	336.0
F.O.H. + E.F.O.H	536.0	241.7	315.6
M.O.H. + E.M.O.H	129.0	106.9	139.6
P.O.F.	7.7	29.3	7.7
E.F.O.F.	12.3	5.5	7.2
E.M.O.F.	3.0	2.4	3.2

10.000 E. A. POINTS

**ADJUSTMENTS TO EAF:**

$$\frac{P.H. - TGT\ POH}{P.H. - ACT\ POH} \times (FOH + EFOH + MOH + EMOH) = ADJUSTED\ EUOH$$

$$\frac{4369.0 - 336.0}{4369.0 - 1280.2} \times (93.4 + 148.3 + 106.4 + 0.5) = 1.3057 \times 348.6 = 455.2$$

$$\frac{POH + EUOH}{PH} \times 100\% = POF + EUOF = \frac{336.0 + 455.2}{4369.0} = 18.1$$

$$100.0 - (POF + EUOF) = EAF = 100.0 - 18.1 = 81.9$$

- PH = PERIOD HOURS
- EAF = EQUIVALENT AVAILABILITY FACTOR
- POH = PLANNED OUTAGE HOURS
- FOH = FORCED OUTAGE HOURS
- MOH = MAINTENANCE OUTAGE HOURS
- EUOH = EQUIVALENT UNPLANNED OUTAGE HOURS
- POF = PLANNED OUTAGE FACTOR
- EFOF = EQUIVALENT FORCED OUTAGE FACTOR
- EMOF = EQUIVALENT MAINTENANCE OUTAGE FACTOR
- EUOF = UNPLANNED OUTAGE FACTOR

TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO PERFORMANCE  
BIG BEND UNIT NO. 1  
OCTOBER 1993 - MARCH 1994

WEIGHTING FACTOR = 0.82%

	<u>6 MO. TARGET</u>	<u>6 MO. ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
P.H.	4369.0	4369.0	4369.0
E.A.F.	82.0	85.5	82.2
P.O.H.	168.0	0.0	168.0
F.O.H. + E.F.O.H	441.0	601.4	578.3
M.O.H. + E.M.O.H	181.0	32.0	30.8
P.O.F.	3.8	0.0	3.8
E.F.O.F.	10.1	13.8	13.2
E.M.O.F.	4.1	0.7	0.7

1.011 E. A. POINTS

## ADJUSTMENTS TO EAF:

$$\frac{P.H. - TGT POH}{P.H. - ACT POH} \times (FOH + EFOH + MOH + EMOH) = \text{ADJUSTED EUOH}$$

$$\frac{4369.0 - 168.0}{4369.0 - 0.0} \times (565.9 + 35.5 + 3.0 + 29.0) = 0.9615 \times 633.4 = 609.0$$

$$\frac{POH + EUOH}{PH} \times 100\% = POF + EUOF = \frac{168.0 + 609.0}{4369.0} = 17.8$$

$$100.0 - (POF + EUOF) = \text{EAF} = 100.0 - 17.8 = 82.2$$

PH = PERIOD HOURS  
EAF = EQUIVALENT AVAILABILITY FACTOR  
POH = PLANNED OUTAGE HOURS  
FOH = FORCED OUTAGE HOURS  
MOH = MAINTENANCE OUTAGE HOURS  
EUOH = EQUIVALENT UNPLANNED OUTAGE HOURS  
POF = PLANNED OUTAGE FACTOR  
EFOF = EQUIVALENT FORCED OUTAGE FACTOR  
EMOF = EQUIVALENT MAINTENANCE OUTAGE FACTOR  
EUOF = UNPLANNED OUTAGE FACTOR

TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO PERFORMANCE  
BIG BEND UNIT NO. 2  
OCTOBER 1993 - MARCH 1994

WEIGHTING FACTOR = 5.14%

	<u>6 MO. TARGET</u>	<u>6 MO. ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
P.H.	4369.0	4369.0	4369.0
E.A.F.	57.2	92.7	60.6
P.O.H.	1512.0	0.0	1512.0
F.O.H. + E.F.O.H	280.0	226.8	148.3
M.O.H. + E.M.O.H	77.0	92.2	60.3
P.O.F.	34.6	0.0	34.6
E.F.O.F.	6.4	5.2	3.4
E.M.O.F.	1.8	2.1	1.4

10.000 E. A. POINTS

ADJUSTMENTS TO EAF:

$$\frac{P.H. - TGT\ POH}{P.H. - ACT\ POH} \times (FOH + EFOH + MOH + EMOH) = \text{ADJUSTED EUOH}$$

$$\frac{4369.0 - 1512.0}{4369.0 - 0.0} \times (137.6 + 89.2 + 45.8 + 46.4) = 0.6539 \times 319.0 = 208.6$$

$$\frac{POH + EUOH}{PH} \times 100\% = POF + EUOF = \frac{1512.0 + 208.6}{4369.0} = 39.4$$

$$100.0 - (POF + EUOF) = \text{EAF} = 100.0 - 39.4 = 60.6$$

- PH = PERIOD HOURS
- EAF = EQUIVALENT AVAILABILITY FACTOR
- POH = PLANNED OUTAGE HOURS
- FOH = FORCED OUTAGE HOURS
- MOH = MAINTENANCE OUTAGE HOURS
- EUOH = EQUIVALENT UNPLANNED OUTAGE HOURS
- POF = PLANNED OUTAGE FACTOR
- EFOF = EQUIVALENT FORCED OUTAGE FACTOR
- EMOF = EQUIVALENT MAINTENANCE OUTAGE FACTOR
- EUOF = UNPLANNED OUTAGE FACTOR

TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO PERFORMANCE  
BIG BEND UNIT NO. 3  
OCTOBER 1993 - MARCH 1994

WEIGHTING FACTOR = 12.35%

	<u>6 MO. TARGET</u>	<u>6 MO. ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
P.H.	4369.0	<del>4369.0</del>	4369.0
E.A.F.	80.0	87.4	86.8
P.O.H.	312.0	283.5	312.0
F.O.H. + E.F.O.H	300.0	195.8	194.4
M.O.H. + E.M.O.H	264.0	72.1	71.6
P.O.F.	7.1	6.5	7.1
E.F.O.F.	6.9	4.5	4.4
E.M.O.F.	6.0	1.7	1.6

10.000 E. A. POINTS

ADJUSTMENTS TO EAF:

$$\frac{P.H. - TGT\ POH}{P.H. - ACT\ POH} \times (FOH + EFOH + MOH + EMOH) = ADJUSTED\ EUOH$$

$$\frac{4369.0 - 312.0}{4369.0 - 283.5} \times (151.0 + 44.8 + 14.8 + 57.3) = 0.9930 \times 267.9 = 266.0$$

$$\frac{POH + EUOH}{PH} \times 100\% = POF + EUOF = \frac{312.0 + 266.0}{4369.0} = 13.2$$

$$100.0 - (POF + EUOF) = EAF = 100.0 - 13.2 = 86.8$$

- PH = PERIOD HOURS
- EAF = EQUIVALENT AVAILABILITY FACTOR
- POH = PLANNED OUTAGE HOURS
- FOH = FORCED OUTAGE HOURS
- MOH = MAINTENANCE OUTAGE HOURS
- EUOH = EQUIVALENT UNPLANNED OUTAGE HOURS
- POF = PLANNED OUTAGE FACTOR
- EFOF = EQUIVALENT FORCED OUTAGE FACTOR
- EMOF = EQUIVALENT MAINTENANCE OUTAGE FACTOR
- EUOF = UNPLANNED OUTAGE FACTOR

TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO PERFORMANCE  
BIG BEND UNIT NO. 4  
OCTOBER 1993 - MARCH 1994

WEIGHTING FACTOR = 11.05%

	<u>6 MO. TARGET</u>	<u>6 MO. ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
P.H.	4369.0	4369.0	4369.0
E.A.F.	64.7	88.9	68.5
P.O.H.	1176.0	223.9	1176.0
F.O.H. + E.F.O.H	239.0	100.8	77.6
M.O.H. + E.M.O.H	128.0	159.3	122.7
P.O.F.	26.9	5.1	26.9
E.F.O.F.	5.5	2.3	1.8
E.M.O.F.	2.9	3.6	2.8

10.000 E. A. POINTS

ADJUSTMENTS TO EAF:

$$\frac{P.H. - TGT\ POH}{P.H. - ACT\ POH} \times (FOH + EFOH + MOH + EMOH) = \text{ADJUSTED EUOH}$$

$$\frac{4369.0 - 1176.0}{4369.0 - 223.9} \times (64.6 + 36.2 + 74.4 + 84.9) = 0.7703 \times 260.1 = 200.4$$

$$\frac{POH + EUOH}{PH} \times 100\% = POF + EUOF = \frac{1176.0 + 200.4}{4369.0} = 31.5$$

$$100.0 - (POF + EUOF) = \text{EAF} = 100.0 - 31.5 = 68.5$$

- PH = PERIOD HOURS
- EAF = EQUIVALENT AVAILABILITY FACTOR
- POH = PLANNED OUTAGE HOURS
- FOH = FORCED OUTAGE HOURS
- MOH = MAINTENANCE OUTAGE HOURS
- EUOH = EQUIVALENT UNPLANNED OUTAGE HOURS
- POF = PLANNED OUTAGE FACTOR
- EFOF = EQUIVALENT FORCED OUTAGE FACTOR
- EMOF = EQUIVALENT MAINTENANCE OUTAGE FACTOR
- EUOF = UNPLANNED OUTAGE FACTOR

TAMPA ELECTRIC COMPANY  
 ADJUSTMENTS TO HEAT RATE  
 GANNON 5  
 HEAT RATE DATA  
 OCTOBER 1993 - MARCH 1994

WEIGHTING FACTOR = 8.87%

	<u>6 MO. TARGET</u>	<u>6 MO ACTUAL PERFORMANCE</u>
ANOHR (Btu/kwh)	10416	10266
STA. NET GEN. (GWH)	553.8	445.5
OPER. Btu (10 <sup>9</sup> btu)	5768.512	4573.463
NET OUTPUT FACTOR	64.5	70.9

0.000 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON:

$$\text{CURRENT EQUATION } \text{NOF}(-18.46470) + 11607.3 = \text{ANOHR}$$

$$70.9(-18.46470) + 11607.3 = 10299$$

$$10266 - 10298 = -32$$

$$10416 + -32 = 10384$$

ANOHR = AVERAGE NET OPERATING HEAT RATE  
 NOF = NET OPERATING FACTOR

TAMPA ELECTRIC COMPANY  
 ADJUSTMENTS TO HEAT RATE  
 GANNON 6  
 HEAT RATE DATA  
 OCTOBER 1993 - MARCH 1994

WEIGHTING FACTOR = 11.59%

	<u>6 MO. TARGET</u>	<u>6 MO ACTUAL PERFORMANCE</u>
ANCHR (Btu/kwh)	10129	10335
STA. NET GEN. (GWH)	959.1	475.1
OPER. Btu (10 <sup>9</sup> btu)	9714.772	4910.465
NET OUTPUT FACTOR	72.4	71.6

-5.263 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON:

$$\text{CURRENT EQUATION } \text{NOF}(-15.28630) + 11235.6 = \text{ANOHR}$$

$$71.6(-15.28630) + 11235.6 = 10141$$

$$10335 - 10141 = 195$$

$$10129 + 195 = 10324$$

ANOHR = AVERAGE NET OPERATING HEAT RATE  
 NOF = NET OPERATING FACTOR



TAMPA ELECTRIC COMPANY  
 ADJUSTMENTS TO HEAT RATE  
 BIG BEND UNIT 1  
 HEAT RATE DATA  
 OCTOBER 1993 - MARCH 1994

WEIGHTING FACTOR = 9.83%

	<u>6 MO. TARGET</u>	<u>6 MO ACTUAL PERFORMANCE</u>
ANOHR (Btu/kwh)	9834	10013
STA. NET GEN. (GWH)	1417.0	1342.0
OPER. Btu (10 <sup>9</sup> btu)	13934.520	13436.998
NET OUTPUT FACTOR	91.0	87.2

-5.000 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON:

$$\text{CURRENT EQUATION } \text{NOF}(-6.23790) + 10401.4 = \text{ANOHR}$$

$$87.2(-6.23790) + 10401.4 = 9857$$

$$10013 - 9857 = 156$$

$$9834 + 156 = 9990$$

ANOHR = AVERAGE NET OPERATING HEAT RATE  
 NOF = NET OPERATING FACTOR

TAMPA ELECTRIC COMPANY  
 ADJUSTMENTS TO HEAT RATE  
 BIG BEND UNIT 2  
 HEAT RATE DATA  
 OCTOBER 1993 -- MARCH 1994

WEIGHTING FACTOR = 8.81%

	<u>6 MO. TARGET</u>	<u>6 MO ACTUAL PERFORMANCE</u>
ANOHR (Btu/kwh)	9821	9969
STA NET GEN. (GWH)	963.1	1440.3
OPER. Btu (10 <sup>9</sup> btu)	9458.125	14357.686
NET OUTPUT FACTOR	89.0	84.8

-2.966 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON:

CURRENT EQUATION  $NOF(-0.79520) + 9891.7 = ANOHR$

$84.8(-0.79520) + 9891.7 = 9824$

$9969 - 9824 = 145$

$9821 + 145 = 9966$

ANOHR = AVERAGE NET OPERATING HEAT RATE  
 NOF = NET OPERATING FACTOR

TAMPA ELECTRIC COMPANY  
 ADJUSTMENTS TO HEAT RATE  
 BIG BEND 3  
 HEAT RATE DATA  
 OCTOBER 1993 -- MARCH 1994

WEIGHTING FACTOR = 9.95%

	<u>6 MO. TARGET</u>	<u>6 MO ACTUAL PERFORMANCE</u>
ANCHR (Btu/kwh)	9536	9667
STA. NET GEN. (GWH)	1436.5	1384.8
OPER. Btu (10 <sup>9</sup> btu)	13699.333	13386.502
NET OUTPUT FACTOR	88.9	62.2

0.000 HEAT RATE POINTS

## ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON:

$$\text{CURRENT EQUATION } \text{NOF}(-11.52270) + 10560.7 = \text{ANCHR}$$

$$82.2(-11.52270) + 10560.7 = 9614$$

$$9667 - 9614 = 53$$

$$9536 + 53 = 9589$$

ANCHR = AVERAGE NET OPERATING HEAT RATE  
 NOF = NET OPERATING FACTOR

TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO HEAT RATE  
BIG BEND UNIT #  
HEAT RATE DATA  
OCTOBER 1993 - MARCH 1994

WEIGHTING FACTOR = 7.73%

	<u>6 MO. TARGET</u>	<u>6 MO ACTUAL PERFORMANCE</u>
ANOHR (Btu/kwh)	9927	9955
STA. NET GEN. (GWH)	1156.5	1570.6
OPER. Btu (10 <sup>9</sup> btu)	11481.368	15635.751
NET OUTPUT FACTOR	87.0	68.1

0.000 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON:

$$\text{CURRENT EQUATION } \text{NOF}(-17.47120) + 11447.3 = \text{ANOHR}$$

$$88.1(-17.47120) + 11447.3 = 9908$$

$$9955 - 9908 = 47$$

$$9927 + 47 = 9974$$

ANOHR = AVERAGE NET OPERATING HEAT RATE  
NOF = NET OPERATING FACTOR

## TAMPA ELECTRIC COMPANY

## GPIF PLANNED OUTAGE SCHEDULE - ACTUAL


OCTOBER 1993 - MARCH 1994

<u>STATION/UNIT</u>	<u>ACTUAL OUTAGE DATES</u>	<u>OUTAGE REASON</u>
** GANNON 5	DEC 14 - DEC 22	FUEL SYSTEM CLEAN-UP
* GANNON 6	SEP 14 - NOV 28	REPLACE COLD REHEAT LINE REPLACE BOILER FLOOR REPLACE HOT GAS DUCT & TOGGLE DUCT REPLACE COOLING TOWER HIGH PRESSURE TURBINE INSPECTION INSPECT GOVERNOR VALVES INSPECT FRONT STD.
** BIG BEND 3	NOV 30 - DEC 5	SO3 PROBE INSTALLATION
** BIG BEND 4	FEB 26 - MAR 10	FUEL SYSTEM CLEAN-UP

Milestone or Critical Path Charts of actual schedule are included on page 20.

\* Start / End date outside of GPIF period

\*\* Outage was less than two weeks in duration and a CPM was not included for this unit.



TAMPA ELECTRIC COMPANY  
 GANNON UNIT NO. 6  
 PLANNED DUTAGE 1993  
 ACTUAL CPM  
 11/10/93

TAMPA ELECTRIC COMPANY  
GENERATING PERFORMANCE INCENTIVE POINTS TABLE

OCTOBER 1993 - MARCH 1994

GANNON 5

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS/(LOSS) (\$x1000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS/(LOSS) (\$x1000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	131.0	53.0	+10	426.6	10019
+9	117.9	52.7	+9	383.9	10046
+8	104.6	52.4	+8	341.3	10079
+7	91.7	52.2	+7	298.6	10111
+6	78.6	51.9	+6	256.0	10144
+5	65.5	51.6	+5	213.3	10177
+4	52.4	51.3	+4	170.6	10210
+3	39.3	51.0	+3	128.0	10243
+2	26.2	50.8	+2	85.3	10275
+1	13.1	50.5	+1	42.7	10308
0	0.0	50.2	0	0.0	10341
-1	(36.1)	49.8	-1	(42.7)	10524
-2	(72.1)	49.0	-2	(85.3)	10557
-3	(108.2)	48.4	-3	(128.0)	10589
-4	(144.2)	47.8	-4	(170.6)	10622
-5	(180.3)	47.3	-5	(213.3)	10655
-6	(216.4)	46.7	-6	(256.0)	10688
-7	(252.4)	46.1	-7	(298.6)	10721
-8	(288.5)	45.5	-8	(341.3)	10753
-9	(324.5)	44.9	-9	(383.9)	10786
-10	(360.6)	44.3	-10	(426.6)	10819

← EAF Points 10,000

Adjusted EAF 17.3 →

← ANOHR Points 0,000

Adjusted Actual ANOHR 10284 →

Weighting Factor = 2.72%

Weighting Factor = 8.87%

TAMPA ELECTRIC COMPANY  
GENERATING PERFORMANCE INCENTIVE POINTS TABLE  
OCTOBER 1993 - MARCH 1994  
GANNON 6

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS/(LOSS) (\$1000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS/(LOSS) (\$1000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	247.4	80.4	+10	557.8	9826
+9	222.7	80.1	+9	501.8	9849
+8	187.9	79.7	+8	446.1	9872
+7	173.2	79.4	+7	390.3	9894
+6	148.4	79.1	+6	334.6	9917
+5	123.7	78.8	+5	278.8	9940
+4	99.0	78.4	+4	223.0	9963
+3	74.2	78.1	+3	167.3	9986
+2	49.5	77.8	+2	111.5	10006
+1	24.7	77.4	+1	55.8	10031
0	0.0	77.1	0	0.0	10054
-1	(68.8)	76.4	-1	(55.8)	10129
-2	(137.6)	75.7	-2	(111.5)	10204
-3	(206.4)	75.0	-3	(167.3)	10227
-4	(275.2)	74.3	-4	(223.0)	10250
-5	(344.0)	73.6	-5	(278.8)	10272
-6	(412.8)	72.9	-6	(334.6)	10295
-7	(481.6)	72.2	-7	(390.3)	10318
-8	(550.4)	71.5	-8	(446.1)	10341
-9	(619.2)	70.8	-9	(501.8)	10364
-10	(688.0)	70.1	-10	(557.6)	10386

← EAF P<sub>1</sub> 10,000

Adjusted EAF 81.9 →

← AHR Points -5.263

Adjusted Actual ANOHR 10324 →

Weighting Factor = 5.14%

Weighting Factor = 11.59%



TAMPA ELECTRIC COMPANY  
GENERATING PERFORMANCE INCENTIVE POINTS TABLE

OCTOBER 1993 - MARCH 1994

BIG BEND 1

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS/(LOSS) (\$x1000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS/(LOSS) (\$x1000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	387.8	85.0	+10	472.7	9597
+9	295.0	84.7	+9	425.4	9613
+8	262.2	84.4	+8	378.2	9629
+7	229.5	84.1	+7	330.9	9646
+6	196.7	83.8	+6	283.6	9662
+5	163.9	83.5	+5	236.4	9678
+4	131.1	83.2	+4	189.1	9694
+3	98.3	82.9	+3	141.8	9710
+2	65.6	82.6	+2	94.5	9727
+1	32.8	82.3	+1	47.3	9743
0	0.0	82.0	0	0.0	9759
-1	(128.3)	81.4	-1	(47.3)	9834
-2	(256.7)	80.8	-2	(94.5)	9909
-3	(385.0)	80.2	-3	(141.8)	9925
-4	(513.3)	79.6	-4	(189.1)	9941
-5	(641.7)	79.0	-5	(236.4)	9956
-6	(770.0)	78.3	-6	(283.6)	9974
-7	(898.3)	77.7	-7	(330.9)	9990
-8	(1,026.6)	77.1	-8	(378.2)	10006
-9	(1,155.0)	76.5	-9	(425.4)	10022
-10	(1,283.3)	75.9	-10	(472.7)	10039
					10055
					10071

← EAF Points 1.011

Adjusted EAF 82.3 →

← AHR Points -5.000

Adjusted Actual ANOHR 9990 →

Weighting Factor = 6.62%

Weighting Factor = 2.83%

TAMPA ELECTRIC COMPANY  
GENERATING PERFORMANCE INCENTIVE POINTS TABLE  
OCTOBER 1993 - MARCH 1994  
BIG BEND 2

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS/(LOSS) (\$x1000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS/(LOSS) (\$x1000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	247.0	50.8	+10	423.0	9510
+9	222.3	90.3	+9	381.5	9534
+8	197.6	59.9	+8	339.1	9557
+7	172.9	59.6	+7	296.7	9581
+6	148.2	59.2	+6	254.3	9604
+5	123.5	58.9	+5	212.0	9628
+4	98.8	58.6	+4	169.6	9652
+3	74.1	58.2	+3	127.2	9675
+2	49.4	57.9	+2	84.8	9699
+1	24.7	57.5	+1	42.4	9722
0	0.0	57.2	0	0.0	9746
-1	(97.1)	56.5	-1	(42.4)	9821
-2	(194.2)	55.9	-2	(84.8)	9896
-3	(291.4)	55.2	-3	(127.2)	9920
-4	(388.3)	54.5	-4	(169.6)	9943
-5	(485.4)	53.9	-5	(212.0)	9967
-6	(582.5)	53.2	-6	(254.3)	9990
-7	(679.6)	52.5	-7	(296.7)	10014
-8	(776.6)	51.8	-8	(339.1)	10038
-9	(873.7)	51.2	-9	(381.5)	10061
-10	(970.8)	50.5	-10	(423.9)	10085

← EAF Points 10/100

Adjusted EAF 50.8 →

← AHR Points -2.000

Adjusted Actual ANOHR 9.000 →

Weighting Factor = 5.14%

Weighting Factor = 8.81%

TAMPA ELECTRIC COMPANY  
GENERATING PERFORMANCE INCENTIVE POINTS TABLE

OCTOBER 1993 - MARCH 1994

BIG BEND 3

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS/(LOSS) (\$x1000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS/(LOSS) (\$x1000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	544.0	82.9	+10	478.7	9299
+9	534.8	82.8	+9	430.8	9315
+8	475.2	82.3	+8	383.0	9331
+7	415.6	82.0	+7	335.1	9348
+6	356.4	81.7	+6	287.2	9364
+5	297.0	81.5	+5	239.4	9380
+4	237.6	81.2	+4	191.5	9396
+3	178.2	80.9	+3	143.6	9412
+2	118.8	80.6	+2	95.7	9429
+1	59.4	80.3	+1	47.9	9445
0	0.0	80.0	0	0.0	9461
-1	(92.9)	79.4	-1	(47.9)	9477
-2	(185.9)	78.8	-2	(95.7)	9493
-3	(278.8)	78.2	-3	(143.6)	9509
-4	(371.8)	77.6	-4	(191.5)	9525
-5	(464.7)	77.1	-5	(239.4)	9541
-6	(557.6)	76.5	-6	(287.2)	9557
-7	(650.6)	75.9	-7	(335.1)	9573
-8	(743.5)	75.3	-8	(383.0)	9589
-9	(836.5)	74.7	-9	(430.8)	9605
-10	(929.4)	74.1	-10	(478.7)	9621

Points  
19.670

Adjusted  
EAI  
88.8

AHR  
Points  
0.000

Adjusted  
Actual  
AHOHR  
9589

Weighting Factor = 12.35%

Weighting Factor = 9.95%

TAMPA ELECTRIC COMPANY  
GENERATING PERFORMANCE INCENTIVE POINTS TABLE

OCTOBER 1993 - MARCH 1994

BIG BEND 4

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS/(LOSS) (\$x1000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS/(LOSS) (\$x1000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	531.7	87.7	+10	371.3	9700
+9	478.5	87.4	+9	334.2	9715
+8	425.4	87.1	+8	297.0	9730
+7	372.2	86.8	+7	259.9	9746
+6	319.0	86.5	+6	222.8	9761
+5	265.9	86.2	+5	185.7	9776
+4	212.7	85.9	+4	148.5	9791
+3	159.5	85.6	+3	111.4	9806
+2	106.3	85.3	+2	74.3	9822
+1	53.2	85.0	+1	37.1	9837
0	0.0	84.7	0	0.0	9852
-1	(88.4)	84.1	-1	(37.1)	9927
-2	(176.7)	83.5	-2	(74.3)	10002
-3	(265.1)	82.9	-3	(111.4)	10017
-4	(353.4)	82.3	-4	(148.5)	10032
-5	(441.8)	81.7	-5	(185.7)	10048
-6	(530.1)	81.1	-6	(222.8)	10063
-7	(618.4)	80.5	-7	(259.9)	10078
-8	(706.8)	79.9	-8	(297.0)	10093
-9	(795.2)	79.3	-9	(334.2)	10108
-10	(883.5)	78.7	-10	(371.3)	10124

EAP Points 10,000

Adjusted EAP 87.5

AHR Points 0,000

Adjusted Actual ANOHR 9974

Weighting Factor = 11.05%

Weighting Factor = 7.73%

TAMPA ELECTRIC COMPANY  
COMPARISON OF GPIF TARGETS VS. ACTUAL PERFORMANCE

AVAILABILITY

<u>PLANT/UNIT</u>	<u>TARGET WEIGHTING FACTOR</u>	<u>NORMALIZED WEIGHTING FACTOR</u>	<u>TARGET PERIOD OCT 93 - MAR 94</u>			<u>ACTUAL PERFORMANCE OCT 93 - MAR 94</u>		
			<u>POF</u>	<u>EUOF</u>	<u>EUOR</u>	<u>POF</u>	<u>EUOF</u>	<u>EUOR</u>
BIG BEND1	6.82%	15.8	3.8	14.2	14.8	0.0	14.5	14.5
BIG BEND2	5.14%	11.9	34.6	8.2	12.5	0.0	7.3	7.3
BIG BEND3	12.35%	28.6	7.1	12.9	13.9	6.5	6.1	6.6
BIG BEND 4	11.05%	25.6	26.9	8.4	11.5	5.1	6.0	6.3
GANNON 5	2.72%	6.3	7.1	12.8	13.7	4.1	5.7	8.9
GANNON 6	<u>5.14%</u>	<u>11.9</u>	<u>7.7</u>	<u>15.3</u>	<u>18.5</u>	<u>29.3</u>	<u>6.0</u>	<u>17.2</u>
GPIF SYSTEM WGT'D AVG.	43.22%	100.0	15.0	11.7	13.6	6.9	7.7	9.2
GPIF SYSTEM WEIGHTED EQUIVALENT AVAILABILITY				<u>73.3</u>			<u>65.4</u>	
			<u>5 PERIOD AVERAGE POF</u>	<u>EUOF</u>	<u>EUOR</u>	<u>5 PERIOD AVERAGE POF</u>	<u>EUOF</u>	<u>EUOR</u>
			7.6	11.5	12.8		80.9	

AVERAGE NET OPERATING HEAT RATE (Btu/kwh)

<u>PLANT/UNIT</u>	<u>TARGET WEIGHTING FACTOR</u>	<u>NORMALIZED WEIGHTING FACTOR</u>	<u>HEAT RATE TARGET</u>	<u>ADJUSTED ACTUAL HEAT RATE OCT 93 - MAR 94</u>
GANNON 5	8.87%	15.6	10416	10384
GANNON 6	11.59%	20.4	10129	10324
BIG BEND 1	9.83%	17.3	9834	9990
BIG BEND 2	8.81%	15.5	9821	9966
BIG BEND 3	9.95%	17.6	9536	9589
BIG BEND 4	<u>7.73%</u>	<u>13.6</u>	<u>9927</u>	<u>9974</u>
	56.78%	100.0		
GPIF SYSTEM WEIGHTED AVERAGE H.R. (Btu/kwh)			9947	10047

TAMPA ELECTRIC COMPANY  
GENERATING PERFORMANCE INCENTIVE POINTS CALCULATION  
OCTOBER 1993 - MARCH 1994

Points are calculated according to the formula:

$$GPIP = \sum_{i=1}^n [ (a_i) (EAP_i) + (e_i) (AHRP_i) ]$$

Where:

$$i = 1, n$$

a = Unit equivalent availability weighting factor

EAP = Unit equivalent availability points

e = Station average heat rate weighting factor

AHRP = Station average heat rate points

Weighting factors and point values are listed in separate tables.

$$\begin{aligned} GPIP = & 2.72\% (GN5 EAP) + 5.14\% (GN6 EAP) + 6.82\% (BB1 EAP) \\ & + 5.14\% (BB2 EAP) + 12.35\% (BB3 EAP) + 11.05\% (BB4 EAP) \\ & + 8.87\% (GN5 AHRP) + 11.59\% (GN6 AHRP) + 9.83\% (BB1 AHRP) \\ & + 8.81\% (BB2 AHRP) + 9.95\% (BB3 AHRP) + 7.73\% (BB4 AHRP) \end{aligned}$$

$$\begin{aligned} GPIP = & 2.72\% (10.000) + 5.14\% (10.000) + 6.82\% (1.011) \\ & + 5.14\% (10.000) + 12.35\% (10.000) + 11.05\% (10.000) \\ & + 8.87\% (0.000) + 11.59\% (-5.263) + 9.83\% (-5.000) \\ & + 8.81\% (-2.966) + 9.95\% (0.000) + 7.73\% (0.000) \end{aligned}$$

$$\begin{aligned} GPIP = & (0.272) + (0.514) + (0.069) + (0.514) + (1.235) \\ & + (1.105) + (0.000) + (-0.510) + (-0.492) + (-0.261) \\ & + (0.000) + (0.000) \end{aligned}$$

$$GPIP = 2.346 \text{ POINTS}$$

REWARD/PENALTY dollar amounts of the Generating Performance Incentive Factor (GPIF) are determined directly from the table for the corresponding Generating Performance Points (GPIP) - see page 2.

$$GPIP = \underline{\$406,404}$$