

# MACFARLANE AUSLEY FERGUSON & McMULLEN

ATTORNEYS AND COUNSELORS AT LAW

111 MADISON STREET, SUITE 2300  
P.O. BOX 1531 (ZIP 33601)  
TAMPA, FLORIDA 33602  
(813) 273-4200 FAX (813) 273-4396

227 SOUTH CALHOUN STREET  
P.O. BOX 391 (ZIP 32302)  
TALLAHASSEE, FLORIDA 32301  
(904) 224-9115 FAX (904) 222-7560

400 CLEVELAND STREET  
P.O. BOX 1869 (ZIP 34617)  
CLEARWATER, FLORIDA 34615  
(813) 441-8986 FAX (813) 442-8470

IN REPLY REFER TO:

November 14, 1994

HAND DELIVERED

Tallahassee

Ms. Blanca S. Bayo, Director  
Division of Records and Reporting  
Florida Public Service Commission  
101 East Gaines Street  
Tallahassee, Florida 32309-0850

Re: Fuel and Purchased Power Cost Recovery Clause  
with Generating Performance Incentive Factor;  
FPSC Docket No. 940001-EI

Dear Ms. Bayo:

Enclosed for filing in the above docket on behalf of Tampa  
Electric Company are fifteen (15) copies of each of the following:

11514-941.

Prepared Direct Testimony of Mary Jo Pennino and Exhibit  
(MJP-1) entitled Fuel Cost Recovery and Capacity Cost  
Recovery Final True-Ups, April 1994-September 1994.

11515-942.

Prepared Direct Testimony of George A. Keselowsky and  
Exhibit (GAK-1) entitled April 1994-September 1994  
Generating Performance Incentive Factor Results.

11516-943.

Exhibit (RFT/EAT-1) entitled Oil Backout Cost Recovery,  
Actual, April 1994-September 1994. *R. J. Gomez / E. A. Thomas*

Please acknowledge receipt and filing of the above by stamping  
the duplicate copy of this letter and returning same to this  
writer.

Thank you for your assistance in connection with this matter.

Sincerely,

*James D. Beasley*  
James D. Beasley

RECEIVED & FILED

*mas*  
BUREAU OF RECORDS

JDB/pp  
Enclosures

cc: All Parties of Record (w/enc.)

ACK

AFA

APP \_\_\_\_\_

CAF \_\_\_\_\_

CMU \_\_\_\_\_

CTR \_\_\_\_\_

EAG *Outlets*

LEG *Brewer*

LIN *Orizy*

PC \_\_\_\_\_

RCH \_\_\_\_\_

SEC *1*

WAS \_\_\_\_\_

OTH \_\_\_\_\_

CERTIFICATE OF SERVICE

I HEREBY CERTIFY that a true copy of the foregoing testimony and exhibits, filed on behalf of Tampa Electric Company, has been furnished by U. S. Mail on this 14<sup>th</sup> day of November, 1994 to the following:

Ms. Martha C. Brown\*  
Ms. Donna L. Canzano  
Division of Legal Services  
Florida Public Service  
Commission  
101 East Gaines Street  
Tallahassee, FL 32399-0863

Mr. James A. McGee  
Senior Counsel  
Florida Power Corporation  
Post Office Box 14042  
St. Petersburg, FL 33733

Mr. Joseph A. McGlothlin  
Ms. Vicki Gordon Kaufman  
McWhirter, Reeves, McGlothlin,  
Davidson & Bakas  
315 S. Calhoun St., Suite 716  
Tallahassee, FL 32301

Mr. Jack Shreve  
Office of Public Counsel  
Room 812  
111 West Madison Street  
Tallahassee, FL 32399-1400

Mr. Matthew M. Childs  
Steel Hector & Davis  
Suite 601  
215 South Monroe Street  
Tallahassee, FL 32301

Mr. John W. McWhirter  
McWhirter, Reeves, McGlothlin,  
Davidson & Bakas  
Post Office Box 3350  
Tampa, FL 33601


Ms. Suzanne Brownless  
Suzanne Brownless P.A.  
1546 Blairstone Pines Drive  
Tallahassee, FL 32301

Mr. Floyd R. Self  
Messer, Vickers, Caparello,  
Madsen, Lewis, Goldman & Metz  
Post Office Box 1876  
Tallahassee, FL 32301-1876

Mr. G. Edison Holland, Jr.  
Beggs & Lane  
Post Office Box 12950  
Pensacola, FL 32576

Mr. Eugene M. Trisko  
Post Office Box 596  
Berkeley Springs, WV 25411

Mr. H. G. Wells  
Energy Consultant  
276 Spring Run Circle  
Longwood, FL 32779

  
ATTORNEY

DOCKET NO. 940001-EI  
TAMPA ELECTRIC COMPANY  
SUBMITTED FOR FILING 11/14/94  
(TRUE UP)

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION  
PREPARED DIRECT TESTIMONY  
OF  
GEORGE A. KESELOWSKY

Q. Will you please state your name, business address, and employer?

A. My name is George A. Keselowsky and my business address is Post Office Box 111, Tampa, Florida 33601. I am employed by Tampa Electric Company.

Q. Please furnish us with a brief outline of your educational background and business experience.

A. I graduated in 1972 from the University of South Florida with a Bachelor of Science Degree in Mechanical Engineering. I have been employed by Tampa Electric Company in various engineering positions since that time. My current position is that of Senior Consulting Engineer - Production Engineering.

1 Q. What are your current responsibilities?

2  
3 A. I am responsible for testing and reporting unit performance, and the compilation  
4 and reporting of generation statistics.

5  
6 Q. What is the purpose of your testimony?

7  
8 A. My testimony presents the actual performance results from unit equivalent  
9 availability and station heat rate used to determine the Generating Performance  
10 Incentive Factor (GPIF) for the period April 1994 through September 1994. I will  
11 also compare these results to the targets established prior to the beginning of the  
12 period.

13  
14 Q. Have you prepared an exhibit with the results for this six month period?

15  
16 A. Yes. Under my direction and supervision an exhibit has been prepared entitled,  
17 "Tampa Electric Company, April 1994 - September 1994, Generating Performance  
18 Incentive Factor Results" consisting of 28 pages that was filed with this testimony  
19 (Have identified as Exhibit GAK-1).

20  
21 Q. Have you calculated the results of Tampa Electric Company for its performance  
22 under the GPIF during this period?

23  
24 A. Yes I have. This is shown on page 4 of my exhibit. Based upon +0.788 GPIF  
25 points, the result is a reward amount of \$146,321 for the period.

1 Q. Please proceed with your review of the actual results for the April 1994 -  
2 September 1994 period.

3  
4 A. On page 3 of my exhibit, the actual average common equity for the period is shown  
5 on line 8 as \$918,569,094. This produces the maximum penalty or reward figure  
6 of \$1,856,865 as shown on line 15, page 3, and also on page 2 of my exhibit.

7  
8 Q. Would you please explain how you arrived at the actual equivalent availability  
9 results for the six units included within the GPIF?

10  
11 A. Yes I will. Operating data on each of our operating units is filed monthly with the  
12 Florida Public Service Commission on the Actual Unit Performance data form.  
13 Additionally, outage information is reported to the Commission on a monthly basis.  
14 A summary of this data for the six months provides the basis for the GPIF.

15  
16 Q. Are the equivalent availability results shown on page 6, column 2, directly  
17 applicable to the GPIF table?

18  
19 A. Not exactly. Adjustments to equivalent availability may be required as noted in  
20 section 4.3.3 of the GPIF Manual. The actual equivalent availability including the  
21 required adjustment is shown on page 6 of my exhibit.

22  
23 The necessary adjustments as prescribed in the GPIF Manual are further defined  
24 by a letter dated October 23, 1981, from Mr. J.H. Hoff<sup>sis</sup> of the Commission's  
25 Staff. The adjustments for each unit are as follows:

1           Gannon Unit No. 5  
2

3           On this unit, 192 planned outage hours were originally scheduled to fall within the  
4           Summer 1994 period. The actual planned outage activities required 120.6 hours.  
5           Consequently, the actual equivalent availability of 85.4% is adjusted to 83.9% as  
6           shown on page 7 of my exhibit.  
7

8           Gannon Unit No. 6  
9

10           This unit was not scheduled to have a planned outage during the Summer 1994  
11           period, and did not in fact have one. Consequently, the actual equivalent  
12           availability of 90.7% requires no adjustment, as shown on page 8 of my exhibit.  
13

14           Big Bend Unit No. 1  
15

16           On this unit, 1,344 planned outage hours were originally scheduled to fall within  
17           the Summer 1994 period. The actual planned outage activities required 1,342.6  
18           hours. Since the actual hours were nearly identical to the planned hours, the  
19           adjustment process produced a change only beyond the first decimal point.  
20           Consequently, the actual equivalent availability of 59.1% remains 59.1% after  
21           adjustment as shown on page 9 of my exhibit.  
22  
23  
24  
25

1        Big Bend Unit No. 2

2  
3        This unit was not scheduled to have a planned outage during the Summer 1994  
4        period, and did not in fact have one. Consequently, the actual equivalent  
5        availability of 79.2% requires no adjustment as shown on page 10 of my exhibit.  
6

7        Big Bend Unit No. 3

8  
9        This unit was not scheduled to have a planned outage during the Summer 1994  
10       period, and did not in fact have one. Consequently, the actual equivalent  
11       availability of 90.9% requires no adjustment as shown on page 11 of my exhibit.  
12

13       Big Bend Unit No. 4

14  
15       This unit was not scheduled to have a planned outage the Summer 1994 period, and  
16       did not in fact have one. Consequently, the actual equivalent availability of 92.6%  
17       requires no adjustment as shown on page 12 of my exhibit.  
18

19      Q.    How did you arrive at the applicable equivalent availability points for each unit?  
20

21      A.    The final adjusted equivalent availabilities for each unit are shown on page 6,  
22        column 4, of my exhibit. This number is entered into the respective Generating  
23        Performance Incentive Point (GPIP) Table for each particular unit on pages 21  
24        through 26. Page 4 of my exhibit summarizes the equivalent availability points to  
25        be awarded or penalized.

1 Q. Would you please explain the heat rate results relative to the GPIF?  
2

3 A. The actual heat rate and adjusted actual heat rate for Gannon and Big Bend Station  
4 are shown on page 6 of my exhibit. The adjustment was developed based on the  
5 guidelines of section 4.3.6 of the GPIF Manual. This procedure is further defined  
6 by a letter dated October 23, 1981, from Mr. J.H. Hoffsis of the FPSC Staff. The  
7 final adjusted actual heat rates are also shown on page 5 of my exhibit. This heat  
8 rate number is entered into the respective GPIF table for the particular unit, shown  
9 on pages 21 through 26. Page 4 of my exhibit summarizes the weighted heat rate  
10 and equivalent availability points to be awarded.  
11

12 Q. What is the overall GPIF for Tampa Electric Company during this six month  
13 period?  
14

15 A. This is shown on page 28 of my exhibit. Essentially, the weighing factors shown  
16 on page 4, column 3, plus the equivalent availability points and the heat rate points  
17 shown on page 4, column 4, are substituted within the equation. This resultant  
18 value, +0.788, is then entered into the GPIF table on page 2. Using linear  
19 interpolation, a reward amount of \$146,321 is calculated.  
20

21 Q. Does this conclude your testimony?  
22

23 A. Yes, it does.  
24  
25



TAMPA ELECTRIC COMPANY  
APRIL 1994 - SEPTEMBER 1994  
GENERATING PERFORMANCE INCENTIVE FACTOR  
RESULTS  
TABLE OF CONTENTS

SCHEDULE

	<u>PAGE</u>
GPIF REWARD / PENALTY TABLE ACTUAL	
GPIF CALCULATIONS OF MAXIMUM ALLOWED INCENTIVE DOLLARS	2
CALCULATIONS OF SYSTEM ACTUAL GPIF POINTS	3
GPIF UNIT PERFORMANCE SUMMARY, EQUIVALENT AVAILABILITY	4
GPIF UNIT PERFORMANCE SUMMARY, AVERAGE NET OPERATING HEAT RATE	5
GPIF UNIT PERFORMANCE DATA	5
GPIF ( EAF & HEAT RATE ) ADJUSTMENT COMPUTATIONS	6
PLANNED OUTAGE SCHEDULE - ACTUAL	7-18
CRITICAL PATH DIAGRAM	19
GENERATING PERFORMANCE INCENTIVE POINTS TABLES (ACTUAL)	20
COMPARISON OF GPIF TARGET VS ACTUAL PERFORMANCE	21-26
GENERATING PERFORMANCE INCENTIVE POINTS CALCULATIONS	27
	28

**TAMPA ELECTRIC COMPANY  
 GENERATING PERFORMANCE INCENTIVE POINTS TABLE  
 REWARD/PENALTY TABLE  
 APRIL 1994 - SEPTEMBER 1994**

<b>GENERATING PERFORMANCE INCENTIVE POINTS (OPIP)</b>	<b>FUEL SAVINGS/(LOSS) (\$000)</b>	<b>GENERATING PERFORMANCE INCENTIVE FACTOR (\$000)</b>
+10	6,536.2	1,856.9
+9	5,882.6	1,671.2
+8	5,229.0	1,485.5
+7	4,575.3	1,299.8
+6	3,921.7	1,114.1
+5	3,268.1	928.4
+4	2,614.5	742.7
+3	1,960.9	557.1
+2	1,307.2	371.4
+1	653.6	185.7
0	0.0	0.0
-1	(930.6)	(185.7)
-2	(1,861.2)	(371.4)
-3	(2,791.8)	(557.1)
-4	(3,722.4)	(742.7)
-5	(4,653.0)	(928.4)
-6	(5,583.5)	(1,114.1)
-7	(6,514.1)	(1,299.8)
-8	(7,444.7)	(1,485.5)
-9	(8,375.3)	(1,671.2)
-10	(9,305.9)	(1,856.9)

← **OPIP  
Points  
0.785** →

← **REWARD  
DOLLARS  
\$146,321** →

**TAMPA ELECTRIC COMPANY  
 GENERATING PERFORMANCE INCENTIVE FACTOR  
 CALCULATION OF MAXIMUM ALLOWED INCENTIVE DOLLARS**

**APRIL 1994 - SEPTEMBER 1994**

Line 1	Beginning of period balance of common equity End of month common equity:	\$879,129,116
Line 2	Month of April 1994	\$866,964,388
Line 3	Month of May 1994	\$917,715,189
Line 4	Month of June 1994	\$929,771,637
Line 5	Month of July 1994	\$917,508,178
Line 6	Month of August 1994	\$952,433,388
Line 7	Month of September 1994	\$966,461,765
Line 8	(summation of line 1 through 7 divided by 7)	\$918,569,094
Line 9	25 Basis points	0.0025
Line 10	Revenue expansion factor	61.3738%
Line 11	Maximum allowed incentive Dollars (Line 8 times 9 divided by line 10 times 0.5)	\$1,870,849
Line 12	Jurisdictional Sales	7,449,689 MWH
Line 13	Total Sales	7,505,793 MWH
Line 14	Jurisdictional Separation Factor (Line 12 divided by line 13)	99.25%
Line 15	Maximum Allowed Jurisdictional Incentive Dollars (Line 11 times Line 14)	\$1,856,865

TAMPA ELECTRIC COMPANY  
 CALCULATION OF SYSTEM GPIF POINTS  
 APRIL 1994 - SEPTEMBER 1994  
 ACTUAL

<u>PLANT/UNIT</u>	<u>6 MO ADJ ACTUAL PERFORMANCE</u>	<u>WEIGHTING FACTOR %</u>	<u>UNIT POINTS</u>	<u>WEIGHTED UNIT POINTS</u>
GANNON 5	83.9 EAF	2.31%	4.444	0.103
GANNON 6	90.7 EAF	8.58%	10.000	0.858
BIG BEND 1	59.1 EAF	8.91%	1.217	0.108
BIG BEND 2	79.2 EAF	8.77%	-10.000	-0.877
BIG BEND 3	90.9 EAF	12.42%	10.000	1.242
BIG BEND 4	82.6 EAF	8.59%	10.000	0.859
GANNON 5	10495 ANOHR	5.47%	-0.446	-0.024
GANNON 6	10088 ANOHR	9.60%	-4.239	-0.418
BIG BEND 1	9088 ANOHR	7.38%	0.000	0.000
BIG BEND 2	10214 ANOHR	9.60%	-2.941	-0.285
BIG BEND 3	9830 ANOHR	9.13%	-8.524	-0.778
BIG BEND 4	10173 ANOHR	6.89%	0.000	0.000
		<u>100.00%</u>	<u>0.000</u>	<u>0.000</u>
				0.788

GPIF REWARD: \$146,321

TAMPA ELECTRIC COMPANY  
 GPIF TARGET AND RANGE SUMMARY  
 APRIL 1994 - SEPTEMBER 1994

EQUIVALENT AVAILABILITY

<u>PLANT/UNIT</u>	<u>WEIGHTING FACTOR (%)</u>	<u>RAP TARGET (%)</u>	<u>RAP MAX. (%)</u>	<u>RANG RANG MIN. (%)</u>	<u>MAX. FUEL SAVINGS (\$000)</u>	<u>MAX. FUEL LOSS (\$000)</u>	<u>RAP ADJUSTED ACTUAL \$</u>	<u>ACTUAL FUEL SAVINGS/LOSS (\$000)</u>
OANNON 5	2.31%	82.7	85.5	77.1	190.9	(424.9)	83.9	87.1
OANNON 6	8.58%	83.1	84.5	76.3	540.8	(843.3)	90.7	540.8
BIG BEND 1	8.91%	58.6	62.3	51.2	582.3	(1,165.1)	59.1	70.9
BIG BEND 2	8.77%	87.6	90.1	82.6	573.0	(926.3)	79.2	(926.3)
BIG BEND 3	12.42%	83.5	84.8	74.9	811.8	(1,501.8)	90.9	811.8
BIG BEND 4	<u>1.99%</u>	88.1	90.5	83.3	<u>541.2</u>	<u>(1,149.2)</u>	92.6	541.2
OPIF SYSTEM	49.58%				<u>3,240.1</u>	<u>(6,009.8)</u>		

AVERAGE NET OPERATING HEAT RATE  
 FOR  
GPIF COAL GENERATING UNITS

<u>PLANT/UNIT</u>	<u>WEIGHTING FACTOR (%)</u>	<u>ARORR Plant</u>	<u>TARGET NOP</u>	<u>ARORR TARGET RANG MIN. MAX.</u>	<u>MAX. FUEL SAVINGS (\$000)</u>	<u>MAX. FUEL LOSS (\$000)</u>	<u>ACTUAL ADJUSTED ARORR</u>	<u>ACTUAL FUEL SAVINGS/LOSS (\$000)</u>
OANNON 5	5.47%	10408	69.9	10064 10752	357.3	(357.3)	10495	0.0
OANNON 6	9.88%	10454	65.9	10051 10857	644.3	(644.3)	10468	(273.1)
BIG BEND 1	7.38%	10062	90.2	9720 10404	482.1	(482.1)	9988	0.0
BIG BEND 2	9.69%	10069	87.5	9756 10382	633.1	(633.1)	10214	(186.2)
BIG BEND 3	9.13%	9876	87.7	9391 9961	597.0	(597.0)	9930	(308.9)
BIG BEND 4	<u>1.07%</u>	10114	87.8	9845 10383	<u>582.3</u>	<u>(582.3)</u>	10173	0.0
OPIF SYSTEM	50.42%				<u>3,296.1</u>	<u>(3,296.1)</u>		

ACTUAL UNIT PERFORMANCE DATA  
TAMPA ELECTRIC COMPANY  
APRIL 1994 - SEPTEMBER 1994

<u>PLANT/UNIT</u>	<u>ACTUAL EAF %</u>	<u>ADJUSTMENTS (1) EAF %</u>	<u>EAF ADJUSTED ACTUAL %</u>
GANNON 5	85.4		
GANNON 6	90.7	-1.5	83.9
BIG BEND 1	59.1	0.0	90.7
BIG BEND 2	79.2	0.0	59.1
BIG BEND 3	90.9	0.0	79.2
BIG BEND 4	92.6	0.0	90.9
		0.0	92.6

<u>PLANT/UNIT</u>	<u>ACTUAL ANOHR Btu/kwh</u>	<u>ADJUSTMENT (2) TO ANOHR Btu/kwh</u>	<u>ANOHR ADJUSTED ACTUAL Btu/kwh</u>
GANNON 5	10413		
GANNON 6	10510	82	10495
BIG BEND 1	10059	158	10668
BIG BEND 2	10241	-71	9988
BIG BEND 3	9942	-27	10214
BIG BEND 4	10161	-12	9930
		12	10173

(1) Documentation of adjustments to Actual EAF on pages 7-12

(2) Documentation of adjustmentst to Actual ANOHR on pages 13-18

TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO PERFORMANCE  
GANNON UNIT NO. 5  
APRIL 1994 - SEPTEMBER 1994

WEIGHTING FACTOR = 2.31%

	<u>6 MO. TARGET</u>	<u>6 MO. ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
P.H.	4391.0	4391.0	4391.0
E.A.F.	82.7	85.4	83.9
P.O.H.	192.0	120.6	192.0
F.O.H. + E.F.O.H.	462.0	489.8	481.6
M.O.H. + E.M.O.H.	105.0	31.9	31.4
P.O.F.	4.4	2.7	4.4
E.F.O.F.	10.5	11.2	11.0
E.M.O.F.	2.4	0.7	0.7

ADJUSTMENTS TO EAF:

4.444 E. A. POINTS

$$\frac{P.H. - TGT POH}{P.H. - ACT POH} \times (FOH + EFOH + MOH + EMOH) = \text{ADJUSTED EUOH}$$

$$\frac{4391.0 - 192.0}{4391.0 - 120.6} \times (238.7 + 251.1 + 0.0 + 31.9) = 0.9833 \times 521.7 = 513.0$$

$$\frac{POH + EUOH}{PH} \times 100\% = POF + EUOF = \frac{192.0 + 513.0}{4391.0} = 16.1$$

$$100.0 - (POF + EUOF) = EAF = 100.0 - 16.1 = 83.9$$

- PH = PERIOD HOURS
- EAF = EQUIVALENT AVAILABILITY FACTOR
- POH = PLANNED OUTAGE HOURS
- FOH = FORCED OUTAGE HOURS
- MOH = MAINTENANCE OUTAGE HOURS
- EUOH = EQUIVALENT UNPLANNED OUTAGE HOURS
- POF = PLANNED OUTAGE FACTOR
- EFOF = EQUIVALENT FORCED OUTAGE FACTOR
- EMOF = EQUIVALENT MAINTENANCE OUTAGE FACTOR
- EUOF = UNPLANNED OUTAGE FACTOR

TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO PERFORMANCE  
GANNON UNIT NO. 6  
APRIL 1994 - SEPTEMBER 1994

WEIGHTING FACTOR = 0.58%

	<u>6 MO. TARGET</u>	<u>6 MO. ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
		4391.0	4391.0
P.H.	4391.0	90.7	90.7
E.A.F.	63.1	0.0	0.0
P.O.H.	0.0	315.9	315.9
F.O.H. + E.F.O.H	610.0	91.6	91.6
M.O.H. + E.M.O.H	132.0	0.0	0.0
P.O.F.	0.0	7.2	7.2
E.F.O.F.	13.9	2.1	2.1
E.M.O.F.	3.0		
		10.000	E. A. POINTS

ADJUSTMENTS TO EAF:

$$\frac{P.H. - TGT\ POH}{P.H. - ACT\ POH} \times (FOH + EFOH + MOH + EMOH) = ADJUSTED\ EUOH$$

$$\frac{4391.0 - 0.0}{4391.0 - 0.0} \times (135.5 + 180.4 + 61.8 + 29.8) = 1.0000 \times 407.5 = 407.5$$

$$\frac{POH + EUOH}{PH} \times 100\% = POF + EUOF = \frac{0.0 + 407.5}{4391.0} = 9.3$$

$$100.0 - (POF + EUOF) = EAF = 100.0 - 9.3 = 90.7$$

- PH = PERIOD HOURS
- EAF = EQUIVALENT AVAILABILITY FACTOR
- POH = PLANNED OUTAGE HOURS
- FOH = FORCED OUTAGE HOURS
- MOH = MAINTENANCE OUTAGE HOURS
- EUOH = EQUIVALENT UNPLANNED OUTAGE HOURS
- POF = PLANNED OUTAGE FACTOR
- EFOF = EQUIVALENT FORCED OUTAGE FACTOR
- EMOF = EQUIVALENT MAINTENANCE OUTAGE FACTOR
- EUOF = UNPLANNED OUTAGE FACTOR



TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO PERFORMANCE  
BIG BEND UNIT NO. 1  
APRIL 1994 - SEPTEMBER 1994

WEIGHTING FACTOR = 6.91%

	<u>6 MO. TARGET</u>	<u>6 MO. ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
P.H.	4391.0	4391.0	4391.0
E.A.F.	58.8	59.1	59.1
P.O.H.	1344.0	1342.6	1344.0
F.O.H. + E.F.O.H	338.0	201.3	201.2
M.O.H. + E.M.O.H	137.0	253.0	252.9
P.O.F.	30.6	30.6	30.6
E.F.O.F.	7.7	4.6	4.6
E.M.O.F.	3.1	5.8	5.8

ADJUSTMENTS TO EAF:

1.217 E. A. POINTS

$$\frac{P.H. - TGT POH}{P.H. - ACT POH} \times (FOH + EFOH + MOH + EMOH) = \text{ADJUSTED EUOH}$$

$$\frac{4391.0 - 1344.0}{4391.0 - 1342.6} \times (81.8 + 119.5 + 177.4 + 75.6) = 0.9995 \times 454.3 = 454.1$$

$$\frac{POH + EUOH}{PH} \times 100\% = POF + EUOF = \frac{1344.0 + 454.1}{4391.0} = 40.9$$

$$100.0 - (POF + EUOF) = EAF = 100.0 - 40.9 = 59.1$$

- PH = PERIOD HOURS
- EAF = EQUIVALENT AVAILABILITY FACTOR
- POH = PLANNED OUTAGE HOURS
- FOH = FORCED OUTAGE HOURS
- MOH = MAINTENANCE OUTAGE HOURS
- EUOH = EQUIVALENT UNPLANNED OUTAGE HOURS
- POF = PLANNED OUTAGE FACTOR
- EFOF = EQUIVALENT FORCED OUTAGE FACTOR
- EMOF = EQUIVALENT MAINTENANCE OUTAGE FACTOR
- EUOF = UNPLANNED OUTAGE FACTOR

**TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO PERFORMANCE  
BIG BEND UNIT NO. 2  
APRIL 1994 - SEPTEMBER 1994**

WEIGHTING FACTOR = 8.77%

	<u>6 MO. TARGET</u>	<u>6 MO. ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
P.H.	4391.0	4391.0	4391.0
E.A.F.	87.6	79.2	79.2
P.O.H.	0.0	0.0	0.0
F.O.H. + E.F.O.H	404.0	771.3	771.3
M.O.H. + E.M.O.H	141.0	143.6	143.6
P.O.F.	0.0	0.0	0.0
E.F.O.F.	9.2	17.6	17.6
E.M.O.F.	3.2	3.3	3.3

-10.000 E. A. POINTS

**ADJUSTMENTS TO EAF:**

$$\frac{\text{P.H.} - \text{TGT POH}}{\text{P.H.} - \text{ACT POH}} \times (\text{FOH} + \text{EFOH} + \text{MOH} + \text{EMOH}) = \text{ADJUSTED EUOH}$$

$$\frac{4391.0 - 0.0}{4391.0 - 0.0} \times (559.4 + 211.9 + 54.8 + 88.8) = 1.0000 \times 914.9 = 914.9$$

$$\frac{\text{POH} + \text{EUOH}}{\text{PH}} \times 100\% = \text{POF} + \text{EUOF} = \frac{0.0 + 914.9}{4391.0} = 20.8$$

$$100.0 - (\text{POF} + \text{EUOF}) = \text{EAF} = 100.0 - 20.8 = 79.2$$

PH = PERIOD HOURS  
 EAF = EQUIVALENT AVAILABILITY FACTOR  
 POH = PLANNED OUTAGE HOURS  
 FOH = FORCED OUTAGE HOURS  
 MOH = MAINTENANCE OUTAGE HOURS  
 EUOH = EQUIVALENT UNPLANNED OUTAGE HOURS  
 POF = PLANNED OUTAGE FACTOR  
 EFOF = EQUIVALENT FORCED OUTAGE FACTOR  
 EMOF = EQUIVALENT MAINTENANCE OUTAGE FACTOR  
 EUOF = UNPLANNED OUTAGE FACTOR

**TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO PERFORMANCE  
BIG BEND UNIT NO. 3  
APRIL 1994 - SEPTEMBER 1994**

WEIGHTING FACTOR = 12.42%

	<u>6 MO. TARGET</u>	<u>6 MO. ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
P.H.	4391.0	4391.0	4391.0
E.A.F.	83.5	90.9	90.9
P.O.H.	0.0	0.0	0.0
F.O.H. + E.F.O.H	479.0	125.1	125.1
M.O.H. + E.M.O.H	246.0	275.0	275.0
P.O.F.	0.0	0.0	0.0
E.F.O.F.	10.9	2.8	2.8
E.M.O.F.	5.6	6.3	6.3

10.000 E. A. POINTS

**ADJUSTMENTS TO EAF:**

$$\frac{\text{P.H.} - \text{TGT POH}}{\text{P.H.} - \text{ACT POH}} \times (\text{FOH} + \text{EFOH} + \text{MOH} + \text{EMOH}) = \text{ADJUSTED EUOH}$$

$$\frac{4391.0 - 0.0}{4391.0 - 0.0} \times (95.8 + 29.3 + 110.6 + 164.4) = 1.0000 \times 400.1 = 400.1$$

$$\frac{\text{POH} + \text{EUOH}}{\text{PH}} \times 100\% = \text{POF} + \text{EUOF} = \frac{0.0 + 400.1}{4391.0} = 9.1$$

$$100.0 - (\text{POF} + \text{EUOF}) = \text{EAF} = 100.0 - 9.1 = 90.9$$

PH = PERIOD HOURS  
EAF = EQUIVALENT AVAILABILITY FACTOR  
POH = PLANNED OUTAGE HOURS  
FOH = FORCED OUTAGE HOURS  
MOH = MAINTENANCE OUTAGE HOURS  
EUOH = EQUIVALENT UNPLANNED OUTAGE HOURS  
POF = PLANNED OUTAGE FACTOR  
EFOF = EQUIVALENT FORCED OUTAGE FACTOR  
EMOF = EQUIVALENT MAINTENANCE OUTAGE FACTOR  
EUOF = UNPLANNED OUTAGE FACTOR

TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO PERFORMANCE  
BIG BEND UNIT NO. 4  
APRIL 1994 - SEPTEMBER 1994

WEIGHTING FACTOR = 8.59%

	<u>6 MO. TARGET</u>	<u>6 MO. ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
P.H.	4391.0	4391.0	4391.0
E.A.F.	88.1	92.6	92.6
P.O.H.	0.0	0.0	0.0
F.O.H. + E.F.O.H	417.0	58.0	58.0
M.O.H. + E.M.O.H	105.0	266.1	266.1
P.O.F.	0.0	0.0	0.0
E.F.O.F.	9.5	1.3	1.3
E.M.O.F.	2.4	6.1	6.1

ADJUSTMENTS TO EAF:

10.000 E. A. POINTS

$$\frac{P.H. - TGT\ POH}{P.H. - ACT\ POH} \times (FOH + EFOH + MOH + EMOH) = \text{ADJUSTED EUOH}$$

$$\frac{4391.0 - 0.0}{4391.0 - 0.0} \times (37.9 + 20.1 + 111.0 + 155.1) = 1.0000 \times 324.1 = 324.1$$

$$\frac{POH + EUOH}{PH} \times 100\% = POF + EUOF = \frac{0.0 + 324.1}{4391.0} = 7.4$$

$$100.0 - (POF + EUOF) = EAF = 100.0 - 7.4 = 92.6$$

- PH = PERIOD HOURS
- EAF = EQUIVALENT AVAILABILITY FACTOR
- POH = PLANNED OUTAGE HOURS
- FOH = FORCED OUTAGE HOURS
- MOH = MAINTENANCE OUTAGE HOURS
- EUOH = EQUIVALENT UNPLANNED OUTAGE HOURS
- POF = PLANNED OUTAGE FACTOR
- EFOF = EQUIVALENT FORCED OUTAGE FACTOR
- EMOF = EQUIVALENT MAINTENANCE OUTAGE FACTOR
- EUOF = UNPLANNED OUTAGE FACTOR

TAMPA ELECTRIC COMPANY  
 ADJUSTMENTS TO HEAT RATE  
 GANNON 5  
 HEAT RATE DATA  
 APRIL 1994 - SEPTEMBER 1994

WEIGHTING FACTOR = 5.47%

	<u>6 MO. TARGET</u>	<u>6 MO ACTUAL PERFORMANCE</u>
ANOHR (Btu/kwh)	10408	10413
STA NET GEN. (GWH)	620.9	666.9
OPER. Btu (10 <sup>9</sup> btu)	6482.541	6944.351
NET OUTPUT FACTOR	69.9	74.1

-0.446 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON:

CURRENT EQUATION  $NOF(-19.63800) + 11780.7 = ANOHR$   
 $74.1(-19.63800) + 11780.7 = 10328$   
 $10413 - 10328 = 87$   
 $10408 + 87 = 10495$

ANOHR = AVERAGE NET OPERATING HEAT RATE  
 NOF = NET OPERATING FACTOR

TAMPA ELECTRIC COMPANY  
 ADJUSTMENTS TO HEAT RATE  
 GANNON 6  
 HEAT RATE DATA  
 APRIL 1994 - SEPTEMBER 1994

WEIGHTING FACTOR = 9.86%

	<u>6 MO. TARGET</u>	<u>6 MO ACTUAL PERFORMANCE</u>
ANOHR (Btu/kwh)		
STA NET GEN. (GWH)	10454	10510
OPER. Btu (10 <sup>9</sup> btu)	951.2	1147.0
NET OUTPUT FACTOR	9944.186	12055.060
	65.9	77.9

-4.238 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON:

CURRENT EQUATION  $NOF(-13.18000) + 11322.8 = ANOHR$   
 $77.9(-13.18000) + 11322.8 = 10296$   
 $10510 - 10296 = 214$   
 $10454 + 214 = 10668$

ANOHR = AVERAGE NET OPERATING HEAT RATE  
 NOF = NET OPERATING FACTOR

TAMPA ELECTRIC COMPANY  
 ADJUSTMENTS TO HEAT RATE  
 BIG BEND UNIT 1  
 HEAT RATE DATA  
 APRIL 1994 - SEPTEMBER 1994

WEIGHTING FACTOR = 7.38%

	<u>6 MO. TARGET</u>	<u>6 MO ACTUAL PERFORMANCE</u>
ANOHR (Btu/kwh)	10062	10059
STA. NET GEN. (GWH)	1009.8	961.3
OPER. Btu (10 <sup>9</sup> btu)	10160.786	9570.178
NET OUTPUT FACTOR	90.2	85.1

0.000 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON:

$$\text{CURRENT EQUATION } \text{NOF}(-13.91400) + 11317.0 = \text{ANOHR}$$

$$85.1(-13.91400) + 11317.0 = 10133$$

$$10059 - 10133 = -74$$

$$10062 + -74 = 9988$$

ANOHR = AVERAGE NET OPERATING HEAT RATE  
 NOF = NET OPERATING FACTOR

TAMPA ELECTRIC COMPANY  
 ADJUSTMENTS TO HEAT RATE  
 BIG BEND UNIT 2  
 HEAT RATE DATA  
 APRIL 1994 - SEPTEMBER 1994

WEIGHTING FACTOR = 9.00%

	<u>6 MO. TARGET</u>	<u>6 MO ACTUAL PERFORMANCE</u>
ANOH <sub>R</sub> (Btu/kwh)	10069	10241
STA. NET GEN. (GWH)	1443.6	1287.4
OPER. Btu (10 <sup>9</sup> Btu)	14535.587	13183.816
NET OUTPUT FACTOR	87.7	84.0

-2.941 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON:

$$\text{CURRENT EQUATION } \text{NOF}(-7.33850) + 10712.3 = \text{ANOH}_R$$

$$84.0(-7.33850) + 10712.3 = 10096$$

$$10241 - 10096 = 145$$

$$10096 + 145 = 10241$$

ANOH<sub>R</sub> = AVERAGE NET OPERATING HEAT RATE  
 NOF = NET OPERATING FACTOR



**TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO HEAT RATE  
BIG BEND 3  
HEAT RATE DATA  
APRIL 1994 - SEPTEMBER 1994**

WEIGHTING FACTOR = 9.13%

	<u>6 MO. TARGET</u>	<u>6 MO ACTUAL PERFORMANCE</u>
ANOMR (Btu/kwh)	9676	9942
STA. NET GEN. (GWH)	1497.3	1550.6
OPER. Btu (10 <sup>9</sup> btu)	14488.763	15416.046
NET OUTPUT FACTOR	87.8	86.2

-8.524 HEAT RATE POINTS

**ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON:**

$$\text{CURRENT EQUATION } \text{NOF}(-7.15950) + 10305.1 = \text{ANOMR}$$

$$86.2(-7.15950) + 10305.1 = 9688$$

$$9942 - 9688 = 254$$

$$9676 + 254 = 9930$$

ANOMR = AVERAGE NET OPERATING HEAT RATE  
NOF = NET OPERATING FACTOR

TAMPA ELECTRIC COMPANY  
 ADJUSTMENTS TO HEAT RATE  
 BIG BEND UNIT 4  
 HEAT RATE DATA  
 APRIL 1994 - SEPTEMBER 1994

WEIGHTING FACTOR = 8.89%

	<u>6 MO. TARGET</u>	<u>6 MO ACTUAL PERFORMANCE</u>
ANOH <sub>R</sub> (Btu/kwh)	10114	10161
STA. NET GEN. (GWH)	1582.2	1656.9
OPER. Btu (10 <sup>9</sup> btu)	16002.734	16834.553
NET OUTPUT FACTOR	67.8	68.6

0.000 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON:

$$\text{CURRENT EQUATION } \text{NOF}(-12.33300) + 11194.9 = \text{ANOH}_R$$

$$68.6(-12.33300) + 11194.9 = 10102$$

$$10161 - 10102 = 59$$

$$10114 + 59 = 10173$$

ANOH<sub>R</sub> = AVERAGE NET OPERATING HEAT RATE  
 NOF = NET OPERATING FACTOR

## TAMPA ELECTRIC COMPANY


## GPIF PLANNED OUTAGE SCHEDULE - ACTUAL

APRIL 1994 - SEPTEMBER 1994

<u>STATION/UNIT</u>	<u>PLANNED OUTAGE DATES</u>	<u>OUTAGE REASON</u>
BIG BEND 1	APR 6 - MAY 30	LP TURBINE MODIFICATION INSPECT GOV. W'S/INT/RHT/THRTL W'S REPLACE HTRH REPLACE PULV. SHELL & THROAT LINERS PENT HOUSE PRESSURIZATION REPLACE LOWER WATER WALL TUBES REPLACE COLD RHT PIPING REPLACE BURNER PANELS BOILER CHEMICAL CLEAN REPLACE PRECIP. OUTLET DUCT GENERATOR STEP-UP TRANSFORMER MOD.
** GANNON 5	APR 3 - APR 9	FUEL SYSTEM CLEAN-UP

Milestone or Critical Path Chart of actual schedule are included on page 20.

\*\* Outage is less than two weeks in duration and a CPM was not included for this unit.



TAMPA ELECTRIC COMPANY  
 BIG BEND UNIT NO. 1  
 PLANNED OUTAGE 1994  
 ACTUAL CPM  
 11/03/93

PAGE 20 OF 28

TAMPA ELECTRIC COMPANY  
GENERATING PERFORMANCE INCENTIVE POINTS TABLE  
APRIL 1994 - SEPTEMBER 1994  
GANNON 5

<u>EQUIVALENT AVAILABILITY POINTS</u>	<u>FUEL SAVINGS/(LOSS) (\$1000)</u>	<u>ADJUSTED ACTUAL EQUIVALENT AVAILABILITY</u>	<u>AVERAGE HEAT RATE POINTS</u>	<u>FUEL SAVINGS/(LOSS) (\$1000)</u>	<u>ADJUSTED ACTUA AVERAGE HEAT RATE</u>
				357.3	10364
+10	150.0	85.5	+10		
				321.6	10391
+9	155.8	85.2	+9		
				285.8	10118
+8	120.7	84.9	+8		
				250.1	10143
+7	103.6	84.7	+7		
				214.4	10172
+6	98.5	84.4	+6		
				178.7	10199
+5	75.5	84.1	+5		
				142.9	10225
+4	60.4	83.8	+4		
				107.2	10252
+3	45.3	83.5	+3		
				71.5	10279
+2	30.2	83.3	+2		
				35.7	10306
+1	15.1	83.0	+1		
				0.0	10333
0	0.0	82.7	0	0.0	10408
				0.0	10483
-1	(42.5)	82.1	-1	(35.7)	10510
				(71.5)	10537
-2	(85.0)	81.6	-2		
				(107.2)	10564
-3	(127.5)	81.0	-3		
				(142.9)	10591
-4	(170.0)	80.5	-4		
				(178.7)	10618
-5	(212.5)	79.9	-5		
				(214.4)	10644
-6	(254.0)	79.3	-6		
				(250.1)	10671
-7	(297.4)	78.8	-7		
				(285.8)	10698
-8	(339.9)	78.2	-8		
				(321.6)	10725
-9	(382.4)	77.7	-9		
				(357.3)	10752
-10	(424.9)	77.1	-10		

AV Points  
+4.4

Adjusted  
RAF  
0.9

AHR  
Points  
-0.446

Adjusted  
Actual  
ANHR  
10495

Weighting Factor = 2.510

Weighting Factor = 5.470

TAMPA ELECTRIC COMPANY  
GENERATING PERFORMANCE INCENTIVE POINTS TABLE

APRIL 1994 - SEPTEMBER 1994

GANNON 6

<u>EQUIVALENT AVAILABILITY POINTS</u>	<u>FUEL SAVINGS/(LOSS) (\$/HR)</u>	<u>ADJUSTED ACTUAL EQUIVALENT AVAILABILITY</u>	<u>AVERAGE HEAT RATE POINTS</u>	<u>FUEL SAVINGS/(LOSS) (\$/1000)</u>	<u>ADJUSTED ACTUAL AVERAGE HEAT RATE</u>
+10	568.8	86.5	+10	644.3	10001
+9	504.7	86.2	+9	579.9	11084
+8	440.6	85.8	+8	515.4	10117
+7	376.5	85.5	+7	451.0	10149
+6	312.3	85.1	+6	386.6	10182
+5	248.4	84.8	+5	322.2	10215
+4	184.3	84.5	+4	257.7	10248
+3	120.2	84.1	+3	193.3	11281
+2	56.1	83.8	+2	128.9	10313
+1	0.0	83.4	+1	64.4	10346
0	0.0	83.1	0	0.0	10379
-1	(64.3)	82.4	-1	0.0	10454
-2	(168.7)	81.7	-2	64.4	10529
-3	(273.0)	81.1	-3	128.9	10542
-4	(377.3)	80.4	-4	(64.4)	10595
-5	(481.7)	79.7	-5	(128.9)	10627
-6	(586.0)	79.0	-6	(193.3)	10640
-7	(690.3)	78.3	-7	(257.7)	10693
-8	(794.6)	77.7	-8	(322.2)	10726
-9	(898.9)	77.0	-9	(386.6)	10759
-10	(1003.3)	76.5	-10	(451.0)	10791

Weighting Factor = 8.50%

Weighting Factor = 9.50%

**TAMPA ELECTRIC COMPANY**  
**GENERATING PERFORMANCE INCENTIVE POINTS TABLE**  
**APRIL 1994 - SEPTEMBER 1994**  
**BIG BEND 1**

<u>EQUIVALENT AVAILABLE POINTS</u>	<u>FUEL SAVINGS(LOSS) (\$1,000)</u>	<u>ADJUSTED ACTUAL EQUIVALENT AVAILABILITY</u>	<u>AVERAGE HEAT RATE POINTS</u>	<u>FUEL SAVINGS(LOSS) (\$1,000)</u>	<u>ADJUSTED ACTUA AVERAGE HEAT RATE</u>
+10	982.3	62.3	+10	482.1	9720
+9	524.1	61.9	+9	433.9	9747
+8	465.8	61.6	+8	385.7	9773
+7	407.6	61.2	+7	337.5	9800
+6	349.4	60.8	+6	289.3	9827
+5	291.2	60.4	+5	241.1	9854
+4	232.9	60.1	+4	192.8	9880
+3	174.7	59.7	+3	144.6	9907
+2	116.5	59.3	+2	96.4	9934
+1	58.2	59.0	+1	48.2	9960
0	0.0	58.6	0	0.0	9987
-1	(116.5)	57.9	-1	(48.2)	10062
-2	(233.0)	57.1	-2	(96.4)	10137
-3	(349.5)	56.4	-3	(144.6)	10164
-4	(466.0)	55.6	-4	(192.8)	10190
-5	(582.6)	54.9	-5	(241.1)	10217
-6	(699.1)	54.2	-6	(289.3)	10244
-7	(815.6)	53.4	-7	(337.5)	10271
-8	(932.1)	52.7	-8	(385.7)	10297
-9	(1,048.6)	51.9	-9	(433.9)	10324
-10	(1,165.1)	51.2	-10	(482.1)	10351
					10377
					10404

← RAF Points 1.217

Adjusted RAF 29.1 →

← AHR Points 0.000

Adjusted Actual AHR 9988 →

Weighting Factor = 1.91%

Weighting Factor = 7.38%

TAMPA ELECTRIC COMPANY  
GENERATING PERFORMANCE INCENTIVE POINTS TABLE

APRIL 1994 - SEPTEMBER 1994

BIG BEND 2

<u>EQUIVALENT AVAILABILITY POINTS</u>	<u>FUEL SAVINGS/(LOSS) (\$1000)</u>	<u>ADJUSTED ACTUAL EQUIVALENT AVAILABILITY</u>	<u>AVERAGE HEAT RATE POINTS</u>	<u>FUEL SAVINGS/(LOSS) (\$1000)</u>	<u>ADJUSTED ACTUA AVERAGE HEAT RATE</u>
+10	573.0	90.1	+10	633.1	9756
+9	515.7	89.9	+9	569.8	9780
+8	458.4	89.6	+8	506.5	9804
+7	401.1	89.4	+7	443.2	9827
+6	343.8	89.1	+6	379.9	9851
+5	286.5	88.9	+5	316.6	9875
+4	229.2	88.6	+4	253.2	9899
+3	171.9	88.4	+3	189.9	9923
+2	114.6	88.1	+2	126.6	9946
+1	57.3	87.9	+1	63.3	9970
0	0.0	87.6	0	0.0	9994
-1	(92.4)	87.1	-1	0.0	10018
-2	(183.3)	86.6	-2	(63.3)	10144
-3	(277.0)	86.1	-3	(126.6)	10168
-4	(370.7)	85.6	-4	(189.9)	10192
-5	(463.2)	85.1	-5	(253.2)	10215
-6	(555.6)	84.6	-6	(316.6)	10239
-7	(648.4)	84.1	-7	(379.9)	10263
-8	(741.0)	83.6	-8	(443.2)	10287
-9	(833.7)	83.1	-9	(506.5)	10311
-10	(926.3)	82.6	-10	(569.8)	10334
				(633.1)	10358
					10382

RAP Points  
-10,000

Adjusted RAP  
79.2

ARR Points  
-2,941

Adjusted Actual ANOHR  
10214

Weighting Factor = 8.77%

Weighting Factor = 9.69%



TAMPA ELECTRIC COMPANY  
GENERATING PERFORMANCE INCENTIVE POINTS TABLE  
APRIL 1994 - SEPTEMBER 1994  
BIG BEND 3

<u>EQUIVALENT AVAILABILITY POINTS</u>	<u>FUEL SAVINGS/(LOSS) (\$1000)</u>	<u>ADJUSTED ACTUAL EQUIVALENT AVAILABILITY</u>	<u>AVERAGE HEAT RATE POINTS</u>	<u>FUEL SAVINGS/(LOSS) (\$1000)</u>	<u>ADJUSTED ACTUAL AVERAGE HEAT RATE</u>
+10	611.6	84.0	+10	507.0	9301
+9	738.6	86.5	+9	537.5	9412
+8	648.4	88.1	+8	477.6	9480
+7	568.5	85.8	+7	417.9	9454
+6	487.1	85.5	+6	358.2	9475
+5	405.9	84.8	+5	298.5	9486
+4	324.7	84.0	+4	238.8	9517
+3	243.5	84.5	+3	179.1	9558
+2	162.4	84.2	+2	119.4	9559
+1	81.2	84.0	+1	59.7	9580
0	0.0	83.5	0	0.0	9601
-1	(150.1)	82.0	-1	0.0	9676
-2	(300.2)	82.2	-2	(59.7)	9751
-3	(450.3)	81.5	-3	(119.4)	9772
-4	(600.4)	80.9	-4	(179.1)	9793
-5	(750.5)	80.2	-5	(238.8)	9814
-6	(900.6)	79.5	-6	(298.5)	9835
-7	(1,050.7)	78.9	-7	(358.2)	9856
-8	(1,200.8)	78.2	-8	(417.9)	9877
-9	(1,350.9)	77.6	-9	(477.6)	9898
-10	(1,501.0)	76.9	-10	(537.3)	9919
				(597.0)	9940
					9961

EA Points 1000

Adjusted AEP 1000

AER Points -0.571

Adjusted Actual AROER 9920

Weighting Factor = 12.42%

Weighting Factor = 9.13%

TAMPA ELECTRIC COMPANY  
GENERATING PERFORMANCE INCENTIVE POINTS TABLE  
APRIL 1984 - SEPTEMBER 1984  
BIG BEND 4

EQUIVALENT AVAILABLE POINTS	FUEL SAVING(LOSS) (\$/1000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVING(LOSS) (\$/1000)	ADJUSTED ACTUA AVERAGE HEAT RATE
+10	501.3	98.5	+10	582.3	9843
+9	385.3	98.3	+9	524.1	9884
+8	448.8	98.0	+8	465.8	9884
+7	392.9	98.8	+7	407.6	9908
+6	326.8	99.3	+6	349.4	9928
+5	268.7	99.1	+5	291.2	9942
+4	224.5	98.6	+4	232.9	9961
+3	168.4	98.6	+3	174.7	9981
+2	112.3	98.3	+2	116.5	10000
+1	56.1	98.1	+1	58.2	10020
0	0.0	97.6	0	0.0	10039
-1	(114.8)	97.1	-1	(58.2)	10114
-2	(228.8)	96.7	-2	(114.5)	10188
-3	(344.8)	96.2	-3	(174.7)	10208
-4	(459.7)	85.7	-4	(232.9)	10228
-5	(574.6)	85.2	-5	(291.2)	10247
-6	(689.5)	84.7	-6	(349.4)	10267
-7	(804.4)	84.3	-7	(407.6)	10326
-8	(919.4)	83.8	-8	(465.8)	10345
-9	(1,034.3)	83.3	-9	(524.1)	10364
-10	(1,149.2)		-10	(582.3)	10383

EA  
Fuel  
SAVING

Adjusted  
EA  
AVAILABILITY

AER  
Points  
0.000

Adjusted  
Actual  
AVERAGE  
10172

Weighting Factor = 0.39%

Weighting Factor = 0.89%

TAMPA ELECTRIC COMPANY

COMPARISON OF OPIF TABOETS VS. PRIOR PERIOD ACTUAL PERFORMANCE

AVAILABILITY

PLANT/UNIT	TABOET WEIGHTING FACTOR	NORMALIZED WEIGHTING FACTOR	TABOET PERIOD APR 94 - SEP 94			ACTUAL PERFORMANCE APR 94 - SEP 94		
			POP	HUOP	HUOR	POP	HUOP	HUOR
BIG BEND1	8.91%	18.0	30.6	10.8	15.6	30.6	10.3	14.8
BIG BEND2	8.77%	17.7	0.0	12.4	12.4	0.0	20.8	20.8
BIG BEND3	12.42%	25.1	0.0	18.5	18.5	0.0	8.1	8.1
BIG BEND 4	8.58%	17.3	0.0	11.9	11.9	0.0	7.4	7.4
GANNON 5	2.31%	4.7	4.4	12.8	19.5	2.7	11.8	12.2
GANNON 6	8.59%	17.3	0.0	16.9	16.9	0.0	8.3	8.3
48.58% GPIF SYSTEM WGTD AVG.		100.0	5.7	13.8	14.7	5.8	11.3	12.1
GPIF SYSTEM WEIGHTED EQUIVALENT AVAILABILITY			80.4			63.1		
			5 PERIOD AVERAGE POE EVOE EUOR			5 PERIOD AVERAGE EAF		
			7.3 11.5 12.7			81.2		

PLANT/UNIT	TARGET WEIGHTING FACTOR	NORMALIZED WEIGHTING FACTOR	HEAT RATE TARGET	ADJUSTED ACTUAL HEAT RATE APR 94 - SEP 94
GANNON 5	5.47%	10.8	10408	10495
GANNON 6	8.88%	18.6	10454	10668
BIG BEND 1	7.38%	14.8	10082	9988
BIG BEND 2	8.88%	18.2	10069	10214
BIG BEND 3	8.13%	18.1	9878	9930
BIG BEND 4	8.89%	17.8	10114	10173
80.42% GPIF SYSTEM WEIGHTED AVERAGE H.R. (Btu/kwh)		100.0	10117	10242

TAMPA ELECTRIC COMPANY  
GENERATING PERFORMANCE INCENTIVE POINTS CALCULATION  
APRIL 1994 - SEPTEMBER 1994

Points are calculated according to the formula:

$$GPIP = \sum_{i=1}^n [ (a_i) (EAP_i) + (b_i) (AHRP_i) ]$$

Where:

$$i=1, n$$

a = Unit equivalent availability weighting factor

EAP = Unit equivalent availability points

b = Station average heat rate weighting factor

AHRP = Station average heat rate points

Weighting factors and point values are listed in separate tables.

$$\begin{aligned} GPIP = & 2.31\% (GN5 EAP) + 8.58\% (GN6 EAP) + 8.91\% (BB1 EAP) \\ & + 8.77\% (BB2 EAP) + 12.42\% (BB3 EAP) + 8.59\% (BB4 EAP) \\ & + 5.47\% (GN5 AHRP) + 9.86\% (GN6 AHRP) + 7.38\% (BB1 AHRP) \\ & + 9.89\% (BB2 AHRP) + 9.13\% (BB3 AHRP) + 8.89\% (BB4 AHRP) \end{aligned}$$

$$\begin{aligned} GPIP = & 2.31\% (4.444) + 8.58\% (10.000) + 8.91\% (1.217) \\ & + 8.77\% (-10.000) + 12.42\% (10.000) + 8.59\% (10.000) \\ & + 5.47\% (-0.446) + 9.86\% (-4.238) + 7.38\% (0.000) \\ & + 9.89\% (-2.941) + 9.13\% (-8.524) + 8.89\% (0.000) \end{aligned}$$

$$\begin{aligned} GPIP = & (0.103) + (0.858) + (0.108) + (-0.877) + (1.242) \\ & + (0.859) + (-0.024) + (-0.418) + (0.000) + (-0.285) \\ & + (-0.778) + (0.000) \end{aligned}$$

$$GPIP = 0.788 \text{ POINTS}$$

REWARD/PENALTY dollar amounts of the Generating Performance Incentive Factor (GPIF) are determined directly from the table for the corresponding Generating Performance Points (GPIP) - see page 2.

$$GPIP = \underline{\underline{\$146,321}}$$