

MACFARLANE AUSLEY FERGUSON & McMULLEN

FILED

ATTORNEYS AND COUNSELORS AT LAW

227 SOUTH CALHOUN STREET  
P.O. BOX 391 (ZIP 32302)  
TALLAHASSEE, FLORIDA 32301  
19041 224 9115 FAX 19041 222 7560

111 MADISON STREET, SUITE 2300  
P.O. BOX 1531 (ZIP 33601)  
TAMPA, FLORIDA 33602  
18131 273 4200 FAX 18131 273 4386

400 CLEVELAND STREET  
P.O. BOX 1669 (ZIP 34617)  
CLEARWATER, FLORIDA 34615  
18131 441 8906 FAX 18131 442 0470

May 20, 1996

HAND DELIVERED

IN REPLY REFER TO:

Tallahassee

Ms. Blanca S. Bayo, Director  
Division of Records and Reporting  
Florida Public Service Commission  
2540 Shumard Oak Boulevard  
Tallahassee, Florida 32399-0850

Re: Fuel and Purchased Power Cost Recovery Clause  
with Generating Performance Incentive Factor;  
FPSC Docket No. 960001-EI

Dear Ms. Bayo:

Enclosed for filing in the above docket, on behalf of Tampa Electric Company, are fifteen (15) copies of each of the following:

1. Prepared Direct Testimony of Mary Jo Pennino and Exhibit (MJP-1) entitled Fuel Cost Recovery and Capacity Cost Recovery for the period October 1995 through March 1996.
2. Prepared Direct Testimony of George A. Keselowsky with Exhibit (GAK-1) regarding Tampa Electric Company's Generating Performance Incentive Factor Results for the period October 1995 through March 1996.

Please acknowledge receipt and filing of the above by stamping the duplicate copy of this letter and returning same to this writer.

Thank you for your assistance in connection with this matter.

Sincerely,

*James D. Beasley*  
James D. Beasley

ACK \_\_\_\_\_  
 AFA \_\_\_\_\_  
 APP \_\_\_\_\_  
 CME \_\_\_\_\_  
 CMT \_\_\_\_\_  
 CTR \_\_\_\_\_  
 ERS \_\_\_\_\_

LET 1 JDB/pp  
ENC 3 Enclosures

CC: All Parties of Record (w/encs.)

ORD \_\_\_\_\_  
 RCH \_\_\_\_\_  
 SEC 1 \_\_\_\_\_  
 WAS \_\_\_\_\_  
 OTH \_\_\_\_\_

*Keselowsky*  
 DOCUMENT NUMBER - DATE  
 05574 MAY 20 1996  
 FPSC-RECORDS/REPORTING

*Remind*  
 DOCUMENT NUMBER - DATE  
 05573 MAY 20 1996  
 FPSC-RECORDS/REPORTING

CERTIFICATE OF SERVICE

I HEREBY CERTIFY that a true copy of the foregoing testimony and exhibits, filed on behalf of Tampa Electric Company, has been furnished by U. S. Mail or hand delivery (\*) on this 20<sup>th</sup> day of May, 1996 to the following:

Ms. Martha C. Brown\*  
Ms. Mary Elizabeth Culpepper  
Division of Legal Services  
Florida Public Service Comm'n.  
101 East Gaines Street  
Tallahassee, FL 32399-0863

Mr. James A. McGee  
Senior Counsel  
Florida Power Corporation  
Post Office Box 14042  
St. Petersburg, FL 33733

Mr. Joseph A. McGlothlin  
Ms. Vicki Gordon Kaufman  
McWhirter, Reeves, McGlothlin,  
Davidson, Rief & Bakas  
117 S. Gadsden Street  
Tallahassee, FL 32301

Mr. Jack Shreve  
Office of Public Counsel  
Room 812  
111 West Madison Street  
Tallahassee, FL 32399-1400

Mr. Matthew M. Childs  
Steel Hector & Davis  
Suite 601  
215 South Monroe Street  
Tallahassee, FL 32301

Mr. John W. McWhirter  
McWhirter, Reeves, McGlothlin,  
Davidson & Bakas  
Post Office Box 3350  
Tampa, FL 33601

Ms. Suzanne Brownless  
Suzanne Brownless P.A.  
1311-B Paul Russell Road #202  
Tallahassee, FL 32301

Mr. David M. Kleppinger  
McNees, Wallace & Nurick  
Post Office Box 1166  
Harrisburg, PA 17108-1166

Mr. Floyd R. Self  
Messer, Vickers, Caparello,  
Madsen, Lewis, Goldman & Metz  
Post Office Box 1876  
Tallahassee, FL 32301-1876

Mr. G. Edison Holland, Jr.  
Beggs & Lane  
Post Office Box 12950  
Pensacola, FL 32576


Mr. Barry Huddleston  
Destec Energy  
2500 CityWest Blvd. Suite 150  
Houston, TX 77042

Mr. Eugene M. Trisko  
Post Office Box 596  
Berkeley Springs, WV 25411

Mr. Roger Yott  
Air Products & Chemicals, Inc.  
7540 Windsor Drive, Suite 301  
Allentown, PA 18195

Mr. Peter J. P. Brickfield  
Brickfield, Burchette & Ritts  
1025 Thomas Jefferson St. N.W.  
Eighth Floor, West Tower  
Washington, D.C. 20007-0805

Mr. Stephen R. Yurek  
Dahlen, Berg & Co.  
2150 Dain Bosworth Plaza  
60 South Sixth Street  
Minneapolis, MN 55402

  
ATTORNEY

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

PREPARED DIRECT TESTIMONY

OF

GEORGE A. KESELOWSKY

1  
2  
3  
4  
5  
6 Q. Will you please state your name, business address, and  
7 employer?

8  
9 A. My name is George A. Keselowsky and my business address is  
10 Post Office Box 111, Tampa, Florida 33601. I am employed  
11 by Tampa Electric Company.

12  
13 Q. Please furnish us with a brief outline of your educational  
14 background and business experience.

15  
16 A. I graduated in 1972 from the University of South Florida  
17 with a Bachelor of Science Degree in Mechanical  
18 Engineering. I have been employed by Tampa Electric  
19 Company in various engineering positions since that time.  
20 My current position is that of Senior Consulting Engineer  
21 -Production Engineering.

1 Q. What are your current responsibilities?

2

3 A. I am responsible for testing and reporting unit  
4 performance, and the compilation and reporting of  
5 generation statistics.

6

7 Q. What is the purpose of your testimony?

8

9 A. My testimony presents the actual performance results from  
10 unit equivalent availability and station heat rate used to  
11 determine the Generating Performance Incentive Factor  
12 (GPIF) for the period October 1995 through March 1996. I  
13 will also compare these results to the targets established  
14 prior to the beginning of the period.

15

16 Q. Have you prepared an exhibit with the results for this six  
17 month period?

18

19 A. Yes. Under my direction and supervision an exhibit has  
20 been prepared entitled, "Tampa Electric Company, October  
21 1995 - March 1996, Generating Performance Incentive Factor  
22 Results" consisting of 28 pages that was filed with this  
23 testimony (Have identified as Exhibit GAK-1).

24

25

- 1 Q. Have you calculated the results of Tampa Electric Company  
2 for its performance under the GPIF during this period?  
3
- 4 A. Yes I have. This is shown on page 4 of my exhibit. Based  
5 upon -0.494 GPIF points, the result is a penalty amount of  
6 \$104,014 for the period.  
7
- 8 Q. Please proceed with your review of the actual results for  
9 the October 1995 - March 1996 period.  
10
- 11 A. On page 3 of my exhibit, the actual average common equity  
12 for the period is shown on line 8 as \$1,037,899,631. This  
13 produces the maximum penalty or reward figure of \$2,105,538  
14 as shown on line 15, page 3, and also page 2 of my exhibit.  
15
- 16 Q. Would you please explain how you arrived at the actual  
17 equivalent availability results for the six units included  
18 within the GPIF?  
19
- 20 A. Yes I will. Operating data on each of our operating units  
21 is filed monthly with the Florida Public Service Commission  
22 on the Actual Unit Performance data form. Additionally,  
23 outage information is reported to the Commission on a  
24 monthly basis. A summary of this data for the six months  
25 provides the basis for the GPIF.

1 Q. Are the equivalent availability results shown on page 6,  
2 column 2, directly applicable to the GPIF table?

3  
4 A. Not exactly. Adjustments to equivalent availability may be  
5 required as noted in section 4.3.3 of the GPIF Manual. The  
6 actual equivalent availability including the required  
7 adjustment is shown on page 6 of my exhibit. The necessary  
8 adjustments as prescribed in the GPIF Manual are further  
9 defined by a letter dated October 23, 1981, from Mr. J.H.  
10 Hoffsis of the Commission's Staff. The adjustments for  
11 each unit are as follows:

12  
13 Gannon Unit No. 5

14 On this unit, 1248 planned outage hours were originally  
15 scheduled to fall within the Winter 1995 period. The  
16 actual planned outage activities required 1362.3 hours.  
17 Consequently, the actual equivalent availability of 60.4%  
18 is adjusted to 62.6%, as shown on page 7 of my exhibit.

19  
20 Gannon Unit No. 6

21 On this unit, 168 planned outage hours were originally  
22 scheduled to fall within the Winter 1995 period. The  
23 actual planned outage activities required 170.2 hours.  
24 Consequently, the actual equivalent availability of 84.9%  
25 is adjusted to 85.0%, as shown on page 8 of my exhibit.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

Big Bend Unit No. 1

This unit was not scheduled to have a planned outage during the Winter 1995 period and did not in fact have one. Consequently, the actual equivalent availability of 87.4% requires no adjustment as shown on page 9 of my exhibit.

Big Bend Unit No. 2

On this unit 936 planned outage hours were originally scheduled to fall within the Winter 1995 period. Due to a revision of the outage schedule, planned outage activities were rescheduled such that no planned outage took place during the period. Consequently, the actual equivalent availability of 85.5% is adjusted to 67.3% as shown on page 10 of my exhibit.

Big Bend Unit No. 3

On this unit no planned outage hours were originally scheduled to fall within the Winter 1995 period. Due to a revision of the outage schedule, an outage was moved forward and associated planned outage activities required 457.1 hours. Consequently, the actual equivalent availability of 75.7 is adjusted to 84.5 as shown on page 11 of my exhibit.

1        Big Bend Unit No. 4

2        On this unit 384 planned outage hours were originally  
3        scheduled to fall within the Winter 1995 period. Actual  
4        planned outage activities required 484.6 hours.  
5        Consequently, the actual equivalent availability of 84.4%  
6        is adjusted to 86.5% as shown on page 12 of my exhibit.

7

8        Q.    How did you arrive at the applicable equivalent  
9        availability points for each unit?

10

11        A.    The final adjusted equivalent availabilities for each unit  
12        are shown on page 6, column 4, of my exhibit. This number  
13        is entered into the respective Generating Performance  
14        Incentive Point (GPIP) Table for each particular unit on  
15        pages 21 through 26. Page 4 of my exhibit summarizes the  
16        equivalent availability points to be awarded or penalized.

17

18        Q.    Would you please explain the heat rate results relative to  
19        the GPIP?

20

21        A.    The actual heat rate and adjusted actual heat rate for  
22        Gannon and Big Bend Station are shown on page 6 of my  
23        exhibit. The adjustment was developed based on the  
24        guidelines of section 4.3.6 of the GPIP Manual. This  
25        procedure is further defined by a letter dated October 23,



1 1981, from Mr. J.H. Hoffsis of the FPSC Staff. The final  
2 adjusted actual heat rates are also shown on page 5 of my  
3 exhibit. This heat rate number is entered into the  
4 respective GPIIP table for the particular unit, shown on  
5 pages 21 through 26. Page 4 of my exhibit summarizes the  
6 weighted heat rate and equivalent availability points to be  
7 awarded.

8

9 Q. Were any additional adjustments to heat rate required?

10

11 A. In order to assure compatability of data, Big Bend Unit 3  
12 heat rates have been calculated in the standard fashion,  
13 without scrubber power. This methodology has been reviewed  
14 and approved by the PSC staff, to be employed until there  
15 is sufficient operational history with the scrubber to meet  
16 target preparation guidelines.

17

18 Q. Does this assure that the Big Bend 3 heat rate for the  
19 period is appropriate for comparison to its target and  
20 meets GPIIF criteria?

21

22 A. Yes.

23

24

25

1 Q. What is the overall GPIF for Tampa Electric Company during  
2 this six month period?

3

4 A. This is shown on page 28 of my exhibit. Essentially, the  
5 weighting factors shown on page 4, column 3, plus the  
6 equivalent availability points and the heat rate points  
7 shown on page 4, column 4, are substituted within the  
8 equation. This resultant value, -0.494, is then entered  
9 into the GPIF table on page 2. Using linear interpolation,  
10 a penalty amount of \$104,014 is calculated.

11

12 Q. Does this conclude your testimony?

13

14 A. Yes, it does.

15

16

17

18

19

20

21

22

23

24

25

**TAMPA ELECTRIC COMPANY  
OCTOBER 1995 - MARCH 1996  
GENERATING PERFORMANCE INCENTIVE FACTOR  
RESULTS  
TABLE OF CONTENTS**

<u>SCHEDULE</u>	<u>PAGE</u>
GPIF REWARD / PENALTY TABLE ACTUAL	2
GPIF CALCULATIONS OF MAXIMUM ALLOWED INCENTIVE DOLLARS	3
CALCULATIONSS OF SYSTEM ACTUAL GPIF POINTS	4
GPIF UNIT PERFORMANCE SUMMARY, EQUIVALENT AVAILABILITY	5
GPIF UNIT PERFORMANCE SUMMARY, AVERAGE NET OPERATING HEAT RATE	5
GPIF UNIT PERFORMANCE DATA	6
GPIF ( EAF & HEAT RATE ) ADJUSTMENT COMPUTATIONS	7 - 18
PLANNED OUTAGE SCHEDULE - ACTUAL	19
CRITICAL PATH DIAGRAM	20
GENERATING PERFORMANCE INCENTIVE POINTS TABLES (ACTUAL)	21 - 26
COMPARISON OF GPIF TARGET VS ACTUAL PERFORMANCE	27
GENERATING PERFORMANCE INCENTIVE POINTS CALCULATIONS	28

**TAMPA ELECTRIC COMPANY  
GENERATING PERFORMANCE INCENTIVE POINTS TABLE  
REWARD / PENALTY TABLE - ACTUAL  
OCTOBER 1995 - MARCH 1996**

GENERATING PERFORMANCE INCENTIVE POINTS (GPIP)	FUEL SAVINGS / (LOSS) (\$000)	GENERATING PERFORMANCE INCENTIVE FACTOR (\$000)
+10	5,848.7	2,105.5
+9	5,263.8	1,895.0
+8	4,679.0	1,684.4
+7	4,094.1	1,473.9
+6	3,509.2	1,263.3
+5	2,924.4	1,052.8
+4	2,339.5	842.2
+3	1,754.6	631.7
+2	1,169.7	421.1
+1	584.9	210.6
0	0	0.0
-1	(843.6)	(219.6)
-2	(1,687.3)	(421.1)
-3	(2,530.9)	(631.7)
-4	(3,374.6)	(842.2)
-5	(4,218.2)	(1,052.8)
-6	(5,061.8)	(1,263.3)
-7	(5,905.5)	(1,473.9)
-8	(6,749.1)	(1,684.4)
-9	(7,592.8)	(1,895.0)
-10	(8,436.4)	(2,105.5)

	← <span style="border: 1px solid black; padding: 5px;">GPIP Points -0.494</span>	<span style="border: 1px solid black; padding: 5px;">REWARD DOLLARS (\$104,014)</span> →	
--	--	--	--

**TAMPA ELECTRIC COMPANY  
GENERATING PERFORMANCE INCENTIVE FACTOR  
CALCULATION OF MAXIMUM ALLOWED INCENTIVE DOLLARS  
ACTUAL  
OCTOBER 1995 - MARCH 1996**

Line 1	Beginning of period balance of common equity end of month common equity:	\$1,039,227,974
Line 2	Month of October 1995	\$1,005,966,630
Line 3	Month of November 1995	\$1,033,300,593
Line 4	Month of December 1995	\$1,040,147,535
Line 5	Month of January 1996	\$1,017,740,140
Line 6	Month of February 1996	\$1,062,757,358
Line 7	Month of March 1996	\$1,066,157,188
Line 8	(summation of line 1 through line 7 divided by 7)	\$1,037,899,631
Line 9	25 Basis points	0.0025
Line 10	Revenue expansion factor	61.3738%
Line 11	Maximum allowed incentive Dollars (Line 8 times line 9 divided by line 10 times 0.5)	\$2,113,890
Line 12	Jurisdictional Sales	7128371 MWH
Line 13	Total Sales	7156645 MWH
Line 14	Jurisdictional Separation Factor (Line 12 divided by line 13)	99.60%
Line 15	Maximum Allowed Jurisdictional Incentive Dollars (Line 11 times line 14)	\$2,105,538

**TAMPA ELECTRIC COMPANY  
CALCULATION OF SYSTEM GPIF POINTS  
OCTOBER 1995 - MARCH 1996  
ACTUAL**

<u>PLANT/UNIT</u>	<u>6 MO ADJ ACTUAL PERFORMANCE</u>	<u>WEIGHTING FACTOR %</u>	<u>UNIT POINTS</u>	<u>WEIGHTED UNIT POINTS</u>
GANNON 5	62.6% EAF	0.57%	-1.558	-0.009
GANNON 6	85.0% EAF	3.47%	10.000	0.347
BIG BEND 1	87.4% EAF	6.04%	7.000	0.423
BIG BEND 2	67.3% EAF	4.88%	-0.941	-0.046
BIG BEND 3	84.5% EAF	5.48%	-5.904	-0.324
BIG BEND 4	86.5% EAF	3.16%	10.000	0.316
GANNON 5	10124 ANOHR	7.73%	0.000	0.000
GANNON 6	10677 ANOHR	12.86%	-9.338	-1.201
BIG BEND 1	9908 ANOHR	9.82%	0.000	0.000
BIG BEND 2	9854 ANOHR	12.94%	0.000	0.000
BIG BEND 3	9632 ANOHR	19.03%	0.000	0.000
BIG BEND 4	9936 ANOHR	<u>14.02%</u>	0.000	<u>0.000</u>
				-0.494

GPIF REWARD

(\$104,014)

TAMPA ELECTRIC COMPANY

GPIF TARGET AND RANGE SUMMARY

OCTOBER 1995 - MARCH 1996

EQUIVALENT AVAILABILITY

<u>PLANT/UNIT</u>	<u>WEIGHTING FACTOR (%)</u>	<u>EAF TARGET (%)</u>	<u>EAF MAX. (%)</u>	<u>RANGE MIN. (%)</u>	<u>MAX. FUEL SAVINGS (\$000)</u>	<u>MAX. FUEL LOSS (\$000)</u>	<u>EAF ADJUSTED ACTUAL %</u>	<u>ACTUAL FUEL SAVINGS/LOSS (\$000)</u>
GANNON 5	0.57%	63.6	66.5	57.4	21.5	(72.8)	62.6%	(3.4)
GANNON 6	3.47%	81.9	84.9	75.8	130.1	(240.2)	85.0%	130.1
BIG BEND 1	6.04%	85.4	88.3	79.6	226.7	(445.4)	87.4%	158.7
BIG BEND 2	4.88%	67.9	71.1	61.5	182.9	(449.8)	67.3%	(17.2)
BIG BEND 3	5.48%	87.4	89.9	82.4	205.4	(561.1)	84.5%	(331.3)
BIG BEND 4	3.16%	82.9	84.9	78.6	118.7	(413.7)	86.5%	118.7
GPIF SYSTEM	23.60%				885.3	(2,183.0)		

AVERAGE NET OPERATING HEAT RATE  
FOR  
GPIF COAL GENERATING UNITS

<u>PLANT/UNIT</u>	<u>WEIGHTING FACTOR (%)</u>	<u>ANOHR Btu/kwh</u>	<u>TARGET NOF</u>	<u>ANOHR TARGET RANGE</u>		<u>MAX. FUEL SAVINGS (\$000)</u>	<u>MAX. FUEL LOSS (\$000)</u>	<u>ACTUAL ADJUSTED ANOHR</u>	<u>ACTUAL FUEL SAVINGS/LOSS (\$000)</u>
				<u>MIN.</u>	<u>MAX.</u>				
GANNON 5	7.73%	10178	78.3	9760	10596	289.8	(289.8)	10124	0.0
GANNON 6	12.86%	10348	70.7	10001	10695	482.3	(482.3)	10677	(450.4)
BIG BEND 1	9.82%	9931	90.9	9747	10115	368.4	(368.4)	9908	0.0
BIG BEND 2	12.94%	9837	91.7	9533	10141	485.3	(485.3)	9854	0.0
BIG BEND 3	19.03%	9596	91.5	9244	9948	713.9	(713.9)	9632	0.0
BIG BEND 4	14.02%	9989	91.1	9667	10311	526.4	(526.4)	9936	0.0
GPIF SYSTEM	76.40%					2,866.1	(2,866.1)		

**TAMPA ELECTRIC COMPANY  
ACTUAL UNIT PERFORMANCE DATA  
OCTOBER 1995 - MARCH 1996**

<u>PLANT / UNIT</u>	<u>ACTUAL EAF %</u>	<u>ADJUSTMENTS (1) EAF %</u>	<u>EAF ADJUSTED ACTUAL %</u>
GANNON 5	63.6	-1.0	62.6
GANNON 6	81.9	3.1	85.0
BIG BEND 1	85.4	2.0	87.4
BIG BEND 2	67.9	-0.6	67.3
BIG BEND 3	87.4	-2.9	84.5
BIG BEND 4	82.9	3.6	86.5

<u>PLANT / UNIT</u>	<u>ACTUAL ANOHR Btu/kwh</u>	<u>ADJUSTMENTS (1) TO ANOHR Btu/kwh</u>	<u>ANOHR ADJUSTED ACTUAL Btu/kwh</u>
GANNON 5	10047	77	10124
GANNON 6	10657	20	10677
BIG BEND 1	9940	-32	9908
BIG BEND 2	9906	-52	9854
BIG BEND 3	9763	-131	9632
BIG BEND 4	9995	-59	9936

(1) Documentation of adjustments to Actual EAF on pages 7 - 12

(1) Documentation of adjustments to Actual ANOHR on pages 13 - 18



TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO PERFORMANCE  
GANNON UNIT NO. 5  
OCTOBER 1995 - MARCH 1996

WEIGHTING FACTOR = 0.57%

	<u>6 MO. TARGET</u>	<u>6 MO. ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
P.H.	4393.0	4393.0	4393.0
E.A.F.	63.6	60.4	62.6
P.O.H.	1248.0	1362.3	1248.0
F.O.H. + E.F.O.H.	315.0	288.9	299.8
M.O.H. + E.M.O.H.	38.0	90.3	93.7
P.O.F.	28.4	31.0	28.4
E.F.O.F.	7.2	6.6	6.8
E.M.O.F.	0.9	2.1	2.1

-1.558 E. A. POINTS

ADJUSTMENTS TO E.A.F.

$$\frac{P.H. - TGT\ POH}{P.H. - ACT\ POH} \times (FOH + EFOH + MOH + EMOH) = \text{ADJUSTED EUOH}$$

$$\frac{4393 - 1248}{4393 - 1362} \times (171.0 + 117.9 + 75.9 + 14.4) = 393.5$$

$$\frac{1248 + 394}{4393} \times 100 = 37.4$$

$$100.0 - 37.4 = 62.6$$

- PH - PERIOD HOURS
- EAF - EQUIVALENT AVAILABILITY FACTOR
- POH - PLANNED OUTAGE HOURS
- FOH - FORCED OUTAGE HOURS
- MOH - MAINTENANCE OUTAGE HOURS
- POF - PLANNED OUTAGE FACTOR
- EFOF - EQUIVALENT FORCED OUTAGE FACTOR
- EMOF - EQUIVALENT MAINTENANCE OUTAGE FACTOR

TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO PERFORMANCE  
GANNON UNIT NO. 6  
OCTOBER 1995 - MARCH 1996

WEIGHTING FACTOR = 3.47%

	<u>6 MO. TARGET</u>	<u>6 MO. ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
P.H.	4393.0	4393.0	4393.0
E.A.F.	81.9	84.9	85.0
P.O.H.	168.0	170.2	168.0
F.O.H. + E.F.O.H	524.0	218.2	218.3
M.O.H. + E.M.O.H	106.0	273.6	273.7
P.O.F.	3.8	3.9	3.8
E.F.O.F.	11.9	5.0	5.0
E.M.O.F.	2.4	6.2	6.2

10.000 E. A. POINTS

ADJUSTMENTS TO E.A.F.

$$\frac{P.H. - TGT\ POH}{P.H. - ACT\ POH} \times (FOH + EFOH + MOH + EMOH) = \text{ADJUSTED EUOH}$$

$$\frac{4393 - 168}{4393 - 170} \times (9.5 + 208.7 + 255.7 + 17.9) = 492.1$$

$$\frac{168 + 492}{4393} \times 100 = 15$$

$$100.0 - 15.0 = 85.0$$

PH - PERIOD HOURS  
EAF - EQUIVALENT AVAILABILITY FACTOR  
POH - PLANNED OUTAGE HOURS  
FOH - FORCED OUTAGE HOURS  
MOH - MAINTENANCE OUTAGE HOURS  
EUOH - EQUIVALENT UNPLANNED OUTAGE HOURS  
POF - PLANNED OUTAGE FACTOR  
EFOF - EQUIVALENT FORCED OUTAGE FACTOR

TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO PERFORMANCE  
BIG BEND UNIT NO. 1  
OCTOBER 1995 - MARCH 1996

WEIGHTING FACTOR = 6.04%

	<u>6 MO. TARGET</u>	<u>6 MO. ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
P.H.	4393.0	4393.0	4393.0
E.A.F.	84.5	87.4	87.4
P.O.H.	0.0	0.0	0.0
F.O.H + E.F.O.H	470.0	396.3	396.3
M.O.H + E.M.O.H	171.0	155.9	155.9
P.O.F.	0.0	0.0	0.0
E.F.O.F.	10.7	9.0	9.0
E.M.O.F.	3.9	3.5	3.5

7.000 E. A. POINTS

ADJUSTMENTS TO E.A.F.

$$\frac{P.H. - TGT POH}{P.H. - ACT POH} \times (FOH + EFOH + MOH + EMOH) = \text{ADJUSTED EUOH}$$

$$\frac{4393 - 0}{4393 - 0} \times (271.9 + 124.4 + 36.3 + 119.6) = 552.2$$

$$\frac{0 + 552}{4393} \times 100 = 12.6$$

$$100.0 - 12.6 = 87.4$$

PH - PERIOD HOURS  
EAF - EQUIVALENT AVAILABILITY FACTOR  
POH - PLANNED OUTAGE HOURS  
FOH - FORCED OUTAGE HOURS  
MOH - MAINTENANCE OUTAGE HOURS  
EUOH - EQUIVALENT UNPLANNED OUTAGE HOURS  
POF - PLANNED OUTAGE FACTOR  
EFOF - EQUIVALENT FORCED OUTAGE FACTOR

TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO PERFORMANCE  
BIG BEND UNIT NO. 2  
OCTOBER 1995 - MARCH 1996

WEIGHTING FACTOR = 4.88%

	<u>6 MO. TARGET</u>	<u>6 MO. ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
P.H.	4393.0	4393.0	4393.0
E.A.F.	67.9	85.5	67.3
P.O.H.	936.0	0.0	936.0
F.O.H. + E.F.O.H	380.0	331.8	261.1
M.O.H. + E.M.O.H	93.0	304.4	239.5
P.O.F.	21.3	0.0	21.3
E.F.O.F.	8.7	7.6	5.9
E.M.O.F.	2.1	6.9	5.5

-0.941 E. A. POINTS

ADJUSTMENTS TO E.A.F.

$$\frac{P.H. - TGT\ POH}{P.H. - ACT\ POH} \times (FOH + EFOH + MOH + EMOH) = \text{ADJUSTED EUOH}$$

$$\frac{4393 - 936}{4393 - 0} \times (123.2 + 208.6 + 230.7 + 73.7) = 500.6$$

$$\frac{936 + 501}{4393} \times 100 = 32.7$$

$$100.0 - 32.7 = 67.3$$

- PH - PERIOD HOURS
- EAF - EQUIVALENT AVAILABILITY FACTOR
- POH - PLANNED OUTAGE HOURS
- FOH - FORCED OUTAGE HOURS
- MOH - MAINTENANCE OUTAGE HOURS
- EUOH - EQUIVALENT UNPLANNED OUTAGE HOURS
- POF - PLANNED OUTAGE FACTOR
- EFOF - EQUIVALENT FORCED OUTAGE FACTOR

TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO PERFORMANCE  
BIG BEND UNIT NO. 3  
OCTOBER 1995 - MARCH 1996

WEIGHTING FACTOR = 5.48%

	<u>€ MO. TARGET</u>	<u>6 MO. ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
P.H.	4393.0	4393.0	4393.0
E.A.F.	87.4	75.7	84.5
P.O.H.	0.0	457.1	0.0
F.O.H. + E.F.O.H	387.0	483.9	540.1
M.O.H. + E.M.O.H	167.0	128.2	143.1
P.O.F.	0.0	10.4	0.0
E.F.O.F.	8.8	11.0	12.3
E.M.O.F.	3.8	2.9	3.3

-5.904 E. A. POINTS

ADJUSTMENTS TO E.A.F.

$$\frac{P.H. - TGT\ POH}{P.H. - ACT\ POH} \times (FOH + EFOH + MOH + EMOH) = \text{ADJUSTED EUOH}$$

$$\frac{4393 - 0}{4393 - 457} \times (107.4 + 376.5 + 0.0 + 128.2) = 683.2$$

$$\frac{0 + 683}{4393} \times 100 = 15.5$$

$$100.0 - 15.5 = 84.5$$

PH - PERIOD HOURS  
EAF - EQUIVALENT AVAILABILITY FACTOR  
POH - PLANNED OUTAGE HOURS  
FOH - FORCED OUTAGE HOURS  
MOH - MAINTENANCE OUTAGE HOURS  
EUOH - EQUIVALENT UNPLANNED OUTAGE HOURS  
POF - PLANNED OUTAGE FACTOR  
EFOF - EQUIVALENT FORCED OUTAGE FACTOR

TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO PERFORMANCE  
BIG BEND UNIT NO. 4  
OCTOBER 1995 - MARCH 1996

WEIGHTING FACTOR = 3.16%

	<u>6 MO. TARGET</u>	<u>6 MO. ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
P.H.	4393.0	4393.0	4393.0
E.A.F.	82.9	84.4	86.5
P.O.H.	384.0	484.6	384.0
F.O.H. + E.F.O.H	184.0	83.1	85.2
M.O.H. + E.M.O.H	184.0	118.4	121.4
P.O.F.	8.7	11.0	8.7
E.F.O.F.	4.2	1.9	1.9
E.M.O.F.	4.2	2.7	2.8

10.000 E. A. POINTS

ADJUSTMENTS TO E.A.F.

$$\frac{P.H. - TGT\ POH}{P.H. - ACT\ POH} \times (FOH + EFOH + MOH + EMOH) = \text{ADJUSTED EUOH}$$

$$\frac{4393 - 384}{4393 - 485} \times (3.1 + 80.0 + 29.3 + 89.1) = 206.7$$

$$\frac{384 + 207}{4393} \times 100 = 13.5$$

$$100.0 - 13.5 = 86.5$$

PH - PERIOD HOURS  
EAF - EQUIVALENT AVAILABILITY FACTOR  
POH - PLANNED OUTAGE HOURS  
FOH - FORCED OUTAGE HOURS  
MOH - MAINTENANCE OUTAGE HOURS  
EUOH - EQUIVALENT UNPLANNED OUTAGE HOURS  
POF - PLANNED OUTAGE FACTOR  
EFOF - EQUIVALENT FORCED OUTAGE FACTOR

TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO HEAT RATE  
GANNON UNIT NO. 5  
HEAT RATE DATA  
OCTOBER 1995 - MARCH 1996

WEIGHTING FACTOR = 7.73%

	<u>6 MO. TARGET</u>	<u>6 MO ACTUAL PERFORMANCE</u>
ANOHR (Btu/kwh)	10178	10047
STA. NET GEN. (GWH)	470.5	510.3
OPER. Btu (10 <sup>9</sup> btu)	4788.480	5126.900
NET OUTPUT FACTOR	78.3	81.5

0.000 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON

CURRENT EQUATION  $\text{NOF}(-23.5270) + 12019.7 = \text{ANOHR}$

81.5  $(-23.5270) + 12019.7 = 10101$

10047 - 10101 = -54

10178 + -54 = 10124

ANOHR = AVERAGE NET OPERATING HEAT RATE  
NOF = NET OPERATING FACTOR

TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO HEAT RATE  
GANNON UNIT NO. 6  
HEAT RATE DATA  
OCTOBER 1995 - MARCH 1996

WEIGHTING FACTOR = 12.86%

	<u>6 MO. TARGET</u>	<u>6 MO ACTUAL PERFORMANCE</u>
ANOHR (Btu/kwh)	10348	10657
STA. NET GEN. (GWH)	930.8	1007.8
OPER. Btu (10 <sup>9</sup> btu)	9631.980	10740.300
NET OUTPUT FACTOR	70.7	77.1

-9.338 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON

CURRENT EQUATION  $NOF(-3.0507) + 10563.7 = ANOHR$

77.1 (-3.0507) + 10563.7 = 10328

10657 - 10328 = 329

10348 + 329 = 10677

ANOHR = AVERAGE NET OPERATING HEAT RATE  
NOF = NET OPERATING FACTOR



TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO HEAT RATE  
BIG BEND UNIT NO. 1  
HEAT RATE DATA  
OCTOBER 1995 - MARCH 1996

WEIGHTING FACTOR = 9.82%

	<u>6 MO. TARGET</u>	<u>6 MO ACTUAL PERFORMANCE</u>
ANOHR (Btu/kwh)	9931	9940
STA. NET GEN. (GWH)	1550.1	1502.4
OPER. Btu (10 <sup>9</sup> btu)	15393.900	14934.200
NET OUTPUT FACTOR	90.9	85.3

0.000 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON

CURRENT EQUATION  $NOF(-5.8450) + 10462.1 = ANOHR$

85.3	(-5.8450)	+	10462.1	=	9963
9940	-		9963	=	-23
9931	+		-23	=	9908

ANOHR = AVERAGE NET OPERATING HEAT RATE  
NOF = NET OPERATING FACTOR

TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO HEAT RATE  
BIG BEND UNIT NO. 2  
HEAT RATE DATA  
OCTOBER 1995 - MARCH 1996

WEIGHTING FACTOR = 12.94%

	<u>6 MO. TARGET</u>	<u>6 MO ACTUAL PERFORMANCE</u>
ANOHR (Btu/kwh)	9837	9906
STA. NET GEN. (GWH)	1237.3	1509.8
OPER. Btu (10 <sup>9</sup> btu)	12171.500	14956.900
NET OUTPUT FACTOR	91.7	86.7

0.000 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON

CURRENT EQUATION	NOF(-10.3610) + 10787.2 = ANOHR		
86.7 (-10.3610) + 10787.2	=		9889
9906 -	9889	=	17
9837 +	17	=	9854

ANOHR = AVERAGE NET OPERATING HEAT RATE  
NOF = NET OPERATING FACTOR

TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO HEAT RATE  
BIG BEND UNIT NO. 3  
HEAT RATE DATA  
OCTOBER 1995 - MARCH 1996

WEIGHTING FACTOR = 19.03%

	<u>6 MO. TARGET</u>	<u>6 MO ACTUAL PERFORMANCE</u>
ANOHR (Btu/kwh)	9596	9763
STA. NET GEN. (GWH)	1608.2	1390.5
OPER. Btu (10 <sup>9</sup> btu)	15431.700	13575.100
NET OUTPUT FACTOR	91.5	82.7

0.000 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON

CURRENT EQUATION  $NOF(-14.9350) + 10962.1 = ANOHR$

82.7	(-14.9350)	+	10962.1	=	9727
9763	-		9727	=	36
9596	+		36	=	9632

ANOHR = AVERAGE NET OPERATING HEAT RATE  
NOF = NET OPERATING FACTOR

TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO HEAT RATE  
BIG BEND UNIT NO. 4  
HEAT RATE DATA  
OCTOBER 1995 - MARCH 1996

WEIGHTING FACTOR = 14.02%

	<u>6 MO. TARGET</u>	<u>6 MO. TARGET</u>	<u>6 MO ACTUAL PERFORMANCE</u>
ANOHR (Btu/lwh)	9989	9989	9995
STA. NET GEN. (GWH)	1545.0	1545.0	1450.5
OPER. Btu (10 <sup>9</sup> btu)	15431.800	15431.800	14497.100
NET OUTPUT FACTOR	91.1	91.1	83.7

0.000 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON

CURRENT EQUATION	NOF(-8.0541) + 10722.3	=	ANOHR	
83.7	(-8.0541) + 10722.3	=	10048	
9995	-	10048	=	-53
9989	+	-53	=	9936

ANOHR = AVERAGE NET OPERATING HEAT RATE  
NOF = NET OPERATING FACTOR


TAMPA ELECTRIC COMPANY  
GPIF PLANNED OUTAGE SCHEDULE - ACTUAL  
OCTOBER 1995 - MARCH 1996

<u>STATION/UNIT</u>	<u>PLANNED OUTAGE DATES</u>	<u>OUTAGE REASON</u>
*BIG BEND 3	MAR 14 - APR 1	ANNUAL MAINTENANCE OUTAGE
BIG BEND 4	FEB 17 - MAR 8	ANNUAL MAINTENANCE OUTAGE
GANNON 5	OCT 26 - DEC 21	HP INSPECTION (BORESONIC)* GENERATOR INSPECTION INSP. FRT. STD. INSP. GOV/INT/THRTL. VV'S OUTLET CONDENSER TUBE SHEETS BOILER CHEMECIAL CLN.
GANNON 6	OCT 19 - OCT 25	ANNUAL MAINTENANCE OUTAGE

Milestone or Critical Path Charts of actual schedule are included on page 20.

\*Start / End dates outside of GPIF period.

\*\*Outage is less than two weeks in duration and a CPM was not included for this unit.



TAMPA ELECTRIC COMPANY  
 GANNON UNIT NO. 5  
 PLANNED OUTAGE 1995  
 ACTUAL CPM  
 05/14/96

TAMPA ELECTRIC COMPANY  
GENERATING PERFORMANCE INCENTIVE POINTS TABLE  
OCTOBER 1995 - MARCH 1996  
GANNON 5

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	21.5	66.5	+10	289.8	9760
+9	19.4	66.2	+9	260.8	9794
+8	17.2	65.9	+8	231.8	9829
+7	15.1	65.6	+7	202.9	9863
+6	12.9	65.3	+6	173.9	9897
+5	10.8	65.1	+5	144.9	9932
+4	8.6	64.8	+4	115.9	9966
+3	6.5	64.5	+3	86.9	10000
+2	4.3	64.2	+2	58.0	10034
+1	2.2	63.9	+1	29.0	10069
0	0.0	63.6	0	0.0	10103
				0.0	10178
				0.0	10253
-1	(7.3)	63.0	-1	(29.0)	10287
-2	(14.6)	62.4	-2	(58.0)	10322
-3	(21.8)	61.7	-3	(86.9)	10356
-4	(29.1)	61.1	-4	(115.9)	10390
-5	(36.4)	60.5	-5	(144.9)	10425
-6	(43.7)	59.9	-6	(173.9)	10459
-7	(51.0)	59.3	-7	(202.9)	10493
-8	(58.2)	58.6	-8	(231.8)	10527
-9	(65.5)	58.0	-9	(260.8)	10562
-10	(72.8)	57.4	-10	(289.8)	10596

← <b>EAF POINTS -1.558</b> →	<b>Adjusted EAF 62.6%</b>	← <b>AHR POINTS 8.990</b> →	<b>Adjusted Actual ANOHR 10124</b> →
Weighting Factor =	0.57%	Weighting Factor =	7.73%

TAMPA ELECTRIC COMPANY  
GENERATING PERFORMANCE INCENTIVE POINTS TABLE  
OCTOBER 1995 - MARCH 1996  
GANNON 6

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	130.1	84.9	+10	482.3	9760
+9	117.1	84.6	+9	434.1	9811
+8	104.1	84.3	+8	385.8	9863
+7	91.1	84.0	+7	337.6	9914
+6	78.1	83.7	+6	289.4	9965
+5	65.1	83.4	+5	241.2	10017
+4	52.0	83.1	+4	192.9	10068
+3	39.0	82.8	+3	144.7	10119
+2	26.0	82.5	+2	96.5	10170
+1	13.0	82.2	+1	48.2	10222
0	0.0	81.9	0	0.0	10273
-1	(24.0)	81.3	-1	(48.2)	10348
-2	(48.0)	80.7	-2	(96.5)	10423
-3	(72.1)	80.1	-3	(144.7)	10450
-4	(96.1)	79.5	-4	(192.9)	10477
-5	(120.1)	78.9	-5	(241.2)	10505
-6	(144.1)	78.2	-6	(289.4)	10532
-7	(168.1)	77.6	-7	(337.6)	10559
-8	(192.2)	77.0	-8	(385.8)	10586
-9	(216.2)	76.4	-9	(434.1)	10613
-10	(240.2)	75.8	-10	(482.3)	10641

<div style="border: 1px solid black; padding: 2px; display: inline-block;">EAF POINTS 18.000</div>	<div style="border: 1px solid black; padding: 2px; display: inline-block;">Adjusted EAF 25.0%</div>	<div style="border: 1px solid black; padding: 2px; display: inline-block;">AHR POINTS -9.338</div>	<div style="border: 1px solid black; padding: 2px; display: inline-block;">Adjusted Actual AHR 10677</div>
Weighting Factor =	3.47%	Weighting Factor =	12.86%



TAMPA ELECTRIC COMPANY  
 GENERATING PERFORMANCE INCENTIVE POINTS TABLE  
 OCTOBER 1995 - MARCH 1996  
 BIG BEND 1

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	226.7	88.3	+10	368.4	9747
+9	204.0	88.0	+9	331.6	9758
+8	181.4	87.7	+8	294.7	9769
+7	158.7	87.4	+7	257.9	9780
+6	136.0	87.1	+6	221.0	9791
+5	113.4	86.9	+5	184.2	9802
+4	90.7	86.6	+4	147.4	9812
+3	68.0	86.3	+3	110.5	9823
+2	45.3	86.0	+2	73.7	9834
+1	22.7	85.7	+1	36.8	9845
0	0.0	85.4	0	0.0	9856
-1	(44.5)	84.8	-1	(36.8)	10017
-2	(89.1)	84.2	-2	(73.7)	10028
-3	(133.6)	83.7	-3	(110.5)	10039
-4	(178.2)	83.1	-4	(147.4)	10050
-5	(222.7)	82.5	-5	(184.2)	10061
-6	(267.2)	81.9	-6	(221.0)	10071
-7	(311.8)	81.3	-7	(257.9)	10082
-8	(356.3)	80.8	-8	(294.7)	10093
-9	(400.9)	80.2	-9	(331.6)	10104
-10	(445.4)	79.6	-10	(368.4)	10115

EAP POINTS 7.000      Adjusted EAP 87.4

AHR POINTS 0.000      Adjusted Actual AHR 9908

Weighting Factor =                      6.04%                      Weighting Factor =                      9.82%

TAMPA ELECTRIC COMPANY  
GENERATING PERFORMANCE INCENTIVE POINTS TABLE  
OCTOBER 1995 - MARCH 1996  
BIG BEND 2

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	182.9	71.1	+10	485.3	9533
+9	164.6	70.8	+9	436.8	9556
+8	146.3	70.5	+8	388.2	9579
+7	128.0	70.1	+7	339.7	9602
+6	109.7	69.8	+6	291.2	9625
+5	91.5	69.5	+5	242.7	9648
+4	73.2	69.2	+4	194.1	9670
+3	54.9	68.9	+3	145.6	9693
+2	36.6	68.5	+2	97.1	9716
+1	18.3	68.2	+1	48.5	9739
0	0.0	67.9	0	0.0	9762
-1	(45.0)	67.3	-1	(48.5)	9935
-2	(90.0)	66.6	-2	(97.1)	9958
-3	(134.9)	66.0	-3	(145.6)	9981
-4	(179.9)	65.3	-4	(194.1)	10004
-5	(224.9)	64.7	-5	(242.7)	10027
-6	(269.9)	64.1	-6	(291.2)	10049
-7	(314.9)	63.4	-7	(339.7)	10072
-8	(359.8)	62.8	-8	(388.2)	10095
-9	(404.8)	62.1	-9	(436.8)	10118
-10	(449.8)	61.5	-10	(485.3)	10141

← <b>EAF POINTS -8.941</b>	<b>Adjusted EAF 67.3%</b> →	← <b>AJR POINTS 8.000</b>	<b>Adjusted Actual AJR 9854</b> →
Weighting Factor =	4.88%	Weighting Factor =	12.94%

TAMPA ELECTRIC COMPANY  
GENERATING PERFORMANCE INCENTIVE POINTS TABLE  
OCTOBER 1995 - MARCH 1995  
BIG BEND 3

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	205.4	89.9	+10	713.9	9244
+9	184.9	89.7	+9	642.5	9272
+8	164.3	89.4	+8	571.1	9299
+7	143.8	89.2	+7	499.7	9327
+6	123.2	88.9	+6	428.3	9355
+5	102.7	88.7	+5	357.0	9383
+4	82.2	88.4	+4	285.6	9410
+3	61.6	88.2	+3	214.2	9438
+2	41.1	87.9	+2	142.8	9466
+1	20.5	87.7	+1	71.4	9493
0	0.0	87.4	0	0.0	9521
-1	(56.1)	86.9	-1	(71.4)	9556
-2	(112.2)	86.4	-2	(142.8)	9596
-3	(168.3)	85.9	-3	(214.2)	9637
-4	(224.4)	85.4	-4	(285.6)	9671
-5	(280.6)	84.9	-5	(357.0)	9699
-6	(336.7)	84.4	-6	(428.3)	9726
-7	(392.8)	83.9	-7	(499.7)	9754
-8	(448.9)	83.4	-8	(571.1)	9782
-9	(505.0)	82.9	-9	(642.5)	9810
-10	(561.1)	82.4	-10	(713.9)	9837

← <b>EAP POINTS -5.994</b> →	<b>Adjusted EAP 84.5%</b> →	← <b>AHR POINTS 8.800</b> →	<b>Adjusted Actual AVERAGE 9633</b> →
--------------------------------------	-------------------------------------	-------------------------------------	---

Weighting Factor =	5.48%	Weighting Factor =	19.03%
--------------------	-------	--------------------	--------

TAMPA ELECTRIC COMPANY  
GENERATING PERFORMANCE INCENTIVE POINTS TABLE  
OCTOBER 1995 - MARCH 1996  
BIG BEND 4

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	118.7	\$4.9	+10	526.4	9667
+9	106.8	\$4.7	+9	473.8	9692
+8	95.0	\$4.5	+8	421.1	9716
+7	83.1	\$4.3	+7	368.5	9741
+6	71.2	\$4.1	+6	315.8	9766
+5	59.4	\$3.9	+5	263.2	9791
+4	47.5	\$3.7	+4	210.6	9815
+3	35.6	\$3.5	+3	157.9	9840
+2	23.7	\$3.3	+2	105.3	9865
+1	11.9	\$3.1	+1	52.6	9889
0	0.0	\$2.9	0	0.0	9914
-1	(41.4)	\$2.5	-1	(52.6)	9989
-2	(82.7)	\$2.0	-2	(105.3)	10064
-3	(124.1)	\$1.6	-3	(157.9)	10089
-4	(165.5)	\$1.2	-4	(210.6)	10113
-5	(206.9)	\$0.8	-5	(263.2)	10138
-6	(248.2)	\$0.3	-6	(315.8)	10163
-7	(289.6)	79.9	-7	(368.5)	10188
-8	(331.0)	79.5	-8	(421.1)	10212
-9	(372.3)	79.0	-9	(473.8)	10227
-10	(413.7)	78.6	-10	(526.4)	10262
					10286
					10311

EAP POINTS 18,000	Adjusted EAP 84.5%	AHR POINTS 8,000	Adjusted Actual AHR 9936
-------------------	--------------------	------------------	--------------------------

Weighting Factor =	3.16%	Weighting Factor =	14.02%
--------------------	-------	--------------------	--------

TAMPA ELECTRIC COMPANY

COMPARISON OF GPIF TARGETS VS. PRIOR PERIOD ACTUAL PERFORMANCE

OCTOBER 1995 - MARCH 1996

AVAILABILITY

PLANT/UNIT	TARGET WEIGHTING FACTOR	NORMALIZED WEIGHTING FACTOR	TARGET PERIOD OCT 95 - MAR 96			ACTUAL PERFORMANCE OCT 95 - MAR 96		
			POF	EUOF	EUOR	POF	EUOF	EUOR
BIG BEND 1	6.04%	25.6	0.0	14.6	14.6	0.0	12.6	12.6
BIG BEND 2	4.88%	20.7	21.3	10.8	13.7	0.0	14.5	14.5
BIG BEND 3	5.48%	23.2	0.0	12.6	12.6	10.4	13.9	15.6
BIG BEND 4	3.16%	13.4	8.7	8.4	9.2	11.0	4.6	5.2
GANNON 5	0.57%	2.4	28.4	8.0	11.2	31.0	8.6	12.5
GANNON 6	3.47%	14.7	3.8	14.3	14.9	3.9	11.2	11.6
	23.60%	100.0						
GPIF SYSTEM WEIGHTED AVERAGE			6.8	12.3	13.2	5.3	11.9	12.5
GPIF SYSTEM WEIGHTED EQUIVALENT AVAILABILITY			80.9			82.9		
			5 PERIOD AVERAGE			5 PERIOD AVERAGE		
			POF	EUOF	EUOR	EAF		
			8.8	11.4	12.9	79.8		

AVERAGE NET OPERATING HEAT RATE (Btu/kwh)

PLANT/UNIT	TARGET WEIGHTING FACTOR	NORMALIZED WEIGHTING FACTOR	HEAT RATE TARGET	ADJUSTED
				ACTUAL HEAT RATE APR 95 - SEP 95
GANNON 5	7.73%	10.1	10178	10124
GANNON 6	12.86%	16.8	10348	10677
BIG BEND 1	9.82%	12.9	9931	9908
BIG BEND 2	12.94%	16.9	9837	9854
BIG BEND 3	19.03%	24.9	9596	9632
BIG BEND 4	14.02%	18.4	9989	9936
	76.40%	100.0		
GPIF SYSTEM WEIGHTED AVERAGE HEAT RATE (Btu/kwh)			9937	9987

**TAMPA ELECTRIC COMPANY  
GENERATING PERFORMANCE INCENTIVE POINTS CALCULATION  
OCTOBER 1995 - MARCH 1996**

Points are calculated according to the formula:

$$\text{GPIP} = \sum_{i=1}^n [(a_i)(\text{EAP}_i) + (e_i)(\text{AHRP}_i)]$$

Where:

$i=1,n$

$a$  = Unit equivalent availability weighting factor

EAP = Unit equivalent availability points

$e$  = Station average heat rate weighting factor

AHRP = Station average heat rate points

Weighting factors and point values are listed in separate tables.

GPIP =	0.57% * (GN 5 EAP)	+	3.47% * (GN 6 EAP)	+	6.04% * (BB 1 EAP)
	+ 4.88% * (BB 2 EAP)		+ 5.48% * (BB 3 EAP)		+ 3.16% * (BB 4 EAP)
	+ 7.73% * (GN 5 AHRP)		+ 12.86% * (GN 6 AHRP)		+ 9.82% * (BB 1 AHRP)
	+ 12.94% * (BB 2 AHRP)		+ 19.03% * (BB 3 AHRP)		+ 14.02% * (BB 4 AHRP)

GPIP =	0.57% * -1.558	+	3.47% * 10.000	+	6.04% * 7.000
	+ 4.88% * -0.941		+ 5.48% * -5.904		+ 3.16% * 10.000
	+ 7.73% * 0.000		+ 12.86% * -9.338		+ 9.82% * 0.000
	+ 12.94% * 0.000		+ 19.03% * 0.000		+ 14.02% * 0.000

GPIP =	-0.009	+	0.347	+	0.423	+	-0.046
	+ -0.324		+ 0.316		+ 0.000		+ -1.201
	+ 0.000		+ 0.000		+ 0.000		+ 0.000

GPIP = -0.494 POINTS

REWARD/PENALTY dollar amounts of the Generating Performance Incentive Factor (GPIF) are determined directly from the table for the corresponding Generating Performance Points (GPIP) - see page 2.

GPIP = (\$104,014)