

# AUSLEY & McMULLEN

ATTORNEYS AND COUNSELORS AT LAW

ORIGINAL  
COPY

227 SOUTH CALHOUN STREET  
P.O. BOX 391 (ZIP 32302)  
TALLAHASSEE, FLORIDA 32301  
(904) 224-9115 FAX (904) 222-7560

June 23, 1997

HAND DELIVERED

Ms. Blanca S. Bayo, Director  
Division of Records and Reporting  
Florida Public Service Commission  
2540 Shumard Oak Boulevard  
Tallahassee, Florida 32399-0850

Re: Fuel and Purchased Power Cost Recovery Clause  
with Generating Performance Incentive Factor;  
FPSC Docket No. 970001-EI

Dear Ms. Bayo:

Enclosed for filing in the above docket, on behalf of Tampa Electric Company, are ten copies of each of the following:

1. Petition of Tampa Electric Company. *06/25/97*
2. Prepared Direct Testimony of Karen A. Branick and Exhibit (KAB-2) regarding Tampa Electric's projected Total Fuel and Purchased Power Cost Recovery Factors, Exhibit (KAB-3) regarding projected Capacity Cost Recovery Factors for the period October 1997 through March 1998 and Exhibit KAB-4 regarding the company's Deferred Revenue Plan \$25 million refund during the period October 1997 through December 1998. *06/25/97*
3. Prepared Direct Testimony of George A. Keselowsky with Exhibits (GAK-2) and (GAK-3) regarding Tampa Electric Company's projected performance under the Generating Performance Incentive Factor for the period October 1997 through March 1998.

ACK *Dandeneau*  
AFA \_\_\_\_\_  
APP \_\_\_\_\_  
CAF \_\_\_\_\_  
CMU \_\_\_\_\_  
CTR \_\_\_\_\_  
EAG *Bao*  
LEG *1*  
LIN *3708*  
OPC \_\_\_\_\_  
RCH \_\_\_\_\_  
SEC *1* Pursuant to an agreement with Staff, Tampa Electric will file on Wednesday, June 25, 1997, Prepared Direct Testimony of Charles R. Black with Exhibit CRB-1 regarding 1996 transportation and coal benchmark calculations. The company will also file on that date, pursuant to Staff's agreement, Supplemental Direct Testimony of Karen A. Branick and Exhibit KAB-5 and Prepared Direct Testimony of Gerard J. Kordecki, all pertaining to the effect of FERC open access orders on Florida Broker Transactions.  
WAS \_\_\_\_\_  
OTH \_\_\_\_\_

Ms. Blanca S. Bayo  
June 23, 1997  
Page 2

Please acknowledge receipt and filing of the above by stamping the duplicate copy of this letter and returning same to this writer.

Thank you for your assistance in connection with this matter.

Sincerely,



James D. Beasley

JDB/pp  
Enclosures

cc: All Parties of Record (w/encls.)

ORIGINAL  
FILE COPY

TAMPA ELECTRIC COMPANY  
DOCKET NO. 970001-EI  
SUBMITTED FOR FILING 6/23/97  
(PROJECTION)

1 BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION  
2 PREPARED DIRECT TESTIMONY  
3 OF  
4 GEORGE A. KESELOWSKY

5  
6 Q. Will you please state your name, business address, and  
7 employer?

8  
9 A. My name is George A. Keselowsky and my business address is  
10 Post Office Box 111, Tampa, Florida 33601. I am employed  
11 by Tampa Electric Company.

12  
13 Q. Please furnish us with a brief outline of your educational  
14 background and business experience.

15  
16 A. I graduated in 1972 from the University of South Florida  
17 with a Bachelor of Science Degree in Mechanical  
18 Engineering. I have been employed by Tampa Electric  
19 Company in various engineering positions since that time.  
20 My current position is that of Senior Consulting Engineer  
21 - Energy Supply Engineering.

22  
23 Q. What are your current responsibilities?

24  
25 A. I am responsible for testing and reporting unit

1 DOCUMENT NUMBER-DATE  
06258 JUN 23 5

FPSO-RECORDS/REPORTING

1           performance, and the compilation and reporting of  
2           generation statistics.

3

4       Q.     What is the purpose of your testimony?

5

6       A.     My testimony presents Tampa Electric Company's methodology  
7           for determining the various factors required to compute the  
8           Generating Performance Incentive Factor (GPIF) as ordered  
9           by this Commission.

10

11      Q.     Have you prepared an exhibit showing the various elements  
12           of the derivation of Tampa Electric Company's GPIF formula?

13

14      A.     Yes, I have prepared, under my direction and supervision,  
15           an exhibit entitled "Tampa Electric Company, Generating  
16           Performance Incentive Factor" October 1997 - March 1998,  
17           consisting of 34 pages filed with the Commission on  
18           June 23, 1997. (Have identified as Exhibit GAK-2). The  
19           data prepared within this exhibit is consistent with the  
20           GPIF Implementation Manual previously approved by this  
21           Commission.

22

23

24

25

- 1     Q. Which generating units on Tampa Electric Company's system  
2       are included in the determination of your GPIF?  
3  
4     A. Six of our coal-fired units are included. These are:  
5       Gannon Station Units 5 and 6; and Big Bend Station Units 1,  
6       2, 3, and 4.  
7  
8     Q. Will you describe how Tampa Electric Company evolved the  
9       various factors associated with the GPIF as ordered by this  
10      Commission?  
11  
12    A. Yes. First, the two factors to be used, as set forth by  
13       the Commission Staff, are unit availability and station  
14       heat rate.  
15  
16    Q. Please continue.  
17  
18    A. A target was established for equivalent availability for  
19       each unit considered for this period. Heat rate targets  
20       were also established for each unit. A range of potential  
21       improvement and degradation was determined for each of  
22       these parameters.  
23  
24  
25

1 Q. Would you describe how the target values for unit  
2 availability were determined?

3

4 A. Yes I will. The Planned Outage Factor (POF) and the  
5 Equivalent Unplanned Outage Factor (EUOF) were subtracted  
6 from 100% to determine the target equivalent availability.  
7 The factors for each of the 6 units included within the  
8 GPIF are shown on page 5 of my exhibit. For example, the  
9 projected EUOF for Big Bend Unit One is 13.0%. The Planned  
10 Outage Factor for this same unit during this period is  
11 7.7%. Therefore, the target equivalent availability for  
12 this unit equals:

13

14  $100\% - [(13.0\% + 7.7\%)] = 79.3\%$

15

16 This is shown on page 4, column 3 of my exhibit.

17

18 Q. How was the potential for unit availability improvement  
19 determined?

20

21 A. Maximum equivalent availability is arrived at using the  
22 following formula.

23

24

25

1                   Equivalent Availability Maximum

2                    $EAF_{MAX} = 100\% - [0.8 (EUOF_t) + 0.95 (POF_t)]$

3  
4                   The factors included in the above equations are the same  
5                   factors that determine target equivalent availability. To  
6                   attain the maximum incentive points, a 20% reduction in  
7                   Forced Outage and Maintenance Outage Factors (EUOF), plus  
8                   a 5% reduction in the Planned Outage Factor (POF) will be  
9                   necessary. Continuing with our example on Big Bend Unit  
10                  One:

11  
12                   $EAF_{MAX} = 100\% - [0.8 (13.0\%) + 0.95 (7.7\%)] = 82.3\%$

13  
14                  This is shown on page 4, column 4 of my exhibit.

15  
16                  Q. How was the potential for unit availability degradation  
17                  determined?

18  
19                  A. The potential for unit availability degradation is  
20                  significantly greater than is the potential for unit  
21                  availability improvement. This concept was discussed  
22                  extensively and approved in earlier hearings before this  
23                  Commission. Tampa Electric Company's approach to  
24                  incorporating this skewed effect into the unit availability  
25                  tables is to use a potential degradation range equal to

1           twice the potential improvement. Consequently, minimum  
2           equivalent availability is arrived at via the following  
3           formula:

4

5           Equivalent Availability Minimum

6            $EAF_{MIN} = 100\% - [1.4 (EUOF_T) + 1.10 (POF_T)]$

7

8           Again, continuing with our example of Big Bend Unit One,

9

10           $EAF_{MIN} = 100\% - [1.4 (13.0\%) + 1.1 (7.7\%)] = 73.3\%$

11

12          Equivalent availability MAX and MIN for the other five  
13          units is computed in a similar manner.

14

15          Q. How do you arrive at the Planned Outage, Maintenance Outage  
16          and Forced Outage Factors?

17

18          A. Our planned outages for this period are shown on page 19 of  
19          my exhibit. A Critical Path Method (C.P.M.) for each major  
20          planned outage which affects GPIP is included in my  
21          exhibit. For example, Big Bend Unit 3 is scheduled for an  
22          annual maintenance outage November 1 to November 21, 1997.  
23          There are 504 planned outage hours scheduled for the winter  
24          1997 period, and a total of 4369 hours during this 6 month  
25          period. Consequently, the Planned Outage Factor for Unit 3

1       at Big Bend is  $504/4369 \times 100\%$  or 11.5%. This factor is  
2       shown on pages 5 and 17 of my exhibit. Big Bend Unit 1 has  
3       a planned outage factor of 7.7% as does Big Bend Unit 2.  
4       Big Bend Units 3 and 4 have planned outage factors of  
5       11.5%, as does Gannon Unit 5. Gannon Unit 6 has a planned  
6       outage factor of 1.1%.

7

8       Q. How did you arrive at the Forced Outage and Maintenance  
9       Outage Factors on each unit?

10

11      A. Graphs of both of these factors (adjusted for planned  
12       outages) vs. time are prepared. Both monthly data and 12  
13       month moving average data are recorded. For each unit the  
14       most current, March 1997, 12 month ending value was used as  
15       a basis for the projection. This value was adjusted up or  
16       down by analyzing trends and causes for recent forced and  
17       maintenance outages. All projected factors are based upon  
18       historical unit performance, engineering judgment, time  
19       since last planned outage, and equipment performance  
20       resulting in a forced or maintenance outage. These target  
21       factors are additive and result in a EUOF of 13.0% for Big  
22       Bend Unit One. The Equivalent Unplanned Outage Factor  
23       (EUOF) for Big Bend Unit One is verified by the data shown  
24       on page 15, lines 3, 5, 10 and 11 of my exhibit and  
25       calculated using the formula:

$$\text{EUOF} = \frac{(\text{FOH} + \text{EFOH} + \text{MOH} + \text{EMOH})}{\text{Period Hours}} \times 100$$

or

$$\text{EUIO!} = \frac{(400 + 168)}{4369} \times 100 = 13.0\%$$

Relative to Big Bend Unit One, the EUOF of 13.0% forms the basis of our Equivalent Availability target development as shown on sheets 4 and 5 of my exhibit.

Please continue with your review of the remaining units.

## Big Bend Unit One

A. The projected EUOF for this unit is 13.0% during this period. This unit will have a planned outage this period and the Planned Outage Factor is 7.7%. This results in a target equivalent availability of 79.3% for the period.

## Big Bend Unit Two

The projected EUOF for this unit is 12.6%. This unit will have a planned outage during this period and the Planned Outage Factor is 7.7%. Therefore, the target equivalent availability for this unit is 79.7%.

### Big Bend Unit Three

The projected EUOF for this unit is 14.4%. This unit will have a planned outage this period and the Planned Outage Factor is 11.5%. Therefore, the target equivalent availability for this unit is 74.1%.

## Big Bend Unit Four

The projected EUOF for this unit is 7.4%. This unit will have a planned outage during this period and the Planned Outage Factor is 11.5%. This results in a target equivalent availability of 81.1% for the period.

## Gannon Unit Five

The projected EUOF for this unit is 11.1%. This unit will have a planned outage during this period and the Planned Outage Factor is 11.5%. Therefore, the target equivalent availability for this unit is 77.3%.

## Gannon Unit Six

The projected EUOF for this unit is 10.5%. This unit will have a planned outage during this period and the Planned Outage Factor is 1.1%. Therefore, the target equivalent availability for this unit is 88.4%.

1 Q. Would you summarize your testimony regarding Equivalent  
2 Availability Factor (EAF), Equivalent Unplanned Outage  
3 Factor (EUOF) and Equivalent Unplanned Outage Rate (EUOR)?

4  
5 A. Yes I will. Please note on page 5 that the GPIF system  
6 weighted Equivalent Availability Factor (EAF) equals 78.2%.  
7 This target compares very favorably to previous GPIF  
8 periods when compared on a common planned outage factor  
9 basis. These targets represent an outstanding level of  
10 performance for our system.

11  
12 Q. As you graph and monitor Forced and Maintenance Outage  
13 Factors, why are they adjusted for planned outage hours?

14  
15 A. This adjustment makes these factors more accurate and  
16 comparable. Obviously, a unit in a planned outage stage or  
17 reserve shutdown stage will not incur a forced or  
18 maintenance outage. Since our units are usually base  
19 loaded, reserve shutdown is generally not a factor. To  
20 demonstrate the effects of a planned outage, note the EUOR  
21 and EUOF for Gannon Unit Six on page 14. During the months  
22 of October through February, EUOF and EUOR are equal. This  
23 is due to the fact that no planned outages are scheduled  
24 during these months. During the month of March, EUOR  
25 exceeds EUOF. The reason for this difference is the

1           scheduling of a planned outage. The adjusted factors apply  
2           to the period hours after planned outage hours have been  
3           extracted.

4

5       Q. Does this mean that both rate and factor data are used in  
6           calculated data?

7

8       A. Yes it does. Rates provide a proper and accurate method of  
9           arriving at the unit parameters. These are then converted  
10          to factors since they are directly additive. That is, the  
11          Forced Outage Factor + Maintenance Outage Factor + Planned  
12          Outage Factor + Equivalent Availability = 100%. Since  
13          factors are additive, they are easier to work with and to  
14          understand.

15

16       Q. Has Tampa Electric Company prepared the necessary heat rate  
17           data required for the determination of the Generating  
18           Performance Incentive Factor?

19

20       A. Yes. Target heat rates as well as ranges of potential  
21           operation have been developed as required.

22

23       Q. How were these targets determined?

24

25       A. Net heat rate data for the three most recent winter

1        periods, along with the PROMOD III program, formed the  
2        basis of our target development. Projections of unit  
3        performance were made with the aid of PROMOD III. The  
4        historical data and the target values are analyzed to  
5        assure applicability to current conditions of operation.  
6        This provides assurance that any periods of abnormal  
7        operations, or equipment modifications having material  
8        effect on heat rate can be taken into consideration.

9  
10      Q. The accomplishment of scrubbing the flue gas from Big Bend  
11       Unit 3 requires an additional amount of station service  
12       power. How do you plan to address the associated effect to  
13       net heat rate for GPIF purposes?

14  
15      A. The change in heat rate for this unit resulting from increased  
16       utilization of the Unit 4 scrubber can be quantified, but the  
17       operational history is short of GPIF guidelines. The target for  
18       Big Bend 3 has, therefore, been developed in the standard  
19       fashion using data without scrubber power. In order to assure  
20       compatibility with this target, scrubber power will be removed  
21       prior to calculating Unit 3 heat rate for the subsequent True-Up  
22       process. This method has been reviewed and approved by the PSC  
23       Staff to be employed until there is sufficient history to meet  
24       target preparation guidelines. Successful implementation of this  
25       innovation to maximize the potential of existing plant

1           equipment, represents a major cost savings and a significant  
2           benefit for our customers.

3

4       Q. Have you developed the heat rate targets in accordance with  
5           GPIF guidelines?

6

7       A. Yes.

8

9       Q. How were the ranges of heat rate improvement and heat rate  
10           degradation determined?

11

12      A. The ranges were determined through analysis of historical  
13           net heat rate and net output factor data. This is the same  
14           data from which the net heat rate vs. net output factor  
15           curves have been developed for each unit. This information  
16           is shown on pages 26 through 31 of my exhibit.

17

18      Q. Would you elaborate on the analysis used in the  
19           determination of the ranges?

20

21      A. The net heat rate vs. net output factor curves are the results  
22           of a first order curve fit to historical data. The standard  
23           error of the estimate of this data was determined, and a factor  
24           was applied to produce a band of potential improvement and  
25           degradation. Both the curve fit and the standard error of the

1 estimate were performed by computer program for each unit. These  
2 curves are also used in post period adjustments to actual heat  
3 rates to account for unanticipated changes in unit dispatch.

4

5 Q. Can you summarize your heat rate projection for the winter  
6 1997 period?

7

8 A. Yes. The heat rate target for Big Bend Unit 1 is 10,084  
9 Btu/Net kwh. The range about this value, to allow for  
10 potential improvement or degradation, is  $\pm 237$  Btu/Net kwh.  
11 The heat rate target for Big Bend Unit 2 is 9,961 Btu/Net  
12 kwh with a range of  $\pm 345$  Btu/Net kwh. The heat rate target  
13 for Big Bend Unit 3 is 9,680 Btu/Net kwh, with a range of  
14  $\pm 362$  Btu/Net kwh. The heat rate target for Big Bend Unit  
15 4 is 10,025 Btu/Net kwh with a range of  $\pm 315$  Btu/Net kwh.  
16 The heat rate target for Gannon Unit 5 is 10,378 Btu/Net  
17 kwh with a range of  $\pm 392$  Btu/Net kwh. The heat rate target  
18 for Gannon Unit 6 is 10,692 Btu/Net kwh with a range of  
19  $\pm 393$  Btu/Net kwh. A zone of tolerance of  $\pm 75$  Btu/Net kwh  
20 is included within the range for each target. This is  
21 shown on page 4, and pages 7 through 12 of my exhibit.

22

23

24

25

1     Q. Do you feel that the heat rate targets and ranges in your  
2       projection meet the criteria of the GPIF and the philosophy  
3       of this Commission?

4

5     A. Yes I do.

6

7     Q. After determining the target values and ranges for average  
8       net operating heat rate and equivalent availability, what  
9       is the next step in the GPIF?

10

11    A. The next step is to calculate the savings and weighting  
12      factor to be used for both average net operating heat rate  
13      and equivalent availability. This is shown on pages 7  
14      through 12. Our PROMOD III cost simulation model was used  
15      to calculate the total system fuel cost if all units  
16      operated at target heat rate and target availability for  
17      the period. This total system fuel cost of \$114,813,500 is  
18      shown on page 6 column 2.

19

20      The PROMOD III output was then used to calculate total  
21      system fuel cost with each unit individually operating at  
22      maximum improvement in equivalent availability and each  
23      station operating at maximum improvement in average net  
24      operating heat rate. The respective savings are shown on  
25      page 6 column 4. After all the individual savings are

1       calculated, column 4 is totaled: \$4,133,500 reflects the  
2       savings if all units operated at maximum improvement. A  
3       weighting factor for each parameter is then calculated by  
4       dividing individual savings by the total. For Big Bend  
5       Unit Two, the weighting factor for equivalent availability  
6       is 5.22% as shown in the right hand column on page 6.  
7       Pages 7 thru 12 show the point table, the Fuel  
8       Savings/(Loss), and the equivalent availability or heat  
9       rate value. The individual weighting factor is also shown.  
10      For example, on Big Bend Unit Two, page 10, if the unit  
11      operates at 82.6% equivalent availability, fuel savings  
12      would equal \$215,700 and 10 equivalent availability points  
13      would be awarded.

14  
15      The Generating Performance Incentive Factor Reward/Penalty  
16      Table on page 2 is a summary of the tables on pages 7  
17      through 12. The left hand column of this document shows  
18      the Tampa Electric Company's incentive points. The center  
19      column shows the total fuel savings and is the same amount  
20      as shown on page 6, column 4, \$4,133,500. The right hand  
21      column of page 2 is the estimated reward or penalty based  
22      upon performance.

23  
24  
25

- 1 Q. How were the maximum allowed incentive dollars determined?  
2
- 3 A. Referring to my exhibit on page 3, line 8, the estimated  
4 average common equity for the period October 1997 - March  
5 1998 is shown to be \$1,157,214,571. This produces the  
6 maximum allowed jurisdictional incentive dollars of  
7 \$2,351,688 shown on line 15.
- 8
- 9 Q. Is there any other constraint set forth by this Commission  
10 regarding the magnitude of incentive dollars?
- 11
- 12 A. Yes. Incentive dollars are not to exceed fifty percent of  
13 fuel savings. Page 2 of my exhibit demonstrates that the  
14 maximum allowed incentive dollars have been reduced to meet  
15 this constraint.
- 16
- 17 Q. Do you wish to summarize your testimony on the GPIF?
- 18
- 19 A. Yes. To the best of my knowledge and understanding, Tampa  
20 Electric Company has fully complied with the Commission's  
21 directions, philosophy, and methodology in our  
22 determination of Generating Performance Incentive Factor.  
23 The GPIF for Tampa Electric Company is expressed by the  
24 following formula for calculating Generating Performance  
25 Incentive Points (GPIP):

1           GPIP = ( 0.0146 EAP<sub>GNS</sub> + 0.0101 EAP<sub>GU</sub>  
2                   + 0.0416 EAP<sub>BB1</sub> + 0.0522 EAP<sub>BB2</sub>  
3                   + 0.0798 EAP<sub>BB3</sub> + 0.0398 EAP<sub>BB4</sub>  
4                   + 0.0740 HRP<sub>GNS</sub> + 0.1185 HRP<sub>GU</sub>  
5                   + 0.1067 HRP<sub>BB1</sub> + 0.1614 HRP<sub>BB2</sub>  
6                   + 0.1522 HRP<sub>BB3</sub> + 0.1491 HRP<sub>BB4</sub>)

7           Where:

8           GPIP = Generating performance incentive points.

9           EAP = Equivalent availability points awarded/deducted for  
10               Units 5 and 6 at Gannon and Units 1, 2, 3 and 4 at  
11               Big Bend.

12           HRP = Average net heat rate points awarded/deducted for  
13               Units 5 and 6 at Gannon and Units 1, 2, 3 and 4 at  
14               Big Bend.

15  
16           Q. Have you prepared a document summarizing the GPIF targets  
17               for the October 1997 - March 1998 period?

18  
19           A. Yes. The availability and heat rate targets for each unit  
20               are listed on attachment "A" to this testimony entitled  
21               "Tampa Electric Company GPIF Targets, October 1, 1997  
22               - March 31, 1998".

23  
24  
25

1     Q.   Do you wish to sponsor an exhibit consisting of estimated  
2               unit performance data supporting the fuel adjustment?

3

4     A.   Yes I do. (Have identified as Exhibit GAK-3).

5

6     Q.   Briefly describe this exhibit.

7

8     A.   This exhibit consists of 23 pages. This data is Tampa Electric  
9               Company's estimate of the Unit Performance Data and Unit Outage  
10              Data for the October 1997 - March 1998 period.

11

12    Q.   Does this conclude your testimony?

13

14    A.   Yes.

15

16

17

18

19

20

21

22

23

24

25

**ATTACHMENT "A"**  
June 23, 1997

**TAMPA ELECTRIC COMPANY  
GPIF TARGETS**  
October 1, 1997 - March 31, 1998

Unit	Availability			Heat Rate
	EAF	POF	EUOF	
Gannon 5	77.3	11.5	11.1	10,378 <sup>1/</sup>
Gannon 6	88.4	1.1	10.5	10,692 <sup>2/</sup>
Big Bend 1	79.3	7.7	13.0	10,084 <sup>3/</sup>
Big Bend 2	79.7	7.7	12.6	9,961 <sup>4/</sup>
Big Bend 3	74.1	11.5	14.4	9,680 <sup>5/</sup>
Big Bend 4	81.1	11.5	7.4	10,025 <sup>6/</sup>

<sup>1/</sup> Original Sheet 7.401.97E, Pg. 13

<sup>2/</sup> Original Sheet 7.401.97E, Pg. 14

<sup>3/</sup> Original Sheet 7.401.97E, Pg. 15

<sup>4/</sup> Original Sheet 7.401.97E, Pg. 16

<sup>5/</sup> Original Sheet 7.401.97E, Pg. 17

<sup>6/</sup> Original Sheet 7.401.97E, Pg. 18

**TAMPA ELECTRIC COMPANY  
GENERATING PERFORMANCE INCENTIVE FACTOR  
OCTOBER 1997 - MARCH 1998  
TABLE OF CONTENTS**

<b><u>SCHEDULE</u></b>	<b>PAGE</b>
GPIF REWARD / PENALTY TABLE ESTIMATED	2
GPIF CALCULATIONS OF MAXIMUM ALLOWED INCENTIVE DOLLARS	3
GPIF TARGET AND RANGE SUMMARY	4
COMPARISON GPIF TARGETS VS PRIOR PERIODS ACTUAL PERFORMANCE	5
GPIF HEAT RATE SUMMARY	5
DERIVATION OF WEIGHTING FACTORS	6
GENERATING PERFORMANCE INCENTIVE POINT TABLES	7 - 12
ESTIMATED UNIT PERFORMANCE DATA	13 - 18
PLANNED OUTAGE SCHEDULE	19
TAMPA ELECTRIC COMPANY FORCED OUTAGE AND MAINTENANCE OUTAGE FACTOR GRAPHS	20 - 25
NET HEAT RATE VS NET OUTPUT FACTOR GRAPHS	26 - 31
GENERATING UNITS IN GPIF (TABLE 4.2 IN MANUAL)	32
UNIT RATINGS AS OF OCTOBER 1, 1997	33
PROJECTED PERCENT GENERATION BY UNIT	34

**TAMPA ELECTRIC COMPANY**  
**GENERATING PERFORMANCE INCENTIVE POINTS TABLE**  
**REWARD / PENALTY TABLE - ESTIMATED**  
**OCTOBER 1997 - MARCH 1998**

GENERATING PERFORMANCE INCENTIVE POINTS (GPIP)	FUEL SAVINGS / (LOSS) (\$000)	GENERATING PERFORMANCE INCENTIVE FACTOR (\$000)
+10	4,133.5	2,066.3
+9	3,720.2	1,860.1
+8	3,306.8	1,653.4
+7	2,893.5	1,446.7
+6	2,480.1	1,240.1
+5	2,066.8	1,033.4
+4	1,653.4	826.7
+3	1,240.1	620.0
+2	826.7	413.4
+1	413.4	206.7
0	0	0.0
-1	(508.5)	(206.7)
-2	(1,017.0)	(413.4)
-3	(1,525.5)	(620.0)
-4	(2,034.0)	(826.7)
-5	(2,542.5)	(1,033.4)
-6	(3,050.9)	(1,240.1)
-7	(3,559.4)	(1,446.7)
-8	(4,067.9)	(1,653.4)
-9	(4,576.4)	(1,860.1)
-10	(5,084.9)	(2,066.8)

**TAMPA ELECTRIC COMPANY  
GENERATING PERFORMANCE INCENTIVE FACTOR  
CALCULATION OF MAXIMUM ALLOWED INCENTIVE DOLLARS  
ESTIMATED  
OCTOBER 1997 - MARCH 1998**

Line 1	Beginning of period balance of common equity	\$1,151,310,000
	End of month common equity:	
Line 2	Month of October	1997
Line 3	Month of November	1997
Line 4	Month of December	1997
Line 5	Month of January	1998
Line 6	Month of February	1998
Line 7	Month of March	1998
Line 8	(summation of line 1 through line 7 divided by 7)	\$1,157,214,571
Line 9	25 Basis points	0.0025
Line 10	Revenue expansion factor	61.3738%
Line 11	Maximum allowed incentive Dollars (Line 8 times line 9 divided by line 10 times 0.5)	\$2,356,899
Line 12	Jurisdictional Sales	7134610 MWH
Line 13	Total Sales	7150418 MWH
Line 14	Jurisdictional Separation Factor (Line 12 divided by line 13)	99.78%
Line 15	Maximum Allowed Jurisdictional Incentive Dollars (Line 11 times line 14)	\$2,351,688

**TAMPA ELECTRIC COMPANY**  
**GPIF TARGET AND RANGE SUMMARY**  
**OCTOBER 1997 - MARCH 1998**

**EQUIVALENT AVAILABILITY**

<u>PLANT/UNIT</u>	<u>WEIGHTING FACTOR (%)</u>	<u>EAF TARGET (%)</u>	<u>EAF MAX. (%)</u>	<u>RANGE MIN. (%)</u>	<u>MAX. FUEL SAVINGS (\$000)</u>	<u>MAX. FUEL LOSS (\$000)</u>
GANNON 5	1.46%	77.3	80.1	71.7	60.3	(115.4)
GANNON 6	1.01%	88.4	90.6	84.2	41.8	(106.4)
BIG BEND 1	4.16%	79.3	82.3	73.3	172.1	(379.0)
BIG BEND 2	5.22%	79.7	82.6	73.9	215.7	(360.7)
BIG BEND 3	7.98%	74.1	77.6	67.3	330.0	(611.5)
BIG BEND 4	3.98%	81.1	83.2	77.1	164.6	(362.9)
GPIF SYSTEM	23.81%				984.5	(1,935.9)

**AVERAGE NET OPERATING HEAT RATE  
FOR  
GPIF COAL GENERATING UNITS**

<u>PLANT/UNIT</u>	<u>WEIGHTING FACTOR (%)</u>	<u>ANOHR Btu/lwh</u>	<u>TARGET NOF</u>	<u>ANOHR TARGET RANGE MIN.</u>	<u>ANOHR TARGET RANGE MAX.</u>	<u>MAX. FUEL SAVINGS (\$000)</u>	<u>MAX. FUEL LOSS (\$000)</u>
GANNON 5	7.40%	10378	69.1	9986	10770	306.0	(306.0)
GANNON 6	11.85%	10692	66.3	10299	11085	490.0	(490.0)
BIG BEND 1	10.67%	10084	80.9	9847	10321	441.0	(441.0)
BIG BEND 2	16.14%	9961	83.6	9616	10306	667.0	(667.0)
BIG BEND 3	15.22%	9680	91.6	9318	10042	629.0	(629.0)
BIG BEND 4	14.91%	10025	86.3	9710	10340	616.0	(616.0)
GPIF SYSTEM	76.19%					3,149.0	(3,149.0)

TAMPA ELECTRIC COMPANY  
COMPARISON OF CWP TARGETS VS. PRIOR PERIOD ACTUAL PERFORMANCE

## AVAILABILITY

PLANT/UNIT	TARGET WEIGHTING FACTOR	TARGET PERIOD			ACTUAL PERFORMANCE OCT '81 - MAR '82			ACTUAL PERFORMANCE APR '81 - SEP '81			ACTUAL PERFORMANCE APR '81 - SEP '81					
		POP	ELCP	BLDG	POP	ELCP	BLDG	POP	ELCP	BLDG	POP	ELCP	BLDG			
BIG BEND 1	4.10%	11.3	7.7	13.0	14.1	9.3	12.6	17.2	6.0	15.2	15.2	8.2	11.1	7.7	7.6	8.2
BIG BEND 2	3.22%	21.9	7.7	12.4	13.6	8.8	11.5	12.6	6.0	12.8	12.8	6.0	11.4	11.4	20.7	11.9
BIG BEND 3	7.90%	33.5	11.5	14.4	16.2	9.0	16.5	16.5	6.7	15.7	15.8	10.4	13.9	13.5	21.1	13.7
BIG BEND 4	3.90%	16.7	11.5	7.4	8.3	11.9	5.5	4.3	6.0	7.3	7.3	11.0	4.6	5.3	6.0	7.4
GANNON 1	1.40%	6.1	11.5	11.1	12.4	11.8	22.3	23.9	4.7	12.2	12.8	31.0	8.6	12.3	8.3	8.5
GANNON 2	1.87%	4.2	1.1	18.5	19.4	9.5	11.4	12.6	30.1	5.2	5.4	3.9	11.2	11.7	5.9	7.2
CWP SYSTEM BUDGET AVE.	23.87%	99.9	9.6	12.2	13.5	6.8	13.5	14.4	1.8	12.9	13.1	7.4	11.8	12.7	12.2	11.5
CWP SYSTEM BUDGETED EQUIVALENT AVAILABILITY					78.2				79.2			85.1			86.8	
																78.1

AVERAGE NET OPERATED HEAT RATE (Mw/h)

	3 PERIOD AVERAGE POP	ELCP	BLDG	5 PERIOD AVERAGE POP	ELCP	BLDG
	7.1	11.0	11.9	8.1	9	9

PLANT/UNIT	TARGET WEIGHTING FACTOR	NORMALIZED WEIGHTING FACTOR	HEAT RATE TARGET	ADJUSTED PRIOR HEAT RATE APR '81 - SEP '81		ADJUSTED PRIOR HEAT RATE APR '81 - SEP '81		
				POP	ELCP	POP	ELCP	
GANNON 1	7.40%	9.1	103.78	106.04		101.14		
GANNON 2	11.87%	15.6	106.92	110.25		107.72		
BIG BEND 1	10.47%	14.0	108.64	101.04		101.09		
BIG BEND 2	14.14%	21.2	99.81	101.44		100.82		
BIG BEND 3	13.22%	20.0	94.00	98.03		97.98		
BIG BEND 4	14.97%	19.6	100.25	101.97		97.75		
								100.74

CWP SYSTEM WEIGHTED AVERAGE HEAT RATE (Mw/h)

100.9

102.64

101.13

100.8

100.8

100.8

**TAMPA ELECTRIC COMPANY**  
**DERIVATION OF WEIGHTING FACTORS**  
**OCTOBER 1997 - MARCH 1998**  
**PRODUCTION COSTING SIMULATION**  
**FUEL COST (\$000)**

UNIT PERFORMANCE INDICATOR	AT TARGET	IMPROVEMENT	SAVINGS	WEIGHTING FACTOR (% OF SAVINGS)
<b>EQUIVALENT AVAILABILITY</b>				
EA <sub>1</sub> GANNON 5	114813.5	114753.2	60.3	1.46%
EA <sub>2</sub> GANNON 6	114813.5	114771.7	41.8	1.01%
EA <sub>3</sub> BIG BEND 1	114813.5	114641.4	172.1	4.16%
EA <sub>4</sub> BIG BEND 2	114813.5	114597.8	215.7	5.22%
EA <sub>5</sub> BIG BEND 3	114813.5	114483.5	330.0	7.98%
EA <sub>6</sub> BIG BEND 4	114813.5	114648.9	164.6	3.98%
<b>HEAT RATE</b>				
AHR <sub>1</sub> GANNON 5	114813.5	114507.5	306.0	7.40%
AHR <sub>2</sub> GANNON 6	114813.5	114323.5	490.0	11.85%
AHR <sub>3</sub> BIG BEND 1	114813.5	114372.5	441.0	10.67%
AHR <sub>4</sub> BIG BEND 2	114813.5	114146.5	667.0	16.14%
AHR <sub>5</sub> BIG BEND 3	114813.5	114184.5	629.0	15.22%
AHR <sub>6</sub> BIG BEND 4	114813.5	114197.5	616.0	14.91%
<b>TOTAL SAVINGS</b>				4133.5
				100.00%

(1) Fuel Adjustment Base Case - All unit performance indicators at target.

(2) All other unit performance indicators at target.

(3) Expressed in replacement energy cost.

**TAMPA ELECTRIC COMPANY**  
**GENERATING PERFORMANCE INCENTIVE POINTS TABLE**  
**OCTOBER 1997 - MARCH 1998**  
**GANNON 5**

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	60.3	80.1	+10	306.0	9986
+9	54.3	79.8	+9	275.4	10018
+8	48.2	79.5	+8	244.8	10049
+7	42.2	79.3	+7	214.2	10081
+6	36.2	79.0	+6	183.6	10113
+5	30.2	78.7	+5	153.0	10145
+4	24.1	78.4	+4	122.4	10176
+3	18.1	78.1	+3	91.8	10208
+2	12.1	77.9	+2	61.2	10240
+1	6.0	77.6	+1	30.6	10271
0	0.0	77.3	0	0.0	10303
				0.0	10378
-1	(11.5)	76.7	-1	(30.6)	10485
-2	(23.1)	76.2	-2	(61.2)	10516
-3	(34.6)	75.6	-3	(91.8)	10548
-4	(46.2)	75.1	-4	(122.4)	10580
-5	(57.7)	74.5	-5	(153.0)	10612
-6	(69.2)	73.9	-6	(183.6)	10643
-7	(80.8)	73.4	-7	(214.2)	10675
-8	(92.3)	72.8	-8	(244.8)	10707
-9	(103.9)	72.3	-9	(275.4)	10738
-10	(115.4)	71.7	-10	(306.0)	10770

Weighting Factor =

1.46%

Weighting Factor =

7.40%

**TAMPA ELECTRIC COMPANY**  
**GENERATING PERFORMANCE INCENTIVE POINTS TABLE**  
**OCTOBER 1997 - MARCH 1998**  
**GANNON 6**

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	41.8	90.6	+10	490.0	10299
+9	37.6	90.4	+9	441.0	10331
+8	33.4	90.2	+8	392.0	10363
+7	29.3	89.9	+7	343.0	10394
+6	25.1	89.7	+6	294.0	10426
+5	20.9	89.5	+5	245.0	10458
+4	16.7	89.3	+4	196.0	10490
+3	12.5	89.1	+3	147.0	10522
+2	8.4	88.8	+2	98.0	10553
+1	4.2	88.6	+1	49.0	10585
				0.0	10617
0	0.0	88.4	0	0.0	10692
				0.0	10767
-1	(10.6)	88.0	-1	(49.0)	10799
-2	(21.3)	87.6	-2	(98.0)	10831
-3	(31.9)	87.1	-3	(147.0)	10862
-4	(42.6)	86.7	-4	(196.0)	10894
-5	(53.2)	86.3	-5	(245.0)	10926
-6	(63.8)	85.9	-6	(294.0)	10958
-7	(74.5)	85.5	-7	(343.0)	10990
-8	(85.1)	85.0	-8	(392.0)	11021
-9	(95.8)	84.6	-9	(441.0)	11053
-10	(106.4)	84.2	-10	(490.0)	11085

Weighting Factor =

1.01%

% Weighting Factor =

11.85%

**TAMPA ELECTRIC COMPANY**  
**GENERATING PERFORMANCE INCENTIVE POINTS TABLE**  
**OCTOBER 1997 - MARCH 1998**  
**BIG BEND 1**

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	172.1	82.3	+10	441.0	9847
+9	154.9	82.0	+9	396.9	9863
+8	137.7	81.7	+8	352.8	9879
+7	120.5	81.4	+7	308.7	9896
+6	103.3	81.1	+6	264.6	9912
+5	86.1	80.8	+5	220.5	9928
+4	68.8	80.5	+4	176.4	9944
+3	51.6	80.2	+3	132.3	9960
+2	34.4	79.9	+2	88.2	9977
+1	17.2	79.6	+1	44.1	9993
				0.0	10009
0	0.0	79.3	0	0.0	10084
				0.0	10159
-1	(37.9)	78.7	-1	(44.1)	10175
-2	(75.8)	78.1	-2	(88.2)	10191
-3	(113.7)	77.5	-3	(132.3)	10208
-4	(151.6)	76.9	-4	(176.4)	10224
-5	(189.5)	76.3	-5	(220.5)	10240
-6	(227.4)	75.7	-6	(264.6)	10256
-7	(265.3)	75.1	-7	(308.7)	10272
-8	(303.2)	74.5	-8	(352.8)	10289
-9	(341.1)	73.9	-9	(396.9)	10305
-10	(379.0)	73.3	-10	(441.0)	10321

Weighting Factor =

4.16%

Weighting Factor =

10.67%

**TAMPA ELECTRIC COMPANY**  
**GENERATING PERFORMANCE INCENTIVE POINTS TABLE**  
**OCTOBER 1997 - MARCH 1998**  
**BIG BEND 2**

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	215.7	82.6	+10	667.0	9616
+9	194.1	82.3	+9	600.3	9643
+8	172.6	82.0	+8	533.6	9670
+7	151.0	81.7	+7	466.9	9697
+6	129.4	81.4	+6	400.2	9724
+5	107.9	81.2	+5	333.5	9751
+4	86.3	80.9	+4	266.8	9778
+3	64.7	80.6	+3	200.1	9805
+2	43.1	80.3	+2	133.4	9832
+1	21.6	80.0	+1	66.7	9859
				0.0	9886
0	0.0	79.7	0	0.0	9961
				0.0	10036
-1	(36.1)	79.1	-1	(66.7)	10063
-2	(72.1)	78.5	-2	(133.4)	10090
-3	(108.2)	78.0	-3	(200.1)	10117
-4	(144.3)	77.4	-4	(266.8)	10144
-5	(180.4)	76.8	-5	(333.5)	10171
-6	(216.4)	76.2	-6	(400.2)	10198
-7	(252.5)	75.6	-7	(466.9)	10225
-8	(288.6)	75.1	-8	(533.6)	10252
-9	(324.6)	74.5	-9	(600.3)	10279
-10	(360.7)	73.9	-10	(667.0)	10306

Weighting Factor =

5.22%

Weighting Factor =

16.14%

**TAMPA ELECTRIC COMPANY**  
**GENERATING PERFORMANCE INCENTIVE POINTS TABLE**  
**OCTOBER 1997 - MARCH 1998**  
**BIG BEND 3**

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	330.0	77.6	+10	629.0	9318
+9	297.0	77.3	+9	566.1	9347
+8	264.0	76.9	+8	503.2	9375
+7	231.0	76.6	+7	440.3	9404
+6	198.0	76.2	+6	377.4	9433
+5	165.0	75.9	+5	314.5	9462
+4	132.0	75.5	+4	251.6	9490
+3	99.0	75.2	+3	188.7	9519
+2	66.0	74.8	+2	125.8	9548
+1	33.0	74.5	+1	62.9	9576
				0.0	9605
0	0.0	74.1	0	0.0	9680
				0.0	9755
-1	(61.2)	73.4	-1	(62.9)	9784
-2	(122.3)	72.7	-2	(125.8)	9812
-3	(183.5)	72.1	-3	(188.7)	9841
-4	(244.6)	71.4	-4	(251.6)	9870
-5	(305.8)	70.7	-5	(314.5)	9899
-6	(366.9)	70.0	-6	(377.4)	9927
-7	(428.1)	69.3	-7	(440.3)	9956
-8	(489.2)	68.7	-8	(503.2)	9985
-9	(550.4)	68.0	-9	(566.1)	10013
-10	(611.5)	67.3	-10	(629.0)	10042

Weighting Factor = 7.98%

Weighting Factor = 15.22%

**TAMPA ELECTRIC COMPANY**  
**GENERATING PERFORMANCE INCENTIVE POINTS TABLE**  
**OCTOBER 1997 - MARCH 1998**  
**BIG BEND 4**

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	164.6	83.2	+10	616.0	9710
+9	148.1	83.0	+9	554.4	9734
+8	131.7	82.8	+8	492.8	9756
+7	115.2	82.6	+7	431.2	9787
+6	98.8	82.4	+6	369.6	9806
+5	82.3	82.2	+5	308.0	9830
+4	65.8	81.9	+4	246.4	9854
+3	49.4	81.7	+3	184.8	9878
+2	32.9	81.5	+2	123.2	9902
+1	16.5	81.3	+1	61.6	9926
				0.0	9950
0	0.0	81.1	0	0.0	10025
				0.0	10100
-1	36.3	80.7	-1	(61.6)	10124
-2	72.6	80.3	-2	(123.2)	10148
-3	108.9	79.9	-3	(184.8)	10172
-4	145.2	79.5	-4	(246.4)	10196
-5	181.5	79.1	-5	(308.0)	10220
-6	217.7	78.7	-6	(369.6)	10244
-7	254.0	78.3	-7	(431.2)	10268
-8	290.3	77.9	-8	(492.8)	10292
-9	326.6	77.5	-9	(554.4)	10316
-10	362.9	77.1	-10	(616.0)	10340

Weighting Factor =

3.98%

Weighting Factor =

14.91%

## TAMPA ELECTRIC COMPANY

## ESTIMATED UNIT PERFORMANCE DATA

OCTOBER 1997 - MARCH 1998

PLANT/UNIT	MONTH OF: OCT 97	MONTH OF: NOV 97	MONTH OF: DEC 97	MONTH OF: JAN 98	MONTH OF: FEB 98	MONTH OF: MAR 98	PERIOD WINTER 1997
GANNON 5							
1. EAF (%)	87.4	87.4	47.8	87.5	65.6	87.5	77.3
2. POF	0.0	0.0	45.2	0.0	25.0	0.0	11.5
3. EUOF	12.6	12.6	7.0	12.5	9.4	12.5	11.1
4. EUOR	12.6	12.6	12.7	12.5	12.5	12.5	12.6
5. PH	745	720	744	744	672	744	4369
6. SH	686	664	376	686	465	686	3563
7. RSH	0	0	0	0	0	0	0
8. UH	59	56	368	58	207	58	806
9. POH	0	0	336	0	168	0	504
10. FOH & EFOH	75	72	41	74	50	74	386
11. MOH & EMOH	19	19	11	19	13	19	100
12. OPER BTU (GBTU)	1242.838	1094.813	526.659	1061.106	794.362	1209.090	5928.868
13. NET GEN (MWH)	118451	105715	50518	102485	77091	117024	571284
14. ANOHR (BTU/KWH)	10492	10356	10425	10354	10304	10332	10378
15. NOF (%)	74.4	68.6	57.9	64.4	71.5	73.5	69.1
16. NGC (MW)	232	232	232	232	232	232	232
17. ANOHR EQUATION	ANOHR = NOF(-18.7056) + 11670.7						

FILED:  
SUSPENDED:  
EFFECTIVE: 10/01/97  
DOCKET NO.: 970001-EI  
ORDER NO.:

## TAMPA ELECTRIC COMPANY

## ESTIMATED UNIT PERFORMANCE DATA

OCTOBER 1997 - MARCH 1998

PLANT/UNIT	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	PERIOD
	OCT 97	NOV 97	DEC 97	JAN 98	FEB 98	MAR 98	WINTER 1997
1. EAF (%)	89.4	89.4	89.4	89.4	89.4	83.6	88.4
2. POF	0.0	0.0	0.0	0.0	0.0	6.5	1.1
3. EUOF	10.6	10.6	10.6	10.6	10.6	9.9	10.5
4. EUOR	10.6	10.6	10.6	10.6	10.6	10.6	10.6
5. PH	745	720	744	744	672	744	4369
6. SH	679	657	679	679	613	634	3941
7. RSH	0	0	0	0	0	0	0
8. UH	66	63	65	65	59	110	428
9. POH	0	0	0	0	0	48	48
10. FOH & EFOH	41	40	41	41	37	38	238
11. MOH & EMOH	38	37	38	38	34	36	220
12. OPER BTU (GBTU)	2121.245	1851.908	1514.267	1713.180	1804.019	1944.876	10949.495
13. NET GEN (MWH)	198290	173663	139359	159517	169997	183212	1024038
14. ANOHR (BTU/KWH)	0	10664	10866	10740	10612	10615	10692
15. NOF (%)	0.0	67.4	52.4	59.9	70.7	73.7	66.3
16. NSC (MW)	392	392	392	392	392	392	392
17. ANOHR EQUATION	ANOHR = NOF(-18.7199) + 11933.6						

FILED:  
 SUSPENDED:  
 EFFECTIVE: 10/01/97  
 DOCKET NO.: 970001-E!  
 ORDER NO.:

## TAMPA ELECTRIC COMPANY

## ESTIMATED UNIT PERFORMANCE DATA

OCTOBER 1997 - MARCH 1998

PLANT/UNIT	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	PERIOD
	OCT 97	NOV 97	DEC 97	JAN 98	FEB 98	MAR 98	WINTER 1997
1. EAF (%)	85.9	86.0	85.9	85.9	85.9	47.2	79.3
2. POF	0.0	0.0	0.0	0.0	0.0	45.2	7.7
3. EUOF	14.1	14.0	14.1	14.1	14.1	7.7	13.0
4. EUOR	14.1	14.0	14.1	14.1	14.1	14.0	14.1
5. PH	745	720	744	744	672	744	4369
6. SH	674	652	674	674	609	369	3652
7. RSH	0	0	0	0	0	0	0
8. UH	71	68	70	70	63	375	717
9. POH	0	0	0	0	0	336	336
10. FOH & EFOH	74	71	74	74	67	40	400
11. MOH & EMOH	31	30	31	31	28	17	168
12. OPER BTU (GBTU)	2565.223	2337.527	2239.249	2218.309	2117.911	1369.595	12847.814
13. NET GEN (MWH)	252431	232453	222867	219780	210388	136175	1274094
14. ANOHR (BTU/KWH)	0	10056	10047	10093	10067	10058	10084
15. NOF (%)	0.0	82.7	76.7	75.7	80.2	85.6	80.9
16. NSC (MW)	431	431	431	431	431	431	431
17. ANOHR EQUATION	ANOHR = NOF(-22.4860) + 11903.0						

FILED:  
 SUSPENDED:  
 EFFECTIVE: 10/01/97  
 DOCKET NO.: 970001-EI  
 ORDER NO.:

## TAMPA ELECTRIC COMPANY

## ESTIMATED UNIT PERFORMANCE DATA

OCTOBER 1997 - MARCH 1998

PLANT/UNIT	MONTH OF: OCT 97	MONTH OF: NOV 97	MONTH OF: DEC 97	MONTH OF: JAN 98	MONTH OF: FEB 98	MONTH OF: MAR 98	PERIOD WINTER 1997
BIG BEND 2							
1. EAF (%)	47.4	86.4	86.4	86.4	86.3	86.4	79.7
2. POF	45.1	0.0	0.0	0.0	0.0	0.0	7.7
3. EUOF	7.5	13.6	13.6	13.6	13.7	13.6	12.6
4. EUOR	13.7	13.6	13.6	13.6	13.7	13.6	13.6
5. PH	745	720	744	744	672	744	4369
6. SH	370	652	674	674	609	674	3653
7. RSH	0	0	0	0	0	0	0
8. UH	375	68	70	70	63	70	716
9. POH	336	0	0	0	0	0	336
10. FOH & EFOH	36	63	65	65	59	65	353
11. MOH & EMOH	20	35	36	36	33	36	196
12. OPER BTU (GBTU)	1427.774	2434.167	2252.173	2259.391	2174.097	2560.969	13108.591
13. NET GEN (MWH)	143978	245249	224721	225776	217925	256310	1315961
14. ANOHR (BTU/KWH)	9917	9925	10022	10007	9976	9914	9961
15. NOF (%)	90.3	87.3	77.4	77.7	83.0	88.9	83.6
16. NSC (MW)	431	431	431	431	431	431	431
17. ANOHR EQUATION	ANOHR = NOF(-18.2305) + 11485.3						

FILED:  
SUSPENDED:  
EFFECTIVE: 10/01/97  
DOCKET NO.: 970001-EI  
ORDER NO.:

## TAMPA ELECTRIC COMPANY

## ESTIMATED UNIT PERFORMANCE DATA

OCTOBER 1997 - MARCH 1998

PLANT/UNIT	MONTH OF:	PERIOD					
	OCT 97	NOV 97	DEC 97	JAN 98	FEB 98	MAR 98	WINTER 1997
BIG BEND 3 GPIF							
1. EAF (%)	83.8	25.1	83.7	83.7	83.8	83.7	74.1
2. POF	0.0	70.0	0.0	0.0	0.0	0.0	11.5
3. EUOF	16.2	4.9	16.3	16.3	16.2	16.3	14.4
4. EUOR	16.2	16.2	16.3	16.3	16.2	16.3	16.2
5. PH	745	720	744	744	672	744	4369
6. SH	652	189	652	652	589	652	3386
7. RSH	0	0	0	0	0	0	0
8. UH	93	531	92	92	83	92	983
9. POH	0	504	0	0	0	0	504
10. FOH & EFOH	91	26	91	91	82	91	472
11. MOH & EMOH	30	9	30	30	27	30	156
12. OPER BTU (GBTU)	2615.404	749.060	2410.854	2464.943	2317.230	2626.272	13183.763
13. NET GEN (MWH)	264424	76278	249117	257644	242699	271742	1361904
14. ANOHR (BTU/KWH)	9691	9820	9678	9587	9548	9665	9680
15. NOF (%)	92.4	91.9	87.0	90.0	93.9	94.9	91.6
16. NSC (MW)	439	439	439	439	439	439	439
17. ANOHR EQUATION : ANOHR = NOF(-17.9962) + 11328.8							

FILED:  
 SUSPENDED:  
 EFFECTIVE: 10/01/97  
 DOCKET NO.: 970001-EI  
 ORDER NO.:

## TAMPA ELECTRIC COMPANY

## ESTIMATED UNIT PERFORMANCE DATA

OCTOBER 1997 - MARCH 1998

PLANT/UNIT	MONTH OF: OCT 97	MONTH OF: NOV 97	MONTH OF: DEC 97	MONTH OF: JAN 98	MONTH OF: FEB 98	MONTH OF: MAR 98	PERIOD WINTER 1997
BIG BEND 4							
1. EAF (%)	91.7	91.7	91.7	91.7	72.0	47.3	81.1
2. POF	0.0	0.0	0.0	0.0	21.4	48.4	11.5
3. EUOF	8.3	8.3	8.3	8.3	6.5	4.3	7.4
4. EUOR	8.3	8.3	8.3	8.3	8.3	8.3	8.3
5. PH	745	720	744	744	672	744	4369
6. SH	710	687	710	710	504	367	3680
7. RSH	0	0	0	0	0	0	0
8. UH	35	33	34	34	168	377	681
9. POH	0	0	0	0	144	360	504
10. FOH & EFOH	32	31	32	32	23	17	167
11. MOH & EMOH	30	29	30	30	21	15	155
12. OPER BTU (GBTU)	2841.278	2654.026	2601.190	2666.688	1983.029	1512.064	14258.275
13. NET GEN (MWH)	283387	264023	258994	266049	198553	151297	1422303
14. ANOHR (BTU/KWH)	10026	10052	10043	10023	9987	9994	10025
15. NOF (%)	89.3	86.0	81.6	83.8	88.1	92.2	86.3
16. NSC (MW)	447	447	447	447	447	447	447
17. ANOHR EQUATION	ANOHR = NOF(-6.9608) + 10625.5						


FILED:  
SUSPENDED:  
EFFECTIVE: 10/01/97  
DOCKET NO.: 970001-EI  
ORDER NO.:

TAMPA ELECTRIC COMPANY  
PLANNED OUTAGE SCHEDULE (ESTIMATED)  
GPIF UNITS  
OCTOBER 1997 - MARCH 1998


PLANT / UNIT	PLANNED OUTAGE DATES	OUTAGE DESCRIPTION
+ BIG BEND 1	MAR 16 - MAY 29	ANNUAL MAINT. OUTAGE
+ BIG BEND 2	OCT 14 - OCT 27	ANNUAL MAINT. OUTAGE
+ BIG BEND 3	NOV 01 - NOV 21	ANNUAL MAINT. OUTAGE
+ BIG BEND 4	FEB 23 - MAR 15	ANNUAL MAINT. OUTAGE
+ GANNON 5	DEC 01 - DEC 14	FUEL SYSTEM CLEAN-UP
+ GANNON 5	FEB 16 - FEB 22	FUEL SYSTEM CLEAN-UP
+ * GANNON 6	MAR 30 - APR 19	FUEL SYSTEM CLEAN-UP

\* OUTAGE START / END DATE OUT OF GPIF PERIOD  
+ CPM WAS NOT INCLUDED FOR THIS UNIT, OUTAGE IS LESS THAN 3 WEEKS


Tampa Electric Company  
GANNON UNIT #5 EEOF




Tampa Electric Company  
GANNON UNIT #5 EMOF




Tampa Electric Company  
GANNON UNIT #6 EEOF



Tampa Electric Company  
GANNON UNIT #6 EMOF




Tampa Electric Company  
BIG BEND UNIT #1 EEOF




EEOF (ADJUSTED FOR PLANNED OUTAGE HOURS)

Tampa Electric Company  
BIG BEND UNIT #1 EMOF




EMOF (ADJUSTED FOR PLANNED OUTAGE HOURS)


Tampa Electric Company  
BIG BEND UNIT #2 EEOF




Tampa Electric Company  
BIG BEND UNIT #2 EMOF




Tampa Electric Company  
BIG BEND UNIT #3 EFOF




Tampa Electric Company  
BIG BEND UNIT #3 EMOF




Tampa Electric Company  
BIG BEND UNIT #4 EEOF



Tampa Electric Company  
BIG BEND UNIT #4 EMOF




TAMPA ELECTRIC COMPANY  
 HEAT RATE VS. NET OUTPUT FACTOR  
 GANNON 5, WINTER 1997




TARGET NET HEAT RATE: 10378  
 TARGET NET OUTPUT FACTOR: 69.1%

TAMPA ELECTRIC COMPANY  
 HEAT RATE VS. NET OUTPUT FACTOR  
 GANNON 6, WINTER 1997




TARGET NET HEAT RATE: 10692  
 TARGET NET OUTPUT FACTOR: 66.3%

TAMPA ELECTRIC COMPANY  
HEAT RATE VS. NET OUTPUT FACTOR  
BIG BEND 1, WINTER 1997




TARGET NET HEAT RATE: 10084  
TARGET NET OUTPUT FACTOR: 80.9%

TAMPA ELECTRIC COMPANY  
 HEAT RATE VS. NET OUTPUT FACTOR  
 BIG BEND 2, WINTER 1997




TARGET NET HEAT RATE: 9961  
 TARGET NET OUTPUT FACTOR: 83.6%

TAMPA ELECTRIC COMPANY  
 HEAT RATE VS. NET OUTPUT FACTOR  
 BIG BEND 3, WINTER 1997



TARGET NET HEAT RATE: 9680  
 TARGET NET OUTPUT FACTOR: 91.6%

TAMPA ELECTRIC COMPANY  
 HEAT RATE VS. NET OUTPUT FACTOR  
 BIG BEND 4, WINTER 1997



TARGET NET HEAT RATE: 10025  
 TARGET NET OUTPUT FACTOR: 86.3%

TAMPA ELECTRIC COMPANY  
TABLE 4.2  
GENERATING UNITS IN GPIF  
OCTOBER 1997 - MARCH 1998

UNIT	MDC GROSS (MW)	NDC NET (MW)
GANNON 5	245	232
GANNON 6	405	392
BIG BEND 1	445	431
BIG BEND 2	445	431
BIG BEND 3	455	439
BIG BEND 4	475	447
TOTAL	2470	2372
SYSTEM TOTAL	3871	3653
% OF SYSTEM TOTAL	63.81%	64.93%

TAMPA ELECTRIC COMPANY  
UNITS RATINGS  
OCTOBER 1997 - MARCH 1998

UNIT	MDC GROSS (MW)	NDC NET (MW)
HOOKERS POINT 1	35	34
HOOKERS POINT 2	35	34
HOOKERS POINT 3	35	34
HOOKERS POINT 4	45	43
HOOKERS POINT 5	70	67
HOOKERS TOTAL	220	212
GANNON 1	125	119
GANNON 2	125	118
GANNON 3	165	155
GANNON 4	200	189
GANNON 5	245	232
GANNON 6	405	392
GANNON TOTAL	1265	1205
BIG BEND 1	445	431
BIG BEND 2	445	431
BIG BEND 3	455	439
BIG BEND 4	475	447
BIG BEND TOTAL	1820	1748
GANNON CT	17	17
BIG BEND CT1	17	17
BIG BEND CT2	85	85
BIG BEND CT3	85	85
CT TOTAL	204	204
PHILLIPS 1	18	17
PHILLIPS 2	18	17
PHILLIPS TOTAL	36	34
POLK	326	250
POLK TOTAL	326	250
SYSTEM TOTAL	3871	3653

**TAMPA ELECTRIC COMPANY**  
**PERCENT GENERATION BY UNIT**  
**OCTOBER 1997 - MARCH 1998**

STATION	UNIT	NET OUTPUT MWH	% OF PROJECTED OUTPUT	% CUMULATIVE PROJECTED OUTPUT
BIG BEND	4	1,422,303	16.04%	16.04%
BIG BEND	3	1,361,904	15.36%	31.41%
BIG BEND	2	1,315,961	14.84%	46.25%
BIG BEND	1	1,274,094	14.37%	60.62%
GANNON	6	1,024,038	11.55%	72.18%
POLK		722,717	8.15%	80.33%
GANNON	5	571,284	6.44%	86.77%
GANNON	4	389,093	4.39%	91.16%
GANNON	3	325,769	3.67%	94.84%
GANNON	1	221,634	2.50%	97.34%
GANNON	2	214,528	2.42%	99.76%
PHILLIPS	2	3,277	0.04%	99.80%
BIG BEND CT	2	3,224	0.04%	99.83%
HOOKERS POINT	5	3,141	0.04%	99.87%
BIG BEND CT	3	2,895	0.03%	99.90%
PHILLIPS	1	2,588	0.03%	99.93%
HOOKERS POINT	4	1,933	0.02%	99.95%
HOOKERS POINT	3	1,307	0.01%	99.97%
HOOKERS POINT	2	1,125	0.01%	99.98%
HOOKERS POINT	1	987	0.01%	99.99%
BIG BEND CT	1	499	0.01%	99.99%
GANNON CT	1	473	0.01%	100.00%
 <b>TOTAL GENERATION</b>		 <b>6,864,774</b>	 <b>100.00%</b>	
 GENERATION BY COAL UNITS:		 <b>8,843,325</b>	 <b>MWH</b>	
 % GENERATION BY COAL UNITS:		 <b>99.76%</b>		
 GENERATION BY OIL UNITS:		 <b>21,449</b>	 <b>MWH</b>	
 % GENERATION BY OIL UNITS:		 <b>0.17%</b>		
 GENERATION BY GPIF UNITS:		 <b>6,969,584</b>	 <b>MWH</b>	
 % GENERATION BY GPIF UNITS:		 <b>78.62%</b>		

TAMPA ELECTRIC COMPANY  
GENERATING PERFORMANCE INCENTIVE FACTOR  
OCTOBER 1997 - MARCH 1998  
TABLE OF CONTENTS

<u>SCHEDULE</u>	<u>PAGE</u>
BIG BEND 1 - ESTIMATED UNIT PERFORMANCE DATA	2
BIG BEND 2 - ESTIMATED UNIT PERFORMANCE DATA	3
BIG BEND 3 - ESTIMATED UNIT PERFORMANCE DATA	4
BIG BEND 4 - ESTIMATED UNIT PERFORMANCE DATA	5
GANNON 1 - ESTIMATED UNIT PERFORMANCE DATA	6
GANNON 2 - ESTIMATED UNIT PERFORMANCE DATA	7
GANNON 3 - ESTIMATED UNIT PERFORMANCE DATA	8
GANNON 4 - ESTIMATED UNIT PERFORMANCE DATA	9
GANNON 5 - ESTIMATED UNIT PERFORMANCE DATA	10
GANNON 6 - ESTIMATED UNIT PERFORMANCE DATA	11
HOOKERS POINT 1 - ESTIMATED UNIT PERFORMANCE DATA	12
HOOKERS POINT 2 - ESTIMATED UNIT PERFORMANCE DATA	13
HOOKERS POINT 3 - ESTIMATED UNIT PERFORMANCE DATA	14
HOOKERS POINT 4 - ESTIMATED UNIT PERFORMANCE DATA	15
HOOKERS POINT 5 - ESTIMATED UNIT PERFORMANCE DATA	16
GANNON CT1 - ESTIMATED UNIT PERFORMANCE DATA	17
BIG BEND CT1 - ESTIMATED UNIT PERFORMANCE DATA	18
BIG BEND CT2 - ESTIMATED UNIT PERFORMANCE DATA	19
BIG BEND CT3 - ESTIMATED UNIT PERFORMANCE DATA	20
PHILLIPS 1 - ESTIMATED UNIT PERFORMANCE DATA	21
PHILLIPS 2 - ESTIMATED UNIT PERFORMANCE DATA	22
POLK - ESTIMATED UNIT PERFORMANCE DATA	23

## TAMPA ELECTRIC COMPANY

## ESTIMATED UNIT PERFORMANCE DATA

OCTOBER 1997 - MARCH 1998

PLANT/UNIT	MONTH OF: OCT 97	MONTH OF: NOV 97	MONTH OF: DEC 97	MONTH OF: JAN 98	MONTH OF: FEB 98	MONTH OF: MAR 98	PERIOD WINTER 1997
BIG BEND 1							
1. EAF (%)	85.9	86.0	85.9	85.9	85.9	47.2	79.3
2. POF	0.0	0.0	0.0	0.0	0.0	45.2	7.7
3. EUOF	14.1	14.0	14.1	14.1	14.1	7.7	13.0
4. EUOR	14.1	14.0	14.1	14.1	14.1	14.0	14.1
5. PH	745	720	744	744	672	744	4369
6. SH	674	652	674	674	609	369	3652
7. RSH	0	0	0	0	0	0	0
8. UH	71	68	70	70	63	375	717
9. POH	0	0	0	0	0	336	336
10. FOH & EFOH	74	71	74	74	67	40	400
11. MOH & EMOH	31	30	31	31	28	17	168
12. OPER BTU (GBTU)	2565.223	2337.527	2239.249	2218.309	2117.911	1369.595	12847.814
13. NET GEN (MWH)	252431	232453	222867	219760	210388	136175	1274094
14. ANOHR (BTU/KWH)	0	10056	10047	10063	10067	10058	10064
15. NOF (%)	0.0	82.7	76.7	75.7	80.2	85.6	80.9
16. NSC (MW)	431	431	431	431	431	431	431
17. ANOHR EQUATION	ANOHR = NOF(-22.4860) + 11803.0						

FILED:  
 SUSPENDED:  
 EFFECTIVE: 10/01/97  
 DOCKET NO.: 970001-EI  
 ORDER NO.:

## TAMPA ELECTRIC COMPANY

## ESTIMATED UNIT PERFORMANCE DATA

OCTOBER 1997 - MARCH 1998

PLANT/UNIT	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	PERIOD
	OCT 97	NOV 97	DEC 97	JAN 98	FEB 98	MAR 98	WINTER 1997
1. EAF (%)	47.4	86.4	86.4	86.4	86.3	86.4	79.7
2. POF	45.1	0.0	0.0	0.0	0.0	0.0	7.7
3. EUOF	7.5	13.6	13.6	13.6	13.7	13.6	12.6
4. EUOR	13.7	13.6	13.6	13.6	13.7	13.6	13.6
5. PH	745	720	744	744	672	744	4369
6. SH	370	652	674	674	609	674	3653
7. RSH	0	0	0	0	0	0	0
8. UH	375	68	70	70	63	70	716
9. POH	336	0	0	0	0	0	336
10. FOH & EFOH	36	63	65	65	59	65	353
11. MOH & EMOH	20	35	36	36	33	36	196
12. OPER BTU (GBTU)	1427.774	2434.167	2252.173	2259.391	2174.097	2560.989	13108.591
13. NET GEN (MWH)	143978	245249	224721	225778	217925	258310	1315961
14. ANOHR (BTU/KWH)	9917	9925	10022	10007	9976	9914	9961
15. NOF (%)	90.3	87.3	77.4	77.7	83.0	88.9	83.6
16. NSC (MW)	431	431	431	431	431	431	431
17. ANOHR EQUATION	ANOHR = NOF(-18.2305) + 11485.3						

FILED:  
 SUSPENDED:  
 EFFECTIVE: 10/01/97  
 DOCKET NO.: 970001-EI  
 ORDER NO.:

## TAMPA ELECTRIC COMPANY

## ESTIMATED UNIT PERFORMANCE DATA

OCTOBER 1997 - MARCH 1998

PLANT/UNIT	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	PERIOD
BIG BEND 3 FADJ	OCT 97	NOV 97	DEC 97	JAN 98	FEB 98	MAR 98	WINTER 1997
1. EAF (%)	83.8	25.1	83.7	83.7	83.8	83.7	74.1
2. POF	0.0	70.0	0.0	0.0	0.0	0.0	11.5
3. EUOF	16.2	4.9	16.3	16.3	16.2	16.3	14.4
4. EUOR	16.2	16.2	16.3	16.3	16.2	16.3	16.2
5. PH	745	720	744	744	672	744	4369
6. SH	652	189	652	652	589	652	3386
7. RSH	0	0	0	0	0	0	0
8. UH	93	531	92	92	83	92	983
9. FOH	0	504	0	0	0	0	504
10. FOH & EFOH	91	26	91	91	82	91	472
11. MOH & EMOH	30	9	30	30	27	30	156
12. OPER BTU (GBTU)	2568.566	735.645	2367.679	2420.799	2275.732	2579.240	12947.661
13. NET GEN (MWH)	263823	75709	243893	249326	234580	265376	1332807
14. ANOHR (BTU/KWH)	9732	9717	9708	9709	9701	9719	9715
15. NOF (%)	92.2	91.2	85.2	87.1	90.7	92.7	89.7
16. NSC (MW)	439	439	439	439	439	439	439
17. ANOHR EQUATION	$\text{ANOHR} = \text{NOF}(-17.9962) + 11328.8$						

FILED:  
 SUSPENDED:  
 EFFECTIVE: 10/01/97  
 DOCKET NO.: 970001-EI  
 ORDER NO.:

## TAMPA ELECTRIC COMPANY

## ESTIMATED UNIT PERFORMANCE DATA

OCTOBER 1997 - MARCH 1998

PLANT/UNIT	MONTH OF: OCT 97	MONTH OF: NOV 97	MONTH OF: DEC 97	MONTH OF: JAN 98	MONTH OF: FEB 98	MONTH OF: MAR 98	PERIOD WINTER 1997
BIG BEND 4							
1. EAF (%)	91.7	91.7	91.7	91.7	72.0	47.3	81.1
2. POF	0.0	0.0	0.0	0.0	21.4	48.4	11.5
3. EUOF	8.3	8.3	8.3	8.3	6.5	4.3	7.4
4. EUOR	8.3	8.3	8.3	8.3	8.3	8.3	8.3
5. PH	745	720	744	744	672	744	4369
6. SH	710	687	710	710	504	367	3688
7. RSH	0	0	0	0	0	0	0
8. UH	35	33	34	34	168	377	681
9. POH	0	0	0	0	144	360	504
10. FOH & EFOH	32	31	32	32	23	17	167
11. MOH & EMOH	30	29	30	30	21	15	155
12. OPER BTU (GBTU)	2841.278	2654.026	2601.190	2666.688	1983.029	1512.064	14258.275
13. NET GEN (MWH)	283387	264023	258994	266049	198553	151297	1422303
14. ANOHR (BTU/KWH)	10026	10052	10043	10023	9987	9994	10025
15. NOF (%)	89.3	86.0	81.6	83.8	88.1	92.2	86.3
16. NSC (MW)	447	447	447	447	447	447	447
17. ANOHR EQUATION	ANOHR = NOF(-8.9808) + 10625.5						

FILED:  
SUSPENDED:  
EFFECTIVE: 10/01/97  
DOCKET NO.: 970001-EI  
ORDER NO.:

## TAMPA ELECTRIC COMPANY

## ESTIMATED UNIT PERFORMANCE DATA

OCTOBER 1997 - MARCH 1998

PLANT/UNIT	MONTH OF: OCT 97	MONTH OF: NOV 97	MONTH OF: DEC 97	MONTH OF: JAN 98	MONTH OF: FEB 98	MONTH OF: MAR 98	PERIOD WINTER 1997
GANNON 1							
1. EAF (%)	49.8	85.7	85.6	85.6	85.7	85.6	79.5
2. POF	41.9	0.0	0.0	0.0	0.0	0.0	7.1
3. EUOF	8.3	14.3	14.4	14.4	14.3	14.4	13.3
4. EUOR	14.3	14.3	14.4	14.4	14.3	14.4	14.3
5. PH	745	720	744	744	672	744	4369
6. SH	245	313	482	488	462	531	2521
7. RSH	0	0	0	0	0	0	0
8. UH	500	407	262	256	210	213	1848
9. POH	312	0	0	0	0	0	312
10. FOH & EFOH	23	39	40	40	36	40	218
11. MOH & EMOH	39	64	67	67	60	67	364
12. OPER BTU (GBTU)	320.059	373.534	439.883	416.603	469.976	579.544	2599.599
13. NET GEN (MWH)	27632	32354	37141	34787	40067	49653	221634
14. ANOHR (BTU/KWH)	11583	11545	11844	11976	11730	11672	11729
15. NOF (%)	94.8	86.9	64.8	59.9	72.9	78.6	73.9
16. NSC (MW)	119	119	119	119	119	119	119

FILED  
SUSPENDED:  
EFFECTIVE: 10/01/97  
DOCKET NO.: 970001-EI  
ORDER NO.:

## TAMPA ELECTRIC COMPANY

## ESTIMATED UNIT PERFORMANCE DATA

OCTOBER 1997 - MARCH 1998

PLANT/UNIT	MONTH OF: OCT 97	MONTH OF: NOV 97	MONTH OF: DEC 97	MONTH OF: JAN 98	MONTH OF: FEB 98	MONTH OF: MAR 98	PERIOD WINTER 1997
GANNON 2							
1. EAF (%)	71.1	71.1	71.1	71.1	71.0	71.1	71.1
2. POF	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3. EUOF	28.9	28.9	28.9	28.9	29.0	28.9	28.9
4. EUOR	28.9	28.9	28.9	28.9	29.0	28.9	28.9
5. PH	745	720	744	744	672	744	4369
6. SH	366	300	426	433	413	473	2411
7. RSH	0	0	0	0	0	0	0
8. UH	379	420	318	311	259	271	1958
9. POH	0	0	0	0	0	0	0
10. FOH & EFOH	155	150	155	155	140	155	910
11. MOH & EMOH	60	58	60	60	55	60	353
12. OPER BTU (GBTU)	449,554	344,730	373,968	400,313	421,148	503,931	2493,644
13. NET GEN (MWH)	38193	29908	32077	34535	36548	43267	214528
14. ANOHR (BTU/KWH)	11771	11526	11658	11592	11523	11647	11624
15. NOF (%)	88.4	84.5	63.8	67.6	75.0	77.5	75.4
16. NSC (MW)	118	116	118	118	118	118	118

FILED:  
SUSPENDED:  
EFFECTIVE: 10/01/97  
DOCKET NO.: 970001-EI  
ORDER NO.:

## TAMPA ELECTRIC COMPANY

## ESTIMATED UNIT PERFORMANCE DATA

OCTOBER 1997 - MARCH 1998

PLANT/UNIT	MONTH OF: OCT 97	MONTH OF: NOV 97	MONTH OF: DEC 97	MONTH OF: JAN 98	MONTH OF: FEB 98	MONTH OF: MAR 98	PERIOD WINTER 1997
GANNON 3							
1. EAF (%)	77.3	77.2	77.3	77.3	77.2	77.3	77.3
2. POF	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3. EUOF	22.7	22.8	22.7	22.7	22.8	22.7	22.7
4. EUOR	22.7	22.8	22.7	22.7	22.8	22.7	22.7
5. PH	745	720	744	744	672	744	4369
6. SH	404	343	463	471	456	512	2649
7. RSH	0	0	0	0	0	0	0
8. UH	341	377	281	273	216	232	1720
9. POH	0	0	0	0	0	0	0
10. FOH & EFOH	101	98	101	101	92	101	594
11. MOH & EMOH	68	66	68	68	61	68	399
12. OPER BTU (GBTU)	655.726	523.624	570.472	593.467	627.265	726.193	3696.747
13. NET GEN (MWH)	57419	46497	50043	52262	55596	63952	325769
14. ANOHR (BTU/KWH)	11420	11261	11400	11358	11283	11355	11348
15. NOF (%)	91.7	87.5	69.7	71.6	78.7	80.6	79.3
16. NSC (MW)	155	155	155	155	155	155	155

FILED:  
SUSPENDED:  
EFFECTIVE: 10/01/97  
DOCKET NO.: 970001-EI  
ORDER NO.:

## TAMPA ELECTRIC COMPANY

## ESTIMATED UNIT PERFORMANCE DATA

OCTOBER 1997 - MARCH 1998

PLANT/UNIT	MONTH OF:	PERIOD					
	OCT 97	NOV 97	DEC 97	JAN 98	FEB 98	MAR 98	WINTER 1997
1. EAF (%)	86.2	86.3	86.2	86.2	86.2	86.2	86.2
2. POF	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3. EUOF	13.8	13.8	13.8	13.8	13.8	13.8	13.8
4. EUOR	13.8	13.8	13.8	13.8	13.8	13.8	13.8
5. PH	745	720	744	744	672	744	4369
6. SH	469	394	518	516	501	564	2962
7. RSH	0	0	0	0	0	0	0
8. UH	276	326	226	228	171	180	1407
9. POH	0	0	0	0	0	0	0
10. FOH & EFOH	57	55	57	57	52	57	335
11. MOH & EMOH	46	44	46	46	41	46	269
12. OPER BTU (GBTU)	882,623	702,610	573,672	601,914	696,085	880,233	4337,137
13. NET GEN (MWH)	79856	64245	50215	53033	62386	79358	389093
14. ANOHR (BTU/KWH)	11053	10936	11424	11350	11158	11092	11147
15. NOF (%)	90.1	86.3	51.3	54.4	65.9	74.4	69.5
16. NSC (MW)	189	189	189	189	189	189	189

FILED:  
 SUSPENDED:  
 EFFECTIVE 10/01/97  
 DOCKET NO.: 970001-EI  
 ORDER NO.:

## TAMPA ELECTRIC COMPANY

## ESTIMATED UNIT PERFORMANCE DATA

OCTOBER 1997 - MARCH 1998

PLANT/UNIT	MONTH OF: OCT 97	MONTH OF: NOV 97	MONTH OF: DEC 97	MONTH OF: JAN 98	MONTH OF: FEB 98	MONTH OF: MAR 98	PERIOD WINTER 1997
GANNON 5							
1. EAF (%)	87.4	87.4	47.8	87.5	65.6	87.5	77.3
2. POF	0.0	0.0	45.2	0.0	25.0	0.0	11.5
3. EUOF	12.6	12.6	7.0	12.5	9.4	12.5	11.1
4. EUOR	12.6	12.6	12.7	12.5	12.5	12.5	12.6
5. PH	745	720	744	744	672	744	4369
6. SH	686	664	376	686	465	686	3563
7. RSH	0	0	0	0	0	0	0
8. UH	59	56	368	58	207	58	806
9. POH	0	0	336	0	168	0	504
10. FOH & EFOH	75	72	41	74	50	74	386
11. MOH & EMOH	19	19	11	19	13	19	100
12. OPER BTU (GBTU)	1242.838	1094.813	526.659	1061.106	794.362	1209.090	5928.868
13. NET GEN (MWH)	118451	105715	50518	102485	77091	117024	571284
14. ANOHR (BTU/KWH)	10492	10356	10425	10354	10304	10332	10378
15. NOF (%)	74.4	68.6	57.9	64.4	71.5	73.5	69.1
16. NSC (MW)	232	232	232	232	232	232	232
17. ANOHR EQUATION	ANOHR = NOF(-18.7056) + 11670.7						

FILED:  
SUSPENDED:  
EFFECTIVE: 10/01/97  
DOCKET NO.: 970001-EI  
ORDER NO.:

## TAMPA ELECTRIC COMPANY

## ESTIMATED UNIT PERFORMANCE DATA

OCTOBER 1997 - MARCH 1998

PLANT/UNIT	MONTH OF: OCT 97	MONTH OF: NOV 97	MONTH OF: DEC 97	MONTH OF: JAN 98	MONTH OF: FEB 98	MONTH OF: MAR 98	PERIOD WINTER 1997
GANNON 6							
1. EAF (%)	89.4	89.4	89.4	89.4	89.4	83.6	88.4
2. POF	0.0	0.0	0.0	0.0	0.0	6.5	1.1
3. EUOF	10.6	10.6	10.6	10.6	10.6	9.9	10.5
4. EUOR	10.6	10.6	10.6	10.6	10.6	10.6	10.6
5. PH	745	720	744	744	672	744	4389
6. SH	679	657	679	679	613	634	3941
7. RSH	0	0	0	0	0	0	0
8. UH	66	63	65	65	59	110	428
9. POH	0	0	0	0	0	48	48
10. FOH & EFOH	41	40	41	41	37	38	238
11. MOH & EMOH	38	37	38	38	34	36	220
12. OPER BTU (GBTU)	2121.245	1851.908	1514.267	1713.180	1804.019	1944.876	10949.495
13. NET GEN (MWH)	198290	173663	139359	159517	169997	183212	1024038
14. ANOHR (BTU/KWH)	0	10664	10866	10740	10612	10615	10692
15. NOF (%)	0.0	67.4	52.4	59.9	70.7	73.7	66.3
16. NSC (MW)	392	392	392	392	392	392	392
17. ANOHR EQUATION	ANOHR = NOF(-18.7199) + 11833.6						

FILED:  
SUSPENDED:  
EFFECTIVE: 10/01/97  
DOCKET NO.: 970001-EI  
ORDER NO.:

## TAMPA ELECTRIC COMPANY

## ESTIMATED UNIT PERFORMANCE DATA

OCTOBER 1997 - MARCH 1998

PLANT/UNIT	MONTH OF:	PERIOD					
	OCT 97	NOV 97	DEC 97	JAN 98	FEB 98	MAR 98	WINTER 1997
HOOKERS PT 1							
1. EAF (%)	93.0	93.1	93.0	72.0	93.2	93.0	89.5
2. POF	0.0	0.0	0.0	22.6	0.0	0.0	3.8
3. EUOF	7.0	6.9	7.0	5.4	6.8	7.0	6.7
4. EUOR	7.0	6.9	7.0	6.9	6.8	7.0	7.0
5. PH	745	720	744	744	672	744	4369
6. SH	25	5	2	0	0	0	32
7. RSH	0	0	0	0	0	0	0
8. UH	720	715	742	744	672	744	4337
9. POH	0	0	0	168	0	0	168
10. FOH & EFOH	36	35	36	28	32	36	203
11. MOH & EMOH	16	15	16	12	14	16	89
12. OPER BTU (GBTU)	13,162	2,446	1,096	0.000	0.000	0.000	16,704
13. NET GEN (MWH)	775	146	66	0	0	0	987
14. ANOHR (BTU/KWH)	16983	16753	16606	0	0	0	16924
15. NOF (%)	91.2	85.9	97.1	0.0	0.0	0.0	90.7
16. NSC (MW)	34	34	34	34	34	34	34

FILED:  
 SUSPENDED:  
 EFFECTIVE: 10/01/97  
 DOCKET NO.: 970001-EI  
 ORDER NO.:

## TAMPA ELECTRIC COMPANY

## ESTIMATED UNIT PERFORMANCE DATA

OCTOBER 1997 - MARCH 1998

PLANT/UNIT	MONTH OF: OCT 97	MONTH OF: NOV 97	MONTH OF: DEC 97	MONTH OF: JAN 98	MONTH OF: FEB 98	MONTH OF: MAR 98	PERIOD WINTER 1997
HOOKERS PT 2							
1. EAF (%)	93.0	93.1	93.0	72.0	93.2	93.0	89.5
2. POF	0.0	0.0	0.0	22.6	0.0	0.0	3.8
3. EUOF	7.0	6.9	7.0	5.4	6.8	7.0	6.7
4. EUOR	7.0	6.9	7.0	6.9	6.8	7.0	7.0
5. PH	745	720	744	744	672	744	4369
6. SH	28	5	2	0	0	0	35
7. RSH	0	0	0	0	0	0	0
8. UH	717	715	742	744	672	744	4334
9. POH	0	0	0	168	0	0	168
10. FOH & EFOH	36	35	36	28	32	36	203
11. MOH & EMOH	16	15	16	12	14	16	89
12. OPER BTU (GBTU)	14,991	2,655	0.941	0.000	0.000	0.000	18,787
13. NET GEN (MWH)	896	172	57	0	0	0	1125
14. ANOHR (BTU/KWH)	16731	16599	16509	0	0	0	16700
15. NOF (%)	94.1	101.2	83.8	0.0	0.0	0.0	94.5
16. NSC (MW)	34	34	34	34	34	34	34

FILED:  
SUSPENDED:  
EFFECTIVE: 10/01/97  
DOCKET NO.: 970001-EI  
ORDER NO.:

## TAMPA ELECTRIC COMPANY

## ESTIMATED UNIT PERFORMANCE DATA

OCTOBER 1997 - MARCH 1998

PLANT/UNIT	MONTH OF:	PERIOD					
	OCT 97	NOV 97	DEC 97	JAN 98	FEB 98	MAR 98	WINTER 1997
HOOKERS PT 3							
1. EAF (%)	93.0	93.1	93.0	72.0	93.2	93.0	89.5
2. POF	0.0	0.0	0.0	22.6	0.0	0.0	3.8
3. EUOF	7.0	6.9	7.0	5.4	6.8	7.0	6.7
4. EUOR	7.0	6.9	7.0	6.9	6.8	7.0	7.0
5. PH	745	720	744	744	672	744	4369
6. SH	32	6	2	0	0	0	40
7. RSH	0	0	0	0	0	0	0
8. UH	713	714	742	744	672	744	4329
9. POH	0	0	0	168	0	0	168
10. FOH & EFOH	36	35	36	28	32	36	203
11. MOH & EMOH	16	15	16	12	14	16	89
12. OPER BTU (GBTU)	17,044	3,290	1,247	0,000	0,000	0,000	21,581
13. NET GEN (MWH)	1029	201	77	0	0	0	1307
14. ANOHR (BTU/KWH)	16564	16368	16195	0	0	0	16512
15. NOF (%)	94.6	98.5	113.2	0.0	0.0	0.0	96.1
16. NSC (MW)	34	34	34	34	34	34	34

FILED:  
 SUSPENDED:  
 EFFECTIVE: 10/01/97  
 DOCKET NO.: 970001-EI  
 ORDER NO.:

## TAMPA ELECTRIC COMPANY

## ESTIMATED UNIT PERFORMANCE DATA

OCTOBER 1997 - MARCH 1998

PLANT/UNIT	MONTH OF:	PERIOD					
	OCT 97	NOV 97	DEC 97	JAN 98	FEB 98	MAR 98	WINTER 1997
HOOKERS PT 4							
1. EAF (%)	93.0	93.1	93.0	72.0	93.2	93.0	89.5
2. POF	0.0	0.0	0.0	22.6	0.0	0.0	3.6
3. EUOF	7.0	6.9	7.0	5.4	6.8	7.0	6.7
4. EUOR	7.0	6.9	7.0	6.9	6.8	7.0	7.0
5. PH	745	720	744	744	672	744	4369
6. SH	38	8	3	0	0	0	49
7. RSH	0	0	0	0	0	0	0
8. UH	707	712	741	744	672	744	4320
9. POH	0	0	0	188	0	0	168
10. FOH & EFOH	36	35	36	28	32	36	203
11. MOH & EMOH	16	15	16	12	14	16	89
12. OPER BTU (GBTU)	24.730	4.836	1.808	0.000	0.000	0.000	31.374
13. NET GEN (MWH)	1517	302	114	0	0	0	1933
14. ANOHR (BTU/KWH)	16302	16013	15880	0	0	0	16231
15. NOF (%)	92.8	87.8	88.4	0.0	0.0	0.0	91.7
16. NSC (MW)	43	43	43	43	43	43	43

FILED:  
 SUSPENDED:  
 EFFECTIVE: 10/01/97  
 DOCKET NO.: 970001-EI  
 ORDER NO.:

## TAMPA ELECTRIC COMPANY

## ESTIMATED UNIT PERFORMANCE DATA

OCTOBER 1997 - MARCH 1998

PLANT/UNIT	MONTH OF:	PERIOD					
	OCT 97	NOV 97	DEC 97	JAN 98	FEB 98	MAR 98	WINTER 1997
1. EAF (%)	79.6	79.5	79.6	77.0	62.5	79.6	76.5
2. POF	0.0	0.0	0.0	3.2	21.4	0.0	3.8
3. EUOF	20.4	20.4	20.4	19.8	16.1	20.4	19.6
4. EUOR	20.4	20.4	20.4	20.4	20.5	20.4	20.4
5. PH	745	720	744	744	672	744	4369
6. SH	42	9	3	0	0	0	54
7. RSH	0	0	0	0	0	0	0
8. UH	703	711	741	744	672	744	4315
9. POH	0	0	0	24	144	0	168
10. FOH & EFOH	121	117	121	117	86	121	683
11. MOH & EMOH	31	30	31	30	22	31	175
12. OPER BTU (GBTU)	40,027	7,965	2,961	0,000	0,000	0,000	50,953
13. NET GEN (MWH)	2459	496	186	0	0	0	3141
14. ANOHR (BTU/KWH)	16278	16058	15919	0	0	0	16222
15. NOF (%)	87.4	82.3	92.5	0.0	0.0	0.0	86.8
16. NSC (MW)	67	67	67	67	67	67	67

FILED:  
SUSPENDED:  
EFFECTIVE: 10/01/97  
DOCKET NO.: 970001-EI  
ORDER NO.:

## TAMPA ELECTRIC COMPANY

## ESTIMATED UNIT PERFORMANCE DATA

OCTOBER 1997 - MARCH 1998

PLANT/UNIT	MONTH OF:	PERIOD					
	OCT 97	NOV 97	DEC 97	JAN 98	FEB 98	MAR 98	WINTER 1997
1. EAF (%)	77.9	77.9	77.8	57.8	78.0	77.8	74.5
2. POF	0.0	0.0	0.0	25.8	0.0	0.0	4.4
3. EUOF	22.1	22.1	22.2	16.4	22.0	22.2	21.1
4. EUOR	22.1	22.1	22.2	22.1	22.0	22.2	22.1
5. PH	745	720	744	744	672	744	4369
6. SH	10	2	1	5	5	8	31
7. RSH	0	0	0	0	0	0	0
8. UH	735	718	743	739	687	736	4338
9. POH	0	0	0	192	0	0	192
10. FOH & EFOH	149	144	149	110	134	149	835
11. MOH & EMOH	16	15	16	12	14	16	89
12. OPER BTU (GBTU)	3.160	0.520	0.224	1.744	1.917	2.773	10.338
13. NET GEN (MWH)	144	24	10	80	88	127	473
14. ANOHR (BTU/KWH)	21944	21667	22400	21800	21784	21835	21856
15. NOF (%)	84.7	70.6	58.8	94.1	103.5	93.4	89.8
16. NSC (MW)	17	17	17	17	17	17	17

FILED:  
 SUSPENDED:  
 EFFECTIVE: 10/01/97  
 DOCKET NO.: 970001-EI  
 ORDER NO.:

## TAMPA ELECTRIC COMPANY

## ESTIMATED UNIT PERFORMANCE DATA

OCTOBER 1997 - MARCH 1998

PLANT/UNIT	MONTH OF: OCT 97	MONTH OF: NOV 97	MONTH OF: DEC 97	MONTH OF: JAN 98	MONTH OF: FEB 98	MONTH OF: MAR 98	PERIOD WINTER 1997
BIG BEND CT 1							
1. EAF (%)	65.0	65.0	64.9	64.9	65.0	64.9	65.0
2. POF	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3. EUOF	35.0	35.0	35.1	35.1	35.0	35.1	35.0
4. EUOR	35.0	35.0	35.1	35.1	35.0	35.1	35.0
5. PH	745	720	744	744	672	744	4369
6. SH	11	2	1	5	6	8	33
7. RSH	0	0	0	0	0	0	0
8. UH	734	718	743	739	666	736	4336
9. POH	0	0	0	0	0	0	0
10. FOH & EFOH	149	144	149	149	134	149	874
11. MOH & EMOH	112	108	112	112	101	112	657
12. OPER BTU (GBTU)	2.930	0.485	0.210	1.597	1.773	2.583	9.578
13. NET GEN (MWH)	153	25	11	83	92	135	499
14. ANOHR (BTU/KWH)	19150	19400	19091	19241	19272	19133	19194
15. NOF (%)	81.8	73.5	64.7	97.6	90.2	99.3	88.9
16. NSC (MW)	17	17	17	17	17	17	17

FILED:  
SUSPENDED:  
EFFECTIVE: 10/01/97  
DOCKET NO.: 970001-EI  
ORDER NO.:

## TAMPA ELECTRIC COMPANY

## ESTIMATED UNIT PERFORMANCE DATA

OCTOBER 1997 - MARCH 1998

PLANT/UNIT	MONTH OF:	PERIOD					
	OCT 97	NOV 97	DEC 97	JAN 98	FEB 98	MAR 98	WINTER 1997
1. EAF (%)	69.1	69.2	69.1	69.1	69.0	37.9	63.8
2. POF	0.0	0.0	0.0	0.0	0.0	45.2	7.7
3. EUOF	30.9	30.8	30.9	30.9	31.0	16.9	28.5
4. EUOR	30.9	30.8	30.9	30.9	31.0	30.9	30.9
5. PH	745	720	744	744	672	744	4369
6. SH	18	3	1	8	10	8	48
7. RSH	0	0	0	0	0	0	0
8. UH	727	717	743	736	662	736	4321
9. POH	0	0	0	0	0	336	336
10. FOH & EFOH	115	111	115	115	104	63	623
11. MOH & EMOH	115	111	115	115	104	63	623
12. OPER BTU (GBTU)	16,899	2,810	1,525	9,894	11,561	9,233	52,022
13. NET GEN (MWH)	1016	168	96	625	734	585	3224
14. ANOHR (BTU/KWH)	16633	16726	15885	15830	15887	15783	16136
15. NOF (%)	66.4	65.9	112.9	91.9	86.4	86.0	79.0
16. NSC (MW)	85	85	85	85	85	85	85

FILED:  
 SUSPENDED:  
 EFFECTIVE: 10/01/97  
 DOCKET NO.: 970001-EI  
 ORDER NO.:

## TAMPA ELECTRIC COMPANY

## ESTIMATED UNIT PERFORMANCE DATA

OCTOBER 1997 - MARCH 1998

PLANT/UNIT	MONTH OF:	PERIOD					
	OCT 97	NOV 97	DEC 97	JAN 98	FEB 98	MAR 98	WINTER 1997
1. EAF (%)	69.1	69.2	69.1	69.1	69.0	69.1	69.1
2. POF	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3. EUOF	30.9	30.8	30.9	30.9	31.0	30.9	30.9
4. EUOR	30.9	30.8	30.9	30.9	31.0	30.9	30.9
5. PH	745	720	744	744	672	744	4369
6. SH	14	2	1	7	8	12	44
7. RSH	0	0	0	0	0	0	0
8. UH	731	718	743	737	664	732	4325
9. POH	0	0	0	0	0	0	0
10. FOH & EFOH	115	111	115	115	104	115	675
11. MOH & EMOH	115	111	115	115	104	115	675
12. OPER BTU (GBTU)	13,561	2,246	1,148	8,057	9,171	13,577	47,760
13. NET GEN (MWH)	797	132	70	498	565	833	2895
14. ANOHR (BTU/KWH)	17015	17015	16400	16179	16232	16299	16497
15. NOF (%)	67.0	77.6	82.4	83.7	83.1	81.7	77.4
16. NSC (MW)	85	85	85	85	85	85	85

FILED:  
 SUSPENDED:  
 EFFECTIVE 10/01/97  
 DOCKET NO. 970001-EI  
 ORDER NO.:

## TAMPA ELECTRIC COMPANY

## ESTIMATED UNIT PERFORMANCE DATA

OCTOBER 1997 - MARCH 1998

PLANT/UNIT	MONTH OF: OCT 97	MONTH OF: NOV 97	MONTH OF: DEC 97	MONTH OF: JAN 98	MONTH OF: FEB 98	MONTH OF: MAR 98	PERIOD WINTER 1997
PHILLIPS 1							
1. EAF (%)	28.5	21.4	80.0	80.0	80.1	80.0	61.5
2. POF	64.4	73.3	0.0	0.0	0.0	0.0	23.1
3. EUOF	7.1	5.3	20.0	20.0	19.9	20.0	15.4
4. EUOR	20.0	19.8	20.0	20.0	19.9	20.0	20.0
5. PH	745	720	744	744	672	744	4369
6. SH	16	5	7	18	35	75	156
7. RSH	0	0	0	0	0	0	0
8. UH	729	715	737	726	637	669	4213
9. POH	480	528	0	0	0	0	1008
10. FOH & EFOH	19	13	52	52	47	52	235
11. MOH & EMOH	34	25	97	97	87	97	437
12. OPER BTU (GBTU)	2,628	0.746	1.024	2.956	5.667	12.076	25,097
13. NET GEN (MWH)	271	77	106	305	584	1245	2588
14. ANOHR (BTU/KWH)	9697	9688	9660	9692	9704	9700	9697
15. NOF (%)	99.6	90.6	89.1	99.7	98.2	97.6	97.6
16. NSC (MW)	17	17	17	17	17	17	17

FILED:  
SUSPENDED  
EFFECTIVE: 10/01/97  
DOCKET NO.: 970001-EI  
ORDER NO.:

## TAMPA ELECTRIC COMPANY

## ESTIMATED UNIT PERFORMANCE DATA

OCTOBER 1997 - MARCH 1998

PLANT/UNIT	MONTH OF: OCT 97	MONTH OF: NOV 97	MONTH OF: DEC 97	MONTH OF: JAN 98	MONTH OF: FEB 98	MONTH OF: MAR 98	PERIOD WINTER 1997
PHILLIPS 2							
1. EAF (%)	80.0	80.0	80.0	80.0	80.1	80.0	80.0
2. POF	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3. EUOF	20.0	20.0	20.0	20.0	19.9	20.0	20.0
4. EUOR	20.0	20.0	20.0	20.0	19.9	20.0	20.0
5. PH	745	720	744	744	672	744	4369
6. SH	48	16	6	18	35	74	197
7. RSH	0	0	0	0	0	0	0
8. UH	697	704	738	726	637	670	4172
9. POH	0	0	0	0	0	0	0
10. FOH & EFOH	52	50	52	52	47	52	305
11. MOH & EMOH	97	94	97	97	87	97	589
12. OPER BTU (GBTU)	7.687	2.554	0.994	2.925	5.621	12.024	31.805
13. NET GEN (MWH)	793	263	102	301	579	1239	3277
14. ANOHR (BTU/KWH)	9694	9711	9745	9718	9708	9705	9706
15. NOF (%)	97.2	96.7	100.0	98.4	97.3	98.5	97.9
16. NSC (MW)	17	17	17	17	17	17	17

FILED:  
SUSPENDED  
EFFECTIVE 10/01/97  
DOCKET NO. 970001-EI  
ORDER NO.:

## TAMPA ELECTRIC COMPANY

## ESTIMATED UNIT PERFORMANCE DATA

OCTOBER 1997 - MARCH 1998

PLANT/UNIT	MONTH OF: OCT 97	MONTH OF: NOV 97	MONTH OF: DEC 97	MONTH OF: JAN 98	MONTH OF: FEB 98	MONTH OF: MAR 98	PERIOD WINTER 1997
POLK							
1. EAF (%)	2.6	80.1	80.1	80.1	80.1	72.4	62.5
2. POF	96.8	0.0	0.0	0.0	25.0	9.7	22.0
3. EUOF	0.7	19.9	19.9	19.9	14.9	17.8	15.5
4. EUOR	20.8	19.9	19.9	19.9	19.8	19.8	19.9
5. PH	745	720	744	744	672	744	4369
6. SH	20	570	585	672	456	611	2914
7. RSH	0	0	0	0	0	0	0
8. UH	725	150	159	72	216	133	1455
9. POH	721	0	0	0	168	72	961
10. FOH & EFOH	3	86	89	89	60	80	407
11. MOH & EMOH	2	57	59	59	40	53	270
12. OPER BTU (GBTU)	45.175	1338.760	1370.010	1536.460	1050.630	1404.810	6745.845
13. NET GEN (MWH)	4791	141571	144574	165928	113713	152140	722717
14. ANOHR (BTU/KWH)	9429	9456	9476	9260	9239	9234	9334
15. NOF (%)	95.8	99.3	98.9	98.8	99.7	99.6	99.2
16. NSC (MW)	250	250	250	250	250	250	250

FILED:  
SUSPENDED:  
EFFECTIVE: 10/01/97  
DOCKET NO.: 970001-EI  
ORDER NO.: