

LAW OFFICES
ROSE, SUNDSTROM & BENTLEY, LLP
2548 BLAIRSTONE PINES DRIVE
TALLAHASSEE, FLORIDA 32301
(904) 877-6555

ORIGINAL

CHRIS H. BENTLEY, P.A.
F. MARSHALL DETERDING
BRIAN L. GOSTER
MARTIN S. FRIEDMAN, P.A.
JOHN R. JENKINS, P.A.
STEVEN T. MINDLIN, P.A.
ROBERT M. G. ROSE
DAREN L. SHIPPY
WILLIAM E. SUNDSTROM, P.A.
DIANE D. TREMOR, P.A.
JOHN L. WHARTON

MAILING ADDRESS
POST OFFICE BOX 1567
TALLAHASSEE, FLORIDA 32302-1567
TELECOPIER (904) 888-4029

September 22, 1997

VIA HAND DELIVERY

Martha A. Golden, Economic Analyst
Division of Water and Wastewater
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399-0850

Re: Radnor/Plantation Corporation; Joint Application for Authority
to Transfer Facilities; Docket No. 970429-WS
Our File No. 25067.01


Dear Martha:

Attached is a copy of a letter from the DEP to Radnor
concerning final certification of the corrosion control program
implemented by the Utility.

Should you have any further questions concerning this, please
let me know.

Sincerely,

ROSE, SUNDSTROM & BENTLEY, LLP


F. Marshall Deterding
For The Firm

ACK _____
AFA _____
APP _____
CAF _____
CMU _____
CTR _____
EAG _____
LEG _____
LIN _____
OPC _____
RCH _____
SEC 1 _____
WAS _____
OTH _____

FMD/lts
Enclosures
cc: Ms. Blanca Bayo
Rosanne Gervasi, Esquire
Ms. Joann Chase
Richard Redemann, P.E.
Mr. Bill Dean
Matthew Commisky, Esquire
Bruce May, Esquire

DOCUMENT NUMBER-DATE

09623 SEP 22 5

FPSC-RECORDS/REPORTING



Department of Environmental Protection

Lawton Chiles
Governor

Southeast District
P.O. Box 15425
West Palm Beach, Florida 33416

Virginia B. Wetherell
Secretary

AUG 25 1997

Timothy Q. Hudak, Vice President
IHC Realty Partnership, L.P.
680 Andersen Drive
Pittsburgh, PA 15220

Permit Number: WC-43-261691
Permit Issued: December 27, 1994
County: Martin
Public Water System: Indian River Plantation
Project: Corrosion Control

Re: Approval to Operate Corrosion Control Treatment System

Dear Mr. Hudak:

This acknowledges receipt of certification that the subject modification to the referenced public water system has been completed in accordance with the plans and related materials approved by this agency. Based on the information provided, the project described as follows is acceptable for service:

One chemical feed pump, rated for 24 gallons per day (gpd) for feeding an orthopolyphosphate blend (Calciquest Zink 1037) to the suction side of the high service pumps; and a 30 gallon solution tank. The dosage rate is proposed to be 4.0 milligrams per liter (mg/L). The chemical feed pump is activated by the high service pumps.

Responsibility for the system includes the following duties which are required by Florida Administrative Code (F.A.C.) Chapter 62-550, and 40 CFR 141:

1. Monitoring for water quality parameters at the locations and frequencies as specified in 40 CFR 141.87(c)(1) and (2), is required as follows:
 - a) Distribution system taps: 1 set of samples (pH, alkalinity, orthophosphate) every 3 months, at the same locations as specified in the Water Quality Parameter Sampling Plan.
 - b) Point of entry to distribution: 1 sample (pH, orthophosphate concentration and dosage) every two weeks.
2. Monitoring for lead and copper tap samples at the locations and frequencies as specified in 40 CFR 141.86(d)(2)(ii), is required as follows:
 - a) Frequency: Two consecutive six-month periods after implementation of corrosion control treatment.
 - b) Location: At the same tap sites as specified in the Lead and Copper Sampling Plan.


Timothy Q. Hudak, Vice President
IHC Realty Partnership, L.P.

Page 2

If the proposed project fails to demonstrate optimal corrosion control treatment, the permittee shall recommend an alternative corrosion control treatment from among those listed in 40 CFR 141.82(c)(1). A Department permit or written approval would be required for the alternate corrosion control treatment.

If you have any questions, please contact Michele Owens of this office at 561/681-6751.

Sincerely,



John Morra, P.E.
Program Manager
Drinking Water Section

JM:mo
mo

cc: John Lisle, Jr., Operations Supervisor - Indian River Plantation
Susan Stevens, Esquire - Holland and Knight, Tallahassee