



Public Service Commission  
-M-E-M-O-R-A-N-D-U-M-

---

**DATE:** July 22, 2003  
**TO:** Blanca Bayo, Director, Commission Clerk and Administrative Services  
**FROM:** Division Of Economic Regulation (Matlock) *sum*  
**RE:** Docket No. 030623-EI - Complaints by Southeastern Utility Services, Inc., on Behalf of Various Customers, against Florida Power & Light Company concerning Thermal Demand Meter Error

---

Please place the following correspondence in the above docket file.

- E-Mail from Roseann Lucas, FPL to Sid Matlock stating that the file sent with e-mail on Friday 7/18/03 was incorrect and incomplete. We were asked to disregard any previous files and use only the files attached to Tuesday, July 22, 2003 e-mail.
- George Brown refereed meter test results attached to Tuesday, July 22, 2003 e-mail from Roseanne Lucas, FPL.

Thanks.

SWM:kb

DOCUMENT NUMBER DATE

06571 JUL 22 8

FPSC-COMMISSION CLERK

**Sid Matlock**

---

**From:** Roseanne\_Lucas@fpl.com  
**Sent:** Tuesday, July 22, 2003 10:36 AM  
**To:** Sid Matlock  
**Cc:** jruehl@PSC.STATE.FL.US  
**Subject:** Target/ Updated FPSC- George Brown Refereed Meter Test Spread Sheet

FPSCRefereedGBMet      Target- brkdwn 46      FPSCRefereedGBMet  
ertestsrev7-2...      accts fpsc c...      ertestsrev7-1..      Sid,

I just realized that I attached an incorrect/incomplete file in the email I sent below to you on Friday, this is the file I should have sent to you. Please disregard any previous files sent to you.

(See attached file: FPSCRefereedGBMetertestsrev7-22.xls)  
----- Forwarded by Roseanne Lucas/RAD/FPL on 07/22/03 08:56 AM -----

Roseanne Lucas  
07/18/03 03:20 PM

To: smatlock@psc.state.fl.us  
cc:  
Subject: Target/ Updated FPSC- George

Brown Refereed

Meter Test Spread Sheet

Sid,

Here is the electronic file you requested for the 46 Target accounts and the updated spread sheet for all the meter tests witnessed by the FPSC and George Brown (a total of 47 meters).

(See attached file: Target- brkdwn 46 accts fpsc complaint 7-03.xls)  
(See attached file: FPSCRefereedGBMetertestsrev7-18.xls)

**FPSC/GEORGE BROWN REFEREED METER TEST RESULTS**

Revised 7/18/03

Target, Ocean Properties, Kash n' Karry, Food Lion, Walmart

ATTACHMENT #1

COMPANY						Scale	Full Scale	kWh Test	kWh Test	kWh Test	kWh Test	Test	RETEST	Full Scale	
COMPLAINT #	Premise	Sym	Num	Dst	Address	Value	% Error	SF%	SP%	SL%	WA%	Date	DATE	% Error	
TARGET CORPORATION (15)															
482065C	1.	435343416	1V	7032D	72	3251 HOLLYWOOD BLVD # 300	7	2.01	99.97	100.07	100.74	100.11	12/10/02	5/21/03	4.84
482065C	2.	862136933	1V	7019D	53	13711 S TAMiami TRL # 300	3.5	4.21	100.74	100.9	100.62	100.77	12/10/02	N/A	N/A
482065C	3.	3679858	1V	5192D	52	6150 14TH ST W	7	2.68	100.12	100.05	100.58	100.17	12/10/02	5/21/03	4.36
482065C	4.	3639292	1V	7505D	11	2380 WINTL SPEEDWAY BLVD	3.5	1.93	100.36	99.99	99.38	100.11	12/10/02	N/A	N/A
482065C	5.	552167401	1V	55773	42	5900 LAKE WORTH RD # TARGET	7	0.62	99.97	100.51	100.31	100.17	12/10/02	5/21/03	-0.63
482065C	6.	3587797	1V	7001D	41	1901 N CONGRESS AVE	3.5	4.6	100.44	100.08	97.65	99.94	12/10/02	N/A	N/A
482065C	7.	34079415	1V	5774D	54	26831 S TAMiami TRL # TARGET	7	-0.03	99.51	99.49	99.58	99.52	12/10/02	N/A	N/A
482065C	8.	3575420	1V	5025D	41	1200 LINTON BLVD # TARGET	7	1.73	100.2	99.74	99.34	99.95	12/10/02	5/21/03	4.12
482065C	9.	3582694	1V	5885D	41	21637 STATE ROAD 7 # TARGET	7	2.73	99.91	99.76	99.44	99.80	12/10/02	5/21/03	4.84
482065C	10.	895487734	1V	7745D	86	14075 BISCAYNE BLVD	7	-1.12	100.18	100.14	99.27	100.04	12/10/02	5/21/03	-2.78
482065C	11.	941808655	1V	5211D	81	8458 S DIXIE HWY	7	-1.55	100.41	99.76	99.73	100.13	12/10/02	5/21/03	-2.78
482065C	12.	3627833	1V	5887D	55	1400 TAMiami TRL # TARGET	7	3.25	99.85	99.69	98.59	99.62	12/10/02	5/21/03	4.36
482065C	13.	3661074	1V	5159D	57	4271 TAMiami TRL S # TARGET	7	3.11	100.2	100.13	99.31	100.05	12/10/02	5/21/03	4.36
N/A	14.	73776531	1V	5679D	54	2324 PINE RIDGE RD	7	4.39	98.25	96.19	93.82	97.03	3/28/03	5/21/03	5.07
514226E	15.	299626231	1V	5871D	56	5350 Fruitville Rd	7	3.14	99.45	99.39	99.62	99.46	8/21/02	5/21/2003*	2.21
DILLARDS (1)															
521185E*	1934679	1V	5216D	73	9001 WATLANTIC BLVD	7	2.45	100.09	99.79	99.48	99.92	12/10/02	5/21/03	4.84	
*DOCKET# 30623-EI															

**TARGET FRUITVILLE\***

\* At the FPSC's request, on 4/3/03, meter (1V5871D) was retested. This retesting was witnessed by George Brown, FPSC Field Engineer, Clinton Willams and FPL Representatives. As requested, meter 1V5871D was retested only on demand, not kWh registration. In each test, upon adding load (approximately 61.4%), the red pusher pointer and the black indicator pointer moved together to register the highest point of demand. Once load was removed the pointers moved together to various points on the scale before the black indicator stopped somewhere between 2.75 and 3.7, leaving the red pusher pointer continuing back to 0 registration. The registration of the demand was within allowable tolerances each time it was tested, as follows: 3.32, 3.2, 3.57, 3.37

COMPANY						Scale	Full Scale	kWh Test	kWh Test	kWh Test	kWh Test	Test	RETEST	Full Scale	
COMPLAINT #	Premise	Sym	Num	Dst	Address	Value	% Error	SF%	SP%	SL%	WA%	Date	DATE	% Error	
Ocean Properties (7)															
N/A	1.	499514	1V	70077	41	10 N Ocean Blvd	3.5	1.26	100.49	100.46	99.19	100.3	2/26/03	N/A	N/A
480308-C	2.	2707050	1V	52093	52	100 Riverfront Holiday Inn	7	6.00	100.33	100.15	100.20	100.26	8/21/02		
N/A	3.	1280736	1V	54034	56	4711 GULF OF MEXICO DR	3.5	4.12	99.77	99.56	99.59	99.68	2/26/03	N/A	N/A
N/A	4.	434483	1V	59333	41	2809 S OCEAN BLVD # HSE	3.5	-0.15	99.93	99.56	100.38	99.89	2/26/03	N/A	N/A
N/A	5.	317438	1V	74963	41	1601 N Congress	7	3.77	100.24	100.48	99.36	100.18	2/26/03	5/21/03	3.41
N/A	6.	789229911	1U	53145	54	Highpoint Dr #Hotel	1.5	-1.68	100.49	100.66	100.3	100.51	2/26/03	N/A	N/A
N/A	7.	374675	1U	71993	41	8144 Glades Rd.	3	1.82	100.00	100.00	99.55	99.94	2/26/03	5/21/03	1.36
Hutchinson Island (1)															
N/A	1.	2888685	1U	82230	40	Hutchinson Island	3	0.15	100.1	99.36	98.86	99.71	2/26/03		

**FPSC/GEORGE BROWN REFEREED METER TEST RESULTS**  
Target, Ocean Properties, Kash n' Karry, Food Lion, Walmart

Revised 7/18/03



**FPSC/GEORGE BROWN REFEREED METER TEST RESULTS**

Revised 7/18/03

Target, Ocean Properties, Kash n' Karry, Food Lion, Walmart

COMPANY						Scale	Full Scal	kWh Test	kWh Test	kWh Test	kWh Test	Test	RETEST	Full Scale	
COMPLAINT#	Premise	Sym	Num	Dst	Address	Value	% Error	SF%	SP%	SL%	WA%	Date	DATE	% Error	
Kash N' Karry (8)															
499833C	1.	960069	1U	70868	52	5802 14th St #W	3	-3.17	101.06	100.61	100.01	100.78	02/26/03	N/A	N/A
499833C	2.	1333326	1U	77484	57	2111 Tamiami Tr	1.5	-0.01	99.68	99.00	98.32	99.29	02/26/03	N/A	N/A
499833C	3.	1333326	1U	71924	55	2050 Forrest Nelson	3	-19.84	99.94	99.61	99.1	99.72	02/26/03	N/A	N/A
499833C	4.	1333326	1U	71857	53	8595 College Pky	1.5	5.65	99.85	99.62	99.08	99.67	02/26/03	N/A	N/A
499833C	5.	1281530	1U	79391	56	4404 Bee Ridge Rd	1.5	3.65	100.53	100.27	99.6	100.32	02/26/03	N/A	N/A
499833C	6.	3732465	1U	56944	53	18751 Three Oaks	3	5.82	100.26	99.45	99.31	99.89	02/26/03		
499833C	7.	3732465	1U	78293	52	6015 26 st #W	3	2.02	99.86	99.8	99.03	99.72	02/26/03	5/21/03	2.69
499833C	8.	3715781	1U	51177	44	2820 SW Port St Lucie Blvd	METER REMOVED 5/01/02					N/A	N/A	N	

COMPANY						Scale	Full Scal	kWh Test	kWh Test	kWh Test	kWh Test	Test	RETEST	Full Scale	
COMPLAINT #	Premise	Sym	Num	Dst	Address	Value	% Error	SF%	SP%	SL%	WA%	Date	DATE	% Error	
Food Lion (7)															
499833C	1.	3668262	1U	71578	22	1569 Palm Bay Rd	3	-4.5	99.8	100.36	99.2	99.88	2/26/03	N/A	N/A
499833C	2.	3732465	1U	70636	32	Gleason PL #Food Lion	1.5	4.32	100.02	99.81	99.7	99.92	2/26/03	N/A	N/A
499833C	3.	3732465	1U	75679	55	1133 Balharbor Blvd	1.5	0.98	99.96	99.34	98.74	99.61	2/26/03	N/A	N/A
499833C	4.	3732465	1U	72446	42	5760 Jog Rd	3	0.15	99.59	98.71	99.19	99.28	2/26/03	5/21/03	0.36
499833C	5.	3732465	1U	52747	11	1603 Nova Dr	3	1.82	100.23	98.97	99.65	99.78	2/26/03	5/21/03	-1.97
499833C	6.	3732465	1U	51401	11	101 E Granada	3	2.16	99.92	99.81	100.25	99.94	2/26/03	5/21/03	2.69
499833C	7.	3209799	1U	53593	34	1326 S 6TH ST	METER REMOVED 6/13/02					N/A	N/A	N/A	

COMPANY						Scale	Full Scal	kWh Test	kWh Test	kWh Test	kWh Test	Test	RETEST	Full Scale	
COMPLAINT #	Premise	Sym	Num	Dst	Address	Value	% Error	SF%	SP%	SL%	WA%	Date	DATE	% Error	
Walmart (8)															
N/A	1.	799883715	1V	7014D	41	22100 STATE ROAD 7	3.5	2.03	100.14	99.91	99.39	99.97	12/10/02	N/A	N/A
N/A	2.	2932189	1V	5249D	22	1001 E EAU GALLIE BLVD	7.0	0.73	100.05	99.26	98.63	99.62	12/10/02	5/21/03	3.64
N/A	3.	2812917	1V	5441D	21	1802 US HIGHWAY 1	3.5	2.78	99.87	99.70	99.92	99.83	12/10/02	N/A	N/A
N/A	4.	329802	1V	5443D	21	3275 GARDEN ST # 146	3.5	2.78	99.46	99.65	99.06	99.46	12/10/02	N/A	N/A
N/A	5.	3436415	1V	7942D	11	1115 BEVILLE RD	3.5	0.78	99.91	99.65	97.26	99.45	12/10/02	N/A	N/A
N/A	6.	2692471	1V	5898D	12	101 US HIGHWAY 19 N	7.0	1.82	99.95	99.61	99.36	99.77	12/10/02	5/21/03	3.64
N/A	7.	2769275	1V	59210	43	3371 US HIGHWAY 441 S	7.0	1.58	99.23	98.22	98.29	98.81	12/10/02	5/21/03	3.41
N/A	8.	2762683	1V	5221D	57	1560 US HIGHWAY 41 BYP	3.5	-2.92	100.25	100.22	99.80	100.18	12/10/02	N/A	N/A

TARGET BRK DWN 46 ---  
ATTACHMENT #2

**TARGET ACCOUNTS**  
**21265 Biscayne Blvd, Aventura**

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
3834545257	06/15/98	06/24/03	32	237600	470	6V	7472D	05/08/98	65.82
3834545257	06/15/98	05/23/03	29	221760	470	6V	7472D	05/08/98	67.79
3834545257	06/15/98	04/24/03	29	192000	437	6V	7472D	05/08/98	63.13
3834545257	06/15/98	03/26/03	29	211680	468	6V	7472D	05/08/98	64.99
3834545257	06/15/98	02/25/03	32	199920	458	6V	7472D	05/08/98	56.84
3834545257	06/15/98	01/24/03	35	205680	458	6V	7472D	05/08/98	53.46
3834545257	06/15/98	12/20/02	30	203040	480	6V	7472D	05/08/98	58.75
3834545257	06/15/98	11/20/02	29	208560	497	6V	7472D	05/08/98	60.29
3834545257	06/15/98	10/22/02	29	234720	523	6V	7472D	05/08/98	64.48
3834545257	06/15/98	09/23/02	32	257520	497	6V	7472D	05/08/98	67.47
3834545257	06/15/98	08/22/02	29	228720	478	6V	7472D	05/08/98	68.75
3834545257	06/15/98	07/24/02	30	224880	497	6V	7472D	05/08/98	62.84
3834545257	06/15/98	06/24/02	32	233280	497	6V	7472D	05/08/98	61.12
3834545257	06/15/98	05/23/02	29	212400	497	6V	7472D	05/08/98	61.40
3834545257	06/15/98	04/24/02	29	204960	497	6V	7472D	05/08/98	59.25
3834545257	06/15/98	03/26/02	29	199920	490	6V	7472D	05/08/98	58.62
3834545257	06/15/98	02/25/02	31	206400	487	6V	7472D	05/08/98	56.96
3834545257	06/15/98	01/25/02	35	216480	487	6V	7472D	05/08/98	52.92
3834545257	06/15/98	12/21/01	31	222960	487	6V	7472D	05/08/98	61.54
3834545257	06/15/98	11/20/01	29	197040	540	6V	7472D	05/08/98	52.43
3834545257	06/15/98	10/22/01	31	233040	540	6V	7472D	05/08/98	58.00
3834545257	06/15/98	09/21/01	30	236400	540	6V	7472D	05/08/98	60.80
3834545257	06/15/98	08/22/01	29	238320	533	6V	7472D	05/08/98	64.24
3834545257	06/15/98	07/24/01	32	256800	506	6V	7472D	05/08/98	66.08
3834545257	06/15/98	06/22/01	30	238080	506	6V	7472D	05/08/98	65.35
3834545257	06/15/98	05/23/01	29	204960	490	6V	7472D	05/08/98	60.10
3834545257	06/15/98	04/24/01	29	194880	478	6V	7472D	05/08/98	58.58
3834545257	06/15/98	03/26/01	31	206880	478	6V	7472D	05/08/98	58.17
3834545257	06/15/98	02/23/01	29	195840	478	6V	7472D	05/08/98	58.87
3834545257	06/15/98	01/25/01	34	194880	446	6V	7472D	05/08/98	53.55
3834545257	06/15/98	12/22/00	31	211920	463	6V	7472D	05/08/98	61.52
3834545257	06/15/98	11/21/00	29	207360	466	6V	7472D	05/08/98	63.93
3834545257	06/15/98	10/23/00	31	230880	492	6V	7472D	05/08/98	63.07
3834545257	06/15/98	09/22/00	30	251280	514	6V	7472D	05/08/98	67.90
3834545257	06/15/98	08/23/00	30	249600	514	6V	7472D	05/08/98	67.44
3834545257	06/15/98	07/24/00	32	258720	516	6V	7472D	05/08/98	65.29

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
3834545257	06/15/98	06/22/00	30	246240	492	6V	7472D	05/08/98	69.51
3834545257	06/15/98	05/23/00	29	213840	466	6V	7472D	05/08/98	65.93
3834545257	06/15/98	04/24/00	31	205440	475	6V	7472D	05/08/98	58.13
3834545257	06/15/98	03/24/00	29	192240	514	6V	7472D	05/08/98	53.74
3834545257	06/15/98	02/24/00	30	183840	514	6V	7472D	05/08/98	49.68
3834545257	06/15/98	01/25/00	34	208560	514	6V	7472D	05/08/98	49.73
3834545257	06/15/98	12/22/99	30	205920	514	6V	7472D	05/08/98	55.64
3834545257	06/15/98	11/22/99	31	209040	514	6V	7472D	05/08/98	54.66
3834545257	06/15/98	10/22/99	29	216000	514	6V	7472D	05/08/98	60.38
3834545257	06/15/98	09/23/99	30	265200	526	6V	7472D	05/08/98	70.03
3834545257	06/15/98	08/24/99	32	254880	511	6V	7472D	05/08/98	64.95
3834545257	06/15/98	07/23/99	30	233040	504	6V	7472D	05/08/98	64.22
3834545257	06/15/98	06/23/99	30	220320	492	6V	7472D	05/08/98	62.20
3834545257	06/15/98	05/24/99	31	222480	511	6V	7472D	05/08/98	58.52
3834545257	06/15/98	04/23/99	30	198960	521	6V	7472D	05/08/98	53.04
3834545257	06/15/98	03/24/99	29	174000	475	6V	7472D	05/08/98	52.63
3834545257	06/15/98	02/23/99	29	181920	468	6V	7472D	05/08/98	55.85
3834545257	06/15/98	01/25/99	34	210000	530	6V	7472D	05/08/98	48.56
3834545257	06/15/98	12/22/98	32	219360	485	6V	7472D	05/08/98	58.89
3834545257	06/15/98	11/20/98	30	212640	482	6V	7472D	05/08/98	61.27
3834545257	06/15/98	10/21/98	29	227760	492	6V	7472D	05/08/98	66.51
3834545257	06/15/98	09/22/98	32	253920	502	6V	7472D	05/08/98	65.86
3834545257	06/15/98	08/21/98	29	237600	528	6V	7472D	05/08/98	64.66
3834545257	06/15/98	07/23/98	30	236400	497	6V	7472D	05/08/98	66.06
3834545257	06/15/98	06/23/98	8	45120	458	6V	7472D	05/08/98	51.31

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>1901 N Congress Ave, Boynton Beach</b>									
3924215316	06/24/91	06/13/03	30	243600	514	6V	7605D	11/06/02	65.82
3924215316	06/24/91	05/14/03	29	230400	490	6V	7605D	11/06/02	67.56
3924215316	06/24/91	04/15/03	29	210960	506	6V	7605D	11/06/02	59.90
3924215316	06/24/91	03/17/03	32	237840	535	6V	7605D	11/06/02	57.89
3924215316	06/24/91	02/13/03	30	184800	432	6V	7605D	11/06/02	59.41
3924215316	06/24/91	01/14/03	34	216960	487	6V	7605D	11/06/02	54.60
3924215316	06/24/91	12/12/02	32	231360	502	6V	7605D	11/06/02	60.01
3924215316	06/24/91	11/11/02	29	225840	528	6V	7605D	11/06/02	61.46
3924215316	06/24/91	10/11/02	30	252240	564	1V	7001D	07/01/91	62.12
3924215316	06/24/91	09/12/02	29	244800	576	1V	7001D	07/01/91	61.06
3924215316	06/24/91	08/13/02	31	268560	576	1V	7001D	07/01/91	62.67
3924215316	06/24/91	07/15/02	30	248880	576	1V	7001D	07/01/91	60.01
3924215316	06/24/91	06/13/02	30	247200	576	1V	7001D	07/01/91	59.61
3924215316	06/24/91	05/14/02	29	230400	552	1V	7001D	07/01/91	59.97
3924215316	06/24/91	04/15/02	32	230400	540	1V	7001D	07/01/91	55.56
3924215316	06/24/91	03/15/02	29	194400	516	1V	7001D	07/01/91	54.13
3924215316	06/24/91	02/14/02	30	212400	480	1V	7001D	07/01/91	61.46
3924215316	06/24/91	01/15/02	34	226320	576	1V	7001D	07/01/91	48.15
3924215316	06/24/91	12/12/01	32	236640	564	1V	7001D	07/01/91	54.63
3924215316	06/24/91	11/09/01	29	231120	528	1V	7001D	07/01/91	62.89
3924215316	06/24/91	10/11/01	29	239520	504	1V	7001D	07/01/91	68.28
3924215316	06/24/91	09/12/01	32	281520	576	1V	7001D	07/01/91	63.64
3924215316	06/24/91	08/13/01	29	238080	576	1V	7001D	07/01/91	59.39
3924215316	06/24/91	07/13/01	31	237840	552	1V	7001D	07/01/91	57.91
3924215316	06/24/91	06/13/01	31	230640	576	1V	7001D	07/01/91	53.82
3924215316	06/24/91	05/14/01	30	197040	528	1V	7001D	07/01/91	51.83
3924215316	06/24/91	04/13/01	29	192480	504	1V	7001D	07/01/91	54.87
3924215316	06/24/91	03/15/01	29	185040	504	1V	7001D	07/01/91	52.75
3924215316	06/24/91	02/14/01	28	175920	480	1V	7001D	07/01/91	54.54
3924215316	06/24/91	01/16/01	35	203040	480	1V	7001D	07/01/91	50.36
3924215316	06/24/91	12/13/00	32	210480	480	1V	7001D	07/01/91	57.10
3924215316	06/24/91	11/10/00	29	194160	504	1V	7001D	07/01/91	55.35
3924215316	06/24/91	10/12/00	29	222960	504	1V	7001D	07/01/91	63.56
3924215316	06/24/91	09/13/00	30	238080	528	1V	7001D	07/01/91	62.63
3924215316	06/24/91	08/14/00	32	253200	540	1V	7001D	07/01/91	61.05
3924215316	06/24/91	07/13/00	30	264960	540	1V	7001D	07/01/91	68.15
3924215316	06/24/91	06/13/00	32	240000	516	1V	7001D	07/01/91	60.56

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
3924215316	06/24/91	05/12/00	29	200400	480	1V	7001D	07/01/91	59.99
3924215316	06/24/91	04/13/00	30	199440	480	1V	7001D	07/01/91	57.71
3924215316	06/24/91	03/15/00	29	185040	456	1V	7001D	07/01/91	58.30
3924215316	06/24/91	02/14/00	32	180960	480	1V	7001D	07/01/91	49.09
3924215316	06/24/91	01/13/00	31	195120	456	1V	7001D	07/01/91	57.51
3924215316	06/24/91	12/13/99	33	218880	492	1V	7001D	07/01/91	56.17
3924215316	06/24/91	11/11/99	29	202560	480	1V	7001D	07/01/91	60.63
3924215316	06/24/91	10/13/99	28	217440	540	1V	7001D	07/01/91	59.92
3924215316	06/24/91	09/14/99	32	253920	547	1V	7001D	07/01/91	60.44
3924215316	06/24/91	08/13/99	30	240000	564	1V	7001D	07/01/91	59.10
3924215316	06/24/91	07/14/99	30	223680	552	1V	7001D	07/01/91	56.28
3924215316	06/24/91	06/14/99	32	246480	528	1V	7001D	07/01/91	60.78
3924215316	06/24/91	05/13/99	29	206880	528	1V	7001D	07/01/91	56.30
3924215316	06/24/91	04/14/99	30	196560	516	1V	7001D	07/01/91	52.91
3924215316	06/24/91	03/15/99	31	180960	480	1V	7001D	07/01/91	50.67
3924215316	06/24/91	02/12/99	29	186960	480	1V	7001D	07/01/91	55.96
3924215316	06/24/91	01/14/99	31	187680	516	1V	7001D	07/01/91	48.89
3924215316	06/24/91	12/14/98	32	222240	504	1V	7001D	07/01/91	57.42
3924215316	06/24/91	11/12/98	30	209280	504	1V	7001D	07/01/91	57.67
3924215316	06/24/91	10/13/98	31	240480	540	1V	7001D	07/01/91	59.86
3924215316	06/24/91	09/14/98	30	241680	540	1V	7001D	07/01/91	62.16
3924215316	06/24/91	08/13/98	29	229440	528	1V	7001D	07/01/91	62.43
3924215316	06/24/91	07/15/98	30	228000	528	1V	7001D	07/01/91	59.97
3924215316	06/24/91	06/15/98	32	239520	504	1V	7001D	07/01/91	61.88
3924215316	06/24/91	05/14/98	29	197520	480	1V	7001D	07/01/91	59.12
3924215316	06/24/91	04/15/98	29	178080	468	1V	7001D	07/01/91	54.67
3924215316	06/24/91	03/17/98	29	174480	468	1V	7001D	07/01/91	53.57
3924215316	06/24/91	02/16/98	33	198240	480	1V	7001D	07/01/91	52.15
3924215316	06/24/91	01/14/98	33	226320	516	1V	7001D	07/01/91	55.38
3924215316	06/24/91	12/12/97	30	216480	516	1V	7001D	07/01/91	58.27
3924215316	06/24/91	11/12/97	30	223440	480	1V	7001D	07/01/91	64.65
3924215316	06/24/91	10/13/97	30	223440	516	1V	7001D	07/01/91	60.14
3924215316	06/24/91	09/11/97	30	232800	528	1V	7001D	07/01/91	61.24
3924215316	06/24/91	08/12/97	30	220560	516	1V	7001D	07/01/91	59.37
3924215316	06/24/91	07/14/97	30	233280	540	1V	7001D	07/01/91	60.00
3924215316	06/24/91	06/12/97	30	212400	492	1V	7001D	07/01/91	59.96
3924215316	06/24/91	05/13/97	30	191040	492	1V	7001D	07/01/91	53.93
3924215316	06/24/91	04/14/97	30	193680	480	1V	7001D	07/01/91	56.04

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
3924215316	06/24/91	03/14/97	30	197280	480	1V	7001D	07/01/91	57.08
3924215316	06/24/91	02/12/97	30	168240	456	1V	7001D	07/01/91	51.24
3924215316	06/24/91	01/13/97	30	198960	456	1V	7001D	07/01/91	60.60
3924215316	06/24/91	12/11/96	30	216720	480	1V	7001D	07/01/91	62.71
3924215316	06/24/91	11/08/96	30	196080	504	1V	7001D	07/01/91	54.03
3924215316	06/24/91	10/10/96	30	203520	492	1V	7001D	07/01/91	57.45
3924215316	06/24/91	09/11/96	30	226560	497	1V	7001D	07/01/91	63.31
3924215316	06/24/91	08/12/96	30	234720	504	1V	7001D	07/01/91	64.68
3924215316	06/24/91	07/12/96	30	221760	528	1V	7001D	07/01/91	58.33
3924215316	06/24/91	06/12/96	30	227760	504	1V	7001D	07/01/91	62.76
3924215316	06/24/91	05/13/96	30	224640	552	1V	7001D	07/01/91	56.52
3924215316	06/24/91	04/12/96	30	182880	492	1V	7001D	07/01/91	51.63
3924215316	06/24/91	03/14/96	30	176400	480	1V	7001D	07/01/91	51.04
3924215316	06/24/91	02/14/96	30	169440	480	1V	7001D	07/01/91	49.03
3924215316	06/24/91	01/16/96	30	198960	480	1V	7001D	07/01/91	57.57
3924215316	06/24/91	12/13/95	30	221280	480	1V	7001D	07/01/91	64.03
3924215316	06/24/91	11/13/95	30	217200	480	1V	7001D	07/01/91	62.85
3924215316	06/24/91	10/12/95	30	222240	480	1V	7001D	07/01/91	64.31
3924215316	06/24/91	09/13/95	30	222720	504	1V	7001D	07/01/91	61.38
3924215316	06/24/91	08/14/95	30	232560	504	1V	7001D	07/01/91	64.09
3924215316	06/24/91	07/14/95	30	222240	492	1V	7001D	07/01/91	62.74
3924215316	06/24/91	06/14/95	30	217200	492	1V	7001D	07/01/91	61.31
3924215316	06/24/91	05/15/95	30	213840	480	1V	7001D	07/01/91	61.88
3924215316	06/24/91	04/14/95	30	188160	480	1V	7001D	07/01/91	54.44
3924215316	06/24/91	03/16/95	30	174480	408	1V	7001D	07/01/91	59.40
3924215316	06/24/91	02/15/95	30	153600	420	1V	7001D	07/01/91	50.79
3924215316	06/24/91	01/17/95	30	195840	432	1V	7001D	07/01/91	62.96
3924215316	06/24/91	12/15/94	30	210000	480	1V	7001D	07/01/91	60.76
3924215316	06/24/91	11/15/94	30	235920	492	1V	7001D	07/01/91	66.60
3924215316	06/24/91	10/13/94	30	210240	516	1V	7001D	07/01/91	56.59
3924215316	06/24/91	09/14/94	30	222000	528	1V	7001D	07/01/91	58.40
3924215316	06/24/91	08/15/94	30	222720	528	1V	7001D	07/01/91	58.59
3924215316	06/24/91	07/15/94	30	248880	528	1V	7001D	07/01/91	65.47
3924215316	06/24/91	06/15/94	30	204960	504	1V	7001D	07/01/91	56.48
3924215316	06/24/91	05/16/94	30	200880	480	1V	7001D	07/01/91	58.13
3924215316	06/24/91	04/15/94	30	181440	480	1V	7001D	07/01/91	52.50
3924215316	06/24/91	03/17/94	30	170400	480	1V	7001D	07/01/91	49.31
3924215316	06/24/91	02/15/94	30	177840	480	1V	7001D	07/01/91	51.46

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
3924215316	06/24/91	01/14/94	30	161520	456	1V	7001D	07/01/91	49.20
3924215316	06/24/91	12/15/93	30	195360	456	1V	7001D	07/01/91	59.50
3924215316	06/24/91	11/15/93	30	252480	504	1V	7001D	07/01/91	69.58
3924215316	06/24/91	10/14/93	30	238560	552	1V	7001D	07/01/91	60.02
3924215316	06/24/91	09/15/93	30	238080	528	1V	7001D	07/01/91	62.63
3924215316	06/24/91	08/16/93	30	235920	528	1V	7001D	07/01/91	62.06
3924215316	06/24/91	07/15/93	30	222240	552	1V	7001D	07/01/91	55.92
3924215316	06/24/91	06/15/93	30	204000	480	1V	7001D	07/01/91	59.03
3924215316	06/24/91	05/14/93	30	165360	456	1V	7001D	07/01/91	50.37
3924215316	06/24/91	04/15/93	30	169200	480	1V	7001D	07/01/91	48.96
3924215316	06/24/91	03/16/93	30	162720	432	1V	7001D	07/01/91	52.31

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>6250 W Sample Rd, Coral Springs</b>									
4109452211	06/21/91	06/20/03	29	210120	454	6V	5606D	03/27/96	66.50
4109452211	06/21/91	05/21/03	29	209040	468	6V	5606D	03/27/96	64.18
4109452211	06/21/91	04/22/03	31	198720	462	6V	5606D	03/27/96	57.81
4109452211	06/21/91	03/24/03	29	197280	484	6V	5606D	03/27/96	58.56
4109452211	06/21/91	02/21/03	31	175080	382	6V	5606D	03/27/96	61.60
4109452211	06/21/91	01/22/03	35	189000	479	6V	5606D	03/27/96	46.97
4109452211	06/21/91	12/18/02	29	180240	492	6V	5606D	03/27/96	52.64
4109452211	06/21/91	11/18/02	32	218160	470	6V	5606D	03/27/96	60.44
4109452211	06/21/91	10/18/02	28	214200	532	6V	5606D	03/27/96	59.92
4109452211	06/21/91	09/19/02	31	237840	510	6V	5606D	03/27/96	62.68
4109452211	06/21/91	08/20/02	28	214200	520	6V	5606D	03/27/96	61.30
4109452211	06/21/91	07/22/02	32	226800	482	6V	5606D	03/27/96	61.27
4109452211	06/21/91	06/20/02	30	210720	478	6V	5606D	03/27/96	61.23
4109452211	06/21/91	05/21/02	29	216240	470	6V	5606D	03/27/96	66.10
4109452211	06/21/91	04/22/02	31	230040	466	6V	5606D	03/27/96	66.35
4109452211	06/21/91	03/22/02	29	207240	442	6V	5606D	03/27/96	67.37
4109452211	06/21/91	02/21/02	29	202920	410	6V	5606D	03/27/96	71.11
4109452211	06/21/91	01/23/02	35	229560	414	6V	5606D	03/27/96	66.01
4109452211	06/21/91	12/19/01	34	232800	451	6V	5606D	03/27/96	63.26
4109452211	06/21/91	11/16/01	28	184200	482	6V	5606D	03/27/96	56.87
4109452211	06/21/91	10/18/01	29	206520	509	6V	5606D	03/27/96	58.30
4109452211	06/21/91	09/19/01	30	240840	532	6V	5606D	03/27/96	62.88
4109452211	06/21/91	08/20/01	31	245640	536	6V	5606D	03/27/96	61.60
4109452211	06/21/91	07/20/01	30	226560	485	6V	5606D	03/27/96	64.88
4109452211	06/21/91	06/20/01	32	233280	470	6V	5606D	03/27/96	64.63
4109452211	06/21/91	05/21/01	29	213960	436	6V	5606D	03/27/96	70.51
4109452211	06/21/91	04/20/01	29	190680	462	6V	5606D	03/27/96	59.30
4109452211	06/21/91	03/22/01	29	182880	436	6V	5606D	03/27/96	60.27
4109452211	06/21/91	02/21/01	29	179760	401	6V	5606D	03/27/96	64.41
4109452211	06/21/91	01/23/01	34	215160	438	6V	5606D	03/27/96	60.20
4109452211	06/21/91	12/20/00	33	244920	450	6V	5606D	03/27/96	68.72
4109452211	06/21/91	11/17/00	29	217680	408	6V	5606D	03/27/96	76.66
4109452211	06/21/91	10/19/00	29	236160	466	6V	5606D	03/27/96	72.81
4109452211	06/21/91	09/20/00	30	262200	466	6V	5606D	03/27/96	78.15
4109452211	06/21/91	08/21/00	33	292080	469	6V	5606D	03/27/96	78.63
4109452211	06/21/91	07/20/00	29	231480	480	6V	5606D	03/27/96	69.29
4109452211	06/21/91	06/20/00	32	233880	466	6V	5606D	03/27/96	65.35



Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
4109452211	06/21/91	05/19/00	29	193200	448	6V	5606D	03/27/96	61.96
4109452211	06/21/91	04/20/00	29	186360	426	6V	5606D	03/27/96	62.85
4109452211	06/21/91	03/22/00	29	177120	420	6V	5606D	03/27/96	60.59
4109452211	06/21/91	02/22/00	32	174120	398	6V	5606D	03/27/96	56.96
4109452211	06/21/91	01/21/00	31	175800	398	6V	5606D	03/27/96	59.37
4109452211	06/21/91	12/20/99	33	210480	420	6V	5606D	03/27/96	63.28
4109452211	06/21/91	11/18/99	29	185400	466	6V	5606D	03/27/96	57.16
4109452211	06/21/91	10/20/99	29	208560	466	6V	5606D	03/27/96	64.30
4109452211	06/21/91	09/21/99	32	236280	502	6V	5606D	03/27/96	61.29
4109452211	06/21/91	08/20/99	30	268560	502	6V	5606D	03/27/96	74.30
4109452211	06/21/91	07/21/99	30	243000	455	6V	5606D	03/27/96	74.18
4109452211	06/21/91	06/21/99	32	227880	467	6V	5606D	03/27/96	63.54
4109452211	06/21/91	05/20/99	29	227400	456	6V	5606D	03/27/96	71.65
4109452211	06/21/91	04/21/99	30	172680	421	6V	5606D	03/27/96	56.97
4109452211	06/21/91	03/22/99	31	177600	422	6V	5606D	03/27/96	56.57
4109452211	06/21/91	02/19/99	9	50760	422	6V	5606D	03/27/96	55.69
4109452211	06/21/91	02/10/99	30	187320	424	6V	5606D	03/27/96	61.36
4109452211	06/21/91	01/11/99	33	198360	402	6V	5606D	03/27/96	62.30
4109452211	06/21/91	12/09/98	33	218640	424	6V	5606D	03/27/96	65.11
4109452211	06/21/91	11/06/98	29	198240	472	6V	5606D	03/27/96	60.34
4109452211	06/21/91	10/08/98	29	211560	472	6V	5606D	03/27/96	64.40
4109452211	06/21/91	09/09/98	30	238440	466	6V	5606D	03/27/96	71.07
4109452211	06/21/91	08/10/98	31	236400	456	6V	5606D	03/27/96	69.68
4109452211	06/21/91	07/10/98	30	224520	468	6V	5606D	03/27/96	66.63
4109452211	06/21/91	06/10/98	30	213480	464	6V	5606D	03/27/96	63.90
4109452211	06/21/91	05/11/98	31	179640	439	6V	5606D	03/27/96	55.00
4109452211	06/21/91	04/10/98	29	166560	403	6V	5606D	03/27/96	59.38
4109452211	06/21/91	03/12/98	30	185280	400	6V	5606D	03/27/96	64.33
4109452211	06/21/91	02/10/98	31	168960	348	6V	5606D	03/27/96	65.26
4109452211	06/21/91	01/10/98	30	187200	397	6V	5606D	03/27/96	65.49
4109452211	06/21/91	12/09/97	30	201000	414	6V	5606D	03/27/96	67.43
4109452211	06/21/91	11/06/97	30	189000	436	6V	5606D	03/27/96	60.21
4109452211	06/21/91	10/08/97	30	198960	443	6V	5606D	03/27/96	62.38
4109452211	06/21/91	09/08/97	30	226440	451	6V	5606D	03/27/96	69.73
4109452211	06/21/91	08/07/97	30	225600	470	6V	5606D	03/27/96	66.67
4109452211	06/21/91	07/09/97	30	207960	451	6V	5606D	03/27/96	64.04
4109452211	06/21/91	06/09/97	30	222840	444	6V	5606D	03/27/96	69.71
4109452211	06/21/91	05/08/97	30	174360	436	6V	5606D	03/27/96	55.54

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
4109452211	06/21/91	04/09/97	30	176040	406	6V	5606D	03/27/96	60.22
4109452211	06/21/91	03/11/97	30	200520	409	6V	5606D	03/27/96	68.09
4109452211	06/21/91	02/07/97	30	167640	398	6V	5606D	03/27/96	58.50
4109452211	06/21/91	01/08/97	30	182400	413	6V	5606D	03/27/96	61.34
4109452211	06/21/91	12/06/96	30	195960	424	6V	5606D	03/27/96	64.19
4109452211	06/21/91	11/05/96	30	196080	458	6V	5606D	03/27/96	59.46
4109452211	06/21/91	10/07/96	30	230880	461	6V	5606D	03/27/96	69.56
4109452211	06/21/91	09/06/96	30	234720	498	6V	5606D	03/27/96	65.46
4109452211	06/21/91	08/07/96	30	233280	499	6V	5606D	03/27/96	64.93
4109452211	06/21/91	07/09/96	30	260160	515	6V	5606D	03/27/96	70.16
4109452211	06/21/91	06/07/96	30	235920	472	6V	5606D	03/27/96	69.42
4109452211	06/21/91	05/08/96	30	195240	460	6V	5606D	03/27/96	58.95
4109452211	06/21/91	04/09/96	30	177505	444	6V	5606D	03/27/96	55.53
4109452211	06/21/91	03/11/96	30	175680	420	1V	5992D	05/01/91	58.10
4109452211	06/21/91	02/09/96	30	169320	384	1V	5992D	05/01/91	61.24
4109452211	06/21/91	01/10/96	30	207900	444	1V	5992D	05/01/91	65.03
4109452211	06/21/91	12/08/95	30	191400	432	1V	5992D	05/01/91	61.54
4109452211	06/21/91	11/07/95	30	195720	456	1V	5992D	05/01/91	59.61
4109452211	06/21/91	10/09/95	30	226200	540	1V	5992D	05/01/91	58.18
4109452211	06/21/91	09/08/95	30	229080	528	1V	5992D	05/01/91	60.26
4109452211	06/21/91	08/09/95	30	238920	528	1V	5992D	05/01/91	62.85
4109452211	06/21/91	07/11/95	30	238560	504	1V	5992D	05/01/91	65.74
4109452211	06/21/91	06/09/95	30	210240	468	1V	5992D	05/01/91	62.39
4109452211	06/21/91	05/10/95	30	188280	456	1V	5992D	05/01/91	57.35
4109452211	06/21/91	04/11/95	30	174480	444	1V	5992D	05/01/91	54.58
4109452211	06/21/91	03/13/95	30	175680	420	1V	5992D	05/01/91	58.10
4109452211	06/21/91	02/10/95	30	169320	384	1V	5992D	05/01/91	61.24
4109452211	06/21/91	01/11/95	30	189000	396	1V	5992D	05/01/91	66.29
4109452211	06/21/91	12/12/94	30	230400	420	1V	5992D	05/01/91	76.19
4109452211	06/21/91	11/09/94	30	198360	444	1V	5992D	05/01/91	62.05
4109452211	06/21/91	10/10/94	30	219240	480	1V	5992D	05/01/91	63.44
4109452211	06/21/91	09/09/94	30	227160	480	1V	5992D	05/01/91	65.73
4109452211	06/21/91	08/10/94	30	199680	480	1V	5992D	05/01/91	57.78
4109452211	06/21/91	07/12/94	30	227160	480	1V	5992D	05/01/91	65.73
4109452211	06/21/91	06/10/94	30	201480	468	1V	5992D	05/01/91	59.79
4109452211	06/21/91	05/11/94	30	184800	516	1V	5992D	05/01/91	49.74
4109452211	06/21/91	04/12/94	30	171840	480	1V	5992D	05/01/91	49.72
4109452211	06/21/91	03/14/94	30	173160	420	1V	5992D	05/01/91	57.26

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
4109452211	06/21/91	02/10/94	30	157080	420	1V	5992D	05/01/91	51.94
4109452211	06/21/91	01/11/94	30	171480	420	1V	5992D	05/01/91	56.71
4109452211	06/21/91	12/10/93	30	197280	420	1V	5992D	05/01/91	65.24
4109452211	06/21/91	11/09/93	30	181080	480	1V	5992D	05/01/91	52.40
4109452211	06/21/91	10/11/93	30	206040	480	1V	5992D	05/01/91	59.62
4109452211	06/21/91	09/10/93	30	200040	480	1V	5992D	05/01/91	57.88
4109452211	06/21/91	08/11/93	30	202080	480	1V	5992D	05/01/91	58.47
4109452211	06/21/91	07/12/93	30	208920	480	1V	5992D	05/01/91	60.45
4109452211	06/21/91	06/10/93	30	182040	480	1V	5992D	05/01/91	52.67
4109452211	06/21/91	05/11/93	30	155520	480	1V	5992D	05/01/91	45.00
4109452211	06/21/91	04/12/93	30	160680	420	1V	5992D	05/01/91	53.13
4109452211	06/21/91	03/11/93	30	141600	408	1V	5992D	05/01/91	48.20

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>13711 S Tamiami Trl #300, Fort Myers</b>									
4229819083	04/21/93	06/24/03	32	271920	557	6V	7732D	11/12/02	63.57
4229819083	04/21/93	05/23/03	29	232560	528	6V	7732D	11/12/02	63.28
4229819083	04/21/93	04/24/03	29	205680	518	6V	7732D	11/12/02	57.05
4229819083	04/21/93	03/26/03	29	221040	521	6V	7732D	11/12/02	60.96
4229819083	04/21/93	02/25/03	32	194880	509	6V	7732D	11/12/02	49.85
4229819083	04/21/93	01/24/03	35	129600	367	6V	7732D	11/12/02	42.04
4229819083	04/21/93	12/20/02	30	122880	295	6V	7732D	11/12/02	57.85
4229819083	04/21/93	11/20/02	30	145200	384	6V	7732D	11/12/02	52.52
4229819083	04/21/93	10/22/02	28	151920	384	1V	7019D	05/27/93	58.87
4229819083	04/21/93	09/23/02	32	203520	600	1V	7019D	05/27/93	44.17
4229819083	04/21/93	08/22/02	30	268320	600	1V	7019D	05/27/93	62.11
4229819083	04/21/93	07/24/02	29	253200	576	1V	7019D	05/27/93	63.16
4229819083	04/21/93	06/24/02	32	279120	588	1V	7019D	05/27/93	61.81
4229819083	04/21/93	05/23/02	29	240000	576	1V	7019D	05/27/93	59.87
4229819083	04/21/93	04/24/02	29	216000	552	1V	7019D	05/27/93	56.22
4229819083	04/21/93	03/26/02	29	201360	540	1V	7019D	05/27/93	53.58
4229819083	04/21/93	02/25/02	31	201840	540	1V	7019D	05/27/93	50.24
4229819083	04/21/93	01/25/02	35	205920	552	1V	7019D	05/27/93	44.41
4229819083	04/21/93	12/21/01	31	224160	588	1V	7019D	05/27/93	51.24
4229819083	04/21/93	11/20/01	29	199440	600	1V	7019D	05/27/93	47.76
4229819083	04/21/93	10/22/01	31	242880	588	1V	7019D	05/27/93	55.52
4229819083	04/21/93	09/21/01	30	247680	600	1V	7019D	05/27/93	57.33
4229819083	04/21/93	08/22/01	29	250320	600	1V	7019D	05/27/93	59.94
4229819083	04/21/93	07/24/01	32	265200	588	1V	7019D	05/27/93	58.73
4229819083	04/21/93	06/22/01	30	251040	576	1V	7019D	05/27/93	60.53
4229819083	04/21/93	05/23/01	29	212880	540	1V	7019D	05/27/93	56.64
4229819083	04/21/93	04/24/01	29	199920	528	1V	7019D	05/27/93	54.40
4229819083	04/21/93	03/26/01	31	207840	516	1V	7019D	05/27/93	54.14
4229819083	04/21/93	02/23/01	29	182400	492	1V	7019D	05/27/93	53.27
4229819083	04/21/93	01/25/01	34	177840	504	1V	7019D	05/27/93	43.24
4229819083	04/21/93	12/22/00	32	201360	540	1V	7019D	05/27/93	48.55
4229819083	04/21/93	11/21/00	28	189840	576	1V	7019D	05/27/93	49.05
4229819083	04/21/93	10/23/00	31	237840	588	1V	7019D	05/27/93	54.37
4229819083	04/21/93	09/22/00	30	247200	588	1V	7019D	05/27/93	58.39
4229819083	04/21/93	08/23/00	30	258480	576	1V	7019D	05/27/93	62.33
4229819083	04/21/93	07/24/00	32	270240	576	1V	7019D	05/27/93	61.09
4229819083	04/21/93	06/22/00	30	253680	600	1V	7019D	05/27/93	58.72

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
4229819083	04/21/93	05/23/00	29	218880	576	1V	7019D	05/27/93	54.60
4229819083	04/21/93	04/24/00	31	216000	540	1V	7019D	05/27/93	53.76
4229819083	04/21/93	03/24/00	29	189120	504	1V	7019D	05/27/93	53.91
4229819083	04/21/93	02/24/00	30	174240	504	1V	7019D	05/27/93	48.02
4229819083	04/21/93	01/25/00	34	200400	516	1V	7019D	05/27/93	47.59
4229819083	04/21/93	12/22/99	30	198480	600	1V	7019D	05/27/93	45.94
4229819083	04/21/93	11/22/99	31	210480	528	1V	7019D	05/27/93	53.58
4229819083	04/21/93	10/22/99	29	231600	588	1V	7019D	05/27/93	56.59
4229819083	04/21/93	09/23/99	30	250080	600	1V	7019D	05/27/93	57.89
4229819083	04/21/93	08/24/99	32	274560	600	1V	7019D	05/27/93	59.58
4229819083	04/21/93	07/23/99	30	253440	600	1V	7019D	05/27/93	58.67
4229819083	04/21/93	06/23/99	30	237360	588	1V	7019D	05/27/93	56.07
4229819083	04/21/93	05/24/99	31	232080	552	1V	7019D	05/27/93	56.51
4229819083	04/21/93	04/23/99	30	202560	552	1V	7019D	05/27/93	50.97
4229819083	04/21/93	03/24/99	30	174240	456	1V	7019D	05/27/93	53.07
4229819083	04/21/93	02/23/99	28	172800	504	1V	7019D	05/27/93	51.02
4229819083	04/21/93	01/25/99	34	213120	552	1V	7019D	05/27/93	47.31
4229819083	04/21/93	12/22/98	32	216240	552	1V	7019D	05/27/93	51.01
4229819083	04/21/93	11/20/98	30	204000	576	1V	7019D	05/27/93	49.19
4229819083	04/21/93	10/21/98	29	228960	576	1V	7019D	05/27/93	57.11
4229819083	04/21/93	09/22/98	32	265680	600	1V	7019D	05/27/93	57.66
4229819083	04/21/93	08/21/98	29	245280	600	1V	7019D	05/27/93	58.74
4229819083	04/21/93	07/23/98	30	251760	624	1V	7019D	05/27/93	56.04
4229819083	04/21/93	06/23/98	32	266400	600	1V	7019D	05/27/93	57.81
4229819083	04/21/93	05/22/98	29	207120	588	1V	7019D	05/27/93	50.61
4229819083	04/21/93	04/23/98	30	198960	576	1V	7019D	05/27/93	47.97
4229819083	04/21/93	03/25/98	28	162720	576	1V	7019D	05/27/93	42.04
4229819083	04/21/93	02/24/98	32	180000	552	1V	7019D	05/27/93	42.46
4229819083	04/21/93	01/23/98	32	191040	552	1V	7019D	05/27/93	45.06
4229819083	04/21/93	12/22/97	30	195600	576	1V	7019D	05/27/93	47.16
4229819083	04/21/93	11/20/97	30	194640	564	1V	7019D	05/27/93	47.93
4229819083	04/21/93	10/21/97	30	237360	588	1V	7019D	05/27/93	56.07
4229819083	04/21/93	09/19/97	30	240480	600	1V	7019D	05/27/93	55.67
4229819083	04/21/93	08/20/97	30	239760	600	1V	7019D	05/27/93	55.50
4229819083	04/21/93	07/22/97	30	256560	600	1V	7019D	05/27/93	59.39
4229819083	04/21/93	06/20/97	30	232080	600	1V	7019D	05/27/93	53.72
4229819083	04/21/93	05/21/97	8	61440	600	1V	7019D	05/27/93	53.33
4229819083	04/21/93	05/13/97	30	194640	600	1V	7019D	05/27/93	45.06

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
4229819083	04/21/93	04/14/97	30	200160	564	1V	7019D	05/27/93	49.29
4229819083	04/21/93	03/14/97	30	200640	552	1V	7019D	05/27/93	50.48
4229819083	04/21/93	02/12/97	30	166560	540	1V	7019D	05/27/93	42.84
4229819083	04/21/93	01/13/97	30	191040	528	1V	7019D	05/27/93	50.25
4229819083	04/21/93	12/11/96	30	203040	528	1V	7019D	05/27/93	53.41
4229819083	04/21/93	11/08/96	30	215280	576	1V	7019D	05/27/93	51.91
4229819083	04/21/93	10/10/96	30	239760	600	1V	7019D	05/27/93	55.50
4229819083	04/21/93	09/11/96	30	261120	576	1V	7019D	05/27/93	62.96
4229819083	04/21/93	08/12/96	30	276480	588	1V	7019D	05/27/93	65.31
4229819083	04/21/93	07/12/96	30	267840	600	1V	7019D	05/27/93	62.00
4229819083	04/21/93	06/12/96	30	243840	600	1V	7019D	05/27/93	56.44
4229819083	04/21/93	05/13/96	30	222240	552	1V	7019D	05/27/93	55.92
4229819083	04/21/93	04/12/96	30	181440	528	1V	7019D	05/27/93	47.73
4229819083	04/21/93	03/14/96	30	175920	576	1V	7019D	05/27/93	42.42
4229819083	04/21/93	02/14/96	30	173280	564	1V	7019D	05/27/93	42.67
4229819083	04/21/93	01/16/96	30	198720	552	1V	7019D	05/27/93	50.00
4229819083	04/21/93	12/13/95	30	195360	600	1V	7019D	05/27/93	45.22
4229819083	04/21/93	11/13/95	30	274800	672	1V	7019D	05/27/93	56.80
4229819083	04/21/93	10/12/95	30	283920	648	1V	7019D	05/27/93	60.85
4229819083	04/21/93	09/13/95	30	305760	672	1V	7019D	05/27/93	63.19
4229819083	04/21/93	08/14/95	30	307920	672	1V	7019D	05/27/93	63.64
4229819083	04/21/93	07/14/95	30	258480	600	1V	7019D	05/27/93	59.83
4229819083	04/21/93	06/14/95	30	268800	672	1V	7019D	05/27/93	55.56
4229819083	04/21/93	05/15/95	30	269520	660	1V	7019D	05/27/93	56.72
4229819083	04/21/93	04/14/95	30	216000	552	1V	7019D	05/27/93	54.35
4229819083	04/21/93	03/16/95	30	190560	516	1V	7019D	05/27/93	51.29
4229819083	04/21/93	02/15/95	30	162720	528	1V	7019D	05/27/93	42.80
4229819083	04/21/93	01/17/95	30	207600	504	1V	7019D	05/27/93	57.21
4229819083	04/21/93	12/15/94	30	220800	528	1V	7019D	05/27/93	58.08
4229819083	04/21/93	11/15/94	30	250080	552	1V	7019D	05/27/93	62.92
4229819083	04/21/93	10/13/94	30	236880	576	1V	7019D	05/27/93	57.12
4229819083	04/21/93	09/14/94	30	252960	576	1V	7019D	05/27/93	61.00
4229819083	04/21/93	08/15/94	30	259680	576	1V	7019D	05/27/93	62.62
4229819083	04/21/93	07/15/94	30	248640	564	1V	7019D	05/27/93	61.23
4229819083	04/21/93	06/15/94	30	239280	576	1V	7019D	05/27/93	57.70
4229819083	04/21/93	05/16/94	30	237840	552	1V	7019D	05/27/93	59.84
4229819083	04/21/93	04/15/94	30	202080	528	1V	7019D	05/27/93	53.16
4229819083	04/21/93	03/17/94	30	192960	504	1V	7019D	05/27/93	53.17

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
4229819083	04/21/93	02/15/94	30	198480	504	1V	7019D	05/27/93	54.70
4229819083	04/21/93	01/14/94	30	181920	504	1V	7019D	05/27/93	50.13
4229819083	04/21/93	12/15/93	30	206880	528	1V	7019D	05/27/93	54.42
4229819083	04/21/93	11/15/93	30	236880	552	1V	7019D	05/27/93	59.60
4229819083	04/21/93	10/14/93	30	227760	576	1V	7019D	05/27/93	54.92
4229819083	04/21/93	09/15/93	30	195840	504	1V	7019D	05/27/93	53.97
4229819083	04/21/93	08/16/93	30	169440	504	1V	7019D	05/27/93	46.69
4229819083	04/21/93	07/15/93	30	109920	372	1V	7019D	05/27/93	41.04
4229819083	04/21/93	06/15/93	30	95280	360	1V	7019D	05/27/93	36.76
4229819083	04/21/93	05/14/93	23	71040	288	1V	7019D	05/27/93	44.69

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>26831 S Tamiami TRL, Bonita Springs</b>									
4497700023	10/14/97	06/16/03	32	171840	350	6V	5288D	11/12/02	63.93
4497700023	10/14/97	05/15/03	29	153720	338	6V	5288D	11/12/02	65.34
4497700023	10/14/97	04/16/03	29	149640	343	6V	5288D	11/12/02	62.68
4497700023	10/14/97	03/18/03	29	149280	326	6V	5288D	11/12/02	65.79
4497700023	10/14/97	02/17/03	33	145440	306	6V	5288D	11/12/02	60.01
4497700023	10/14/97	01/15/03	33	144000	313	6V	5288D	11/12/02	58.09
4497700023	10/14/97	12/13/02	30	141240	314	6V	5288D	11/12/02	62.47
4497700023	10/14/97	11/13/02	29	148560	336	6V	5288D	11/12/02	63.53
4497700023	10/14/97	10/15/02	29	157800	348	1V	5774D	10/14/97	65.15
4497700023	10/14/97	09/16/02	32	171960	348	1V	5774D	10/14/97	64.34
4497700023	10/14/97	08/15/02	29	158880	348	1V	5774D	10/14/97	65.60
4497700023	10/14/97	07/17/02	30	158760	348	1V	5774D	10/14/97	63.36
4497700023	10/14/97	06/17/02	32	164520	360	1V	5774D	10/14/97	59.51
4497700023	10/14/97	05/16/02	29	149040	336	1V	5774D	10/14/97	63.73
4497700023	10/14/97	04/17/02	29	135960	336	1V	5774D	10/14/97	58.14
4497700023	10/14/97	03/19/02	29	125760	302	1V	5774D	10/14/97	59.83
4497700023	10/14/97	02/18/02	32	141720	305	1V	5774D	10/14/97	60.50
4497700023	10/14/97	01/17/02	34	141360	302	1V	5774D	10/14/97	57.36
4497700023	10/14/97	12/14/01	31	147000	305	1V	5774D	10/14/97	64.78
4497700023	10/14/97	11/13/01	29	136920	324	1V	5774D	10/14/97	60.72
4497700023	10/14/97	10/15/01	31	158520	307	1V	5774D	10/14/97	69.40
4497700023	10/14/97	09/14/01	30	158280	348	1V	5774D	10/14/97	63.17
4497700023	10/14/97	08/15/01	29	149040	305	1V	5774D	10/14/97	70.21
4497700023	10/14/97	07/17/01	32	162480	360	1V	5774D	10/14/97	58.77
4497700023	10/14/97	06/15/01	30	152400	307	1V	5774D	10/14/97	68.95
4497700023	10/14/97	05/16/01	13	60240	324	1V	5774D	10/14/97	59.59
4497700023	10/14/97	05/03/01	29	132720	324	1V	5774D	10/14/97	58.85
4497700023	10/14/97	04/04/01	29	128520	336	1V	5774D	10/14/97	54.96
4497700023	10/14/97	03/06/01	29	127560	300	1V	5774D	10/14/97	61.09
4497700023	10/14/97	02/05/01	31	121200	300	1V	5774D	10/14/97	54.30
4497700023	10/14/97	01/05/01	32	132720	324	1V	5774D	10/14/97	53.34
4497700023	10/14/97	12/04/00	33	149520	336	1V	5774D	10/14/97	56.19
4497700023	10/14/97	11/01/00	30	144360	336	1V	5774D	10/14/97	59.67
4497700023	10/14/97	10/03/00	31	164520	348	1V	5774D	10/14/97	63.54
4497700023	10/14/97	09/01/00	30	157800	348	1V	5774D	10/14/97	62.98
4497700023	10/14/97	08/02/00	30	151680	336	1V	5774D	10/14/97	62.70
4497700023	10/14/97	07/03/00	31	161880	360	1V	5774D	10/14/97	60.44



Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
4497700023	10/14/97	06/02/00	30	148920	336	1V	5774D	10/14/97	61.56
4497700023	10/14/97	05/03/00	29	129840	336	1V	5774D	10/14/97	55.52
4497700023	10/14/97	04/04/00	29	136560	324	1V	5774D	10/14/97	60.56
4497700023	10/14/97	03/06/00	33	139200	312	1V	5774D	10/14/97	56.33
4497700023	10/14/97	02/03/00	28	115920	324	1V	5774D	10/14/97	53.24
4497700023	10/14/97	01/05/00	33	147600	312	1V	5774D	10/14/97	59.73
4497700023	10/14/97	12/03/99	31	138720	324	1V	5774D	10/14/97	57.55
4497700023	10/14/97	11/02/99	29	144240	360	1V	5774D	10/14/97	57.57
4497700023	10/14/97	10/04/99	32	180720	372	1V	5774D	10/14/97	63.26
4497700023	10/14/97	09/02/99	30	178320	360	1V	5774D	10/14/97	68.80
4497700023	10/14/97	08/03/99	32	201120	348	1V	5774D	10/14/97	75.25
4497700023	10/14/97	07/02/99	29	176280	360	1V	5774D	10/14/97	70.35
4497700023	10/14/97	06/03/99	30	157080	336	1V	5774D	10/14/97	64.93
4497700023	10/14/97	05/04/99	29	153240	336	1V	5774D	10/14/97	65.53
4497700023	10/14/97	04/05/99	32	164040	324	1V	5774D	10/14/97	65.92
4497700023	10/14/97	03/04/99	29	128880	312	1V	5774D	10/14/97	59.35
4497700023	10/14/97	02/03/99	29	121320	312	1V	5774D	10/14/97	55.87
4497700023	10/14/97	01/05/99	34	155280	336	1V	5774D	10/14/97	56.64
4497700023	10/14/97	12/02/98	33	185520	336	1V	5774D	10/14/97	69.72
4497700023	10/14/97	10/30/98	29	147840	348	1V	5774D	10/14/97	61.04
4497700023	10/14/97	10/01/98	30	167280	336	1V	5774D	10/14/97	69.15
4497700023	10/14/97	09/01/98	29	175200	360	1V	5774D	10/14/97	69.92
4497700023	10/14/97	08/03/98	33	210240	348	1V	5774D	10/14/97	76.28
4497700023	10/14/97	07/02/98	28	177360	360	1V	5774D	10/14/97	73.31
4497700023	10/14/97	06/03/98	30	174480	336	1V	5774D	10/14/97	72.12
4497700023	10/14/97	05/04/98	31	158880	324	1V	5774D	10/14/97	65.91
4497700023	10/14/97	04/03/98	29	132240	348	1V	5774D	10/14/97	54.60
4497700023	10/14/97	03/05/98	30	147720	324	1V	5774D	10/14/97	63.32
4497700023	10/14/97	02/03/98	29	120840	312	1V	5774D	10/14/97	55.65
4497700023	10/14/97	01/05/98	34	140040	312	1V	5774D	10/14/97	55.01
4497700023	10/14/97	12/02/97	30	157800	288	1V	5774D	10/14/97	76.10
4497700023	10/14/97	10/30/97	16	45960	192	1V	5774D	10/14/97	62.34

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>5350 Fruitville Rd, Sarasota</b>									
4990958540	02/11/97	06/03/03	32	286680	588	6V	5344D	08/10/02	63.48
4990958540	02/11/97	05/02/03	29	222240	571	6V	5344D	08/10/02	55.92
4990958540	02/11/97	04/03/03	29	227040	596	6V	5344D	08/10/02	54.73
4990958540	02/11/97	03/05/03	30	210960	557	6V	5344D	08/10/02	52.60
4990958540	02/11/97	02/03/03	32	195840	442	6V	5344D	08/10/02	57.69
4990958540	02/11/97	01/02/03	31	206880	563	6V	5344D	08/10/02	49.39
4990958540	02/11/97	12/02/02	33	235560	570	6V	5344D	08/10/02	52.18
4990958540	02/11/97	10/30/02	29	247800	566	6V	5344D	08/10/02	62.90
4990958540	02/11/97	10/01/02	32	292560	619	6V	5344D	08/10/02	61.54
4990958540	02/11/97	08/30/02	29	180240	623	6V	5344D	08/10/02	41.57
4990958540	02/11/97	08/01/02	30	267480	600	1V	5871D	05/14/97	61.92
4990958540	02/11/97	07/02/02	29	246720	648	1V	5871D	05/14/97	54.70
4990958540	02/11/97	06/03/02	32	257520	600	1V	5871D	05/14/97	55.89
4990958540	02/11/97	05/02/02	29	221280	636	1V	5871D	05/14/97	49.99
4990958540	02/11/97	04/03/02	29	199560	624	1V	5871D	05/14/97	45.95
4990958540	02/11/97	03/05/02	29	180000	600	1V	5871D	05/14/97	43.10
4990958540	02/11/97	02/04/02	32	209880	600	1V	5871D	05/14/97	45.55
4990958540	02/11/97	01/03/02	34	241320	540	1V	5871D	05/14/97	54.77
4990958540	02/11/97	11/30/01	31	218160	636	1V	5871D	05/14/97	46.10
4990958540	02/11/97	10/30/01	29	227760	648	1V	5871D	05/14/97	50.50
4990958540	02/11/97	10/01/01	32	261840	660	1V	5871D	05/14/97	51.66
4990958540	02/11/97	08/30/01	29	253200	672	1V	5871D	05/14/97	54.14
4990958540	02/11/97	08/01/01	30	259800	648	1V	5871D	05/14/97	55.68
4990958540	02/11/97	07/02/01	31	264600	612	1V	5871D	05/14/97	58.11
4990958540	02/11/97	06/01/01	30	232080	660	1V	5871D	05/14/97	48.84
4990958540	02/11/97	05/02/01	29	204840	576	1V	5871D	05/14/97	51.10
4990958540	02/11/97	04/03/01	29	180960	576	1V	5871D	05/14/97	45.14
4990958540	02/11/97	03/05/01	31	202920	564	1V	5871D	05/14/97	48.36
4990958540	02/11/97	02/02/01	29	166920	564	1V	5871D	05/14/97	42.52
4990958540	02/11/97	01/04/01	34	205800	708	1V	5871D	05/14/97	35.62
4990958540	02/11/97	12/01/00	31	202320	600	1V	5871D	05/14/97	45.32
4990958540	02/11/97	10/31/00	29	203400	564	1V	5871D	05/14/97	51.82
4990958540	02/11/97	10/02/00	32	269640	624	1V	5871D	05/14/97	56.27
4990958540	02/11/97	08/31/00	30	256320	636	1V	5871D	05/14/97	55.97
4990958540	02/11/97	08/01/00	32	266280	660	1V	5871D	05/14/97	52.53
4990958540	02/11/97	06/30/00	29	234240	624	1V	5871D	05/14/97	53.93
4990958540	02/11/97	06/01/00	30	240240	600	1V	5871D	05/14/97	55.61

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
4990958540	02/11/97	05/02/00	31	200160	600	1V	5871D	05/14/97	44.84
4990958540	02/11/97	04/03/00	29	195720	600	1V	5871D	05/14/97	46.87
4990958540	02/11/97	03/03/00	30	177360	540	1V	5871D	05/14/97	45.62
4990958540	02/11/97	02/02/00	29	172080	540	1V	5871D	05/14/97	45.79
4990958540	02/11/97	01/04/00	33	206040	564	1V	5871D	05/14/97	46.13
4990958540	02/11/97	12/02/99	31	199440	600	1V	5871D	05/14/97	44.68
4990958540	02/11/97	11/01/99	31	236160	612	1V	5871D	05/14/97	51.87
4990958540	02/11/97	10/01/99	30	236880	600	1V	5871D	05/14/97	54.83
4990958540	02/11/97	09/01/99	30	246240	636	1V	5871D	05/14/97	53.77
4990958540	02/11/97	08/02/99	32	265080	660	1V	5871D	05/14/97	52.30
4990958540	02/11/97	07/01/99	29	225480	600	1V	5871D	05/14/97	53.99
4990958540	02/11/97	06/02/99	30	236160	624	1V	5871D	05/14/97	52.56
4990958540	02/11/97	05/03/99	32	227880	600	1V	5871D	05/14/97	49.45
4990958540	02/11/97	04/01/99	29	176640	576	1V	5871D	05/14/97	44.06
4990958540	02/11/97	03/03/99	29	174600	540	1V	5871D	05/14/97	46.46
4990958540	02/11/97	02/02/99	29	174840	600	1V	5871D	05/14/97	41.87
4990958540	02/11/97	01/04/99	34	223080	600	1V	5871D	05/14/97	45.56
4990958540	02/11/97	12/01/98	33	230280	600	1V	5871D	05/14/97	48.46
4990958540	02/11/97	10/29/98	29	231240	648	1V	5871D	05/14/97	51.27
4990958540	02/11/97	09/30/98	30	233880	600	1V	5871D	05/14/97	54.14
4990958540	02/11/97	08/31/98	32	275520	648	1V	5871D	05/14/97	55.36
4990958540	02/11/97	07/31/98	30	276960	660	1V	5871D	05/14/97	58.28
4990958540	02/11/97	07/01/98	28	243720	624	1V	5871D	05/14/97	58.12
4990958540	02/11/97	06/02/98	32	249840	576	1V	5871D	05/14/97	56.48
4990958540	02/11/97	05/01/98	29	185040	564	1V	5871D	05/14/97	47.14
4990958540	02/11/97	04/02/98	29	170880	552	1V	5871D	05/14/97	44.48
4990958540	02/11/97	03/04/98	30	171720	576	1V	5871D	05/14/97	41.41
4990958540	02/11/97	02/02/98	31	188400	564	1V	5871D	05/14/97	44.90
4990958540	02/11/97	01/02/98	32	216720	588	1V	5871D	05/14/97	47.99
4990958540	02/11/97	12/01/97	30	230640	612	1V	5871D	05/14/97	52.34
4990958540	02/11/97	10/29/97	30	233640	564	1V	5871D	05/14/97	57.54
4990958540	02/11/97	09/29/97	30	271080	660	1V	5871D	05/14/97	57.05
4990958540	02/11/97	08/28/97	30	278640	660	1V	5871D	05/14/97	58.64
4990958540	02/11/97	07/30/97	30	282120	672	1V	5871D	05/14/97	58.31
4990958540	02/11/97	06/30/97	30	231360	600	1V	5871D	05/14/97	53.56
4990958540	02/11/97	05/30/97	30	52440	336	1V	5871D	05/14/97	21.68
4990958540	02/11/97	04/30/97	30	35400	180	1V	5515D	02/11/97	27.31
4990958540	02/11/97	04/01/97	30	85680	282	1V	5515D	02/11/97	42.20

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
4990958540	02/11/97	03/03/97	22	21000	144	1V	5515D	02/11/97	27.62

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>14075 Biscayne Blvd, Miami</b>									
5053085220	08/29/96	06/27/03	29	245280	480	6V	7107D	11/05/02	73.42
5053085220	08/29/96	05/29/03	30	240720	473	6V	7107D	11/05/02	70.68
5053085220	08/29/96	04/29/03	29	202320	439	6V	7107D	11/05/02	66.22
5053085220	08/29/96	03/31/03	31	229920	463	6V	7107D	11/05/02	66.75
5053085220	08/29/96	02/28/03	30	196320	432	6V	7107D	11/05/02	63.12
5053085220	08/29/96	01/29/03	33	183600	454	6V	7107D	11/05/02	51.06
5053085220	08/29/96	12/27/02	32	214320	442	6V	7107D	11/05/02	63.14
5053085220	08/29/96	11/25/02	31	228240	451	6V	7107D	11/05/02	68.02
5053085220	08/29/96	10/25/02	29	234480	480	1V	7745D	08/07/96	70.19
5053085220	08/29/96	09/26/02	30	253200	480	1V	7745D	08/07/96	73.26
5053085220	08/29/96	08/27/02	29	248880	480	1V	7745D	08/07/96	74.50
5053085220	08/29/96	07/29/02	32	261840	456	1V	7745D	08/07/96	74.77
5053085220	08/29/96	06/27/02	29	230160	480	1V	7745D	08/07/96	68.89
5053085220	08/29/96	05/29/02	30	224400	360	1V	7745D	08/07/96	86.57
5053085220	08/29/96	04/29/02	31	206640	480	1V	7745D	08/07/96	57.86
5053085220	08/29/96	03/29/02	29	185760	360	1V	7745D	08/07/96	74.14
5053085220	08/29/96	02/28/02	29	173760	360	1V	7745D	08/07/96	69.35
5053085220	08/29/96	01/30/02	33	205200	360	1V	7745D	08/07/96	71.97
5053085220	08/29/96	12/28/01	31	215760	456	1V	7745D	08/07/96	63.60
5053085220	08/29/96	11/27/01	33	223680	480	1V	7745D	08/07/96	58.84
5053085220	08/29/96	10/25/01	29	218160	480	1V	7745D	08/07/96	65.30
5053085220	08/29/96	09/26/01	30	238560	480	1V	7745D	08/07/96	69.03
5053085220	08/29/96	08/27/01	31	258240	480	1V	7745D	08/07/96	72.31
5053085220	08/29/96	07/27/01	30	230400	480	1V	7745D	08/07/96	66.67
5053085220	08/29/96	06/27/01	29	220560	480	1V	7745D	08/07/96	66.02
5053085220	08/29/96	05/29/01	32	211200	480	1V	7745D	08/07/96	57.29
5053085220	08/29/96	04/27/01	29	186960	480	1V	7745D	08/07/96	55.96
5053085220	08/29/96	03/29/01	29	181920	480	1V	7745D	08/07/96	54.45
5053085220	08/29/96	02/28/01	29	184320	480	1V	7745D	08/07/96	55.17
5053085220	08/29/96	01/30/01	32	167280	480	1V	7745D	08/07/96	45.38
5053085220	08/29/96	12/29/00	31	189120	480	1V	7745D	08/07/96	52.96
5053085220	08/29/96	11/28/00	33	207360	480	1V	7745D	08/07/96	54.55
5053085220	08/29/96	10/26/00	29	197280	480	1V	7745D	08/07/96	59.05
5053085220	08/29/96	09/27/00	30	233280	480	1V	7745D	08/07/96	67.50
5053085220	08/29/96	08/28/00	32	246240	504	1V	7745D	08/07/96	63.62
5053085220	08/29/96	07/27/00	30	232320	480	1V	7745D	08/07/96	67.22
5053085220	08/29/96	06/27/00	32	240960	456	1V	7745D	08/07/96	68.80

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
5053085220	08/29/96	05/26/00	29	190320	432	1V	7745D	08/07/96	63.30
5053085220	08/29/96	04/27/00	29	179760	432	1V	7745D	08/07/96	59.79
5053085220	08/29/96	03/29/00	29	174720	384	1V	7745D	08/07/96	65.37
5053085220	08/29/96	02/29/00	32	177600	360	1V	7745D	08/07/96	64.24
5053085220	08/29/96	01/28/00	30	168000	384	1V	7745D	08/07/96	60.76
5053085220	08/29/96	12/29/99	30	180960	384	1V	7745D	08/07/96	65.45
5053085220	08/29/96	11/29/99	33	206640	432	1V	7745D	08/07/96	60.40
5053085220	08/29/96	10/27/99	29	199680	408	1V	7745D	08/07/96	70.32
5053085220	08/29/96	09/28/99	32	120480	240	1V	7745D	08/07/96	65.36
5053085220	08/29/96	08/27/99	30	244080	480	1V	7745D	08/07/96	70.63
5053085220	08/29/96	07/28/99	30	241920	480	1V	7745D	08/07/96	70.00
5053085220	08/29/96	06/28/99	32	229200	480	1V	7745D	08/07/96	62.17
5053085220	08/29/96	05/27/99	29	192720	480	1V	7745D	08/07/96	57.69
5053085220	08/29/96	04/28/99	30	182400	480	1V	7745D	08/07/96	52.78
5053085220	08/29/96	03/29/99	31	195120	480	1V	7745D	08/07/96	54.64
5053085220	08/29/96	02/26/99	29	183600	480	1V	7745D	08/07/96	54.96
5053085220	08/29/96	01/28/99	30	186240	480	1V	7745D	08/07/96	53.89
5053085220	08/29/96	12/29/98	34	234480	480	1V	7745D	08/07/96	59.87
5053085220	08/29/96	11/25/98	30	213120	480	1V	7745D	08/07/96	61.67
5053085220	08/29/96	10/26/98	30	226320	480	1V	7745D	08/07/96	65.49
5053085220	08/29/96	09/25/98	31	240960	360	1V	7745D	08/07/96	89.96
5053085220	08/29/96	08/26/98	29	245760	480	1V	7745D	08/07/96	73.56
5053085220	08/29/96	07/28/98	32	261600	480	1V	7745D	08/07/96	70.96
5053085220	08/29/96	06/26/98	29	238320	480	1V	7745D	08/07/96	71.34
5053085220	08/29/96	05/28/98	30	210480	480	1V	7745D	08/07/96	60.90
5053085220	08/29/96	04/28/98	29	193440	480	1V	7745D	08/07/96	57.90
5053085220	08/29/96	03/30/98	31	201840	480	1V	7745D	08/07/96	56.52
5053085220	08/29/96	02/27/98	30	185760	480	1V	7745D	08/07/96	53.75
5053085220	08/29/96	01/28/98	30	191280	480	1V	7745D	08/07/96	55.35
5053085220	08/29/96	12/29/97	34	221280	480	1V	7745D	08/07/96	56.50
5053085220	08/29/96	11/25/97	30	223680	480	1V	7745D	08/07/96	64.72
5053085220	08/29/96	10/24/97	30	222960	480	1V	7745D	08/07/96	64.51
5053085220	08/29/96	09/24/97	30	224160	480	1V	7745D	08/07/96	64.86
5053085220	08/29/96	08/25/97	30	253920	480	1V	7745D	08/07/96	73.47
5053085220	08/29/96	07/25/97	30	240000	480	1V	7745D	08/07/96	69.44
5053085220	08/29/96	06/25/97	30	214560	456	1V	7745D	08/07/96	65.35
5053085220	08/29/96	05/27/97	30	221760	480	1V	7745D	08/07/96	64.17
5053085220	08/29/96	04/25/97	30	190800	480	1V	7745D	08/07/96	55.21

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
5053085220	08/29/96	03/27/97	30	217200	480	1V	7745D	08/07/96	62.85
5053085220	08/29/96	02/26/97	30	198480	480	1V	7745D	08/07/96	57.43
5053085220	08/29/96	01/27/97	30	198480	432	1V	7745D	08/07/96	63.81
5053085220	08/29/96	12/26/96	30	216960	456	1V	7745D	08/07/96	66.08
5053085220	08/29/96	11/22/96	30	214560	480	1V	7745D	08/07/96	62.08
5053085220	08/29/96	10/23/96	30	222480	480	1V	7745D	08/07/96	64.38
5053085220	08/29/96	09/24/96	25	190800	480	1V	7745D	08/07/96	66.25

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>2650 NW Federal Hwy, Stuart</b>									
5289024506	09/04/92	06/20/03	30	250680	531	9V	5737H	06/01/92	65.57
5289024506	09/04/92	05/21/03	29	214920	492	9V	5737H	06/01/92	62.76
5289024506	09/04/92	04/22/03	29	182280	480	9V	5737H	06/01/92	54.56
5289024506	09/04/92	03/24/03	31	212640	481	9V	5737H	06/01/92	59.42
5289024506	09/04/92	02/21/03	30	166200	440	9V	5737H	06/01/92	52.46
5289024506	09/04/92	01/22/03	35	189960	454	9V	5737H	06/01/92	49.81
5289024506	09/04/92	12/18/02	30	186480	455	9V	5737H	06/01/92	56.92
5289024506	09/04/92	11/18/02	31	221040	483	9V	5737H	06/01/92	61.51
5289024506	09/04/92	10/18/02	29	227520	524	9V	5737H	06/01/92	62.38
5289024506	09/04/92	09/19/02	30	236520	522	9V	5737H	06/01/92	62.93
5289024506	09/04/92	08/20/02	29	226800	547	9V	5737H	06/01/92	59.57
5289024506	09/04/92	07/22/02	32	232800	516	9V	5737H	06/01/92	58.75
5289024506	09/04/92	06/20/02	30	216000	487	9V	5737H	06/01/92	61.60
5289024506	09/04/92	05/21/02	29	207480	499	9V	5737H	06/01/92	59.74
5289024506	09/04/92	04/22/02	31	200400	481	9V	5737H	06/01/92	56.00
5289024506	09/04/92	03/22/02	29	180720	474	9V	5737H	06/01/92	54.78
5289024506	09/04/92	02/21/02	29	177840	466	9V	5737H	06/01/92	54.83
5289024506	09/04/92	01/23/02	35	192240	470	9V	5737H	06/01/92	48.69
5289024506	09/04/92	12/19/01	33	229200	517	9V	5737H	06/01/92	55.98
5289024506	09/04/92	11/16/01	29	229200	488	9V	5737H	06/01/92	67.48
5289024506	09/04/92	10/18/01	29	251880	514	9V	5737H	06/01/92	70.41
5289024506	09/04/92	09/19/01	30	256680	546	9V	5737H	06/01/92	65.29
5289024506	09/04/92	08/20/01	31	249600	555	9V	5737H	06/01/92	60.45
5289024506	09/04/92	07/20/01	30	235680	498	9V	5737H	06/01/92	65.73
5289024506	09/04/92	06/20/01	30	216480	498	9V	5737H	06/01/92	60.37
5289024506	09/04/92	05/21/01	31	207480	492	9V	5737H	06/01/92	56.68
5289024506	09/04/92	04/20/01	29	190320	506	9V	5737H	06/01/92	54.04
5289024506	09/04/92	03/22/01	29	196320	458	9V	5737H	06/01/92	61.59
5289024506	09/04/92	02/21/01	29	172560	460	9V	5737H	06/01/92	53.90
5289024506	09/04/92	01/23/01	34	182880	414	9V	5737H	06/01/92	54.13
5289024506	09/04/92	12/20/00	33	211920	455	9V	5737H	06/01/92	58.81
5289024506	09/04/92	11/17/00	29	194760	451	9V	5737H	06/01/92	62.05
5289024506	09/04/92	10/19/00	29	220080	498	9V	5737H	06/01/92	63.50
5289024506	09/04/92	09/20/00	30	244680	509	9V	5737H	06/01/92	66.76
5289024506	09/04/92	08/21/00	32	258960	511	9V	5737H	06/01/92	65.99
5289024506	09/04/92	07/20/00	30	240480	519	9V	5737H	06/01/92	64.35
5289024506	09/04/92	06/20/00	32	252720	539	9V	5737H	06/01/92	61.05



Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
5289024506	09/04/92	05/19/00	29	201360	500	9V	5737H	06/01/92	57.86
5289024506	09/04/92	04/20/00	29	187680	487	9V	5737H	06/01/92	55.37
5289024506	09/04/92	03/22/00	29	181200	437	9V	5737H	06/01/92	59.58
5289024506	09/04/92	02/22/00	32	177720	414	9V	5737H	06/01/92	55.90
5289024506	09/04/92	01/21/00	32	184920	434	9V	5737H	06/01/92	55.48
5289024506	09/04/92	12/20/99	32	203400	450	9V	5737H	06/01/92	58.85
5289024506	09/04/92	11/18/99	29	187680	458	9V	5737H	06/01/92	58.88
5289024506	09/04/92	10/20/99	29	217080	498	9V	5737H	06/01/92	62.63
5289024506	09/04/92	09/21/99	32	231360	521	9V	5737H	06/01/92	57.82
5289024506	09/04/92	08/20/99	30	233280	550	9V	5737H	06/01/92	58.91
5289024506	09/04/92	07/21/99	30	223080	522	9V	5737H	06/01/92	59.36
5289024506	09/04/92	06/21/99	32	225480	505	9V	5737H	06/01/92	58.14
5289024506	09/04/92	05/20/99	29	196800	491	9V	5737H	06/01/92	57.59
5289024506	09/04/92	04/21/99	30	190440	517	9V	5737H	06/01/92	51.16
5289024506	09/04/92	03/22/99	31	177840	440	9V	5737H	06/01/92	54.33
5289024506	09/04/92	02/19/99	29	174720	437	9V	5737H	06/01/92	57.44
5289024506	09/04/92	01/21/99	34	202680	456	9V	5737H	06/01/92	54.47
5289024506	09/04/92	12/18/98	30	201720	481	9V	5737H	06/01/92	58.25
5289024506	09/04/92	11/18/98	30	203160	507	9V	5737H	06/01/92	55.65
5289024506	09/04/92	10/19/98	31	241440	525	9V	5737H	06/01/92	61.81
5289024506	09/04/92	09/18/98	30	234000	550	9V	5737H	06/01/92	59.09
5289024506	09/04/92	08/19/98	29	247200	560	9V	5737H	06/01/92	63.42
5289024506	09/04/92	07/21/98	32	262920	566	9V	5737H	06/01/92	60.48
5289024506	09/04/92	06/19/98	30	251640	568	9V	5737H	06/01/92	61.53
5289024506	09/04/92	05/20/98	29	197280	519	9V	5737H	06/01/92	54.61
5289024506	09/04/92	04/21/98	29	183360	539	9V	5737H	06/01/92	48.88
5289024506	09/04/92	03/23/98	31	177120	460	9V	5737H	06/01/92	51.75
5289024506	09/04/92	02/20/98	30	160920	411	9V	5737H	06/01/92	54.38
5289024506	09/04/92	01/21/98	34	197760	466	9V	5737H	06/01/92	52.01
5289024506	09/04/92	12/18/97	30	193080	478	9V	5737H	06/01/92	56.10
5289024506	09/04/92	11/18/97	30	205680	479	9V	5737H	06/01/92	59.64
5289024506	09/04/92	10/17/97	30	210720	491	9V	5737H	06/01/92	59.61
5289024506	09/04/92	09/17/97	30	210960	528	9V	5737H	06/01/92	55.49
5289024506	09/04/92	08/18/97	30	274731	509	9V	5737H	06/01/92	74.96
5289024506	09/04/92	07/18/97	30	226800	450	9V	5737H	06/01/92	70.00
5289024506	09/04/92	06/18/97	30	209880	484	9V	5737H	06/01/92	60.23
5289024506	09/04/92	05/19/97	30	192120	475	9V	5737H	06/01/92	56.18
5289024506	09/04/92	04/18/97	30	168600	448	9V	5737H	06/01/92	52.27

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
5289024506	09/04/92	03/20/97	30	180360	416	9V	5737H	06/01/92	60.22
5289024506	09/04/92	02/18/97	30	172920	428	9V	5737H	06/01/92	56.11
5289024506	09/04/92	01/17/97	30	168000	397	9V	5737H	06/01/92	58.77
5289024506	09/04/92	12/17/96	30	201360	429	9V	5737H	06/01/92	65.19
5289024506	09/04/92	11/15/96	30	191640	450	9V	5737H	06/01/92	59.15
5289024506	09/04/92	10/16/96	30	196320	494	9V	5737H	06/01/92	55.20
5289024506	09/04/92	09/17/96	30	237600	483	9V	5737H	06/01/92	68.32
5289024506	09/04/92	08/16/96	30	233400	534	9V	5737H	06/01/92	60.71
5289024506	09/04/92	07/18/96	30	239880	551	9V	5737H	06/01/92	60.47
5289024506	09/04/92	06/18/96	30	210840	476	9V	5737H	06/01/92	61.52
5289024506	09/04/92	05/17/96	30	178560	431	9V	5737H	06/01/92	57.54
5289024506	09/04/92	04/18/96	30	150480	419	9V	5737H	06/01/92	49.88
5289024506	09/04/92	03/20/96	30	155880	406	9V	5737H	06/01/92	53.33
5289024506	09/04/92	02/20/96	30	147000	384	9V	5737H	06/01/92	53.17
5289024506	09/04/92	01/22/96	30	171240	413	9V	5737H	06/01/92	57.59
5289024506	09/04/92	12/19/95	30	193560	405	9V	5737H	06/01/92	66.38
5289024506	09/04/92	11/17/95	30	193440	469	9V	5737H	06/01/92	57.29
5289024506	09/04/92	10/18/95	30	210240	490	9V	5737H	06/01/92	59.59
5289024506	09/04/92	09/19/95	30	231120	489	9V	5737H	06/01/92	65.64
5289024506	09/04/92	08/18/95	30	203760	485	9V	5737H	06/01/92	58.35
5289024506	09/04/92	07/20/95	30	217560	515	9V	5737H	06/01/92	58.67
5289024506	09/04/92	06/20/95	30	226320	496	9V	5737H	06/01/92	63.37
5289024506	09/04/92	05/19/95	30	194400	494	9V	5737H	06/01/92	54.66
5289024506	09/04/92	04/20/95	30	170280	440	9V	5737H	06/01/92	53.75
5289024506	09/04/92	03/22/95	30	153120	430	9V	5737H	06/01/92	49.46
5289024506	09/04/92	02/21/95	30	145440	395	9V	5737H	06/01/92	51.14
5289024506	09/04/92	01/23/95	30	162120	392	9V	5737H	06/01/92	57.44
5289024506	09/04/92	12/21/94	30	186120	502	9V	5737H	06/01/92	51.49
5289024506	09/04/92	11/21/94	30	202200	487	9V	5737H	06/01/92	57.67
5289024506	09/04/92	10/20/94	30	198000	487	9V	5737H	06/01/92	56.47
5289024506	09/04/92	09/20/94	30	222480	504	9V	5737H	06/01/92	61.31
5289024506	09/04/92	08/19/94	30	203400	517	9V	5737H	06/01/92	54.64
5289024506	09/04/92	07/21/94	30	213600	544	9V	5737H	06/01/92	54.53
5289024506	09/04/92	06/21/94	30	212880	521	9V	5737H	06/01/92	56.75
5289024506	09/04/92	05/20/94	30	190320	516	9V	5737H	06/01/92	51.23
5289024506	09/04/92	04/21/94	30	189720	488	9V	5737H	06/01/92	54.00
5289024506	09/04/92	03/23/94	30	162120	543	9V	5737H	06/01/92	41.47
5289024506	09/04/92	02/22/94	30	175800	473	9V	5737H	06/01/92	51.62

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
5289024506	09/04/92	01/21/94	30	151920	402	9V	5737H	06/01/92	52.49
5289024506	09/04/92	12/21/93	30	180720	461	9V	5737H	06/01/92	54.45
5289024506	09/04/92	11/19/93	30	188040	565	9V	5737H	06/01/92	46.22
5289024506	09/04/92	10/20/93	30	192480	494	9V	5737H	06/01/92	54.12
5289024506	09/04/92	09/21/93	30	220800	540	9V	5737H	06/01/92	56.79
5289024506	09/04/92	08/20/93	30	206880	518	9V	5737H	06/01/92	55.47
5289024506	09/04/92	07/21/93	30	194400	498	9V	5737H	06/01/92	54.22
5289024506	09/04/92	06/21/93	30	195720	467	9V	5737H	06/01/92	58.21
5289024506	09/04/92	05/20/93	30	163320	426	9V	5737H	06/01/92	53.25
5289024506	09/04/92	04/21/93	30	167640	432	9V	5737H	06/01/92	53.90
5289024506	09/04/92	03/22/93	30	137160	383	9V	5737H	06/01/92	49.74

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>2750 W New Haven Ave, Melbourne Village</b>									
5419800197	06/19/92	06/17/03	32	256320	511	9V	5080H	07/22/99	65.31
5419800197	06/19/92	05/16/03	29	217680	512	9V	5080H	07/22/99	61.09
5419800197	06/19/92	04/17/03	29	201720	516	9V	5080H	07/22/99	56.17
5419800197	06/19/92	03/19/03	29	196320	487	9V	5080H	07/22/99	57.92
5419800197	06/19/92	02/18/03	33	177960	446	9V	5080H	07/22/99	50.38
5419800197	06/19/92	01/16/03	33	177240	425	9V	5080H	07/22/99	52.66
5419800197	06/19/92	12/14/02	31	190560	483	9V	5080H	07/22/99	53.03
5419800197	06/19/92	11/13/02	29	217440	506	9V	5080H	07/22/99	61.74
5419800197	06/19/92	10/15/02	29	247320	513	9V	5080H	07/22/99	69.27
5419800197	06/19/92	09/16/02	32	272640	522	9V	5080H	07/22/99	68.01
5419800197	06/19/92	08/15/02	29	255120	545	9V	5080H	07/22/99	67.26
5419800197	06/19/92	07/17/02	30	250800	528	9V	5080H	07/22/99	65.97
5419800197	06/19/92	06/17/02	32	252480	526	9V	5080H	07/22/99	62.50
5419800197	06/19/92	05/16/02	29	224160	509	9V	5080H	07/22/99	63.27
5419800197	06/19/92	04/17/02	29	197040	479	9V	5080H	07/22/99	59.10
5419800197	06/19/92	03/19/02	29	179040	463	9V	5080H	07/22/99	55.56
5419800197	06/19/92	02/18/02	32	205800	450	9V	5080H	07/22/99	59.55
5419800197	06/19/92	01/17/02	34	196560	459	9V	5080H	07/22/99	52.48
5419800197	06/19/92	12/14/01	31	219480	461	9V	5080H	07/22/99	63.99
5419800197	06/19/92	11/13/01	29	215160	516	9V	5080H	07/22/99	59.91
5419800197	06/19/92	10/15/01	31	243480	534	9V	5080H	07/22/99	61.28
5419800197	06/19/92	09/14/01	30	250560	542	9V	5080H	07/22/99	64.21
5419800197	06/19/92	08/15/01	29	257880	584	9V	5080H	07/22/99	63.44
5419800197	06/19/92	07/17/01	32	276960	530	9V	5080H	07/22/99	68.04
5419800197	06/19/92	06/15/01	30	237360	541	9V	5080H	07/22/99	60.94
5419800197	06/19/92	05/16/01	29	197160	478	9V	5080H	07/22/99	59.26
5419800197	06/19/92	04/17/01	29	184200	525	9V	5080H	07/22/99	50.41
5419800197	06/19/92	03/19/01	31	193320	459	9V	5080H	07/22/99	56.61
5419800197	06/19/92	02/16/01	29	164880	422	9V	5080H	07/22/99	56.14
5419800197	06/19/92	01/18/01	34	182400	459	9V	5080H	07/22/99	48.70
5419800197	06/19/92	12/15/00	31	195720	462	9V	5080H	07/22/99	56.94
5419800197	06/19/92	11/14/00	29	197640	454	9V	5080H	07/22/99	62.55
5419800197	06/19/92	10/16/00	31	245520	536	9V	5080H	07/22/99	61.57
5419800197	06/19/92	09/15/00	30	253320	544	9V	5080H	07/22/99	64.68
5419800197	06/19/92	08/16/00	30	260640	563	9V	5080H	07/22/99	64.30
5419800197	06/19/92	07/17/00	32	264360	529	9V	5080H	07/22/99	65.07
5419800197	06/19/92	06/15/00	30	235920	537	9V	5080H	07/22/99	61.02

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
5419800197	06/19/92	05/16/00	29	203520	488	9V	5080H	07/22/99	59.92
5419800197	06/19/92	04/17/00	31	198720	455	9V	5080H	07/22/99	58.70
5419800197	06/19/92	03/17/00	30	188760	427	9V	5080H	07/22/99	61.40
5419800197	06/19/92	02/16/00	29	151320	395	9V	5080H	07/22/99	55.04
5419800197	06/19/92	01/18/00	34	196200	439	9V	5080H	07/22/99	54.77
5419800197	06/19/92	12/15/99	30	190080	441	9V	5080H	07/22/99	59.86
5419800197	06/19/92	11/15/99	31	215400	491	9V	5080H	07/22/99	58.96
5419800197	06/19/92	10/15/99	29	240960	538	9V	5080H	07/22/99	64.35
5419800197	06/19/92	09/16/99	30	252960	546	9V	5080H	07/22/99	64.35
5419800197	06/19/92	08/17/99	32	275400	515	9V	5080H	07/22/99	69.63
5419800197	06/19/92	07/16/99	30	248880	537	9V	5154H	12/02/98	64.37
5419800197	06/19/92	06/16/99	30	239760	529	9V	5154H	12/02/98	62.95
5419800197	06/19/92	05/17/99	31	216000	500	9V	5154H	12/02/98	58.06
5419800197	06/19/92	04/16/99	30	190080	501	9V	5154H	12/02/98	52.69
5419800197	06/19/92	03/17/99	29	156720	397	9V	5154H	12/02/98	56.72
5419800197	06/19/92	02/16/99	32	190200	454	9V	5154H	12/02/98	54.55
5419800197	06/19/92	01/15/99	31	177240	461	9V	5154H	12/02/98	51.68
5419800197	06/19/92	12/15/98	32	216720	480	9V	5154H	12/02/98	58.79
5419800197	06/19/92	11/13/98	30	208920	516	1V	5209D	03/01/92	56.23
5419800197	06/19/92	10/14/98	29	234240	540	1V	5209D	03/01/92	62.32
5419800197	06/19/92	09/15/98	32	281160	540	1V	5209D	03/01/92	67.80
5419800197	06/19/92	08/14/98	29	255840	540	1V	5209D	03/01/92	68.07
5419800197	06/19/92	07/16/98	30	262680	600	1V	5209D	03/01/92	60.81
5419800197	06/19/92	06/16/98	32	271200	600	1V	5209D	03/01/92	58.85
5419800197	06/19/92	05/15/98	29	208320	564	1V	5209D	03/01/92	53.07
5419800197	06/19/92	04/16/98	29	187800	564	1V	5209D	03/01/92	47.84
5419800197	06/19/92	03/18/98	29	170760	516	1V	5209D	03/01/92	47.55
5419800197	06/19/92	02/17/98	33	174480	528	1V	5209D	03/01/92	41.72
5419800197	06/19/92	01/15/98	31	180120	540	1V	5209D	03/01/92	44.83
5419800197	06/19/92	12/15/97	30	198120	540	1V	5209D	03/01/92	50.96
5419800197	06/19/92	11/13/97	30	194760	540	1V	5209D	03/01/92	50.09
5419800197	06/19/92	10/14/97	30	251760	540	1V	5209D	03/01/92	64.75
5419800197	06/19/92	09/12/97	30	237000	552	1V	5209D	03/01/92	59.63
5419800197	06/19/92	08/13/97	30	245760	552	1V	5209D	03/01/92	61.84
5419800197	06/19/92	07/15/97	30	255600	576	1V	5209D	03/01/92	61.63
5419800197	06/19/92	06/13/97	30	224640	540	1V	5209D	03/01/92	57.78
5419800197	06/19/92	05/14/97	30	187680	528	1V	5209D	03/01/92	49.37
5419800197	06/19/92	04/15/97	30	181440	552	1V	5209D	03/01/92	45.65

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
5419800197	06/19/92	03/17/97	30	204480	480	1V	5209D	03/01/92	59.17
5419800197	06/19/92	02/13/97	30	165600	480	1V	5209D	03/01/92	47.92
5419800197	06/19/92	01/14/97	30	194640	516	1V	5209D	03/01/92	52.39
5419800197	06/19/92	12/12/96	30	199440	504	1V	5209D	03/01/92	54.96
5419800197	06/19/92	11/12/96	30	202800	516	1V	5209D	03/01/92	54.59
5419800197	06/19/92	10/11/96	30	233640	552	1V	5209D	03/01/92	58.79
5419800197	06/19/92	09/12/96	30	244680	576	1V	5209D	03/01/92	59.00
5419800197	06/19/92	08/13/96	30	237600	564	1V	5209D	03/01/92	58.51
5419800197	06/19/92	07/15/96	30	254400	540	1V	5209D	03/01/92	65.43
5419800197	06/19/92	06/13/96	30	221520	540	1V	5209D	03/01/92	56.98
5419800197	06/19/92	05/14/96	30	201360	528	1V	5209D	03/01/92	52.97
5419800197	06/19/92	04/15/96	30	189600	504	1V	5209D	03/01/92	52.25
5419800197	06/19/92	03/15/96	30	170640	480	1V	5209D	03/01/92	49.38
5419800197	06/19/92	02/15/96	30	159600	370	1V	5209D	03/01/92	59.91
5419800197	06/19/92	01/17/96	30	180600	456	1V	5209D	03/01/92	55.01
5419800197	06/19/92	12/14/95	30	191760	480	1V	5209D	03/01/92	55.49
5419800197	06/19/92	11/14/95	30	223320	528	1V	5209D	03/01/92	58.74
5419800197	06/19/92	10/13/95	30	237600	552	1V	5209D	03/01/92	59.78
5419800197	06/19/92	09/14/95	30	242280	516	1V	5209D	03/01/92	65.21
5419800197	06/19/92	08/15/95	30	246240	576	1V	5209D	03/01/92	59.38
5419800197	06/19/92	07/17/95	30	267000	564	1V	5209D	03/01/92	65.75
5419800197	06/19/92	06/15/95	30	240840	576	1V	5209D	03/01/92	58.07
5419800197	06/19/92	05/16/95	30	224880	564	1V	5209D	03/01/92	55.38
5419800197	06/19/92	04/17/95	30	202200	504	1V	5209D	03/01/92	55.72
5419800197	06/19/92	03/17/95	30	172440	480	1V	5209D	03/01/92	49.90
5419800197	06/19/92	02/16/95	30	157320	444	1V	5209D	03/01/92	49.21
5419800197	06/19/92	01/18/95	30	180120	480	1V	5209D	03/01/92	52.12
5419800197	06/19/92	12/16/94	30	240480	528	1V	5209D	03/01/92	63.26
5419800197	06/19/92	11/16/94	30	190440	520	1V	5209D	03/01/92	50.87
5419800197	06/19/92	10/17/94	30	240480	552	1V	5209D	03/01/92	60.51
5419800197	06/19/92	09/15/94	30	238560	552	1V	5209D	03/01/92	60.02
5419800197	06/19/92	08/16/94	30	227160	552	1V	5209D	03/01/92	57.16
5419800197	06/19/92	07/18/94	30	247080	564	1V	5209D	03/01/92	60.85
5419800197	06/19/92	06/16/94	30	209400	564	1V	5209D	03/01/92	51.57
5419800197	06/19/92	05/17/94	30	192720	540	1V	5209D	03/01/92	49.57
5419800197	06/19/92	04/18/94	30	185760	516	1V	5209D	03/01/92	50.00
5419800197	06/19/92	03/18/94	30	157440	444	1V	5209D	03/01/92	49.25
5419800197	06/19/92	02/16/94	30	144840	468	1V	5209D	03/01/92	42.98

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
5419800197	06/19/92	01/18/94	30	150480	396	1V	5209D	03/01/92	52.78
5419800197	06/19/92	12/16/93	30	164280	504	1V	5209D	03/01/92	45.27
5419800197	06/19/92	11/16/93	30	192120	504	1V	5209D	03/01/92	52.94
5419800197	06/19/92	10/15/93	30	195360	576	1V	5209D	03/01/92	47.11
5419800197	06/19/92	09/16/93	30	207840	570	1V	5209D	03/01/92	50.64
5419800197	06/19/92	08/17/93	30	229320	564	1V	5209D	03/01/92	56.47
5419800197	06/19/92	07/16/93	30	200400	564	1V	5209D	03/01/92	49.35
5419800197	06/19/92	06/16/93	30	189360	559	1V	5209D	03/01/92	47.05
5419800197	06/19/92	05/17/93	30	167520	468	1V	5209D	03/01/92	49.72
5419800197	06/19/92	04/16/93	30	149040	420	1V	5209D	03/01/92	49.29
5419800197	06/19/92	03/17/93	30	131400	396	1V	5209D	03/01/92	46.09

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>2750 W New Haven Ave # Lift, Melbourne Village</b>									
5424805116	05/01/92	06/17/03	32	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	05/16/03	29	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	04/17/03	29	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	03/19/03	29	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	02/18/03	33	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	01/16/03	33	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	12/14/02	31	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	11/13/02	29	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	10/15/02	29	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	09/16/02	32	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	08/15/02	29	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	07/17/02	30	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	06/17/02	32	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	05/16/02	29	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	04/17/02	29	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	03/19/02	29	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	02/18/02	32	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	01/17/02	34	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	12/14/01	31	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	11/13/01	29	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	10/15/01	31	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	09/14/01	30	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	08/15/01	29	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	07/17/01	32	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	06/15/01	30	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	05/16/01	29	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	04/17/01	29	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	03/19/01	31	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	02/16/01	29	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	01/18/01	34	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	12/15/00	31	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	11/14/00	29	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	10/16/00	31	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	09/15/00	30	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	08/16/00	30	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	07/17/00	32	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	06/15/00	30	0	0	5J	97936	05/01/92	-



Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
5424805116	05/01/92	05/16/00	29	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	04/17/00	31	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	03/17/00	30	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	02/16/00	29	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	01/18/00	34	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	12/15/99	30	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	11/15/99	31	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	10/15/99	29	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	09/16/99	30	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	08/17/99	32	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	07/16/99	30	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	06/16/99	30	2	0	5J	97936	05/01/92	-
5424805116	05/01/92	05/17/99	31	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	04/16/99	30	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	03/17/99	29	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	02/16/99	32	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	01/15/99	31	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	12/15/98	32	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	11/13/98	30	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	10/14/98	29	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	09/15/98	32	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	08/14/98	29	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	07/16/98	30	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	06/16/98	32	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	05/15/98	29	7	0	5J	97936	05/01/92	-
5424805116	05/01/92	04/16/98	29	2	0	5J	97936	05/01/92	-
5424805116	05/01/92	03/18/98	29	3	0	5J	97936	05/01/92	-
5424805116	05/01/92	02/17/98	33	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	01/15/98	31	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	12/15/97	30	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	11/13/97	30	18	0	5J	97936	05/01/92	-
5424805116	05/01/92	10/14/97	30	14	0	5J	97936	05/01/92	-
5424805116	05/01/92	09/12/97	30	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	08/13/97	30	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	07/15/97	30	0	0	5J	97936	05/01/92	-
5424805116	05/01/92	06/13/97	30	4	0	5J	97936	05/01/92	-
5424805116	05/01/92	05/14/97	30	9	0	5J	97936	05/01/92	-
5424805116	05/01/92	04/15/97	30	11	0	5J	97936	05/01/92	-

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
5424805116	05/01/92	03/17/97	30	14	0	5J	97936	05/01/92	-
5424805116	05/01/92	02/13/97	30	25	0	5J	97936	05/01/92	-
5424805116	05/01/92	01/14/97	30	8	0	5J	97936	05/01/92	-
5424805116	05/01/92	12/12/96	30	13	0	5J	97936	05/01/92	-
5424805116	05/01/92	11/12/96	30	3	0	5J	97936	05/01/92	-
5424805116	05/01/92	10/11/96	30	2	0	5J	97936	05/01/92	-
5424805116	05/01/92	09/12/96	30	13	0	5J	97936	05/01/92	-
5424805116	05/01/92	08/13/96	30	12	0	5J	97936	05/01/92	-
5424805116	05/01/92	07/15/96	30	47	0	5J	97936	05/01/92	-
5424805116	05/01/92	06/13/96	30	20	0	5J	97936	05/01/92	-
5424805116	05/01/92	05/14/96	30	7	0	5J	97936	05/01/92	-
5424805116	05/01/92	04/15/96	30	7	0	5J	97936	05/01/92	-
5424805116	05/01/92	03/15/96	30	8	0	5J	97936	05/01/92	-
5424805116	05/01/92	02/15/96	30	7	0	5J	97936	05/01/92	-
5424805116	05/01/92	01/17/96	30	16	0	5J	97936	05/01/92	-
5424805116	05/01/92	12/14/95	30	13	0	5J	97936	05/01/92	-
5424805116	05/01/92	11/14/95	30	7	0	5J	97936	05/01/92	-
5424805116	05/01/92	10/13/95	30	11	0	5J	97936	05/01/92	-
5424805116	05/01/92	09/14/95	30	21	0	5J	97936	05/01/92	-
5424805116	05/01/92	08/15/95	30	55	0	5J	97936	05/01/92	-
5424805116	05/01/92	07/17/95	30	67	0	5J	97936	05/01/92	-
5424805116	05/01/92	06/15/95	30	42	0	5J	97936	05/01/92	-
5424805116	05/01/92	05/16/95	30	44	0	5J	97936	05/01/92	-
5424805116	05/01/92	04/17/95	30	43	0	5J	97936	05/01/92	-
5424805116	05/01/92	03/17/95	30	58	0	5J	97936	05/01/92	-
5424805116	05/01/92	02/16/95	30	398	0	5J	97936	05/01/92	-
5424805116	05/01/92	01/18/95	30	196	0	5J	97936	05/01/92	-
5424805116	05/01/92	12/16/94	30	28	0	5J	97936	05/01/92	-
5424805116	05/01/92	11/16/94	30	90	0	5J	97936	05/01/92	-
5424805116	05/01/92	10/17/94	30	46	0	5J	97936	05/01/92	-
5424805116	05/01/92	09/15/94	30	51	0	5J	97936	05/01/92	-
5424805116	05/01/92	08/16/94	30	39	0	5J	97936	05/01/92	-
5424805116	05/01/92	07/18/94	30	56	0	5J	97936	05/01/92	-
5424805116	05/01/92	06/16/94	30	43	0	5J	97936	05/01/92	-
5424805116	05/01/92	05/17/94	30	36	0	5J	97936	05/01/92	-
5424805116	05/01/92	04/18/94	30	51	0	5J	97936	05/01/92	-
5424805116	05/01/92	03/18/94	30	39	0	5J	97936	05/01/92	-
5424805116	05/01/92	02/16/94	30	43	0	5J	97936	05/01/92	-

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
5424805116	05/01/92	01/18/94	30	91	0	5J	97936	05/01/92	-
5424805116	05/01/92	12/16/93	30	147	0	5J	97936	05/01/92	-
5424805116	05/01/92	11/16/93	30	67	0	5J	97936	05/01/92	-
5424805116	05/01/92	10/15/93	30	35	0	5J	97936	05/01/92	-
5424805116	05/01/92	09/16/93	30	28	0	5J	97936	05/01/92	-
5424805116	05/01/92	08/17/93	30	41	0	5J	97936	05/01/92	-
5424805116	05/01/92	07/16/93	30	32	0	5J	97936	05/01/92	-
5424805116	05/01/92	06/16/93	30	38	0	5J	97936	05/01/92	-
5424805116	05/01/92	05/17/93	30	48	0	5J	97936	05/01/92	-
5424805116	05/01/92	04/16/93	30	59	0	5J	97936	05/01/92	-
5424805116	05/01/92	03/17/93	30	40	0	5J	97936	05/01/92	-

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>4271 Tamiami Trl S, Venice</b>									
5954343371	03/04/92	06/23/03	32	254880	538	6V	5749D	11/11/02	61.69
5954343371	03/04/92	05/22/03	29	222600	517	6V	5749D	11/11/02	61.86
5954343371	03/04/92	04/23/03	29	191760	484	6V	5749D	11/11/02	56.93
5954343371	03/04/92	03/25/03	29	205800	493	6V	5749D	11/11/02	59.98
5954343371	03/04/92	02/24/03	32	186120	491	6V	5749D	11/11/02	49.36
5954343371	03/04/92	01/23/03	35	194040	457	6V	5749D	11/11/02	50.55
5954343371	03/04/92	12/19/02	30	183480	463	6V	5749D	11/11/02	55.04
5954343371	03/04/92	11/19/02	29	214680	500	6V	5749D	11/11/02	61.69
5954343371	03/04/92	10/21/02	31	268680	576	1V	5159D	03/01/92	62.70
5954343371	03/04/92	09/20/02	30	248160	576	1V	5159D	03/01/92	59.84
5954343371	03/04/92	08/21/02	29	245760	588	1V	5159D	03/01/92	60.05
5954343371	03/04/92	07/23/02	32	259200	588	1V	5159D	03/01/92	57.40
5954343371	03/04/92	06/21/02	30	231480	576	1V	5159D	03/01/92	55.82
5954343371	03/04/92	05/22/02	29	208920	504	1V	5159D	03/01/92	59.56
5954343371	03/04/92	04/23/02	29	189120	480	1V	5159D	03/01/92	56.61
5954343371	03/04/92	03/25/02	31	185880	480	1V	5159D	03/01/92	52.05
5954343371	03/04/92	02/22/02	29	176400	570	1V	5159D	03/01/92	44.46
5954343371	03/04/92	01/24/02	35	197400	576	1V	5159D	03/01/92	40.80
5954343371	03/04/92	12/20/01	31	214080	600	1V	5159D	03/01/92	47.96
5954343371	03/04/92	11/19/01	31	206040	564	1V	5159D	03/01/92	49.10
5954343371	03/04/92	10/19/01	29	218640	582	1V	5159D	03/01/92	53.98
5954343371	03/04/92	09/20/01	30	235800	612	1V	5159D	03/01/92	53.51
5954343371	03/04/92	08/21/01	29	242760	624	1V	5159D	03/01/92	55.90
5954343371	03/04/92	07/23/01	32	294000	600	1V	5159D	03/01/92	63.80
5954343371	03/04/92	06/21/01	30	246600	600	1V	5159D	03/01/92	57.08
5954343371	03/04/92	05/22/01	29	205080	600	1V	5159D	03/01/92	49.11
5954343371	03/04/92	04/23/01	31	210000	588	1V	5159D	03/01/92	48.00
5954343371	03/04/92	03/23/01	29	197400	576	1V	5159D	03/01/92	49.24
5954343371	03/04/92	02/22/01	29	185040	564	1V	5159D	03/01/92	47.14
5954343371	03/04/92	01/24/01	34	195120	516	1V	5159D	03/01/92	46.34
5954343371	03/04/92	12/21/00	31	200400	540	1V	5159D	03/01/92	49.88
5954343371	03/04/92	11/20/00	31	221880	564	1V	5159D	03/01/92	52.88
5954343371	03/04/92	10/20/00	29	227760	576	1V	5159D	03/01/92	56.81
5954343371	03/04/92	09/21/00	30	246600	576	1V	5159D	03/01/92	59.46
5954343371	03/04/92	08/22/00	32	259680	576	1V	5159D	03/01/92	58.70
5954343371	03/04/92	07/21/00	30	229680	600	1V	5159D	03/01/92	53.17
5954343371	03/04/92	06/21/00	30	229080	528	1V	5159D	03/01/92	60.26

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
5954343371	03/04/92	05/22/00	31	206640	552	1V	5159D	03/01/92	50.32
5954343371	03/04/92	04/21/00	29	188040	540	1V	5159D	03/01/92	50.03
5954343371	03/04/92	03/23/00	29	182520	480	1V	5159D	03/01/92	54.63
5954343371	03/04/92	02/23/00	30	168480	516	1V	5159D	03/01/92	45.35
5954343371	03/04/92	01/24/00	34	198000	480	1V	5159D	03/01/92	50.55
5954343371	03/04/92	12/21/99	32	200640	516	1V	5159D	03/01/92	50.63
5954343371	03/04/92	11/19/99	29	187920	552	1V	5159D	03/01/92	48.91
5954343371	03/04/92	10/21/99	29	215760	552	1V	5159D	03/01/92	56.16
5954343371	03/04/92	09/22/99	30	227280	564	1V	5159D	03/01/92	55.97
5954343371	03/04/92	08/23/99	32	249240	528	1V	5159D	03/01/92	61.46
5954343371	03/04/92	07/22/99	30	244440	516	1V	5159D	03/01/92	65.79
5954343371	03/04/92	06/22/99	32	232080	504	1V	5159D	03/01/92	59.96
5954343371	03/04/92	05/21/99	29	202800	504	1V	5159D	03/01/92	57.81
5954343371	03/04/92	04/22/99	30	190560	540	1V	5159D	03/01/92	49.01
5954343371	03/04/92	03/23/99	29	164880	564	1V	5159D	03/01/92	42.00
5954343371	03/04/92	02/22/99	31	187800	516	1V	5159D	03/01/92	48.92
5954343371	03/04/92	01/22/99	32	181560	528	1V	5159D	03/01/92	44.77
5954343371	03/04/92	12/21/98	32	208560	540	1V	5159D	03/01/92	50.29
5954343371	03/04/92	11/19/98	30	199320	504	1V	5159D	03/01/92	54.93
5954343371	03/04/92	10/20/98	29	222000	552	1V	5159D	03/01/92	57.78
5954343371	03/04/92	09/21/98	32	246600	558	1V	5159D	03/01/92	57.54
5954343371	03/04/92	08/20/98	29	238200	540	1V	5159D	03/01/92	63.38
5954343371	03/04/92	07/22/98	30	237360	564	1V	5159D	03/01/92	58.45
5954343371	03/04/92	06/22/98	32	252480	540	1V	5159D	03/01/92	60.88
5954343371	03/04/92	05/21/98	29	197280	516	1V	5159D	03/01/92	54.93
5954343371	03/04/92	04/22/98	29	189120	480	1V	5159D	03/01/92	56.61
5954343371	03/04/92	03/24/98	29	169680	492	1V	5159D	03/01/92	49.55
5954343371	03/04/92	02/23/98	33	184680	480	1V	5159D	03/01/92	48.58
5954343371	03/04/92	01/22/98	34	195480	480	1V	5159D	03/01/92	49.91
5954343371	03/04/92	12/19/97	30	183960	468	1V	5159D	03/01/92	54.59
5954343371	03/04/92	11/19/97	30	183480	480	1V	5159D	03/01/92	53.09
5954343371	03/04/92	10/20/97	30	230040	516	1V	5159D	03/01/92	61.92
5954343371	03/04/92	09/18/97	30	224400	504	1V	5159D	03/01/92	61.84
5954343371	03/04/92	08/19/97	30	233520	528	1V	5159D	03/01/92	61.43
5954343371	03/04/92	07/21/97	30	240840	504	1V	5159D	03/01/92	66.37
5954343371	03/04/92	06/19/97	30	209040	480	1V	5159D	03/01/92	60.49
5954343371	03/04/92	05/20/97	30	181800	456	1V	5159D	03/01/92	55.37
5954343371	03/04/92	04/21/97	30	182880	504	1V	5159D	03/01/92	50.40

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
5954343371	03/04/92	03/21/97	30	172920	456	1V	5159D	03/01/92	52.67
5954343371	03/04/92	02/20/97	30	162840	444	1V	5159D	03/01/92	50.94
5954343371	03/04/92	01/21/97	30	183600	420	1V	5159D	03/01/92	60.71
5954343371	03/04/92	12/18/96	30	172920	480	1V	5159D	03/01/92	50.03
5954343371	03/04/92	11/18/96	30	201120	504	1V	5159D	03/01/92	55.42
5954343371	03/04/92	10/17/96	30	205680	492	1V	5159D	03/01/92	58.06
5954343371	03/04/92	09/18/96	30	223920	504	1V	5159D	03/01/92	61.71
5954343371	03/04/92	08/19/96	30	230400	480	1V	5159D	03/01/92	66.67
5954343371	03/04/92	07/19/96	30	222240	504	1V	5159D	03/01/92	61.24
5954343371	03/04/92	06/19/96	30	213120	504	1V	5159D	03/01/92	58.73
5954343371	03/04/92	05/20/96	30	200640	480	1V	5159D	03/01/92	58.06
5954343371	03/04/92	04/19/96	30	160800	432	1V	5159D	03/01/92	51.70
5954343371	03/04/92	03/21/96	30	157560	444	1V	5159D	03/01/92	49.29
5954343371	03/04/92	02/21/96	30	150720	444	1V	5159D	03/01/92	47.15
5954343371	03/04/92	01/23/96	30	170400	480	1V	5159D	03/01/92	49.31
5954343371	03/04/92	12/20/95	30	168480	480	1V	5159D	03/01/92	48.75
5954343371	03/04/92	11/20/95	30	195360	480	1V	5159D	03/01/92	56.53
5954343371	03/04/92	10/19/95	30	203880	540	1V	5159D	03/01/92	52.44
5954343371	03/04/92	09/20/95	30	213840	540	1V	5159D	03/01/92	55.00
5954343371	03/04/92	08/21/95	30	226200	480	1V	5159D	03/01/92	65.45
5954343371	03/04/92	07/21/95	30	214200	492	1V	5159D	03/01/92	60.47
5954343371	03/04/92	06/21/95	30	206280	552	1V	5159D	03/01/92	51.90
5954343371	03/04/92	05/22/95	30	212760	468	1V	5159D	03/01/92	63.14
5954343371	03/04/92	04/21/95	30	168240	444	1V	5159D	03/01/92	52.63
5954343371	03/04/92	03/23/95	30	155760	480	1V	5159D	03/01/92	45.07
5954343371	03/04/92	02/22/95	30	152280	420	1V	5159D	03/01/92	50.36
5954343371	03/04/92	01/24/95	30	165120	432	1V	5159D	03/01/92	53.09
5954343371	03/04/92	12/22/94	30	170520	456	1V	5159D	03/01/92	51.94
5954343371	03/04/92	11/22/94	30	196920	456	1V	5159D	03/01/92	59.98
5954343371	03/04/92	10/21/94	30	194880	480	1V	5159D	03/01/92	56.39
5954343371	03/04/92	09/21/94	30	202560	480	1V	5159D	03/01/92	58.61
5954343371	03/04/92	08/22/94	30	209400	480	1V	5159D	03/01/92	60.59
5954343371	03/04/92	07/22/94	30	198960	480	1V	5159D	03/01/92	57.57
5954343371	03/04/92	06/22/94	30	199560	504	1V	5159D	03/01/92	54.99
5954343371	03/04/92	05/23/94	30	193800	468	1V	5159D	03/01/92	57.51
5954343371	03/04/92	04/22/94	30	168720	456	1V	5159D	03/01/92	51.39
5954343371	03/04/92	03/24/94	30	151800	420	1V	5159D	03/01/92	50.20
5954343371	03/04/92	02/23/94	30	157320	408	1V	5159D	03/01/92	53.55

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
5954343371	03/04/92	01/24/94	30	156000	372	1V	5159D	03/01/92	58.24
5954343371	03/04/92	12/22/93	30	165840	420	1V	5159D	03/01/92	54.84
5954343371	03/04/92	11/22/93	30	186360	480	1V	5159D	03/01/92	53.92
5954343371	03/04/92	10/21/93	30	181800	480	1V	5159D	03/01/92	52.60
5954343371	03/04/92	09/22/93	30	202200	480	1V	5159D	03/01/92	58.51
5954343371	03/04/92	08/23/93	30	214200	480	1V	5159D	03/01/92	61.98
5954343371	03/04/92	07/22/93	30	197640	480	1V	5159D	03/01/92	57.19
5954343371	03/04/92	06/22/93	30	197520	480	1V	5159D	03/01/92	57.15
5954343371	03/04/92	05/21/93	30	159600	420	1V	5159D	03/01/92	52.78
5954343371	03/04/92	04/22/93	30	153120	420	1V	5159D	03/01/92	50.63
5954343371	03/04/92	03/23/93	30	126240	360	1V	5159D	03/01/92	48.70

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>1919 NW 19 St #401, Ft Lauderdale</b>									
6058501096	03/18/03	06/16/03	32	27840	53	6V	78242	07/08/99	68.40
6058501096	03/18/03	05/15/03	29	29280	50	6V	78242	07/08/99	84.14
6058501096	03/18/03	04/16/03	29	29520	62	6V	78242	07/08/99	68.41



Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>11253 Pines Blvd, Pembroke Pines</b>									
6482592539	09/01/94	06/20/03	30	241320	509	6V	5230D	09/21/94	65.85
6482592539	09/01/94	05/21/03	29	250920	545	6V	5230D	09/21/94	66.15
6482592539	09/01/94	04/22/03	29	208080	515	6V	5230D	09/21/94	58.05
6482592539	09/01/94	03/24/03	31	246360	530	6V	5230D	09/21/94	62.48
6482592539	09/01/94	02/21/03	30	204840	520	6V	5230D	09/21/94	54.71
6482592539	09/01/94	01/22/03	35	218040	508	6V	5230D	09/21/94	51.10
6482592539	09/01/94	12/18/02	30	220200	518	6V	5230D	09/21/94	59.04
6482592539	09/01/94	11/18/02	31	248160	526	6V	5230D	09/21/94	63.41
6482592539	09/01/94	10/18/02	29	239160	512	6V	5230D	09/21/94	67.11
6482592539	09/01/94	09/19/02	30	253920	518	6V	5230D	09/21/94	68.08
6482592539	09/01/94	08/20/02	29	262680	542	6V	5230D	09/21/94	69.63
6482592539	09/01/94	07/22/02	32	260760	526	6V	5230D	09/21/94	64.55
6482592539	09/01/94	06/20/02	30	250320	540	6V	5230D	09/21/94	64.38
6482592539	09/01/94	05/21/02	29	232200	515	6V	5230D	09/21/94	64.78
6482592539	09/01/94	04/22/02	31	236160	508	6V	5230D	09/21/94	62.48
6482592539	09/01/94	03/22/02	29	196920	450	6V	5230D	09/21/94	62.87
6482592539	09/01/94	02/21/02	29	193560	353	6V	5230D	09/21/94	78.78
6482592539	09/01/94	01/23/02	35	227040	440	6V	5230D	09/21/94	61.43
6482592539	09/01/94	12/19/01	33	254760	484	6V	5230D	09/21/94	66.46
6482592539	09/01/94	11/16/01	29	214800	494	6V	5230D	09/21/94	62.47
6482592539	09/01/94	10/18/01	29	233520	505	6V	5230D	09/21/94	66.44
6482592539	09/01/94	09/19/01	30	254880	538	6V	5230D	09/21/94	65.80
6482592539	09/01/94	08/20/01	28	244080	534	6V	5230D	09/21/94	68.02
6482592539	09/01/94	07/20/01	33	277080	530	6V	5230D	09/21/94	66.01
6482592539	09/01/94	06/20/01	30	249120	532	6V	5230D	09/21/94	65.04
6482592539	09/01/94	05/21/01	31	221880	506	6V	5230D	09/21/94	58.94
6482592539	09/01/94	04/20/01	29	193440	511	6V	5230D	09/21/94	54.39
6482592539	09/01/94	03/22/01	35	258600	466	6V	5230D	09/21/94	66.06
6482592539	09/01/94	02/15/01	29	195120	455	6V	5230D	09/21/94	61.61
6482592539	09/01/94	01/17/01	34	215640	478	6V	5230D	09/21/94	55.29
6482592539	09/01/94	12/14/00	31	235440	491	6V	5230D	09/21/94	64.45
6482592539	09/01/94	11/13/00	31	236160	493	6V	5230D	09/21/94	64.39
6482592539	09/01/94	10/13/00	29	252000	530	6V	5230D	09/21/94	68.31
6482592539	09/01/94	09/14/00	30	268080	660	6V	5230D	09/21/94	56.41
6482592539	09/01/94	08/15/00	33	286800	559	6V	5230D	09/21/94	64.78
6482592539	09/01/94	07/14/00	29	235320	510	6V	5230D	09/21/94	66.29
6482592539	09/01/94	06/14/00	30	249000	510	6V	5230D	09/21/94	67.81

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
6482592539	09/01/94	05/15/00	31	234240	490	6V	5230D	09/21/94	64.25
6482592539	09/01/94	04/14/00	29	212040	466	6V	5230D	09/21/94	65.38
6482592539	09/01/94	03/16/00	30	216600	475	6V	5230D	09/21/94	63.33
6482592539	09/01/94	02/15/00	32	201360	454	6V	5230D	09/21/94	57.75
6482592539	09/01/94	01/14/00	31	213840	452	6V	5230D	09/21/94	63.59
6482592539	09/01/94	12/14/99	32	231840	466	6V	5230D	09/21/94	64.78
6482592539	09/01/94	11/12/99	29	202440	472	6V	5230D	09/21/94	61.62
6482592539	09/01/94	10/14/99	29	246960	505	6V	5230D	09/21/94	70.26
6482592539	09/01/94	09/15/99	30	258120	545	6V	5230D	09/21/94	65.78
6482592539	09/01/94	08/16/99	33	293280	547	6V	5230D	09/21/94	67.70
6482592539	09/01/94	07/15/99	29	245520	517	6V	5230D	09/21/94	68.23
6482592539	09/01/94	06/15/99	32	265080	521	6V	5230D	09/21/94	66.25
6482592539	09/01/94	05/14/99	29	229560	518	6V	5230D	09/21/94	63.67
6482592539	09/01/94	04/15/99	30	224880	497	6V	5230D	09/21/94	62.84
6482592539	09/01/94	03/16/99	29	193920	490	6V	5230D	09/21/94	56.86
6482592539	09/01/94	02/15/99	33	237480	468	6V	5230D	09/21/94	64.07
6482592539	09/01/94	01/14/99	30	203640	492	6V	5230D	09/21/94	57.49
6482592539	09/01/94	12/14/98	32	259800	504	6V	5230D	09/21/94	67.12
6482592539	09/01/94	11/12/98	30	230040	496	6V	5230D	09/21/94	64.42
6482592539	09/01/94	10/13/98	29	257280	516	6V	5230D	09/21/94	71.64
6482592539	09/01/94	09/14/98	33	293880	530	6V	5230D	09/21/94	70.01
6482592539	09/01/94	08/13/98	29	262560	534	6V	5230D	09/21/94	70.64
6482592539	09/01/94	07/15/98	29	269040	570	6V	5230D	09/21/94	67.82
6482592539	09/01/94	06/15/98	32	275280	545	6V	5230D	09/21/94	65.77
6482592539	09/01/94	05/14/98	29	228600	499	6V	5230D	09/21/94	65.82
6482592539	09/01/94	04/15/98	29	207120	473	6V	5230D	09/21/94	62.91
6482592539	09/01/94	03/17/98	29	193560	461	6V	5230D	09/21/94	60.33
6482592539	09/01/94	02/16/98	34	225480	445	6V	5230D	09/21/94	62.10
6482592539	09/01/94	01/14/98	32	230040	454	6V	5230D	09/21/94	65.98
6482592539	09/01/94	12/12/97	30	227040	469	6V	5230D	09/21/94	67.24
6482592539	09/01/94	11/12/97	30	232200	469	6V	5230D	09/21/94	68.76
6482592539	09/01/94	10/13/97	30	280680	456	6V	5230D	09/21/94	85.49
6482592539	09/01/94	09/11/97	30	244440	497	6V	5230D	09/21/94	68.31
6482592539	09/01/94	08/12/97	30	243480	476	6V	5230D	09/21/94	71.04
6482592539	09/01/94	07/14/97	30	263040	469	6V	5230D	09/21/94	77.90
6482592539	09/01/94	06/12/97	30	215760	436	6V	5230D	09/21/94	68.73
6482592539	09/01/94	05/13/97	30	207000	428	6V	5230D	09/21/94	67.17
6482592539	09/01/94	04/14/97	30	218280	436	6V	5230D	09/21/94	69.53

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
6482592539	09/01/94	03/14/97	30	205680	436	6V	5230D	09/21/94	65.52
6482592539	09/01/94	02/12/97	30	182400	426	6V	5230D	09/21/94	59.47
6482592539	09/01/94	01/13/97	30	209520	420	6V	5230D	09/21/94	69.29
6482592539	09/01/94	12/11/96	30	219720	436	6V	5230D	09/21/94	69.99
6482592539	09/01/94	11/08/96	30	219480	474	6V	5230D	09/21/94	64.31
6482592539	09/01/94	10/10/96	30	240720	516	6V	5230D	09/21/94	64.79
6482592539	09/01/94	09/11/96	30	265320	503	6V	5230D	09/21/94	73.26
6482592539	09/01/94	08/12/96	30	285600	548	6V	5230D	09/21/94	72.38
6482592539	09/01/94	07/12/96	30	254880	511	6V	5230D	09/21/94	69.28
6482592539	09/01/94	06/12/96	30	240480	475	6V	5230D	09/21/94	70.32
6482592539	09/01/94	05/13/96	30	246240	448	6V	5230D	09/21/94	76.34
6482592539	09/01/94	04/12/96	30	203040	446	6V	5230D	09/21/94	63.23
6482592539	09/01/94	03/14/96	30	195840	428	6V	5230D	09/21/94	63.55
6482592539	09/01/94	02/14/96	30	189720	414	6V	5230D	09/21/94	63.65
6482592539	09/01/94	01/16/96	30	217680	436	6V	5230D	09/21/94	69.34
6482592539	09/01/94	12/13/95	30	234120	448	6V	5230D	09/21/94	72.58
6482592539	09/01/94	11/13/95	30	232320	506	6V	5230D	09/21/94	63.77
6482592539	09/01/94	10/12/95	30	234720	484	6V	5230D	09/21/94	67.36
6482592539	09/01/94	09/13/95	30	241080	444	6V	5230D	09/21/94	75.41
6482592539	09/01/94	08/14/95	30	210120	452	6V	5230D	09/21/94	64.56
6482592539	09/01/94	07/14/95	30	240240	467	6V	5230D	09/21/94	71.45
6482592539	09/01/94	06/14/95	30	215640	475	6V	5230D	09/21/94	63.05
6482592539	09/01/94	05/15/95	30	222840	475	6V	5230D	09/21/94	65.16
6482592539	09/01/94	04/14/95	30	187440	437	6V	5230D	09/21/94	59.57
6482592539	09/01/94	03/16/95	30	176520	388	6V	5230D	09/21/94	63.19
6482592539	09/01/94	02/15/95	30	138720	372	6V	5230D	09/21/94	51.79
6482592539	09/01/94	01/17/95	30	189960	426	6V	5230D	09/21/94	61.93
6482592539	09/01/94	12/15/94	30	272400	498	6V	5230D	09/21/94	75.97
6482592539	09/01/94	11/15/94	30	217200	480	6V	5230D	09/21/94	62.85
6482592539	09/01/94	10/13/94	30	190920	480	6V	5230D	09/21/94	55.24
6482592539	09/01/94	09/14/94	13	93240	480	1V	54038	09/21/94	62.26

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>5501 N University Dr, Sunrise</b>									
6607761506	08/16/01	06/09/03	32	499920	847	6V	79174	02/27/01	76.85
6607761506	08/16/01	05/08/03	30	453120	840	6V	79174	02/27/01	74.92
6607761506	08/16/01	04/09/03	29	441600	852	6V	79174	02/27/01	74.47
6607761506	08/16/01	03/11/03	31	450960	850	6V	79174	02/27/01	71.31
6607761506	08/16/01	02/07/03	30	402240	816	6V	79174	02/27/01	68.46
6607761506	08/16/01	01/08/03	33	464160	862	6V	79174	02/27/01	67.99
6607761506	08/16/01	12/06/02	31	460080	874	6V	79174	02/27/01	70.75
6607761506	08/16/01	11/05/02	29	469920	876	6V	79174	02/27/01	77.07
6607761506	08/16/01	10/07/02	31	516720	895	6V	79174	02/27/01	77.60
6607761506	08/16/01	09/06/02	30	497280	902	6V	79174	02/27/01	76.57
6607761506	08/16/01	08/07/02	29	494160	893	6V	79174	02/27/01	79.51
6607761506	08/16/01	07/09/02	32	556320	926	6V	79174	02/27/01	78.23
6607761506	08/16/01	06/07/02	30	514080	931	6V	79174	02/27/01	76.69
6607761506	08/16/01	05/08/02	29	461040	931	6V	79174	02/27/01	71.15
6607761506	08/16/01	04/09/02	29	441360	833	6V	79174	02/27/01	76.13
6607761506	08/16/01	03/11/02	31	458640	845	6V	79174	02/27/01	72.95
6607761506	08/16/01	02/08/02	30	455760	840	6V	79174	02/27/01	75.36
6607761506	08/16/01	01/09/02	34	512640	862	6V	79174	02/27/01	72.88
6607761506	08/16/01	12/06/01	31	479040	857	6V	79174	02/27/01	75.13
6607761506	08/16/01	11/05/01	31	492000	852	6V	79174	02/27/01	77.62
6607761506	08/16/01	10/05/01	29	476400	890	6V	79174	02/27/01	76.91
6607761506	08/16/01	09/06/01	21	361920	890	6V	79174	02/27/01	80.68

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>3241 Executive Way, Miramar</b>									
6671257282	03/20/96	06/13/03	30	4327	0	5L	11549	03/20/96	-
6671257282	03/20/96	05/14/03	29	3994	0	5L	11549	03/20/96	-
6671257282	03/20/96	04/15/03	29	3478	0	5L	11549	03/20/96	-
6671257282	03/20/96	03/17/03	32	4083	0	5L	11549	03/20/96	-
6671257282	03/20/96	02/13/03	30	3056	0	5L	11549	03/20/96	-
6671257282	03/20/96	01/14/03	33	2488	0	5L	11549	03/20/96	-
6671257282	03/20/96	12/12/02	31	2720	0	5L	11549	03/20/96	-
6671257282	03/20/96	11/11/02	31	4027	0	5L	11549	03/20/96	-
6671257282	03/20/96	10/11/02	29	4844	0	5L	11549	03/20/96	-
6671257282	03/20/96	09/12/02	30	4742	0	5L	11549	03/20/96	-
6671257282	03/20/96	08/13/02	29	5366	0	5L	11549	03/20/96	-
6671257282	03/20/96	07/15/02	32	4707	0	5L	11549	03/20/96	-
6671257282	03/20/96	06/13/02	30	4325	0	5L	11549	03/20/96	-
6671257282	03/20/96	05/14/02	29	4737	0	5L	11549	03/20/96	-
6671257282	03/20/96	04/15/02	31	4022	0	5L	11549	03/20/96	-
6671257282	03/20/96	03/15/02	29	2945	0	5L	11549	03/20/96	-
6671257282	03/20/96	02/14/02	30	3420	0	5L	11549	03/20/96	-
6671257282	03/20/96	01/15/02	34	2852	0	5L	11549	03/20/96	-
6671257282	03/20/96	12/12/01	33	3145	0	5L	11549	03/20/96	-
6671257282	03/20/96	11/09/01	29	3599	0	5L	11549	03/20/96	-
6671257282	03/20/96	10/11/01	29	3871	0	5L	11549	03/20/96	-
6671257282	03/20/96	09/12/01	30	4644	0	5L	11549	03/20/96	-
6671257282	03/20/96	08/13/01	31	4094	0	5L	11549	03/20/96	-
6671257282	03/20/96	07/13/01	30	4179	0	5L	11549	03/20/96	-
6671257282	03/20/96	06/13/01	30	5120	0	5L	11549	03/20/96	-
6671257282	03/20/96	05/14/01	31	3833	0	5L	11549	03/20/96	-
6671257282	03/20/96	04/13/01	29	3160	0	5L	11549	03/20/96	-
6671257282	03/20/96	03/15/01	31	3623	0	5L	11549	03/20/96	-
6671257282	03/20/96	02/12/01	32	3830	0	5L	11549	03/20/96	-
6671257282	03/20/96	01/11/01	31	2877	0	5L	11549	03/20/96	-
6671257282	03/20/96	12/11/00	33	3802	0	5L	11549	03/20/96	-
6671257282	03/20/96	11/08/00	29	3813	0	5L	11549	03/20/96	-
6671257282	03/20/96	10/10/00	29	5160	0	5L	11549	03/20/96	-
6671257282	03/20/96	09/11/00	32	5627	0	5L	11549	03/20/96	-
6671257282	03/20/96	08/10/00	30	5456	0	5L	11549	03/20/96	-
6671257282	03/20/96	07/11/00	32	5409	0	5L	11549	03/20/96	-
6671257282	03/20/96	06/09/00	30	4815	0	5L	11549	03/20/96	-

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
6671257282	03/20/96	05/10/00	29	3846	0	5L	11549	03/20/96	-
6671257282	03/20/96	04/11/00	29	3572	0	5L	11549	03/20/96	-
6671257282	03/20/96	03/13/00	32	3588	0	5L	11549	03/20/96	-
6671257282	03/20/96	02/10/00	30	2690	0	5L	11549	03/20/96	-
6671257282	03/20/96	01/11/00	33	3251	0	5L	11549	03/20/96	-
6671257282	03/20/96	12/09/99	30	3668	0	5L	11549	03/20/96	-
6671257282	03/20/96	11/09/99	29	4107	0	5L	11549	03/20/96	-
6671257282	03/20/96	10/11/99	31	5863	0	5L	11549	03/20/96	-
6671257282	03/20/96	09/10/99	30	5041	0	5L	11549	03/20/96	-
6671257282	03/20/96	08/11/99	30	4988	0	5L	11549	03/20/96	-
6671257282	03/20/96	07/12/99	32	4671	0	5L	11549	03/20/96	-
6671257282	03/20/96	06/10/99	30	4640	0	5L	11549	03/20/96	-
6671257282	03/20/96	05/11/99	29	4120	0	5L	11549	03/20/96	-
6671257282	03/20/96	04/12/99	32	3796	0	5L	11549	03/20/96	-
6671257282	03/20/96	03/11/99	29	3404	0	5L	11549	03/20/96	-
6671257282	03/20/96	02/10/99	30	3266	0	5L	11549	03/20/96	-
6671257282	03/20/96	01/11/99	33	3510	0	5L	11549	03/20/96	-
6671257282	03/20/96	12/09/98	33	3659	0	5L	11549	03/20/96	-
6671257282	03/20/96	11/06/98	29	4491	0	5L	11549	03/20/96	-
6671257282	03/20/96	10/08/98	29	5007	0	5L	11549	03/20/96	-
6671257282	03/20/96	09/09/98	30	5445	0	5L	11549	03/20/96	-
6671257282	03/20/96	08/10/98	31	5551	0	5L	11549	03/20/96	-
6671257282	03/20/96	07/10/98	30	7276	0	5L	11549	03/20/96	-
6671257282	03/20/96	06/10/98	30	3780	0	5L	11549	03/20/96	-
6671257282	03/20/96	05/11/98	31	3751	0	5L	11549	03/20/96	-
6671257282	03/20/96	04/10/98	29	3387	0	5L	11549	03/20/96	-
6671257282	03/20/96	03/12/98	30	2993	0	5L	11549	03/20/96	-
6671257282	03/20/96	02/10/98	31	3434	0	5L	11549	03/20/96	-
6671257282	03/20/96	01/10/98	33	3179	0	5L	11549	03/20/96	-
6671257282	03/20/96	12/09/97	30	3262	0	5L	11549	03/20/96	-
6671257282	03/20/96	11/06/97	30	4005	0	5L	11549	03/20/96	-
6671257282	03/20/96	10/08/97	30	3932	0	5L	11549	03/20/96	-
6671257282	03/20/96	09/08/97	30	4237	0	5L	11549	03/20/96	-
6671257282	03/20/96	08/07/97	30	4013	0	5L	11549	03/20/96	-
6671257282	03/20/96	07/09/97	30	4087	0	5L	11549	03/20/96	-
6671257282	03/20/96	06/09/97	30	3882	0	5L	11549	03/20/96	-
6671257282	03/20/96	05/08/97	30	3637	0	5L	11549	03/20/96	-
6671257282	03/20/96	04/09/97	30	3071	0	5L	11549	03/20/96	-

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
6671257282	03/20/96	03/11/97	30	3705	0	5L	11549	03/20/96	-
6671257282	03/20/96	02/07/97	30	3069	0	5L	11549	03/20/96	-
6671257282	03/20/96	01/08/97	30	1195	0	5L	11549	03/20/96	-
6671257282	03/20/96	12/06/96	30	4247	0	5L	11549	03/20/96	-
6671257282	03/20/96	11/05/96	30	40102	0	5L	11549	03/20/96	-
6671257282	03/20/96	10/07/96	30	36129	0	5L	11549	03/20/96	-
6671257282	03/20/96	09/06/96	30	31873	0	5L	11549	03/20/96	-
6671257282	03/20/96	08/07/96	30	27152	0	5L	11549	03/20/96	-
6671257282	03/20/96	07/09/96	30	23045	0	5L	11549	03/20/96	-
6671257282	03/20/96	06/07/96	30	18514	0	5L	11549	03/20/96	-
6671257282	03/20/96	05/08/96	30	14266	0	5L	11549	03/20/96	-
6671257282	03/20/96	04/09/96	19	10716	0	5L	11549	03/20/96	-

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>1440 US Highway 1 S #LS, Saint Augustine</b>									
6982415231	02/01/02	06/17/03	32	26	0	6J	88590	01/23/02	-
6982415231	02/01/02	05/16/03	29	19	0	6J	88590	01/23/02	-
6982415231	02/01/02	04/17/03	29	20	0	6J	88590	01/23/02	-
6982415231	02/01/02	03/19/03	29	26	0	6J	88590	01/23/02	-
6982415231	02/01/02	02/18/03	33	59	0	6J	88590	01/23/02	-
6982415231	02/01/02	01/16/03	33	103	0	6J	88590	01/23/02	-
6982415231	02/01/02	12/14/02	31	24	0	6J	88590	01/23/02	-
6982415231	02/01/02	11/13/02	29	19	0	6J	88590	01/23/02	-
6982415231	02/01/02	10/15/02	29	17	0	6J	88590	01/23/02	-
6982415231	02/01/02	09/16/02	32	19	0	6J	88590	01/23/02	-
6982415231	02/01/02	08/15/02	29	22	0	6J	88590	01/23/02	-
6982415231	02/01/02	07/17/02	30	23	0	6J	88590	01/23/02	-
6982415231	02/01/02	06/17/02	32	49	0	6J	88590	01/23/02	-
6982415231	02/01/02	05/16/02	29	79	0	6J	88590	01/23/02	-
6982415231	02/01/02	04/17/02	29	69	0	6J	88590	01/23/02	-
6982415231	02/01/02	03/19/02	29	206	0	6J	88590	01/23/02	-
6982415231	02/01/02	02/18/02	17	16	0	6J	88590	01/23/02	-



Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>1901 S Congress Ave STE 210, Boynton Beach</b>									
7226615370	04/08/99	06/16/03	32	4263	0	5E	53995	04/08/99	-
7226615370	04/08/99	05/15/03	30	3933	0	5E	53995	04/08/99	-
7226615370	04/08/99	04/16/03	28	2965	0	5E	53995	04/08/99	-
7226615370	04/08/99	03/18/03	29	3509	0	5E	53995	04/08/99	-
7226615370	04/08/99	02/17/03	33	2763	0	5E	53995	04/08/99	-
7226615370	04/08/99	01/15/03	34	2526	0	5E	53995	04/08/99	-
7226615370	04/08/99	12/13/02	30	3066	0	5E	53995	04/08/99	-
7226615370	04/08/99	11/12/02	29	4062	0	5E	53995	04/08/99	-
7226615370	04/08/99	10/14/02	32	4853	0	5E	53995	04/08/99	-
7226615370	04/08/99	09/13/02	30	4636	0	5E	53995	04/08/99	-
7226615370	04/08/99	08/14/02	28	4159	0	5E	53995	04/08/99	-
7226615370	04/08/99	07/16/02	32	3781	0	5E	53995	04/08/99	-
7226615370	04/08/99	06/14/02	30	3928	0	5E	53995	04/08/99	-
7226615370	04/08/99	05/15/02	29	3909	0	5E	53995	04/08/99	-
7226615370	04/08/99	04/16/02	29	3697	0	5E	53995	04/08/99	-
7226615370	04/08/99	03/18/02	32	3398	0	5E	53995	04/08/99	-
7226615370	04/08/99	02/15/02	30	3124	0	5E	53995	04/08/99	-
7226615370	04/08/99	01/16/02	34	2647	0	5E	53995	04/08/99	-
7226615370	04/08/99	12/13/01	30	3353	0	5E	53995	04/08/99	-
7226615370	04/08/99	11/12/01	31	3919	0	5E	53995	04/08/99	-
7226615370	04/08/99	10/12/01	30	3975	0	5E	53995	04/08/99	-
7226615370	04/08/99	09/13/01	30	4259	0	5E	53995	04/08/99	-
7226615370	04/08/99	08/14/01	30	3971	0	5E	53995	04/08/99	-
7226615370	04/08/99	07/16/01	30	4145	0	5E	53995	04/08/99	-
7226615370	04/08/99	06/14/01	31	4118	0	5E	53995	04/08/99	-
7226615370	04/08/99	05/15/01	28	3000	0	5E	53995	04/08/99	-
7226615370	04/08/99	04/16/01	31	3602	0	5E	53995	04/08/99	-
7226615370	04/08/99	03/16/01	29	3532	0	5E	53995	04/08/99	-
7226615370	04/08/99	02/15/01	29	2913	0	5E	53995	04/08/99	-
7226615370	04/08/99	01/17/01	35	3169	0	5E	53995	04/08/99	-
7226615370	04/08/99	12/14/00	32	3215	0	5E	53995	04/08/99	-
7226615370	04/08/99	11/13/00	30	3417	0	5E	53995	04/08/99	-
7226615370	04/08/99	10/13/00	28	3897	0	5E	53995	04/08/99	-
7226615370	04/08/99	09/14/00	30	4205	0	5E	53995	04/08/99	-
7226615370	04/08/99	08/15/00	32	4475	0	5E	53995	04/08/99	-
7226615370	04/08/99	07/14/00	30	4688	0	5E	53995	04/08/99	-
7226615370	04/08/99	06/14/00	30	5004	0	5E	53995	04/08/99	-

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
7226615370	04/08/99	05/15/00	31	4250	0	5E	53995	04/08/99	-
7226615370	04/08/99	04/14/00	29	3910	0	5E	53995	04/08/99	-
7226615370	04/08/99	03/16/00	30	3546	0	5E	53995	04/08/99	-
7226615370	04/08/99	02/15/00	32	2926	0	5E	53995	04/08/99	-
7226615370	04/08/99	01/14/00	31	3075	0	5E	53995	04/08/99	-
7226615370	04/08/99	12/14/99	32	3484	0	5E	53995	04/08/99	-
7226615370	04/08/99	11/12/99	30	3898	0	5E	53995	04/08/99	-
7226615370	04/08/99	10/14/99	28	4216	0	5E	53995	04/08/99	-
7226615370	04/08/99	09/15/99	32	4403	0	5E	53995	04/08/99	-
7226615370	04/08/99	08/16/99	30	4831	0	5E	53995	04/08/99	-
7226615370	04/08/99	07/15/99	30	4260	0	5E	53995	04/08/99	-
7226615370	04/08/99	06/15/99	32	4553	0	5E	53995	04/08/99	-
7226615370	04/08/99	05/14/99	29	3960	0	5E	53995	04/08/99	-
7226615370	04/08/99	04/15/99	7	936	0	5E	53995	04/08/99	-

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>250 Crockett Blvd, Merritt Island</b>									
7744750584	06/26/96	06/09/03	32	241560	511	6V	5468D	09/20/96	61.55
7744750584	06/26/96	05/08/03	29	196920	467	6V	5468D	09/20/96	60.58
7744750584	06/26/96	04/09/03	29	192600	464	6V	5468D	09/20/96	59.64
7744750584	06/26/96	03/11/03	32	197640	446	6V	5468D	09/20/96	57.70
7744750584	06/26/96	02/07/03	30	165120	388	6V	5468D	09/20/96	59.11
7744750584	06/26/96	01/08/03	33	189480	431	6V	5468D	09/20/96	55.51
7744750584	06/26/96	12/06/02	31	199800	484	6V	5468D	09/20/96	55.49
7744750584	06/26/96	11/05/02	29	216240	492	6V	5468D	09/20/96	63.15
7744750584	06/26/96	10/07/02	31	251520	492	6V	5468D	09/20/96	68.71
7744750584	06/26/96	09/06/02	30	239040	493	6V	5468D	09/20/96	67.34
7744750584	06/26/96	08/07/02	29	242040	509	6V	5468D	09/20/96	68.32
7744750584	06/26/96	07/09/02	32	234240	497	6V	5468D	09/20/96	61.37
7744750584	06/26/96	06/07/02	30	225720	504	6V	5468D	09/20/96	62.20
7744750584	06/26/96	05/08/02	29	209400	500	6V	5468D	09/20/96	60.17
7744750584	06/26/96	04/09/02	29	192840	473	6V	5468D	09/20/96	58.58
7744750584	06/26/96	03/11/02	31	180120	436	6V	5468D	09/20/96	55.53
7744750584	06/26/96	02/08/02	30	185400	450	6V	5468D	09/20/96	57.22
7744750584	06/26/96	01/09/02	34	206520	457	6V	5468D	09/20/96	55.38
7744750584	06/26/96	12/06/01	31	204600	449	6V	5468D	09/20/96	61.25
7744750584	06/26/96	11/05/01	31	221640	490	6V	5468D	09/20/96	60.80
7744750584	06/26/96	10/05/01	29	202680	493	6V	5468D	09/20/96	59.07
7744750584	06/26/96	09/06/01	31	232200	475	6V	5468D	09/20/96	65.70
7744750584	06/26/96	08/07/01	28	215040	508	6V	5468D	09/20/96	62.99
7744750584	06/26/96	07/09/01	32	249000	532	6V	5468D	09/20/96	60.94
7744750584	06/26/96	06/07/01	30	225360	533	6V	5468D	09/20/96	58.72
7744750584	06/26/96	05/08/01	29	193560	506	6V	5468D	09/20/96	54.96
7744750584	06/26/96	04/09/01	31	191760	500	6V	5468D	09/20/96	51.55
7744750584	06/26/96	03/09/01	29	188040	485	6V	5468D	09/20/96	55.71
7744750584	06/26/96	02/08/01	30	163080	462	6V	5468D	09/20/96	49.03
7744750584	06/26/96	01/09/01	33	188400	498	6V	5468D	09/20/96	47.77
7744750584	06/26/96	12/07/00	31	191760	499	6V	5468D	09/20/96	51.65
7744750584	06/26/96	11/06/00	31	209640	514	6V	5468D	09/20/96	54.82
7744750584	06/26/96	10/06/00	29	227040	547	6V	5468D	09/20/96	59.64
7744750584	06/26/96	09/07/00	30	237240	588	6V	5468D	09/20/96	56.04
7744750584	06/26/96	08/08/00	32	249240	588	6V	5468D	09/20/96	55.19
7744750584	06/26/96	07/07/00	30	242160	553	6V	5468D	09/20/96	60.82
7744750584	06/26/96	06/07/00	30	225000	552	6V	5468D	09/20/96	56.61

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
7744750584	06/26/96	05/08/00	31	198960	487	6V	5468D	09/20/96	54.91
7744750584	06/26/96	04/07/00	29	182040	485	6V	5468D	09/20/96	53.93
7744750584	06/26/96	03/09/00	30	179160	456	6V	5468D	09/20/96	54.57
7744750584	06/26/96	02/08/00	31	172200	470	6V	5468D	09/20/96	49.25
7744750584	06/26/96	01/08/00	32	198360	479	6V	5468D	09/20/96	53.92
7744750584	06/26/96	12/07/99	32	216120	482	6V	5468D	09/20/96	58.38
7744750584	06/26/96	11/05/99	29	219360	527	6V	5468D	09/20/96	59.81
7744750584	06/26/96	10/07/99	29	229920	562	6V	5468D	09/20/96	58.78
7744750584	06/26/96	09/08/99	30	243720	571	6V	5468D	09/20/96	59.28
7744750584	06/26/96	08/09/99	32	265680	528	6V	5468D	09/20/96	65.52
7744750584	06/26/96	07/08/99	30	241080	517	6V	5468D	09/20/96	64.76
7744750584	06/26/96	06/08/99	32	256440	546	6V	5468D	09/20/96	61.15
7744750584	06/26/96	05/07/99	29	199680	541	6V	5468D	09/20/96	53.03
7744750584	06/26/96	04/08/99	30	184560	527	6V	5468D	09/20/96	48.64
7744750584	06/26/96	03/09/99	29	162360	500	6V	5468D	09/20/96	46.66
7744750584	06/26/96	02/08/99	31	188520	491	6V	5468D	09/20/96	51.61
7744750584	06/26/96	01/08/99	32	197520	538	6V	5468D	09/20/96	47.80
7744750584	06/26/96	12/07/98	33	236520	498	6V	5468D	09/20/96	59.97
7744750584	06/26/96	11/04/98	29	226080	526	6V	5468D	09/20/96	61.75
7744750584	06/26/96	10/06/98	32	262560	533	6V	5468D	09/20/96	64.14
7744750584	06/26/96	09/04/98	29	241560	554	6V	5468D	09/20/96	62.65
7744750584	06/26/96	08/06/98	29	241800	546	6V	5468D	09/20/96	63.63
7744750584	06/26/96	07/08/98	30	252000	546	6V	5468D	09/20/96	64.10
7744750584	06/26/96	06/08/98	32	247920	598	6V	5468D	09/20/96	53.98
7744750584	06/26/96	05/07/98	29	176880	473	6V	5468D	09/20/96	53.73
7744750584	06/26/96	04/08/98	29	183720	498	6V	5468D	09/20/96	53.01
7744750584	06/26/96	03/10/98	32	180120	497	6V	5468D	09/20/96	47.19
7744750584	06/26/96	02/06/98	29	166920	518	6V	5468D	09/20/96	46.30
7744750584	06/26/96	01/08/98	34	201000	538	6V	5468D	09/20/96	45.79
7744750584	06/26/96	12/05/97	30	194400	545	6V	5468D	09/20/96	49.54
7744750584	06/26/96	11/04/97	30	197280	546	6V	5468D	09/20/96	50.18
7744750584	06/26/96	10/06/97	30	232920	534	6V	5468D	09/20/96	60.58
7744750584	06/26/96	09/04/97	30	230400	569	6V	5468D	09/20/96	56.24
7744750584	06/26/96	08/05/97	30	225480	548	6V	5468D	09/20/96	57.15
7744750584	06/26/96	07/07/97	30	234960	517	6V	5468D	09/20/96	63.12
7744750584	06/26/96	06/05/97	30	211200	502	6V	5468D	09/20/96	58.43
7744750584	06/26/96	05/06/97	30	190440	542	6V	5468D	09/20/96	48.80
7744750584	06/26/96	04/07/97	30	210840	538	6V	5468D	09/20/96	54.43

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
7744750584	06/26/96	03/07/97	30	207240	508	6V	5468D	09/20/96	56.66
7744750584	06/26/96	02/05/97	30	189600	508	6V	5468D	09/20/96	51.84
7744750584	06/26/96	01/06/97	30	222000	427	6V	5468D	09/20/96	72.21
7744750584	06/26/96	12/04/96	30	225240	470	6V	5468D	09/20/96	66.56
7744750584	06/26/96	11/01/96	30	242640	557	6V	5468D	09/20/96	60.50
7744750584	06/26/96	10/03/96	30	127800	546	6V	5468D	09/20/96	32.51
7744750584	06/26/96	09/04/96	30	-	-	1V	59691	08/28/96	-
7744750584	06/26/96	08/05/96	30	-	-	6V	55990	06/26/96	-
7744750584	06/26/96	07/05/96	9	-	-	6V	55990	06/26/96	-

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>1440 US Highway 1 S, Saint Augustine</b>									
8615368035	02/01/02	06/17/03	32	220800	458	6V	79406	10/26/01	62.77
8615368035	02/01/02	05/16/03	29	188880	458	6V	79406	10/26/01	59.25
8615368035	02/01/02	04/17/03	29	172800	444	6V	79406	10/26/01	55.92
8615368035	02/01/02	03/19/03	29	162960	413	6V	79406	10/26/01	56.69
8615368035	02/01/02	02/18/03	33	186240	485	6V	79406	10/26/01	48.48
8615368035	02/01/02	01/16/03	33	182880	410	6V	79406	10/26/01	56.32
8615368035	02/01/02	12/14/02	31	170400	386	6V	79406	10/26/01	59.33
8615368035	02/01/02	11/13/02	29	181200	437	6V	79406	10/26/01	59.58
8615368035	02/01/02	10/15/02	29	206160	533	6V	79406	10/26/01	55.57
8615368035	02/01/02	09/16/02	32	228240	545	6V	79406	10/26/01	54.53
8615368035	02/01/02	08/15/02	29	205200	528	6V	79406	10/26/01	55.84
8615368035	02/01/02	07/17/02	30	209520	470	6V	79406	10/26/01	61.91
8615368035	02/01/02	06/17/02	32	218400	466	6V	79406	10/26/01	61.02
8615368035	02/01/02	05/16/02	29	194640	444	6V	79406	10/26/01	62.99
8615368035	02/01/02	04/17/02	29	175680	420	6V	79406	10/26/01	60.10
8615368035	02/01/02	03/19/02	29	158640	410	6V	79406	10/26/01	55.59
8615368035	02/01/02	02/18/02	17	81840	346	6V	79406	10/26/01	57.97

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>4752 NE 11 Ave #MN, Ft Lauderdale</b>									
9342942183	03/27/89	06/09/03	32	978	0	5C	87757	06/01/69	-
9342942183	03/27/89	05/08/03	29	891	0	5C	87757	06/01/69	-
9342942183	03/27/89	04/09/03	29	746	0	5C	87757	06/01/69	-
9342942183	03/27/89	03/11/03	32	880	0	5C	87757	06/01/69	-
9342942183	03/27/89	02/07/03	30	675	0	5C	87757	06/01/69	-
9342942183	03/27/89	01/08/03	33	873	0	5C	87757	06/01/69	-
9342942183	03/27/89	12/06/02	31	828	0	5C	87757	06/01/69	-
9342942183	03/27/89	11/05/02	29	1005	0	5C	87757	06/01/69	-
9342942183	03/27/89	10/07/02	31	1035	0	5C	87757	06/01/69	-
9342942183	03/27/89	09/06/02	30	915	0	5C	87757	06/01/69	-
9342942183	03/27/89	08/07/02	29	787	0	5C	87757	06/01/69	-
9342942183	03/27/89	07/09/02	32	1064	0	5C	87757	06/01/69	-
9342942183	03/27/89	06/07/02	30	835	0	5C	87757	06/01/69	-
9342942183	03/27/89	05/08/02	29	874	0	5C	87757	06/01/69	-
9342942183	03/27/89	04/09/02	29	737	0	5C	87757	06/01/69	-
9342942183	03/27/89	03/11/02	31	760	0	5C	87757	06/01/69	-
9342942183	03/27/89	02/08/02	30	832	0	5C	87757	06/01/69	-
9342942183	03/27/89	01/09/02	34	798	0	5C	87757	06/01/69	-
9342942183	03/27/89	12/06/01	31	829	0	5C	87757	06/01/69	-
9342942183	03/27/89	11/05/01	32	989	0	5C	87757	06/01/69	-
9342942183	03/27/89	10/05/01	28	1015	0	5C	87757	06/01/69	-
9342942183	03/27/89	09/06/01	30	1232	0	5C	87757	06/01/69	-
9342942183	03/27/89	08/07/01	29	949	0	5C	87757	06/01/69	-
9342942183	03/27/89	07/09/01	32	1230	0	5C	87757	06/01/69	-
9342942183	03/27/89	06/07/01	30	956	0	5C	87757	06/01/69	-
9342942183	03/27/89	05/08/01	29	826	0	5C	87757	06/01/69	-
9342942183	03/27/89	04/09/01	31	821	0	5C	87757	06/01/69	-
9342942183	03/27/89	03/09/01	29	749	0	5C	87757	06/01/69	-
9342942183	03/27/89	02/08/01	30	644	0	5C	87757	06/01/69	-
9342942183	03/27/89	01/09/01	33	946	0	5C	87757	06/01/69	-
9342942183	03/27/89	12/07/00	34	1268	0	5C	87757	06/01/69	-
9342942183	03/27/89	11/03/00	29	1140	0	5C	87757	06/01/69	-
9342942183	03/27/89	10/05/00	29	1190	0	5C	87757	06/01/69	-
9342942183	03/27/89	09/06/00	30	1294	0	5C	87757	06/01/69	-
9342942183	03/27/89	08/07/00	32	1186	0	5C	87757	06/01/69	-
9342942183	03/27/89	07/06/00	30	1251	0	5C	87757	06/01/69	-
9342942183	03/27/89	06/06/00	32	1578	0	5C	87757	06/01/69	-

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
9342942183	03/27/89	05/05/00	29	1205	0	5C	87757	06/01/69	-
9342942183	03/27/89	04/06/00	29	1468	0	5C	87757	06/01/69	-
9342942183	03/27/89	03/08/00	30	1189	0	5C	87757	06/01/69	-
9342942183	03/27/89	02/07/00	31	1063	0	5C	87757	06/01/69	-
9342942183	03/27/89	01/07/00	32	1060	0	5C	87757	06/01/69	-
9342942183	03/27/89	12/06/99	32	1662	0	5C	87757	06/01/69	-
9342942183	03/27/89	11/04/99	29	1483	0	5C	87757	06/01/69	-
9342942183	03/27/89	10/06/99	29	1476	0	5C	87757	06/01/69	-
9342942183	03/27/89	09/07/99	33	1668	0	5C	87757	06/01/69	-
9342942183	03/27/89	08/05/99	29	1785	0	5C	87757	06/01/69	-
9342942183	03/27/89	07/07/99	30	1363	0	5C	87757	06/01/69	-
9342942183	03/27/89	06/07/99	32	1537	0	5C	87757	06/01/69	-
9342942183	03/27/89	05/06/99	29	1029	0	5C	87757	06/01/69	-
9342942183	03/27/89	04/07/99	30	1024	0	5C	87757	06/01/69	-
9342942183	03/27/89	03/08/99	31	758	0	5C	87757	06/01/69	-
9342942183	03/27/89	02/05/99	29	1039	0	5C	87757	06/01/69	-
9342942183	03/27/89	01/07/99	34	2108	0	5C	87757	06/01/69	-
9342942183	03/27/89	12/04/98	31	2531	0	5C	87757	06/01/69	-
9342942183	03/27/89	11/03/98	29	1877	0	5C	87757	06/01/69	-
9342942183	03/27/89	10/05/98	32	1538	0	5C	87757	06/01/69	-
9342942183	03/27/89	09/03/98	29	1426	0	5C	87757	06/01/69	-
9342942183	03/27/89	08/05/98	29	1682	0	5C	87757	06/01/69	-
9342942183	03/27/89	07/07/98	32	1344	0	5C	87757	06/01/69	-
9342942183	03/27/89	06/05/98	30	1084	0	5C	87757	06/01/69	-
9342942183	03/27/89	05/06/98	29	1102	0	5C	87757	06/01/69	-
9342942183	03/27/89	04/07/98	29	978	0	5C	87757	06/01/69	-
9342942183	03/27/89	03/09/98	32	870	0	5C	87757	06/01/69	-
9342942183	03/27/89	02/05/98	29	675	0	5C	87757	06/01/69	-
9342942183	03/27/89	01/07/98	34	1024	0	5C	87757	06/01/69	-
9342942183	03/27/89	12/04/97	30	1224	0	5C	87757	06/01/69	-
9342942183	03/27/89	11/03/97	30	1202	0	5C	87757	06/01/69	-
9342942183	03/27/89	10/03/97	30	1361	0	5C	87757	06/01/69	-
9342942183	03/27/89	09/03/97	30	1376	0	5C	87757	06/01/69	-
9342942183	03/27/89	08/04/97	30	1603	0	5C	87757	06/01/69	-
9342942183	03/27/89	07/03/97	30	1177	0	5C	87757	06/01/69	-
9342942183	03/27/89	06/04/97	30	1315	0	5C	87757	06/01/69	-
9342942183	03/27/89	05/05/97	30	1116	0	5C	87757	06/01/69	-
9342942183	03/27/89	04/04/97	30	870	0	5C	87757	06/01/69	-



Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
9342942183	03/27/89	03/06/97	30	934	0	5C	87757	06/01/69	-
9342942183	03/27/89	02/04/97	30	843	0	5C	87757	06/01/69	-
9342942183	03/27/89	01/03/97	30	976	0	5C	87757	06/01/69	-
9342942183	03/27/89	12/03/96	30	1089	0	5C	87757	06/01/69	-
9342942183	03/27/89	10/31/96	30	1128	0	5C	87757	06/01/69	-
9342942183	03/27/89	10/02/96	30	1102	0	5C	87757	06/01/69	-
9342942183	03/27/89	09/03/96	30	1493	0	5C	87757	06/01/69	-
9342942183	03/27/89	08/02/96	30	1731	0	5C	87757	06/01/69	-
9342942183	03/27/89	07/03/96	30	1162	0	5C	87757	06/01/69	-
9342942183	03/27/89	06/04/96	30	1545	0	5C	87757	06/01/69	-
9342942183	03/27/89	05/03/96	30	840	0	5C	87757	06/01/69	-
9342942183	03/27/89	04/04/96	30	833	0	5C	87757	06/01/69	-
9342942183	03/27/89	03/06/96	30	698	0	5C	87757	06/01/69	-
9342942183	03/27/89	02/06/96	30	908	0	5C	87757	06/01/69	-
9342942183	03/27/89	01/06/96	30	704	0	5C	87757	06/01/69	-
9342942183	03/27/89	12/05/95	30	1259	0	5C	87757	06/01/69	-
9342942183	03/27/89	11/02/95	30	1238	0	5C	87757	06/01/69	-
9342942183	03/27/89	10/04/95	30	709	0	5C	87757	06/01/69	-
9342942183	03/27/89	09/05/95	20	751	0	5C	87757	06/01/69	-
9342942183	03/27/89	08/15/95	30	903	0	5C	87757	06/01/69	-
9342942183	03/27/89	07/17/95	30	919	0	5C	87757	06/01/69	-
9342942183	03/27/89	06/15/95	30	760	0	5C	87757	06/01/69	-
9342942183	03/27/89	05/16/95	30	811	0	5C	87757	06/01/69	-
9342942183	03/27/89	04/17/95	30	699	0	5C	87757	06/01/69	-
9342942183	03/27/89	03/17/95	30	472	0	5C	87757	06/01/69	-
9342942183	03/27/89	02/16/95	30	455	0	5C	87757	06/01/69	-
9342942183	03/27/89	01/18/95	30	394	0	5C	87757	06/01/69	-
9342942183	03/27/89	12/16/94	30	1130	0	5C	87757	06/01/69	-
9342942183	03/27/89	11/16/94	30	1034	0	5C	87757	06/01/69	-
9342942183	03/27/89	10/17/94	30	603	0	5C	87757	06/01/69	-
9342942183	03/27/89	09/15/94	30	514	0	5C	87757	06/01/69	-
9342942183	03/27/89	08/16/94	30	761	0	5C	87757	06/01/69	-
9342942183	03/27/89	07/18/94	30	703	0	5C	87757	06/01/69	-
9342942183	03/27/89	06/16/94	30	640	0	5C	87757	06/01/69	-
9342942183	03/27/89	05/17/94	30	965	0	5C	87757	06/01/69	-
9342942183	03/27/89	04/18/94	30	372	0	5C	87757	06/01/69	-
9342942183	03/27/89	03/18/94	30	390	0	5C	87757	06/01/69	-
9342942183	03/27/89	02/16/94	30	325	0	5C	87757	06/01/69	-

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
9342942183	03/27/89	01/18/94	30	336	0	5C	87757	06/01/69	-
9342942183	03/27/89	12/16/93	30	752	0	5C	87757	06/01/69	-
9342942183	03/27/89	11/16/93	30	655	0	5C	87757	06/01/69	-
9342942183	03/27/89	10/15/93	30	565	0	5C	87757	06/01/69	-
9342942183	03/27/89	09/16/93	30	511	0	5C	87757	06/01/69	-
9342942183	03/27/89	08/17/93	30	779	0	5C	87757	06/01/69	-
9342942183	03/27/89	07/16/93	30	545	0	5C	87757	06/01/69	-
9342942183	03/27/89	06/16/93	30	454	0	5C	87757	06/01/69	-
9342942183	03/27/89	05/17/93	30	172	0	5C	87757	06/01/69	-
9342942183	03/27/89	04/16/93	30	540	0	5C	87757	06/01/69	-
9342942183	03/27/89	03/17/93	30	263	0	5C	87757	06/01/69	-

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>2380 W Intl Speedway Blvd, Daytona Beach</b>									
9591801916	11/13/91	07/01/03	29	204240	478	6V	7543D	11/09/02	61.39
9591801916	11/13/91	06/02/03	32	221280	473	6V	7543D	11/09/02	60.91
9591801916	11/13/91	05/01/03	29	168000	430	6V	7543D	11/09/02	56.13
9591801916	11/13/91	04/02/03	29	160560	461	6V	7543D	11/09/02	50.04
9591801916	11/13/91	03/04/03	32	166800	403	6V	7543D	11/09/02	53.89
9591801916	11/13/91	01/31/03	31	143040	343	6V	7543D	11/09/02	56.05
9591801916	11/13/91	12/31/02	34	170640	374	6V	7543D	11/09/02	55.91
9591801916	11/13/91	11/27/02	29	165840	444	6V	7543D	11/09/02	53.67
9591801916	11/13/91	10/29/02	29	195600	456	1V	7505D	03/12/93	61.63
9591801916	11/13/91	09/30/02	32	236640	480	1V	7505D	03/12/93	64.19
9591801916	11/13/91	08/29/02	29	209760	504	1V	7505D	03/12/93	59.80
9591801916	11/13/91	07/31/02	30	218160	504	1V	7505D	03/12/93	60.12
9591801916	11/13/91	07/01/02	31	213840	504	1V	7505D	03/12/93	57.03
9591801916	11/13/91	05/31/02	30	203280	480	1V	7505D	03/12/93	58.82
9591801916	11/13/91	05/01/02	29	191040	480	1V	7505D	03/12/93	57.18
9591801916	11/13/91	04/02/02	29	168240	408	1V	7505D	03/12/93	59.25
9591801916	11/13/91	03/04/02	31	158880	480	1V	7505D	03/12/93	44.49
9591801916	11/13/91	02/01/02	30	158400	480	1V	7505D	03/12/93	45.83
9591801916	11/13/91	01/02/02	34	204960	480	1V	7505D	03/12/93	52.33
9591801916	11/13/91	11/29/01	31	189600	480	1V	7505D	03/12/93	53.09
9591801916	11/13/91	10/29/01	31	198480	480	1V	7505D	03/12/93	55.58
9591801916	11/13/91	09/28/01	30	218400	480	1V	7505D	03/12/93	63.19
9591801916	11/13/91	08/29/01	29	221040	480	1V	7505D	03/12/93	66.16
9591801916	11/13/91	07/31/01	32	244080	504	1V	7505D	03/12/93	63.06
9591801916	11/13/91	06/29/01	29	216960	528	1V	7505D	03/12/93	59.04
9591801916	11/13/91	05/31/01	30	204240	504	1V	7505D	03/12/93	56.28
9591801916	11/13/91	05/01/01	29	181200	480	1V	7505D	03/12/93	54.24
9591801916	11/13/91	04/02/01	31	170160	480	1V	7505D	03/12/93	47.65
9591801916	11/13/91	03/02/01	29	161520	480	1V	7505D	03/12/93	48.35
9591801916	11/13/91	02/01/01	29	171120	456	1V	7505D	03/12/93	53.92
9591801916	11/13/91	01/03/01	34	176400	360	1V	7505D	03/12/93	60.05
9591801916	11/13/91	11/30/00	31	161520	504	1V	7505D	03/12/93	43.07
9591801916	11/13/91	10/30/00	31	200640	480	1V	7505D	03/12/93	56.18
9591801916	11/13/91	09/29/00	30	210480	480	1V	7505D	03/12/93	60.90
9591801916	11/13/91	08/30/00	30	212880	504	1V	7505D	03/12/93	58.66
9591801916	11/13/91	07/31/00	32	227520	504	1V	7505D	03/12/93	58.78
9591801916	11/13/91	06/29/00	29	205440	504	1V	7505D	03/12/93	58.57

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
9591801916	11/13/91	05/31/00	30	198240	528	1V	7505D	03/12/93	52.15
9591801916	11/13/91	05/01/00	31	197040	480	1V	7505D	03/12/93	55.17
9591801916	11/13/91	03/31/00	29	165840	456	1V	7505D	03/12/93	52.25
9591801916	11/13/91	03/02/00	30	146160	456	1V	7505D	03/12/93	44.52
9591801916	11/13/91	02/01/00	29	137280	480	1V	7505D	03/12/93	41.09
9591801916	11/13/91	01/03/00	33	162960	480	1V	7505D	03/12/93	42.87
9591801916	11/13/91	12/01/99	33	179040	480	1V	7505D	03/12/93	47.10
9591801916	11/13/91	10/29/99	29	175920	480	1V	7505D	03/12/93	52.66
9591801916	11/13/91	09/30/99	30	203040	480	1V	7505D	03/12/93	58.75
9591801916	11/13/91	08/31/99	32	246000	528	1V	7505D	03/12/93	60.67
9591801916	11/13/91	07/30/99	30	228480	528	1V	7505D	03/12/93	60.10
9591801916	11/13/91	06/30/99	29	193440	504	1V	7505D	03/12/93	55.15
9591801916	11/13/91	06/01/99	32	193440	504	1V	7505D	03/12/93	49.98
9591801916	11/13/91	04/30/99	30	176880	480	1V	7505D	03/12/93	51.18
9591801916	11/13/91	03/31/99	29	135600	384	1V	7505D	03/12/93	50.74
9591801916	11/13/91	03/02/99	29	141120	432	1V	7505D	03/12/93	46.93
9591801916	11/13/91	02/01/99	32	152400	432	1V	7505D	03/12/93	45.93
9591801916	11/13/91	12/31/98	31	167280	432	1V	7505D	03/12/93	52.05
9591801916	11/13/91	11/30/98	33	190320	456	1V	7505D	03/12/93	52.70
9591801916	11/13/91	10/28/98	29	183360	480	1V	7505D	03/12/93	54.89
9591801916	11/13/91	09/29/98	32	219840	480	1V	7505D	03/12/93	59.64
9591801916	11/13/91	08/28/98	29	210480	528	1V	7505D	03/12/93	57.28
9591801916	11/13/91	07/30/98	30	246960	552	1V	7505D	03/12/93	62.14
9591801916	11/13/91	06/30/98	29	188640	487	1V	7505D	03/12/93	55.65
9591801916	11/13/91	06/01/98	32	207120	480	1V	7505D	03/12/93	56.18
9591801916	11/13/91	04/30/98	29	169200	456	1V	7505D	03/12/93	53.31
9591801916	11/13/91	04/01/98	29	147600	432	1V	7505D	03/12/93	49.09
9591801916	11/13/91	03/03/98	32	155040	456	1V	7505D	03/12/93	44.27
9591801916	11/13/91	01/30/98	30	142800	456	1V	7505D	03/12/93	43.49
9591801916	11/13/91	12/31/97	33	168000	456	1V	7505D	03/12/93	46.52
9591801916	11/13/91	11/28/97	30	156960	408	1V	7505D	03/12/93	53.43
9591801916	11/13/91	10/28/97	30	193440	480	1V	7505D	03/12/93	55.97
9591801916	11/13/91	09/26/97	30	195600	480	1V	7505D	03/12/93	56.60
9591801916	11/13/91	08/27/97	30	198480	480	1V	7505D	03/12/93	57.43
9591801916	11/13/91	07/29/97	30	217680	504	1V	7505D	03/12/93	59.99
9591801916	11/13/91	06/27/97	30	180480	480	1V	7505D	03/12/93	52.22
9591801916	11/13/91	05/29/97	30	167280	432	1V	7505D	03/12/93	53.78
9591801916	11/13/91	04/29/97	30	147600	408	1V	7505D	03/12/93	50.25

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
9591801916	11/13/91	03/31/97	30	156720	408	1V	7505D	03/12/93	53.35
9591801916	11/13/91	02/28/97	30	141600	384	1V	7505D	03/12/93	51.22
9591801916	11/13/91	01/29/97	30	143040	384	1V	7505D	03/12/93	51.74
9591801916	11/13/91	12/28/96	30	150240	384	1V	7505D	03/12/93	54.34
9591801916	11/13/91	11/26/96	30	168720	456	1V	7505D	03/12/93	51.39
9591801916	11/13/91	10/25/96	30	169200	480	1V	7505D	03/12/93	48.96
9591801916	11/13/91	09/26/96	30	205920	504	1V	7505D	03/12/93	56.75
9591801916	11/13/91	08/27/96	30	206400	504	1V	7505D	03/12/93	56.88
9591801916	11/13/91	07/29/96	30	229920	552	1V	7505D	03/12/93	57.85
9591801916	11/13/91	06/27/96	30	202800	528	1V	7505D	03/12/93	53.35
9591801916	11/13/91	05/29/96	30	186000	528	1V	7505D	03/12/93	48.93
9591801916	11/13/91	04/29/96	30	169440	456	1V	7505D	03/12/93	51.61
9591801916	11/13/91	03/29/96	30	147840	432	1V	7505D	03/12/93	47.53
9591801916	11/13/91	02/29/96	30	145680	432	1V	7505D	03/12/93	46.84
9591801916	11/13/91	01/31/96	30	136320	384	1V	7505D	03/12/93	49.31
9591801916	11/13/91	01/02/96	30	178320	384	1V	7505D	03/12/93	64.50
9591801916	11/13/91	11/29/95	30	182400	432	1V	7505D	03/12/93	58.64
9591801916	11/13/91	10/27/95	30	192960	432	1V	7505D	03/12/93	62.04
9591801916	11/13/91	09/28/95	30	191520	432	1V	7505D	03/12/93	61.57
9591801916	11/13/91	08/29/95	30	201360	480	1V	7505D	03/12/93	58.26
9591801916	11/13/91	07/31/95	30	217680	480	1V	7505D	03/12/93	62.99
9591801916	11/13/91	06/29/95	30	189120	480	1V	7505D	03/12/93	54.72
9591801916	11/13/91	05/31/95	30	191760	480	1V	7505D	03/12/93	55.49
9591801916	11/13/91	05/01/95	30	170400	374	1V	7505D	03/12/93	63.28
9591801916	11/13/91	03/31/95	30	145920	408	1V	7505D	03/12/93	49.67
9591801916	11/13/91	03/02/95	30	133920	384	1V	7505D	03/12/93	48.44
9591801916	11/13/91	02/01/95	30	126960	360	1V	7505D	03/12/93	48.98
9591801916	11/13/91	01/03/95	30	170640	432	1V	7505D	03/12/93	54.86
9591801916	11/13/91	12/01/94	30	175920	456	1V	7505D	03/12/93	53.58
9591801916	11/13/91	10/31/94	30	190320	480	1V	7505D	03/12/93	55.07
9591801916	11/13/91	09/29/94	30	187200	480	1V	7505D	03/12/93	54.17
9591801916	11/13/91	08/30/94	30	188400	552	1V	7505D	03/12/93	47.40
9591801916	11/13/91	08/01/94	30	209280	552	1V	7505D	03/12/93	52.66
9591801916	11/13/91	06/30/94	30	184560	480	1V	7505D	03/12/93	53.40
9591801916	11/13/91	06/01/94	30	172560	456	1V	7505D	03/12/93	52.56
9591801916	11/13/91	05/02/94	30	164400	456	1V	7505D	03/12/93	50.07
9591801916	11/13/91	04/01/94	30	145920	456	1V	7505D	03/12/93	44.44
9591801916	11/13/91	03/03/94	30	138480	408	1V	7505D	03/12/93	47.14

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
9591801916	11/13/91	02/01/94	30	122160	360	1V	7505D	03/12/93	47.13
9591801916	11/13/91	01/03/94	30	144960	360	1V	7505D	03/12/93	55.93
9591801916	11/13/91	12/01/93	30	158160	528	1V	7505D	03/12/93	41.60
9591801916	11/13/91	10/29/93	30	161760	528	1V	7505D	03/12/93	42.55
9591801916	11/13/91	09/30/93	30	201120	528	1V	7505D	03/12/93	52.90
9591801916	11/13/91	08/31/93	30	221760	528	1V	7505D	03/12/93	58.33
9591801916	11/13/91	07/30/93	30	209280	528	1V	7505D	03/12/93	55.05
9591801916	11/13/91	06/30/93	30	191760	552	1V	7505D	03/12/93	48.25
9591801916	11/13/91	06/01/93	30	181680	444	1V	7505D	03/12/93	56.83
9591801916	11/13/91	04/30/93	30	142320	480	1V	7505D	03/12/93	41.18
9591801916	11/13/91	04/01/93	30	141120	480	1V	7505D	03/12/93	40.83
9591801916	11/13/91	03/02/93	30	141360	353	1V	7505D	03/12/93	55.62

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>2324 Pine Ridge Rd, Naples</b>									
9642810569	03/18/94	06/04/03	30	212880	469	6V	5901D	01/02/03	63.04
9642810569	03/18/94	05/05/03	31	193440	451	6V	5901D	01/02/03	57.65
9642810569	03/18/94	04/04/03	29	179760	430	6V	5901D	01/02/03	60.06
9642810569	03/18/94	03/06/03	30	174120	427	6V	5901D	01/02/03	56.64
9642810569	03/18/94	02/04/03	32	150120	332	6V	5901D	01/02/03	58.88
9642810569	03/18/94	01/03/03	31	165600	384	6V	5901D	01/02/03	57.96
9642810569	03/18/94	12/03/02	33	188640	384	1V	5679D	03/18/94	62.03
9642810569	03/18/94	10/31/02	29	192720	384	1V	5679D	03/18/94	72.11
9642810569	03/18/94	10/02/02	29	195840	384	1V	5679D	03/18/94	73.28
9642810569	03/18/94	09/03/02	32	218280	396	1V	5679D	03/18/94	71.77
9642810569	03/18/94	08/02/02	30	211320	384	1V	5679D	03/18/94	76.43
9642810569	03/18/94	07/03/02	29	204720	384	1V	5679D	03/18/94	76.60
9642810569	03/18/94	06/04/02	32	217920	480	1V	5679D	03/18/94	59.11
9642810569	03/18/94	05/03/02	29	197400	384	1V	5679D	03/18/94	73.86
9642810569	03/18/94	04/04/02	29	190440	372	1V	5679D	03/18/94	73.55
9642810569	03/18/94	03/06/02	29	171360	372	1V	5679D	03/18/94	66.18
9642810569	03/18/94	02/05/02	32	190800	384	1V	5679D	03/18/94	64.70
9642810569	03/18/94	01/04/02	32	199320	384	1V	5679D	03/18/94	67.59
9642810569	03/18/94	12/03/01	33	207480	384	1V	5679D	03/18/94	68.22
9642810569	03/18/94	10/31/01	29	195360	384	1V	5679D	03/18/94	73.10
9642810569	03/18/94	10/02/01	32	217440	384	1V	5679D	03/18/94	73.73
9642810569	03/18/94	08/31/01	29	214440	384	1V	5679D	03/18/94	80.24
9642810569	03/18/94	08/02/01	30	213720	372	1V	5679D	03/18/94	79.79
9642810569	03/18/94	07/03/01	29	205080	372	1V	5679D	03/18/94	79.21
9642810569	03/18/94	06/04/01	32	210480	372	1V	5679D	03/18/94	73.67
9642810569	03/18/94	05/03/01	29	178680	384	1V	5679D	03/18/94	66.86
9642810569	03/18/94	04/04/01	29	173040	372	1V	5679D	03/18/94	66.83
9642810569	03/18/94	03/06/01	29	173400	372	1V	5679D	03/18/94	66.97
9642810569	03/18/94	02/05/01	31	162000	372	1V	5679D	03/18/94	58.53
9642810569	03/18/94	01/05/01	32	174480	372	1V	5679D	03/18/94	61.07
9642810569	03/18/94	12/04/00	33	207000	372	1V	5679D	03/18/94	70.26
9642810569	03/18/94	11/01/00	30	187440	372	1V	5679D	03/18/94	69.98
9642810569	03/18/94	10/03/00	31	223800	372	1V	5679D	03/18/94	80.86
9642810569	03/18/94	09/01/00	30	212040	384	1V	5679D	03/18/94	76.69
9642810569	03/18/94	08/02/00	30	219480	372	1V	5679D	03/18/94	81.94
9642810569	03/18/94	07/03/00	31	215640	372	1V	5679D	03/18/94	77.91
9642810569	03/18/94	06/02/00	31	211560	384	1V	5679D	03/18/94	74.05

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
9642810569	03/18/94	05/03/00	28	169560	372	1V	5679D	03/18/94	67.83
9642810569	03/18/94	04/04/00	31	193080	372	1V	5679D	03/18/94	69.76
9642810569	03/18/94	03/06/00	30	170040	372	1V	5679D	03/18/94	63.49
9642810569	03/18/94	02/03/00	29	160680	372	1V	5679D	03/18/94	62.06
9642810569	03/18/94	01/05/00	33	196800	372	1V	5679D	03/18/94	66.80
9642810569	03/18/94	12/03/99	31	187560	372	1V	5679D	03/18/94	67.77
9642810569	03/18/94	11/02/99	31	210600	384	1V	5679D	03/18/94	73.71
9642810569	03/18/94	10/04/99	30	215520	384	1V	5679D	03/18/94	77.95
9642810569	03/18/94	09/02/99	31	228120	384	1V	5679D	03/18/94	79.85
9642810569	03/18/94	08/03/99	31	226800	372	1V	5679D	03/18/94	81.95
9642810569	03/18/94	07/02/99	29	197520	384	1V	5679D	03/18/94	73.90
9642810569	03/18/94	06/03/99	30	198240	408	1V	5679D	03/18/94	67.48
9642810569	03/18/94	05/04/99	31	188400	384	1V	5679D	03/18/94	65.94
9642810569	03/18/94	04/05/99	30	163560	384	1V	5679D	03/18/94	59.16
9642810569	03/18/94	03/04/99	29	145440	372	1V	5679D	03/18/94	56.17
9642810569	03/18/94	02/03/99	29	148560	360	1V	5679D	03/18/94	59.29
9642810569	03/18/94	01/05/99	34	185880	372	1V	5679D	03/18/94	61.23
9642810569	03/18/94	12/02/98	33	186960	372	1V	5679D	03/18/94	63.46
9642810569	03/18/94	10/30/98	29	193440	372	1V	5679D	03/18/94	74.71
9642810569	03/18/94	10/01/98	30	186360	372	1V	5679D	03/18/94	69.58
9642810569	03/18/94	09/01/98	29	195480	432	1V	5679D	03/18/94	65.01
9642810569	03/18/94	08/03/98	32	208680	384	1V	5679D	03/18/94	70.76
9642810569	03/18/94	07/02/98	29	194760	384	1V	5679D	03/18/94	72.87
9642810569	03/18/94	06/03/98	32	198120	396	1V	5679D	03/18/94	65.14
9642810569	03/18/94	05/04/98	29	157800	396	1V	5679D	03/18/94	57.25
9642810569	03/18/94	04/03/98	29	166080	384	1V	5679D	03/18/94	62.14
9642810569	03/18/94	03/05/98	30	171240	384	1V	5679D	03/18/94	61.94
9642810569	03/18/94	02/03/98	29	170400	384	1V	5679D	03/18/94	63.76
9642810569	03/18/94	01/05/98	34	205440	384	1V	5679D	03/18/94	65.56
9642810569	03/18/94	12/02/97	30	210480	384	1V	5679D	03/18/94	76.13
9642810569	03/18/94	10/30/97	30	208200	408	1V	5679D	03/18/94	70.87
9642810569	03/18/94	09/30/97	30	221160	408	1V	5679D	03/18/94	75.29
9642810569	03/18/94	08/29/97	30	222000	408	1V	5679D	03/18/94	75.57
9642810569	03/18/94	07/31/97	30	206400	408	1V	5679D	03/18/94	70.26
9642810569	03/18/94	07/01/97	30	211080	468	1V	5679D	03/18/94	62.64
9642810569	03/18/94	06/02/97	30	222840	456	1V	5679D	03/18/94	67.87
9642810569	03/18/94	05/01/97	30	190920	456	1V	5679D	03/18/94	58.15
9642810569	03/18/94	04/02/97	30	190680	456	1V	5679D	03/18/94	58.08
9642810569	03/18/94	03/04/97	30	202200	420	1V	5679D	03/18/94	66.87
9642810569	03/18/94	01/31/97	30	173040	468	1V	5679D	03/18/94	51.35
9642810569	03/18/94	12/31/96	30	183240	420	1V	5679D	03/18/94	60.60



Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
9642810569	03/18/94	11/29/96	30	183000	456	1V	5679D	03/18/94	55.74
9642810569	03/18/94	10/29/96	30	180960	456	1V	5679D	03/18/94	55.12
9642810569	03/18/94	09/30/96	30	223800	468	1V	5679D	03/18/94	66.42
9642810569	03/18/94	08/29/96	30	194160	444	1V	5679D	03/18/94	60.74
9642810569	03/18/94	07/31/96	30	192360	456	1V	5679D	03/18/94	58.59
9642810569	03/18/94	07/01/96	30	202560	456	1V	5679D	03/18/94	61.70
9642810569	03/18/94	05/31/96	30	189480	456	1V	5679D	03/18/94	57.71
9642810569	03/18/94	05/01/96	30	164520	444	1V	5679D	03/18/94	51.46
9642810569	03/18/94	04/02/96	30	158280	396	1V	5679D	03/18/94	55.51
9642810569	03/18/94	03/04/96	30	160080	372	1V	5679D	03/18/94	59.77
9642810569	03/18/94	02/02/96	30	148920	372	1V	5679D	03/18/94	55.60
9642810569	03/18/94	01/04/96	30	181800	396	1V	5679D	03/18/94	63.76
9642810569	03/18/94	12/01/95	30	177000	420	1V	5679D	03/18/94	58.53
9642810569	03/18/94	10/31/95	30	196200	432	1V	5679D	03/18/94	63.08
9642810569	03/18/94	10/02/95	30	228600	432	1V	5679D	03/18/94	73.50
9642810569	03/18/94	08/31/95	30	220080	432	1V	5679D	03/18/94	70.76
9642810569	03/18/94	08/02/95	30	213240	420	1V	5679D	03/18/94	70.52
9642810569	03/18/94	07/03/95	30	190080	420	1V	5679D	03/18/94	62.86
9642810569	03/18/94	06/02/95	30	203280	432	1V	5679D	03/18/94	65.35
9642810569	03/18/94	05/03/95	30	181080	408	1V	5679D	03/18/94	61.64
9642810569	03/18/94	04/04/95	30	170040	384	1V	5679D	03/18/94	61.50
9642810569	03/18/94	03/06/95	30	150000	372	1V	5679D	03/18/94	56.00
9642810569	03/18/94	02/03/95	30	139080	372	1V	5679D	03/18/94	51.93
9642810569	03/18/94	01/05/95	30	166800	408	1V	5679D	03/18/94	56.78
9642810569	03/18/94	12/05/94	30	203520	408	1V	5679D	03/18/94	69.28
9642810569	03/18/94	11/02/94	30	199560	432	1V	5679D	03/18/94	64.16
9642810569	03/18/94	10/03/94	30	188880	420	1V	5679D	03/18/94	62.46
9642810569	03/18/94	09/01/94	30	187680	420	1V	5679D	03/18/94	62.06
9642810569	03/18/94	08/03/94	30	190200	396	1V	5679D	03/18/94	66.71
9642810569	03/18/94	07/05/94	30	188760	396	1V	5679D	03/18/94	66.20
9642810569	03/18/94	06/03/94	16	77280	330	1V	5679D	03/18/94	60.98
9642810569	03/18/94	05/17/94	30	112560	312	1V	5679D	03/18/94	50.11
9642810569	03/18/94	04/18/94	30	115440	420	1V	5679D	03/18/94	38.17

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
9779751222	06/09/03	06/26/03	17	293760	542	6V	70031	06/06/03	132.84

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>20500 SW 112 Ave, Miami</b>									
207722216	09/03/97	06/12/03	30	231120	524	6V	57703	08/26/97	61.26
207722216	09/03/97	05/13/03	29	206400	488	6V	57703	08/26/97	60.77
207722216	09/03/97	04/14/03	31	217200	510	6V	57703	08/26/97	57.24
207722216	09/03/97	03/14/03	30	217320	509	6V	57703	08/26/97	59.30
207722216	09/03/97	02/12/03	30	181920	424	6V	57703	08/26/97	59.59
207722216	09/03/97	01/13/03	33	208920	451	6V	57703	08/26/97	58.49
207722216	09/03/97	12/11/02	33	222840	490	6V	57703	08/26/97	57.42
207722216	09/03/97	11/08/02	29	223560	500	6V	57703	08/26/97	64.24
207722216	09/03/97	10/10/02	29	230280	506	6V	57703	08/26/97	65.39
207722216	09/03/97	09/11/02	30	245400	516	6V	57703	08/26/97	66.05
207722216	09/03/97	08/12/02	31	240120	487	6V	57703	08/26/97	66.27
207722216	09/03/97	07/12/02	30	212880	466	6V	57703	08/26/97	63.45
207722216	09/03/97	06/12/02	30	213840	452	6V	57703	08/26/97	65.71
207722216	09/03/97	05/13/02	31	220800	461	6V	57703	08/26/97	64.38
207722216	09/03/97	04/12/02	29	194760	445	6V	57703	08/26/97	62.88
207722216	09/03/97	03/14/02	29	176400	433	6V	57703	08/26/97	58.53
207722216	09/03/97	02/13/02	30	188400	420	6V	57703	08/26/97	62.30
207722216	09/03/97	01/14/02	34	205680	460	6V	57703	08/26/97	54.80
207722216	09/03/97	12/11/01	33	223200	458	6V	57703	08/26/97	61.53
207722216	09/03/97	11/08/01	29	205200	472	6V	57703	08/26/97	62.46
207722216	09/03/97	10/10/01	29	216120	486	6V	57703	08/26/97	63.89
207722216	09/03/97	09/11/01	32	258480	376	6V	57703	08/26/97	89.51
207722216	09/03/97	08/10/01	29	221040	516	6V	57703	08/26/97	61.55
207722216	09/03/97	07/12/01	30	227520	494	6V	57703	08/26/97	63.97
207722216	09/03/97	06/12/01	32	234600	494	6V	57703	08/26/97	61.84
207722216	09/03/97	05/11/01	29	185400	472	6V	57703	08/26/97	56.44
207722216	09/03/97	04/12/01	29	191280	499	6V	57703	08/26/97	55.08
207722216	09/03/97	03/14/01	29	187800	499	6V	57703	08/26/97	54.07
207722216	09/03/97	02/13/01	32	193680	416	6V	57703	08/26/97	60.62
207722216	09/03/97	01/12/01	31	175800	521	6V	57703	08/26/97	45.35
207722216	09/03/97	12/12/00	33	211680	449	6V	57703	08/26/97	59.53
207722216	09/03/97	11/09/00	29	202320	440	6V	57703	08/26/97	66.07
207722216	09/03/97	10/11/00	29	232080	487	6V	57703	08/26/97	68.47
207722216	09/03/97	09/12/00	32	278520	536	6V	57703	08/26/97	67.66
207722216	09/03/97	08/11/00	30	274200	539	6V	57703	08/26/97	70.66
207722216	09/03/97	07/12/00	30	240240	521	6V	57703	08/26/97	64.04
207722216	09/03/97	06/12/00	32	238800	487	6V	57703	08/26/97	63.85

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
207722216	09/03/97	05/11/00	29	186000	461	6V	57703	08/26/97	57.97
207722216	09/03/97	04/12/00	29	184080	491	6V	57703	08/26/97	53.87
207722216	09/03/97	03/14/00	32	190560	463	6V	57703	08/26/97	53.59
207722216	09/03/97	02/11/00	30	162840	385	6V	57703	08/26/97	58.74
207722216	09/03/97	01/12/00	33	190680	413	6V	57703	08/26/97	58.29
207722216	09/03/97	12/10/99	30	179520	491	6V	57703	08/26/97	50.78
207722216	09/03/97	11/10/99	29	200280	491	6V	57703	08/26/97	58.61
207722216	09/03/97	10/12/99	29	250200	529	6V	57703	08/26/97	67.96
207722216	09/03/97	09/13/99	32	289440	548	6V	57703	08/26/97	68.77
207722216	09/03/97	08/12/99	30	260760	530	6V	57703	08/26/97	68.33
207722216	09/03/97	07/13/99	32	241800	528	6V	57703	08/26/97	59.63
207722216	09/03/97	06/11/99	30	213600	499	6V	57703	08/26/97	59.45
207722216	09/03/97	05/12/99	29	199440	472	6V	57703	08/26/97	60.71
207722216	09/03/97	04/13/99	32	195000	467	6V	57703	08/26/97	54.37
207722216	09/03/97	03/12/99	29	174840	438	6V	57703	08/26/97	57.35
207722216	09/03/97	02/11/99	30	197760	438	6V	57703	08/26/97	62.71
207722216	09/03/97	01/12/99	33	201000	541	6V	57703	08/26/97	46.91
207722216	09/03/97	12/10/98	31	210240	541	6V	57703	08/26/97	52.23
207722216	09/03/97	11/09/98	31	216240	541	6V	57703	08/26/97	53.72
207722216	09/03/97	10/09/98	29	248880	541	6V	57703	08/26/97	66.10
207722216	09/03/97	09/10/98	30	257280	526	6V	57703	08/26/97	67.93
207722216	09/03/97	08/11/98	29	237840	512	6V	57703	08/26/97	66.74
207722216	09/03/97	07/13/98	32	260040	540	6V	57703	08/26/97	62.70
207722216	09/03/97	06/11/98	30	220440	623	6V	57703	08/26/97	49.14
207722216	09/03/97	05/12/98	29	187440	484	6V	57703	08/26/97	55.64
207722216	09/03/97	04/13/98	31	184440	469	6V	57703	08/26/97	52.86
207722216	09/03/97	03/13/98	30	189600	470	6V	57703	08/26/97	56.03
207722216	09/03/97	02/11/98	30	168840	437	6V	57703	08/26/97	53.66
207722216	09/03/97	01/12/98	33	225720	486	6V	57703	08/26/97	58.64
207722216	09/03/97	12/10/97	30	178200	475	6V	57703	08/26/97	52.11
207722216	09/03/97	11/14/97	30	210600	480	6V	57703	08/26/97	60.94
207722216	09/03/97	10/15/97	30	211440	455	6V	57703	08/26/97	64.54
207722216	09/03/97	09/15/97	12	84840	455	6V	57703	08/26/97	64.74

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>7795 SW 40 St, Miami</b>									
242753184	05/09/95	06/05/03	30	249600	514	6V	7236D	05/09/95	67.44
242753184	05/09/95	05/06/03	29	208800	514	6V	7236D	05/09/95	58.37
242753184	05/09/95	04/07/03	31	230640	514	6V	7236D	05/09/95	60.31
242753184	05/09/95	03/07/03	30	212160	516	6V	7236D	05/09/95	57.11
242753184	05/09/95	02/05/03	30	167280	516	6V	7236D	05/09/95	45.03
242753184	05/09/95	01/06/03	33	217440	516	6V	7236D	05/09/95	53.21
242753184	05/09/95	12/04/02	33	229200	502	6V	7236D	05/09/95	57.65
242753184	05/09/95	11/01/02	29	243360	502	6V	7236D	05/09/95	69.65
242753184	05/09/95	10/03/02	29	256320	530	6V	7236D	05/09/95	69.49
242753184	05/09/95	09/04/02	30	263040	521	6V	7236D	05/09/95	70.12
242753184	05/09/95	08/05/02	31	278160	511	6V	7236D	05/09/95	73.16
242753184	05/09/95	07/05/02	30	238800	485	6V	7236D	05/09/95	68.38
242753184	05/09/95	06/05/02	30	243360	446	6V	7236D	05/09/95	75.78
242753184	05/09/95	05/06/02	31	217200	446	6V	7236D	05/09/95	65.46
242753184	05/09/95	04/05/02	29	216480	449	6V	7236D	05/09/95	69.27
242753184	05/09/95	03/07/02	29	208560	410	6V	7236D	05/09/95	73.09
242753184	05/09/95	02/06/02	30	227040	418	6V	7236D	05/09/95	75.44
242753184	05/09/95	01/07/02	34	264240	454	6V	7236D	05/09/95	71.33
242753184	05/09/95	12/04/01	33	253920	444	6V	7236D	05/09/95	72.21
242753184	05/09/95	11/01/01	29	253200	480	6V	7236D	05/09/95	75.79
242753184	05/09/95	10/03/01	29	258480	487	6V	7236D	05/09/95	76.26
242753184	05/09/95	09/04/01	32	314880	499	6V	7236D	05/09/95	82.16
242753184	05/09/95	08/03/01	29	242640	492	6V	7236D	05/09/95	70.86
242753184	05/09/95	07/05/01	30	242400	504	6V	7236D	05/09/95	66.80
242753184	05/09/95	06/05/01	32	235200	466	6V	7236D	05/09/95	65.72
242753184	05/09/95	05/04/01	29	193920	466	6V	7236D	05/09/95	59.79
242753184	05/09/95	04/05/01	29	187920	434	6V	7236D	05/09/95	62.21
242753184	05/09/95	03/07/01	29	189120	456	6V	7236D	05/09/95	59.59
242753184	05/09/95	02/06/01	31	186240	406	6V	7236D	05/09/95	61.66
242753184	05/09/95	01/06/01	32	214080	444	6V	7236D	05/09/95	62.78
242753184	05/09/95	12/05/00	33	225600	403	6V	7236D	05/09/95	70.68
242753184	05/09/95	11/02/00	29	210960	427	6V	7236D	05/09/95	70.98
242753184	05/09/95	10/04/00	29	225120	475	6V	7236D	05/09/95	68.09
242753184	05/09/95	09/05/00	33	272400	437	6V	7236D	05/09/95	78.70
242753184	05/09/95	08/03/00	29	229680	478	6V	7236D	05/09/95	69.04
242753184	05/09/95	07/05/00	30	242400	466	6V	7236D	05/09/95	72.25
242753184	05/09/95	06/05/00	32	240240	439	6V	7236D	05/09/95	71.26

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
242753184	05/09/95	05/04/00	29	192960	442	6V	7236D	05/09/95	62.72
242753184	05/09/95	04/05/00	29	196800	442	6V	7236D	05/09/95	63.97
242753184	05/09/95	03/07/00	32	195120	422	6V	7236D	05/09/95	60.20
242753184	05/09/95	02/04/00	29	177600	406	6V	7236D	05/09/95	62.85
242753184	05/09/95	01/06/00	33	216960	451	6V	7236D	05/09/95	60.74
242753184	05/09/95	12/04/99	31	205680	451	6V	7236D	05/09/95	61.30
242753184	05/09/95	11/03/99	29	207840	494	6V	7236D	05/09/95	60.45
242753184	05/09/95	10/05/99	32	249840	490	6V	7236D	05/09/95	66.39
242753184	05/09/95	09/03/99	30	189360	475	6V	7236D	05/09/95	55.37
242753184	05/09/95	08/04/99	29	231840	487	6V	7236D	05/09/95	68.40
242753184	05/09/95	07/06/99	32	236880	463	6V	7236D	05/09/95	66.62
242753184	05/09/95	06/04/99	30	221520	456	6V	7236D	05/09/95	67.47
242753184	05/09/95	05/05/99	29	196800	487	6V	7236D	05/09/95	58.06
242753184	05/09/95	04/06/99	32	189840	454	6V	7236D	05/09/95	54.45
242753184	05/09/95	03/05/99	29	162960	413	6V	7236D	05/09/95	56.69
242753184	05/09/95	02/04/99	29	170400	439	6V	7236D	05/09/95	55.77
242753184	05/09/95	01/06/99	34	217440	470	6V	7236D	05/09/95	56.70
242753184	05/09/95	12/03/98	31	213600	487	6V	7236D	05/09/95	58.95
242753184	05/09/95	11/02/98	31	228240	461	6V	7236D	05/09/95	66.55
242753184	05/09/95	10/02/98	30	245280	497	6V	7236D	05/09/95	68.54
242753184	05/09/95	09/02/98	29	257280	514	6V	7236D	05/09/95	71.92
242753184	05/09/95	08/04/98	29	255360	499	6V	7236D	05/09/95	73.53
242753184	05/09/95	07/06/98	32	277440	521	6V	7236D	05/09/95	69.34
242753184	05/09/95	06/04/98	30	250080	509	6V	7236D	05/09/95	68.24
242753184	05/09/95	05/05/98	29	201360	504	6V	7236D	05/09/95	57.40
242753184	05/09/95	04/06/98	31	203280	485	6V	7236D	05/09/95	56.34
242753184	05/09/95	03/06/98	30	188640	463	6V	7236D	05/09/95	56.59
242753184	05/09/95	02/04/98	29	198240	439	6V	7236D	05/09/95	64.88
242753184	05/09/95	01/06/98	34	228480	478	6V	7236D	05/09/95	58.58
242753184	05/09/95	12/03/97	30	243600	458	6V	7236D	05/09/95	73.87
242753184	05/09/95	10/31/97	30	223680	482	6V	7236D	05/09/95	64.45
242753184	05/09/95	10/02/97	30	244320	480	6V	7236D	05/09/95	70.69
242753184	05/09/95	09/02/97	30	256800	490	6V	7236D	05/09/95	72.79
242753184	05/09/95	08/01/97	30	234480	480	6V	7236D	05/09/95	67.85
242753184	05/09/95	07/02/97	30	224640	494	6V	7236D	05/09/95	63.16
242753184	05/09/95	06/03/97	30	227280	504	6V	7236D	05/09/95	62.63
242753184	05/09/95	05/02/97	30	193680	468	6V	7236D	05/09/95	57.48
242753184	05/09/95	04/03/97	30	186720	466	6V	7236D	05/09/95	55.65

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
242753184	05/09/95	03/05/97	30	198480	449	6V	7236D	05/09/95	61.40
242753184	05/09/95	02/03/97	30	186480	420	6V	7236D	05/09/95	61.67
242753184	05/09/95	01/02/97	30	197280	468	6V	7236D	05/09/95	58.55
242753184	05/09/95	12/02/96	30	217920	470	6V	7236D	05/09/95	64.40
242753184	05/09/95	10/30/96	30	216000	478	6V	7236D	05/09/95	62.76
242753184	05/09/95	10/01/96	30	280320	506	6V	7236D	05/09/95	76.94
242753184	05/09/95	08/30/96	30	243840	490	6V	7236D	05/09/95	69.12
242753184	05/09/95	08/01/96	30	266160	492	6V	7236D	05/09/95	75.14
242753184	05/09/95	07/02/96	30	248160	511	6V	7236D	05/09/95	67.45
242753184	05/09/95	06/03/96	30	247680	499	6V	7236D	05/09/95	68.94
242753184	05/09/95	05/02/96	30	196080	497	6V	7236D	05/09/95	54.80
242753184	05/09/95	04/03/96	30	177600	480	6V	7236D	05/09/95	51.39
242753184	05/09/95	03/05/96	30	166320	437	6V	7236D	05/09/95	52.86
242753184	05/09/95	02/05/96	30	188880	432	6V	7236D	05/09/95	60.73
242753184	05/09/95	01/05/96	30	200400	434	6V	7236D	05/09/95	64.13
242753184	05/09/95	12/04/95	30	215760	449	6V	7236D	05/09/95	66.74
242753184	05/09/95	11/01/95	30	228240	499	6V	7236D	05/09/95	63.53
242753184	05/09/95	10/03/95	30	282480	535	6V	7236D	05/09/95	73.33
242753184	05/09/95	09/01/95	30	258480	535	6V	7236D	05/09/95	67.10
242753184	05/09/95	08/03/95	30	250320	538	6V	7236D	05/09/95	64.62
242753184	05/09/95	07/05/95	30	219600	473	6V	7236D	05/09/95	64.48
242753184	05/09/95	06/05/95	27	197760	473	6V	7236D	05/09/95	64.52

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>21637 State Road 7, Boca Raton</b>									
287311708	06/20/91	06/27/03	28	229560	482	6V	5895D	11/06/02	70.87
287311708	06/20/91	05/29/03	30	239400	500	6V	5895D	11/06/02	66.50
287311708	06/20/91	04/29/03	29	222480	431	6V	5895D	11/06/02	74.17
287311708	06/20/91	03/31/03	31	242640	446	6V	5895D	11/06/02	73.12
287311708	06/20/91	02/28/03	31	209040	468	6V	5895D	11/06/02	60.04
287311708	06/20/91	01/29/03	32	189600	408	6V	5895D	11/06/02	60.51
287311708	06/20/91	12/27/02	32	222960	416	6V	5895D	11/06/02	69.79
287311708	06/20/91	11/25/02	31	226920	492	6V	5895D	11/06/02	61.99
287311708	06/20/91	10/25/02	29	239400	540	1V	5885D	06/01/91	63.70
287311708	06/20/91	09/26/02	30	256440	540	1V	5885D	06/01/91	65.96
287311708	06/20/91	08/27/02	29	259440	564	1V	5885D	06/01/91	66.09
287311708	06/20/91	07/29/02	32	275040	540	1V	5885D	06/01/91	66.32
287311708	06/20/91	06/27/02	29	229680	540	1V	5885D	06/01/91	61.11
287311708	06/20/91	05/29/02	30	222120	480	1V	5885D	06/01/91	64.27
287311708	06/20/91	04/29/02	31	214080	480	1V	5885D	06/01/91	59.95
287311708	06/20/91	03/29/02	29	209880	480	1V	5885D	06/01/91	62.82
287311708	06/20/91	02/28/02	29	193680	480	1V	5885D	06/01/91	57.97
287311708	06/20/91	01/30/02	33	216720	480	1V	5885D	06/01/91	57.01
287311708	06/20/91	12/28/01	31	223440	480	1V	5885D	06/01/91	62.57
287311708	06/20/91	11/27/01	33	235920	480	1V	5885D	06/01/91	62.06
287311708	06/20/91	10/25/01	29	223080	480	1V	5885D	06/01/91	66.77
287311708	06/20/91	09/26/01	30	248880	516	1V	5885D	06/01/91	66.99
287311708	06/20/91	08/27/01	31	285000	540	1V	5885D	06/01/91	70.94
287311708	06/20/91	07/27/01	31	272280	504	1V	5885D	06/01/91	72.61
287311708	06/20/91	06/27/01	28	239760	540	1V	5885D	06/01/91	66.07
287311708	06/20/91	05/29/01	32	242400	480	1V	5885D	06/01/91	65.76
287311708	06/20/91	04/27/01	29	213240	480	1V	5885D	06/01/91	63.83
287311708	06/20/91	03/29/01	29	201360	456	1V	5885D	06/01/91	63.45
287311708	06/20/91	02/28/01	29	199080	444	1V	5885D	06/01/91	64.42
287311708	06/20/91	01/30/01	32	183120	468	1V	5885D	06/01/91	50.95
287311708	06/20/91	12/29/00	31	206640	468	1V	5885D	06/01/91	59.35
287311708	06/20/91	11/28/00	33	223560	444	1V	5885D	06/01/91	63.57
287311708	06/20/91	10/26/00	29	239400	492	1V	5885D	06/01/91	69.91
287311708	06/20/91	09/27/00	30	270240	528	1V	5885D	06/01/91	71.09
287311708	06/20/91	08/28/00	32	285720	528	1V	5885D	06/01/91	70.46
287311708	06/20/91	07/27/00	30	246480	480	1V	5885D	06/01/91	71.32
287311708	06/20/91	06/27/00	32	255000	504	1V	5885D	06/01/91	65.88



Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
287311708	06/20/91	05/26/00	29	213840	504	1V	5885D	06/01/91	60.96
287311708	06/20/91	04/27/00	29	202680	480	1V	5885D	06/01/91	60.67
287311708	06/20/91	03/29/00	29	196800	468	1V	5885D	06/01/91	60.42
287311708	06/20/91	02/29/00	33	217200	456	1V	5885D	06/01/91	60.14
287311708	06/20/91	01/28/00	29	199200	456	1V	5885D	06/01/91	62.76
287311708	06/20/91	12/29/99	30	213840	456	1V	5885D	06/01/91	65.13
287311708	06/20/91	11/29/99	33	244080	480	1V	5885D	06/01/91	64.20
287311708	06/20/91	10/27/99	29	235080	492	1V	5885D	06/01/91	68.65
287311708	06/20/91	09/28/99	32	259320	480	1V	5885D	06/01/91	70.35
287311708	06/20/91	08/27/99	30	262200	504	1V	5885D	06/01/91	72.26
287311708	06/20/91	07/28/99	30	240720	504	1V	5885D	06/01/91	66.34
287311708	06/20/91	06/28/99	32	251880	480	1V	5885D	06/01/91	68.33
287311708	06/20/91	05/27/99	29	205200	480	1V	5885D	06/01/91	61.42
287311708	06/20/91	04/28/99	30	214680	480	1V	5885D	06/01/91	62.12
287311708	06/20/91	03/29/99	31	192240	420	1V	5885D	06/01/91	61.52
287311708	06/20/91	02/26/99	29	184440	408	1V	5885D	06/01/91	64.95
287311708	06/20/91	01/28/99	30	185880	420	1V	5885D	06/01/91	61.47
287311708	06/20/91	12/29/98	34	233280	468	1V	5885D	06/01/91	61.09
287311708	06/20/91	11/25/98	30	212640	456	1V	5885D	06/01/91	64.77
287311708	06/20/91	10/26/98	32	244440	480	1V	5885D	06/01/91	66.31
287311708	06/20/91	09/25/98	29	220800	480	1V	5885D	06/01/91	66.09
287311708	06/20/91	08/26/98	29	228840	480	1V	5885D	06/01/91	68.50
287311708	06/20/91	07/28/98	32	241800	480	1V	5885D	06/01/91	65.59
287311708	06/20/91	06/26/98	29	219120	504	1V	5885D	06/01/91	62.47
287311708	06/20/91	05/28/98	30	205080	480	1V	5885D	06/01/91	59.34
287311708	06/20/91	04/28/98	29	179520	432	1V	5885D	06/01/91	59.71
287311708	06/20/91	03/30/98	31	178440	444	1V	5885D	06/01/91	54.02
287311708	06/20/91	02/27/98	30	166680	456	1V	5885D	06/01/91	50.77
287311708	06/20/91	01/28/98	30	174120	456	1V	5885D	06/01/91	53.03
287311708	06/20/91	12/29/97	34	202920	456	1V	5885D	06/01/91	54.53
287311708	06/20/91	11/25/97	30	196800	456	1V	5885D	06/01/91	59.94
287311708	06/20/91	10/24/97	30	217800	444	1V	5885D	06/01/91	68.13
287311708	06/20/91	09/24/97	30	228600	480	1V	5885D	06/01/91	66.15
287311708	06/20/91	08/25/97	30	249240	492	1V	5885D	06/01/91	70.36
287311708	06/20/91	07/25/97	30	249480	480	1V	5885D	06/01/91	72.19
287311708	06/20/91	06/25/97	30	230640	456	1V	5885D	06/01/91	70.25
287311708	06/20/91	05/27/97	30	215760	456	1V	5885D	06/01/91	65.72
287311708	06/20/91	04/25/97	30	172440	456	1V	5885D	06/01/91	52.52

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
287311708	06/20/91	03/27/97	30	180840	444	1V	5885D	06/01/91	56.57
287311708	06/20/91	02/26/97	30	175920	444	1V	5885D	06/01/91	55.03
287311708	06/20/91	01/27/97	30	178800	456	1V	5885D	06/01/91	54.46
287311708	06/20/91	12/26/96	30	191160	444	1V	5885D	06/01/91	59.80
287311708	06/20/91	11/22/96	30	190320	480	1V	5885D	06/01/91	55.07
287311708	06/20/91	10/23/96	30	195480	480	1V	5885D	06/01/91	56.56
287311708	06/20/91	09/24/96	30	235440	492	1V	5885D	06/01/91	66.46
287311708	06/20/91	08/23/96	30	224520	504	1V	5885D	06/01/91	61.87
287311708	06/20/91	07/25/96	30	222120	492	1V	5885D	06/01/91	62.70
287311708	06/20/91	06/25/96	30	246240	516	1V	5885D	06/01/91	66.28
287311708	06/20/91	05/24/96	30	209760	480	1V	5885D	06/01/91	60.69
287311708	06/20/91	04/25/96	30	192840	444	1V	5885D	06/01/91	60.32
287311708	06/20/91	03/27/96	30	174120	456	1V	5885D	06/01/91	53.03
287311708	06/20/91	02/27/96	30	173160	444	1V	5885D	06/01/91	54.17
287311708	06/20/91	01/29/96	30	200400	444	1V	5885D	06/01/91	62.69
287311708	06/20/91	12/28/95	30	210480	456	1V	5885D	06/01/91	64.11
287311708	06/20/91	11/27/95	30	238680	480	1V	5885D	06/01/91	69.06
287311708	06/20/91	10/25/95	30	210840	480	1V	5885D	06/01/91	61.01
287311708	06/20/91	09/26/95	30	227040	480	1V	5885D	06/01/91	65.69
287311708	06/20/91	08/25/95	30	210120	480	1V	5885D	06/01/91	60.80
287311708	06/20/91	07/27/95	30	224760	492	1V	5885D	06/01/91	63.45
287311708	06/20/91	06/27/95	30	229440	516	1V	5885D	06/01/91	61.76
287311708	06/20/91	05/26/95	30	215400	528	1V	5885D	06/01/91	56.66
287311708	06/20/91	04/27/95	30	201240	444	1V	5885D	06/01/91	62.95
287311708	06/20/91	03/29/95	30	195120	444	1V	5885D	06/01/91	61.04
287311708	06/20/91	02/28/95	30	163320	420	1V	5885D	06/01/91	54.01
287311708	06/20/91	01/30/95	30	185760	420	1V	5885D	06/01/91	61.43
287311708	06/20/91	12/29/94	30	203880	480	1V	5885D	06/01/91	58.99
287311708	06/20/91	11/29/94	30	219840	540	1V	5885D	06/01/91	56.54
287311708	06/20/91	10/27/94	30	200040	480	1V	5885D	06/01/91	57.88
287311708	06/20/91	09/27/94	30	226320	504	1V	5885D	06/01/91	62.37
287311708	06/20/91	08/26/94	30	217200	492	1V	5885D	06/01/91	61.31
287311708	06/20/91	07/28/94	30	218760	492	1V	5885D	06/01/91	61.75
287311708	06/20/91	06/28/94	30	219360	468	1V	5885D	06/01/91	65.10
287311708	06/20/91	05/27/94	30	190680	480	1V	5885D	06/01/91	55.17
287311708	06/20/91	04/28/94	30	180960	480	1V	5885D	06/01/91	52.36
287311708	06/20/91	03/30/94	30	175320	468	1V	5885D	06/01/91	52.03
287311708	06/20/91	03/01/94	30	182160	432	1V	5885D	06/01/91	58.56

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
287311708	06/20/91	01/28/94	30	162840	444	1V	5885D	06/01/91	50.94
287311708	06/20/91	12/29/93	30	192840	420	1V	5885D	06/01/91	63.77
287311708	06/20/91	11/29/93	30	202800	456	1V	5885D	06/01/91	61.77
287311708	06/20/91	10/27/93	30	192120	444	1V	5885D	06/01/91	60.10
287311708	06/20/91	09/28/93	30	217320	456	1V	5885D	06/01/91	66.19
287311708	06/20/91	08/27/93	30	210120	504	1V	5885D	06/01/91	57.90
287311708	06/20/91	07/28/93	30	207840	480	1V	5885D	06/01/91	60.14
287311708	06/20/91	06/28/93	30	216720	480	1V	5885D	06/01/91	62.71
287311708	06/20/91	05/27/93	30	171720	480	1V	5885D	06/01/91	49.69
287311708	06/20/91	04/28/93	30	170520	420	1V	5885D	06/01/91	56.39
287311708	06/20/91	03/27/93	30	148680	408	1V	5885D	06/01/91	50.61

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>8326 S Dixie Hwy, Miami</b>									
290334358	11/25/98	06/18/03	30	3309	0	6N	24569	11/21/97	-
290334358	11/25/98	05/19/03	31	3377	0	6N	24569	11/21/97	-
290334358	11/25/98	04/18/03	29	2902	0	6N	24569	11/21/97	-
290334358	11/25/98	03/20/03	29	3138	0	6N	24569	11/21/97	-
290334358	11/25/98	02/19/03	33	2733	0	6N	24569	11/21/97	-
290334358	11/25/98	01/17/03	32	2461	0	6N	24569	11/21/97	-
290334358	11/25/98	12/16/02	32	2697	0	6N	24569	11/21/97	-
290334358	11/25/98	11/14/02	29	2705	0	6N	24569	11/21/97	-
290334358	11/25/98	10/16/02	29	3075	0	6N	24569	11/21/97	-
290334358	11/25/98	09/17/02	32	3374	0	6N	24569	11/21/97	-
290334358	11/25/98	08/16/02	29	3151	0	6N	24569	11/21/97	-
290334358	11/25/98	07/18/02	30	3203	0	6N	24569	11/21/97	-
290334358	11/25/98	06/18/02	32	3161	0	6N	24569	11/21/97	-
290334358	11/25/98	05/17/02	29	3155	0	6N	24569	11/21/97	-
290334358	11/25/98	04/18/02	29	3088	0	6N	24569	11/21/97	-
290334358	11/25/98	03/20/02	29	2651	0	6N	24569	11/21/97	-
290334358	11/25/98	02/19/02	32	3040	0	6N	24569	11/21/97	-
290334358	11/25/98	01/18/02	32	2876	0	6N	24569	11/21/97	-
290334358	11/25/98	12/17/01	33	3701	0	6N	24569	11/21/97	-
290334358	11/25/98	11/14/01	29	2720	0	6N	24569	11/21/97	-
290334358	11/25/98	10/16/01	29	2855	0	6N	24569	11/21/97	-
290334358	11/25/98	09/17/01	32	3466	0	6N	24569	11/21/97	-
290334358	11/25/98	08/16/01	29	3045	0	6N	24569	11/21/97	-
290334358	11/25/98	07/18/01	30	3014	0	6N	24569	11/21/97	-
290334358	11/25/98	06/18/01	32	2963	0	6N	24569	11/21/97	-
290334358	11/25/98	05/17/01	29	1978	0	6N	24569	11/21/97	-
290334358	11/25/98	04/18/01	29	2067	0	6N	24569	11/21/97	-
290334358	11/25/98	03/20/01	29	2133	0	6N	24569	11/21/97	-
290334358	11/25/98	02/19/01	31	1738	0	6N	24569	11/21/97	-
290334358	11/25/98	01/19/01	32	1731	0	6N	24569	11/21/97	-
290334358	11/25/98	12/18/00	33	1925	0	6N	24569	11/21/97	-
290334358	11/25/98	11/15/00	29	1662	0	6N	24569	11/21/97	-
290334358	11/25/98	10/17/00	29	1758	0	6N	24569	11/21/97	-
290334358	11/25/98	09/18/00	32	2086	0	6N	24569	11/21/97	-
290334358	11/25/98	08/17/00	30	2215	0	6N	24569	11/21/97	-
290334358	11/25/98	07/18/00	32	2302	0	6N	24569	11/21/97	-
290334358	11/25/98	06/16/00	30	1840	0	6N	24569	11/21/97	-

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
290334358	11/25/98	05/17/00	29	1574	0	6N	24569	11/21/97	-
290334358	11/25/98	04/18/00	29	1292	0	6N	24569	11/21/97	-
290334358	11/25/98	03/20/00	32	1191	0	6N	24569	11/21/97	-
290334358	11/25/98	02/17/00	29	945	0	6N	24569	11/21/97	-
290334358	11/25/98	01/19/00	34	1517	0	6N	24569	11/21/97	-
290334358	11/25/98	12/16/99	30	1510	0	6N	24569	11/21/97	-
290334358	11/25/98	11/16/99	29	1671	0	6N	24569	11/21/97	-
290334358	11/25/98	10/18/99	31	1426	0	6N	24569	11/21/97	-
290334358	11/25/98	09/17/99	30	1374	0	6N	24569	11/21/97	-
290334358	11/25/98	08/18/99	30	2149	0	6N	24569	11/21/97	-
290334358	11/25/98	07/19/99	32	2200	0	6N	24569	11/21/97	-
290334358	11/25/98	06/17/99	30	2063	0	6N	24569	11/21/97	-
290334358	11/25/98	05/18/99	29	2006	0	6N	24569	11/21/97	-
290334358	11/25/98	04/19/99	32	1967	0	6N	24569	11/21/97	-
290334358	11/25/98	03/18/99	29	1823	0	6N	24569	11/21/97	-
290334358	11/25/98	02/17/99	29	1332	0	6N	24569	11/21/97	-
290334358	11/25/98	01/19/99	34	1664	0	6N	24569	11/21/97	-
290334358	11/25/98	12/16/98	21	1415	0	6N	24569	11/21/97	-

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>12801 W Sunriswe Blvd, Sunrise</b>									
605961796	03/20/92	06/12/03	30	380040	699	9V	5122H	10/24/97	75.51
605961796	03/20/92	05/13/03	29	332760	689	9V	5122H	10/24/97	69.39
605961796	03/20/92	04/14/03	31	326160	720	9V	5122H	10/24/97	60.89
605961796	03/20/92	03/14/03	30	329280	683	9V	5122H	10/24/97	66.96
605961796	03/20/92	02/12/03	30	253680	680	9V	5122H	10/24/97	51.81
605961796	03/20/92	01/13/03	33	280080	703	9V	5122H	10/24/97	50.30
605961796	03/20/92	12/11/02	33	317640	692	9V	5122H	10/24/97	57.96
605961796	03/20/92	11/08/02	29	335040	706	9V	5122H	10/24/97	68.18
605961796	03/20/92	10/10/02	29	349200	714	9V	5122H	10/24/97	70.27
605961796	03/20/92	09/11/02	30	369000	728	9V	5122H	10/24/97	70.40
605961796	03/20/92	08/12/02	31	404280	728	9V	5122H	10/24/97	74.64
605961796	03/20/92	07/12/02	30	352440	696	9V	5122H	10/24/97	70.33
605961796	03/20/92	06/12/02	30	364560	713	9V	5122H	10/24/97	71.01
605961796	03/20/92	05/13/02	31	358320	692	9V	5122H	10/24/97	69.60
605961796	03/20/92	04/12/02	29	300720	653	9V	5122H	10/24/97	66.17
605961796	03/20/92	03/14/02	29	263280	651	9V	5122H	10/24/97	58.11
605961796	03/20/92	02/13/02	30	288480	642	9V	5122H	10/24/97	62.41
605961796	03/20/92	01/14/02	34	288000	642	9V	5122H	10/24/97	54.98
605961796	03/20/92	12/11/01	33	325440	665	9V	5122H	10/24/97	61.79
605961796	03/20/92	11/08/01	29	318000	712	9V	5122H	10/24/97	64.17
605961796	03/20/92	10/10/01	29	339120	721	9V	5122H	10/24/97	67.58
605961796	03/20/92	09/11/01	32	407280	726	9V	5122H	10/24/97	73.05
605961796	03/20/92	08/10/01	29	357960	758	9V	5122H	10/24/97	67.85
605961796	03/20/92	07/12/01	30	362040	737	9V	5122H	10/24/97	68.23
605961796	03/20/92	06/12/01	32	360360	736	9V	5122H	10/24/97	63.75
605961796	03/20/92	05/11/01	29	282360	699	9V	5122H	10/24/97	58.04
605961796	03/20/92	04/12/01	29	279720	676	9V	5122H	10/24/97	59.45
605961796	03/20/92	03/14/01	29	264840	654	9V	5122H	10/24/97	58.18
605961796	03/20/92	02/13/01	32	262200	660	9V	5122H	10/24/97	51.73
605961796	03/20/92	01/12/01	31	245760	645	9V	5122H	10/24/97	51.21
605961796	03/20/92	12/12/00	33	309600	690	9V	5122H	10/24/97	56.65
605961796	03/20/92	11/09/00	29	286200	637	9V	5122H	10/24/97	64.55
605961796	03/20/92	10/11/00	29	341160	689	9V	5122H	10/24/97	71.14
605961796	03/20/92	09/12/00	32	390720	702	9V	5122H	10/24/97	72.47
605961796	03/20/92	08/11/00	30	351960	700	9V	5122H	10/24/97	69.83
605961796	03/20/92	07/12/00	30	347760	698	9V	5122H	10/24/97	69.20
605961796	03/20/92	05/11/00	29	286320	689	9V	5122H	10/24/97	59.71

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
605961796	03/20/92	04/12/00	29	278040	676	9V	5122H	10/24/97	59.10
605961796	03/20/92	03/14/00	32	289320	667	9V	5122H	10/24/97	56.48
605961796	03/20/92	02/11/00	30	223800	633	9V	5122H	10/24/97	49.10
605961796	03/20/92	01/12/00	33	311160	696	9V	5122H	10/24/97	56.45
605961796	03/20/92	12/10/99	30	292320	730	9V	5122H	10/24/97	55.62
605961796	03/20/92	11/10/99	29	307080	723	9V	5122H	10/24/97	61.02
605961796	03/20/92	10/12/99	29	350280	749	9V	5122H	10/24/97	67.19
605961796	03/20/92	09/13/99	32	400560	802	9V	5122H	10/24/97	65.03
605961796	03/20/92	08/12/99	30	387000	778	9V	5122H	10/24/97	69.09
605961796	03/20/92	07/13/99	32	374880	741	9V	5122H	10/24/97	65.87
605961796	03/20/92	06/11/99	30	321480	676	9V	5122H	10/24/97	66.05
605961796	03/20/92	05/12/99	29	297840	694	9V	5122H	10/24/97	61.66
605961796	03/20/92	04/13/99	32	293040	689	9V	5122H	10/24/97	55.38
605961796	03/20/92	03/12/99	29	224880	641	9V	5122H	10/24/97	50.41
605961796	03/20/92	02/11/99	30	266520	660	9V	5122H	10/24/97	56.09
605961796	03/20/92	01/12/99	33	284520	708	9V	5122H	10/24/97	50.74
605961796	03/20/92	12/10/98	31	313800	676	9V	5122H	10/24/97	62.39
605961796	03/20/92	11/09/98	31	320400	701	9V	5122H	10/24/97	61.43
605961796	03/20/92	10/09/98	29	346800	727	9V	5122H	10/24/97	68.54
605961796	03/20/92	09/10/98	30	390720	757	9V	5122H	10/24/97	71.69
605961796	03/20/92	08/11/98	29	360480	737	9V	5122H	10/24/97	70.28
605961796	03/20/92	07/13/98	32	386520	699	9V	5122H	10/24/97	72.00
605961796	03/20/92	06/11/98	30	342120	718	9V	5122H	10/24/97	66.18
605961796	03/20/92	05/12/98	29	287520	706	9V	5122H	10/24/97	58.51
605961796	03/20/92	04/13/98	31	280680	659	9V	5122H	10/24/97	57.25
605961796	03/20/92	03/13/98	30	267480	646	9V	5122H	10/24/97	57.51
605961796	03/20/92	02/11/98	30	244560	593	9V	5122H	10/24/97	57.28
605961796	03/20/92	01/12/98	33	304920	676	9V	5122H	10/24/97	56.95
605961796	03/20/92	12/10/97	30	313200	671	9V	5122H	10/24/97	64.83
605961796	03/20/92	11/07/97	30	298920	673	9V	5122H	10/24/97	61.69
605961796	03/20/92	10/09/97	30	342360	665	9V	5699H	03/01/92	71.50
605961796	03/20/92	09/09/97	30	385080	656	9V	5699H	03/01/92	81.53
605961796	03/20/92	08/08/97	30	364680	672	9V	5699H	03/01/92	75.37
605961796	03/20/92	07/10/97	30	334920	679	9V	5699H	03/01/92	68.51
605961796	03/20/92	06/10/97	30	327600	647	9V	5699H	03/01/92	70.32
605961796	03/20/92	05/09/97	30	274080	661	9V	5699H	03/01/92	57.59
605961796	03/20/92	04/10/97	30	261240	642	9V	5699H	03/01/92	56.52
605961796	03/20/92	03/12/97	30	272160	600	9V	5699H	03/01/92	63.00

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
605961796	03/20/92	02/10/97	30	245400	570	9V	5699H	03/01/92	59.80
605961796	03/20/92	01/09/97	30	247920	570	9V	5699H	03/01/92	60.41
605961796	03/20/92	12/09/96	30	289920	677	9V	5699H	03/01/92	59.48
605961796	03/20/92	11/06/96	30	291120	663	9V	5699H	03/01/92	60.99
605961796	03/20/92	10/08/96	30	334920	697	9V	5699H	03/01/92	66.74
605961796	03/20/92	09/09/96	30	392400	741	9V	5699H	03/01/92	73.55
605961796	03/20/92	08/08/96	30	370440	724	9V	5699H	03/01/92	71.06
605961796	03/20/92	07/10/96	30	364560	755	9V	5699H	03/01/92	67.06
605961796	03/20/92	06/10/96	30	361320	744	9V	5699H	03/01/92	67.45
605961796	03/20/92	05/09/96	30	294960	700	9V	5699H	03/01/92	58.52
605961796	03/20/92	04/10/96	30	256080	690	9V	5699H	03/01/92	51.55
605961796	03/20/92	03/12/96	30	248760	619	9V	5699H	03/01/92	55.82
605961796	03/20/92	02/12/96	30	253320	541	9V	5699H	03/01/92	65.03
605961796	03/20/92	01/11/96	30	245400	570	9V	5699H	03/01/92	59.80
605961796	03/20/92	12/11/95	30	294000	644	9V	5699H	03/01/92	63.41
605961796	03/20/92	11/08/95	30	316200	670	9V	5699H	03/01/92	65.55
605961796	03/20/92	10/10/95	30	336480	728	9V	5699H	03/01/92	64.19
605961796	03/20/92	09/11/95	30	380880	778	9V	5699H	03/01/92	67.99
605961796	03/20/92	08/10/95	30	323400	731	9V	5699H	03/01/92	61.45
605961796	03/20/92	07/12/95	30	336240	741	9V	5699H	03/01/92	63.02
605961796	03/20/92	06/12/95	30	366840	721	9V	5699H	03/01/92	70.67
605961796	03/20/92	05/11/95	30	302040	702	9V	5699H	03/01/92	59.76
605961796	03/20/92	04/12/95	30	269520	642	9V	5699H	03/01/92	58.31
605961796	03/20/92	03/14/95	30	227400	601	9V	5699H	03/01/92	52.55
605961796	03/20/92	02/13/95	30	224160	602	9V	5699H	03/01/92	51.72
605961796	03/20/92	01/12/95	30	225120	616	9V	5699H	03/01/92	50.76
605961796	03/20/92	12/13/94	30	311520	668	9V	5699H	03/01/92	64.77
605961796	03/20/92	11/10/94	30	286920	693	9V	5699H	03/01/92	57.50
605961796	03/20/92	10/11/94	30	288720	750	9V	5699H	03/01/92	53.47
605961796	03/20/92	09/12/94	30	337560	764	9V	5699H	03/01/92	61.37
605961796	03/20/92	08/11/94	30	309240	729	9V	5699H	03/01/92	58.92
605961796	03/20/92	07/13/94	30	321480	791	9V	5699H	03/01/92	56.45
605961796	03/20/92	06/13/94	30	313800	768	9V	5699H	03/01/92	56.75
605961796	03/20/92	05/12/94	30	272160	676	9V	5699H	03/01/92	55.92
605961796	03/20/92	04/13/94	30	255960	710	9V	5699H	03/01/92	50.07
605961796	03/20/92	03/15/94	30	256920	606	9V	5699H	03/01/92	58.88
605961796	03/20/92	02/11/94	30	220560	586	9V	5699H	03/01/92	52.28
605961796	03/20/92	01/12/94	30	209160	545	9V	5699H	03/01/92	53.30



Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
605961796	03/20/92	12/13/93	30	274800	679	9V	5699H	03/01/92	56.21
605961796	03/20/92	11/10/93	30	271920	716	9V	5699H	03/01/92	52.75
605961796	03/20/92	10/12/93	30	287760	728	9V	5699H	03/01/92	54.90
605961796	03/20/92	09/13/93	30	335040	783	9V	5699H	03/01/92	59.43
605961796	03/20/92	08/12/93	30	315840	767	9V	5699H	03/01/92	57.19
605961796	03/20/92	07/13/93	30	314520	729	9V	5699H	03/01/92	59.92
605961796	03/20/92	06/11/93	30	275040	743	9V	5699H	03/01/92	51.41
605961796	03/20/92	05/12/93	30	233760	620	9V	5699H	03/01/92	52.37
605961796	03/20/92	04/13/93	30	246000	600	9V	5699H	03/01/92	56.94
605961796	03/20/92	03/12/93	30	214440	530	9V	5699H	03/01/92	56.19

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>3251 Hollywood Blvd #300, Hollywood</b>									
771059334	08/03/93	06/06/03	30	258960	578	6V	7454D	11/05/02	62.23
771059334	08/03/93	05/07/03	29	209760	542	6V	7454D	11/05/02	55.61
771059334	08/03/93	04/08/03	29	214080	562	6V	7454D	11/05/02	54.73
771059334	08/03/93	03/10/03	32	227520	528	6V	7454D	11/05/02	56.11
771059334	08/03/93	02/06/03	30	165840	408	6V	7454D	11/05/02	56.45
771059334	08/03/93	01/07/03	33	211440	557	6V	7454D	11/05/02	47.93
771059334	08/03/93	12/05/02	31	209280	564	6V	7454D	11/05/02	49.87
771059334	08/03/93	11/04/02	31	247680	600	1V	7032D	07/19/93	55.48
771059334	08/03/93	10/04/02	28	228960	480	1V	7032D	07/19/93	70.98
771059334	08/03/93	09/06/02	30	253440	540	1V	7032D	07/19/93	65.19
771059334	08/03/93	08/07/02	29	241920	552	1V	7032D	07/19/93	62.97
771059334	08/03/93	07/09/02	32	251040	600	1V	7032D	07/19/93	54.48
771059334	08/03/93	06/07/02	30	238800	552	1V	7032D	07/19/93	60.08
771059334	08/03/93	05/08/02	29	224880	552	1V	7032D	07/19/93	58.53
771059334	08/03/93	04/09/02	29	205920	528	1V	7032D	07/19/93	56.03
771059334	08/03/93	03/11/02	31	194880	528	1V	7032D	07/19/93	49.61
771059334	08/03/93	02/08/02	30	194400	552	1V	7032D	07/19/93	48.91
771059334	08/03/93	01/09/02	34	215040	600	1V	7032D	07/19/93	43.92
771059334	08/03/93	12/06/01	31	204720	552	1V	7032D	07/19/93	49.85
771059334	08/03/93	11/05/01	31	242880	600	1V	7032D	07/19/93	54.41
771059334	08/03/93	10/05/01	29	226320	552	1V	7032D	07/19/93	58.91
771059334	08/03/93	09/06/01	30	260160	600	1V	7032D	07/19/93	60.22
771059334	08/03/93	08/07/01	29	235920	600	1V	7032D	07/19/93	56.49
771059334	08/03/93	07/09/01	32	262800	600	1V	7032D	07/19/93	57.03
771059334	08/03/93	06/07/01	30	225360	576	1V	7032D	07/19/93	54.34
771059334	08/03/93	05/08/01	29	199680	480	1V	7032D	07/19/93	59.77
771059334	08/03/93	04/09/01	31	201120	480	1V	7032D	07/19/93	56.32
771059334	08/03/93	03/09/01	29	185280	480	1V	7032D	07/19/93	55.46
771059334	08/03/93	02/08/01	30	169920	480	1V	7032D	07/19/93	49.17
771059334	08/03/93	01/09/01	33	187200	480	1V	7032D	07/19/93	49.24
771059334	08/03/93	12/07/00	31	199680	552	1V	7032D	07/19/93	48.62
771059334	08/03/93	11/06/00	31	231600	660	1V	7032D	07/19/93	47.17
771059334	08/03/93	10/06/00	29	221760	600	1V	7032D	07/19/93	53.10
771059334	08/03/93	09/07/00	30	248160	600	1V	7032D	07/19/93	57.44
771059334	08/03/93	08/08/00	32	258720	600	1V	7032D	07/19/93	56.15
771059334	08/03/93	07/07/00	30	229680	552	1V	7032D	07/19/93	57.79
771059334	08/03/93	06/07/00	30	223680	528	1V	7032D	07/19/93	58.84

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
771059334	08/03/93	05/08/00	31	206880	528	1V	7032D	07/19/93	52.66
771059334	08/03/93	04/07/00	29	190320	576	1V	7032D	07/19/93	47.47
771059334	08/03/93	03/09/00	30	179040	528	1V	7032D	07/19/93	47.10
771059334	08/03/93	02/08/00	31	170640	480	1V	7032D	07/19/93	47.78
771059334	08/03/93	01/08/00	32	197280	528	1V	7032D	07/19/93	48.65
771059334	08/03/93	12/07/99	32	203040	576	1V	7032D	07/19/93	45.90
771059334	08/03/93	11/05/99	29	203040	600	1V	7032D	07/19/93	48.62
771059334	08/03/93	10/07/99	29	221760	600	1V	7032D	07/19/93	53.10
771059334	08/03/93	09/08/99	30	243840	600	1V	7032D	07/19/93	56.44
771059334	08/03/93	08/09/99	32	274560	600	1V	7032D	07/19/93	59.58
771059334	08/03/93	07/08/99	30	217680	600	1V	7032D	07/19/93	50.39
771059334	08/03/93	06/08/99	32	252720	528	1V	7032D	07/19/93	62.32
771059334	08/03/93	05/07/99	29	199200	480	1V	7032D	07/19/93	59.63
771059334	08/03/93	04/08/99	30	186960	480	1V	7032D	07/19/93	54.10
771059334	08/03/93	03/09/99	29	165120	480	1V	7032D	07/19/93	49.43
771059334	08/03/93	02/08/99	31	195360	480	1V	7032D	07/19/93	54.70
771059334	08/03/93	01/08/99	32	203760	480	1V	7032D	07/19/93	55.27
771059334	08/03/93	12/07/98	33	239520	480	1V	7032D	07/19/93	63.01
771059334	08/03/93	11/04/98	29	225360	492	1V	7032D	07/19/93	65.81
771059334	08/03/93	10/06/98	33	264480	600	1V	7032D	07/19/93	55.66
771059334	08/03/93	09/04/98	29	259200	576	1V	7032D	07/19/93	64.66
771059334	08/03/93	08/06/98	29	253680	576	1V	7032D	07/19/93	63.28
771059334	08/03/93	07/08/98	29	254880	576	1V	7032D	07/19/93	63.58
771059334	08/03/93	06/08/98	32	256800	528	1V	7032D	07/19/93	63.33
771059334	08/03/93	05/07/98	29	195360	528	1V	7032D	07/19/93	53.16
771059334	08/03/93	04/08/98	29	180240	576	1V	7032D	07/19/93	44.96
771059334	08/03/93	03/10/98	32	191280	528	1V	7032D	07/19/93	47.17
771059334	08/03/93	02/06/98	29	164640	528	1V	7032D	07/19/93	44.80
771059334	08/03/93	01/08/98	35	212880	552	1V	7032D	07/19/93	45.91
771059334	08/03/93	12/05/97	30	200160	552	1V	7032D	07/19/93	50.36
771059334	08/03/93	11/04/97	30	203520	576	1V	7032D	07/19/93	49.07
771059334	08/03/93	10/06/97	30	252960	552	1V	7032D	07/19/93	63.65
771059334	08/03/93	09/04/97	30	255840	600	1V	7032D	07/19/93	59.22
771059334	08/03/93	08/05/97	30	234480	552	1V	7032D	07/19/93	59.00
771059334	08/03/93	07/07/97	30	256320	552	1V	7032D	07/19/93	64.49
771059334	08/03/93	06/05/97	30	224640	552	1V	7032D	07/19/93	56.52
771059334	08/03/93	05/06/97	30	199200	552	1V	7032D	07/19/93	50.12
771059334	08/03/93	04/07/97	30	204480	552	1V	7032D	07/19/93	51.45

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
771059334	08/03/93	03/07/97	30	200160	552	1V	7032D	07/19/93	50.36
771059334	08/03/93	02/05/97	30	170160	480	1V	7032D	07/19/93	49.24
771059334	08/03/93	01/06/97	30	201120	480	1V	7032D	07/19/93	58.19
771059334	08/03/93	12/04/96	30	219600	552	1V	7032D	07/19/93	55.25
771059334	08/03/93	11/01/96	30	215280	576	1V	7032D	07/19/93	51.91
771059334	08/03/93	10/03/96	30	245760	720	1V	7032D	07/19/93	47.41
771059334	08/03/93	09/04/96	30	253200	720	1V	7032D	07/19/93	48.84
771059334	08/03/93	08/05/96	30	270720	480	1V	7032D	07/19/93	78.33
771059334	08/03/93	07/05/96	30	233280	480	1V	7032D	07/19/93	67.50
771059334	08/03/93	06/05/96	30	226800	480	1V	7032D	07/19/93	65.63
771059334	08/03/93	05/06/96	30	216720	480	1V	7032D	07/19/93	62.71
771059334	08/03/93	04/05/96	30	187200	480	1V	7032D	07/19/93	54.17
771059334	08/03/93	03/07/96	30	170400	480	1V	7032D	07/19/93	49.31
771059334	08/03/93	02/07/96	30	177120	504	1V	7032D	07/19/93	48.81
771059334	08/03/93	01/08/96	30	200160	528	1V	7032D	07/19/93	52.65
771059334	08/03/93	12/06/95	30	213840	576	1V	7032D	07/19/93	51.56
771059334	08/03/93	11/03/95	30	231120	576	1V	7032D	07/19/93	55.73
771059334	08/03/93	10/05/95	30	238800	528	1V	7032D	07/19/93	62.82
771059334	08/03/93	09/06/95	30	250080	552	1V	7032D	07/19/93	62.92
771059334	08/03/93	08/07/95	30	257760	552	1V	7032D	07/19/93	64.86
771059334	08/03/93	07/07/95	30	250560	552	1V	7032D	07/19/93	63.04
771059334	08/03/93	06/07/95	30	251280	552	1V	7032D	07/19/93	63.22
771059334	08/03/93	05/08/95	30	239520	528	1V	7032D	07/19/93	63.01
771059334	08/03/93	04/07/95	30	201840	504	1V	7032D	07/19/93	55.62
771059334	08/03/93	03/09/95	30	194160	480	1V	7032D	07/19/93	56.18
771059334	08/03/93	02/08/95	30	162240	480	1V	7032D	07/19/93	46.94
771059334	08/03/93	01/09/95	30	201840	480	1V	7032D	07/19/93	58.40
771059334	08/03/93	12/08/94	30	237840	480	1V	7032D	07/19/93	68.82
771059334	08/03/93	11/05/94	30	236880	528	1V	7032D	07/19/93	62.31
771059334	08/03/93	10/06/94	30	237840	528	1V	7032D	07/19/93	62.56
771059334	08/03/93	09/07/94	30	256800	480	1V	7032D	07/19/93	74.31
771059334	08/03/93	08/08/94	30	263040	528	1V	7032D	07/19/93	69.19
771059334	08/03/93	07/08/94	30	248640	480	1V	7032D	07/19/93	71.94
771059334	08/03/93	06/08/94	30	229200	480	1V	7032D	07/19/93	66.32
771059334	08/03/93	05/09/94	30	228960	480	1V	7032D	07/19/93	66.25
771059334	08/03/93	04/08/94	30	189360	480	1V	7032D	07/19/93	54.79
771059334	08/03/93	03/10/94	30	186720	408	1V	7032D	07/19/93	63.56
771059334	08/03/93	02/08/94	30	180000	432	1V	7032D	07/19/93	57.87

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
771059334	08/03/93	01/08/94	30	181200	408	1V	7032D	07/19/93	61.68
771059334	08/03/93	12/08/93	30	221760	480	1V	7032D	07/19/93	64.17
771059334	08/03/93	11/05/93	30	216720	552	1V	7032D	07/19/93	54.53
771059334	08/03/93	10/07/93	30	207600	480	1V	7032D	07/19/93	60.07
771059334	08/03/93	09/08/93	30	141600	408	1V	7032D	07/19/93	48.20
771059334	08/03/93	08/09/93	6	88800	252	1V	7032D	07/19/93	244.71

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>3200 N Federal Hwy #130, Ft Lauderdale</b>									
777818204	07/27/99	06/06/03	30	0	0	5L	23712	04/01/91	-
777818204	07/27/99	05/07/03	29	0	0	5L	23712	04/01/91	-
777818204	07/27/99	04/08/03	29	0	0	5L	23712	04/01/91	-
777818204	07/27/99	03/10/03	32	0	0	5L	23712	04/01/91	-
777818204	07/27/99	02/06/03	30	0	0	5L	23712	04/01/91	-
777818204	07/27/99	01/07/03	33	0	0	5L	23712	04/01/91	-
777818204	07/27/99	12/05/02	31	0	0	5L	23712	04/01/91	-
777818204	07/27/99	11/04/02	31	0	0	5L	23712	04/01/91	-
777818204	07/27/99	10/04/02	29	0	0	5L	23712	04/01/91	-
777818204	07/27/99	09/05/02	30	0	0	5L	23712	04/01/91	-
777818204	07/27/99	08/06/02	29	0	0	5L	23712	04/01/91	-
777818204	07/27/99	07/08/02	32	0	0	5L	23712	04/01/91	-
777818204	07/27/99	06/06/02	30	0	0	5L	23712	04/01/91	-
777818204	07/27/99	05/07/02	29	0	0	5L	23712	04/01/91	-
777818204	07/27/99	04/08/02	31	0	0	5L	23712	04/01/91	-
777818204	07/27/99	03/08/02	29	0	0	5L	23712	04/01/91	-
777818204	07/27/99	02/07/02	30	0	0	5L	23712	04/01/91	-
777818204	07/27/99	01/08/02	34	0	0	5L	23712	04/01/91	-
777818204	07/27/99	12/05/01	33	0	0	5L	23712	04/01/91	-
777818204	07/27/99	11/02/01	29	0	0	5L	23712	04/01/91	-
777818204	07/27/99	10/04/01	29	0	0	5L	23712	04/01/91	-
777818204	07/27/99	09/05/01	30	0	0	5L	23712	04/01/91	-
777818204	07/27/99	08/06/01	31	0	0	5L	23712	04/01/91	-
777818204	07/27/99	07/06/01	30	0	0	5L	23712	04/01/91	-
777818204	07/27/99	06/06/01	30	0	0	5L	23712	04/01/91	-
777818204	07/27/99	05/07/01	31	0	0	5L	23712	04/01/91	-
777818204	07/27/99	04/06/01	29	0	0	5L	23712	04/01/91	-
777818204	07/27/99	03/08/01	29	0	0	5L	23712	04/01/91	-
777818204	07/27/99	02/07/01	30	0	0	5L	23712	04/01/91	-
777818204	07/27/99	01/08/01	33	0	0	5L	23712	04/01/91	-
777818204	07/27/99	12/06/00	34	0	0	5L	23712	04/01/91	-
777818204	07/27/99	11/02/00	29	0	0	5L	23712	04/01/91	-
777818204	07/27/99	10/04/00	29	0	0	5L	23712	04/01/91	-
777818204	07/27/99	09/05/00	33	0	0	5L	23712	04/01/91	-
777818204	07/27/99	08/03/00	29	0	0	5L	23712	04/01/91	-
777818204	07/27/99	07/05/00	30	0	0	5L	23712	04/01/91	-
777818204	07/27/99	06/05/00	32	0	0	5L	23712	04/01/91	-

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
777818204	07/27/99	05/04/00	29	0	0	5L	23712	04/01/91	-
777818204	07/27/99	04/05/00	29	0	0	5L	23712	04/01/91	-
777818204	07/27/99	03/07/00	32	0	0	5L	23712	04/01/91	-
777818204	07/27/99	02/04/00	29	0	0	5L	23712	04/01/91	-
777818204	07/27/99	01/06/00	33	0	0	5L	23712	04/01/91	-
777818204	07/27/99	12/04/99	31	0	0	5L	23712	04/01/91	-
777818204	07/27/99	11/03/99	29	0	0	5L	23712	04/01/91	-
777818204	07/27/99	10/05/99	32	0	0	5L	23712	04/01/91	-
777818204	07/27/99	09/03/99	30	0	0	5L	23712	04/01/91	-
777818204	07/27/99	08/04/99	7	1006	0	5L	23712	04/01/91	-

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>8458 S Dixie Hwy, Miami</b>									
811739556	10/09/96	06/18/03	30	222000	464	6V	5883D	11/05/02	66.45
811739556	10/09/96	05/19/03	31	220680	457	6V	5883D	11/05/02	64.90
811739556	10/09/96	04/18/03	29	171600	382	6V	5883D	11/05/02	64.54
811739556	10/09/96	03/20/03	29	185640	431	6V	5883D	11/05/02	61.88
811739556	10/09/96	02/19/03	33	187920	407	6V	5883D	11/05/02	58.30
811739556	10/09/96	01/17/03	32	189600	439	6V	5883D	11/05/02	56.24
811739556	10/09/96	12/16/02	32	207360	466	6V	5883D	11/05/02	57.94
811739556	10/09/96	11/14/02	29	206880	466	6V	5883D	11/05/02	63.79
811739556	10/09/96	10/16/02	29	220080	480	1V	5211D	12/19/96	65.88
811739556	10/09/96	09/17/02	32	245400	480	1V	5211D	12/19/96	66.57
811739556	10/09/96	08/16/02	29	230760	480	1V	5211D	12/19/96	69.07
811739556	10/09/96	07/18/02	30	226920	480	1V	5211D	12/19/96	65.66
811739556	10/09/96	06/18/02	32	236640	420	1V	5211D	12/19/96	73.36
811739556	10/09/96	05/17/02	29	204000	420	1V	5211D	12/19/96	69.79
811739556	10/09/96	04/18/02	29	207480	396	1V	5211D	12/19/96	75.28
811739556	10/09/96	03/20/02	29	188520	420	1V	5211D	12/19/96	64.49
811739556	10/09/96	02/19/02	32	217800	420	1V	5211D	12/19/96	67.52
811739556	10/09/96	01/18/02	32	204360	480	1V	5211D	12/19/96	55.44
811739556	10/09/96	12/17/01	33	240000	444	1V	5211D	12/19/96	68.25
811739556	10/09/96	11/14/01	29	213600	420	1V	5211D	12/19/96	73.07
811739556	10/09/96	10/16/01	29	221520	480	1V	5211D	12/19/96	66.31
811739556	10/09/96	09/17/01	32	265560	480	1V	5211D	12/19/96	72.04
811739556	10/09/96	08/16/01	29	234960	480	1V	5211D	12/19/96	70.33
811739556	10/09/96	07/18/01	30	237360	480	1V	5211D	12/19/96	68.68
811739556	10/09/96	06/18/01	32	246120	480	1V	5211D	12/19/96	66.76
811739556	10/09/96	05/17/01	29	195360	396	1V	5211D	12/19/96	70.88
811739556	10/09/96	04/18/01	29	203640	360	1V	5211D	12/19/96	81.27
811739556	10/09/96	03/20/01	29	188520	360	1V	5211D	12/19/96	75.24
811739556	10/09/96	02/19/01	31	184920	360	1V	5211D	12/19/96	69.04
811739556	10/09/96	01/19/01	32	177240	480	1V	5211D	12/19/96	48.08
811739556	10/09/96	12/18/00	33	219000	360	1V	5211D	12/19/96	76.81
811739556	10/09/96	11/15/00	29	198960	480	1V	5211D	12/19/96	59.55
811739556	10/09/96	10/17/00	29	216840	480	1V	5211D	12/19/96	64.91
811739556	10/09/96	09/18/00	32	246480	480	1V	5211D	12/19/96	66.86
811739556	10/09/96	08/17/00	30	236160	480	1V	5211D	12/19/96	68.33
811739556	10/09/96	07/18/00	32	256680	480	1V	5211D	12/19/96	69.63
811739556	10/09/96	06/16/00	30	225120	480	1V	5211D	12/19/96	65.14



Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
811739556	10/09/96	05/17/00	29	205920	480	1V	5211D	12/19/96	61.64
811739556	10/09/96	04/18/00	29	188640	360	1V	5211D	12/19/96	75.29
811739556	10/09/96	03/20/00	32	201720	360	1V	5211D	12/19/96	72.96
811739556	10/09/96	02/17/00	29	160200	360	1V	5211D	12/19/96	63.94
811739556	10/09/96	01/19/00	34	206400	480	1V	5211D	12/19/96	52.70
811739556	10/09/96	12/16/99	30	193680	480	1V	5211D	12/19/96	56.04
811739556	10/09/96	11/16/99	29	206280	480	1V	5211D	12/19/96	61.75
811739556	10/09/96	10/18/99	31	256800	460	1V	5211D	12/19/96	75.04
811739556	10/09/96	09/17/99	30	237240	480	1V	5211D	12/19/96	68.65
811739556	10/09/96	08/18/99	30	214920	480	1V	5211D	12/19/96	62.19
811739556	10/09/96	07/19/99	32	234240	480	1V	5211D	12/19/96	63.54
811739556	10/09/96	06/17/99	30	228840	480	1V	5211D	12/19/96	66.22
811739556	10/09/96	05/18/99	29	192000	480	1V	5211D	12/19/96	57.47
811739556	10/09/96	04/19/99	32	142920	480	1V	5211D	12/19/96	38.77
811739556	10/09/96	03/18/99	29	204720	472	1V	5211D	12/19/96	62.32
811739556	10/09/96	02/17/99	29	182160	480	1V	5211D	12/19/96	54.53
811739556	10/09/96	01/19/99	34	220080	360	1V	5211D	12/19/96	74.92
811739556	10/09/96	12/16/98	30	232800	480	1V	5211D	12/19/96	67.36
811739556	10/09/96	11/16/98	32	253920	420	1V	5211D	12/19/96	78.72
811739556	10/09/96	10/15/98	29	262920	480	1V	5211D	12/19/96	78.70
811739556	10/09/96	09/16/98	30	286200	480	1V	5211D	12/19/96	82.81
811739556	10/09/96	08/17/98	31	303240	540	1V	5211D	12/19/96	75.48
811739556	10/09/96	07/17/98	30	297480	480	1V	5211D	12/19/96	86.08
811739556	10/09/96	06/17/98	30	277560	480	1V	5211D	12/19/96	80.31
811739556	10/09/96	05/18/98	31	261240	480	1V	5211D	12/19/96	73.15
811739556	10/09/96	04/17/98	29	224040	480	1V	5211D	12/19/96	67.06
811739556	10/09/96	03/19/98	29	208080	456	1V	5211D	12/19/96	65.56
811739556	10/09/96	02/18/98	33	234480	444	1V	5211D	12/19/96	66.68
811739556	10/09/96	01/16/98	31	217800	456	1V	5211D	12/19/96	64.20
811739556	10/09/96	10/15/98	30	262920	480	1V	5211D	12/19/96	76.08
811739556	10/09/96	09/16/98	30	286200	480	1V	5211D	12/19/96	82.81
811739556	10/09/96	08/17/98	30	303240	540	1V	5211D	12/19/96	77.99
811739556	10/09/96	07/17/98	30	297480	480	1V	5211D	12/19/96	86.08
811739556	10/09/96	06/17/98	30	277560	480	1V	5211D	12/19/96	80.31
811739556	10/09/96	05/18/98	30	261240	480	1V	5211D	12/19/96	75.59
811739556	10/09/96	04/17/98	30	224040	480	1V	5211D	12/19/96	64.83
811739556	10/09/96	03/19/98	30	208080	456	1V	5211D	12/19/96	63.38
811739556	10/09/96	02/18/98	30	234480	444	1V	5211D	12/19/96	73.35

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
811739556	10/09/96	01/16/98	30	217800	456	1V	5211D	12/19/96	66.34
811739556	10/09/96	12/16/97	30	234360	480	1V	5211D	12/19/96	67.81
811739556	10/09/96	11/14/97	30	237120	428	1V	5211D	12/19/96	76.95
811739556	10/09/96	10/15/97	30	289320	492	1V	5211D	12/19/96	81.67
811739556	10/09/96	09/15/97	30	262680	540	1V	5211D	12/19/96	67.56
811739556	10/09/96	08/14/97	30	256440	504	1V	5211D	12/19/96	70.67
811739556	10/09/96	07/16/97	30	247200	504	1V	5211D	12/19/96	68.12
811739556	10/09/96	06/16/97	30	252720	480	1V	5211D	12/19/96	73.13
811739556	10/09/96	05/15/97	30	202080	480	1V	5211D	12/19/96	58.47
811739556	10/09/96	04/16/97	30	191160	480	1V	5211D	12/19/96	55.31
811739556	10/09/96	03/18/97	30	225480	480	1V	5211D	12/19/96	65.24
811739556	10/09/96	02/14/97	30	177840	480	1V	5211D	12/19/96	51.46
811739556	10/09/96	01/15/97	30	224280	480	1V	5211D	12/19/96	64.90
811739556	10/09/96	12/13/96	30	205236	396	1V	59202	09/05/96	71.98
811739556	10/09/96	11/13/96	30	232595	396	1V	59202	09/05/96	81.58
811739556	10/09/96	10/14/96	5	59880	360	1V	59202	09/05/96	138.61

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>1400 Tamiami Trl, Port Charlotte</b>									
1005445984	10/03/91	06/19/03	30	223560	529	6V	5906D	11/11/02	58.70
1005445984	10/03/91	05/20/03	29	209040	509	6V	5906D	11/11/02	59.01
1005445984	10/03/91	04/21/03	31	199080	480	6V	5906D	11/11/02	55.75
1005445984	10/03/91	03/21/03	29	198480	490	6V	5906D	11/11/02	58.20
1005445984	10/03/91	02/20/03	30	162840	469	6V	5906D	11/11/02	48.22
1005445984	10/03/91	01/21/03	35	179040	457	6V	5906D	11/11/02	46.64
1005445984	10/03/91	12/17/02	32	201840	468	6V	5906D	11/11/02	56.16
1005445984	10/03/91	11/15/02	29	220320	504	6V	5906D	11/11/02	62.81
1005445984	10/03/91	10/17/02	29	227280	540	1V	5887D	12/01/92	60.47
1005445984	10/03/91	09/18/02	30	236760	552	1V	5887D	12/01/92	59.57
1005445984	10/03/91	08/19/02	31	248880	564	1V	5887D	12/01/92	59.31
1005445984	10/03/91	07/19/02	30	222720	540	1V	5887D	12/01/92	57.28
1005445984	10/03/91	06/19/02	30	219480	540	1V	5887D	12/01/92	56.45
1005445984	10/03/91	05/20/02	31	228000	540	1V	5887D	12/01/92	56.75
1005445984	10/03/91	04/19/02	29	192000	540	1V	5887D	12/01/92	51.09
1005445984	10/03/91	03/21/02	29	171720	480	1V	5887D	12/01/92	51.40
1005445984	10/03/91	02/20/02	29	171840	516	1V	5887D	12/01/92	47.85
1005445984	10/03/91	01/22/02	35	188880	528	1V	5887D	12/01/92	42.59
1005445984	10/03/91	12/18/01	33	227760	540	1V	5887D	12/01/92	53.25
1005445984	10/03/91	11/15/01	29	188760	540	1V	5887D	12/01/92	50.22
1005445984	10/03/91	10/17/01	29	229680	540	1V	5887D	12/01/92	61.11
1005445984	10/03/91	09/18/01	32	244320	540	1V	5887D	12/01/92	58.91
1005445984	10/03/91	08/17/01	29	217920	540	1V	5887D	12/01/92	57.98
1005445984	10/03/91	07/19/01	30	224160	540	1V	5887D	12/01/92	57.65
1005445984	10/03/91	06/19/01	32	244800	540	1V	5887D	12/01/92	59.03
1005445984	10/03/91	05/18/01	29	194400	504	1V	5887D	12/01/92	55.42
1005445984	10/03/91	04/19/01	29	182640	528	1V	5887D	12/01/92	49.70
1005445984	10/03/91	03/21/01	29	191280	504	1V	5887D	12/01/92	54.53
1005445984	10/03/91	02/20/01	29	183960	576	1V	5887D	12/01/92	45.89
1005445984	10/03/91	01/22/01	34	178920	480	1V	5887D	12/01/92	45.68
1005445984	10/03/91	12/19/00	33	204600	480	1V	5887D	12/01/92	53.82
1005445984	10/03/91	11/16/00	29	195120	504	1V	5887D	12/01/92	55.62
1005445984	10/03/91	10/18/00	29	224400	540	1V	5887D	12/01/92	59.71
1005445984	10/03/91	09/19/00	32	265560	540	1V	5887D	12/01/92	64.03
1005445984	10/03/91	08/18/00	30	243240	552	1V	5887D	12/01/92	61.20
1005445984	10/03/91	07/19/00	30	224040	552	1V	5887D	12/01/92	56.37
1005445984	10/03/91	06/19/00	32	223560	540	1V	5887D	12/01/92	53.91

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
1005445984	10/03/91	05/18/00	29	197880	516	1V	5887D	12/01/92	55.10
1005445984	10/03/91	04/19/00	29	179280	480	1V	5887D	12/01/92	53.66
1005445984	10/03/91	03/21/00	29	170760	504	1V	5887D	12/01/92	48.68
1005445984	10/03/91	02/21/00	32	165720	480	1V	5887D	12/01/92	44.95
1005445984	10/03/91	01/20/00	34	181080	504	1V	5887D	12/01/92	44.03
1005445984	10/03/91	12/17/99	30	180360	480	1V	5887D	12/01/92	52.19
1005445984	10/03/91	11/17/99	29	174960	504	1V	5887D	12/01/92	49.88
1005445984	10/03/91	10/19/99	29	196680	516	1V	5887D	12/01/92	54.76
1005445984	10/03/91	09/20/99	32	233640	552	1V	5887D	12/01/92	55.11
1005445984	10/03/91	08/19/99	30	216600	480	1V	5887D	12/01/92	62.67
1005445984	10/03/91	07/20/99	32	223440	540	1V	5887D	12/01/92	53.88
1005445984	10/03/91	06/18/99	30	220320	540	1V	5887D	12/01/92	56.67
1005445984	10/03/91	05/19/99	29	189480	492	1V	5887D	12/01/92	55.33
1005445984	10/03/91	04/20/99	32	195840	480	1V	5887D	12/01/92	53.13
1005445984	10/03/91	03/19/99	29	147960	432	1V	5887D	12/01/92	49.21
1005445984	10/03/91	02/18/99	29	162600	480	1V	5887D	12/01/92	48.67
1005445984	10/03/91	01/20/99	34	180840	480	1V	5887D	12/01/92	46.17
1005445984	10/03/91	12/17/98	30	189360	504	1V	5887D	12/01/92	52.18
1005445984	10/03/91	11/17/98	32	199080	504	1V	5887D	12/01/92	51.43
1005445984	10/03/91	10/16/98	29	202800	528	1V	5887D	12/01/92	55.19
1005445984	10/03/91	09/17/98	30	205080	540	1V	5887D	12/01/92	52.75
1005445984	10/03/91	08/18/98	29	213240	516	1V	5887D	12/01/92	59.38
1005445984	10/03/91	07/20/98	32	235320	516	1V	5887D	12/01/92	59.38
1005445984	10/03/91	06/18/98	30	216960	480	1V	5887D	12/01/92	62.78
1005445984	10/03/91	05/19/98	29	179400	480	1V	5887D	12/01/92	53.70
1005445984	10/03/91	04/20/98	31	190440	480	1V	5887D	12/01/92	53.33
1005445984	10/03/91	03/20/98	29	161040	480	1V	5887D	12/01/92	48.20
1005445984	10/03/91	02/19/98	30	148200	420	1V	5887D	12/01/92	49.01
1005445984	10/03/91	01/20/98	34	177000	480	1V	5887D	12/01/92	45.19
1005445984	10/03/91	12/17/97	30	174120	480	1V	5887D	12/01/92	50.38
1005445984	10/03/91	11/17/97	30	173880	480	1V	5887D	12/01/92	50.31
1005445984	10/03/91	10/16/97	30	211560	540	1V	5887D	12/01/92	54.41
1005445984	10/03/91	09/16/97	30	235560	540	1V	5887D	12/01/92	60.59
1005445984	10/03/91	08/15/97	30	214200	540	1V	5887D	12/01/92	55.09
1005445984	10/03/91	07/17/97	30	219240	492	1V	5887D	12/01/92	61.89
1005445984	10/03/91	06/17/97	30	226920	480	1V	5887D	12/01/92	65.66
1005445984	10/03/91	05/16/97	30	181920	480	1V	5887D	12/01/92	52.64
1005445984	10/03/91	04/17/97	30	174840	480	1V	5887D	12/01/92	50.59

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
1005445984	10/03/91	03/19/97	30	190560	480	1V	5887D	12/01/92	55.14
1005445984	10/03/91	02/17/97	30	171120	444	1V	5887D	12/01/92	53.53
1005445984	10/03/91	01/16/97	30	165000	432	1V	5887D	12/01/92	53.05
1005445984	10/03/91	12/16/96	30	177000	480	1V	5887D	12/01/92	51.22
1005445984	10/03/91	11/14/96	30	193800	504	1V	5887D	12/01/92	53.41
1005445984	10/03/91	10/15/96	30	201480	540	1V	5887D	12/01/92	51.82
1005445984	10/03/91	09/16/96	30	243480	540	1V	5887D	12/01/92	62.62
1005445984	10/03/91	08/15/96	30	225960	516	1V	5887D	12/01/92	60.82
1005445984	10/03/91	07/17/96	30	231480	516	1V	5887D	12/01/92	62.31
1005445984	10/03/91	06/17/96	30	231360	480	1V	5887D	12/01/92	66.94
1005445984	10/03/91	05/16/96	30	196560	480	1V	5887D	12/01/92	56.88
1005445984	10/03/91	04/17/96	30	163800	480	1V	5887D	12/01/92	47.40
1005445984	10/03/91	03/19/96	30	163080	480	1V	5887D	12/01/92	47.19
1005445984	10/03/91	02/19/96	30	162000	456	1V	5887D	12/01/92	49.34
1005445984	10/03/91	01/19/96	30	163200	420	1V	5887D	12/01/92	53.97
1005445984	10/03/91	12/18/95	30	171360	480	1V	5887D	12/01/92	49.58
1005445984	10/03/91	11/16/95	30	191040	480	1V	5887D	12/01/92	55.28
1005445984	10/03/91	10/17/95	30	217800	480	1V	5887D	12/01/92	63.02
1005445984	10/03/91	09/18/95	30	242280	480	1V	5887D	12/01/92	70.10
1005445984	10/03/91	08/17/95	30	223680	504	1V	5887D	12/01/92	61.64
1005445984	10/03/91	07/19/95	30	221520	504	1V	5887D	12/01/92	61.04
1005445984	10/03/91	06/19/95	30	224280	480	1V	5887D	12/01/92	64.90
1005445984	10/03/91	05/18/95	30	200520	480	1V	5887D	12/01/92	58.02
1005445984	10/03/91	04/19/95	30	172800	444	1V	5887D	12/01/92	54.05
1005445984	10/03/91	03/21/95	30	156360	408	1V	5887D	12/01/92	53.23
1005445984	10/03/91	02/20/95	30	159000	420	1V	5887D	12/01/92	52.58
1005445984	10/03/91	01/20/95	30	160560	360	1V	5887D	12/01/92	61.94
1005445984	10/03/91	12/20/94	30	200760	480	1V	5887D	12/01/92	58.09
1005445984	10/03/91	11/18/94	30	197160	480	1V	5887D	12/01/92	57.05
1005445984	10/03/91	10/19/94	30	207000	492	1V	5887D	12/01/92	58.43
1005445984	10/03/91	09/19/94	30	230880	504	1V	5887D	12/01/92	63.62
1005445984	10/03/91	08/18/94	30	204720	480	1V	5887D	12/01/92	59.24
1005445984	10/03/91	07/20/94	30	220200	504	1V	5887D	12/01/92	60.68
1005445984	10/03/91	06/20/94	30	217920	480	1V	5887D	12/01/92	63.06
1005445984	10/03/91	05/19/94	30	193440	480	1V	5887D	12/01/92	55.97
1005445984	10/03/91	04/20/94	30	174840	456	1V	5887D	12/01/92	53.25
1005445984	10/03/91	03/22/94	30	168840	408	1V	5887D	12/01/92	57.48
1005445984	10/03/91	02/18/94	30	147360	396	1V	5887D	12/01/92	51.68

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
1005445984	10/03/91	01/20/94	30	146520	360	1V	5887D	12/01/92	56.53
1005445984	10/03/91	12/20/93	30	167160	408	1V	5887D	12/01/92	56.90
1005445984	10/03/91	11/18/93	30	192600	456	1V	5887D	12/01/92	58.66
1005445984	10/03/91	10/19/93	30	185040	468	1V	5887D	12/01/92	54.91
1005445984	10/03/91	09/20/93	30	224400	480	1V	5887D	12/01/92	64.93
1005445984	10/03/91	08/19/93	30	216960	480	1V	5887D	12/01/92	62.78
1005445984	10/03/91	07/20/93	30	212280	480	1V	5887D	12/01/92	61.42
1005445984	10/03/91	06/18/93	30	191040	480	1V	5887D	12/01/92	55.28
1005445984	10/03/91	05/19/93	30	171960	432	1V	5887D	12/01/92	55.29
1005445984	10/03/91	04/20/93	30	163680	372	1V	5887D	12/01/92	61.11
1005445984	10/03/91	03/19/93	30	131400	348	1V	5887D	12/01/92	52.44

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>5900 Lake Worth Rd, Greenacres</b>									
1365472420	01/29/98	06/04/03	29	206040	439	6V	52784	11/06/02	67.43
1365472420	01/29/98	05/05/03	31	200760	427	6V	52784	11/06/02	63.19
1365472420	01/29/98	04/04/03	29	190200	452	6V	52784	11/06/02	60.46
1365472420	01/29/98	03/06/03	30	192360	462	6V	52784	11/06/02	57.83
1365472420	01/29/98	02/04/03	32	175320	371	6V	52784	11/06/02	61.53
1365472420	01/29/98	01/03/03	31	186000	451	6V	52784	11/06/02	55.43
1365472420	01/29/98	12/03/02	33	207600	467	6V	52784	11/06/02	56.13
1365472420	01/29/98	10/31/02	29	202560	480	1V	55773	06/11/02	60.63
1365472420	01/29/98	10/02/02	29	213240	480	1V	55773	06/11/02	63.83
1365472420	01/29/98	09/03/02	33	242520	480	1V	55773	06/11/02	63.79
1365472420	01/29/98	08/02/02	29	210840	480	1V	55773	06/11/02	63.11
1365472420	01/29/98	07/03/02	30	192120	456	1V	55773	06/11/02	58.52
1365472420	01/29/98	06/04/02	31	184200	480	1V	51108	10/17/97	51.58
1365472420	01/29/98	05/03/02	29	159480	408	1V	51108	10/17/97	56.16
1365472420	01/29/98	04/04/02	29	154560	444	1V	51108	10/17/97	50.02
1365472420	01/29/98	03/06/02	29	161280	372	1V	51108	10/17/97	62.29
1365472420	01/29/98	02/05/02	19	100560	396	1V	51108	10/17/97	55.69
1365472420	01/29/98	01/17/02	34	178320	444	1V	51108	10/17/97	49.22
1365472420	01/29/98	12/14/01	31	174120	444	1V	51108	10/17/97	52.71
1365472420	01/29/98	11/13/01	29	169440	420	1V	51108	10/17/97	57.96
1365472420	01/29/98	10/15/01	31	174360	456	1V	51108	10/17/97	51.39
1365472420	01/29/98	09/14/01	30	209520	460	1V	51108	10/17/97	63.26
1365472420	01/29/98	08/15/01	29	168720	480	1V	51108	10/17/97	50.50
1365472420	01/29/98	07/17/01	32	186480	480	1V	51108	10/17/97	50.59
1365472420	01/29/98	06/15/01	30	189600	456	1V	51108	10/17/97	57.75
1365472420	01/29/98	05/16/01	29	156600	432	1V	51108	10/17/97	52.08
1365472420	01/29/98	04/17/01	28	156000	420	1V	51108	10/17/97	55.27
1365472420	01/29/98	03/19/01	31	184320	420	1V	51108	10/17/97	58.99
1365472420	01/29/98	02/16/01	29	167280	420	1V	51108	10/17/97	57.22
1365472420	01/29/98	01/18/01	35	188160	420	1V	51108	10/17/97	53.33
1365472420	01/29/98	12/15/00	31	190680	444	1V	51108	10/17/97	57.72
1365472420	01/29/98	11/14/00	29	178920	432	1V	51108	10/17/97	59.51
1365472420	01/29/98	10/16/00	31	211680	456	1V	51108	10/17/97	62.39
1365472420	01/29/98	09/15/00	30	210240	444	1V	51108	10/17/97	65.77
1365472420	01/29/98	08/16/00	30	216720	456	1V	51108	10/17/97	66.01
1365472420	01/29/98	07/17/00	32	225000	456	1V	51108	10/17/97	64.25
1365472420	01/29/98	06/15/00	30	203280	444	1V	51108	10/17/97	63.59

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
1365472420	01/29/98	05/16/00	29	177360	420	1V	51108	10/17/97	60.67
1365472420	01/29/98	04/17/00	32	193680	444	1V	51108	10/17/97	56.80
1365472420	01/29/98	03/17/00	29	166440	420	1V	51108	10/17/97	56.94
1365472420	01/29/98	02/16/00	29	148560	420	1V	51108	10/17/97	50.82
1365472420	01/29/98	01/18/00	34	194400	444	1V	51108	10/17/97	53.66
1365472420	01/29/98	12/15/99	30	185520	420	1V	51108	10/17/97	61.35
1365472420	01/29/98	11/15/99	31	193680	420	1V	51108	10/17/97	61.98
1365472420	01/29/98	10/15/99	29	203400	432	1V	51108	10/17/97	67.65
1365472420	01/29/98	09/16/99	30	213720	456	1V	51108	10/17/97	65.10
1365472420	01/29/98	08/17/99	32	242160	456	1V	51108	10/17/97	69.15
1365472420	01/29/98	07/16/99	30	212880	432	1V	51108	10/17/97	68.44
1365472420	01/29/98	06/16/99	30	207720	432	1V	51108	10/17/97	66.78
1365472420	01/29/98	05/17/99	31	202560	444	1V	51108	10/17/97	61.32
1365472420	01/29/98	04/16/99	30	197280	444	1V	51108	10/17/97	61.71
1365472420	01/29/98	03/17/99	29	164400	420	1V	51108	10/17/97	56.24
1365472420	01/29/98	02/16/99	32	197040	420	1V	51108	10/17/97	61.09
1365472420	01/29/98	01/15/99	31	184680	408	1V	51108	10/17/97	60.84
1365472420	01/29/98	12/15/98	32	210960	408	1V	51108	10/17/97	67.33
1365472420	01/29/98	11/13/98	30	194520	444	1V	51108	10/17/97	60.85
1365472420	01/29/98	10/14/98	29	219840	480	1V	51108	10/17/97	65.80
1365472420	01/29/98	09/15/98	32	261840	480	1V	51108	10/17/97	71.03
1365472420	01/29/98	08/14/98	29	228480	420	1V	51108	10/17/97	78.16
1365472420	01/29/98	07/16/98	30	232680	420	1V	51108	10/17/97	76.94
1365472420	01/29/98	06/16/98	32	238800	420	1V	51108	10/17/97	74.03
1365472420	01/29/98	05/15/98	29	198720	420	1V	51108	10/17/97	67.98
1365472420	01/29/98	04/16/98	29	185040	420	1V	51108	10/17/97	63.30
1365472420	01/29/98	03/18/98	29	167400	420	1V	51108	10/17/97	57.27
1365472420	01/29/98	02/17/98	19	89760	372	1V	51108	10/17/97	52.91



Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>1200 Linton Blvd, Delray Beach</b>									
1385410566	06/21/91	06/09/03	30	211080	462	6V	5901D	11/06/02	63.46
1385410566	06/21/91	05/08/03	30	186240	446	6V	5901D	11/06/02	58.00
1385410566	06/21/91	04/09/03	28	175800	418	6V	5901D	11/06/02	62.59
1385410566	06/21/91	03/11/03	32	204120	409	6V	5901D	11/06/02	64.98
1385410566	06/21/91	02/07/03	30	180240	366	6V	5901D	11/06/02	68.40
1385410566	06/21/91	01/08/03	33	214440	406	6V	5901D	11/06/02	66.69
1385410566	06/21/91	12/06/02	31	216360	422	6V	5901D	11/06/02	68.91
1385410566	06/21/91	11/05/02	29	210840	432	1V	5025D	06/01/91	70.12
1385410566	06/21/91	10/07/02	31	222360	432	1V	5025D	06/01/91	69.18
1385410566	06/21/91	09/06/02	30	237960	480	1V	5025D	06/01/91	68.85
1385410566	06/21/91	08/07/02	29	208200	444	1V	5025D	06/01/91	67.37
1385410566	06/21/91	07/09/02	32	208560	480	1V	5025D	06/01/91	56.58
1385410566	06/21/91	06/07/02	30	203640	480	1V	5025D	06/01/91	58.92
1385410566	06/21/91	05/08/02	29	193920	420	1V	5025D	06/01/91	66.34
1385410566	06/21/91	04/09/02	29	208800	480	1V	5025D	06/01/91	62.50
1385410566	06/21/91	03/11/02	32	213000	420	1V	5025D	06/01/91	66.03
1385410566	06/21/91	02/08/02	30	212280	480	1V	5025D	06/01/91	61.42
1385410566	06/21/91	01/09/02	34	239520	480	1V	5025D	06/01/91	61.15
1385410566	06/21/91	12/06/01	30	226440	444	1V	5025D	06/01/91	70.83
1385410566	06/21/91	11/05/01	31	254280	480	1V	5025D	06/01/91	71.20
1385410566	06/21/91	10/05/01	30	255240	504	1V	5025D	06/01/91	70.34
1385410566	06/21/91	09/06/01	29	279960	516	1V	5025D	06/01/91	77.95
1385410566	06/21/91	08/07/01	31	253200	540	1V	5025D	06/01/91	63.02
1385410566	06/21/91	07/09/01	31	231840	480	1V	5025D	06/01/91	64.92
1385410566	06/21/91	06/07/01	29	206640	480	1V	5025D	06/01/91	61.85
1385410566	06/21/91	05/08/01	29	188280	480	1V	5025D	06/01/91	56.36
1385410566	06/21/91	04/09/01	31	198480	480	1V	5025D	06/01/91	55.58
1385410566	06/21/91	03/09/01	30	185160	444	1V	5025D	06/01/91	57.92
1385410566	06/21/91	02/08/01	29	166200	444	1V	5025D	06/01/91	53.78
1385410566	06/21/91	01/09/01	33	181080	432	1V	5025D	06/01/91	52.93
1385410566	06/21/91	12/07/00	31	193440	480	1V	5025D	06/01/91	54.17
1385410566	06/21/91	11/06/00	31	197880	480	1V	5025D	06/01/91	55.41
1385410566	06/21/91	10/06/00	29	220560	480	1V	5025D	06/01/91	66.02
1385410566	06/21/91	09/07/00	30	243600	480	1V	5025D	06/01/91	70.49
1385410566	06/21/91	08/08/00	32	249720	480	1V	5025D	06/01/91	67.74
1385410566	06/21/91	07/07/00	31	242400	480	1V	5025D	06/01/91	67.88
1385410566	06/21/91	06/07/00	29	215640	480	1V	5025D	06/01/91	64.55

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
1385410566	06/21/91	05/08/00	32	209640	480	1V	5025D	06/01/91	56.87
1385410566	06/21/91	04/07/00	29	193200	468	1V	5025D	06/01/91	59.31
1385410566	06/21/91	03/09/00	29	174120	456	1V	5025D	06/01/91	54.86
1385410566	06/21/91	02/08/00	32	180480	420	1V	5025D	06/01/91	55.95
1385410566	06/21/91	01/08/00	31	205560	456	1V	5025D	06/01/91	60.59
1385410566	06/21/91	12/07/99	32	219000	360	1V	5025D	06/01/91	79.21
1385410566	06/21/91	11/05/99	29	215400	480	1V	5025D	06/01/91	64.48
1385410566	06/21/91	10/07/99	29	231480	468	1V	5025D	06/01/91	71.07
1385410566	06/21/91	09/08/99	30	229800	492	1V	5025D	06/01/91	64.87
1385410566	06/21/91	08/09/99	32	256560	492	1V	5025D	06/01/91	67.90
1385410566	06/21/91	07/08/99	30	221880	480	1V	5025D	06/01/91	64.20
1385410566	06/21/91	06/08/99	33	240360	480	1V	5025D	06/01/91	63.23
1385410566	06/21/91	05/07/99	28	190920	480	1V	5025D	06/01/91	59.19
1385410566	06/21/91	04/08/99	30	185400	468	1V	5025D	06/01/91	55.02
1385410566	06/21/91	03/09/99	29	169080	456	1V	5025D	06/01/91	53.27
1385410566	06/21/91	02/08/99	31	191160	444	1V	5025D	06/01/91	57.87
1385410566	06/21/91	01/08/99	32	224520	468	1V	5025D	06/01/91	62.47
1385410566	06/21/91	12/07/98	33	243120	468	1V	5025D	06/01/91	65.59
1385410566	06/21/91	11/04/98	30	225360	504	1V	5025D	06/01/91	62.10
1385410566	06/21/91	10/06/98	31	231960	480	1V	5025D	06/01/91	64.95
1385410566	06/21/91	09/04/98	30	241440	492	1V	5025D	06/01/91	68.16
1385410566	06/21/91	08/06/98	28	235680	516	1V	5025D	06/01/91	67.97
1385410566	06/21/91	07/08/98	30	235560	481	1V	5025D	06/01/91	68.02
1385410566	06/21/91	06/08/98	32	240600	480	1V	5025D	06/01/91	65.27
1385410566	06/21/91	05/07/98	29	188280	432	1V	5025D	06/01/91	62.62
1385410566	06/21/91	04/08/98	30	182040	420	1V	5025D	06/01/91	60.20
1385410566	06/21/91	03/10/98	32	183840	432	1V	5025D	06/01/91	55.41
1385410566	06/21/91	02/06/98	28	160320	480	1V	5025D	06/01/91	49.70
1385410566	06/21/91	01/08/98	34	209640	456	1V	5025D	06/01/91	56.34
1385410566	06/21/91	12/05/97	30	197280	456	1V	5025D	06/01/91	60.09
1385410566	06/21/91	11/04/97	30	204840	480	1V	5025D	06/01/91	59.27
1385410566	06/21/91	10/06/97	30	237240	468	1V	5025D	06/01/91	70.41
1385410566	06/21/91	09/04/97	30	255840	492	1V	5025D	06/01/91	72.22
1385410566	06/21/91	08/05/97	30	224520	516	1V	5025D	06/01/91	60.43
1385410566	06/21/91	07/07/97	30	230160	480	1V	5025D	06/01/91	66.60
1385410566	06/21/91	06/05/97	30	203760	480	1V	5025D	06/01/91	58.96
1385410566	06/21/91	05/06/97	30	183720	450	1V	5025D	06/01/91	56.70
1385410566	06/21/91	04/07/97	30	189000	420	1V	5025D	06/01/91	62.50

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
1385410566	06/21/91	03/07/97	30	184800	450	1V	5025D	06/01/91	57.04
1385410566	06/21/91	02/05/97	30	159960	444	1V	5025D	06/01/91	50.04
1385410566	06/21/91	01/06/97	30	188760	450	1V	5025D	06/01/91	58.26
1385410566	06/21/91	12/04/96	30	198600	480	1V	5025D	06/01/91	57.47
1385410566	06/21/91	11/01/96	30	190560	480	1V	5025D	06/01/91	55.14
1385410566	06/21/91	10/03/96	30	215880	480	1V	5025D	06/01/91	62.47
1385410566	06/21/91	09/04/96	30	222720	504	1V	5025D	06/01/91	61.38
1385410566	06/21/91	08/05/96	30	246240	480	1V	5025D	06/01/91	71.25
1385410566	06/21/91	07/05/96	30	233040	480	1V	5025D	06/01/91	67.43
1385410566	06/21/91	06/05/96	30	219960	480	1V	5025D	06/01/91	63.65
1385410566	06/21/91	05/06/96	30	177960	456	1V	5025D	06/01/91	54.20
1385410566	06/21/91	04/05/96	30	164280	480	1V	5025D	06/01/91	47.53
1385410566	06/21/91	03/07/96	30	157440	420	1V	5025D	06/01/91	52.06
1385410566	06/21/91	02/07/96	30	156840	420	1V	5025D	06/01/91	51.87
1385410566	06/21/91	01/08/96	30	188760	456	1V	5025D	06/01/91	57.49
1385410566	06/21/91	12/06/95	30	209280	480	1V	5025D	06/01/91	60.56
1385410566	06/21/91	11/03/95	30	210960	480	1V	5025D	06/01/91	61.04
1385410566	06/21/91	10/05/95	30	196320	480	1V	5025D	06/01/91	56.81
1385410566	06/21/91	09/06/95	30	222600	492	1V	5025D	06/01/91	62.84
1385410566	06/21/91	08/07/95	30	222360	480	1V	5025D	06/01/91	64.34
1385410566	06/21/91	07/07/95	30	200400	480	1V	5025D	06/01/91	57.99
1385410566	06/21/91	06/07/95	30	205320	480	1V	5025D	06/01/91	59.41
1385410566	06/21/91	05/08/95	30	210120	480	1V	5025D	06/01/91	60.80
1385410566	06/21/91	04/07/95	30	159600	432	1V	5025D	06/01/91	51.31
1385410566	06/21/91	03/09/95	30	154080	428	1V	5025D	06/01/91	50.00
1385410566	06/21/91	02/08/95	30	142680	360	1V	5025D	06/01/91	55.05
1385410566	06/21/91	01/09/95	30	166560	396	1V	5025D	06/01/91	58.42
1385410566	06/21/91	12/08/94	30	197760	480	1V	5025D	06/01/91	57.22
1385410566	06/21/91	11/05/94	30	191400	480	1V	5025D	06/01/91	55.38
1385410566	06/21/91	10/06/94	30	177360	456	1V	5025D	06/01/91	54.02
1385410566	06/21/91	09/07/94	30	206880	480	1V	5025D	06/01/91	59.86
1385410566	06/21/91	08/08/94	30	214920	480	1V	5025D	06/01/91	62.19
1385410566	06/21/91	07/08/94	30	218760	480	1V	5025D	06/01/91	63.30
1385410566	06/21/91	06/08/94	30	191640	420	1V	5025D	06/01/91	63.37
1385410566	06/21/91	05/09/94	30	189720	480	1V	5025D	06/01/91	54.90
1385410566	06/21/91	04/08/94	30	166680	420	1V	5025D	06/01/91	55.12
1385410566	06/21/91	03/10/94	30	166440	420	1V	5025D	06/01/91	55.04
1385410566	06/21/91	02/08/94	30	159120	360	1V	5025D	06/01/91	61.39

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
1385410566	06/21/91	01/08/94	30	165240	420	1V	5025D	06/01/91	54.64
1385410566	06/21/91	12/08/93	30	202080	420	1V	5025D	06/01/91	66.83
1385410566	06/21/91	11/05/93	30	176520	480	1V	5025D	06/01/91	51.08
1385410566	06/21/91	10/07/93	30	194400	480	1V	5025D	06/01/91	56.25
1385410566	06/21/91	09/08/93	30	210360	480	1V	5025D	06/01/91	60.87
1385410566	06/21/91	08/09/93	30	214680	480	1V	5025D	06/01/91	62.12
1385410566	06/21/91	07/08/93	30	196320	480	1V	5025D	06/01/91	56.81
1385410566	06/21/91	06/08/93	30	184080	444	1V	5025D	06/01/91	57.58
1385410566	06/21/91	05/07/93	30	146040	420	1V	5025D	06/01/91	48.29
1385410566	06/21/91	04/08/93	30	149760	420	1V	5025D	06/01/91	49.52
1385410566	06/21/91	03/09/93	30	154680	360	1V	5025D	06/01/91	59.68

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>8201 SW 3 St, Plantation</b>									
1435862774	11/23/88	06/13/03	30	0	0	6V	56010D	01/28/97	-
1435862774	11/23/88	05/14/03	29	0	0	6V	56010D	01/28/97	-
1435862774	11/23/88	04/15/03	29	0	0	6V	56010D	01/28/97	-
1435862774	11/23/88	03/17/03	30	0	70	6V	56010D	01/28/97	0.00
1435862774	11/23/88	02/13/03	30	0	70	6V	56010D	01/28/97	0.00
1435862774	11/23/88	01/14/03	33	144720	332	6V	56010D	01/28/97	55.04
1435862774	11/23/88	12/12/02	31	164640	353	6V	56010D	01/28/97	62.69
1435862774	11/23/88	11/11/02	31	174960	322	6V	56010D	01/28/97	73.03
1435862774	11/23/88	10/11/02	29	174600	319	6V	56010D	01/28/97	78.64
1435862774	11/23/88	09/12/02	30	183720	374	6V	56010D	01/28/97	68.23
1435862774	11/23/88	08/13/02	29	185400	358	6V	56010D	01/28/97	74.41
1435862774	11/23/88	07/15/02	32	177000	318	6V	56010D	01/28/97	72.47
1435862774	11/23/88	06/13/02	30	165600	312	6V	56010D	01/28/97	73.72
1435862774	11/23/88	05/14/02	29	167640	340	6V	56010D	01/28/97	70.84
1435862774	11/23/88	04/15/02	31	172560	326	6V	56010D	01/28/97	71.15
1435862774	11/23/88	03/15/02	29	148080	343	6V	56010D	01/28/97	62.03
1435862774	11/23/88	02/14/02	30	162960	311	6V	56010D	01/28/97	72.78
1435862774	11/23/88	01/15/02	34	171000	316	6V	56010D	01/28/97	66.32
1435862774	11/23/88	12/12/01	33	181200	306	6V	56010D	01/28/97	74.77
1435862774	11/23/88	11/09/01	29	164640	320	6V	56010D	01/28/97	73.92
1435862774	11/23/88	10/11/01	29	170520	336	6V	56010D	01/28/97	72.92
1435862774	11/23/88	09/12/01	30	187920	353	6V	56010D	01/28/97	73.94
1435862774	11/23/88	08/13/01	31	190080	352	6V	56010D	01/28/97	72.58
1435862774	11/23/88	07/13/01	31	182160	343	6V	56010D	01/28/97	71.38
1435862774	11/23/88	06/13/01	29	168120	353	6V	56010D	01/28/97	68.43
1435862774	11/23/88	05/14/01	31	164520	342	6V	56010D	01/28/97	64.66
1435862774	11/23/88	04/13/01	29	150120	337	6V	56010D	01/28/97	64.00
1435862774	11/23/88	03/15/01	29	150240	362	6V	56010D	01/28/97	59.63
1435862774	11/23/88	02/14/01	29	139680	342	6V	56010D	01/28/97	58.68
1435862774	11/23/88	01/16/01	34	143400	358	6V	56010D	01/28/97	49.09
1435862774	11/23/88	12/13/00	33	171120	360	6V	56010D	01/28/97	60.02
1435862774	11/23/88	11/10/00	29	155880	310	6V	56010D	01/28/97	72.25
1435862774	11/23/88	10/12/00	29	167160	368	6V	56010D	01/28/97	65.26
1435862774	11/23/88	09/13/00	30	179880	376	6V	56010D	01/28/97	66.45
1435862774	11/23/88	08/14/00	33	194640	317	6V	56010D	01/28/97	77.53
1435862774	11/23/88	07/13/00	29	170520	325	6V	56010D	01/28/97	75.38
1435862774	11/23/88	06/13/00	32	183360	324	6V	56010D	01/28/97	73.69

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
1435862774	11/23/88	05/12/00	29	161520	349	6V	56010D	01/28/97	66.50
1435862774	11/23/88	04/13/00	29	157440	343	6V	56010D	01/28/97	65.95
1435862774	11/23/88	03/15/00	30	156840	299	6V	56010D	01/28/97	72.85
1435862774	11/23/88	02/14/00	32	147600	280	6V	56010D	01/28/97	68.64
1435862774	11/23/88	01/13/00	31	171120	325	6V	56010D	01/28/97	70.77
1435862774	11/23/88	12/13/99	32	180360	324	6V	56010D	01/28/97	72.48
1435862774	11/23/88	11/11/99	29	171000	346	6V	56010D	01/28/97	71.01
1435862774	11/23/88	10/13/99	29	201120	360	6V	56010D	01/28/97	80.27
1435862774	11/23/88	09/14/99	32	186360	338	6V	56010D	01/28/97	71.79
1435862774	11/23/88	08/13/99	30	172440	342	6V	56010D	01/28/97	70.03
1435862774	11/23/88	07/14/99	30	169920	362	6V	56010D	01/28/97	65.19
1435862774	11/23/88	06/14/99	32	181680	328	6V	56010D	01/28/97	72.12
1435862774	11/23/88	05/13/99	30	151920	272	6V	56010D	01/28/97	77.57
1435862774	11/23/88	04/14/99	29	137400	301	6V	56010D	01/28/97	65.59
1435862774	11/23/88	03/15/99	31	146760	290	6V	56010D	01/28/97	68.02
1435862774	11/23/88	02/12/99	30	149880	277	6V	56010D	01/28/97	75.15
1435862774	11/23/88	01/13/99	34	171360	332	6V	56010D	01/28/97	63.25
1435862774	11/23/88	12/11/98	30	164640	332	6V	56010D	01/28/97	68.88
1435862774	11/23/88	11/10/98	29	155400	301	6V	56010D	01/28/97	74.18
1435862774	11/23/88	10/12/98	31	179160	338	6V	56010D	01/28/97	71.24
1435862774	11/23/88	09/11/98	30	178440	334	6V	56010D	01/28/97	74.20
1435862774	11/23/88	08/12/98	29	163440	329	6V	56010D	01/28/97	71.38
1435862774	11/23/88	07/14/98	32	181440	334	6V	56010D	01/28/97	70.73
1435862774	11/23/88	06/12/98	30	169800	316	6V	56010D	01/28/97	74.63
1435862774	11/23/88	05/13/98	29	152040	306	6V	56010D	01/28/97	71.39
1435862774	11/23/88	04/14/98	29	146160	308	6V	56010D	01/28/97	68.18
1435862774	11/23/88	03/16/98	32	158640	307	6V	56010D	01/28/97	67.28
1435862774	11/23/88	02/12/98	31	139320	270	6V	56010D	01/28/97	69.35
1435862774	11/23/88	01/13/98	32	155640	294	6V	56010D	01/28/97	68.93
1435862774	11/23/88	12/11/97	30	154200	298	6V	56010D	01/28/97	71.87
1435862774	11/23/88	11/10/97	30	156960	308	6V	56010D	01/28/97	70.78
1435862774	11/23/88	10/10/97	30	168120	301	6V	56010D	01/28/97	77.57
1435862774	11/23/88	09/10/97	30	162120	320	6V	56010D	01/28/97	70.36
1435862774	11/23/88	08/11/97	30	169320	318	6V	56010D	01/28/97	73.95
1435862774	11/23/88	07/11/97	30	169920	318	6V	56010D	01/28/97	74.21
1435862774	11/23/88	06/11/97	30	152160	310	6V	56010D	01/28/97	68.17
1435862774	11/23/88	05/12/97	30	152760	308	6V	56010D	01/28/97	68.89
1435862774	11/23/88	04/11/97	30	137400	308	6V	56010D	01/28/97	61.96

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
1435862774	11/23/88	03/13/97	30	154800	299	6V	56010D	01/28/97	71.91
1435862774	11/23/88	02/11/97	30	117960	281	6V	56010D	01/28/97	58.30
1435862774	11/23/88	01/10/97	30	96000	281	6V	5560D	02/15/94	47.45
1435862774	11/23/88	12/10/96	30	110520	275	6V	5560D	02/15/94	55.82
1435862774	11/23/88	11/07/96	30	98640	191	6V	5560D	02/15/94	71.73
1435862774	11/23/88	10/09/96	30	150840	293	6V	5560D	02/15/94	71.50
1435862774	11/23/88	09/10/96	30	170760	295	6V	5560D	02/15/94	80.40
1435862774	11/23/88	08/09/96	30	158400	295	6V	5560D	02/15/94	74.58
1435862774	11/23/88	07/11/96	30	147840	290	6V	5560D	02/15/94	70.80
1435862774	11/23/88	06/11/96	30	154440	286	6V	5560D	02/15/94	75.00
1435862774	11/23/88	05/10/96	30	138360	286	6V	5560D	02/15/94	67.19
1435862774	11/23/88	04/11/96	30	129840	283	6V	5560D	02/15/94	63.72
1435862774	11/23/88	03/13/96	30	130920	281	6V	5560D	02/15/94	64.71
1435862774	11/23/88	02/13/96	30	141600	281	6V	5560D	02/15/94	69.99
1435862774	11/23/88	01/12/96	30	127080	293	6V	5560D	02/15/94	60.24
1435862774	11/23/88	12/12/95	30	107040	264	6V	5560D	02/15/94	56.31
1435862774	11/23/88	11/09/95	30	96240	194	6V	5560D	02/15/94	68.90
1435862774	11/23/88	10/11/95	30	98640	198	6V	5560D	02/15/94	69.19
1435862774	11/23/88	09/12/95	30	110760	196	6V	5560D	02/15/94	78.49
1435862774	11/23/88	08/11/95	30	102480	199	6V	5560D	02/15/94	71.52
1435862774	11/23/88	07/13/95	30	93840	192	6V	5560D	02/15/94	67.88
1435862774	11/23/88	06/13/95	30	106560	203	6V	5560D	02/15/94	72.91
1435862774	11/23/88	05/12/95	30	92160	190	6V	5560D	02/15/94	67.37
1435862774	11/23/88	04/13/95	30	114600	274	6V	5560D	02/15/94	58.09
1435862774	11/23/88	03/15/95	30	131280	287	6V	5560D	02/15/94	63.53
1435862774	11/23/88	02/14/95	30	136560	283	6V	5560D	02/15/94	67.02
1435862774	11/23/88	01/13/95	30	136800	282	6V	5560D	02/15/94	67.38
1435862774	11/23/88	12/14/94	30	156000	300	6V	5560D	02/15/94	72.22
1435862774	11/23/88	11/14/94	30	160320	301	6V	5560D	02/15/94	73.98
1435862774	11/23/88	10/12/94	30	147480	293	6V	5560D	02/15/94	69.91
1435862774	11/23/88	09/13/94	30	181920	293	6V	5560D	02/15/94	86.23
1435862774	11/23/88	08/12/94	30	145080	301	6V	5560D	02/15/94	66.94
1435862774	11/23/88	07/14/94	30	148680	304	6V	5560D	02/15/94	67.93
1435862774	11/23/88	06/14/94	30	159120	311	6V	5560D	02/15/94	71.06
1435862774	11/23/88	05/13/94	30	145200	300	6V	5560D	02/15/94	67.22
1435862774	11/23/88	04/14/94	30	140880	299	6V	5560D	02/15/94	65.44
1435862774	11/23/88	03/16/94	30	144240	312	6V	5560D	02/15/94	64.21
1435862774	11/23/88	02/14/94	30	152280	312	1V	51304	08/01/87	67.79

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
1435862774	11/23/88	01/13/94	30	137280	306	1V	51304	08/01/87	62.31
1435862774	11/23/88	12/14/93	30	153240	312	1V	51304	08/01/87	68.22
1435862774	11/23/88	11/12/93	30	141720	318	1V	51304	08/01/87	61.90
1435862774	11/23/88	10/13/93	30	143280	312	1V	51304	08/01/87	63.78
1435862774	11/23/88	09/14/93	30	156000	312	1V	51304	08/01/87	69.44
1435862774	11/23/88	08/13/93	30	141120	312	1V	51304	08/01/87	62.82
1435862774	11/23/88	07/14/93	30	141000	300	1V	51304	08/01/87	65.28
1435862774	11/23/88	06/14/93	30	151320	312	1V	51304	08/01/87	67.36
1435862774	11/23/88	05/13/93	30	130680	300	1V	51304	08/01/87	60.50
1435862774	11/23/88	04/14/93	30	133080	300	1V	51304	08/01/87	61.61
1435862774	11/23/88	03/15/93	30	138000	288	1V	51304	08/01/87	66.55



Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>9905 Southern Blvd, West Palm Beach</b>									
1622926937	03/26/92	06/05/03	30	263760	536	9V	5580H	07/01/92	68.35
1622926937	03/26/92	05/06/03	29	243000	504	9V	5580H	07/01/92	69.27
1622926937	03/26/92	04/07/03	31	227400	475	9V	5580H	07/01/92	64.35
1622926937	03/26/92	03/07/03	30	217200	493	9V	5580H	07/01/92	61.19
1622926937	03/26/92	02/05/03	30	203640	428	9V	5580H	07/01/92	66.08
1622926937	03/26/92	01/06/03	33	260520	492	9V	5580H	07/01/92	66.86
1622926937	03/26/92	12/04/02	33	275880	507	9V	5580H	07/01/92	68.70
1622926937	03/26/92	11/01/02	29	267960	505	9V	5580H	07/01/92	76.24
1622926937	03/26/92	10/03/02	29	277200	498	9V	5580H	07/01/92	79.98
1622926937	03/26/92	09/04/02	30	296040	499	9V	5580H	07/01/92	82.40
1622926937	03/26/92	08/05/02	31	315240	533	9V	5580H	07/01/92	79.50
1622926937	03/26/92	07/05/02	30	251040	510	9V	5580H	07/01/92	68.37
1622926937	03/26/92	06/05/02	30	255840	503	9V	5580H	07/01/92	70.64
1622926937	03/26/92	05/06/02	31	247200	507	9V	5580H	07/01/92	65.53
1622926937	03/26/92	04/05/02	29	216000	478	9V	5580H	07/01/92	64.93
1622926937	03/26/92	03/07/02	29	192240	465	9V	5580H	07/01/92	59.40
1622926937	03/26/92	02/06/02	30	202320	430	9V	5580H	07/01/92	65.35
1622926937	03/26/92	01/07/02	34	236880	474	9V	5580H	07/01/92	61.24
1622926937	03/26/92	12/04/01	33	233280	476	9V	5580H	07/01/92	61.88
1622926937	03/26/92	11/01/01	29	221160	486	9V	5580H	07/01/92	65.38
1622926937	03/26/92	10/03/01	29	222240	516	9V	5580H	07/01/92	61.88
1622926937	03/26/92	09/04/01	32	275520	518	9V	5580H	07/01/92	69.26
1622926937	03/26/92	08/03/01	29	243720	542	9V	5580H	07/01/92	64.61
1622926937	03/26/92	07/05/01	30	238560	486	9V	5580H	07/01/92	68.18
1622926937	03/26/92	06/05/01	32	250800	472	9V	5580H	07/01/92	69.19
1622926937	03/26/92	05/04/01	21	146160	460	9V	5580H	07/01/92	63.04
1622926937	03/26/92	04/13/01	29	198600	468	9V	5580H	07/01/92	60.97
1622926937	03/26/92	03/15/01	29	195600	445	9V	5580H	07/01/92	63.15
1622926937	03/26/92	02/14/01	29	181200	441	9V	5580H	07/01/92	59.04
1622926937	03/26/92	01/16/01	34	204240	444	9V	5580H	07/01/92	56.37
1622926937	03/26/92	12/13/00	33	233160	459	9V	5580H	07/01/92	64.14
1622926937	03/26/92	11/10/00	29	205800	443	9V	5580H	07/01/92	66.75
1622926937	03/26/92	10/12/00	29	236160	524	9V	5580H	07/01/92	64.75
1622926937	03/26/92	09/13/00	30	244560	504	9V	5580H	07/01/92	67.39
1622926937	03/26/92	08/14/00	32	270960	509	9V	5580H	07/01/92	69.31
1622926937	03/26/92	07/13/00	30	242280	492	9V	5580H	07/01/92	68.39
1622926937	03/26/92	06/13/00	32	255000	489	9V	5580H	07/01/92	67.90

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
1622926937	03/26/92	05/12/00	29	208920	462	9V	5580H	07/01/92	64.97
1622926937	03/26/92	04/13/00	29	204840	460	9V	5580H	07/01/92	63.98
1622926937	03/26/92	03/15/00	30	202320	434	9V	5580H	07/01/92	64.75
1622926937	03/26/92	02/14/00	32	191040	397	9V	5580H	07/01/92	62.66
1622926937	03/26/92	01/13/00	31	207120	479	9V	5580H	07/01/92	58.12
1622926937	03/26/92	12/13/99	32	224760	453	9V	5580H	07/01/92	64.60
1622926937	03/26/92	11/11/99	29	207720	453	9V	5580H	07/01/92	65.88
1622926937	03/26/92	10/13/99	29	223920	462	9V	5580H	07/01/92	69.64
1622926937	03/26/92	09/14/99	32	242280	470	9V	5580H	07/01/92	67.12
1622926937	03/26/92	08/13/99	30	238320	482	9V	5580H	07/01/92	68.67
1622926937	03/26/92	07/14/99	30	223680	494	9V	5580H	07/01/92	62.89
1622926937	03/26/92	06/14/99	32	243840	472	9V	5580H	07/01/92	67.27
1622926937	03/26/92	05/13/99	29	203280	465	9V	5580H	07/01/92	62.81
1622926937	03/26/92	04/14/99	30	214680	514	9V	5580H	07/01/92	58.01
1622926937	03/26/92	03/15/99	31	190200	413	9V	5580H	07/01/92	61.90
1622926937	03/26/92	02/12/99	30	192240	421	9V	5580H	07/01/92	63.42
1622926937	03/26/92	01/13/99	33	206880	451	9V	5580H	07/01/92	57.92
1622926937	03/26/92	12/11/98	31	218160	467	9V	5580H	07/01/92	62.79
1622926937	03/26/92	11/10/98	29	207120	451	9V	5580H	07/01/92	65.98
1622926937	03/26/92	10/12/98	31	243480	489	9V	5580H	07/01/92	66.92
1622926937	03/26/92	09/11/98	30	247800	500	9V	5580H	07/01/92	68.83
1622926937	03/26/92	08/12/98	29	233760	484	9V	5580H	07/01/92	69.39
1622926937	03/26/92	07/14/98	32	263880	539	9V	5580H	07/01/92	63.75
1622926937	03/26/92	06/12/98	30	234120	528	9V	5580H	07/01/92	61.58
1622926937	03/26/92	05/13/98	29	205440	472	9V	5580H	07/01/92	62.54
1622926937	03/26/92	04/14/98	29	194880	460	9V	5580H	07/01/92	60.87
1622926937	03/26/92	03/16/98	32	201120	435	9V	5580H	07/01/92	60.20
1622926937	03/26/92	02/12/98	30	183240	411	9V	5580H	07/01/92	61.92
1622926937	03/26/92	01/13/98	33	213120	458	9V	5580H	07/01/92	58.75
1622926937	03/26/92	12/11/97	30	211440	464	9V	5580H	07/01/92	63.29
1622926937	03/26/92	11/10/97	30	214680	490	9V	5580H	07/01/92	60.85
1622926937	03/26/92	10/10/97	30	230880	494	9V	5580H	07/01/92	64.91
1622926937	03/26/92	09/10/97	30	239040	500	9V	5580H	07/01/92	66.40
1622926937	03/26/92	08/11/97	30	246480	483	9V	5580H	07/01/92	70.88
1622926937	03/26/92	07/11/97	30	245400	498	9V	5580H	07/01/92	68.44
1622926937	03/26/92	06/11/97	30	229560	524	9V	5580H	07/01/92	60.85
1622926937	03/26/92	05/12/97	30	212280	477	9V	5580H	07/01/92	61.81
1622926937	03/26/92	04/11/97	30	191640	436	9V	5580H	07/01/92	61.05

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
1622926937	03/26/92	03/13/97	30	199320	429	9V	5580H	07/01/92	64.53
1622926937	03/26/92	02/11/97	30	190920	415	9V	5580H	07/01/92	63.90
1622926937	03/26/92	01/10/97	30	193200	416	9V	5580H	07/01/92	64.50
1622926937	03/26/92	12/10/96	30	215400	437	9V	5580H	07/01/92	68.46
1622926937	03/26/92	11/07/96	30	205800	453	9V	5580H	07/01/92	63.10
1622926937	03/26/92	10/09/96	30	215520	491	9V	5580H	07/01/92	60.96
1622926937	03/26/92	09/10/96	30	245760	494	9V	5580H	07/01/92	69.10
1622926937	03/26/92	08/09/96	30	226560	510	9V	5580H	07/01/92	61.70
1622926937	03/26/92	07/11/96	30	233640	497	9V	5580H	07/01/92	65.29
1622926937	03/26/92	06/11/96	30	227160	456	9V	5580H	07/01/92	69.19
1622926937	03/26/92	05/10/96	30	194400	453	9V	5580H	07/01/92	59.60
1622926937	03/26/92	04/11/96	30	182880	441	9V	5580H	07/01/92	57.60
1622926937	03/26/92	03/13/96	30	176640	414	9V	5580H	07/01/92	59.26
1622926937	03/26/92	02/13/96	30	190320	396	9V	5580H	07/01/92	66.75
1622926937	03/26/92	01/12/96	30	180480	424	9V	5580H	07/01/92	59.12
1622926937	03/26/92	12/12/95	30	217320	447	9V	5580H	07/01/92	67.52
1622926937	03/26/92	11/09/95	30	210720	481	9V	5580H	07/01/92	60.85
1622926937	03/26/92	10/11/95	30	233280	494	9V	5580H	07/01/92	65.59
1622926937	03/26/92	09/12/95	30	255240	537	9V	5580H	07/01/92	66.01
1622926937	03/26/92	08/11/95	30	231240	547	9V	5580H	07/01/92	58.71
1622926937	03/26/92	07/13/95	30	232320	523	9V	5580H	07/01/92	61.70
1622926937	03/26/92	06/13/95	30	244560	497	9V	5580H	07/01/92	68.34
1622926937	03/26/92	05/12/95	30	207120	494	9V	5580H	07/01/92	58.23
1622926937	03/26/92	04/13/95	30	192600	441	9V	5580H	07/01/92	60.66
1622926937	03/26/92	03/15/95	30	179880	438	9V	5580H	07/01/92	57.04
1622926937	03/26/92	02/14/95	30	175440	406	9V	5580H	07/01/92	60.02
1622926937	03/26/92	01/13/95	30	178560	425	9V	5580H	07/01/92	58.35
1622926937	03/26/92	12/14/94	30	202560	452	9V	5580H	07/01/92	62.24
1622926937	03/26/92	11/14/94	30	225720	474	9V	5580H	07/01/92	66.14
1622926937	03/26/92	10/12/94	30	220560	514	9V	5580H	07/01/92	59.60
1622926937	03/26/92	09/13/94	30	247440	505	9V	5580H	07/01/92	68.05
1622926937	03/26/92	08/12/94	30	214680	487	9V	5580H	07/01/92	61.23
1622926937	03/26/92	07/14/94	30	224040	494	9V	5580H	07/01/92	62.99
1622926937	03/26/92	06/14/94	30	218880	480	9V	5580H	07/01/92	63.33
1622926937	03/26/92	05/13/94	30	192960	468	9V	5580H	07/01/92	57.26
1622926937	03/26/92	04/14/94	30	179280	453	9V	5580H	07/01/92	54.97
1622926937	03/26/92	03/16/94	30	167880	408	9V	5580H	07/01/92	57.15
1622926937	03/26/92	02/14/94	30	176640	422	9V	5580H	07/01/92	58.14

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
1622926937	03/26/92	01/13/94	30	159240	394	9V	5580H	07/01/92	56.13
1622926937	03/26/92	12/14/93	30	209640	451	9V	5580H	07/01/92	64.56
1622926937	03/26/92	11/12/93	30	204600	467	9V	5580H	07/01/92	60.85
1622926937	03/26/92	10/13/93	30	194880	468	9V	5580H	07/01/92	57.83
1622926937	03/26/92	09/14/93	30	222960	499	9V	5580H	07/01/92	62.06
1622926937	03/26/92	08/13/93	30	212880	494	9V	5580H	07/01/92	59.85
1622926937	03/26/92	07/14/93	30	199200	478	9V	5580H	07/01/92	57.88
1622926937	03/26/92	06/14/93	30	206160	534	9V	5580H	07/01/92	53.62
1622926937	03/26/92	05/13/93	30	156720	407	9V	5580H	07/01/92	53.48
1622926937	03/26/92	04/14/93	30	153360	394	9V	5580H	07/01/92	54.06
1622926937	03/26/92	03/15/93	30	147360	391	9V	5580H	07/01/92	52.34

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>9905 Southern Blvd #IRR, West Palm Beach</b>									
1629927912	05/13/92	06/05/03	30	26	0	5J	32675	05/01/92	-
1629927912	05/13/92	05/06/03	29	52	0	5J	32675	05/01/92	-
1629927912	05/13/92	04/07/03	31	0	0	5J	32675	05/01/92	-
1629927912	05/13/92	03/07/03	30	0	0	5J	32675	05/01/92	-
1629927912	05/13/92	02/05/03	30	0	0	5J	32675	05/01/92	-
1629927912	05/13/92	01/06/03	33	256	0	5J	32675	05/01/92	-
1629927912	05/13/92	12/04/02	34	12	0	5J	32675	05/01/92	-
1629927912	05/13/92	11/01/02	28	0	0	5J	32675	05/01/92	-
1629927912	05/13/92	10/03/02	29	0	0	5J	32675	05/01/92	-
1629927912	05/13/92	09/04/02	30	54	0	5J	32675	05/01/92	-
1629927912	05/13/92	08/05/02	31	50	0	5J	32675	05/01/92	-
1629927912	05/13/92	07/05/02	30	361	0	5J	32675	05/01/92	-
1629927912	05/13/92	06/05/02	30	1307	0	5J	32675	05/01/92	-
1629927912	05/13/92	05/06/02	31	205	0	5J	32675	05/01/92	-
1629927912	05/13/92	04/05/02	29	961	0	5J	32675	05/01/92	-
1629927912	05/13/92	03/07/02	29	170	0	5J	32675	05/01/92	-
1629927912	05/13/92	02/06/02	30	398	0	5J	32675	05/01/92	-
1629927912	05/13/92	01/07/02	34	236	0	5J	32675	05/01/92	-
1629927912	05/13/92	12/04/01	33	17	0	5J	32675	05/01/92	-
1629927912	05/13/92	11/01/01	29	207	0	5J	32675	05/01/92	-
1629927912	05/13/92	10/03/01	29	325	0	5J	32675	05/01/92	-
1629927912	05/13/92	09/04/01	32	383	0	5J	32675	05/01/92	-
1629927912	05/13/92	08/03/01	29	58	0	5J	32675	05/01/92	-
1629927912	05/13/92	07/05/01	30	16	0	5J	32675	05/01/92	-
1629927912	05/13/92	06/05/01	32	11	0	5J	32675	05/01/92	-
1629927912	05/13/92	05/04/01	21	54	0	5J	32675	05/01/92	-
1629927912	05/13/92	04/13/01	29	493	0	5J	32675	05/01/92	-
1629927912	05/13/92	03/15/01	28	165	0	5J	32675	05/01/92	-
1629927912	05/13/92	02/14/01	30	41	0	5J	32675	05/01/92	-
1629927912	05/13/92	01/16/01	34	135	0	5J	32675	05/01/92	-
1629927912	05/13/92	12/13/00	33	322	0	5J	32675	05/01/92	-
1629927912	05/13/92	11/10/00	29	81	0	5J	32675	05/01/92	-
1629927912	05/13/92	10/12/00	29	0	0	5J	32675	05/01/92	-
1629927912	05/13/92	09/13/00	30	1338	0	5J	32675	05/01/92	-
1629927912	05/13/92	08/14/00	33	828	0	5J	32675	05/01/92	-
1629927912	05/13/92	07/13/00	29	313	0	5J	32675	05/01/92	-
1629927912	05/13/92	06/13/00	32	1010	0	5J	32675	05/01/92	-

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
1629927912	05/13/92	05/12/00	29	71	0	5J	32675	05/01/92	-
1629927912	05/13/92	04/13/00	29	41	0	5J	32675	05/01/92	-
1629927912	05/13/92	03/15/00	30	248	0	5J	32675	05/01/92	-
1629927912	05/13/92	02/14/00	32	105	0	5J	32675	05/01/92	-
1629927912	05/13/92	01/13/00	31	1408	0	5J	32675	05/01/92	-
1629927912	05/13/92	12/13/99	32	825	0	5J	32675	05/01/92	-
1629927912	05/13/92	11/11/99	29	673	0	5J	32675	05/01/92	-
1629927912	05/13/92	10/13/99	29	209	0	5J	32675	05/01/92	-
1629927912	05/13/92	09/14/99	32	231	0	5J	32675	05/01/92	-
1629927912	05/13/92	08/13/99	30	896	0	5J	32675	05/01/92	-
1629927912	05/13/92	07/14/99	30	1014	0	5J	32675	05/01/92	-
1629927912	05/13/92	06/14/99	32	768	0	5J	32675	05/01/92	-
1629927912	05/13/92	05/13/99	29	446	0	5J	32675	05/01/92	-
1629927912	05/13/92	04/14/99	30	1061	0	5J	32675	05/01/92	-
1629927912	05/13/92	03/15/99	31	1162	0	5J	32675	05/01/92	-
1629927912	05/13/92	02/12/99	30	1453	0	5J	32675	05/01/92	-
1629927912	05/13/92	01/13/99	33	1545	0	5J	32675	05/01/92	-
1629927912	05/13/92	12/11/98	31	1401	0	5J	32675	05/01/92	-
1629927912	05/13/92	11/10/98	29	1236	0	5J	32675	05/01/92	-
1629927912	05/13/92	10/12/98	31	1273	0	5J	32675	05/01/92	-
1629927912	05/13/92	09/11/98	30	1305	0	5J	32675	05/01/92	-
1629927912	05/13/92	08/12/98	29	1186	0	5J	32675	05/01/92	-
1629927912	05/13/92	07/14/98	32	1148	0	5J	32675	05/01/92	-
1629927912	05/13/92	06/12/98	30	1079	0	5J	32675	05/01/92	-
1629927912	05/13/92	05/13/98	29	1098	0	5J	32675	05/01/92	-
1629927912	05/13/92	04/14/98	29	771	0	5J	32675	05/01/92	-
1629927912	05/13/92	03/16/98	32	653	0	5J	32675	05/01/92	-
1629927912	05/13/92	02/12/98	30	740	0	5J	32675	05/01/92	-
1629927912	05/13/92	01/13/98	33	1031	0	5J	32675	05/01/92	-
1629927912	05/13/92	12/11/97	30	973	0	5J	32675	05/01/92	-
1629927912	05/13/92	11/10/97	30	802	0	5J	32675	05/01/92	-
1629927912	05/13/92	10/10/97	30	766	0	5J	32675	05/01/92	-
1629927912	05/13/92	09/10/97	30	712	0	5J	32675	05/01/92	-
1629927912	05/13/92	08/11/97	30	617	0	5J	32675	05/01/92	-
1629927912	05/13/92	07/11/97	30	368	0	5J	32675	05/01/92	-
1629927912	05/13/92	06/11/97	30	1003	0	5J	32675	05/01/92	-
1629927912	05/13/92	05/12/97	30	708	0	5J	32675	05/01/92	-
1629927912	05/13/92	04/11/97	30	562	0	5J	32675	05/01/92	-

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
1629927912	05/13/92	03/13/97	30	686	0	5J	32675	05/01/92	-
1629927912	05/13/92	02/11/97	30	698	0	5J	32675	05/01/92	-
1629927912	05/13/92	01/10/97	30	930	0	5J	32675	05/01/92	-
1629927912	05/13/92	12/10/96	30	954	0	5J	32675	05/01/92	-
1629927912	05/13/92	11/07/96	30	384	0	5J	32675	05/01/92	-
1629927912	05/13/92	10/09/96	30	215	0	5J	32675	05/01/92	-
1629927912	05/13/92	09/10/96	30	392	0	5J	32675	05/01/92	-
1629927912	05/13/92	08/09/96	30	503	0	5J	32675	05/01/92	-
1629927912	05/13/92	07/11/96	30	638	0	5J	32675	05/01/92	-
1629927912	05/13/92	06/11/96	30	1503	0	5J	32675	05/01/92	-
1629927912	05/13/92	05/10/96	30	1830	0	5J	32675	05/01/92	-
1629927912	05/13/92	04/11/96	30	1249	0	5J	32675	05/01/92	-
1629927912	05/13/92	03/13/96	30	823	0	5J	32675	05/01/92	-
1629927912	05/13/92	02/13/96	30	1072	0	5J	32675	05/01/92	-
1629927912	05/13/92	01/12/96	30	1021	0	5J	32675	05/01/92	-
1629927912	05/13/92	12/12/95	30	954	0	5J	32675	05/01/92	-
1629927912	05/13/92	11/09/95	30	733	0	5J	32675	05/01/92	-
1629927912	05/13/92	10/11/95	30	610	0	5J	32675	05/01/92	-
1629927912	05/13/92	09/12/95	30	763	0	5J	32675	05/01/92	-
1629927912	05/13/92	08/11/95	30	713	0	5J	32675	05/01/92	-
1629927912	05/13/92	07/13/95	30	677	0	5J	32675	05/01/92	-
1629927912	05/13/92	06/13/95	30	678	0	5J	32675	05/01/92	-
1629927912	05/13/92	05/12/95	30	706	0	5J	32675	05/01/92	-
1629927912	05/13/92	04/13/95	30	670	0	5J	32675	05/01/92	-
1629927912	05/13/92	03/15/95	30	589	0	5J	32675	05/01/92	-
1629927912	05/13/92	02/14/95	30	613	0	5J	32675	05/01/92	-
1629927912	05/13/92	01/13/95	30	207	0	5J	32675	05/01/92	-
1629927912	05/13/92	12/14/94	30	281	0	5J	32675	05/01/92	-
1629927912	05/13/92	11/14/94	30	462	0	5J	32675	05/01/92	-
1629927912	05/13/92	10/12/94	30	425	0	5J	32675	05/01/92	-
1629927912	05/13/92	09/13/94	30	805	0	5J	32675	05/01/92	-
1629927912	05/13/92	08/12/94	30	677	0	5J	32675	05/01/92	-
1629927912	05/13/92	07/14/94	30	374	0	5J	32675	05/01/92	-
1629927912	05/13/92	06/14/94	30	481	0	5J	32675	05/01/92	-
1629927912	05/13/92	05/13/94	30	509	0	5J	32675	05/01/92	-
1629927912	05/13/92	04/14/94	30	627	0	5J	32675	05/01/92	-
1629927912	05/13/92	03/16/94	30	392	0	5J	32675	05/01/92	-
1629927912	05/13/92	02/14/94	30	560	0	5J	32675	05/01/92	-

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
1629927912	05/13/92	01/13/94	30	525	0	5J	32675	05/01/92	-
1629927912	05/13/92	12/14/93	30	603	0	5J	32675	05/01/92	-
1629927912	05/13/92	11/12/93	30	506	0	5J	32675	05/01/92	-
1629927912	05/13/92	10/13/93	30	340	0	5J	32675	05/01/92	-
1629927912	05/13/92	09/14/93	30	380	0	5J	32675	05/01/92	-
1629927912	05/13/92	08/13/93	30	386	0	5J	32675	05/01/92	-
1629927912	05/13/92	07/14/93	30	387	0	5J	32675	05/01/92	-
1629927912	05/13/92	06/14/93	30	1111	0	5J	32675	05/01/92	-
1629927912	05/13/92	05/13/93	30	1386	0	5J	32675	05/01/92	-
1629927912	05/13/92	04/14/93	30	1303	0	5J	32675	05/01/92	-
1629927912	05/13/92	03/15/93	30	865	0	5J	32675	05/01/92	-



Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>8401 S Tamiami Trl, Sarasota</b>									
1891141697	06/14/91	06/13/03	30	228720	471	9V	7403H	02/23/99	67.45
1891141697	06/14/91	05/14/03	29	210000	476	9V	7403H	02/23/99	63.39
1891141697	06/14/91	04/15/03	29	185040	490	9V	7403H	02/23/99	54.26
1891141697	06/14/91	03/17/03	32	196800	427	9V	7403H	02/23/99	60.01
1891141697	06/14/91	02/13/03	30	162960	347	9V	7403H	02/23/99	65.23
1891141697	06/14/91	01/14/03	33	194160	431	9V	7403H	02/23/99	56.88
1891141697	06/14/91	12/12/02	31	191280	471	9V	7403H	02/23/99	54.59
1891141697	06/14/91	11/11/02	31	224880	465	9V	7403H	02/23/99	65.00
1891141697	06/14/91	10/11/02	29	226080	511	9V	7403H	02/23/99	63.57
1891141697	06/14/91	09/12/02	30	239760	534	9V	7403H	02/23/99	62.36
1891141697	06/14/91	08/13/02	29	240000	507	9V	7403H	02/23/99	68.01
1891141697	06/14/91	07/15/02	32	246720	487	9V	7403H	02/23/99	65.97
1891141697	06/14/91	06/13/02	30	227280	481	9V	7403H	02/23/99	65.63
1891141697	06/14/91	05/14/02	29	208800	450	9V	7403H	02/23/99	66.67
1891141697	06/14/91	04/15/02	31	206160	453	9V	7403H	02/23/99	61.17
1891141697	06/14/91	03/15/02	29	169200	466	9V	7403H	02/23/99	52.17
1891141697	06/14/91	02/14/02	30	180480	410	9V	7403H	02/23/99	61.14
1891141697	06/14/91	01/15/02	34	199680	461	9V	7403H	02/23/99	53.08
1891141697	06/14/91	12/12/01	33	248160	422	9V	7403H	02/23/99	74.25
1891141697	06/14/91	11/09/01	29	198240	500	9V	7403H	02/23/99	56.97
1891141697	06/14/91	10/11/01	29	212160	486	9V	7403H	02/23/99	62.72
1891141697	06/14/91	09/12/01	30	240960	505	9V	7403H	02/23/99	66.27
1891141697	06/14/91	08/13/01	31	239760	515	9V	7403H	02/23/99	62.57
1891141697	06/14/91	07/13/01	30	225360	498	9V	7403H	02/23/99	62.85
1891141697	06/14/91	06/13/01	30	222720	471	9V	7403H	02/23/99	65.68
1891141697	06/14/91	05/14/01	31	199200	459	9V	7403H	02/23/99	58.33
1891141697	06/14/91	04/13/01	29	181200	459	9V	7403H	02/23/99	56.72
1891141697	06/14/91	03/15/01	29	177840	462	9V	7403H	02/23/99	55.31
1891141697	06/14/91	02/14/01	29	167520	455	9V	7403H	02/23/99	52.90
1891141697	06/14/91	01/16/01	34	190800	404	9V	7403H	02/23/99	57.88
1891141697	06/14/91	12/13/00	33	202080	416	9V	7403H	02/23/99	61.33
1891141697	06/14/91	11/10/00	29	197520	423	9V	7403H	02/23/99	67.09
1891141697	06/14/91	10/12/00	29	217920	512	9V	7403H	02/23/99	61.15
1891141697	06/14/91	09/13/00	30	234000	520	9V	7403H	02/23/99	62.50
1891141697	06/14/91	08/14/00	32	252480	511	9V	7403H	02/23/99	64.33
1891141697	06/14/91	07/13/00	30	228720	481	9V	7403H	02/23/99	66.04
1891141697	06/14/91	06/13/00	32	238320	463	9V	7403H	02/23/99	67.02

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
1891141697	06/14/91	05/12/00	29	188880	427	9V	7403H	02/23/99	63.55
1891141697	06/14/91	04/13/00	29	180240	492	9V	7403H	02/23/99	52.64
1891141697	06/14/91	03/15/00	30	177840	410	9V	7403H	02/23/99	60.24
1891141697	06/14/91	02/14/00	32	172800	367	9V	7403H	02/23/99	61.31
1891141697	06/14/91	01/13/00	31	180960	463	9V	7403H	02/23/99	52.53
1891141697	06/14/91	12/13/99	32	196320	436	9V	7403H	02/23/99	58.63
1891141697	06/14/91	11/11/99	29	191520	510	9V	7403H	02/23/99	53.96
1891141697	06/14/91	10/13/99	29	215520	540	9V	7403H	02/23/99	57.34
1891141697	06/14/91	09/14/99	32	240240	517	9V	7403H	02/23/99	60.51
1891141697	06/14/91	08/13/99	30	231120	536	9V	7403H	02/23/99	59.89
1891141697	06/14/91	07/14/99	30	217200	506	9V	7403H	02/23/99	59.62
1891141697	06/14/91	06/14/99	32	223440	477	9V	7403H	02/23/99	60.99
1891141697	06/14/91	05/13/99	29	188400	480	9V	7403H	02/23/99	56.39
1891141697	06/14/91	04/14/99	30	181680	470	9V	7403H	02/23/99	53.69
1891141697	06/14/91	03/15/99	31	170640	420	9V	7403H	02/23/99	54.61
1891141697	06/14/91	02/12/99	30	182640	472	9V	7179H	08/17/98	53.74
1891141697	06/14/91	01/13/99	33	185520	450	9V	7179H	08/17/98	52.05
1891141697	06/14/91	12/11/98	31	202560	494	9V	7179H	08/17/98	55.11
1891141697	06/14/91	11/10/98	29	195120	463	9V	7179H	08/17/98	60.55
1891141697	06/14/91	10/12/98	31	231600	510	9V	7179H	08/17/98	61.04
1891141697	06/14/91	09/11/98	30	235200	510	9V	7179H	08/17/98	64.05
1891141697	06/14/91	08/12/98	29	224160	510	9V	7179H	08/17/98	63.15
1891141697	06/14/91	07/14/98	32	245280	529	9V	7019H	04/05/94	60.37
1891141697	06/14/91	06/12/98	30	216240	511	9V	7019H	04/05/94	58.77
1891141697	06/14/91	05/13/98	29	185760	484	9V	7019H	04/05/94	55.14
1891141697	06/14/91	04/14/98	29	172080	495	9V	7019H	04/05/94	49.95
1891141697	06/14/91	03/16/98	32	177600	440	9V	7019H	04/05/94	52.56
1891141697	06/14/91	02/12/98	30	153600	370	9V	7019H	04/05/94	57.66
1891141697	06/14/91	01/13/98	33	182400	407	9V	7019H	04/05/94	56.59
1891141697	06/14/91	12/11/97	30	179040	422	9V	7019H	04/05/94	58.93
1891141697	06/14/91	11/10/97	30	190320	427	9V	7019H	04/05/94	61.90
1891141697	06/14/91	10/10/97	30	209760	452	9V	7019H	04/05/94	64.45
1891141697	06/14/91	09/10/97	30	215280	467	9V	7019H	04/05/94	64.03
1891141697	06/14/91	08/11/97	30	224400	461	9V	7019H	04/05/94	67.61
1891141697	06/14/91	07/11/97	30	214800	460	9V	7019H	04/05/94	64.86
1891141697	06/14/91	06/11/97	30	198960	443	9V	7019H	04/05/94	62.38
1891141697	06/14/91	05/12/97	30	189120	428	9V	7019H	04/05/94	61.37
1891141697	06/14/91	04/11/97	30	172560	393	9V	7019H	04/05/94	60.98

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
1891141697	06/14/91	03/13/97	30	175920	395	9V	7019H	04/05/94	61.86
1891141697	06/14/91	02/11/97	30	163440	385	9V	7019H	04/05/94	58.96
1891141697	06/14/91	01/10/97	30	163920	492	9V	7019H	04/05/94	46.27
1891141697	06/14/91	12/10/96	30	186480	420	9V	7019H	04/05/94	61.67
1891141697	06/14/91	11/07/96	30	189840	469	9V	7019H	04/05/94	56.22
1891141697	06/14/91	10/09/96	30	212160	458	9V	7019H	04/05/94	64.34
1891141697	06/14/91	09/10/96	30	243120	532	9V	7019H	04/05/94	63.47
1891141697	06/14/91	08/09/96	30	224400	532	9V	7019H	04/05/94	58.58
1891141697	06/14/91	07/11/96	30	226320	485	9V	7019H	04/05/94	64.81
1891141697	06/14/91	06/11/96	30	231360	467	9V	7019H	04/05/94	68.81
1891141697	06/14/91	05/10/96	30	199680	439	9V	7019H	04/05/94	63.17
1891141697	06/14/91	04/11/96	30	163200	410	9V	7019H	04/05/94	55.28
1891141697	06/14/91	03/13/96	30	153120	375	9V	7019H	04/05/94	56.71
1891141697	06/14/91	02/13/96	30	171600	381	9V	7019H	04/05/94	62.55
1891141697	06/14/91	01/12/96	30	167760	390	9V	7019H	04/05/94	59.74
1891141697	06/14/91	12/12/95	30	190320	428	9V	7019H	04/05/94	61.76
1891141697	06/14/91	11/09/95	30	193680	451	9V	7019H	04/05/94	59.65
1891141697	06/14/91	10/11/95	30	216960	482	9V	7019H	04/05/94	62.52
1891141697	06/14/91	09/12/95	30	247680	507	9V	7019H	04/05/94	67.85
1891141697	06/14/91	08/11/95	30	227520	494	9V	7019H	04/05/94	63.97
1891141697	06/14/91	07/13/95	30	228240	490	9V	7019H	04/05/94	64.69
1891141697	06/14/91	06/13/95	30	239040	492	9V	7019H	04/05/94	67.48
1891141697	06/14/91	05/12/95	30	201120	516	9V	7019H	04/05/94	54.13
1891141697	06/14/91	04/13/95	30	183360	427	9V	7019H	04/05/94	59.64
1891141697	06/14/91	03/15/95	30	166560	389	9V	7019H	04/05/94	59.47
1891141697	06/14/91	02/14/95	30	166560	367	9V	7019H	04/05/94	63.03
1891141697	06/14/91	01/13/95	30	178080	393	9V	7019H	04/05/94	62.93
1891141697	06/14/91	12/14/94	30	213360	440	9V	7019H	04/05/94	67.35
1891141697	06/14/91	11/14/94	30	225840	460	9V	7019H	04/05/94	68.19
1891141697	06/14/91	10/12/94	30	213120	448	9V	7019H	04/05/94	66.07
1891141697	06/14/91	09/13/94	30	230640	496	9V	7019H	04/05/94	64.58
1891141697	06/14/91	08/12/94	30	205200	505	9V	7019H	04/05/94	56.44
1891141697	06/14/91	07/14/94	30	210000	476	9V	7019H	04/05/94	61.27
1891141697	06/14/91	06/14/94	30	214560	489	9V	7019H	04/05/94	60.94
1891141697	06/14/91	05/13/94	30	188400	451	9V	7019H	04/05/94	58.02
1891141697	06/14/91	04/14/94	30	178560	424	9V	7019H	04/05/94	58.49
1891141697	06/14/91	03/16/94	30	163920	396	9V	7548H	03/01/91	57.49
1891141697	06/14/91	02/14/94	30	165840	385	9V	7548H	03/01/91	59.83

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
1891141697	06/14/91	01/13/94	30	146400	360	9V	7548H	03/01/91	56.48
1891141697	06/14/91	12/14/93	30	182160	427	9V	7548H	03/01/91	59.25
1891141697	06/14/91	11/12/93	30	186000	429	9V	7548H	03/01/91	60.22
1891141697	06/14/91	10/13/93	30	188640	458	9V	7548H	03/01/91	57.21
1891141697	06/14/91	09/14/93	30	215040	478	9V	7548H	03/01/91	62.48
1891141697	06/14/91	08/13/93	30	203520	469	9V	7548H	03/01/91	60.27
1891141697	06/14/91	07/14/93	30	204960	503	9V	7548H	03/01/91	56.59
1891141697	06/14/91	06/14/93	30	197040	469	9V	7548H	03/01/91	58.35
1891141697	06/14/91	05/13/93	30	162960	429	9V	7548H	03/01/91	52.76
1891141697	06/14/91	04/14/93	30	156000	378	9V	7548H	03/01/91	57.32
1891141697	06/14/91	03/15/93	30	157200	346	9V	7548H	03/01/91	63.10

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>1771 Dunlawton Ave, Port Orange</b>									
2100310420	03/20/03	06/06/03	30	290800	684	6V	8270D	03/20/03	59.05
2100310420	03/20/03	05/07/03	29	204800	560	6V	8270D	03/20/03	52.55
2100310420	03/20/03	04/08/03	19	81600	416	6V	8270D	03/20/03	43.02

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>1760 Palm Beach Lakes Blvd, West Palm Beach</b>									
2167427208	11/22/88	06/18/03	30	194400	410	6V	5069D	01/06/99	65.85
2167427208	11/22/88	05/19/03	31	195960	396	6V	5069D	01/06/99	66.51
2167427208	11/22/88	04/18/03	29	165480	395	6V	5069D	01/06/99	60.19
2167427208	11/22/88	03/20/03	29	179040	395	6V	5069D	01/06/99	65.12
2167427208	11/22/88	02/19/03	33	169440	352	6V	5069D	01/06/99	60.78
2167427208	11/22/88	01/17/03	32	158280	352	6V	5069D	01/06/99	58.55
2167427208	11/22/88	12/16/02	32	174000	352	6V	5069D	01/06/99	64.36
2167427208	11/22/88	11/14/02	29	181560	352	6V	5069D	01/06/99	74.11
2167427208	11/22/88	10/16/02	29	198360	396	6V	5069D	01/06/99	71.97
2167427208	11/22/88	09/17/02	32	216960	362	6V	5069D	01/06/99	78.04
2167427208	11/22/88	08/16/02	29	205320	412	6V	5069D	01/06/99	71.60
2167427208	11/22/88	07/18/02	30	189720	353	6V	5069D	01/06/99	74.65
2167427208	11/22/88	06/18/02	32	200160	340	6V	5069D	01/06/99	76.65
2167427208	11/22/88	05/17/02	29	179640	347	6V	5069D	01/06/99	74.38
2167427208	11/22/88	04/18/02	29	164640	341	6V	5069D	01/06/99	69.37
2167427208	11/22/88	03/20/02	29	149880	322	6V	5069D	01/06/99	66.88
2167427208	11/22/88	02/19/02	32	165960	328	6V	5069D	01/06/99	65.88
2167427208	11/22/88	01/18/02	32	152400	312	6V	5069D	01/06/99	63.60
2167427208	11/22/88	12/17/01	33	196560	397	6V	5069D	01/06/99	62.51
2167427208	11/22/88	11/14/01	29	176880	416	6V	5069D	01/06/99	61.09
2167427208	11/22/88	10/16/01	29	189240	430	6V	5069D	01/06/99	63.23
2167427208	11/22/88	09/17/01	32	203160	358	6V	5069D	01/06/99	73.89
2167427208	11/22/88	08/16/01	29	183960	359	6V	5069D	01/06/99	73.62
2167427208	11/22/88	07/18/01	30	185040	374	6V	5069D	01/06/99	68.72
2167427208	11/22/88	06/18/01	32	196920	433	6V	5069D	01/06/99	59.22
2167427208	11/22/88	05/17/01	29	158280	396	6V	5069D	01/06/99	57.43
2167427208	11/22/88	04/18/01	29	154320	432	6V	5069D	01/06/99	51.33
2167427208	11/22/88	03/20/01	29	153120	384	6V	5069D	01/06/99	57.29
2167427208	11/22/88	02/19/01	31	150720	316	6V	5069D	01/06/99	64.11
2167427208	11/22/88	01/19/01	32	170520	395	6V	5069D	01/06/99	56.21
2167427208	11/22/88	12/18/00	33	198720	368	6V	5069D	01/06/99	68.18
2167427208	11/22/88	11/15/00	29	177600	343	6V	5069D	01/06/99	74.39
2167427208	11/22/88	10/17/00	29	191760	401	6V	5069D	01/06/99	68.71
2167427208	11/22/88	09/18/00	32	222240	403	6V	5069D	01/06/99	71.81
2167427208	11/22/88	08/17/00	30	205560	412	6V	5069D	01/06/99	69.30
2167427208	11/22/88	07/18/00	32	219480	418	6V	5069D	01/06/99	68.37
2167427208	11/22/88	06/16/00	30	200760	407	6V	5069D	01/06/99	68.51

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
2167427208	11/22/88	05/17/00	29	176880	382	6V	5069D	01/06/99	66.53
2167427208	11/22/88	04/18/00	29	168600	370	6V	5069D	01/06/99	65.47
2167427208	11/22/88	03/20/00	32	183480	337	6V	5069D	01/06/99	70.89
2167427208	11/22/88	02/17/00	29	148320	409	6V	5069D	01/06/99	52.10
2167427208	11/22/88	01/19/00	34	187800	409	6V	5069D	01/06/99	56.27
2167427208	11/22/88	12/16/99	30	168840	409	6V	5069D	01/06/99	57.33
2167427208	11/22/88	11/16/99	29	177000	409	6V	5069D	01/06/99	62.18
2167427208	11/22/88	10/18/99	31	179760	348	6V	5069D	01/06/99	69.43
2167427208	11/22/88	09/17/99	30	198000	409	6V	5069D	01/06/99	67.24
2167427208	11/22/88	08/18/99	30	200760	376	6V	5069D	01/06/99	74.16
2167427208	11/22/88	07/19/99	32	194040	376	6V	5069D	01/06/99	67.20
2167427208	11/22/88	06/17/99	30	180240	376	6V	5069D	01/06/99	66.58
2167427208	11/22/88	05/18/99	29	172320	376	6V	5069D	01/06/99	65.85
2167427208	11/22/88	04/19/99	32	181440	370	6V	5069D	01/06/99	63.85
2167427208	11/22/88	03/18/99	29	147840	324	6V	5069D	01/06/99	65.56
2167427208	11/22/88	02/17/99	29	156360	324	6V	5069D	01/06/99	69.34
2167427208	11/22/88	01/19/99	34	172618	306	6V	5069D	01/06/99	69.13
2167427208	11/22/88	12/16/98	30	152775	312	1V	52236	08/21/98	68.01
2167427208	11/22/88	11/16/98	32	164992	312	1V	52236	08/21/98	68.86
2167427208	11/22/88	10/15/98	29	164720	324	1V	52236	08/21/98	73.05
2167427208	11/22/88	09/16/98	30	156825	300	1V	52236	08/21/98	72.60
2167427208	11/22/88	08/17/98	31	190800	348	1V	51213	03/13/95	73.69
2167427208	11/22/88	07/17/98	30	181200	336	1V	51213	03/13/95	74.90
2167427208	11/22/88	06/17/98	30	177720	336	1V	51213	03/13/95	73.46
2167427208	11/22/88	05/18/98	31	166800	324	1V	51213	03/13/95	69.20
2167427208	11/22/88	04/17/98	29	147600	324	1V	51213	03/13/95	65.45
2167427208	11/22/88	03/19/98	29	143280	300	1V	51213	03/13/95	68.62
2167427208	11/22/88	02/18/98	33	159600	312	1V	51213	03/13/95	64.59
2167427208	11/22/88	01/16/98	31	154440	312	1V	51213	03/13/95	66.53
2167427208	11/22/88	12/16/97	30	162960	312	1V	51213	03/13/95	72.54
2167427208	11/22/88	11/14/97	30	154680	312	1V	51213	03/13/95	68.86
2167427208	11/22/88	10/15/97	30	170400	324	1V	51213	03/13/95	73.05
2167427208	11/22/88	09/15/97	30	167280	324	1V	51213	03/13/95	71.71
2167427208	11/22/88	08/14/97	30	166680	336	1V	51213	03/13/95	68.90
2167427208	11/22/88	07/16/97	30	167040	324	1V	51213	03/13/95	71.60
2167427208	11/22/88	06/16/97	30	171600	324	1V	51213	03/13/95	73.56
2167427208	11/22/88	05/15/97	30	147480	312	1V	51213	03/13/95	65.65
2167427208	11/22/88	04/16/97	30	139920	318	1V	51213	03/13/95	61.11

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
2167427208	11/22/88	03/18/97	30	154440	300	1V	51213	03/13/95	71.50
2167427208	11/22/88	02/14/97	30	132120	336	1V	51213	03/13/95	54.61
2167427208	11/22/88	01/15/97	30	155280	312	1V	51213	03/13/95	69.12
2167427208	11/22/88	12/13/96	30	142440	300	1V	51213	03/13/95	65.94
2167427208	11/22/88	11/13/96	30	161760	324	1V	51213	03/13/95	69.34
2167427208	11/22/88	10/14/96	30	166200	336	1V	51213	03/13/95	68.70
2167427208	11/22/88	09/13/96	30	158640	312	1V	51213	03/13/95	70.62
2167427208	11/22/88	08/14/96	30	158520	324	1V	51213	03/13/95	67.95
2167427208	11/22/88	07/16/96	30	168480	312	1V	51213	03/13/95	75.00
2167427208	11/22/88	06/14/96	30	153960	324	1V	51213	03/13/95	66.00
2167427208	11/22/88	05/15/96	30	148920	312	1V	51213	03/13/95	66.29
2167427208	11/22/88	04/16/96	30	137760	312	1V	51213	03/13/95	61.32
2167427208	11/22/88	03/18/96	30	146520	300	1V	51213	03/13/95	67.83
2167427208	11/22/88	02/16/96	30	134760	300	1V	51213	03/13/95	62.39
2167427208	11/22/88	01/18/96	30	153480	300	1V	51213	03/13/95	71.06
2167427208	11/22/88	12/15/95	30	147720	300	1V	51213	03/13/95	68.39
2167427208	11/22/88	11/15/95	30	154200	312	1V	51213	03/13/95	68.64
2167427208	11/22/88	10/16/95	30	166920	312	1V	51213	03/13/95	74.31
2167427208	11/22/88	09/15/95	30	162840	324	1V	51213	03/13/95	69.80
2167427208	11/22/88	08/16/95	30	161760	324	1V	51213	03/13/95	69.34
2167427208	11/22/88	07/18/95	30	172560	324	1V	51213	03/13/95	73.97
2167427208	11/22/88	06/16/95	30	163200	318	1V	51213	03/13/95	71.28
2167427208	11/22/88	05/17/95	30	156840	312	1V	51213	03/13/95	69.82
2167427208	11/22/88	04/18/95	30	143520	312	1V	51213	03/13/95	63.89
2167427208	11/22/88	03/20/95	30	144960	312	1V	51213	03/13/95	64.53
2167427208	11/22/88	02/17/95	30	123120	312	1V	5493D	04/01/92	54.81
2167427208	11/22/88	01/19/95	30	137040	300	1V	5493D	04/01/92	63.44
2167427208	11/22/88	12/19/94	30	162480	324	1V	5493D	04/01/92	69.65
2167427208	11/22/88	11/17/94	30	155880	324	1V	5493D	04/01/92	66.82
2167427208	11/22/88	10/18/94	30	168000	324	1V	5493D	04/01/92	72.02
2167427208	11/22/88	09/16/94	30	160320	324	1V	5493D	04/01/92	68.72
2167427208	11/22/88	08/17/94	30	156480	324	1V	5493D	04/01/92	67.08
2167427208	11/22/88	07/19/94	30	170160	324	1V	5493D	04/01/92	72.94
2167427208	11/22/88	06/17/94	30	152400	312	1V	5493D	04/01/92	67.84
2167427208	11/22/88	05/18/94	30	143520	324	1V	5493D	04/01/92	61.52
2167427208	11/22/88	04/19/94	30	141720	312	1V	5493D	04/01/92	63.09
2167427208	11/22/88	03/21/94	30	146640	312	1V	5493D	04/01/92	65.28
2167427208	11/22/88	02/17/94	30	134160	324	1V	5493D	04/01/92	57.51



Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
2167427208	11/22/88	01/19/94	30	145440	306	1V	5493D	04/01/92	66.01
2167427208	11/22/88	12/17/93	30	145680	312	1V	5493D	04/01/92	64.85
2167427208	11/22/88	11/17/93	30	152880	318	1V	5493D	04/01/92	66.77
2167427208	11/22/88	10/18/93	30	158760	312	1V	5493D	04/01/92	70.67
2167427208	11/22/88	09/17/93	30	154800	324	1V	5493D	04/01/92	66.36
2167427208	11/22/88	08/18/93	30	154440	324	1V	5493D	04/01/92	66.20
2167427208	11/22/88	07/19/93	30	161160	324	1V	5493D	04/01/92	69.08
2167427208	11/22/88	06/17/93	30	145680	324	1V	5493D	04/01/92	62.45
2167427208	11/22/88	05/18/93	30	133800	306	1V	5493D	04/01/92	60.73
2167427208	11/22/88	04/19/93	30	150720	300	1V	5493D	04/01/92	69.78
2167427208	11/22/88	03/18/93	30	118680	294	1V	5493D	04/01/92	56.07

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>20500 SW 112 Ave #SIGN, Miami</b>									
2411677368	10/28/97	06/12/03	30	725	0	5C	32546	09/22/97	-
2411677368	10/28/97	05/13/03	29	879	0	5C	32546	09/22/97	-
2411677368	10/28/97	04/14/03	31	949	0	5C	32546	09/22/97	-
2411677368	10/28/97	03/14/03	30	912	0	5C	32546	09/22/97	-
2411677368	10/28/97	02/12/03	30	923	0	5C	32546	09/22/97	-
2411677368	10/28/97	01/13/03	33	1020	0	5C	32546	09/22/97	-
2411677368	10/28/97	12/11/02	33	1007	0	5C	32546	09/22/97	-
2411677368	10/28/97	11/08/02	29	881	0	5C	32546	09/22/97	-
2411677368	10/28/97	10/10/02	29	870	0	5C	32546	09/22/97	-
2411677368	10/28/97	09/11/02	30	895	0	5C	32546	09/22/97	-
2411677368	10/28/97	08/12/02	31	919	0	5C	32546	09/22/97	-
2411677368	10/28/97	07/12/02	30	910	0	5C	32546	09/22/97	-
2411677368	10/28/97	06/12/02	30	903	0	5C	32546	09/22/97	-
2411677368	10/28/97	05/13/02	31	930	0	5C	32546	09/22/97	-
2411677368	10/28/97	04/12/02	29	879	0	5C	32546	09/22/97	-
2411677368	10/28/97	03/14/02	29	992	0	5C	32546	09/22/97	-
2411677368	10/28/97	02/13/02	30	818	0	5C	32546	09/22/97	-
2411677368	10/28/97	01/14/02	34	1045	0	5C	32546	09/22/97	-
2411677368	10/28/97	12/11/01	33	1009	0	5C	32546	09/22/97	-
2411677368	10/28/97	11/08/01	29	882	0	5C	32546	09/22/97	-
2411677368	10/28/97	10/10/01	29	876	0	5C	32546	09/22/97	-
2411677368	10/28/97	09/11/01	32	953	0	5C	32546	09/22/97	-
2411677368	10/28/97	08/10/01	29	875	0	5C	32546	09/22/97	-
2411677368	10/28/97	07/12/01	30	910	0	5C	32546	09/22/97	-
2411677368	10/28/97	06/12/01	32	809	0	5C	32546	09/22/97	-
2411677368	10/28/97	05/11/01	29	740	0	5C	32546	09/22/97	-
2411677368	10/28/97	04/12/01	29	737	0	5C	32546	09/22/97	-
2411677368	10/28/97	03/14/01	29	741	0	5C	32546	09/22/97	-
2411677368	10/28/97	02/13/01	32	829	0	5C	32546	09/22/97	-
2411677368	10/28/97	01/12/01	31	799	0	5C	32546	09/22/97	-
2411677368	10/28/97	12/12/00	33	848	0	5C	32546	09/22/97	-
2411677368	10/28/97	11/09/00	29	744	0	5C	32546	09/22/97	-
2411677368	10/28/97	10/11/00	29	729	0	5C	32546	09/22/97	-
2411677368	10/28/97	09/12/00	32	799	0	5C	32546	09/22/97	-
2411677368	10/28/97	08/11/00	30	862	0	5C	32546	09/22/97	-
2411677368	10/28/97	07/12/00	30	864	0	5C	32546	09/22/97	-
2411677368	10/28/97	06/12/00	32	923	0	5C	32546	09/22/97	-

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
2411677368	10/28/97	05/11/00	29	849	0	5C	32546	09/22/97	-
2411677368	10/28/97	04/12/00	29	854	0	5C	32546	09/22/97	-
2411677368	10/28/97	03/14/00	32	946	0	5C	32546	09/22/97	-
2411677368	10/28/97	02/11/00	30	892	0	5C	32546	09/22/97	-
2411677368	10/28/97	01/12/00	33	978	0	5C	32546	09/22/97	-
2411677368	10/28/97	12/10/99	31	909	0	5C	32546	09/22/97	-
2411677368	10/28/97	11/10/99	28	831	0	5C	32546	09/22/97	-
2411677368	10/28/97	10/12/99	29	749	0	5C	32546	09/22/97	-
2411677368	10/28/97	09/13/99	32	803	0	5C	32546	09/22/97	-
2411677368	10/28/97	08/12/99	30	620	0	5C	32546	09/22/97	-
2411677368	10/28/97	07/13/99	32	652	0	5C	32546	09/22/97	-
2411677368	10/28/97	06/11/99	30	585	0	5C	32546	09/22/97	-
2411677368	10/28/97	05/12/99	29	585	0	5C	32546	09/22/97	-
2411677368	10/28/97	04/13/99	32	681	0	5C	32546	09/22/97	-
2411677368	10/28/97	03/12/99	29	657	0	5C	32546	09/22/97	-
2411677368	10/28/97	02/11/99	30	709	0	5C	32546	09/22/97	-
2411677368	10/28/97	01/12/99	33	808	0	5C	32546	09/22/97	-
2411677368	10/28/97	12/10/98	31	828	0	5C	32546	09/22/97	-
2411677368	10/28/97	11/09/98	31	868	0	5C	32546	09/22/97	-
2411677368	10/28/97	10/09/98	29	769	0	5C	32546	09/22/97	-
2411677368	10/28/97	09/10/98	30	731	0	5C	32546	09/22/97	-
2411677368	10/28/97	08/11/98	29	671	0	5C	32546	09/22/97	-
2411677368	10/28/97	07/13/98	32	731	0	5C	32546	09/22/97	-
2411677368	10/28/97	06/11/98	30	698	0	5C	32546	09/22/97	-
2411677368	10/28/97	05/12/98	29	710	0	5C	32546	09/22/97	-
2411677368	10/28/97	04/13/98	31	810	0	5C	32546	09/22/97	-
2411677368	10/28/97	03/13/98	30	830	0	5C	32546	09/22/97	-
2411677368	10/28/97	02/11/98	30	878	0	5C	32546	09/22/97	-
2411677368	10/28/97	01/12/98	33	983	0	5C	32546	09/22/97	-
2411677368	10/28/97	12/10/97	30	774	-	5C	32546	09/22/97	-
2411677368	10/28/97	11/14/97	16	476	-	5C	32546	09/22/97	-

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>1200 S Federal Hwy, Deerfield Beach</b>									
2439110517	10/05/01	07/01/03	29	274400	584	6V	81004	10/05/01	67.51
2439110517	10/05/01	06/02/03	32	300800	580	6V	81004	10/05/01	67.53
2439110517	10/05/01	05/01/03	29	282800	592	6V	81004	10/05/01	68.64
2439110517	10/05/01	04/02/03	29	256000	596	6V	81004	10/05/01	61.71
2439110517	10/05/01	03/04/03	29	248400	588	6V	81004	10/05/01	60.70
2439110517	10/05/01	01/31/03	34	262400	544	6V	81004	10/05/01	59.11
2439110517	10/05/01	12/31/02	34	285200	600	6V	81004	10/05/01	58.25
2439110517	10/05/01	11/27/02	29	260400	624	6V	81004	10/05/01	59.96
2439110517	10/05/01	10/29/02	29	284400	616	6V	81004	10/05/01	66.33
2439110517	10/05/01	09/30/02	32	311600	624	6V	81004	10/05/01	65.02
2439110517	10/05/01	08/29/02	29	283200	588	6V	81004	10/05/01	69.20
2439110517	10/05/01	07/31/02	30	281200	572	6V	81004	10/05/01	68.28
2439110517	10/05/01	07/01/02	31	278400	556	6V	81004	10/05/01	67.30
2439110517	10/05/01	05/31/02	30	272000	536	6V	81004	10/05/01	70.48
2439110517	10/05/01	05/01/02	29	245600	536	6V	81004	10/05/01	65.83
2439110517	10/05/01	04/02/02	29	232800	492	6V	81004	10/05/01	67.98
2439110517	10/05/01	03/04/02	31	237200	492	6V	81004	10/05/01	64.80
2439110517	10/05/01	02/01/02	30	236800	488	6V	81004	10/05/01	67.40
2439110517	10/05/01	01/02/02	34	284400	520	6V	81004	10/05/01	67.02
2439110517	10/05/01	11/29/01	31	254000	544	6V	81004	10/05/01	62.76
2439110517	10/05/01	10/29/01	24	298800	544	6V	81004	10/05/01	95.36

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>3200 N Federal Hwy #134AB, Ft Lauderdale</b>									
3307059208	07/27/99	06/06/03	30	2924	24	4L	814	05/01/92	16.92
3307059208	07/27/99	05/07/03	29	2481	24	4L	814	05/01/92	14.85
3307059208	07/27/99	04/08/03	29	2152	18	4L	814	05/01/92	17.18
3307059208	07/27/99	03/10/03	32	1421	1	4L	814	05/01/92	185.03
3307059208	07/27/99	02/06/03	30	1376	1	4L	814	05/01/92	191.11
3307059208	07/27/99	01/07/03	33	5159	16	4L	814	05/01/92	40.71
3307059208	07/27/99	12/05/02	31	2470	22	4L	814	05/01/92	15.09
3307059208	07/27/99	11/04/02	31	2067	0	4L	814	05/01/92	-
3307059208	07/27/99	10/04/02	29	743	0	4L	814	05/01/92	-
3307059208	07/27/99	09/05/02	30	784	0	4L	814	05/01/92	-
3307059208	07/27/99	08/06/02	29	760	0	4L	814	05/01/92	-
3307059208	07/27/99	07/08/02	32	827	5	4L	814	05/01/92	21.54
3307059208	07/27/99	06/06/02	30	748	2	4L	814	05/01/92	51.94
3307059208	07/27/99	05/07/02	29	1073	7	4L	814	05/01/92	22.02
3307059208	07/27/99	04/08/02	31	1239	2	4L	814	05/01/92	83.27
3307059208	07/27/99	03/08/02	29	1170	2	4L	814	05/01/92	84.05
3307059208	07/27/99	02/07/02	30	1223	1	4L	814	05/01/92	169.86
3307059208	07/27/99	01/08/02	34	1577	3	4L	814	05/01/92	64.42
3307059208	07/27/99	12/05/01	33	1984	5	4L	814	05/01/92	50.10
3307059208	07/27/99	11/02/01	29	1784	3	4L	814	05/01/92	85.44
3307059208	07/27/99	10/04/01	29	1427	2	4L	814	05/01/92	102.51
3307059208	07/27/99	09/05/01	30	1457	1	4L	814	05/01/92	202.36
3307059208	07/27/99	08/06/01	31	6994	26	4L	814	05/01/92	36.16
3307059208	07/27/99	07/06/01	30	5985	16	4L	814	05/01/92	51.95
3307059208	07/27/99	06/06/01	30	5225	9	4L	814	05/01/92	80.63
3307059208	07/27/99	05/07/01	31	6450	9	4L	814	05/01/92	96.33
3307059208	07/27/99	04/06/01	29	5627	10	4L	814	05/01/92	80.85
3307059208	07/27/99	03/08/01	29	6417	13	4L	814	05/01/92	70.92
3307059208	07/27/99	02/07/01	30	7828	14	4L	814	05/01/92	77.66
3307059208	07/27/99	01/08/01	33	9449	15	4L	814	05/01/92	79.54
3307059208	07/27/99	12/06/00	34	10413	15	4L	814	05/01/92	85.07
3307059208	07/27/99	11/02/00	29	9967	20	4L	814	05/01/92	71.60
3307059208	07/27/99	10/04/00	29	11116	21	4L	814	05/01/92	76.05
3307059208	07/27/99	09/05/00	33	11792	21	4L	814	05/01/92	70.90
3307059208	07/27/99	08/03/00	29	10143	15	4L	814	05/01/92	97.16
3307059208	07/27/99	07/05/00	30	9789	16	4L	814	05/01/92	84.97
3307059208	07/27/99	06/05/00	32	10404	15	4L	814	05/01/92	90.31

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
3307059208	07/27/99	05/04/00	29	10265	17	4L	814	05/01/92	86.76
3307059208	07/27/99	04/05/00	29	10550	16	4L	814	05/01/92	94.74
3307059208	07/27/99	03/07/00	32	11836	20	4L	814	05/01/92	77.06
3307059208	07/27/99	02/04/00	29	9107	20	4L	814	05/01/92	65.42
3307059208	07/27/99	01/06/00	33	9634	18	4L	814	05/01/92	67.58
3307059208	07/27/99	12/04/99	31	12376	25	4L	814	05/01/92	66.54
3307059208	07/27/99	11/03/99	29	5012	15	4L	814	05/01/92	48.01
3307059208	07/27/99	10/05/99	32	11749	15	4L	814	05/01/92	101.99
3307059208	07/27/99	09/03/99	30	12536	28	4L	814	05/01/92	62.18
3307059208	07/27/99	08/04/99	7	1570	28	4L	814	05/01/92	33.38

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>3200 N Federal Hwy #700, Ft Lauderdale</b>									
3515971202	07/12/99	06/06/03	30	274560	517	6V	5707D	08/26/99	73.76
3515971202	07/12/99	05/07/03	29	229560	511	6V	5707D	08/26/99	64.55
3515971202	07/12/99	04/08/03	29	234840	512	6V	5707D	08/26/99	65.90
3515971202	07/12/99	03/10/03	32	258240	496	6V	5707D	08/26/99	67.79
3515971202	07/12/99	02/06/03	30	208680	432	6V	5707D	08/26/99	67.09
3515971202	07/12/99	01/07/03	33	243480	472	6V	5707D	08/26/99	65.13
3515971202	07/12/99	12/05/02	31	235560	480	6V	5707D	08/26/99	65.96
3515971202	07/12/99	11/04/02	31	256200	490	6V	5707D	08/26/99	70.28
3515971202	07/12/99	10/04/02	29	255360	493	6V	5707D	08/26/99	74.42
3515971202	07/12/99	09/05/02	30	270000	499	6V	5707D	08/26/99	75.15
3515971202	07/12/99	08/06/02	29	261600	508	6V	5707D	08/26/99	73.99
3515971202	07/12/99	07/08/02	32	266400	484	6V	5707D	08/26/99	71.67
3515971202	07/12/99	06/06/02	30	250440	485	6V	5707D	08/26/99	71.72
3515971202	07/12/99	05/07/02	29	240480	476	6V	5707D	08/26/99	72.59
3515971202	07/12/99	04/08/02	31	246480	472	6V	5707D	08/26/99	70.19
3515971202	07/12/99	03/08/02	29	215520	474	6V	5707D	08/26/99	65.33
3515971202	07/12/99	02/07/02	30	227880	450	6V	5707D	08/26/99	70.33
3515971202	07/12/99	01/08/02	34	260400	480	6V	5707D	08/26/99	66.48
3515971202	07/12/99	12/05/01	33	258240	473	6V	5707D	08/26/99	68.93
3515971202	07/12/99	11/02/01	29	237600	487	6V	5707D	08/26/99	70.10
3515971202	07/12/99	10/04/01	29	243120	496	6V	5707D	08/26/99	70.43
3515971202	07/12/99	09/05/01	30	265560	511	6V	5707D	08/26/99	72.18
3515971202	07/12/99	08/06/01	31	269040	497	6V	5707D	08/26/99	72.76
3515971202	07/12/99	07/06/01	30	253680	497	6V	5707D	08/26/99	70.89
3515971202	07/12/99	06/06/01	30	237120	466	6V	5707D	08/26/99	70.67
3515971202	07/12/99	05/07/01	31	233880	466	6V	5707D	08/26/99	67.46
3515971202	07/12/99	04/06/01	29	222120	481	6V	5707D	08/26/99	66.35
3515971202	07/12/99	03/08/01	29	224280	454	6V	5707D	08/26/99	70.98
3515971202	07/12/99	02/07/01	30	214800	445	6V	5707D	08/26/99	67.04
3515971202	07/12/99	01/08/01	33	235320	488	6V	5707D	08/26/99	60.89
3515971202	07/12/99	12/06/00	34	258840	486	6V	5707D	08/26/99	65.27
3515971202	07/12/99	11/02/00	29	240000	524	6V	5707D	08/26/99	65.81
3515971202	07/12/99	10/04/00	29	258720	517	6V	5707D	08/26/99	71.90
3515971202	07/12/99	09/05/00	33	298320	521	6V	5707D	08/26/99	72.30
3515971202	07/12/99	08/03/00	29	257520	500	6V	5707D	08/26/99	74.00
3515971202	07/12/99	07/05/00	30	263280	503	6V	5707D	08/26/99	72.70
3515971202	07/12/99	06/05/00	32	271320	498	6V	5707D	08/26/99	70.94

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
3515971202	07/12/99	05/04/00	29	230880	499	6V	5707D	08/26/99	66.48
3515971202	07/12/99	04/05/00	29	229800	497	6V	5707D	08/26/99	66.43
3515971202	07/12/99	03/07/00	32	237360	464	6V	5707D	08/26/99	66.61
3515971202	07/12/99	02/04/00	29	203040	468	6V	5707D	08/26/99	62.33
3515971202	07/12/99	01/06/00	33	254040	479	6V	5707D	08/26/99	66.96
3515971202	07/12/99	12/04/99	31	242760	486	6V	5707D	08/26/99	67.14
3515971202	07/12/99	11/03/99	29	247440	511	6V	5707D	08/26/99	69.57
3515971202	07/12/99	10/05/99	32	245160	467	6V	5707D	08/26/99	68.36
3515971202	07/12/99	09/03/99	30	61320	407	6V	5707D	08/26/99	20.93
3515971202	07/12/99	08/04/99	23	129000	400	6V	58244	07/12/99	58.42



Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>6150 N 14 St W, Bradenton</b>									
3690836659	06/11/92	06/24/03	33	281760	481	6V	5345D	11/11/02	73.96
3690836659	06/11/92	05/23/03	28	216960	436	6V	5345D	11/11/02	74.05
3690836659	06/11/92	04/24/03	29	195960	452	6V	5345D	11/11/02	62.29
3690836659	06/11/92	03/26/03	29	204960	474	6V	5345D	11/11/02	62.13
3690836659	06/11/92	02/25/03	32	187200	424	6V	5345D	11/11/02	57.49
3690836659	06/11/92	01/24/03	35	194160	451	6V	5345D	11/11/02	51.25
3690836659	06/11/92	12/20/02	30	187800	462	6V	5345D	11/11/02	56.46
3690836659	06/11/92	11/20/02	29	205200	528	6V	5345D	11/11/02	55.84
3690836659	06/11/92	10/22/02	29	223560	600	1V	5192D	07/01/92	53.53
3690836659	06/11/92	09/23/02	32	264720	540	1V	5192D	07/01/92	63.83
3690836659	06/11/92	08/22/02	29	244680	540	1V	5192D	07/01/92	65.10
3690836659	06/11/92	07/24/02	30	241200	564	1V	5192D	07/01/92	59.40
3690836659	06/11/92	06/24/02	32	254640	540	1V	5192D	07/01/92	61.40
3690836659	06/11/92	05/23/02	29	225480	540	1V	5192D	07/01/92	59.99
3690836659	06/11/92	04/24/02	29	207480	480	1V	5192D	07/01/92	62.10
3690836659	06/11/92	03/26/02	29	190920	480	1V	5192D	07/01/92	57.15
3690836659	06/11/92	02/25/02	31	189720	480	1V	5192D	07/01/92	53.13
3690836659	06/11/92	01/25/02	35	200760	516	1V	5192D	07/01/92	46.32
3690836659	06/11/92	12/21/01	31	221040	516	1V	5192D	07/01/92	57.58
3690836659	06/11/92	11/20/01	29	197040	540	1V	5192D	07/01/92	52.43
3690836659	06/11/92	10/22/01	31	230880	564	1V	5192D	07/01/92	55.02
3690836659	06/11/92	09/21/01	30	255120	588	1V	5192D	07/01/92	60.26
3690836659	06/11/92	08/22/01	29	235560	600	1V	5192D	07/01/92	56.41
3690836659	06/11/92	07/24/01	32	258720	600	1V	5192D	07/01/92	56.15
3690836659	06/11/92	06/22/01	30	246000	576	1V	5192D	07/01/92	59.32
3690836659	06/11/92	05/23/01	29	205680	552	1V	5192D	07/01/92	53.54
3690836659	06/11/92	04/24/01	29	195000	540	1V	5192D	07/01/92	51.88
3690836659	06/11/92	03/26/01	31	194520	480	1V	5192D	07/01/92	54.47
3690836659	06/11/92	02/23/01	29	175680	504	1V	5192D	07/01/92	50.08
3690836659	06/11/92	01/25/01	34	181920	480	1V	5192D	07/01/92	46.45
3690836659	06/11/92	12/22/00	31	190080	504	1V	5192D	07/01/92	50.69
3690836659	06/11/92	11/21/00	29	197520	540	1V	5192D	07/01/92	52.55
3690836659	06/11/92	10/23/00	32	234480	540	1V	5192D	07/01/92	56.54
3690836659	06/11/92	09/22/00	30	234120	564	1V	5192D	07/01/92	57.65
3690836659	06/11/92	08/23/00	29	235080	576	1V	5192D	07/01/92	58.64
3690836659	06/11/92	07/24/00	32	255480	576	1V	5192D	07/01/92	57.75
3690836659	06/11/92	06/22/00	30	238800	552	1V	5192D	07/01/92	60.08

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
3690836659	06/11/92	05/23/00	29	215040	540	1V	5192D	07/01/92	57.22
3690836659	06/11/92	04/24/00	31	196440	504	1V	5192D	07/01/92	52.39
3690836659	06/11/92	03/24/00	29	181440	480	1V	5192D	07/01/92	54.31
3690836659	06/11/92	02/24/00	30	163920	480	1V	5192D	07/01/92	47.43
3690836659	06/11/92	01/25/00	34	188280	480	1V	5192D	07/01/92	48.07
3690836659	06/11/92	12/22/99	30	182160	504	1V	5192D	07/01/92	50.20
3690836659	06/11/92	11/22/99	31	197040	480	1V	5192D	07/01/92	55.17
3690836659	06/11/92	10/22/99	29	222960	564	1V	5192D	07/01/92	56.80
3690836659	06/11/92	09/23/99	30	235680	576	1V	5192D	07/01/92	56.83
3690836659	06/11/92	08/24/99	32	258360	600	1V	5192D	07/01/92	56.07
3690836659	06/11/92	07/23/99	30	231480	600	1V	5192D	07/01/92	53.58
3690836659	06/11/92	06/23/99	30	226920	552	1V	5192D	07/01/92	57.10
3690836659	06/11/92	05/24/99	31	216960	516	1V	5192D	07/01/92	56.51
3690836659	06/11/92	04/23/99	30	190560	504	1V	5192D	07/01/92	52.51
3690836659	06/11/92	03/24/99	29	164880	480	1V	5192D	07/01/92	49.35
3690836659	06/11/92	02/23/99	29	170880	540	1V	5192D	07/01/92	45.47
3690836659	06/11/92	01/25/99	35	197640	540	1V	5192D	07/01/92	43.57
3690836659	06/11/92	12/22/98	32	221400	504	1V	5192D	07/01/92	57.20
3690836659	06/11/92	11/20/98	30	204240	540	1V	5192D	07/01/92	52.53
3690836659	06/11/92	10/21/98	28	224520	540	1V	5192D	07/01/92	61.87
3690836659	06/11/92	09/22/98	32	257880	564	1V	5192D	07/01/92	59.54
3690836659	06/11/92	08/21/98	29	244200	600	1V	5192D	07/01/92	58.48
3690836659	06/11/92	07/23/98	30	245400	540	1V	5192D	07/01/92	63.12
3690836659	06/11/92	06/23/98	32	261360	540	1V	5192D	07/01/92	63.02
3690836659	06/11/92	05/22/98	29	201840	480	1V	5192D	07/01/92	60.42
3690836659	06/11/92	04/23/98	29	185640	492	1V	5192D	07/01/92	54.21
3690836659	06/11/92	03/25/98	30	165360	444	1V	5192D	07/01/92	51.73
3690836659	06/11/92	02/24/98	32	165840	420	1V	5192D	07/01/92	51.41
3690836659	06/11/92	01/23/98	31	169200	444	1V	5192D	07/01/92	51.22
3690836659	06/11/92	12/22/97	30	181200	420	1V	5192D	07/01/92	59.92
3690836659	06/11/92	11/20/97	30	174360	480	1V	5192D	07/01/92	50.45
3690836659	06/11/92	10/21/97	30	227400	504	1V	5192D	07/01/92	62.67
3690836659	06/11/92	09/19/97	30	212400	528	1V	5192D	07/01/92	55.87
3690836659	06/11/92	08/20/97	30	223440	540	1V	5192D	07/01/92	57.47
3690836659	06/11/92	07/22/97	30	252720	540	1V	5192D	07/01/92	65.00
3690836659	06/11/92	06/20/97	30	210480	528	1V	5192D	07/01/92	55.37
3690836659	06/11/92	05/21/97	30	188760	504	1V	5192D	07/01/92	52.02
3690836659	06/11/92	04/22/97	30	184800	444	1V	5192D	07/01/92	57.81

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
3690836659	06/11/92	03/24/97	30	173040	420	1V	5192D	07/01/92	57.22
3690836659	06/11/92	02/21/97	30	162960	432	1V	5192D	07/01/92	52.39
3690836659	06/11/92	01/22/97	30	179160	420	1V	5192D	07/01/92	59.25
3690836659	06/11/92	12/19/96	30	172320	432	1V	5192D	07/01/92	55.40
3690836659	06/11/92	11/19/96	30	197520	480	1V	5192D	07/01/92	57.15
3690836659	06/11/92	10/18/96	30	195600	528	1V	5192D	07/01/92	51.45
3690836659	06/11/92	09/19/96	30	232200	540	1V	5192D	07/01/92	59.72
3690836659	06/11/92	08/20/96	30	227400	540	1V	5192D	07/01/92	58.49
3690836659	06/11/92	07/22/96	30	253320	540	1V	5192D	07/01/92	65.15
3690836659	06/11/92	06/20/96	30	223560	600	1V	5192D	07/01/92	51.75
3690836659	06/11/92	05/21/96	30	199200	540	1V	5192D	07/01/92	51.23
3690836659	06/11/92	04/22/96	30	182280	528	1V	5192D	07/01/92	47.95
3690836659	06/11/92	03/22/96	30	156720	444	1V	5192D	07/01/92	49.02
3690836659	06/11/92	02/22/96	30	141000	408	1V	5192D	07/01/92	48.00
3690836659	06/11/92	01/24/96	30	160080	420	1V	5192D	07/01/92	52.94
3690836659	06/11/92	12/21/95	30	179520	456	1V	5192D	07/01/92	54.68
3690836659	06/11/92	11/21/95	30	181200	456	1V	5192D	07/01/92	55.19
3690836659	06/11/92	10/20/95	30	194160	492	1V	5192D	07/01/92	54.81
3690836659	06/11/92	09/21/95	30	213720	504	1V	5192D	07/01/92	58.90
3690836659	06/11/92	08/22/95	30	208920	540	1V	5192D	07/01/92	53.73
3690836659	06/11/92	07/24/95	30	248160	540	1V	5192D	07/01/92	63.83
3690836659	06/11/92	06/22/95	30	213720	504	1V	5192D	07/01/92	58.90
3690836659	06/11/92	05/23/95	30	211560	504	1V	5192D	07/01/92	58.30
3690836659	06/11/92	04/24/95	30	197760	468	1V	5192D	07/01/92	58.69
3690836659	06/11/92	03/24/95	30	167160	480	1V	5192D	07/01/92	48.37
3690836659	06/11/92	02/23/95	30	146400	480	1V	5192D	07/01/92	42.36
3690836659	06/11/92	01/25/95	30	165480	504	1V	5192D	07/01/92	45.60
3690836659	06/11/92	12/23/94	30	204600	480	1V	5192D	07/01/92	59.20
3690836659	06/11/92	11/23/94	30	197280	540	1V	5192D	07/01/92	50.74
3690836659	06/11/92	10/24/94	30	213600	480	1V	5192D	07/01/92	61.81
3690836659	06/11/92	09/22/94	30	211920	480	1V	5192D	07/01/92	61.32
3690836659	06/11/92	08/23/94	30	210360	540	1V	5192D	07/01/92	54.10
3690836659	06/11/92	07/25/94	30	230640	504	1V	5192D	07/01/92	63.56
3690836659	06/11/92	06/23/94	30	219120	540	1V	5192D	07/01/92	56.36
3690836659	06/11/92	05/24/94	30	199440	504	1V	5192D	07/01/92	54.96
3690836659	06/11/92	04/25/94	30	194400	480	1V	5192D	07/01/92	56.25
3690836659	06/11/92	03/25/94	30	158760	444	1V	5192D	07/01/92	49.66
3690836659	06/11/92	02/24/94	30	163800	432	1V	5192D	07/01/92	52.66

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
3690836659	06/11/92	01/25/94	30	153840	504	1V	5192D	07/01/92	42.39
3690836659	06/11/92	12/23/93	30	157080	504	1V	5192D	07/01/92	43.29
3690836659	06/11/92	11/23/93	30	185280	468	1V	5192D	07/01/92	54.99
3690836659	06/11/92	10/22/93	30	187800	480	1V	5192D	07/01/92	54.34
3690836659	06/11/92	09/23/93	30	207120	528	1V	5192D	07/01/92	54.48
3690836659	06/11/92	08/24/93	30	225840	540	1V	5192D	07/01/92	58.09
3690836659	06/11/92	07/23/93	30	204600	516	1V	5192D	07/01/92	55.07
3690836659	06/11/92	06/23/93	30	198480	540	1V	5192D	07/01/92	51.05
3690836659	06/11/92	05/24/93	30	177840	468	1V	5192D	07/01/92	52.78
3690836659	06/11/92	04/23/93	30	159120	480	1V	5192D	07/01/92	46.04
3690836659	06/11/92	03/24/93	30	130080	396	1V	5192D	07/01/92	45.62

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
<b>15005 SW 88 St, Miami</b>									
3729248066	12/14/95	06/09/03	32	254880	502	6V	7254D	12/14/95	66.11
3729248066	12/14/95	05/08/03	29	204960	473	6V	7254D	12/14/95	62.26
3729248066	12/14/95	04/09/03	29	206400	497	6V	7254D	12/14/95	59.67
3729248066	12/14/95	03/11/03	32	224160	490	6V	7254D	12/14/95	59.57
3729248066	12/14/95	02/07/03	30	167040	473	6V	7254D	12/14/95	49.05
3729248066	12/14/95	01/08/03	33	207360	509	6V	7254D	12/14/95	51.44
3729248066	12/14/95	12/06/02	31	211920	514	6V	7254D	12/14/95	55.42
3729248066	12/14/95	11/05/02	29	236880	499	6V	7254D	12/14/95	68.21
3729248066	12/14/95	10/07/02	31	264240	518	6V	7254D	12/14/95	68.56
3729248066	12/14/95	09/06/02	30	264720	545	6V	7254D	12/14/95	67.46
3729248066	12/14/95	08/07/02	29	253920	456	6V	7254D	12/14/95	80.01
3729248066	12/14/95	07/09/02	32	266160	518	6V	7254D	12/14/95	66.90
3729248066	12/14/95	06/07/02	30	240240	528	6V	7254D	12/14/95	63.19
3729248066	12/14/95	05/08/02	29	230400	504	6V	7254D	12/14/95	65.68
3729248066	12/14/95	04/09/02	29	216000	511	6V	7254D	12/14/95	60.73
3729248066	12/14/95	03/11/02	31	189840	437	6V	7254D	12/14/95	58.39
3729248066	12/14/95	02/08/02	30	199440	485	6V	7254D	12/14/95	57.11
3729248066	12/14/95	01/09/02	34	218640	492	6V	7254D	12/14/95	54.46
3729248066	12/14/95	12/06/01	31	214080	504	6V	7254D	12/14/95	57.09
3729248066	12/14/95	11/05/01	31	242160	506	6V	7254D	12/14/95	64.32
3729248066	12/14/95	10/05/01	29	219120	485	6V	7254D	12/14/95	64.91
3729248066	12/14/95	09/06/01	30	271440	530	6V	7254D	12/14/95	71.13
3729248066	12/14/95	08/07/01	29	264000	518	6V	7254D	12/14/95	73.23
3729248066	12/14/95	07/09/01	32	272640	518	6V	7254D	12/14/95	68.53
3729248066	12/14/95	06/07/01	30	210720	451	6V	7254D	12/14/95	64.89
3729248066	12/14/95	05/08/01	29	190080	470	6V	7254D	12/14/95	58.11
3729248066	12/14/95	04/09/01	31	216000	492	6V	7254D	12/14/95	59.01
3729248066	12/14/95	03/09/01	29	205440	468	6V	7254D	12/14/95	63.07
3729248066	12/14/95	02/08/01	30	173760	430	6V	7254D	12/14/95	56.12
3729248066	12/14/95	01/09/01	33	198960	466	6V	7254D	12/14/95	53.91
3729248066	12/14/95	12/07/00	31	206160	504	6V	7254D	12/14/95	54.98
3729248066	12/14/95	11/06/00	31	219840	492	6V	7254D	12/14/95	60.06
3729248066	12/14/95	10/06/00	29	233280	485	6V	7254D	12/14/95	69.11
3729248066	12/14/95	09/07/00	30	253920	511	6V	7254D	12/14/95	69.02
3729248066	12/14/95	08/08/00	32	259680	509	6V	7254D	12/14/95	66.43
3729248066	12/14/95	07/07/00	30	258000	506	6V	7254D	12/14/95	70.82
3729248066	12/14/95	06/07/00	30	247680	502	6V	7254D	12/14/95	68.53

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
3729248066	12/14/95	05/08/00	31	205920	478	6V	7254D	12/14/95	57.90
3729248066	12/14/95	04/07/00	29	196800	487	6V	7254D	12/14/95	58.06
3729248066	12/14/95	03/09/00	30	186720	470	6V	7254D	12/14/95	55.18
3729248066	12/14/95	02/08/00	31	185520	446	6V	7254D	12/14/95	55.91
3729248066	12/14/95	01/08/00	32	201120	473	6V	7254D	12/14/95	55.36
3729248066	12/14/95	12/07/99	32	204000	456	6V	7254D	12/14/95	58.25
3729248066	12/14/95	11/05/99	29	214560	545	6V	7254D	12/14/95	56.56
3729248066	12/14/95	10/07/99	29	240720	545	6V	7254D	12/14/95	63.46
3729248066	12/14/95	09/08/99	30	252240	545	6V	7254D	12/14/95	64.28
3729248066	12/14/95	08/09/99	32	280800	545	6V	7254D	12/14/95	67.09
3729248066	12/14/95	07/08/99	30	235440	526	6V	7254D	12/14/95	62.17
3729248066	12/14/95	06/08/99	32	239760	521	6V	7254D	12/14/95	59.92
3729248066	12/14/95	05/07/99	29	206400	509	6V	7254D	12/14/95	58.26
3729248066	12/14/95	04/08/99	30	190080	470	6V	7254D	12/14/95	56.17
3729248066	12/14/95	03/09/99	29	168480	461	6V	7254D	12/14/95	52.51
3729248066	12/14/95	02/08/99	31	191520	463	6V	7254D	12/14/95	55.60
3729248066	12/14/95	01/08/99	32	201840	463	6V	7254D	12/14/95	56.76
3729248066	12/14/95	12/07/98	33	228960	468	6V	7254D	12/14/95	61.77
3729248066	12/14/95	11/04/98	29	217200	490	6V	7254D	12/14/95	63.69
3729248066	12/14/95	10/06/98	32	264000	526	6V	7254D	12/14/95	65.35
3729248066	12/14/95	09/04/98	29	247920	526	6V	7254D	12/14/95	67.72
3729248066	12/14/95	08/06/98	30	253440	530	6V	7254D	12/14/95	66.42
3729248066	12/14/95	07/08/98	29	252960	530	6V	7254D	12/14/95	68.58
3729248066	12/14/95	06/08/98	32	250080	523	6V	7254D	12/14/95	62.26
3729248066	12/14/95	05/07/98	29	188160	490	6V	7254D	12/14/95	55.17
3729248066	12/14/95	04/08/98	29	168720	458	6V	7254D	12/14/95	52.93
3729248066	12/14/95	03/10/98	32	189120	439	6V	7254D	12/14/95	56.09
3729248066	12/14/95	02/06/98	30	170880	442	6V	7254D	12/14/95	53.70
3729248066	12/14/95	01/08/98	33	204720	485	6V	7254D	12/14/95	53.30
3729248066	12/14/95	12/05/97	30	205200	456	6V	7254D	12/14/95	62.50
3729248066	12/14/95	11/04/97	30	207840	468	6V	7254D	12/14/95	61.68
3729248066	12/14/95	10/06/97	30	247680	485	6V	7254D	12/14/95	70.93
3729248066	12/14/95	09/04/97	30	245040	516	6V	7254D	12/14/95	65.96
3729248066	12/14/95	08/05/97	30	234480	516	6V	7254D	12/14/95	63.11
3729248066	12/14/95	07/07/97	30	265680	521	6V	7254D	12/14/95	70.83
3729248066	12/14/95	06/05/97	30	216720	497	6V	7254D	12/14/95	60.56
3729248066	12/14/95	05/06/97	30	193200	475	6V	7254D	12/14/95	56.49
3729248066	12/14/95	04/07/97	30	192720	425	6V	7254D	12/14/95	62.98

Account No	Open Date	Reading Date	Svc Days	KWH	KWD	Mtr Sym	FPL Mtr No	Meter Set Date	Load Factor
3729248066	12/14/95	03/07/97	30	200160	451	6V	7254D	12/14/95	61.64
3729248066	12/14/95	02/05/97	30	166800	358	6V	7254D	12/14/95	64.71
3729248066	12/14/95	01/06/97	30	202800	463	6V	7254D	12/14/95	60.84
3729248066	12/14/95	12/04/96	30	226320	480	6V	7254D	12/14/95	65.49
3729248066	12/14/95	11/01/96	30	209040	456	6V	7254D	12/14/95	63.67
3729248066	12/14/95	10/03/96	30	228240	523	6V	7254D	12/14/95	60.61
3729248066	12/14/95	09/04/96	30	262080	533	6V	7254D	12/14/95	68.29
3729248066	12/14/95	08/05/96	30	269280	552	6V	7254D	12/14/95	67.75
3729248066	12/14/95	07/05/96	30	247920	533	6V	7254D	12/14/95	64.60
3729248066	12/14/95	06/05/96	30	236880	502	6V	7254D	12/14/95	65.54
3729248066	12/14/95	05/06/96	30	223200	482	6V	7254D	12/14/95	64.32
3729248066	12/14/95	04/05/96	30	187440	475	6V	7254D	12/14/95	54.81
3729248066	12/14/95	03/07/96	30	171840	463	6V	7254D	12/14/95	51.55
3729248066	12/14/95	02/07/96	30	150480	499	6V	7254D	12/14/95	41.88
3729248066	12/14/95	01/08/96	24	16800	362	6V	7254D	12/14/95	8.06

**FPSC/GEORGE BROWN REFEREED METER TEST RESULTS**

ATTACHMENT #3 Revised 7/17/03

COMPANY	Premise	Sym	Num	Dst	Address	Scale Value	Full Scale % Error	kWh Test SF%	kWh Test SP%	kWh Test SL%	kWh Test WA%	Test Date	RETEST DATE	Full Scale % Error	
<b>TARGET CORPORATION (15)</b>															
482065C	1.	435343416	1V	7032D	72	3251 HOLLYWOOD BLVD # 300	7	2.01	99.97	100.07	100.74	100.11	12/10/02	5/21/03	4.84
482065C	2.	862138933	1V	7019D	53	13711 S TAMiami TRL # 300	3.5	4.21	100.74	100.9	100.62	100.77	12/10/02	N/A	N/A
482065C	3.	3679858	1V	5192D	52	6150 14TH ST W	7	2.68	100.12	100.05	100.58	100.17	12/10/02	5/21/03	4.36
482065C	4.	3639292	1V	7505D	11	2380 WINTL SPEEDWAY BLVD	3.5	1.93	100.36	99.99	99.38	100.11	12/10/02	N/A	N/A
482065C	5.	552167401	1V	55773	42	5900 LAKE WORTH RD # TARGET	7	0.62	99.97	100.51	100.31	100.17	12/10/02	5/21/03	-0.63
482065C	6.	3587797	1V	7001D	41	1901 N CONGRESS AVE	3.5	4.6	100.44	100.08	97.65	99.94	12/10/02	N/A	N/A
482065C	7.	34079415	1V	5774D	54	26831 S TAMiami TRL # TARGET	7	-0.03	99.51	99.49	99.58	99.52	12/10/02	N/A	N/A
482065C	8.	3575420	1V	5025D	41	1200 LINTON BLVD # TARGET	7	1.73	100.2	99.74	99.34	99.95	12/10/02	5/21/03	4.12
482065C	9.	3582694	1V	5885D	41	21637 STATE ROAD 7 # TARGET	7	2.73	99.91	99.76	99.44	99.80	12/10/02	5/21/03	4.84
482065C	10.	895487734	1V	7745D	86	14075 BISCAYNE BLVD	7	-1.12	100.18	100.14	99.27	100.04	12/10/02	5/21/03	-2.78
482065C	11.	941808655	1V	5211D	81	8458 S DIXIE HWY	7	-1.55	100.41	99.76	99.73	100.13	12/10/02	5/21/03	-2.78
482065C	12.	3627833	1V	5887D	55	1400 TAMiami TRL # TARGET	7	3.25	99.85	99.69	98.59	99.62	12/10/02	5/21/03	4.36
482065C	13.	3661074	1V	5159D	57	4271 TAMiami TRL S # TARGET	7	3.11	100.2	100.13	99.31	100.05	12/10/02	5/21/03	4.36
	14.	73776531	1V	5679D	54	2324 PINE RIDGE RD	7	4.39	98.25	96.19	93.82	97.03	3/28/03	5/21/03	5.07
514226E	15.	299626231	1V	5871D	56	5350 Fruitville Rd	7	3.14	99.45	99.39	99.62	99.46	8/21/02	5/21/2003*	2.21
<b>DILLARDS (1)</b>															
521185E	1.	1934679	1V	5216D	73	9001 W ATLANTIC BLVD	7	2.45	100.09	99.79	99.48	99.92	12/10/02	5/21/03	4.84

**TARGET FRUITVILLE\***

\* At the FPSC's request, on 4/3/03, meter (1V5871D) was retested. This retesting was witnessed by George Brown, FPSC Field Engineer, Clinton Willams and FPL Representatives. As requested, meter 1V5871D was retested only on demand, not kWh registration. In each test, upon adding load (approximately 61.4%), the red pusher pointer and the black indicator pointer moved together to register the highest point of demand. Once load was removed the pointers moved together to various points on the scale before the black indicator stopped somewhere between 2.75 and 3.7, leaving the red pusher pointer continuing back to 0 registration. The registration of the demand was within allowable tolerances each time it was tested, as follows: 3.32, 3.2, 3.57, 3.37

COMPANY	Premise	Sym	Num	Dst	Address	Scale Value	Full Scale % Error	kWh Test SF%	kWh Test SP%	kWh Test SL%	kWh Test WA%	Test Date	RETEST DATE	Full Scale % Error	
<b>Ocean Properties (7)</b>															
	1.	499514	1V	70077	41	10 N Ocean Blvd	3.5	1.26	100.49	100.46	99.19	100.3	2/26/03	N/A	N/A
480308-C	2.	2707050	1V	52093	52	100 Riverfront Holiday Inn	7	6.00	100.33	100.15	100.20	100.26	8/21/02		
	3.	1280736	1V	54034	56	4711 GULF OF MEXICO DR	3.5	4.12	99.77	99.56	99.59	99.68	2/26/03	N/A	N/A
	4.	434483	1V	59333	41	2809 S OCEAN BLVD # HSE	3.5	-0.15	99.93	99.56	100.38	99.89	2/26/03	N/A	N/A
	5.	317438	1V	74963	41	1601 N Congress	7	3.77	100.24	100.48	99.36	100.18	2/26/03	5/21/03	3.41
	6.	789229911	1U	53145	54	Highpoint Dr #Hotel	1.5	-1.68	100.49	100.66	100.3	100.51	2/26/03	N/A	N/A
	7.	374675	1U	71993	41	8144 Glades Rd.	3	1.82	100.00	100.00	99.55	99.94	2/26/03	5/21/03	1.36
<b>Hutchinson Island (1)</b>															



FPSC/GEORGE BROWN REFEREED METER TEST RESULTS

Revised 7/17/03

1.	2888685	1U	82230	40	Hutchinson Island	3	0.15	100.1	99.36	98.86	99.71	2/26/03		
----	---------	----	-------	----	-------------------	---	------	-------	-------	-------	-------	---------	--	--

FPSC/GEORGE BROWN REFEREED METER TEST RESULTS

COMPANY	Premise	Sym	Num	Dst	Address	Scale Value	Full Scal % Error	kWh Test SF%	kWh Test SP%	kWh Test SL%	kWh Test WA%	Test Date	RETEST DATE	Full Scale % Error
Kash N' Karry (8)														
4998333C	1.	960069	1U	70868	52 5802 14th St #W	3	-3.17	101.06	100.61	100.01	100.78	02/26/03	N/A	N/A
4998333C	2.	1333326	1U	77484	57 2111 Tamiami Tr	1.5	-0.01	99.68	99.00	98.32	99.29	02/26/03	N/A	N/A
4998333C	3.	1333326	1U	71924	55 2050 Forrest Nelson	3	-19.84	99.94	99.61	99.1	99.72	02/26/03	N/A	N/A
4998333C	4.	1333326	1U	71857	53 8595 College Pky	1.5	5.65	99.85	99.62	99.08	99.67	02/26/03	N/A	N/A
4998333C	5.	1281530	1U	79391	56 4404 Bee Ridge Rd	1.5	3.65	100.53	100.27	99.6	100.32	02/26/03	N/A	N/A
4998333C	6.	3732465	1U	56944	53 18751 Three Oaks	3	5.82	100.26	99.45	99.31	99.89	02/26/03	N/A	N/A
4998333C	7.	3732465	1U	78293	52 6015 26 st #W	3	2.02	99.86	99.8	99.03	99.72	02/26/03	5/21/03	2.69
4998333C	8.	3715781	1U	51177	44 2820 SW Port St Lucie Blvd							N/A	N/A	N

COMPANY	Premise	Sym	Num	Dst	Address	Scale Value	Full Scal % Error	kWh Test SF%	kWh Test SP%	kWh Test SL%	kWh Test WA%	Test Date	RETEST DATE	Full Scale % Error
Food Lion (7)														
4998333C	1.	3668262	1U	71578	22 1569 Palm Bay Rd	3	-4.5	99.8	100.36	99.2	99.88	2/26/03	N/A	N/A
4998333C	2.	3732465	1U	70836	32 Gleason PL #Food Lion	1.5	4.32	100.02	99.81	99.7	99.92	2/26/03	N/A	N/A
4998333C	3.	3732465	1U	75679	55 1133 Balharbor Blvd	1.5	0.98	99.96	99.34	98.74	99.61	2/26/03	N/A	N/A
4998333C	4.	3732465	1U	72446	42 5760 Jog Rd	3	0.15	99.59	98.71	99.19	99.28	2/26/03	5/21/03	0.36
4998333C	5.	3732465	1U	52747	11 1603 Nova Dr	3	1.82	100.23	98.97	99.65	99.78	2/26/03	5/21/03	-1.97
4998333C	6.	3732465	1U	51401	11 101 E Granada	3	2.16	99.92	99.81	100.25	99.94	2/26/03	5/21/03	2.69
4998333C	7.	3209799	1U	53593	34 1326 S 6TH ST							N/A	N/A	N/A

COMPANY	Premise	Sym	Num	Dst	Address	Scale Value	Full Scal % Error	kWh Test SF%	kWh Test SP%	kWh Test SL%	kWh Test WA%	Test Date	RETEST DATE	Full Scale % Error
Walmart (9)														
	799883715	2	7014D	411	22100 STATE ROAD 7	3.51	2.03	100.14	99.91	99.39	99.97	12/10/02	N/A	
	2932189	1V	5249D	222	1001 E FAU GARIBOLDI	7.0	0.73	100.05	99.26	98.68	99.82	12/10/02	5/21/03	3.64
	2812917	1V	5441D	21	1802 US HIGHWAY 1	4.5	2.78	99.87	99.70	99.92	99.88	12/10/02	N/A	
	329802	1V	5443D	211	3276 GARDEN ST # 116	3.5	2.78	99.46	99.65	99.06	99.46	12/10/02	N/A	
	3436415	1V	7942D	11	1116 BEVILLE RD	3.32	0.78	99.91	99.65	97.26	99.45	12/10/02	N/A	
	2692471	1V	5898D	12	101 US HIGHWAY 10N	7.0	1.82	99.93	99.61	99.36	99.77	12/10/02	5/21/03	3.64
	2769275	1V	5921D	43	3371 US HIGHWAY 4415	7.0	1.58	99.23	98.22	98.29	98.81	12/10/02	5/21/03	3.41