



ORIGINAL

JAMES A. MCGEE

ASSOCIATE GENERAL COUNSEL
PROGRESS ENERGY SERVICE CO., LLC

July 22, 2004

Ms. Blanca S. Bayó, Director
Division of the Commission Clerk
and Administrative Services
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399-0850

Re: Docket No. 040001-EI

Dear Ms. Bayó:

Enclosed for filing in the subject docket on behalf of Progress Energy Florida, Inc., is an original and ten copies of its Performance Data Report for June 2004.

Please acknowledge your receipt of the above filing on the enclosed copy of this letter and return to the undersigned.

Very truly yours,

James A. McGee

RECEIVED-PPSC
JUL 23 AM 9:47
COMMISSION
CLERK

JAM/at
Enclosure

CMP _____

COM 5

CTR _____

cc: Parties of record

ECR _____

GCL _____

OPC _____

MMS _____

RCA _____

SCR _____

SEC 1

OTH cover letter

RECEIVED & FILED

FPSC-BUREAU OF RECORDS

DOCUMENT NUMBER-DATE

08028 JUL 23 3

100 Central Avenue (33701) • Post Office Box 14042 (33733) • St. Petersburg, Florida
Phone: 727.820.5184 • Fax: 727.820.5519 • Email: james.mcgee@pgnmail.com

FPSC-COMMISSION CLERK

Progress Energy Florida

CERTIFICATE OF SERVICE

Docket No. 040001-EI

I HEREBY CERTIFY that a true copy of Progress Energy Florida, Inc.'s Performance Data Report for the month of June 2004 has been furnished to the following individuals by regular US Mail this 22nd day of July 2004.

John Butler
Steel Hector & Davis
200 S. Biscayne Blvd.
Suite 4000
Miami, FL 33131

Jeffrey A. Stone, Esquire
Russell A. Badders, Esquire
Beggs and Lane
P. O. Box 12950
Pensacola, FL 32576-2950

Lee L. Willis, Esquire
James D. Beasley, Esquire
Ausley & McMullen
P. O. Box 391
Tallahassee, FL 32302

Wm. Cochran Keating, IV
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, FL 32399-0850

Robert Vandiver, Esquire
Office of the Public Counsel
111 West Madison Street
Room 812
Tallahassee, FL 32399-1400

Joseph A. McGlothlin, Esquire
Vicki Gordon Kaufman, Esquire
McWhirter, Reeves, McGlothlin,
117 S. Gadsden Street
Tallahassee, FL 32301

John McWhirter, Jr.
McWhirter, Reeves, McGlothlin,
400 North Tampa Street
Suite 2450
Tampa, FL 33601

Norman Horton, Jr., Esquire
Messer, Caparello & Self
P. O. Box 1876
Tallahassee, FL 32302

Ronald C. LeFace, Esquire
Seann M. Frazier, Esquire
Greenberg Traurig
101 East College Avenue
Tallahassee, FL 32301



Attorney

PROGRESS ENERGY FLORIDA

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2004

ANCLOTE 1	Jan-04	Feb-04	Mar-04	Apr-04	May-04	Jun-04	Jul-04	Aug-04	Sep-04	Oct-04	Nov-04	Dec-04	Jan - Jun Period
1. EAF	90.32	96.99	99.52	98.58	93.85	93.85							95.49
2. PH	744	696	744	719	744	720							4,367
3. SH	577.2	560.3	724.6	719.0	744.0	714.1							4,039.2
4. RSH	102.4	135.7	19.4	0.0	0.0	0.0							257.6
5. UH	64.4	0.0	0.0	0.0	0.0	5.9							70.2
6. POH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
7. FOH	64.4	0.0	0.0	0.0	0.0	5.9							70.2
8. MOH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
9. PFOH	23.1	13.2	0.0	49.6	85.8	0.0							171.7
10. LR PF (MW)	164.8	159.0	0.0	4.0	64.8	0.0							67.9
11. PMOH	0.0	52.4	11.2	30.7	108.9	124.0							327.2
12. LR PM (MW)	0.0	159.0	159.0	159.0	158.2	154.3							157.0
13. NSC (MW)	498	498	498	498	498	498							498
14. OPER MBTU	1,399,153	1,482,450	1,742,969	1,863,808	1,915,072	2,088,498							10,491,949
15. NET GEN (MWH)	138,668	147,363	179,497	184,737	189,583	212,089							1,051,937
16. ANOHR (BTU/KWH)	10,089.9	10,059.8	9,710.3	10,089.0	10,101.5	9,847.3							9,973.9
17. NOF (%)	48.24	52.81	49.74	51.59	51.17	59.64							52.30
18. NPC (MW)	498	498	498	498	498	498							498

PROGRESS ENERGY FLORIDA

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2004

ANCLOTE 2	Jan-04	Feb-04	Mar-04	Apr-04	May-04	Jun-04	Jul-04	Aug-04	Sep-04	Oct-04	Nov-04	Dec-04	Jan - Jun Period
1. EAF	98.69	97.77	97.01	67.62	82.88	94.69							89.79
2. PH	744	696	744	719	744	720							4,367
3. SH	663.1	696.0	744.0	503.0	658.4	720.0							3,984.4
4. RSH	81.0	0.0	0.0	0.0	0.0	0.0							81.0
5. UH	0.0	0.0	0.0	216.1	85.6	0.0							301.7
6. POH	0.0	0.0	0.0	216.1	85.6	0.0							301.7
7. FOH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
8. MOH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
9. PFOH	0.0	1.7	4.0	9.4	40.9	4.3							60.2
10. LR PF (MW)	0.0	15.1	156.1	305.9	255.1	270.2							250.8
11. PMOH	30.9	49.2	66.7	34.7	65.8	113.8							361.1
12. LR PM (MW)	156.0	156.0	156.0	156.0	156.0	156.0							156.0
13. NSC (MW)	495	495	495	495	495	495							495
14. OPER MBTU	1,363,547	1,801,870	1,911,438	1,229,320	1,701,438	2,324,451							10,332,064
15. NET GEN (MWH)	132,833	179,808	182,380	124,143	165,337	221,515							1,006,016
16. ANOHR (BTU/KWH)	10,265.1	10,021.1	10,480.5	9,902.5	10,290.7	10,493.4							10,270.3
17. NOF (%)	40.47	52.19	49.52	49.86	50.73	62.15							51.01
18. NPC (MW)	495	495	495	495	495	495							495

PROGRESS ENERGY FLORIDA

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2004

CRYSTAL RIVER 1	Jan-04	Feb-04	Mar-04	Apr-04	May-04	Jun-04	Jul-04	Aug-04	Sep-04	Oct-04	Nov-04	Dec-04	Jan - Jun Period
1. EAF	97.71	89.10	16.05	29.22	80.02	94.13							67.54
2. PH	744	696	744	719	744	720							4,367
3. SH	744.0	627.4	119.4	210.1	604.7	720.0							3,025.5
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
5. UH	0.0	68.7	624.6	508.9	139.3	0.0							1,341.5
6. POH	0.0	0.0	624.6	506.1	0.0	0.0							1,130.7
7. FOH	0.0	68.7	0.0	2.9	76.1	0.0							147.6
8. MOH	0.0	0.0	0.0	0.0	63.3	0.0							63.3
9. PFOH	4.9	0.8	0.0	0.0	0.0	10.5							16.3
10. LR PF (MW)	66.0	74.9	0.0	0.0	0.0	155.8							124.6
11. PMOH	65.2	17.6	0.0	0.0	18.7	164.6							266.1
12. LR PM (MW)	93.8	152.4	0.0	0.0	189.0	87.4							100.4
13. NSC (MW)	379	379	379	379	379	379							379
14. OPER MBTU	2,089,953	2,058,497	365,503	586,007	1,767,680	2,138,916							9,006,556
15. NET GEN (MWH)	212,857	204,585	36,536	55,079	172,880	206,932							888,869
16. ANOHR (BTU/KWH)	9,818.6	10,061.8	10,003.9	10,639.4	10,224.9	10,336.3							10,132.6
17. NOF (%)	75.49	86.04	80.75	69.17	75.44	75.83							77.52
18. NPC (MW)	379	379	379	379	379	379							379

PROGRESS ENERGY FLORIDA

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2004

CRYSTAL RIVER 2	Jan-04	Feb-04	Mar-04	Apr-04	May-04	Jun-04	Jul-04	Aug-04	Sep-04	Oct-04	Nov-04	Dec-04	Jan - Jun Period
1. EAF	94.17	5.14	92.68	94.32	85.24	91.14							77.73
2. PH	744	696	744	719	744	720							4,367
3. SH	744.0	56.2	715.3	693.5	662.2	720.0							3,591.2
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
5. UH	0.0	639.8	28.7	25.5	81.8	0.0							775.8
6. POH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
7. FOH	0.0	0.0	2.6	25.5	81.8	0.0							109.9
8. MOH	0.0	639.8	26.1	0.0	0.0	0.0							665.9
9. PFOH	40.5	49.9	29.7	4.4	20.3	0.0							144.9
10. LR PF (MW)	181.4	199.0	118.6	78.4	276.0	0.0							184.7
11. PMOH	54.0	0.0	73.0	58.5	28.8	362.5							576.8
12. LR PM (MW)	254.4	0.0	123.0	121.3	278.3	85.5							119.3
13. NSC (MW)	486	486	486	486	486	486							486
14. OPER MBTU	2,651,908	150,466	2,698,049	2,684,569	2,387,991	2,493,687							13,066,670
15. NET GEN (MWH)	266,641	13,730	280,206	274,571	241,666	253,802							1,330,616
16. ANOHR (BTU/KWH)	9,945.6	10,958.9	9,628.8	9,777.3	9,881.4	9,825.3							9,820.0
17. NOF (%)	73.74	50.27	80.61	81.47	75.09	72.53							76.24
18. NPC (MW)	486	486	486	486	486	486							486

PROGRESS ENERGY FLORIDA

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2004

CRYSTAL RIVER 3	Jan-04	Feb-04	Mar-04	Apr-04	May-04	Jun-04	Jul-04	Aug-04	Sep-04	Oct-04	Nov-04	Dec-04	Jan - Jun Period
1. EAF	100.00	100.00	87.74	100.00	100.00	99.98							97.91
2. PH	744	696	744	719	744	720							4,367
3. SH	744.0	696.0	672.3	719.0	744.0	720.0							4,295.3
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
5. UH	0.0	0.0	71.7	0.0	0.0	0.0							71.7
6. POH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
7. FOH	0.0	0.0	35.1	0.0	0.0	0.0							35.1
8. MOH	0.0	0.0	36.5	0.0	0.0	0.0							36.5
9. PFOH	0.0	0.0	21.3	0.0	0.0	0.0							21.3
10. LR PF (MW)	0.0	0.0	353.0	0.0	0.0	0.0							353.0
11. PMOH	0.0	0.0	22.0	0.0	0.0	44.7							66.7
12. LR PM (MW)	0.0	0.0	341.9	0.0	0.0	2.0							114.2
13. NSC (MW)	769	769	769	769	769	769							769
14. OPER MBTU	5,984,903	5,599,017	5,284,304	5,783,843	5,985,047	5,791,003							34,428,117
15. NET GEN (MWH)	589,270	551,445	517,097	569,151	583,206	555,585							3,365,754
16. ANOHR (BTU/KWH)	10,156.5	10,153.3	10,219.2	10,162.2	10,262.3	10,423.3							10,228.9
17. NOF (%)	102.99	103.03	100.01	102.94	101.93	100.34							101.90
18. NPC (MW)	769	769	769	769	769	769							769

PROGRESS ENERGY FLORIDA

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2004

CRYSTAL RIVER 4	Jan-04	Feb-04	Mar-04	Apr-04	May-04	Jun-04	Jul-04	Aug-04	Sep-04	Oct-04	Nov-04	Dec-04	Jan - Jun Period
1. EAF	96.37	76.54	94.03	98.46	96.66	98.21							93.51
2. PH	744	696	744	719	744	720							4,367
3. SH	721.3	580.5	744.0	716.2	744.0	714.0							4,220.0
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
5. UH	22.7	115.5	0.0	2.8	0.0	6.0							147.0
6. POH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
7. FOH	22.7	115.5	0.0	2.8	0.0	6.0							147.0
8. MOH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
9. PFOH	5.2	7.5	321.3	116.1	17.9	16.2							484.0
10. LR PF (MW)	351.3	299.5	99.5	51.6	358.0	272.8							109.1
11. PMOH	12.8	285.8	0.0	0.0	27.7	12.0							338.3
12. LR PM (MW)	101.1	112.5	0.0	0.0	415.0	44.0							134.3
13. NSC (MW)	720	720	720	720	720	720							720
14. OPER MBTU	4,179,046	3,100,776	4,349,207	4,324,800	4,306,115	4,379,964							24,639,906
15. NET GEN (MWH)	450,351	322,485	459,633	455,925	448,574	463,248							2,600,216
16. ANOHR (BTU/KWH)	9,279.5	9,615.3	9,462.3	9,485.8	9,599.6	9,454.9							9,476.1
17. NOF (%)	86.71	77.16	85.80	88.41	83.74	90.12							85.58
18. NPC (MW)	720	720	720	720	720	720							720

PROGRESS ENERGY FLORIDA

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2004

CRYSTAL RIVER 5	Jan-04	Feb-04	Mar-04	Apr-04	May-04	Jun-04	Jul-04	Aug-04	Sep-04	Oct-04	Nov-04	Dec-04	Jan - Jun Period
1. EAF	100.00	96.33	100.00	81.13	88.83	99.83							94.38
2. PH	744	696	744	719	744	720							4,367
3. SH	744.0	696.0	744.0	593.8	665.2	720.0							4,163.0
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
5. UH	0.0	0.0	0.0	125.2	78.8	0.0							204.0
6. POH	0.0	0.0	0.0	122.0	76.2	0.0							198.2
7. FOH	0.0	0.0	0.0	3.2	2.6	0.0							5.8
8. MOH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
9. PFOH	0.0	11.0	0.0	0.0	8.0	5.9							24.9
10. LR PF (MW)	0.0	304.4	0.0	0.0	99.0	103.8							190.8
11. PMOH	0.0	144.3	0.0	75.6	11.3	6.0							237.2
12. LR PM (MW)	0.0	103.6	0.0	99.0	202.4	41.0							105.3
13. NSC (MW)	717	717	717	717	717	717							717
14. OPER MBTU	4,632,050	4,181,723	4,591,836	3,620,472	3,803,862	4,489,029							25,318,972
15. NET GEN (MWH)	492,117	437,398	489,122	384,853	396,107	476,216							2,675,813
16. ANOHR (BTU/KWH)	9,412.5	9,560.5	9,387.9	9,407.4	9,603.1	9,426.5							9,462.2
17. NOF (%)	92.25	87.65	91.69	90.39	83.05	92.25							89.65
18. NPC (MW)	717	717	717	717	717	717							717

PROGRESS ENERGY FLORIDA

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2004

HINES 1	Jan-04	Feb-04	Mar-04	Apr-04	May-04	Jun-04	Jul-04	Aug-04	Sep-04	Oct-04	Nov-04	Dec-04	Jan - Jun Period
1. EAF	100.00	100.00	83.60	34.09	82.61	96.11							82.75
2. PH	744	696	744	719	744	720							4,367
3. SH	744.0	696.0	622.0	480.3	744.0	720.0							4,006.3
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
5. UH	0.0	0.0	122.0	238.7	0.0	0.0							360.7
6. POH	0.0	0.0	122.0	238.7	0.0	0.0							360.7
7. FOH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
8. MOH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
9. PFOH	0.0	0.0	0.0	0.0	1.7	48.9							50.7
10. LR PF (MW)	0.0	0.0	0.0	0.0	293.9	276.0							276.6
11. PMOH	0.0	0.0	0.0	480.3	262.1	0.0							742.4
12. LR PM (MW)	0.0	0.0	0.0	236.0	236.0	0.0							236.0
13. NSC (MW)	482	482	482	482	482	482							482
14. OPER MBTU	1,653,792	1,796,347	1,783,285	726,204	1,643,294	1,887,801							9,490,724
15. NET GEN (MWH)	217,724	246,290	244,992	92,129	216,532	256,631							1,274,298
16. ANOHR (BTU/KWH)	7,595.8	7,293.6	7,279.0	7,882.5	7,589.1	7,356.1							7,447.8
17. NOF (%)	60.71	73.42	81.71	39.80	60.38	73.95							65.99
18. NPC (MW)	482	482	482	482	482	482							482

PROGRESS ENERGY FLORIDA

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2004

TIGER BAY	Jan-04	Feb-04	Mar-04	Apr-04	May-04	Jun-04	Jul-04	Aug-04	Sep-04	Oct-04	Nov-04	Dec-04	Jan - Jun Period
1. EAF	100.00	91.46	38.84	94.18	100.00	98.59							87.03
2. PH	744	696	744	719	744	720							4,367
3. SH	595.1	636.6	70.3	492.7	685.2	709.9							3,189.7
4. RSH	148.9	0.0	218.8	184.5	58.8	0.0							610.9
5. UH	0.0	59.4	455.0	41.8	0.0	10.2							566.4
6. POH	0.0	48.0	455.0	0.0	0.0	0.0							503.0
7. FOH	0.0	11.4	0.0	0.0	0.0	10.2							21.6
8. MOH	0.0	0.0	0.0	41.8	0.0	0.0							41.8
9. PFOH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
10. LR PF (MW)	0.0	0.0	0.0	0.0	0.0	0.0							0.0
11. PMOH	0.0	0.0	0.0	0.0	0.0	0.0							0.0
12. LR PM (MW)	0.0	0.0	0.0	0.0	0.0	0.0							0.0
13. NSC (MW)	207	207	207	207	207	207							207
14. OPER MBTU	797,679	896,780	153,325	720,007	944,725	998,031							4,510,545
15. NET GEN (MWH)	98,830	117,429	11,615	90,929	122,847	127,476							569,126
16. ANOHR (BTU/KWH)	8,071.2	7,636.8	13,200.6	7,918.3	7,690.3	7,829.2							7,925.4
17. NOF (%)	80.23	89.11	79.87	89.16	86.61	86.75							86.20
18. NPC (MW)	207	207	207	207	207	207							207

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - JUNE 2004

Anclote 1				
Date	Outage Type	Hours	MW Affected	Description
1/5/2004	PFO	20.90	158.0	CONDENSER TUBE LEAKS
1/13/2004	FFO	64.35	498.0	ECONOMIZER LEAKS
1/21/2004	PFO	2.23	227.9	FEEDWATER PUMP
2/2/2004	PFO	8.98	159.0	CONDENSER TUBE LEAKS
2/3/2004	PMO	6.63	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
2/4/2004	PMO	16.23	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
2/5/2004	PMO	11.07	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
2/14/2004	PFO	4.18	159.1	CONDENSER TUBE LEAKS
2/15/2004	PMO	6.88	159.0	CONDENSER TUBE FOULING TUBE SIDE
2/16/2004	PMO	4.58	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
2/17/2004	PMO	2.72	158.9	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
2/19/2004	PMO	4.32	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
3/2/2004	PMO	6.57	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
3/2/2004	PMO	4.58	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
4/6/2004	PFO	49.58	4.0	OTHER HIGH PRESSURE HEATER PROBLEMS
4/15/2004	PMO	26.20	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
4/23/2004	PMO	4.48	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
5/3/2004	PFO	65.83	4.0	OTHER HIGH PRESSURE HEATER PROBLEMS
5/4/2004	PMO	12.77	155.0	CONDENSER TUBE FOULING TUBE SIDE
5/5/2004	PMO	8.28	155.0	CONDENSER TUBE FOULING TUBE SIDE
5/6/2004	PMO	8.12	159.0	CONDENSER TUBE FOULING TUBE SIDE
5/11/2004	PMO	14.02	159.0	CONDENSER TUBE FOULING TUBE SIDE
5/13/2004	PMO	4.17	158.9	CONDENSER TUBE FOULING TUBE SIDE
5/13/2004	PMO	4.63	159.0	CONDENSER TUBE FOULING TUBE SIDE
5/16/2004	PMO	9.03	159.0	CONDENSER TUBE FOULING TUBE SIDE
5/17/2004	PMO	6.38	159.0	CONDENSER TUBE FOULING TUBE SIDE

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - JUNE 2004

Date	Outage Type	Hours	MW Affected	Description
5/20/2004	PFO	17.32	304.0	OTHER OIL AND GAS FUEL SUPPLY PROBLEMS
5/22/2004	PFO	2.67	13.1	IGNITERS
5/23/2004	PMO	5.58	159.0	CONDENSER TUBE FOULING TUBE SIDE
5/24/2004	PMO	2.17	159.0	CONDENSER TUBE FOULING TUBE SIDE
5/24/2004	PMO	5.85	159.0	CONDENSER TUBE FOULING TUBE SIDE
5/27/2004	PMO	27.08	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
5/31/2004	PMO	7.68	159.0	CONDENSER TUBE FOULING TUBE SIDE
6/3/2004	PMO	6.33	159.0	CONDENSER TUBE FOULING TUBE SIDE
6/4/2004	PMO	2.02	159.0	CONDENSER TUBE FOULING TUBE SIDE
6/6/2004	PMO	6.58	159.0	CONDENSER TUBE FOULING TUBE SIDE
6/7/2004	PMO	2.35	158.9	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
6/8/2004	PMO	6.60	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
6/8/2004	FFO	5.88	498.0	GENERATOR VOLTAGE CONTROL
6/10/2004	PMO	6.30	159.0	CONDENSER TUBE FOULING TUBE SIDE
6/13/2004	PMO	8.77	159.0	CONDENSER TUBE FOULING TUBE SIDE
6/14/2004	PMO	6.73	159.0	CONDENSER TUBE FOULING TUBE SIDE
6/16/2004	PMO	3.12	159.0	CONDENSER TUBE FOULING TUBE SIDE
6/18/2004	PMO	5.53	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
6/21/2004	PMO	5.75	159.0	CONDENSER TUBE FOULING TUBE SIDE
6/22/2004	PMO	3.00	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
6/22/2004	PMO	8.23	159.0	CONDENSER TUBE FOULING TUBE SIDE
6/22/2004	PMO	11.07	96.0	AIR HEATER FOULING (REGENERATIVE)
6/23/2004	PMO	6.38	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
6/23/2004	PMO	9.63	96.0	AIR HEATER FOULING (REGENERATIVE)
6/27/2004	PMO	2.78	420.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/28/2004	PMO	4.75	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - JUNE 2004

Date	Outage Type	Hours	MW Affected	Description
6/29/2004	PMO	6.00	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
6/29/2004	PMO	5.25	159.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - JUNE 2004

Anclote 2				
Date	Outage Type	Hours	MW Affected	Description
1/13/2004	PMO	3.20	155.9	CONDENSER TUBE FOULING TUBE SIDE
1/14/2004	PMO	3.38	156.0	CONDENSER TUBE FOULING TUBE SIDE
1/18/2004	PMO	6.68	156.0	CONDENSER TUBE FOULING TUBE SIDE
1/19/2004	PMO	7.02	156.0	CONDENSER TUBE FOULING TUBE SIDE
1/20/2004	PMO	4.95	156.0	CONDENSER TUBE FOULING TUBE SIDE
1/21/2004	PMO	5.70	156.0	CONDENSER TUBE FOULING TUBE SIDE
2/15/2004	PMO	7.33	156.0	CONDENSER TUBE FOULING TUBE SIDE
2/16/2004	PMO	7.00	156.0	CONDENSER TUBE FOULING TUBE SIDE
2/18/2004	PFO	1.67	15.1	BOTTOM ASH HOPPERS (INCLUDING GATES)
2/22/2004	PMO	8.47	156.0	CONDENSER TUBE FOULING TUBE SIDE
2/23/2004	PMO	7.67	156.0	CONDENSER TUBE FOULING TUBE SIDE
2/24/2004	PMO	6.70	156.0	CONDENSER TUBE FOULING TUBE SIDE
2/25/2004	PMO	5.75	156.0	CONDENSER TUBE FOULING TUBE SIDE
2/26/2004	PMO	6.25	156.0	CONDENSER TUBE FOULING TUBE SIDE
3/16/2004	PMO	2.62	156.0	CONDENSER TUBE FOULING TUBE SIDE
3/16/2004	PMO	1.97	156.0	CONDENSER TUBE FOULING TUBE SIDE
3/16/2004	PMO	1.98	156.0	CONDENSER TUBE FOULING TUBE SIDE
3/16/2004	PMO	9.88	156.0	CONDENSER TUBE FOULING TUBE SIDE
3/17/2004	PFO	3.98	156.0	FEEDWATER PUMP DRIVE - CONTROLS
3/17/2004	PMO	6.55	156.0	CONDENSER TUBE FOULING TUBE SIDE
3/18/2004	PMO	6.17	156.0	CONDENSER TUBE FOULING TUBE SIDE
3/21/2004	PMO	8.20	156.0	CONDENSER TUBE FOULING TUBE SIDE
3/22/2004	PMO	8.50	156.0	CONDENSER TUBE FOULING TUBE SIDE
3/23/2004	PMO	6.33	156.0	CONDENSER TUBE FOULING TUBE SIDE
3/24/2004	PMO	6.88	156.0	CONDENSER TUBE FOULING TUBE SIDE
3/25/2004	PMO	7.62	156.0	CONDENSER TUBE FOULING TUBE SIDE

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - JUNE 2004

Inclote 2				
Date	Outage Type	Hours	MW Affected	Description
4/6/2004	PFO	0.25	479.2	FUEL OIL PUMPS - GENERAL
4/6/2004	PFO	9.13	301.0	FUEL OIL PUMPS - GENERAL
4/11/2004	PMO	8.60	156.0	CONDENSER TUBE FOULING TUBE SIDE
4/12/2004	PMO	6.87	156.0	CONDENSER TUBE FOULING TUBE SIDE
4/13/2004	PMO	8.67	156.0	CONDENSER TUBE FOULING TUBE SIDE
4/14/2004	PMO	4.85	156.0	CONDENSER TUBE FOULING TUBE SIDE
4/15/2004	PMO	1.97	156.0	CONDENSER TUBE FOULING TUBE SIDE
4/16/2004	PMO	3.75	156.0	CONDENSER TUBE FOULING TUBE SIDE
4/21/2004	PO	216.05	495.0	MINOR BOILER OVERHAUL (LESS THAN 720 HOURS)
5/1/2004	PO	85.60	495.0	MINOR BOILER OVERHAUL (LESS THAN 720 HOURS)
5/9/2004	PMO	8.05	156.0	CONDENSER TUBE FOULING TUBE SIDE
5/10/2004	PFO	17.75	190.0	TURBINE CONTROL VALVES
5/11/2004	PMO	12.92	156.0	CONDENSER TUBE FOULING TUBE SIDE
5/12/2004	PMO	6.20	156.0	CONDENSER TUBE FOULING TUBE SIDE
5/12/2004	PMO	9.35	156.0	CONDENSER TUBE FOULING TUBE SIDE
5/17/2004	PMO	2.62	156.0	OTHER CONDENSER TUBE CASING OR SHELL AND INTERNAL PROBLEMS
5/19/2004	PMO	6.08	156.0	CONDENSER TUBE FOULING TUBE SIDE
5/20/2004	PMO	7.67	156.0	CONDENSER TUBE FOULING TUBE SIDE
5/23/2004	PFO	19.75	350.0	BOILER CASING
5/26/2004	PMO	6.33	156.0	CONDENSER TUBE FOULING TUBE SIDE
5/29/2004	PFO	3.35	40.0	HIGH CIRCULATING WATER TEMPERATURE
5/30/2004	PMO	3.32	155.9	CONDENSER TUBE FOULING TUBE SIDE
5/30/2004	PMO	3.22	156.0	CONDENSER TUBE FOULING TUBE SIDE
6/1/2004	PMO	4.58	156.0	CONDENSER TUBE FOULING TUBE SIDE
6/1/2004	PMO	5.83	156.0	CONDENSER TUBE FOULING TUBE SIDE
6/2/2004	PMO	1.30	156.1	CONDENSER TUBE FOULING TUBE SIDE

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - JUNE 2004

Anclothe 2				
Date	Outage Type	Hours	MW Affected	Description
6/2/2004	PMO	6.20	156.0	CONDENSER TUBE FOULING TUBE SIDE
6/7/2004	PMO	8.18	156.0	CONDENSER TUBE FOULING TUBE SIDE
6/9/2004	PMO	8.30	156.0	CONDENSER TUBE FOULING TUBE SIDE
6/11/2004	PMO	3.87	156.0	CONDENSER TUBE FOULING TUBE SIDE
6/15/2004	PMO	7.57	156.0	CONDENSER TUBE FOULING TUBE SIDE
6/16/2004	PMO	8.20	156.0	CONDENSER TUBE FOULING TUBE SIDE
6/17/2004	PMO	7.40	156.0	CONDENSER TUBE FOULING TUBE SIDE
6/20/2004	PFO	1.50	25.1	BOTTOM ASH HOPPERS (INCLUDING GATES)
6/20/2004	PMO	7.23	156.0	CONDENSER TUBE FOULING TUBE SIDE
6/22/2004	PMO	5.93	156.0	CONDENSER TUBE FOULING TUBE SIDE
6/23/2004	PMO	5.70	156.0	CONDENSER TUBE FOULING TUBE SIDE
6/24/2004	PMO	5.10	156.0	CONDENSER TUBE FOULING TUBE SIDE
6/24/2004	PMO	6.07	156.0	CONDENSER TUBE FOULING TUBE SIDE
6/27/2004	PFO	2.78	402.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/27/2004	PMO	6.43	156.0	CONDENSER TUBE FOULING TUBE SIDE
6/28/2004	PMO	2.48	156.1	CONDENSER TUBE FOULING TUBE SIDE
6/29/2004	PMO	1.33	156.0	CONDENSER TUBE FOULING TUBE SIDE
6/29/2004	PMO	2.22	156.1	CONDENSER TUBE FOULING TUBE SIDE
6/29/2004	PMO	2.33	155.9	CONDENSER TUBE FOULING TUBE SIDE
6/29/2004	PMO	6.20	156.0	CONDENSER TUBE FOULING TUBE SIDE
6/30/2004	PMO	5.08	156.0	CONDENSER TUBE FOULING TUBE SIDE

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - JUNE 2004

Crystal River 1				
Date	Outage Type	Hours	MW Affected	Description
1/4/2004	PFO	4.93	66.0	PULVERIZER FEEDERS
1/4/2004	PMO	51.23	47.0	OTHER CIRCULATING WATER SYSTEM PROBLEMS
1/25/2004	PMO	14.00	265.0	COAL CONVEYERS AND FEEDERS
2/1/2004	PMO	5.65	75.0	PULVERIZER MILLS
2/9/2004	PMO	5.17	189.0	CONDENSER TUBE AND WATER BOX CLEANING
2/13/2004	FFO	68.65	379.0	FIRST REHEATER LEAKS
2/23/2004	PMO	6.77	189.0	CONDENSER TUBE AND WATER BOX CLEANING
4/22/2004			74.9	PULVERIZER COAL LEAK (PULVERIZERS ONLY)
			379.0	MAJOR TURBINE OVERHAUL (720 HOURS OR LONGER)
			379.0	FEEDWATER PUMP
4/23/2004	FFO	1.50	379.0	FEEDWATER PUMP
5/5/2004	FFO	23.30	379.0	TURBINE SUPERVISORY SYSTEM
5/12/2004	FFO	51.52	379.0	CONDENSER TUBE LEAKS
5/18/2004	PMO	7.23	189.0	CONDENSER TUBE AND WATER BOX CLEANING
5/19/2004	FFO	1.27	379.0	TURBINE HYDRAULIC SYSTEM PIPES AND VALVES
5/20/2004	PMO	11.47	189.0	CONDENSER TUBE AND WATER BOX CLEANING
5/22/2004	FMO	63.25	379.0	TURBINE MAIN STOP VALVES
6/2/2004	PFO	2.25	94.0	BOTTOM ASH SYSTEMS (WET OR DRY)
6/9/2004	PMO	5.23	189.0	CONDENSER TUBE AND WATER BOX CLEANING
6/12/2004	PMO	7.98	32.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/13/2004	PMO	8.33	32.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/14/2004	PMO	4.73	189.0	CONDENSER TUBE AND WATER BOX CLEANING
6/14/2004	PMO	6.73	84.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/15/2004	PMO	5.97	94.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/16/2004	PMO	54.25	75.0	OTHER PULVERIZER PROBLEMS
6/19/2004	PMO	9.32	70.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - JUNE 2004

Date	Outage Type	Hours	MW Affected	Description
6/20/2004	PMO	6.83	113.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/21/2004	PMO	11.93	46.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/22/2004	PMO	5.58	170.0	CONDENSER TUBE AND WATER BOX CLEANING
6/24/2004	PMO	8.25	94.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/25/2004	PMO	14.52	94.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/26/2004	PMO	13.58	122.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/29/2004	PMO	1.38	46.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/30/2004	PFO	7.08	189.0	CONDENSER TUBE LEAKS
6/30/2004	PFO	1.18	75.0	OTHER PULVERIZER PROBLEMS

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - JUNE 2004

Date	Outage Type	Hours	MW Affected	Description
1/6/2004	PMO	2.45	275.9	CONDENSER TUBE AND WATER BOX CLEANING
1/14/2004	PMO	28.50	252.0	AIR HEATER (HEAT PIPE,PLATE-TYPE)
1/15/2004	PMO	1.67	104.1	PULVERIZER MILLS
1/23/2004	PFO	7.50	104.0	PULVERIZER MILLS
1/23/2004	PMO	7.33	104.0	PULVERIZER MILLS
1/25/2004	PMO	14.00	352.0	COAL CONVEYERS AND FEEDERS
1/30/2004	PFO	82.90	199.0	BOILER RECIRCULATION VALVES
2/3/2004	FMO	639.80	486.0	BOILER RECIRCULATION VALVES
3/3/2004	PFO	9.25	180.0	OTHER FEEDWATER VALVES
3/7/2004	PMO	7.00	85.0	PULVERIZER MILLS
3/8/2004	PMO	7.00	85.0	PULVERIZER MILLS
3/9/2004	FFO	1.50	486.0	OTHER INSTRUMENT AIR PROBLEMS
3/10/2004	PMO	6.57	85.0	PULVERIZER MILLS
3/12/2004	PFO	1.17	85.0	IGNITERS
3/12/2004	PMO	6.08	85.0	PULVERIZER MILLS
3/15/2004	PMO	5.62	271.0	CONDENSER TUBE AND WATER BOX CLEANING
3/17/2004	PMO	4.80	257.0	CONDENSER TUBE AND WATER BOX CLEANING
3/18/2004	PMO	2.40	85.1	PULVERIZER FEEDERS
3/18/2004	PFO	1.05	85.2	PULVERIZER FEEDERS
3/18/2004	PMO	10.38	85.0	PULVERIZER MILLS
3/19/2004	FFO	1.12	486.0	FEEDWATER CONTROLS
3/19/2004	PMO	8.13	191.0	OTHER VOLTAGE CONDUCTORS AND BUSES
3/21/2004	PFO	1.92	129.0	480-VOLT TRANSFORMERS
3/25/2004	PFO	3.82	94.0	FOREIGN OBJECT IN MILL
3/26/2004	FMO	26.12	486.0	CIRCUIT BREAKERS
3/29/2004	PFO	12.50	85.0	OTHER PULVERIZER PROBLEMS

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - JUNE 2004

Crystal River 2				
Date	Outage Type	Hours	MW Affected	Description
3/30/2004	PMO	4.90	94.0	OTHER PULVERIZER PROBLEMS
3/30/2004	PMO	4.50	85.0	OTHER PULVERIZER PROBLEMS
3/31/2004	PMO	2.92	85.0	OTHER PULVERIZER PROBLEMS
3/31/2004	PMO	2.72	85.0	OTHER PULVERIZER PROBLEMS
4/2/2004	PMO	32.12	104.0	PULVERIZER MILLS
4/4/2004	PFO	2.62	94.0	OTHER PULVERIZER PROBLEMS
4/4/2004	PMO	5.33	290.0	CONDENSER TUBE AND WATER BOX CLEANING
4/8/2004	PMO	4.10	85.0	OTHER PULVERIZER PROBLEMS
4/9/2004	PMO	4.67	85.0	OTHER PULVERIZER PROBLEMS
4/11/2004	PMO	4.75	104.0	OTHER PULVERIZER PROBLEMS
4/12/2004	PMO	4.83	143.0	CONDENSER TUBE AND WATER BOX CLEANING
4/13/2004	PMO	2.55	104.1	CIRCULATING WATER PUMPS
4/14/2004	PMO	0.18	93.0	CIRCULATING WATER PUMPS
4/14/2004	FFO	25.50	486.0	EMERGENCY GENERATOR TRIP DEVICES
4/30/2004	PFO	1.80	55.9	BOTTOM ASH SYSTEMS (WET OR DRY)
5/4/2004	PMO	4.58	295.0	CONDENSER TUBE AND WATER BOX CLEANING
5/4/2004	PMO	7.15	295.0	CONDENSER TUBE AND WATER BOX CLEANING
5/6/2004	PMO	5.92	271.0	CONDENSER TUBE AND WATER BOX CLEANING
5/17/2004	PFO	20.33	276.0	BOILER RECIRCULATION VALVES
5/20/2004	PMO	4.10	295.0	CONDENSER TUBE AND WATER BOX CLEANING
5/22/2004	FFO	81.77	486.0	FURNACE WALL LEAKS
5/31/2004	PMO	7.07	247.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/2/2004	PMO	3.58	42.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/2/2004	PMO	10.00	295.0	CONDENSER TUBE AND WATER BOX CLEANING
6/3/2004	PMO	2.50	56.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/6/2004	PMO	5.82	295.0	CONDENSER TUBE AND WATER BOX CLEANING

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - JUNE 2004

Crystal River 2				
Date	Outage Type	Hours	MW Affected	Description
6/7/2004	PMO	5.90	295.0	CONDENSER TUBE AND WATER BOX CLEANING
6/9/2004	PMO	2.00	85.1	PULVERIZER FEEDERS
6/9/2004	PMO	3.75	276.0	CONDENSER TUBE AND WATER BOX CLEANING
6/11/2004	PMO	4.65	295.0	CONDENSER TUBE AND WATER BOX CLEANING
6/12/2004	PMO	5.97	37.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/13/2004	PMO	8.33	51.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/14/2004	PMO	6.63	80.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/15/2004	PMO	6.05	56.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/16/2004	PMO	4.45	352.0	CONDENSER TUBE AND WATER BOX CLEANING
6/19/2004	PMO	9.28	70.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/20/2004	PMO	6.83	123.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/21/2004	PMO	11.93	66.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/21/2004	PMO	5.23	210.0	CONDENSER TUBE AND WATER BOX CLEANING
6/24/2004	PMO	4.50	191.1	CONDENSER TUBE AND WATER BOX CLEANING
6/21/2004	PMO	59.55	85.0	OTHER PULVERIZER PROBLEMS
6/24/2004	PMO	8.25	71.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/25/2004	PMO	15.18	71.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/26/2004	PMO	14.00	176.0	THERMAL DISCHARGE LIMITS - ALL STEAM UNITS
6/22/2004	PMO	158.12	33.0	HEATER DRAIN PUMPS

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - JUNE 2004

Date	Outage Type	Hours	MW Affected	Description
3/2/2004	PMO	6.77	400.0	REACTOR COOLANT/RECIRCULATING PUMP MOTORS
3/3/2004	FMO	36.53	769.0	REACTOR COOLANT/RECIRCULATING PUMP MOTORS
3/4/2004	PMO	15.27	316.0	REACTOR COOLANT/RECIRCULATING PUMP MOTORS
3/24/2004	FFO	35.13	769.0	REACTOR CONTROL SYSTEM/INTEGRATED CONTROL SYSTEM PROBLEMS
3/25/2004	PFO	21.30	353.0	REACTOR CONTROL SYSTEM/INTEGRATED CONTROL SYSTEM PROBLEMS
6/9/2004	PMO	44.70	2.0	REACTOR CONTROL SYSTEM/INTEGRATED CONTROL SYSTEM PROBLEMS

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - JUNE 2004

Crystal River 4				
Date	Outage Type	Hours	MW Affected	Description
1/5/2004	PMO	5.50	101.1	PULVERIZER COAL LEAK (PULVERIZERS ONLY)
1/7/2004	FFO	22.67	720.0	PROCESS COMPUTER
1/10/2004	PMO	7.33	101.0	PULVERIZER COAL LEAK (PULVERIZERS ONLY)
1/21/2004	PFO	1.77	101.1	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
1/26/2004	PFO	3.38	482.1	AC INSTRUMENT POWER TRANSFORMERS
2/1/2004	FFO	1.88	720.0	FORCED DRAFT FAN DRIVES (OTHER THAN MOTOR)
2/10/2004	PMO	3.00	433.9	CEMS CERTIFICATION AND RECERTIFICATION
2/10/2004	PMO	1.50	243.8	CEMS CERTIFICATION AND RECERTIFICATION
2/11/2004	PMO	271.39	102.0	HEATER DRAIN PUMPS
2/12/2004	PMO	5.20	256.0	CEMS CERTIFICATION AND RECERTIFICATION
2/12/2004	PMO	4.75	309.1	CEMS CERTIFICATION AND RECERTIFICATION
2/17/2004	PFO	4.22	509.0	OTHER BOILER TUBE LEAKS
2/17/2004	FFO	87.58	720.0	OTHER BOILER TUBE LEAKS
2/21/2004	FFO	7.87	720.0	DESUPERHEATER/ATTEMPERATOR CONTROLS
2/21/2004	FFO	7.15	720.0	OPERATOR ERROR
2/22/2004	FFO	0.97	720.0	FEEDWATER REGULATING (BOILER LEVEL CONTROL) VALVE
2/23/2004	PFO	3.25	27.9	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
2/25/2004	FFO	8.67	720.0	OTHER EXCITER PROBLEMS
2/25/2004	FFO	1.38	720.0	OPERATOR ERROR
3/1/2004	PFO	15.00	125.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/2/2004	PFO	12.50	130.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/3/2004	PFO	18.83	120.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/4/2004	PFO	5.00	92.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/5/2004	PFO	18.08	139.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/6/2004	PFO	16.83	120.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/7/2004	PFO	14.25	87.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - JUNE 2004

Date	Outage Type	Hours	MW Affected	Description
3/8/2004	PFO	40.33	111.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/11/2004	PFO	13.17	73.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/12/2004	PFO	18.33	125.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/13/2004	PFO	17.08	102.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/17/2004	PFO	15.00	111.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/18/2004	PFO	15.75	111.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/19/2004	PFO	3.92	30.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/20/2004	PFO	4.25	82.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/22/2004	PFO	52.42	92.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/25/2004	PFO	14.00	35.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/26/2004	PFO	5.83	39.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/29/2004	PFO	7.17	63.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/31/2004	PFO	7.75	54.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
3/31/2004	PFO	5.75	38.9	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
4/1/2004	PFO	13.00	101.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
4/1/2004	PFO	5.50	54.1	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
4/2/2004	PFO	19.00	54.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
4/3/2004	PFO	16.75	54.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
4/4/2004	PFO	13.50	35.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
4/5/2004	PFO	5.75	58.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
4/5/2004	PFO	12.50	25.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
4/6/2004	PFO	6.83	58.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
4/6/2004	PFO	11.00	35.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
4/7/2004	PFO	5.33	35.0	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS
4/12/2004	PFO	1.13	101.0	OTHER PULVERIZER PROBLEMS
4/17/2004	PFO	5.80	43.9	OPACITY STACK EMISSIONS - FOSSIL STEAM UNITS

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - JUNE 2004

Date	Outage Type	Hours	MW Affected	Description
4/19/2004	FFO	2.77	720.0	PULVERIZER FEEDER MOTOR
5/17/2004	PMO	8.92	415.0	CONDENSER TUBE AND WATER BOX CLEANING
5/18/2004	PMO	10.25	415.0	CONDENSER TUBE AND WATER BOX CLEANING
5/19/2004	PFO	17.85	358.0	CONDENSER TUBE LEAKS
5/25/2004	PMO	8.50	415.0	CONDENSER TUBE AND WATER BOX CLEANING
6/3/2004	FFO	6.03	720.0	FEEDWATER VALVES (NOT FEEDWATER REGULATING VALVE)
6/3/2004	PFO	9.23	449.0	FEEDWATER VALVES (NOT FEEDWATER REGULATING VALVE)
6/15/2004	PMO	12.00	44.0	CEMS CERTIFICATION AND RECERTIFICATION
6/17/2004	PFO	1.68	110.8	OTHER PULVERIZER PROBLEMS
6/30/2004	PFO	5.23	14.0	OTHER FUEL QUALITY PROBLEMS

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - JUNE 2004

Crystal River 5				
Date	Outage Type	Hours	MW Affected	Description
2/1/2004	PMO	141.33	98.0	PULVERIZER MILLS
2/23/2004	PFO	2.72	99.0	BURNER INSTRUMENTS AND CONTROLS (EXCEPT LIGHT-OFF)
2/24/2004	PMO	2.08	431.0	CEMS CERTIFICATION AND RECERTIFICATION
2/24/2004	PMO	0.83	241.0	CEMS CERTIFICATION AND RECERTIFICATION
2/24/2004	PFO	3.12	431.1	AIR HEATER FOULING (REGENERATIVE)
2/25/2004	PFO	5.15	335.9	AIR HEATER FOULING (REGENERATIVE)
4/22/2004	PMO	75.63	99.0	PULVERIZER OVERHAUL
4/25/2004	FFO	3.20	717.0	OTHER FEEDWATER VALVES
4/25/2004	PO	122.00	717.0	BOILER INSPECTIONS
5/1/2004	PO	76.20	717.0	BOILER INSPECTIONS
5/4/2004	FFO	1.32	717.0	OTHER FEEDWATER VALVES
5/4/2004	FFO	0.60	717.0	OTHER FEEDWATER VALVES
5/4/2004	FFO	0.65	717.0	OTHER FEEDWATER VALVES
5/13/2004	PFO	8.00	99.0	HEATER DRAIN PUMPS
5/26/2004	PMO	3.08	479.1	CONDENSER TUBE AND WATER BOX CLEANING
5/27/2004	PMO	8.25	99.0	PULVERIZER MILLS
6/14/2004	PFO	4.33	99.0	HEATER DRAIN PUMPS
6/16/2004	PMO	6.00	41.0	CEMS CERTIFICATION AND RECERTIFICATION
6/17/2004	PFO	1.57	117.1	OTHER PULVERIZER PROBLEMS

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - JUNE 2004

Date	Outage Type	Hours	MW Affected	Description
3/26/2004	PO	360.68	482.0	MAJOR GAS TURBINE OVERHAUL
4/10/2004	PMO	742.38	236.0	MAJOR GAS TURBINE OVERHAUL
5/20/2004	PFO	1.08	327.1	TURBINE HYDRAULIC SYSTEM PIPES AND VALVES
5/21/2004	PFO	0.65	237.3	GT COOLING AND SEAL AIR SYSTEM
6/18/2004	PFO	5.2	276.0	GT FUEL PIPING AND VALVES
6/19/2004	PFO	8.48	276.0	GT FUEL PIPING AND VALVES
6/20/2004	PFO	35.25	276.0	GT FUEL PIPING AND VALVES

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - JUNE 2004

Tiger Bay				
Date	Outage Type	Hours	MW Affected	Description
2/27/2004	FFO	11.43	207.0	SOLID STATE EXCITER ELEMENT
2/28/2004	PO	503.00	207.0	GAS TURBINE HOT END INSPECTION
4/13/2004	FMO	41.83	207.0	MAIN STEAM RELIEF/SAFETY VALVES
6/1/2004	FFO	10.15	207.0	GT COOLING AND SEAL AIR SYSTEM