

ORIGINAL

Matilda Sanders

From: James A. McGee [jmcgee@tampabay.rr.com]
Sent: Friday, January 28, 2005 10:04 AM
To: Filings@psc.state.fl.us
Subject: Docket No. 050060-EI; PEF Request to Exclude Outage Event

This electronic filing is made by

James A. McGee
P.O. Box 14042
St. Petersburg, FL 33733
727-820-5184
james.mcgee@pgnmail.com

Docket No. 050060-EI

In re: Request of Progress Energy Florida to exclude an Outage Event on December 26, 2004 from its Annual Distribution Service Reliability Report.

On behalf of Progress Energy Florida.

Consisting of 3 pages.

The attached document for filing is Progress Energy's Exhibit A to its Request to Exclude Outage Event, including a filing letter.

- CMP _____
- COM _____
- CTR _____
- ECR _____
- GCL _____
- OPC _____
- MMS _____
- RCA _____
- SCR _____
- SEC 1
- OTH _____

1/28/2005

DOCUMENT NUMBER-DATE

01034 JAN 28 05

FLORIDA PUBLIC SERVICE COMMISSION



ORIGINAL

JAMES A. MCGEE
ASSOCIATE GENERAL COUNSEL
PROGRESS ENERGY SERVICE COMPANY, LLC

January 28, 2005

VIA ELECTRONIC FILING

Ms. Blanca S. Bayó, Director
Division of the Commission Clerk
and Administrative Services
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399-0850

Re: Docket No. 050060-EI; Request of Progress Energy Florida
to exclude an Outage Event on December 26, 2004 from its
Annual Distribution Service Reliability Report.

Dear Ms. Bayó:

By my filing letter of January 25, 2005 that accompanied the subject Request of Progress Energy Florida, I advised that Exhibit A to the Request had been delayed in transmittal and would be submitted shortly by supplemental filing. I have therefore enclosed for filing with this letter Exhibit A to Progress Energy's Request, which is intended to supplement and complete the initial January 25th filing.

Please acknowledge your receipt of the above filing as provided in the Commission's electronic filing procedures. Thank you for your assistance in this matter.

Very truly yours,

s/ James A. McGee

JAM/scc
Enclosures

ATTACHMENT A

**December 26, 2004 Severe Weather Event
Distribution Outage Detail
by Cause and Device Code**

December 26, 2004 Severe Weather Event

Distribution Outage Detail by Cause Code

Outage Cause Code	South Coastal Region		System
	Storm-related Causes	All Causes	
STORM	166	166	178
TREE-PREVENTABLE	166	166	193
TREE-NONPREVENT	14	14	40
CUST. REPORT IN ERROR		93	107
INSIDE CUST. TROUBLE		44	63
CONNECTOR FAILURE		0	13
UNKNOWN		0	21
DEFECTIVE EQUIP.		0	11
EMERG SHUTDOWN - PEF		6	9
OVERLOAD		2	9
OH SECONDARY CABLE		6	7
UG PRIMARY CABLE		2	6
ANIMAL			5
LINE MAINTENANCE		3	5
VEH/CONST. EQUIP.		1	3
HUMAN ERROR - PEF		1	2
HUMAN ERROR - PUBLIC		0	1
DIG-IN		0	
MISCELLANEOUS		2	2
LIGHTNING		0	1
RIGHT-OF-WAY		1	1
Grand Total	346	514	689

Distribution Outage Detail by Device Code

Device Description	Storm-related Outage Causes				All Causes
	Storm	Tree - Non-Preventable	Tree - Preventable	All Storm Causes	
SERVICE	33	3	26	62	188
TRANSFORMER	70	2	63	135	152
FUSE	45	7	67	119	138
TERMINAL POLE FUSE	7	1	7	15	18
FEEDER	5		2	7	10
RECLOSER	5	1		6	6
SECTIONALIZER			1	1	1
SWITCHGEAR	1			1	1
Grand Total	166	14	166	346	514