



JAMES A. MCGEE

ASSOCIATE GENERAL COUNSEL
PROGRESS ENERGY SERVICE CO., LLC

April 20, 2005

Ms. Blanca S. Bayó, Director
Division of the Commission Clerk
and Administrative Services
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399-0850

Re: Docket No. 050001-EI

Dear Ms. Bayó:

Enclosed for filing in the subject docket on behalf of Progress Energy Florida, Inc., is an original and ten copies of its Performance Data Report for March 2005.

Please acknowledge your receipt of the above filing on the enclosed copy of this letter and return to the undersigned.

Very truly yours,

A handwritten signature in black ink, appearing to read "James A. McGee".

James A. McGee

JAM/sc
Enclosure

cc: Parties of record

Progress Energy Florida

CERTIFICATE OF SERVICE

Docket No. 050001-EI

I HEREBY CERTIFY that a true copy of Progress Energy Florida, Inc.'s Performance Data Report for the month of March 2005 has been furnished to the following individuals by regular US Mail this 20th day of April 2005.

John Butler

Steel Hector & Davis
215 South Monroe Street
Suite 601
Tallahassee, FL 32301-1804

Jeffrey A. Stone, Esquire
Russell A. Badders, Esquire
Beggs and Lane
P. O. Box 12950
Pensacola, FL 32576-2950

Lee L. Willis, Esquire
James D. Beasley, Esquire
Ausley & McMullen
P. O. Box 391
Tallahassee, FL 32302

Wm. Cochran Keating, IV
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, FL 32399-0850

Robert Vandiver, Esquire

Office of the Public Counsel
111 West Madison Street
Room 812
Tallahassee, FL 32399-1400

Joseph A. McGlothlin, Esquire
Vicki Gordon Kaufman, Esquire
McWhirter, Reeves, McGlothlin,
117 S. Gadsden Street
Tallahassee, FL 32301

John McWhirter, Jr.
McWhirter, Reeves, McGlothlin,
400 North Tampa Street
Suite 2450
Tampa, FL 33601

Norman Horton, Jr., Esquire
Messer, Caparello & Self
P. O. Box 1876
Tallahassee, FL 32302

Ronald C. LeFace, Esquire
Seann M. Frazier, Esquire
Greenberg Traurig
101 East College Avenue
Tallahassee, FL 32301



Attorney

PROGRESS ENERGY FLORIDA

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2005

ANCLOTE 1	Jan-05	Feb-05	Mar-05	Apr-05	May-05	Jun-05	Jul-05	Aug-05	Sep-05	Oct-05	Nov-05	Dec-05	Jan - Mar Period
1. EAF	90.43	66.83	83.31										80.64
2. PH	744	672	744										2,160
3. SH	648.2	167.7	620.9										1,436.8
4. RSH	25.2	284.0	0.0										309.2
5. UH	70.6	220.3	123.1										414.0
6. POH	70.6	220.3	0.0										290.9
7. FOH	0.0	0.0	123.1										123.1
8. MOH	0.0	0.0	0.0										0.0
9. PFOH	2.4	0.0	4.8										7.3
10. LR PF (MW)	135.3	0.0	110.1										118.5
11. PMOH	0.0	8.1	0.0										8.1
12. LR PM (MW)	0.0	159.0	0.0										159.0
13. NSC (MW)	498	498	498										498
/ 14. OPER MBTU	1,561,432	392,297	1,646,230										3,599,958
15. NET GEN (MWH)	154,665	40,149	165,496										360,310
16. ANOHR (BTU/KWH)	10,095.6	9,771.0	9,947.2										9,991.3
17. NOF (%)	47.91	48.07	53.52										50.35
18. NPC (MW)	498	498	498										498

PROGRESS ENERGY FLORIDA

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2005

ANCLOTE 2	Jan-05	Feb-05	Mar-05	Apr-05	May-05	Jun-05	Jul-05	Aug-05	Sep-05	Oct-05	Nov-05	Dec-05	Jan - Mar Period
1. EAF	58.78	99.70	90.42										82.41
2. PH	744	672	744										2,160
3. SH	278.4	672.0	457.1										1,407.5
4. RSH	165.8	0.0	215.7										381.5
5. UH	299.9	0.0	71.2										371.0
6. POH	281.5	0.0	0.0										281.5
7. FOH	18.4	0.0	71.2										89.5
8. MOH	0.0	0.0	0.0										0.0
9. PFOH	56.9	6.0	0.4										63.3
10. LR PF (MW)	59.0	168.2	105.7										69.7
11. PMOH	0.0	0.0	0.0										0.0
12. LR PM (MW)	0.0	0.0	0.0										0.0
13. NSC (MW)	495	495	495										495
14. OPER MBTU	648,670	1,547,037	1,336,005										3,531,712
15. NET GEN (MWH)	64,318	152,064	136,854										353,236
16. ANOHR (BTU/KWH)	10,085.4	10,173.6	9,762.3										9,998.2
17. NOF (%)	46.68	45.71	60.48										50.70
18. NPC (MW)	495	495	495										495

PROGRESS ENERGY FLORIDA

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2005

CRYSTAL RIVER 1	Jan-05	Feb-05	Mar-05	Apr-05	May-05	Jun-05	Jul-05	Aug-05	Sep-05	Oct-05	Nov-05	Dec-05	Jan - Mar Period
1. EAF	97.25	96.32	96.16										96.59
2. PH	744	672	744										2,160
3. SH	744.0	672.0	744.0										2,160.0
4. RSH	0.0	0.0	0.0										0.0
5. UH	0.0	0.0	0.0										0.0
6. POH	0.0	0.0	0.0										0.0
7. FOH	0.0	0.0	0.0										0.0
8. MOH	0.0	0.0	0.0										0.0
9. PFOH	5.3	5.5	63.7										74.5
10. LR PF (MW)	76.2	265.0	31.1										51.6
11. PMOH	40.0	47.3	50.2										137.4
12. LR PM (MW)	183.9	167.5	176.2										175.4
13. NSC (MW)	379	379	379										379
14. OPER MBTU	2,114,365	1,926,538	2,375,343										6,416,245
15. NET GEN (MWH)	208,634	187,335	235,425										631,394
16. ANOHR (BTU/KWH)	10,134.3	10,283.9	10,089.6										10,162.0
17. NOF (%)	73.99	73.55	83.49										77.13
18. NPC (MW)	379	379	379										379

PROGRESS ENERGY FLORIDA

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2005

CRYSTAL RIVER 2	Jan-05	Feb-05	Mar-05	Apr-05	May-05	Jun-05	Jul-05	Aug-05	Sep-05	Oct-05	Nov-05	Dec-05	Jan - Mar Period
1. EAF	86.04	50.17	84.62										74.39
2. PH	744	672	744										2,160
3. SH	648.0	345.5	646.0										1,639.5
4. RSH	0.0	0.0	0.0										0.0
5. UH	96.0	326.5	98.0										520.5
6. POH	0.0	0.0	0.0										0.0
7. FOH	96.0	130.5	98.0										324.5
8. MOH	0.0	196.0	0.0										196.0
9. PFOH	15.1	6.9	59.6										81.5
10. LR PF (MW)	85.0	194.0	33.0										56.2
11. PMOH	21.8	11.7	50.7										84.2
12. LR PM (MW)	117.8	231.3	118.8										134.1
13. NSC (MW)	486	486	486										486
14. OPER MBTU	2,279,425	1,211,957	2,477,114										5,968,496
15. NET GEN (MWH)	235,155	126,046	258,971										620,172
16. ANOHR (BTU/KWH)	9,693.3	9,615.2	9,565.2										9,623.9
17. NOF (%)	74.67	75.07	82.48										77.83
18. NPC (MW)	486	486	486										486

PROGRESS ENERGY FLORIDA

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2005

CRYSTAL RIVER 3	Jan-05	Feb-05	Mar-05	Apr-05	May-05	Jun-05	Jul-05	Aug-05	Sep-05	Oct-05	Nov-05	Dec-05	Jan - Mar Period
1. EAF	100.00	100.00	100.00										100.00
2. PH	744	672	744										2,160
3. SH	744.0	672.0	744.0										2,160.0
4. RSH	0.0	0.0	0.0										0.0
5. UH	0.0	0.0	0.0										0.0
6. POH	0.0	0.0	0.0										0.0
7. FOH	0.0	0.0	0.0										0.0
8. MOH	0.0	0.0	0.0										0.0
9. PFOH	0.0	0.0	0.0										0.0
10. LR PF (MW)	0.0	0.0	0.0										0.0
11. PMOH	0.0	0.0	0.0										0.0
12. LR PM (MW)	0.0	0.0	0.0										0.0
13. NSC (MW)	769	769	769										769
14. OPER MBTU	5,983,430	5,406,034	5,984,831										17,374,295
15. NET GEN (MWH)	587,870	531,169	587,657										1,706,697
16. ANOHR (BTU/KWH)	10,178.1	10,177.6	10,184.2										10,180.1
17. NOF (%)	102.75	102.79	102.71										102.75
18. NPC (MW)	769	769	769										769

PROGRESS ENERGY FLORIDA

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2005

CRYSTAL RIVER 4	Jan-05	Feb-05	Mar-05	Apr-05	May-05	Jun-05	Jul-05	Aug-05	Sep-05	Oct-05	Nov-05	Dec-05	Jan - Mar Period
1. EAF	99.55	99.76	23.64										73.47
2. PH	744	672	744										2,160
3. SH	744.0	672.0	187.2										1,603.2
4. RSH	0.0	0.0	0.0										0.0
5. UH	0.0	0.0	556.8										556.8
6. POH	0.0	0.0	551.1										551.1
7. FOH	0.0	0.0	0.0										0.0
8. MOH	0.0	0.0	5.7										5.7
9. PFOH	2.2	0.0	10.4										12.6
10. LR PF (MW)	58.9	0.0	605.9										512.3
11. PMOH	13.6	15.2	12.1										40.9
12. LR PM (MW)	168.4	75.4	152.1										129.0
13. NSC (MW)	720	720	720										720
14. OPER MBTU	4,664,246	4,145,737	988,240										9,798,223
15. NET GEN (MWH)	490,605	440,364	104,004										1,034,973
16. ANOHR (BTU/KWH)	9,507.1	9,414.3	9,501.9										9,467.1
17. NOF (%)	91.59	91.01	77.16										89.66
18. NPC (MW)	720	720	720										720

PROGRESS ENERGY FLORIDA

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2005

CRYSTAL RIVER 5	Jan-05	Feb-05	Mar-05	Apr-05	May-05	Jun-05	Jul-05	Aug-05	Sep-05	Oct-05	Nov-05	Dec-05	Jan - Mar Period
1. EAF	86.07	94.70	94.30										91.59
2. PH	744	672	744										2,160
3. SH	652.6	658.6	718.0										2,029.2
4. RSH	0.0	0.0	0.0										0.0
5. UH	91.4	13.4	26.1										130.8
6. POH	0.0	0.0	0.0										0.0
7. FOH	0.0	13.4	0.0										13.4
8. MOH	91.4	0.0	26.1										117.4
9. PFOH	13.2	149.8	32.4										195.4
10. LR PF (MW)	24.0	60.6	91.3										63.2
11. PMOH	41.0	61.2	89.3										191.5
12. LR PM (MW)	206.7	111.9	98.0										125.7
13. NSC (MW)	717	717	717										717
14. OPER MBTU	3,870,572	3,913,541	4,710,168										12,494,281
15. NET GEN (MWH)	409,977	408,757	496,599										1,315,333
16. ANOHR (BTU/KWH)	9,441.0	9,574.2	9,484.9										9,498.9
17. NOF (%)	87.61	86.56	96.47										90.41
18. NPC (MW)	717	717	717										717

PROGRESS ENERGY FLORIDA

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2005

HINES 1	Jan-05	Feb-05	Mar-05	Apr-05	May-05	Jun-05	Jul-05	Aug-05	Sep-05	Oct-05	Nov-05	Dec-05	Jan - Mar Period
1. EAF	99.67	99.97	99.74										99.79
2. PH	744	672	744										2,160
3. SH	520.7	672.0	744.0										1,936.7
4. RSH	223.3	0.0	0.0										223.3
5. UH	0.0	0.0	0.0										0.0
6. POH	0.0	0.0	0.0										0.0
7. FOH	0.0	0.0	0.0										0.0
8. MOH	0.0	0.0	0.0										0.0
9. PFOH	5.5	0.5	4.0										9.9
10. LR PF (MW)	216.0	224.9	236.0										224.4
11. PMOH	0.0	0.0	0.0										0.0
12. LR PM (MW)	0.0	0.0	0.0										0.0
13. NSC (MW)	482	482	482										482
14. OPER MBTU	1,593,554	1,686,896	2,302,270										5,582,720
15. NET GEN (MWH)	202,218	233,028	316,323										751,569
16. ANOHR (BTU/KWH)	7,880.4	7,239.0	7,278.2										7,428.1
17. NOF (%)	80.57	71.94	88.21										80.51
18. NPC (MW)	482	482	482										482

PROGRESS ENERGY FLORIDA

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2005

TIGER BAY	Jan-05	Feb-05	Mar-05	Apr-05	May-05	Jun-05	Jul-05	Aug-05	Sep-05	Oct-05	Nov-05	Dec-05	Jan - Mar Period
1. EAF	69.21	100.00	100.00										89.39
2. PH	744	672	744										2,160
3. SH	85.3	154.8	79.7										319.7
4. RSH	429.7	517.2	664.3										1,611.2
5. UH	229.1	0.0	0.0										229.1
6. POH	0.0	0.0	0.0										0.0
7. FOH	229.1	0.0	0.0										229.1
8. MOH	0.0	0.0	0.0										0.0
9. PFOH	0.0	0.0	0.0										0.0
10. LR PF (MW)	0.0	0.0	0.0										0.0
11. PMOH	0.0	0.0	0.0										0.0
12. LR PM (MW)	0.0	0.0	0.0										0.0
13. NSC (MW)	207	207	207										207
14. OPER MBTU	127,135	297,178	170,846										595,159
15. NET GEN (MWH)	15,625	27,999	15,350										58,974
16. ANOHR (BTU/KWH)	8,136.7	10,613.9	11,130.0										10,091.9
17. NOF (%)	88.54	87.39	93.08										89.12
18. NPC (MW)	207	207	207										207

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - MARCH 2005

Anclote 1				
Date	Outage Type	Hours	MW Affected	Description
1/9/2005	PFO	1.18	109.9	DESUPERHEATER/ATTEMPERATOR VALVES
1/25/2005	PFO	1.25	159.0	COMBUSTION/STEAM CONDITION CONTROLS
1/29/2005	PO	70.55	498.0	BOTTOM ASH HOPPERS (INCLUDING GATES)
2/1/2005	PO	220.32	498.0	BOTTOM ASH HOPPERS (INCLUDING GATES)
2/15/2005	PMO	8.10	159.0	CONDENSER TUBE FOULING TUBE SIDE
3/9/2005	PFO	4.83	110.0	BOTTOM ASH HOPPERS (INCLUDING GATES)
3/19/2005	FFO	123.08	498.0	FIRST SUPERHEATER LEAKS

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - MARCH 2005

Date	Outage Type	Hours	MW Affected	Description
1/2/2005	PFO	0.92	58.8	CONDENSATE/HOTWELL PUMP MOTOR
1/4/2005	PFO	36.17	59.0	CONDENSATE/HOTWELL PUMP MOTOR
1/6/2005	PO	281.50	495.0	TURBINE REHEAT STOP VALVES
1/24/2005	PFO	1.93	58.9	CONDENSATE/HOTWELL PUMP MOTOR
1/24/2005	PFO	2.67	59.0	CONDENSATE/HOTWELL PUMP MOTOR
1/25/2005	FFO	18.37	495.0	AIR SUPPLY DUCTS
1/25/2005	PFO	3.00	59.1	CONDENSATE/HOTWELL PUMP MOTOR
1/28/2005	PFO	4.12	59.0	CONDENSATE/HOTWELL PUMP MOTOR
1/29/2005	PFO	1.97	58.9	CONDENSATE/HOTWELL PUMP MOTOR
1/30/2005	PFO	2.67	59.0	CONDENSATE/HOTWELL PUMP MOTOR
1/31/2005	PFO	3.50	59.0	CONDENSATE/HOTWELL PUMP MOTOR
2/1/2005	PFO	2.90	59.1	CONDENSATE/HOTWELL PUMP MOTOR
2/2/2005	PFO	1.80	107.0	CONDENSATE/HOTWELL PUMP MOTOR
2/3/2005	PFO	1.33	487.9	BURNER INSTRUMENTS AND CONTROLS (EXCEPT LIGHT-OFF)
3/3/2005	PFO	0.37	106.6	BOTTOM ASH HOPPERS (INCLUDING GATES)
3/29/2005	FFO	71.17	495.0	FIRST SUPERHEATER LEAKS

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - MARCH 2005

Crystal River 1				
Date	Outage Type	Hours	MW Affected	Description
1/7/2005	PFO	4.57	75.0	OTHER PULVERIZER PROBLEMS
1/17/2005	PFO	0.75	83.9	PULVERIZER FEEDERS
1/19/2005	PMO	6.88	151.0	CONDENSER TUBE AND WATER BOX CLEANING
1/21/2005	PMO	12.00	265.0	BOTTOM ASH SYSTEMS (WET OR DRY)
1/22/2005	PMO	12.00	94.0	BOTTOM ASH SYSTEMS (WET OR DRY)
1/22/2005	PMO	3.75	265.0	BOTTOM ASH SYSTEMS (WET OR DRY)
1/26/2005	PMO	5.32	189.0	CONDENSER TUBE AND WATER BOX CLEANING
2/6/2005	PMO	6.40	189.0	CONDENSER TUBE AND WATER BOX CLEANING
2/8/2005	PFO	5.50	265.0	BOTTOM ASH SYSTEMS (WET OR DRY)
2/13/2005	PMO	8.00	189.0	CONDENSER TUBE LEAKS
2/14/2005	PMO	6.67	189.0	CONDENSER TUBE LEAKS
2/14/2005	PMO	7.83	189.0	CONDENSER TUBE AND WATER BOX CLEANING
2/15/2005	PMO	5.00	94.0	BOTTOM ASH SYSTEMS (WET OR DRY)
2/15/2005	PMO	5.42	94.0	PULVERIZER FEEDERS
2/17/2005	PMO	6.65	189.0	CONDENSER TUBE AND WATER BOX CLEANING
2/28/2005	PMO	8.37	170.0	CONDENSER TUBE AND WATER BOX CLEANING
3/2/2005	PMO	7.30	75.0	PULVERIZER MILLS
3/14/2005	PFO	3.50	46.0	CONDENSER TUBE LEAKS
3/14/2005	PMO	8.00	265.0	BOTTOM ASH CLINKER GRINDERS
3/15/2005	PMO	4.00	189.0	BOTTOM ASH CLINKER GRINDERS
3/15/2005	PMO	6.00	265.0	BOTTOM ASH CLINKER GRINDERS
3/15/2005	PMO	7.00	189.0	BOTTOM ASH CLINKER GRINDERS
3/28/2005	PMO	4.00	166.0	OTHER BURNER PROBLEMS
3/27/2005	PFO	51.68	23.0	OTHER PULVERIZER PROBLEMS
3/29/2005	PMO	6.83	94.0	PULVERIZER FEEDERS
3/29/2005	PFO	8.50	74.0	PULVERIZER FEEDERS

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - MARCH 2005

Crystal River 2				
Date	Outage Type	Hours	MW Affected	Description
1/6/2005	PMO	4.58	151.0	OTHER FEEDWATER VALVES
1/6/2005	PMO	6.20	144.0	CONDENSER TUBE AND WATER BOX CLEANING
1/9/2005	PMO	4.67	95.0	CONDENSATE BOOSTER PUMP
1/9/2005	PMO	6.33	85.0	PULVERIZER FEEDERS
1/10/2005	PFO	9.50	85.0	PULVERIZER FEEDERS
1/11/2005	PFO	5.57	85.0	PULVERIZER COAL LEAK (PULVERIZERS ONLY)
1/28/2005	FFO	113.97	486.0	FIRST SUPERHEATER LEAKS
2/1/2005	FMO	196.00	486.0	FIRST SUPERHEATER LEAKS
2/10/2005	PFO	4.08	85.0	IGNITERS
2/10/2005	PMO	5.15	151.0	OTHER CIRCULATING WATER SYSTEM PROBLEMS
2/13/2005	PFO	2.82	351.9	FLUE GAS EXPANSION JOINTS
2/15/2005	PMO	6.50	295.0	CONDENSER TUBE AND WATER BOX CLEANING
2/24/2005	FFO	142.03	486.0	PLATEN SUPERHEATER LEAKS
3/13/2005	PMO	8.30	247.0	CONDENSER TUBE AND WATER BOX CLEANING
3/16/2005	PMO	15.00	85.0	PULVERIZER MILLS
3/17/2005	PMO	14.97	94.0	PULVERIZER MILLS
3/19/2005	FFO	66.32	486.0	ECONOMIZER LEAKS
3/21/2005	FFO	2.17	486.0	OTHER BOILER RECIRCULATION PROBLEMS
3/23/2005	PFO	6.30	75.0	OTHER CIRCULATING WATER SYSTEM PROBLEMS
3/23/2005	PMO	12.47	104.0	PULVERIZER MILLS
3/27/2005	PFO	53.25	28.0	OTHER PULVERIZER PROBLEMS

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - MARCH 2005

Crystal River 3				
Date	Outage Type	Hours	MW Affected	Description
				NO OUTAGES

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - MARCH 2005

Crystal River 4				
Date	Outage Type	Hours	MW Affected	Description
1/8/2005	PFO	2.15	58.9	FLUE GAS RECIRCULATION DAMPERS
1/19/2005	PMO	7.75	101.0	PULVERIZER COAL LEAK (PULVERIZERS ONLY)
1/26/2005	PMO	5.83	258.0	CEMS CERTIFICATION AND RECERTIFICATION
2/1/2005	PMO	4.70	87.0	HEATER DRAIN PUMPS
2/2/2005	PMO	4.83	101.0	PULVERIZER FEEDERS
2/24/2005	PMO	5.68	44.0	INDUCED DRAFT FAN LUBRICATION SYSTEMS
3/3/2005	PMO	7.80	101.0	PULVERIZER MILLS
3/4/2005	PO	551.10	720.0	MINOR BOILER OVERHAUL (LESS THAN 720 HOURS)
3/28/2005	FMO	5.70	720.0	MINOR BOILER OVERHAUL (LESS THAN 720 HOURS)
3/28/2005	PFO	10.42	606.0	CONDENSER TUBE LEAKS
3/29/2005	PMO	4.33	243.9	BOILER SAFETY VALVE TEST

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - MARCH 2005

Crystal River 5				
Date	Outage Type	Hours	MW Affected	Description
1/3/2005	FMO	91.37	717.0	PLATEN SUPERHEATER LEAKS
1/8/2005	PFO	13.17	24.0	AIR SUPPLY DAMPERS
1/19/2005	PMO	2.22	98.0	CONDENSER TUBE LEAKS
1/19/2005	PMO	6.52	98.0	PULVERIZER MILLS
1/20/2005	PMO	5.33	108.0	PULVERIZER MILLS
1/23/2005	PMO	2.50	127.1	CONDENSER TUBE LEAKS
1/25/2005	PMO	5.00	97.9	PULVERIZER MILLS
1/28/2005	PMO	6.75	531.0	CONDENSER TUBE LEAKS
1/31/2005	PMO	2.78	214.1	CEMS CERTIFICATION AND RECERTIFICATION
1/31/2005	PMO	3.87	399.9	CEMS CERTIFICATION AND RECERTIFICATION
1/31/2005	PMO	16.70	84.0	OTHER HIGH PRESSURE HEATER PROBLEMS
2/1/2005	PMO	10.73	14.0	OTHER HIGH PRESSURE HEATER PROBLEMS
2/2/2005	PMO	5.23	98.0	PULVERIZER FEEDERS
2/2/2005	PMO	4.75	398.0	CEMS CERTIFICATION AND RECERTIFICATION
2/3/2005	PMO	5.15	98.0	PULVERIZER FEEDERS
2/3/2005	PMO	4.18	212.0	CEMS CERTIFICATION AND RECERTIFICATION
2/3/2005	PMO	6.17	98.0	PULVERIZER FEEDERS
2/5/2005	PFO	1.25	98.1	OTHER PULVERIZER PROBLEMS
2/6/2005	PMO	6.50	98.0	PULVERIZER FEEDERS
2/7/2005	PMO	0.83	98.1	PULVERIZER FEEDERS
2/10/2005	PFO	3.30	98.0	PULVERIZER FEEDERS
2/10/2005	PMO	6.98	98.0	OTHER PULVERIZER PROBLEMS
2/15/2005	FFO	9.82	717.0	OPERATOR ERROR
2/16/2005	FFO	2.95	717.0	AIR SUPPLY DAMPERS
2/16/2005	PFO	18.65	98.0	OTHER PULVERIZER PROBLEMS
2/18/2005	FFO	0.63	717.0	AIR SUPPLY DAMPERS

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - MARCH 2005

Crystal River 5				
Date	Outage Type	Hours	MW Affected	Description
2/18/2005	PFO	5.77	488.0	CONDENSER TUBE LEAKS
2/19/2005	PFO	34.92	17.0	AIR SUPPLY DAMPERS
2/23/2005	PFO	11.62	36.0	AIR SUPPLY DAMPERS
2/24/2005	PFO	16.78	41.0	AIR SUPPLY DAMPERS
2/25/2005	PFO	14.23	41.0	AIR SUPPLY DAMPERS
2/26/2005	PFO	14.92	36.0	AIR SUPPLY DAMPERS
2/27/2005	PFO	12.50	41.0	AIR SUPPLY DAMPERS
2/28/2005	PFO	15.83	41.0	AIR SUPPLY DAMPERS
3/5/2005	PMO	7.50	98.0	PULVERIZER SYSTEM COAL LEAKS (OTHER THAN PULVERIZERS, SEE CODE 03)
3/9/2005	PMO	3.83	98.0	PULVERIZER FEEDERS
3/11/2005	PFO	17.83	74.0	BOILER DRUM RELIEF/SAFETY VALVES
3/15/2005	PFO	1.90	455.9	FORCED DRAFT FAN LUBRICATION SYSTEM
3/19/2005	PMO	3.98	97.9	PULVERIZER FEEDERS
3/26/2005	PFO	12.70	61.0	OTHER PULVERIZER PROBLEMS
3/27/2005	PMO	73.95	98.0	PULVERIZER OVERHAUL
3/30/2005	FMO	26.05	717.0	MINOR BOILER OVERHAUL (LESS THAN 720 HOURS)

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - MARCH 2005

Date	Outage Type	Hours	MW Affected	Description
1/18/2005	PFO	5.45	216.0	GT GAS FUEL SYSTEM
2/11/2005	PFO	0.45	224.9	OTHER FIRE PROTECTION SYSTEM PROBLEMS
3/17/2005	PFO	3.95	236.0	GAS TURBINE VIBRATION

PROGRESS ENERGY FLORIDA

ACTUAL UNIT EVENT DATA -- JANUARY - MARCH 2005

Date	Outage Type	Hours	MW Affected	Description
1/16/2005	FFO	229.1	207.0	OTHER EXCITER PROBLEMS