



ORIGINAL

Public Service Commission

CAPITAL CIRCLE OFFICE CENTER • 2540 SHUMARD OAK BOULEVARD
TALLAHASSEE, FLORIDA 32399-0850

-M-E-M-O-R-A-N-D-U-M-

DATE: June 14, 2006

TO: Blanca S. Bayó, Commission Clerk and Administrative Services Director

FROM: Richard P. Redemann, Professional Engineer III, Division of Economic Regulation

RE: Docket No. 060165-WS – Application for amendment of Certificates 455-W and 389-S to extend water and wastewater service areas in Flagler and Volusia Counties and request for approval of special service availability agreements by Plantation Bay Utility Co.

Please add to the docket file the attached email dated June 12, 2006, from Mr. Martin Friedman, attorney for the applicant to Mr. Richard Redemann, Commission staff. The attachment is the utility's response to Rule 25-30.550(3), Florida Administrative Code, which requires a statement of the treatment plant load, capacity and amount reserved under the special developer agreements.

Attachment

cc: Office of General Counsel (Jaeger)

C:\Msword\060165c.doc

- CMP _____
- COM _____
- CTR _____
- ECR _____
- GCL _____
- OPC _____
- RCA _____
- SCR _____
- SGA _____
- SEC 1
- OTH _____

DOCUMENT NUMBER-DATE

05232 JUN 15 06

FPSC-COMMISSION CLERK

Richard Redemann

From: Martin Friedman [mfriedman@rsbattorneys.com]
Sent: Monday, June 12, 2006 5:08 PM
To: Richard Redemann
Cc: Patti Daniel
Subject: Dkt. No. 050912-WS

Richard,

This is in response to you email of June 9, 2006. You are correct that the water and wastewater "extension" capacities are too high for these developments. Unfortunately, that provision was inartfully drawn. The extension will serve 75 residential ERCs and 56 commercial ERCs, with both water and wastewater. While a typical ERC for water is 350 gpd, and for wastewater is 280 gpd, a water ERC is actually 139 gpd and a wastewater ERC is 108 gpd. in Plantation Bay.

Based upon the recently completed rate case, Order No. PSC-06-0170A-PAA-WS, the water plant has firm reliable capacity of 670,000 gpd, and the wastewater treatment plant has permitted capacity of 475,000 gpd on an AADF basis. That case using a 12/31/06 projected test year concluded that the WWTP flow was 138,009 gpd, and the WTP had average flows of 321,877 gpd (does not include fire flow and growth).

I hope this information is helpful. Give me a call if you have any questions or need anything else.

Regards, Marty

Martin S. Friedman
Rose, Sundstrom & Bentley, LLP
Sanlando Center
2180 W. State Road 434, Suite 2118
Longwood, FL 32779
Phone: 407-830-6331
Fax: 407-830-8522

NOTICE: This e-mail message and any attachment to this e-mail message contains confidential information that is legally privileged. If you are not the intended recipient, you must not review, retransmit, convert to hard copy, copy, use or disseminate this e-mail or any attachments to it. If you have received this e-mail in error, please notify us immediately by return e-mail or by telephone at 407-830-6331 and delete the original and all copies of this transmission (including any attachments).