

ORIGINAL

LAW OFFICES
ROSE, SUNDSTROM & BENTLEY, LLP
2548 BLAIRSTONE PINES DRIVE
TALLAHASSEE, FLORIDA 32301

FREDERICK L. ASCHAUER, JR.
CHRIS H. BENTLEY, P.A.
ROBERT C. BRANNAN
DAVID F. CHESTER
F. MARSHALL DETERDING
JOHN R. JENKINS, P.A.
STEVEN T. MINDLIN, P.A.
CHASITY H. O'STEEN
DAREN L. SHIPPY
WILLIAM E. SUNDSTROM, P.A.
DIANE D. TREMOR, P.A.
JOHN L. WHARTON
ROBERT M. C. ROSE, OF COUNSEL
WAYNE L. SCHIEFELBEIN, OF COUNSEL

(850) 877-6555
FAX (850) 656-4029
www.rsbatorneys.com

REPLY TO CENTRAL FLORIDA OFFICE

CENTRAL FLORIDA OFFICE
SANLANDO CENTER
2180 W. STATE ROAD 434, SUITE 2118
LONGWOOD, FLORIDA 32779
(407) 830-6331
FAX (407) 830-8522

MARTIN S. FRIEDMAN, P.A.
VALERIE L. LORD
BRIAN J. STREET

June 23, 2006

Ms. Blanca Bayo
Commission Clerk and Administrative Services Director
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, FL 32399

HAND DELIVERED

COMMISSION
CLERK

06 JUN 23 PM 12:28

RECEIVED-PPSC

Re: Labrador Utilities, Inc.; Application for Rate Increase in Pasco County, Florida;
Docket No. 030443-WS
Our File No. 30057.64

Dear Ms. Bayo:

Enclosed for filing in the above-referenced docket is the final report of the meter flow test results required under Commission Order No. PSC-04-1281-PAA-WS. The report reflects the test results which were completed on May 24, 2006.

Should you have any questions concerning the enclosed, please do not hesitate to give me a call.

Very truly yours,

VALERIE L. LORD
For the Firm

- CMP _____
- COM _____
- CTR _____
- EDR _____
- ECI _____
- JPC _____
- ICA _____
- ICR _____
- IGA _____
- EC _____
- TH _____

VLL/tlc
Enclosures

- cc: Mr. Steven M. Lubertozzi (w/enclosures) (by U.S. Mail)
- Mr. John Hoy (w/enclosures) (by U.S. Mail)
- Mr. Patrick C. Flynn (w/enclosures) (by U.S. Mail)
- Mr. Troy Rendell, Economic Regulation (w/enclosures) (by hand delivery)
- Cochran Keating, Esq., Office of General Counsel (w/o enclosures) (by hand delivery)
- Stephen C. Reilly, Esq., Office of Public Counsel (w/enclosures) (by hand delivery)

DOCUMENT NUMBER-DATE

05513 JUN 23 06

LABRADOR UTILITIES, INC.
DOCKET NO. 030443-WS

METER CHANGE-OUT GUIDELINES

RANGE OF RESULTS - 95% - 101.5%
CHANGE OUT IF LESS THAN 9.5 OR 10.2 OR GREATER

OF METERS OUTSIDE PSC LIMITS

SLOW METERS	19
FAST METERS	126
TOTAL TESTED	800

RESPONSE TO PAA ACTION REQUEST - ISSUE #1 - METER FLOW TEST RESULTS

ACCOUNT NUMB	TYPE	SERVICE ADDRESS	SIZE	MAKE	SERIAL #	METER READ	VOLUME IN GALLONS		RESULTS		MAKE	NEW SERIAL #	NEW METER READ	DATE CHANGED OUT
							PTM TESTER	CUSTOMER METER	% OF ACCURACY	DATE TESTED				
00693 001898 1	IRRG	FOREST LAKE DR	2	BADG	UNKNOWN	611100	METER INSTALLED 2004							
00693 001843 3	TRLR	41309 WHITMER DR	5/8	BADG	91492989	558570	10.0	9.8	98.00%	3/10/2001				
00693 001845 1	TRLR	41319 WHITMER DR	5/8	BADG	91610801	601720	10.0	9.9	99.00%	3/10/2001				
00693 001847 1	TRLR	41325 WHITMER DR	5/8	BADG	93259674	582850	10.0	8.9	89.00%	3/10/2001	BADG	30223695	10	3/14/2001
00693 001848 2	TRLR	6418 UTOPIA DR	5/8	BADG	93259660	528780	10.0	9.8	98.00%	3/10/2001				
00693 001849 3	TRLR	6414 UTOPIA DR	5/8	BADG	93259660	584190	10.0	9.5	95.00%	3/10/2001	BADG	30223697	10	3/15/2001
00693 001850 1	TRLR	6410 UTOPIA DR	5/8	BADG	92420152	657450	10.0	9.8	98.00%	3/10/2001				
00693 001852 1	TRLR	6402 UTOPIA DR	5/8	BADG	93259664	749140	10.0	9.3	93.00%	3/10/2001	BADG	30223644	10	3/13/2001
00693 001853 1	TRLR	6340 UTOPIA DR	5/8	BADG	19486323	39910	10.0	10.0	100.00%	12/19/2001				
00693 001854 1	TRLR	6336 UTOPIA DR	5/8	BADG	19616969	12700	10.0	10.0	100.00%	12/19/2001				
00693 001856 1	TRLR	6328 UTOPIA DR	5/8	BADG	93060804	222930	10.0	9.9	99.00%	3/13/2001				
00693 001857 1	TRLR	6324 UTOPIA DR	5/8	BADG	93060794	603750	10.0	9.7	97.00%	3/13/2001				
00693 001858 1	TRLR	6320 UTOPIA DR	5/8	BADG	18721964	28590	10.0	10.0	100.00%	12/19/2001				
00693 001859 1	TRLR	6316 UTOPIA DR	5/8	BADG	19074030	238730	5.0	5.0	100.00%	9/13/2000				
00693 001860 1	TRLR	6312 UTOPIA DR	5/8	BADG	29185788	20730	10.0	10.0	100.00%	12/19/2001				
00693 001861 1	TRLR	6308 UTOPIA DR	5/8	BADG	18486296	88460	10.0	10.0	100.00%	12/19/2001				
00693 001862 2	TRLR	6304 UTOPIA DR	5/8	BADG	93259659	920520	10.0	9.7	97.00%	3/13/2001				
00693 001863 2	TRLR	6250 UTOPIA DR	5/8	BADG	92420160	212730	10.0	9.6	96.00%	3/13/2001				
00693 001864 1	TRLR	6246 UTOPIA DR	5/8	BADG	93259657	248830	10.0	9.6	96.00%	3/13/2001				
00693 001865 1	TRLR	6242 UTOPIA DR	5/8	BADG	18721921	78290	10.0	10.0	100.00%	12/19/2001				
00693 001866 1	TRLR	6238 UTOPIA DR	5/8	BADG	93060798	324220	10.0	9.9	99.00%	3/13/2001				
00693 001868 2	TRLR	6230 UTOPIA DR	5/8	BADG	92420206	211010	10.0	9.8	98.00%	3/13/2001				
00693 001869 1	TRLR	6226 UTOPIA DR	5/8	BADG	92420210	824530	10.0	9.8	98.00%	3/13/2001				
00693 001870 1	TRLR	6222 UTOPIA DR	5/8	BADG	92420210	937110	10.0	11.8	118.00%	3/13/2001	BADG	30223642	10	3/14/2001
00693 001871 1	TRLR	6218 UTOPIA DR	5/8	BADG	92420209	813270	10.0	9.8	98.00%	4/20/2002				

LABRADOR UTILITIES, INC.
DOCKET NO. 030443-WS

METER CHANGE-OUT GUIDELINES

RANGE OF RESULTS - 95% - 101.5%
CHANGE OUT IF LESS THAN 9.5 OR 10.2 OR GREATER

OF METERS OUTSIDE PSC LIMITS

SLOW METERS	19
FAST METERS	126
TOTAL TESTED	800

RESPONSE TO PAA ACTION REQUEST - ISSUE #1 - METER FLOW TEST RESULTS

ACCOUNT NUMB	TYPE	SERVICE ADDRESS	SIZE	MAKE	SERIAL #	METER READ	VOLUME IN GALLONS		RESULTS		MAKE	NEW SERIAL #	NEW METER READ	DATE CHANGED OUT
							PTM TESTER	CUSTOMER METER	% OF ACCURACY	DATE TESTED				
00693 001872 1	TRLR	6212 UTOPIA DR	5/8	BADG	92420163	552250	10.0	9.8	98.00%	3/13/2001				
00693 001873 1	TRLR	6202 UTOPIA DR	5/8	BADG	92420207	934170	10.0	9.7	97.00%	3/14/2001				
00693 001874 2	TRLR	6168 UTOPIA DR	5/8	BADG	92420218	264820	10.0	9.8	98.00%	3/14/2001				
00693 001876 1	TRLR	6156 UTOPIA DR	5/8	BADG	93060814	313300	10.0	9.7	97.00%	3/14/2001				
00693 001877 2	TRLR	6136 UTOPIA DR	5/8	BADG	19617007	5220	10.0	10.0	100.00%	12/19/2001				
00693 001878 2	TRLR	6134 UTOPIA DR	5/8	BADG	9240220	194620	10.0	9.8	98.00%	3/14/2001				
00693 001879 3	TRLR	6132 UTOPIA DR	5/8	BADG	93259672	280720	10.0	9.2	92.00%	3/14/2001	BADG	30223674	10	3/17/2001
00693 001880 1	TRLR	6130 UTOPIA DR	5/8	BADG	30223638	1480	10.0	10.0	100.00%	2/6/2001				
00693 001881 1	TRLR	6128 UTOPIA DR	5/8	BADG	93060796	578020	10.0	10.6	106.00%	3/14/2001	BADG	30223694	20	3/14/2001
00693 001882 1	TRLR	6126 UTOPIA DR	5/8	BADG	92420229	339790	10.0	12.5	125.00%	3/14/2001	BADG	30223699	10	3/15/2001
00693 001883 1	TRLR	6124 UTOPIA DR	5/8	BADG	30223634	2000	10.0	10.0	100.00%	2/13/2001				
00693 001884 1	TRLR	6068 UTOPIA DR	5/8	BADG	92420227	508390	NOT TESTED/VACANT LOT							
00693 001885 2	TRLR	6066 UTOPIA DR	5/8	BADG	93060802	465930	10.0	13.5	135.00%	3/14/2001	BADG	30223670	10	3/15/2001
00693 001886 1	TRLR	6064 UTOPIA DR	5/8	BADG	19616973	10880	5.0	5.0	100.00%	9/13/2000				
00693 001887 1	TRLR	6062 UTOPIA DR	5/8	BADG	342480	419130	10.0	9.8	98.00%	3/14/2001				
00693 001888 2	TRLR	6060 UTOPIA DR	5/8	BADG	9240169	542340	10.0	9.6	96.00%	3/14/2001				
00693 001889 1	TRLR	6058 UTOPIA DR	5/8	BADG	92420157	247940	NOT TESTED/VACANT LOT							
00693 001890 2	TRLR	6056 UTOPIA DR	5/8	BADG	18486297	80020	10.0	10.0	100.00%	12/19/2001				
00693 001891 1	TRLR	6054 UTOPIA DR	5/8	BADG	92420231	105970	NOT TESTED/VACANT LOT							
00693 001892 2	TRLR	6052 UTOPIA DR	5/8	BADG	93060811	367220	10.0	9.7	97.00%	3/14/2001				
00693 001893 3	TRLR	6050 UTOPIA DR	5/8	BADG	9240232	233130	10.0	10.0	100.00%	3/14/2001				
00693 001894 1	TRLR	6048 UTOPIA DR	5/8	BADG	930060907	334840	10.0	9.8	98.00%	3/14/2001				
00693 001753 1	TRLR	6046 UTOPIA DR	5/8	BADG	93060806	323420	10.0	9.8	98.00%	3/14/2001				
00693 001751 2	TRLR	5635 VIAU WAY	5/8	BADG	93259835	1262540	10.0	9.7	97.00%	3/14/2001				
00693 001743 1	TRLR	5643 VIAU WAY	5/8	BADG	18149173	131090	10.0	10.0	100.00%	12/19/2001				

LABRADOR UTILITIES, INC.
DOCKET NO. 030443-WS

METER CHANGE-OUT GUIDELINES

RANGE OF RESULTS - 95% - 101.5%
CHANGE OUT IF LESS THAN 9.5 OR 10.2 OR GREATER

OF METERS OUTSIDE PSC LIMITS

SLOW METERS	19
FAST METERS	126
TOTAL TESTED	800

RESPONSE TO PAA ACTION REQUEST - ISSUE #1 - METER FLOW TEST RESULTS

ACCOUNT NUMB	TYPE	SERVICE ADDRESS	SIZE	MAKE	SERIAL #	METER READ	VOLUME IN GALLONS		RESULTS		MAKE	NEW SERIAL #	NEW METER READ	DATE CHANGED OUT
							PTM TESTER	CUSTOMER METER	% OF ACCURACY	DATE TESTED				
00693 001735 2	TRLR	5651 VIAU WAY	5/8	BADG	93259718	316780	10.0	9.4	94.00%	3/14/2001	BADG	30223684	10	3/15/2001
00693 001730 2	TRLR	5705 VIAU WAY	5/8	BADG	93259724	935830	10.0	10.4	104.00%	3/14/2001	BADG	30223696	10	3/17/2001
00693 001711 1	TRLR	5725 VIAU WAY	5/8	BADG	93259825	1217680	10.0	11.5	115.00%	3/21/2001	BADG	30223672	10	3/21/2001
00693 001708 3	TRLR	5727 VIAU WAY	5/8	BADG	93259841	375670	10.0	11.0	110.00%	3/21/2001	BADG	32206541	10	3/21/2001
00693 001703 1	TRLR	5731 VIAU WAY	5/8	BADG	93259727	683850	10.0	9.6	96.00%	3/21/2001				
00693 001702 1	TRLR	5733 VIAU WAY	5/8	BADG	93259855	842170	10.0	13.7	137.00%	3/21/2001	BADG	32206540	10	3/21/2001
00693 001700 2	TRLR	5735 VIAU WAY	5/8	BADG	93259859	974180	10.0	13.3	133.00%	3/21/2001	BADG	32206543	10	3/21/2001
00693 001698 2	TRLR	5737 VIAU WAY	5/8	BADG	18721955	89050	10.0	10.0	100.00%	12/19/2001				
00693 001696 1	TRLR	5739 VIAU WAY	5/8	BADG	17990532	60790	10.0	10.0	100.00%	12/19/2001				
00693 001692 1	TRLR	5743 VIAU WAY	5/8	BADG	93259832	645530	10.0	13.2	132.00%	3/21/2001	BADG	32206544	10	3/23/2001
00693 001689 1	TRLR	5745 VIAU WAY	5/8	BADG	19616906	17080	10.0	10.0	100.00%	12/19/2001				
00693 001685 1	TRLR	5749 VIAU WAY	5/8	BADG	93259859	240180	10.0	9.7	97.00%	3/21/2001				
00693 001684 1	TRLR	5751 VIAU WAY	5/8	BADG	93259857	450290	10.0	14.1	141.00%	3/21/2001	BADG	32206545	10	3/23/2001
00693 001199 1	TRLR	6162 SPRING LAKE CIR	5/8	BADG	30223633	5610	10.0	10.0	100.00%	6/29/2001				
00693 001715 1	TRLR	5720 VIAU WAY	5/8	BADG	93259717	182630	10.0	9.8	98.00%	3/22/2001				
00693 001218 1	TRLR	6250 SPRING LAKE CIR	5/8	BADG	19616971	8980	10.0	10.0	100.00%	12/19/2001				
00693 001738 1	TRLR	5648 VIAU WAY	5/8	BADG	93259720	224290	10.0	9.8	98.00%	3/23/2001				
00693 001742 2	TRLR	5644 VIAU WAY	5/8	BADG	93259860	3240	10.0	0.0	0.00%	3/23/2001	BADG	30223679	10	3/27/2001
00693 001745 2	TRLR	5642 VIAU WAY	5/8	BADG	18721909	71010	10.0	10.0	100.00%	12/19/2001				
00693 001747 1	TRLR	5640 VIAU WAY	5/8	BADG	93259826	378010	10.0	9.1	91.00%	3/23/2001	BADG	32206605	10	3/27/2001
00693 001574 1	TRLR	5912 NAPLES DR	5/8	BADG	93259714	653670	NOT TESTED/VACANT LOT							
00693 001670 1	TRLR	5866 NAPLES DR	5/8	BADG	93259847	408050	10.0	9.7	97.00%	3/23/2001				
00693 001671 1	TRLR	5864 NAPLES DR	5/8	BADG	19616958	9850	10.0	10.0	100.00%	12/19/2001				
00693 001657 2	TRLR	5856 NAPLES DR	5/8	BADG	95325916	420100	10.0	10.3	103.00%	3/23/2001	BADG	32206603	10	3/27/2001
00693 001572 1	TRLR	5812 NAPLES DR	5/8	BADG	18721910	6920	10.0	10.0	100.00%	12/19/2001				

LABRADOR UTILITIES, INC.
DOCKET NO. 030443-WS

METER CHANGE-OUT GUIDELINES

RANGE OF RESULTS - 95% - 101.5%
CHANGE OUT IF LESS THAN 9.5 OR 10.2 OR GREATER

OF METERS OUTSIDE PSC LIMITS

SLOW METERS	19
FAST METERS	126
TOTAL TESTED	800

RESPONSE TO PAA ACTION REQUEST - ISSUE #1 - METER FLOW TEST RESULTS

ACCOUNT NUMB	TYPE	SERVICE ADDRESS	SIZE	MAKE	SERIAL #	METER READ	VOLUME IN GALLONS		RESULTS		MAKE	NEW SERIAL #	NEW METER READ	DATE CHANGED OUT
							PTM TESTER	CUSTOMER METER	% OF ACCURACY	DATE TESTED				
00693 001555 1	TRLR	5802 NAPLES DR	5/8	BADG	93259730	778870	10.0	9.8	98.00%	3/28/2001				
00693 001554 1	TRLR	5801 NAPLES DR	5/8	BADG	93259711	323510	10.0	10.0	100.00%	3/31/2001				
00693 001562 1	TRLR	5805 NAPLES DR	5/8	BADG	93259712	700050	10.0	10.0	100.00%	3/31/2001				
00693 001581 1	TRLR	5815 NAPLES DR	5/8	BADG	93259819	550020	10.0	10.0	100.00%	3/31/2001				
00693 001586 3	TRLR	5817 NAPLES DR	5/8	BADG	93259826	459990	10.0	9.8	98.00%	3/31/2001				
00693 001589 2	TRLR	5819 NAPLES DR	5/8	BADG	93259861	202770	10.0	10.0	100.00%	3/31/2001				
00693 001594 1	TRLR	5821 NAPLES DR	5/8	BADG	93259824	397510	10.0	10.1	101.00%	3/31/2001				
00693 001597 2	TRLR	5823 NAPLES DR	5/8	BADG	93259829	525660	10.0	10.0	100.00%	3/31/2001				
00693 001618 1	TRLR	5833 NAPLES DR	5/8	BADG	93259863	164810	10.0	10.0	100.00%	4/6/2001				
00693 001667 1	TRLR	5857 NAPLES DR	5/8	BADG	93259719	192120	10.0	9.9	99.00%	4/6/2001				
00693 001668 1	TRLR	5859 NAPLES DR	5/8	BADG	93259723	431060	10.0	9.8	98.00%	4/6/2001				
00693 001664 1	TRLR	5960 BENZ PL	5/8	BADG	93299845	583800	10.0	10.0	100.00%	4/6/2001				
00693 001665 1	TRLR	5958 BENZ PL	5/8	BADG	93259725	197090	10.0	10.1	101.00%	4/6/2001				
00693 001660 1	TRLR	5954 BENZ PL	5/8	BADG	93259842	231870	10.0	9.9	99.00%	4/6/2001				
00693 001636 3	TRLR	5942 BENZ PL	5/8	BADG	93259728	152150	10.0	10.0	100.00%	4/6/2001				
00693 001610 2	TRLR	5930 BENZ PL	5/8	BADG	18486292	46120	10.0	10.0	100.00%	12/19/2001				
00693 001607 1	TRLR	5928 BENZ PL	5/8	BADG	93259793	140560	10.0	9.9	99.00%	4/11/2001				
00693 001601 1	TRLR	5926 BENZ PL	5/8	BADG	93259848	332210	10.0	10.0	100.00%	4/11/2001				
00693 001598 1	TRLR	5924 BENZ PL	5/8	BADG	93259862	574970	10.0	9.5	95.00%	4/11/2001	BADG	32206775	10	4/12/2001
00693 001590 1	TRLR	5920 BENZ PL	5/8	BADG	93259848	279720	10.0	11.0	110.00%	4/11/2001	BADG	32206774	10	4/12/2001
00693 001577 2	TRLR	5914 BENZ PL	5/8	BADG	19616961	10960	10.0	10.0	100.00%	12/19/2001				
00693 001902 0	RES	5912 BENZ PL	5/8	BADG	93259174	653860	10.0	10.0	100.00%	4/12/2001				
00693 001566 1	TRLR	5908 BENZ PL	5/8	BADG	93259733	294310	10.0	10.0	100.00%	4/12/2001				
00693 001561 1	TRLR	5906 BENZ PL	5/8	BADG	93259731	395630	10.0	10.0	100.00%	4/12/2001				
00693 001558 1	TRLR	5904 BENZ PL	5/8	BADG	93259729	41090	10.0	10.0	100.00%	4/12/2001				

LABRADOR UTILITIES, INC.
DOCKET NO. 030443-WS

METER CHANGE-OUT GUIDELINES

RANGE OF RESULTS - 95% - 101.5%

CHANGE OUT IF LESS THAN 9.5 OR 10.2 OR GREATER

OF METERS OUTSIDE PSC LIMITS

SLOW METERS 19

FAST METERS 126

TOTAL TESTED 800

RESPONSE TO PAA ACTION REQUEST - ISSUE #1 - METER FLOW TEST RESULTS

ACCOUNT NUMB	TYP E	SERVICE ADDRESS	SIZ E	MA KE	SERIAL #	METER READ	VOLUME IN GALLONS		RESULTS		MA KE	NEW SERIAL #	NEW METER READ	DATE CHANGED OUT
							PTM TESTER	CUSTOMER METER	% OF ACCURACY	DATE TESTED				
00693 001553 2	TRLR	5902 BENZ PL	5/8	BADG	93259732	588830	10.0	9.9	99.00%	4/12/2001				
00693 001559 1	TRLR	5903 BENZ PL	5/8	BADG	93259792	301840	10.0	10.0	100.00%	4/12/2001				
00693 001560 2	TRLR	5905 BENZ PL	5/8	BADG	93259710	486760	10.0	9.9	99.00%	4/12/2001				
00693 001567 1	TRLR	5907 BENZ PL	5/8	BADG	93259851	187990	10.0	10.0	100.00%	4/12/2001				
00693 001568 1	TRLR	5909 BENZ PL	5/8	BADG	93259715	357680	10.0	10.0	100.00%	4/12/2001				
00693 001575 2	TRLR	5911 BENZ PL	5/8	BADG	93259818	213150	10.0	9.9	99.00%	12/19/2001				
00693 001576 1	TRLR	5913 BENZ PL	5/8	BADG	93259853	362770	10.0	9.8	98.00%	4/12/2001				
00693 001584 1	TRLR	5917 BENZ PL	5/8	BADG	93259839	233730	10.0	9.9	99.00%	4/12/2001				
00693 001599 1	TRLR	5923 BENZ PL	5/8	BADG	93259865	283180	10.0	10.1	101.00%	4/12/2001				
00693 001609 1	TRLR	5929 BENZ PL	5/8	BADG	9259864	134140	10.0	9.8	98.00%	4/12/2001				
00693 001616 1	TRLR	5931 BENZ PL	5/8	BADG	93259852	302060	10.0	9.9	99.00%	4/12/2001				
00693 001623 1	TRLR	5933 BENZ PL	5/8	BADG	93259827	226620	10.0	9.8	98.00%	12/19/2001				
00693 001637 1	TRLR	5939 BENZ PL	5/8	BADG	9259836	870410	10.0	9.6	96.00%	12/19/2001				
00693 001653 1	TRLR	5947 BENZ PL	5/8	BADG	93259854	372550	10.0	10.0	100.00%	4/18/2001	BADG	32206498	10	9/17/2001
00693 001661 1	TRLR	5951 BENZ DR	5/8	BADG	93259843	467450	10.0	10.0	100.00%	4/18/2001				
00693 001662 2	TRLR	5953 BENZ PL	5/8	BADG	93259846	345690	10.0	10.0	100.00%	4/18/2001				
00693 001526 1	TRLR	5954 UTOPIA DR	5/8	BADG	92420215	423520	5.0	5.0	100.00%	9/13/2000				
00693 001527 4	TRLR	5952 UTOPIA DR	5/8	BADG	92114032	395560	10.0	10.0	100.00%	4/18/2001				
00693 001528 2	TRLR	5950 UTOPIA DR	5/8	BADG	92114035	575700	10.0	10.0	100.00%	4/18/2001				
00693 001529 2	TRLR	5948 UTOPIA DR	5/8	BADG	92114046	715900	10.0	9.7	97.00%	12/19/2001				
00693 001530 1	TRLR	5946 UTOPIA DR	5/8	BADG	92420168	269830	10.0	10.0	100.00%	12/19/2001				
00693 001531 1	TRLR	5944 UTOPIA DR	5/8	BADG	92420145	223190	10.0	10.0	100.00%	4/18/2001				
00693 001532 1	TRLR	5942 UTOPIA DR	5/8	BADG	92420091	92620	10.0	10.0	100.00%	4/18/2001				
00693 001533 2	TRLR	5940 UTOPIA DR	5/8	BADG	18486289	69610	10.0	10.0	100.00%	4/18/2001				
00693 001534 1	TRLR	5938 UTOPIA DR	5/8	BADG	92420095	224610	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256577	0	4/30/2002

LABRADOR UTILITIES, INC.
DOCKET NO. 030443-WS

METER CHANGE-OUT GUIDELINES

RANGE OF RESULTS - 95% - 101.5%
CHANGE OUT IF LESS THAN 9.5 OR 10.2 OR GREATER

OF METERS OUTSIDE PSC LIMITS

SLOW METERS	19
FAST METERS	126
TOTAL TESTED	800

RESPONSE TO PAA ACTION REQUEST - ISSUE #1 - METER FLOW TEST RESULTS

ACCOUNT NUMB	TYP E	SERVICE ADDRESS	SIZ E	MA KE	SERIAL #	METER READ	VOLUME IN GALLONS		RESULTS				MA KE	NEW SERIAL #	NEW METER READ	DATE CHANGED OUT
							PTM TESTER	CUSTOMER METER	% OF ACCURACY	DATE TESTED						
00693 001536 1	TRLR	5934 UTOPIA DR	5/8	BADG	19616964	6320	10.0	10.0	100.00%	4/18/2001						
00693 001537 1	TRLR	5932 UTOPIA DR	5/8	BADG	92114029	246740	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256574	0	4/30/2002		
00693 001538 1	TRLR	5930 UTOPIA DR	5/8	BADG	92420105	432210	10.0	9.6	96.00%	4/20/2002						
00693 001539 1	TRLR	5928 UTOPIA DR	5/8	BADG	92420100	383180	10.0	9.9	99.00%	4/20/2002						
00693 001540 2	TRLR	5926 UTOPIA DR	5/8	BADG	92420106	325210	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256578	0	4/30/2002		
00693 001541 1	TRLR	5924 UTOPIA DR	5/8	BADG	92420093	252500	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256575	0	4/30/2002		
00693 001542 1	TRLR	5922 UTOPIA DR	5/8	BADG	92113995	593260	10.0	11.2	112.00%	4/19/2001	BADG	32206646	10	4/20/2001		
00693 001543 1	TRLR	5920 UTOPIA DR	5/8	BADG	92113996	373570	10.0	10.0	100.00%	4/19/2001						
00693 001544 4	TRLR	5918 UTOPIA DR	5/8	BADG	92114028	400280	10.0	10.0	100.00%	4/19/2001						
00693 001473 1	TRLR	5916 UTOPIA DR	5/8	BADG	92114026	459460	10.0	9.9	99.00%	12/19/2001						
00693 001472 2	TRLR	5914 UTOPIA DR	5/8	BADG	92113998	280150	10.0	10.0	100.00%	4/19/2001						
00693 001465 2	TRLR	5912 UTOPIA DR	5/8	BADG	92113997	202760	10.0	9.7	97.00%	12/19/2001						
00693 001464 1	TRLR	5910 UTOPIA DR	5/8	BADG	92114033	782390	10.0	10.0	100.00%	4/19/2001						
00693 001457 1	TRLR	5908 UTOPIA DR	5/8	BADG	91838592	373700	10.0	10.1	101.00%	12/19/2001						
00693 001456 1	TRLR	5906 UTOPIA DR	5/8	BADG	92420091	270270	10.0	9.9	99.00%	12/19/2001						
00693 001448 2	TRLR	5902 UTOPIA DR	5/8	BADG	91838634	715260	10.0	10.0	100.00%	4/19/2001						
00693 001676 1	TRLR	5903 TWILIGHT DR	5/8	BADG	93259722	144850	NOT TESTED/VACANT LOT									
00693 001674 1	TRLR	5907 TWILIGHT DR	5/8	BADG	93259822	200720	10.0	9.9	99.00%	12/19/2001						
00693 001551 1	TRLR	5909 TWILIGHT DR	5/8	BADG	32206600	80	10.0	10.0	100.00%	4/20/2001						
00693 001550 2	TRLR	5911 TWILIGHT DR	5/8	BADG	18721924	16310	10.0	10.1	101.00%	4/20/2001						
00693 001549 1	TRLR	5913 TWILIGHT DR	5/8	BADG	92114044	292090	10.0	10.1	101.00%	12/19/2001						
00693 001548 1	TRLR	5915 TWILIGHT DR	5/8	BADG	92420087	1020490	10.0	10.0	100.00%	4/20/2001						
00693 001447 1	TRLR	5901 UTOPIA DR	5/8	BADG	92420085	2688720	5.0	5.0	100.00%	9/13/2000						
00693 001450 1	TRLR	5903 UTOPIA DR	5/8	BADG	92420099	619690	10.0	10.0	100.00%	4/20/2001						
00693 001455 2	TRLR	5905 UTOPIA DR	5/8	BADG	92114024	564680	10.0	10.0	100.00%	12/19/2001						

LABRADOR UTILITIES, INC.
DOCKET NO. 030443-WS

METER CHANGE-OUT GUIDELINES

RANGE OF RESULTS - 95% - 101.5%

CHANGE OUT IF LESS THAN 9.5 OR 10.2 OR GREATER

OF METERS OUTSIDE PSC LIMITS

SLOW METERS	19
FAST METERS	126
TOTAL TESTED	800

RESPONSE TO PAA ACTION REQUEST - ISSUE #1 - METER FLOW TEST RESULTS

ACCOUNT NUMB	TYPE	SERVICE ADDRESS	SIZE	MAKE	SERIAL #	METER READ	VOLUME IN GALLONS		RESULTS		MAKE	NEW SERIAL #	NEW METER READ	DATE CHANGED OUT
							PTM TESTER	CUSTOMER METER	% OF ACCURACY	DATE TESTED				
00693 001458 1	TRLR	5907 UTOPIA DR	5/8	BADG	92114023	1158800	10.0	9.9	99.00%	4/20/2001				
00693 001463 2	TRLR	5909 UTOPIA DR	5/8	BADG	92420092	349500	10.0	10.0	100.00%	4/20/2001				
00693 001466 1	TRLR	5911 UTOPIA DR	5/8	BADG	92420148	279600	10.0	10.0	100.00%	11/27/2001				
00693 001471 1	TRLR	5913 UTOPIA DR	5/8	BADG	92114017	192070	10.0	9.8	98.00%	11/27/2001				
00693 001479 2	TRLR	5917 UTOPIA DR	5/8	BADG	19617008	8500	10.0	10.0	100.00%	4/20/2001				
00693 001480 1	TRLR	5919 UTOPIA DR	5/8	BADG	30223647	12750	10.0	10.0	100.00%	4/20/2001				
00693 001485 3	TRLR	5921 UTOPIA DR	5/8	BADG	92114045	269010	10.0	10.1	101.00%	4/25/2001				
00693 001486 1	TRLR	5923 UTOPIA DR	5/8	BADG	92114009	75250	10.0	10.0	100.00%	4/25/2001				
00693 001491 1	TRLR	5925 UTOPIA DR	5/8	BADG	91938630	213650	10.0	9.9	99.00%	11/27/2001				
00693 001492 1	TRLR	5927 UTOPIA DR	5/8	BADG	92114021	550690	10.0	10.1	101.00%	4/25/2001				
00693 001493 1	TRLR	5929 UTOPIA DR	5/8	BADG	92113999	942290	10.0	10.0	100.00%	4/25/2001				
00693 001498 1	TRLR	5931 UTOPIA DR	5/8	BADG	92420150	46830	10.0	10.0	100.00%	11/27/2001				
00693 001499 1	TRLR	5933 UTOPIA DR	5/8	BADG	92114022	463430	10.0	10.0	100.00%	4/20/2002				
00693 001504 1	TRLR	5935 UTOPIA DR	5/8	BADG	92114007	363600	10.0	9.9	99.00%	11/27/2001				
00693 001505 1	TRLR	5937 UTOPIA DR	5/8	BADG	92114020	204040	10.0	9.7	97.00%	11/27/2001				
00693 001510 1	TRLR	5939 UTOPIA DR	5/8	BADG	92114019	361310	10.0	10.1	101.00%	11/27/2001				
00693 001511 2	TRLR	5941 UTOPIA DR	5/8	BADG	92114030	166290	10.0	9.9	99.00%	11/27/2001				
00693 001515 1	TRLR	5943 UTOPIA DR	5/8	BADG	92114047	510830	10.0	10.0	100.00%	4/25/2001				
00693 001516 3	TRLR	5945 UTOPIA DR	5/8	BADG	92114018	510470	10.0	10.0	100.00%	4/20/2002				
00693 001517 2	TRLR	5947 UTOPIA DR	5/8	BADG	92420107	195110	10.0	10.0	100.00%	11/27/2001				
00693 001524 3	TRLR	5949 UTOPIA DR	5/8	BADG	92420088	339790	10.0	10.0	100.00%	4/25/2001				
00693 001525 1	TRLR	5951 UTOPIA DR	5/8	BADG	92114048	930590	5.0	5.0	100.00%	9/13/2000				
00693 001754 2	TRLR	6045 UTOPIA DR	5/8	BADG	93259658	1708780	10.0	9.8	98.00%	4/25/2001				
00693 001802 1	TRLR	6049 UTOPIA DR	5/8	BADG	92420203	684510	5.0	5.0	100.00%	9/13/2000				
00693 001803 2	TRLR	6051 UTOPIA DR	5/8	BADG	92420204	668830	10.0	0.0	0.00%	4/25/2001	BADG	32206643	10	4/27/2001

LABRADOR UTILITIES, INC.
DOCKET NO. 030443-WS

METER CHANGE-OUT GUIDELINES

RANGE OF RESULTS - 95% - 101.5%

CHANGE OUT IF LESS THAN 9.5 OR 10.2 OR GREATER

OF METERS OUTSIDE PSC LIMITS

SLOW METERS 19

FAST METERS 126

TOTAL TESTED 800

RESPONSE TO PAA ACTION REQUEST - ISSUE #1 - METER FLOW TEST RESULTS

ACCOUNT NUMB	TYP E	SERVICE ADDRESS	SIZ E	MA KE	SERIAL #	METER READ	VOLUME IN GALLONS		RESULTS		MA KE	NEW SERIAL #	NEW METER READ	DATE CHANGED OUT
							PTM TESTER	CUSTOMER METER	% OF ACCURACY	DATE TESTED				
00693 001804 1	TRLR	6053 UTOPIA DR	5/8	BADG	92420225	248770	10.0	9.9	99.00%	11/27/2001				
00693 001805 1	TRLR	6055 UTOPIA DR	5/8	BADG	92420226	153490	NOT TESTED/VACANT LOT							
00693 001806 1	TRLR	6059 UTOPIA DR	5/8	BADG	92420224	206050	NOT TESTED/VACANT LOT							
00693 001807 1	TRLR	6061 UTOPIA DR	5/8	BADG	92420223	1678430	5.0	5.0	100.00%	9/13/2000				
00693 001808 2	TRLR	6063 UTOPIA DR	5/8	BADG	92420221	722230	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256576	0	4/30/2002
00693 001809 1	TRLR	6065 UTOPIA DR	5/8	BADG	92420156	341810	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256579	0	4/30/2002
00693 001810 2	TRLR	6123 UTOPIA DR	5/8	BADG	92420234	274680	10.0	10.0	100.00%	4/25/2001				
00693 001811 2	TRLR	6125 UTOPIA DR	5/8	BADG	92420222	648870	10.0	9.9	99.00%	11/27/2001				
00693 001812 1	TRLR	6127 UTOPIA DR	5/8	BADG	29140607	6090	10.0	10.0	100.00%	4/25/2001				
00693 001813 1	TRLR	6129 UTOPIA DR	5/8	BADG	93060813	308810	10.0	10.0	100.00%	4/25/2001				
00693 001814 1	TRLR	6131 UTOPIA DR	5/8	BADG	92420213	222780	10.0	10.1	101.00%	4/25/2001				
00693 001815 1	TRLR	6133 UTOPIA DR	5/8	BADG	19616974	11040	10.0	10.0	100.00%	4/25/2001				
00693 001816 1	TRLR	6157 UTOPIA DR	5/8	BADG	92420214	616170	10.0	10.1	101.00%	4/25/2001				
00693 001817 1	TRLR	6163 UTOPIA DR	5/8	BADG	93050799	491330	NOT TESTED/VACANT LOT							
00693 001818 1	TRLR	6169 UTOPIA DR	5/8	BADG	93060803	468250	10.0	9.9	99.00%	11/27/2001				
00693 001819 1	TRLR	6203 UTOPIA DR	5/8	BADG	93259667	714780	10.0	9.6	96.00%	4/25/2001				
00693 001820 1	TRLR	6209 UTOPIA DR	5/8	BADG	93259670	754780	10.0	9.7	97.00%	4/25/2001				
00693 001821 1	TRLR	6215 UTOPIA DR	5/8	BADG	18486283	100200	10.0	10.0	100.00%	4/25/2001				
00693 001822 1	TRLR	6221 UTOPIA DR	5/8	BADG	93060816	460950	10.0	9.9	99.00%	4/25/2001				
00693 001823 1	TRLR	6227 UTOPIA DR	5/8	BADG	92420217	464950	10.0	10.0	100.00%	4/25/2001				
00693 001824 3	TRLR	6233 UTOPIA DR	5/8	BADG	92420205	246900	10.0	10.2	102.00%	4/25/2001	BADG	32206647	10	4/27/2001
00693 001825 1	TRLR	6239 UTOPIA DR	5/8	BADG	93259671	613230	10.0	9.4	94.00%	4/25/2001	BADG	32206645	10	4/27/2001
00693 001826 1	TRLR	6241 UTOPIA DR	5/8	BADG	93259669	633940	10.0	9.6	96.00%	5/9/2001				
00693 001827 2	TRLR	6245 UTOPIA DR	5/8	BADG	93259662	1311840	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256568	0	4/30/2002
00693 001829 1	TRLR	6253 UTOPIA DR	5/8	BADG	93259665	1837700	5.0	5.0	100.00%	9/13/2000				

LABRADOR UTILITIES, INC.
DOCKET NO. 030443-WS

METER CHANGE-OUT GUIDELINES

RANGE OF RESULTS - 95% - 101.5%

CHANGE OUT IF LESS THAN 9.5 OR 10.2 OR GREATER

OF METERS OUTSIDE PSC LIMITS

SLOW METERS	19
FAST METERS	126
TOTAL TESTED	800

RESPONSE TO PAA ACTION REQUEST - ISSUE #1 - METER FLOW TEST RESULTS

ACCOUNT NUMB	TYPE	SERVICE ADDRESS	SIZE	MAKE	SERIAL #	METER READ	VOLUME IN GALLONS		RESULTS		MAKE	NEW SERIAL #	NEW METER READ	DATE CHANGED OUT
							PTM TESTER	CUSTOMER METER	% OF ACCURACY	DATE TESTED				
00693 001830 1	TRLR	6307 UTOPIA DR	5/8	BADG	92420155	2042430	10.0	10.0	100.00%	5/9/2001				
00693 001831 1	TRLR	6309 UTOPIA DR	5/8	BADG	93259677	979680	10.0	9.6	96.00%	11/27/2001				
00693 001832 1	TRLR	6313 UTOPIA DR	5/8	BADG	93060793	502850	10.0	9.8	98.00%	5/9/2001				
00693 001833 1	TRLR	6317 UTOPIA DR	5/8	BADG	93060801	198340	10.0	10.0	100.00%	5/9/2001				
00693 001834 1	TRLR	6321 UTOPIA DR	5/8	BADG	93060808	726580	10.0	9.9	99.00%	11/27/2001				
00693 001835 1	TRLR	6325 UTOPIA DR	5/8	BADG	93060809	356530	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256569	0	4/30/2002
00693 001836 2	TRLR	6329 UTOPIA DR	5/8	BADG	93060815	330150	10.0	9.9	99.00%	11/27/2001				
00693 001837 1	TRLR	6333 UTOPIA DR	5/8	BADG	93259678	134980	10.0	9.6	96.00%	11/27/2001				
00693 001838 1	TRLR	6337 UTOPIA DR	5/8	BADG	93259661	854120	5.0	5.0	100.00%	9/13/2000	BADG	29185712	0	7/27/2001
00693 001839 1	TRLR	6341 UTOPIA DR	5/8	BADG	93060800	752240	10.0	10.0	100.00%	5/9/2001				
00693 001840 1	TRLR	6403 UTOPIA DR	5/8	BADG	92420211	175040	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256572	0	4/30/2002
00693 001841 1	TRLR	6407 UTOPIA DR	5/8	BADG	93060812	291470	10.0	10.0	100.00%	11/27/2001				
00693 001842 1	TRLR	6419 UTOPIA DR	5/8	BADG	9242028	749190	10.0	9.9	99.00%	5/9/2001				
00693 001418 1	TRLR	6418 JESSUP DR	5/8	BADG	91492992	2024350	10.0	9.9	99.00%	11/27/2001				
00693 001419 2	TRLR	6412 JESSUP DR	5/8	BADG	91492998	627500	10.0	9.9	99.00%	11/27/2001				
00693 001420 3	TRLR	6406 JESSUP DR	5/8	BADG	91838585	277680	10.0	10.1	101.00%	5/9/2001				
00693 001421 1	TRLR	6400 JESSUP DR	5/8	BADG	91493000	421320	10.0	10.0	100.00%	5/9/2001				
00693 001423 2	TRLR	6344 JESSUP DR	5/8	BADG	91492997	712490	10.0	10.0	100.00%	5/10/2001				
00693 001424 1	TRLR	6338 JESSUP DR	5/8	BADG	18721972	96580	10.0	10.0	100.00%	5/10/2001				
00693 001425 1	TRLR	6334 JESSUP DR	5/8	BADG	91492979	344240	NOT TESTED/VACANT LOT							
00693 001426 1	TRLR	6328 JESSUP DR	5/8	BADG	91492974	429940	10.0	10.1	101.00%	5/10/2001				
00693 001427 2	TRLR	6322 JESSUP DR	5/8	BADG	91610800	393940	5.0	5.0	100.00%	9/13/2000				
00693 001429 2	TRLR	6312 JESSUP DR	5/8	BADG	91610789	471020	10.0	10.0	100.00%	5/10/2001				
00693 001431 1	TRLR	6300 JESSUP DR	5/8	BADG	91232874	856980	10.0	10.0	100.00%	5/10/2001				
00693 001432 1	TRLR	6250 JESSUP DR	5/8	BADG	91610799	874820	10.0	10.3	103.00%	3/7/2001	BADG	30223664	10	4/7/2001

LABRADOR UTILITIES, INC.
DOCKET NO. 030443-WS

METER CHANGE-OUT GUIDELINES

RANGE OF RESULTS - 95% - 101.5%
CHANGE OUT IF LESS THAN 9.5 OR 10.2 OR GREATER

OF METERS OUTSIDE PSC LIMITS

SLOW METERS	19
FAST METERS	126

RESPONSE TO PAA ACTION REQUEST - ISSUE #1 - METER FLOW TEST RESULTS

TOTAL TESTED 800

ACCOUNT NUMB	TYPE	SERVICE ADDRESS	SIZE	MAKE	SERIAL #	METER READ	VOLUME IN GALLONS		RESULTS		MAKE	NEW SERIAL #	NEW METER READ	DATE CHANGED OUT
							PTM TESTER	CUSTOMER METER	% OF ACCURACY	DATE TESTED				
00693 001433 4	TRLR	6246 JESSUP DR	5/8	BADG	91610794	629250	10.0	9.9	99.00%	11/27/2001				
00693 001436 1	TRLR	6232 JESSUP DR	5/8	BADG	18721971	140580	10.0	10.0	100.00%	5/10/2001				
00693 001439 1	TRLR	6214 JESSUP DR	5/8	BADG	18721949	59770	10.0	10.0	100.00%	5/10/2001				
00693 001440 2	TRLR	6208 JESSUP DR	5/8	BADG	91232883	445000	10.0	10.1	101.00%	5/10/2001				
00693 001441 2	TRLR	6202 JESSUP DR	5/8	BADG	30223631	4100	10.0	10.0	100.00%	5/10/2001				
00693 001442 1	TRLR	6168 JESSUP DR	5/8	BADG	91232889	1151260	10.0	10.0	100.00%	5/10/2001				
00693 001444 1	TRLR	6156 JESSUP DR	5/8	BADG	19616997	43240	10.0	10.0	100.00%	5/10/2001				
00693 001788 2	TRLR	6130 JESSUP DR	5/8	BADG	30223636	4020	10.0	10.0	100.00%	5/10/2001				
00693 001789 1	TRLR	6128 JESSUP DR	5/8	BADG	92420096	250610	10.0	10.0	100.00%	11/27/2001				
00693 001790 1	TRLR	6126 JESSUP DR	5/8	BADG	92420146	270150	10.0	10.0	100.00%	11/27/2001				
00693 001791 2	TRLR	6124 JESSUP DR	5/8	BADG	18721922	61490	10.0	10.0	100.00%	5/10/2001				
00693 001792 1	TRLR	6122 JESSUP DR	5/8	BADG	92114012	379270	10.0	10.1	101.00%	5/10/2001				
00693 001793 1	TRLR	6120 JESSUP DR	5/8	BADG	92114015	308430	10.0	10.0	100.00%	5/10/2001				
00693 001794 1	TRLR	6064 JESSUP DR	5/8	BADG	92121025	263800	10.0	9.9	99.00%	11/27/2001				
00693 001795 1	TRLR	6062 JESSUP DR	5/8	BADG	92420167	499720	10.0	10.2	102.00%	5/10/2001	BADG	32206655	0	5/12/2001
00693 001796 1	TRLR	6060 JESSUP DR	5/8	BADG	92420165	400360	10.0	10.1	101.00%	5/10/2001				
00693 001797 2	TRLR	6058 JESSUP DR	5/8	BADG	92420089	252790	10.0	10.0	100.00%	5/10/2001				
00693 001798 3	TRLR	6056 JESSUP DR	5/8	BADG	92114005	413930	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256570	0	4/30/2002
00693 001799 2	TRLR	6054 JESSUP DR	5/8	BADG	92114001	284550	10.0	10.0	100.00%	5/10/2001				
00693 001800 1	TRLR	6052 JESSUP DR	5/8	BADG	92114003	572590	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256580	0	4/30/2002
00693 001755 1	TRLR	6050 JESSUP DR	5/8	BADG	18721912	330400	10.0	10.0	100.00%	5/10/2001				
00693 001523 1	TRLR	5948 JESSUP DR	5/8	BADG	91838646	291590	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256606	0	5/2/2002
00693 001522 1	TRLR	5946 JESSUP DR	5/8	BADG	92420102	281210	10.0	10.0	100.00%	11/27/2001				
00693 001518 1	TRLR	5944 JESSUP DR	5/8	BADG	92420090	636290	10.0	9.8	98.00%	11/27/2001				
00693 001514 1	TRLR	5942 JESSUP DR	5/8	BADG	18721918	56090	10.0	10.0	100.00%	5/10/2001				

LABRADOR UTILITIES, INC.
DOCKET NO. 030443-WS

METER CHANGE-OUT GUIDELINES

RANGE OF RESULTS - 95% - 101.5%

CHANGE OUT IF LESS THAN 9.5 OR 10.2 OR GREATER

OF METERS OUTSIDE PSC LIMITS

SLOW METERS	19
FAST METERS	126
TOTAL TESTED	800

RESPONSE TO PAA ACTION REQUEST - ISSUE #1 - METER FLOW TEST RESULTS

ACCOUNT NUMB	TYP E	SERVICE ADDRESS	SIZ E	MA KE	SERIAL #	METER READ	VOLUME IN GALLONS		RESULTS		MA KE	NEW SERIAL #	NEW METER READ	DATE CHANGED OUT
							PTM TESTER	CUSTOMER METER	% OF ACCURACY	DATE TESTED				
00693 001512 1	TRLR	5940 JESSUP DR	5/8	BADG	42114016	721260	10.0	10.1	101.00%	5/10/2001				
00693 001509 1	TRLR	5938 JESSUP DR	5/8	BADG	91838584	307690	10.0	9.8	98.00%	11/27/2001				
00693 001506 2	TRLR	5936 JESSUP DR	5/8	BADG	91838631	426110	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256604	0	5/2/2002
00693 001503 1	TRLR	5934 JESSUP DR	5/8	BADG	91838632	599860	10.0	10.1	101.00%	5/10/2001				
00693 001500 1	TRLR	5932 JESSUP DR	5/8	BADG	92114006	1028160	10.0	10.0	100.00%	11/27/2001				
00693 001494 2	TRLR	5928 JESSUP DR	5/8	BADG	29140550	28280	10.0	10.0	100.00%	5/10/2001				
00693 001490 1	TRLR	5926 JESSUP DR	5/8	BADG	91838630	753230	10.0	10.1	101.00%	5/11/2001				
00693 001487 1	TRLR	5924 JESSUP DR	5/8	BADG	91838689	221750	10.0	10.0	100.00%	11/27/2001				
00693 001484 3	TRLR	5922 JESSUP DR	5/8	BADG	18721974	22670	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256583	0	5/14/2002
00693 001481 2	TRLR	5920 JESSUP DR	5/8	BADG	91838645	215430	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256608	0	5/3/2002
00693 001478 1	TRLR	5918 JESSUP DR	5/8	BADG	91838623	307630	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256607	0	5/14/2002
00693 001475 1	TRLR	5916 JESSUP DR	5/8	BADG	91838581	226430	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256605	10	5/14/2002
00693 001470 1	TRLR	5914 JESSUP DR	5/8	BADG	92114042	252520	10.0	10.1	101.00%	5/11/2001				
00693 001467 1	TRLR	5912 JESSUP DR	5/8	BADG	92114037	1478300	10.0	10.1	101.00%	5/11/2001				
00693 001462 1	TRLR	5910 JESSUP DR	5/8	BADG	92114013	395960	10.0	10.3	103.00%	5/11/2001	BADG	32206654	10	5/12/2001
00693 001459 4	TRLR	5908 JESSUP DR	5/8	BADG	92114043	284760	10.0	10.1	101.00%	5/11/2001				
00693 001454 2	TRLR	5906 JESSUP DR	5/8	BADG	92114036	524970	NOT TESTED/VACANT LOT							
00693 001451 1	TRLR	5904 JESSUP DR	5/8	BADG	91838590	1031190	5.0	5.0	100.00%	9/13/2000				
00693 001446 1	TRLR	5902 JESSUP DR	5/8	BADG	91838641	438310	10.0	9.9	99.00%	11/27/2001				
00693 001547 1	TRLR	5917 TWILIGHT DR	5/8	BADG	94240149	434750	10.0	10.1	101.00%	5/11/2001				
00693 001546 2	TRLR	5919 TWILIGHT DR	5/8	BADG	92420098	258800	10.0	10.0	100.00%	5/11/2001				
00693 001545 3	TRLR	5921 TWILIGHT DR	5/8	BADG	92114026	187070	10.0	10.0	100.00%	11/27/2001				
00693 001230 1	TRLR	6005 TWILIGHT DR	5/8	BADG	91492981	287520	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256584	0	5/15/2002
00693 001445 2	TRLR	5901 JESSUP DR	5/8	BADG	92420147	353590	10.0	9.7	97.00%	4/5/2002				
00693 001452 1	TRLR	5903 JESSUP DR	5/8	BADG	91838601	419660	10.0	9.9	99.00%	11/27/2001				

RESPONSE TO PAA ACTION REQUEST - ISSUE #1 - METER FLOW TEST RESULTS

METER CHANGE-OUT GUIDELINES
RANGE OF RESULTS - 95% - 101.5%
CHANGE OUT IF LESS THAN 9.5 OR 10.2 OR GREATER

OF METERS OUTSIDE PSC LIMITS
SLOW METERS 19
FAST METERS 126
TOTAL TESTED 800

ACCOUNT NUMB	TYP	SERVICE ADDRESS	SIZ	MA KE	SERIAL #	METER READ	VOLUME IN GALLONS			RESULTS			MA KE	NEW SERIAL #	NEW METER READ	DATE CHANGED OUT	
							PTM TESTER	CUSTOMER METER	% OF ACCURACY	DATE TESTED	NOT TESTED/OFF AT HOUSE/REPLACED PER						
00693 001453 1	TRLR	5905 JESSUP DR	5/8	BADG	92420164	228310	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED
00693 001460 1	TRLR	5907 JESSUP DR	5/8	BADG	92420166	466250	10.0	9.9	99.00%	11/27/2001							
00693 001461 2	TRLR	5909 JESSUP DR	5/8	BADG	91838599	222900	10.0	9.9	99.00%	11/27/2001							
00693 001468 1	TRLR	5911 JESSUP DR	5/8	BADG	91838644	314580	10.0	10.0	100.00%	11/27/2001							
00693 001469 1	TRLR	5913 JESSUP DR	5/8	BADG	91838635	431940	10.0	10.1	101.00%	5/11/2001							
00693 001476 1	TRLR	5915 JESSUP DR	5/8	BADG	91838640	620170	10.0	10.1	101.00%	5/12/2001							
00693 001477 1	TRLR	5917 JESSUP DR	5/8	BADG	91838633	368800	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED
00693 001482 1	TRLR	5919 JESSUP DR	5/8	BADG	91838636	238660	10.0	10.1	101.00%	5/12/2001							
00693 001483 1	TRLR	5921 JESSUP DR	5/8	BADG	91838637	572980	10.0	10.0	100.00%	11/27/2001							
00693 001488 1	TRLR	5923 JESSUP DR	5/8	BADG	91838618	413490	10.0	10.1	101.00%	5/16/2001							
00693 001489 1	TRLR	5925 JESSUP DR	5/8	BADG	91838621	370870	10.0	10.2	102.00%	5/16/2001							
00693 001495 1	TRLR	5927 JESSUP DR	5/8	BADG	91838617	1729110	10.0	9.9	99.00%	4/25/2002							
00693 001496 1	TRLR	5929 JESSUP DR	5/8	BADG	91838622	346380	10.0	10.0	100.00%	11/27/2001							
00693 001501 1	TRLR	5931 JESSUP DR	5/8	BADG	91838620	1325100	10.0	10.1	101.00%	5/16/2001							
00693 001502 1	TRLR	5933 JESSUP DR	5/8	BADG	18721917	63840	10.0	10.0	100.00%	5/16/2001							
00693 001507 1	TRLR	5935 JESSUP DR	5/8	BADG	91838627	844240	10.0	10.1	101.00%	5/16/2001							
00693 001508 1	TRLR	5937 JESSUP DR	5/8	BADG	91838626	360500	10.0	10.0	100.00%	11/27/2001							
00693 001513 1	TRLR	5939 JESSUP DR	5/8	BADG	91838628	207380	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED
00693 001519 1	TRLR	5941 JESSUP DR	5/8	BADG	18486269	68550	10.0	10.0	100.00%	5/16/2001							
00693 001520 2	TRLR	5943 JESSUP DR	5/8	BADG	91838643	607280	10.0	10.2	102.00%	5/16/2001							
00693 001521 1	TRLR	5945 JESSUP DR	5/8	BADG	92114010	688120	10.0	10.0	100.00%	5/16/2001							
00693 001756 1	TRLR	6049 JESSUP DR	5/8	BADG	92420101	1167170	10.0	10.0	100.00%	11/27/2001							
00693 001777 1	TRLR	6051 JESSUP DR	5/8	BADG	29140557	23300	10.0	10.0	100.00%	5/16/2001							
00693 001778 1	TRLR	6053 JESSUP DR	5/8	BADG	92114000	427740	10.0	10.0	100.00%	5/16/2001							
00693 001779 1	TRLR	6055 JESSUP DR	5/8	BADG	91838624	390380	10.0	9.6	96.00%	4/25/2002							

LABRADOR UTILITIES, INC.
DOCKET NO. 030443-WS

METER CHANGE-OUT GUIDELINES
RANGE OF RESULTS - 95% - 101.5%
CHANGE OUT IF LESS THAN 9.5 OR 10.2 OR GREATER

OF METERS OUTSIDE PSC LIMITS
SLOW METERS 19
FAST METERS 126
TOTAL TESTED 800

RESPONSE TO PAA ACTION REQUEST - ISSUE #1 - METER FLOW TEST RESULTS

ACCOUNT NUMB	TYP E	SERVICE ADDRESS	SIZ E	MA KE	SERIAL #	METER READ	VOLUME IN GALLONS		RESULTS		MA KE	NEW SERIAL #	NEW METER READ	DATE CHANGED OUT
							PTM TESTER	CUSTOMER METER	% OF ACCURACY	DATE TESTED				
00693 001780 2	TRLR	6057 JESSUP DR	5/8	BADG	92420163	265460	10.0	9.8	98.00%	4/25/2002				
00693 001781 1	TRLR	6059 JESSUP DR	5/8	BADG	91838693	832150	5.0	5.0	100.00%	9/13/2000				
00693 001782 1	TRLR	6121 JESSUP DR	5/8	BADG	91838602	310450	10.0	10.0	100.00%	5/17/2001				
00693 001783 1	TRLR	6123 JESSUP DR	5/8	BADG	91838600	752340	10.0	10.1	101.00%	5/17/2001				
00693 001784 1	TRLR	6125 JESSUP DR	5/8	BADG	91838604	189910	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	3325682	0	5/15/2002
00693 001785 1	TRLR	6127 JESSUP DR	5/8	BADG	91838603	207660	10.0	9.9	99.00%	11/27/2001	BADG	33256630	0	5/15/2002
00693 001786 1	TRLR	6129 JESSUP DR	5/8	BADG	92114040	554040	10.0	10.4	104.00%	5/17/2001	BADG	32206727	10	5/17/2001
00693 001787 1	TRLR	6131 JESSUP DR	5/8	BADG	92420086	364540	10.0	10.1	101.00%	5/17/2001				
00693 001392 1	TRLR	6157 JESSUP DR	5/8	BADG	18721925	187720	10.0	10.0	100.00%	5/17/2001				
00693 001393 1	TRLR	6163 JESSUP DR	5/8	BADG	91232829	374590	10.0	9.8	98.00%	11/27/2001				
00693 001394 1	TRLR	6169 JESSUP DR	5/8	BADG	91232839	533740	10.0	10.0	100.00%	5/17/2001				
00693 001395 2	TRLR	6203 JESSUP DR	5/8	BADG	29140608	14440	10.0	10.0	100.00%	5/17/2001				
00693 001396 1	TRLR	6209 JESSUP DR	5/8	BADG	18721947	202320	5.0	5.0	100.00%	9/13/2000				
00693 001397 1	TRLR	6215 JESSUP DR	5/8	BADG	91838594	349350	10.0	0.0	0.00%	4/18/2001	BADG	32206721	10	4/18/2001
00693 001398 1	TRLR	6221 JESSUP DR	5/8	BADG	18486320	58250	10.0	10.0	100.00%	5/12/2001				
00693 001399 1	TRLR	6227 JESSUP DR	5/8	BADG	91232830	598000	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256629	0	5/15/2002
00693 001400 3	TRLR	6233 JESSUP DR	5/8	BADG	30223649	4120	10.0	10.0	100.00%	5/12/2001				
00693 001401 1	TRLR	6239 JESSUP DR	5/8	BADG	91492988	494120	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256676	0	5/17/2002
00693 001402 1	TRLR	6241 JESSUP DR	5/8	BADG	91492994	440660	10.0	10.0	100.00%	11/27/2001				
00693 001405 1	TRLR	6301 JESSUP DR	5/8	BADG	18722012	51210	10.0	10.0	100.00%	5/12/2001				
00693 001406 2	TRLR	6307 JESSUP DR	5/8	BADG	32206656	110	10.0	10.0	100.00%	5/1/2001				
00693 001407 1	TRLR	6313 JESSUP DR	5/8	BADG	91232873	525840	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256643	0	5/22/2002
00693 001408 2	TRLR	6317 JESSUP DR	5/8	BADG	19616994	11430	10.0	10.0	100.00%	5/19/2001				
00693 001895 1	TRLR	6329 JESSUP DR	5/8	BADG	92420153	603480	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256673	0	5/23/2002
00693 001410 1	TRLR	6335 JESSUP DR	5/8	BADG	92420158	651120	10.0	9.7	97.00%	11/27/2001				

LABRADOR UTILITIES, INC.
DOCKET NO. 030443-WS

METER CHANGE-OUT GUIDELINES

RANGE OF RESULTS - 95% - 101.5%
CHANGE OUT IF LESS THAN 9.5 OR 10.2 OR GREATER

OF METERS OUTSIDE PSC LIMITS

SLOW METERS	19
FAST METERS	126
TOTAL TESTED	800

RESPONSE TO PAA ACTION REQUEST - ISSUE #1 - METER FLOW TEST RESULTS

ACCOUNT NUMB	TYPE	SERVICE ADDRESS	SIZE	MAKE	SERIAL #	METER READ	VOLUME IN GALLONS		RESULTS		MAKE	NEW SERIAL #	NEW METER READ	DATE CHANGED OUT
							PTM TESTER	CUSTOMER METER	% OF ACCURACY	DATE TESTED				
00693 001411 1	TRLR	6339 JESSUP DR	5/8	BADG	91492983	1353660	10.0	10.0	100.00%	5/15/2001	BADG	32206729	0	5/15/2001
00693 001412 1	TRLR	6345 JESSUP DR	5/8	BADG	91492985	361540	10.0	9.9	99.00%	11/27/2001				
00693 001413 1	TRLR	6351 JESSUP DR	5/8	BADG	18721941	89760	10.0	10.0	100.00%	5/19/2001				
00693 001414 1	TRLR	6401 JESSUP DR	5/8	BADG	18427492	247840	10.0	10.0	100.00%	5/19/2001				
00693 001415 1	TRLR	6407 JESSUP DR	5/8	BADG	18721915	52480	10.0	10.0	100.00%	5/19/2001				
00693 001416 1	TRLR	6413 JESSUP DR	5/8	BADG	18721945	62000	10.0	10.0	100.00%	5/19/2001				
00693 001417 1	TRLR	6419 JESSUP DR	5/8	BADG	19616963	11630	10.0	10.0	100.00%	5/19/2001				
00693 001029 1	TRLR	41282 XENON WAY	5/8	BADG	19148704	98880	10.0	10.0	100.00%	5/19/2001				
00693 001036 2	TRLR	41244 XENON WAY	5/8	BADG	19616987	22690	10.0	10.0	100.00%	5/18/2001				
00693 001374 2	TRLR	6320 PRESIDENTIAL CIR	5/8	BADG	18486298	97470	10.0	10.0	100.00%	5/18/2001				
00693 001375 1	TRLR	6316 PRESIDENTIAL CIR	5/8	BADG	90999694	591260	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256641	0	5/22/2002
00693 001376 2	TRLR	6312 PRESIDENTIAL CIR	5/8	BADG	18721948	39970	10.0	10.0	100.00%	5/18/2001				
00693 001378 1	TRLR	6302 PRESIDENTIAL CIR	5/8	BADG	91232826	462960	10.0	9.8	98.00%	4/27/2002				
00693 001379 2	TRLR	6252 PRESIDENTIAL CIR	5/8	BADG	29140506	17560	10.0	10.0	100.00%	5/18/2001				
00693 001380 3	TRLR	6246 PRESIDENTIAL CIR	5/8	BADG	UNKNOWN	3296290	10.0	10.0	100.00%	5/18/2001				
00693 001381 1	TRLR	6240 PRESIDENTIAL CIR	5/8	BADG	91232825	1215000	10.0	10.1	101.00%	5/18/2001				
00693 001383 1	TRLR	6232 PRESIDENTIAL CIR	5/8	BADG	18486318	70360	10.0	10.0	100.00%	5/18/2001				
00693 001384 2	TRLR	6226 PRESIDENTIAL CIR	5/8	BADG	91839599	426890	10.0	9.9	99.00%	4/27/2002				
00693 001385 1	TRLR	6220 PRESIDENTIAL CIR	5/8	BADG	19822650	120430	10.0	10.0	100.00%	5/18/2001				
00693 001386 1	TRLR	6214 PRESIDENTIAL CIR	5/8	BADG	91232823	109850	10.0	9.9	99.00%	4/27/2002				
00693 001387 1	TRLR	6208 PRESIDENTIAL CIR	5/8	BADG	18721911	55930	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256604	0	5/22/2002
00693 001388 3	TRLR	6202 PRESIDENTIAL CIR	5/8	BADG	19616989	42240	10.0	10.0	100.00%	5/18/2001				
00693 001389 1	TRLR	6168 PRESIDENTIAL CIR	5/8	BADG	90999691	505020	10.0	10.0	100.00%	5/18/2001				
00693 001390 2	TRLR	6162 PRESIDENTIAL CIR	5/8	BADG	90999680	372440	10.0	10.0	100.00%	5/18/2001				
00693 001391 1	TRLR	6156 PRESIDENTIAL CIR	5/8	BADG	91492998	502390	10.0	9.5	95.00%	5/18/2001	BADG	32206657	0	4/28/2001

LABRADOR UTILITIES, INC.
DOCKET NO. 030443-WS

METER CHANGE-OUT GUIDELINES

RANGE OF RESULTS - 95% - 101.5%

CHANGE OUT IF LESS THAN 9.5 OR 10.2 OR GREATER

OF METERS OUTSIDE PSC LIMITS

SLOW METERS	19
FAST METERS	126
TOTAL TESTED	800

RESPONSE TO PAA ACTION REQUEST - ISSUE #1 - METER FLOW TEST RESULTS

ACCOUNT NUMB	TYPE	SERVICE ADDRESS	SIZE	MAKE	SERIAL #	METER READ	VOLUME IN GALLONS		RESULTS		MAKE	NEW SERIAL #	NEW METER READ	DATE CHANGED OUT
							PTM TESTER	CUSTOMER METER	% OF ACCURACY	DATE TESTED				
00693 001767 1	TRLR	6144 PRESIDENTIAL CIR	5/8	BADG	90999701	497090	10.0	10.1	101.00%	5/18/2001				
00693 001768 1	TRLR	6138 PRESIDENTIAL CIR	5/8	BADG	90999700	563190	10.0	10.0	100.00%	5/18/2001				
00693 001769 2	TRLR	6132 PRESIDENTIAL CIR	5/8	BADG	18722016	43880	10.0	10.0	100.00%	5/18/2001				
00693 001770 1	TRLR	6126 PRESIDENTIAL CIR	5/8	BADG	90999686	810100	10.0	9.9	99.00%	5/18/2001				
00693 001771 1	TRLR	6118 PRESIDENTIAL CIR	5/8	BADG	90999684	660690	10.0	10.1	101.00%	5/18/2001				
00693 001772 1	TRLR	6110 PRESIDENTIAL CIR	5/8	BADG	90999684	366990	10.0	10.0	100.00%	11/10/2001				
00693 001773 1	TRLR	6056 PRESIDENTIAL CIR	5/8	BADG	18486280	59880	10.0	10.1	101.00%	5/18/2001				
00693 001774 1	TRLR	6054 PRESIDENTIAL CIR	5/8	BADG	90999695	436550	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256635	0	5/15/2002
00693 001776 1	TRLR	6050 PRESIDENTIAL CIR	5/8	BADG	90123168	440690	10.0	9.9	99.00%	11/10/2001				
00693 001757 2	TRLR	6048 PRESIDENTIAL CIR	5/8	BADG	18721943	47230	10.0	10.0	100.00%	5/18/2001				
00693 001310 1	TRLR	6044 PRESIDENTIAL CIR	5/8	BADG	91838596	619020	10.0	9.9	99.00%	4/26/2002				
00693 001303 1	TRLR	6042 PRESIDENTIAL CIR	5/8	BADG	90123180	808790	10.0	9.8	98.00%	11/10/2001				
00693 001302 2	TRLR	6040 PRESIDENTIAL CIR	5/8	BADG	90123169	600910	10.0	9.9	99.00%	11/10/2001				
00693 001301 2	TRLR	6038 PRESIDENTIAL CIR	5/8	BADG	91492996	504540	10.0	10.0	100.00%	11/10/2001				
00693 001295 3	TRLR	6036 PRESIDENTIAL CIR	5/8	BADG	90123115	512440	10.0	10.1	101.00%	5/18/2001				
00693 001294 1	TRLR	6034 PRESIDENTIAL CIR	5/8	BADG	90123163	508670	10.0	10.1	101.00%	5/18/2001				
00693 001288 1	TRLR	6032 PRESIDENTIAL CIR	5/8	BADG	90123162	848970	10.0	10.4	104.00%	5/25/2001	BADG	32206662	10	5/25/2001
00693 001287 1	TRLR	6030 PRESIDENTIAL CIR	5/8	BADG	90123179	218840	10.0	9.9	99.00%	11/10/2001				
00693 001286 1	TRLR	6028 PRESIDENTIAL CIR	5/8	BADG	90123177	342890	10.0	10.1	101.00%	5/25/2001				
00693 001279 1	TRLR	6026 PRESIDENTIAL CIR	5/8	BADG	90123189	679200	10.0	9.8	98.00%	11/10/2001				
00693 001278 1	TRLR	6024 PRESIDENTIAL CIR	5/8	BADG	90123171	744420	10.0	10.1	101.00%	5/25/2001				
00693 001271 4	TRLR	6022 PRESIDENTIAL CIR	5/8	BADG	90123186	425740	10.0	10.3	103.00%	5/25/2001	BADG	32206661	0	5/25/2001
00693 001262 2	TRLR	6016 PRESIDENTIAL CIR	5/8	BADG	90999672	665690	10.0	9.9	99.00%	11/10/2001				
00693 001255 2	TRLR	6014 PRESIDENTIAL CIR	5/8	BADG	90999692	1216760	10.0	10.0	100.00%	5/25/2001				
00693 001254 2	TRLR	6012 PRESIDENTIAL CIR	5/8	BADG	18721957	42430	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256638	0	5/15/2002

LABRADOR UTILITIES, INC.
DOCKET NO. 030443-WS

METER CHANGE-OUT GUIDELINES

RANGE OF RESULTS - 95% - 101.5%
CHANGE OUT IF LESS THAN 9.5 OR 10.2 OR GREATER

OF METERS OUTSIDE PSC LIMITS

SLOW METERS	19
FAST METERS	126
TOTAL TESTED	800

RESPONSE TO PAA ACTION REQUEST - ISSUE #1 - METER FLOW TEST RESULTS

ACCOUNT NUMB	TYPE	SERVICE ADDRESS	SIZE	MAKE	SERIAL #	METER READ	VOLUME IN GALLONS		RESULTS		MAKE	NEW SERIAL #	NEW METER READ	DATE CHANGED OUT
							PTM TESTER	CUSTOMER METER	% OF ACCURACY	DATE TESTED				
00693 001246 1	TRLR	6008 PRESIDENTIAL CIR	5/8	BADG	18721920	74310	10.0	10.0	100.00%	5/25/2001				
00693 001247 2	TRLR	6010 PRESIDENTIAL CIR	5/8	BADG	90123106	469680	10.0	10.2	102.00%	5/25/2001	BADG	32206660	0	5/25/2001
00693 001239 1	TRLR	6006 PRESIDENTIAL CIR	5/8	BADG	90123113	233650	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256637	0	5/15/2002
00693 001238 1	TRLR	6004 PRESIDENTIAL CIR	5/8	BADG	90123102	375130	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256636	0	5/17/2002
00693 001231 2	TRLR	6002 PRESIDENTIAL CIR	5/8	BADG	90123165	396260	10.0	9.9	99.00%	11/10/2001				
00693 001228 1	TRLR	6015 TWILIGHT DR	5/8	BADG	90123161	433350	NOT TESTED/VACANT LOT							
00693 001227 1	TRLR	6019 TWILIGHT DR	5/8	BADG	90123105	511630	10.0	10.0	100.00%	5/25/2001				
00693 001232 1	TRLR	6001 PRESIDENTIAL CIR	5/8	BADG	90123166	604550	10.0	9.9	99.00%	11/10/2001				
00693 001237 1	TRLR	6003 PRESIDENTIAL CIR	5/8	BADG	90123029	398520	10.0	10.0	100.00%	5/25/2001				
00693 001240 1	TRLR	6005 PRESIDENTIAL CIR	5/8	BADG	90123033	415810	10.0	10.1	101.00%	5/25/2001				
00693 001245 2	TRLR	6007 PRESIDENTIAL CIR	5/8	BADG	90123129	544220	10.0	10.0	100.00%	11/10/2001				
00693 001248 1	TRLR	6009 PRESIDENTIAL CIR	5/8	BADG	90123172	572020	10.0	10.1	101.00%	5/25/2001				
00693 001253 1	TRLR	6011 PRESIDENTIAL CIR	5/8	BADG	90123170	743800	10.0	9.9	99.00%	11/10/2001				
00693 001256 2	TRLR	6013 PRESIDENTIAL CIR	5/8	BADG	90123188	508890	10.0	9.9	99.00%	4/26/2002				
00693 001261 1	TRLR	6015 PRESIDENTIAL CIR	5/8	BADG	90123127	532990	10.0	10.1	101.00%	5/25/2001				
00693 001264 1	TRLR	6017 PRESIDENTIAL CIR	5/8	BADG	90123120	332840	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256634	0	5/17/2002
00693 001269 2	TRLR	6019 PRESIDENTIAL CIR	5/8	BADG	90123123	270010	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256639	0	5/17/2002
00693 001272 1	TRLR	6021 PRESIDENTIAL CIR	5/8	BADG	90123121	512070	10.0	9.9	99.00%	11/10/2001				
00693 001277 3	TRLR	6023 PRESIDENTIAL CIR	5/8	BADG	90123108	340380	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256671	0	5/17/2002
00693 001280 1	TRLR	6025 PRESIDENTIAL CIR	5/8	BADG	90123182	456500	10.0	10.0	100.00%	5/25/2001				
00693 001285 1	TRLR	6029 PRESIDENTIAL CIR	5/8	BADG	90123187	461580	10.0	9.9	99.00%	11/10/2001				
00693 001289 2	TRLR	6031 PRESIDENTIAL CIR	5/8	BADG	90123167	285450	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256624	0	5/17/2002
00693 001293 1	TRLR	6033 PRESIDENTIAL CIR	5/8	BADG	90123183	496170	10.0	10.0	100.00%	5/25/2001				
00693 001296 2	TRLR	6035 PRESIDENTIAL CIR	5/8	BADG	90123126	379000	10.0	9.6	96.00%	4/26/2002				
00693 001300 1	TRLR	6039 PRESIDENTIAL CIR	5/8	BADG	90123184	515940	10.0	9.9	99.00%	11/10/2001				

LABRADOR UTILITIES, INC.
DOCKET NO. 030443-WS

METER CHANGE-OUT GUIDELINES

RANGE OF RESULTS - 95% - 101.5%
CHANGE OUT IF LESS THAN 9.5 OR 10.2 OR GREATER

OF METERS OUTSIDE PSC LIMITS

SLOW METERS	19
FAST METERS	126
TOTAL TESTED	800

RESPONSE TO PAA ACTION REQUEST - ISSUE #1 - METER FLOW TEST RESULTS

ACCOUNT NUMB	TYPE	SERVICE ADDRESS	SIZE	MAKE	SERIAL #	METER READ	VOLUME IN GALLONS		RESULTS		MAKE	NEW SERIAL #	NEW METER READ	DATE CHANGED OUT
							PTM TESTER	CUSTOMER METER	% OF ACCURACY	DATE TESTED				
00693 001309 2	TRLR	6043 PRESIDENTIAL CIR	5/8	BADG	90123178	254580	10.0	9.9	99.00%	4/26/2002				
00693 001311 1	TRLR	6045 PRESIDENTIAL CIR	5/8	BADG	90123173	1324180	10.0	10.0	100.00%	5/25/2001				
00693 001759 1	TRLR	6051 PRESIDENTIAL CIR	5/8	BADG	90123174	318940	10.0	9.8	98.00%	11/10/2001				
00693 001760 1	TRLR	6053 PRESIDENTIAL CIR	5/8	BADG	30223673	3310	10.0	10.0	100.00%	5/25/2001				
00693 001761 1	TRLR	6055 PRESIDENTIAL CIR	5/8	BADG	90123176	210810	10.0	10.4	104.00%	5/26/2001	BADG	32206664	10	5/26/2001
00693 001762 2	TRLR	6111 PRESIDENTIAL CIR	5/8	BADG	90999685	758770	5.0	5.0	100.00%	9/13/2000				
00693 001763 1	TRLR	6119 PRESIDENTIAL CIR	5/8	BADG	90999689	324070	10.0	9.9	99.00%	4/26/2002				
00693 001764 1	TRLR	6127 PRESIDENTIAL CIR	5/8	BADG	90123175	186300	10.0	9.9	99.00%	11/13/2001				
00693 001765 2	TRLR	6135 PRESIDENTIAL CIR	5/8	BADG	19617005	18930	10.0	10.0	100.00%	5/26/2001				
00693 001766 2	TRLR	6143 PRESIDENTIAL CIR	5/8	BADG	30223650	19940	10.0	10.0	100.00%	6/13/2001				
00693 001356 2	TRLR	6157 PRESIDENTIAL CR	5/8	BADG	91232888	595870	10.0	10.5	105.00%	6/13/2001	BADG	32206548	10	6/14/2001
00693 001357 1	TRLR	6163 PRESIDENTIAL CIR	5/8	BADG	18721956	24170	10.0	9.9	99.00%	5/17/2002				
00693 001358 1	TRLR	6169 PRESIDENTIAL CIR	5/8	BADG	90999678	313040	10.0	9.8	98.00%	4/26/2002				
00693 001359 2	TRLR	6203 PRESIDENTIAL CIR	5/8	BADG	30223648	15080	10.0	10.0	100.00%	6/13/2001				
00693 001361 2	TRLR	6215 PRESIDENTIAL CIR	5/8	BADG	19616988	43970	10.0	10.0	100.00%	6/13/2001				
00693 001362 1	TRLR	6221 PRESIDENTIAL CIR	5/8	BADG	91232828	302680	10.0	10.0	100.00%	6/13/2001				
00693 001364 1	TRLR	6233 PRESIDENTIAL CIR	5/8	BADG	91838591	859760	10.0	10.0	100.00%	11/13/2001				
00693 001365 1	TRLR	6239 PRESIDENTIAL CIR	5/8	BADG	90999693	2087600	10.0	10.1	101.00%	6/13/2001				
00693 001366 2	TRLR	6241 PRESIDENTIAL CIR	5/8	BADG	91238888	2146000	10.0	9.9	99.00%	6/13/2001				
00693 001367 1	TRLR	6249 PRESIDENTIAL CIR	5/8	BADG	91838583	707110	10.0	10.0	100.00%	6/13/2001				
00693 001368 1	TRLR	6253 PRESIDENTIAL CIR	5/8	BADG	91610793	425960	10.0	10.1	101.00%	9/12/2001	BADG	32206496	0	9/12/2001
00693 001370 2	TRLR	6313 PRESIDENTIAL CIR	5/8	BADG	91232819	1138760	10.0	9.6	96.00%	4/26/2002				
00693 001371 1	TRLR	6319 PRESIDENTIAL CIR	5/8	BADG	81232877	407760	10.0	9.9	99.00%	11/13/2001				
00693 001061 1	TRLR	6349 PRESIDENTIAL CIR	5/8	BADG	30223637	10860	10.0	10.0	100.00%	6/15/2001				
00693 001068 2	TRLR	6355 PRESIDENTIAL CIR	5/8	BADG	19616965	17330	10.0	10.0	100.00%	6/15/2001				

LABRADOR UTILITIES, INC.
DOCKET NO. 030443-WS

METER CHANGE-OUT GUIDELINES

RANGE OF RESULTS - 95% - 101.5%
CHANGE OUT IF LESS THAN 9.5 OR 10.2 OR GREATER

OF METERS OUTSIDE PSC LIMITS

SLOW METERS	19
FAST METERS	126
TOTAL TESTED	800

RESPONSE TO PAA ACTION REQUEST - ISSUE #1 - METER FLOW TEST RESULTS

ACCOUNT NUMB	TYPE	SERVICE ADDRESS	SIZE	MAKE	SERIAL #	METER READ	VOLUME IN GALLONS		RESULTS		MAKE	NEW SERIAL #	NEW METER READ	DATE CHANGED OUT
							PTM TESTER	CUSTOMER METER	% OF ACCURACY	DATE TESTED				
00693 001072 2	TRLR	6405 PRESIDENTIAL CIR	5/8	BADG	92114008	625110	10.0	9.9	99.00%	11/13/2001				
00693 001074 1	TRLR	6425 PRESIDENTIAL CIR	5/8	BADG	18486319	82110	10.0	10.0	100.00%	6/14/2001				
00693 001340 1	TRLR	6310 FOREST LAKE DR	5/8	BADG	91610803	824560	10.0	10.1	101.00%	6/14/2001				
00693 001341 2	TRLR	6306 FOREST LAKE DR	5/8	BADG	18722013	13410	10.0	10.0	100.00%	6/14/2001				
00693 001342 2	TRLR	6302 FOREST LAKE DR	5/8	BADG	19616990	52400	10.0	10.0	100.00%	6/14/2001				
00693 001343 2	TRLR	6252 FOREST LAKE DR	5/8	BADG	18722011	202250	10.0	10.0	100.00%	6/14/2001				
00693 001344 2	TRLR	6246 FOREST LAKE DR	5/8	BADG	19616991	360030	10.0	10.0	100.00%	6/14/2001				
00693 001345 1	TRLR	6240 FOREST LAKE DR	5/8	BADG	91232820	2017460	5.0	5.0	100.00%	9/13/2000	BADG	32206549	0	6/7/2001
00693 001346 1	TRLR	6238 FOREST LAKE DR	5/8	BADG	91232821	1542510	10.0	10.1	101.00%	6/14/2001				
00693 001347 1	TRLR	6232 FOREST LAKE DR	5/8	BADG	18721939	21690	10.0	10.0	100.00%	6/14/2001				
00693 001348 1	TRLR	6226 FOREST LAKE DR	5/8	BADG	18721650	18090	10.0	10.0	100.00%	6/14/2001				
00693 001349 1	TRLR	6220 FOREST LAKE DR	5/8	BADG	18486294	21310	10.0	10.0	100.00%	6/14/2001				
00693 001350 1	TRLR	6214 FOREST LAKE DR	5/8	BADG	19616953	25330	10.0	10.0	100.00%	6/14/2001				
00693 001351 1	TRLR	6208 FOREST LAKE DR	5/8	BADG	91232834	533710	10.0	10.0	100.00%	6/14/2001	BADG	32248267	0	6/2/2001
00693 001353 1	TRLR	6168 FOREST LAKE DR	5/8	BADG	91232830	985900	10.0	9.9	99.00%	6/14/2001				
00693 001354 2	TRLR	6162 FOREST LAKE DR	5/8	BADG	9183587	245970	10.0	10.0	100.00%	11/7/2001				
00693 001324 1	TRLR	6144 FOREST LAKE DR	5/8	BADG	90123181	1010750	10.0	10.0	100.00%	6/14/2001				
00693 001322 1	TRLR	6136 FOREST LAKE DR	5/8	BADG	90123107	400920	10.0	10.1	101.00%	5/25/2001				
00693 001321 1	TRLR	6128 FOREST LAKE DR	5/8	BADG	90123051	778440	10.0	10.2	102.00%	6/14/2001	BADG	32206788	10	6/15/2001
00693 001320 1	TRLR	6120 FOREST LAKE DR	5/8	BADG	90123111	979740	10.0	10.0	100.00%	11/7/2001				
00693 001316 1	TRLR	6104 FOREST LAKE DR	5/8	BADG	90123023	334080	10.0	10.1	101.00%	6/21/2001				
00693 001315 2	TRLR	6086 FOREST LAKE DR	5/8	BADG	90123024	1097840	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256670	0	5/17/2002
00693 001308 1	TRLR	6078 FOREST LAKE DR	5/8	BADG	90123046	1141010	10.0	10.1	101.00%	6/21/2001				
00693 001305 1	TRLR	6074 FOREST LAKE DR	5/8	BADG	19616972	39980	10.0	10.0	100.00%	6/21/2001				
00693 001299 2	TRLR	6070 FOREST LAKE DR	5/8	BADG	90123026	330190	10.0	10.2	102.00%	6/21/2001	BADG	32206791	10	6/21/2001

LABRADOR UTILITIES, INC.
DOCKET NO. 030443-WS

METER CHANGE-OUT GUIDELINES

RANGE OF RESULTS - 95% - 101.5%
CHANGE OUT IF LESS THAN 9.5 OR 10.2 OR GREATER

OF METERS OUTSIDE PSC LIMITS

SLOW METERS	19
FAST METERS	126
TOTAL TESTED	800

RESPONSE TO PAA ACTION REQUEST - ISSUE #1 - METER FLOW TEST RESULTS

ACCOUNT NUMB	TYPE	SERVICE ADDRESS	SIZE	MAKE	SERIAL #	METER READ	VOLUME IN GALLONS		RESULTS		MAKE	NEW SERIAL #	NEW METER READ	DATE CHANGED OUT
							PTM TESTER	CUSTOMER METER	% OF ACCURACY	DATE TESTED				
00693 001297 2	TRLR	6066 FOREST LAKE DR	5/8	BADG	90123044	524630	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256675	0	5/17/2002
00693 001292 1	TRLR	6062 FOREST LAKE CIR	5/8	BADG	90123036	451590	10.0	9.9	99.00%	11/15/2001				
00693 001290 2	TRLR	6058 FOREST LAKE DR	5/8	BADG	90123025	366260	10.0	10.0	100.00%	11/15/2001				
00693 001284 2	TRLR	6054 FOREST LAKE DR	5/8	BADG	90123190	526950	10.0	10.0	100.00%	6/21/2001				
00693 001281 2	TRLR	6050 FOREST LAKE DR	5/8	BADG	90123050	1795850	10.0	10.0	100.00%	6/21/2001				
00693 001276 1	TRLR	6046 FOREST LAKE DR	5/8	BADG	18721946	52560	10.0	10.0	100.00%	6/21/2001				
00693 001273 1	TRLR	6042 FOREST LAKE DR	5/8	BADG	90123040	761660	10.0	10.0	100.00%	6/22/2001				
00693 001268 1	TRLR	6038 FOREST LAKE DR	5/8	BADG	90123039	117770	10.0	10.0	100.00%	11/15/2001				
00693 001260 1	TRLR	6030 FOREST LAKE DR	5/8	BADG	191616929	39000	10.0	10.0	100.00%	6/22/2001				
00693 001257 1	TRLR	6026 FOREST LAKE DR	5/8	BADG	18721969	26830	10.0	10.0	100.00%	6/22/2001				
00693 001252 3	TRLR	6022 FOREST LAKE DR	5/8	BADG	90123038	844660	10.0	10.0	100.00%	6/22/2001				
00693 001241 1	TRLR	6010 FOREST LAKE DR	5/8	BADG	18721913	130400	10.0	10.0	100.00%	6/22/2001				
00693 001236 1	TRLR	6006 FOREST LAKE DR	5/8	BADG	90125028	734730	10.0	9.9	99.00%	11/15/2001				
00693 001233 1	TRLR	6002 FOREST LAKE DR	5/8	BADG	18721923	304640	5.0	5.0	100.00%	9/13/2000				
00693 001234 1	TRLR	6001 FOREST LAKE DR	5/8	BADG	90123116	1563900	10.0	10.1	101.00%	6/22/2001				
00693 001474 1	TRLR	5915 UTOPIA DR	5/8	BADG	9242040	323400	10.0	10.0	100.00%	4/20/2001				
00693 001282 1	TRLR	6053 FOREST LAKE DR	5/8	BADG	90123047	482010	5.0	5.0	100.00%	9/13/2000				
00693 001298 2	TRLR	6067 FOREST LAKE DR	5/8	BADG	90123043	444420	10.0	9.8	98.00%	11/15/2001				
00693 001306 1	TRLR	6073 FOREST LAKE DR	5/8	BADG	90123125	750670	10.0	10.0	100.00%	6/27/2001				
00693 001307 1	TRLR	6079 FOREST LAKE DR	5/8	BADG	90123041	320620	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256631	0	5/17/2002
00693 001313 1	TRLR	6085 FOREST LAKE DR	5/8	BADG	90123049	676690	5.0	5.0	100.00%	9/13/2000				
00693 001314 1	TRLR	6103 FOREST LAKE DR	5/8	BADG	90123052	617780	10.0	10.0	100.00%	6/27/2001				
00693 001319 1	TRLR	6123 FOREST LAKE DR	5/8	BADG	90123103	261580	10.0	10.0	100.00%	11/15/2001				
00693 001323 4	TRLR	6135 FOREST LAKE DR	5/8	BADG	90123110	566100	10.0	10.4	104.00%	6/27/2001	BADG	32206609	10	6/28/2001
00693 001325 2	TRLR	6143 FOREST LAKE DR	5/8	BADG	90123185	603400	10.0	10.0	100.00%	11/7/2001				

LABRADOR UTILITIES, INC.
DOCKET NO. 030443-WS

METER CHANGE-OUT GUIDELINES

RANGE OF RESULTS - 95% - 101.5%
CHANGE OUT IF LESS THAN 9.5 OR 10.2 OR GREATER

OF METERS OUTSIDE PSC LIMITS

SLOW METERS	19
FAST METERS	126
TOTAL TESTED	800

RESPONSE TO PAA ACTION REQUEST - ISSUE #1 - METER FLOW TEST RESULTS

ACCOUNT NUMB	TYP E	SERVICE ADDRESS	SIZ E	MA KE	SERIAL #	METER READ	VOLUME IN GALLONS		RESULTS		MA KE	NEW SERIAL #	NEW METER READ	DATE CHANGED OUT
							PTM TESTER	CUSTOMER METER	% OF ACCURACY	DATE TESTED				
00693 001326 1	TRLR	6157 FOREST LAKE DR	5/8	BADG	90123118	638940	10.0	10.1	101.00%	6/27/2001				
00693 001327 1	TRLR	6163 FOREST LAKE DR	5/8	BADG	90999679	689070	10.0	9.8	98.00%	6/27/2001				
00693 001328 2	TRLR	6169 FOREST LAKE DR	5/8	BADG	91232891	1508550	10.0	10.0	100.00%	6/27/2001				
00693 001329 1	TRLR	6203 FOREST LAKE DR	5/8	BADG	29140549	19060	10.0	9.9	99.00%	6/27/2001				
00693 001330 1	TRLR	6209 FOREST LAKE DR	5/8	BADG	18486299	77280	10.0	9.9	99.00%	6/27/2001				
00693 001332 2	TRLR	6221 FOREST LAKE DR	5/8	BADG	91232878	127050	5.0	5.0	100.00%	9/13/2000				
00693 001333 1	TRLR	6227 FOREST LAKE DR	5/8	BADG	18486279	10	10.0	10.0	100.00%	11/7/2001				
00693 001334 1	TRLR	6233 FOREST LAKE DR	5/8	BADG	91610805	245660	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256680	0	5/22/2002
00693 001336 1	TRLR	6243 FOREST LAKE DR	5/8	BADG	32206659	1270	10.0	10.0	100.00%	6/28/2001				
00693 001337 3	TRLR	6251 FOREST LAKE DR	5/8	BADG	18722014	75900	10.0	10.0	100.00%	6/28/2001				
00693 001063 1	TRLR	6335 FOREST LAKE DR	5/8	BADG	19616928	38120	5.0	5.0	100.00%	9/13/2000				
00693 001066 1	TRLR	6339 FOREST LAKE DR	5/8	BADG	19616931	11830	5.0	5.0	100.00%	9/14/2000				
00693 001897 1	COMB	6360 SPRING LAKE DR	1	BADG	99242441	457540	10.0	10.0	100.00%	11/15/2001				
00693 001091 1	TRLR	6346 SPRING LAKE CIR	5/8	BADG	18486322	890	10.0	10.0	100.00%	6/28/2001				
00693 001040 1	TRLR	41204 XENON WAY	5/8	BADG	19074049	348960	5.0	5.0	100.00%	9/13/2000				
00693 001204 1	TRLR	6208 SPRING LAKE CIR	5/8	BADG	18721916	212120	10.0	10.0	100.00%	6/29/2001				
00693 001203 2	TRLR	6202 SPRING LAKE CIR	5/8	BADG	18486267	97800	10.0	10.0	100.00%	11/15/2001				
00693 001200 1	TRLR	6168 SPRING LAKE CIR	5/8	BADG	184862295	223380	10.0	10.0	100.00%	6/29/2001				
00693 001195 1	TRLR	6156 SPRING LAKE CIR	5/8	BADG	19616960	39580	10.0	10.0	100.00%	6/29/2001				
00693 001194 1	TRLR	6144 SPRING LAKE CIR	5/8	BADG	18721919	133560	10.0	10.0	100.00%	6/29/2001				
00693 001187 1	TRLR	6120 SPRING LAKE CIR	5/8	BADG	19616959	44970	10.0	10.0	100.00%	6/29/2001				
00693 001184 1	TRLR	6108 SPRING LAKE CIR	5/8	BADG	18486278	324100	10.0	10.0	100.00%	6/29/2001				
00693 001171 2	TRLR	6050 SPRING LAKE CIR	5/8	BADG	18486281	196810	10.0	10.0	100.00%	7/12/2001				
00693 001159 2	TRLR	6014 SPRING LAKE CIR	5/8	BADG	30223629	10090	10.0	10.0	100.00%	7/12/2001				
00693 001155 1	TRLR	6002 SPRING LAKE CIR	5/8	BADG	30223632	8430	10.0	10.0	100.00%	7/12/2001				

LABRADOR UTILITIES, INC.
DOCKET NO. 030443-WS

METER CHANGE-OUT GUIDELINES

RANGE OF RESULTS - 95% - 101.5%

CHANGE OUT IF LESS THAN 9.5 OR 10.2 OR GREATER

OF METERS OUTSIDE PSC LIMITS

SLOW METERS 19

FAST METERS 126

TOTAL TESTED 800

RESPONSE TO PAA ACTION REQUEST - ISSUE #1 - METER FLOW TEST RESULTS

ACCOUNT NUMB	TYPE	SERVICE ADDRESS	SIZE	MAKE	SERIAL #	METER READ	VOLUME IN GALLONS		RESULTS		MAKE	NEW SERIAL #	NEW METER READ	DATE CHANGED OUT
							PTM TESTER	CUSTOMER METER	% OF ACCURACY	DATE TESTED				
00693 001165 1	TRLR	6031 SPRING LAKE CIR	5/8	BADG	90123048	679200	10.0	9.9	99.00%	11/7/2001				
00693 001166 1	TRLR	6037 SPRING LAKE CIR	5/8	BADG	90123122	654270	5.0	5.0	100.00%	9/13/2000				
00693 001177 2	TRLR	6067 SPRING LAKE CIR	5/8	BADG	90123119	924720	10.0	9.9	99.00%	11/7/2001				
00693 001178 1	TRLR	6073 SPRING LAKE CIR	5/8	BADG	90123130	734440	10.0	9.9	99.00%	11/7/2001				
00693 001181 1	TRLR	6101 SPRINGLAKE CIR	5/8	BADG	19616966	9240	10.0	10.0	100.00%	7/12/2001				
00693 001188 1	TRLR	6125 SPRING LAKE CIR	5/8	BADG	90123034	77190	10.0	10.0	100.00%	11/7/2001				
00693 001206 1	TRLR	6213 SPRING LAKE CIR	5/8	BADG	90123124	226530	10.0	10.0	100.00%	11/7/2001				
00693 001101 1	TRLR	6359 SPRING LAKE CIR	5/8	BADG	30082983	38510	10.0	10.0	100.00%	7/12/2001				
00693 001104 2	TRLR	6377 SPRING LAKE CIR	5/8	BADG	18486290	80160	10.0	10.0	100.00%	7/12/2001				
00693 001122 1	TRLR	41044 BREAM CIR	5/8	BADG	19616903	45120	10.0	10.0	100.00%	7/19/2001				
00693 001125 1	TRLR	41026 BREAM CIR	5/8	BADG	18721926	166970	10.0	10.0	100.00%	7/19/2001				
00693 001152 1	TRLR	6120 TWILIGHT DR	5/8	BADG	90123031	292360	10.0	9.9	99.00%	11/9/2001				
00693 001153 1	TRLR	6114 TWILIGHT DR	5/8	BADG	18486277	56830	10.0	10.0	100.00%	7/19/2001				
00693 001147 1	TRLR	6113 TWILIGHT DR	5/8	BADG	19617006	6810	5.0	5.0	100.00%	9/14/2000				
00693 001142 1	TRLR	6143 TWILIGHT DR	5/8	BADG	18486291	224190	10.0	10.0	100.00%	7/19/2001				
00693 001141 1	TRLR	6149 TWILIGHT DR	5/8	BADG	18486293	98120	10.0	10.0	100.00%	7/19/2001				
00693 001129 1	TRLR	41053 BREAM CIR	5/8	BADG	90123101	773430	10.0	10.0	100.00%	7/19/2001				
00693 001048 1	TRLR	6344 PRESIDENTIAL CIR	5/8	BADG	19616957	30770	10.0	10.0	100.00%	7/19/2001				
00693 001051 1	TRLR	41263 XENON WAY	5/8	BADG	30223630	9570	10.0	10.0	100.00%	7/19/2001				
00693 001054 2	TRLR	41287 XENON WAY	5/8	BADG	18721942	58000	10.0	10.0	100.00%	7/19/2001				
00693 001055 1	TRLR	41242 WHITMER DR	5/8	BADG	19616968	16550	10.0	10.0	100.00%	7/19/2001				
00693 001057 1	TRLR	41228 WHITMER DR	5/8	BADG	30223646	17150	10.0	10.0	100.00%	7/19/2001				
00693 001004 1	TRLR	6456 PRESIDENTIAL CIR	5/8	KENT	90004134	739260	10.0	10.0	100.00%	3/9/2001	BADG	32206580	0	4/18/2002
00693 001229 1	TRLR	6009 TWILIGHT DR	5/8	KENT	90004163	700010	10.0	10.0	100.00%	5/25/2001	BADG	32371401	0	4/18/2002
00693 001226 1	TRLR	6025 TWILIGHT DR	5/8	KENT	90004133	753420	10.0	10.1	101.00%	5/25/2001	BADG	32371402	0	4/18/2002

LABRADOR UTILITIES, INC.
DOCKET NO. 030443-WS

METER CHANGE-OUT GUIDELINES

RANGE OF RESULTS - 95% - 101.5%
CHANGE OUT IF LESS THAN 9.5 OR 10.2 OR GREATER

OF METERS OUTSIDE PSC LIMITS

SLOW METERS	19
FAST METERS	126
TOTAL TESTED	800

RESPONSE TO PAA ACTION REQUEST - ISSUE #1 - METER FLOW TEST RESULTS

ACCOUNT NUMB	TYPE	SERVICE ADDRESS	SIZE	MAKE	SERIAL #	METER READ	VOLUME IN GALLONS		RESULTS		MAKE	NEW SERIAL #	NEW METER READ	DATE CHANGED OUT
							PTM TESTER	CUSTOMER METER	% OF ACCURACY	DATE TESTED				
00693 001312 2	TRLR	6082 FOREST LAKE DR	5/8	KENT	90004128	886730	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	32371422	0	4/17/2002
00693 001265 1	TRLR	6034 FOREST LAKE DR	5/8	KENT	90004129	435210	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	32206599	0	4/16/2002
00693 001249 1	TRLR	6018 FOREST LAKE DR	5/8	KENT	90004143	514550	10.0	9.9	99.00%	6/22/2001	BADG	32371436	0	4/17/2002
00693 001244 1	TRLR	6014 FOREST LAKE DR	5/8	KENT	90004145	400750	10.0	10.0	100.00%	6/22/2001	BADG	32371435	0	4/17/2002
00693 001225 1	TRLR	6031 TWILIGHT DR	5/8	KENT	90004152	1549650	5.0	5.0	100.00%	9/14/2000	BADG	33112108	0	4/17/2002
00693 001224 2	TRLR	6035 TWILIGHT DR	5/8	KENT	90004151	802760	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33112080	0	4/17/2002
00693 001223 1	TRLR	6041 TWILIGHT DR	5/8	KENT	90004150	280510	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	32371397	0	4/18/2002
00693 001222 2	TRLR	6047 TWILIGHT DR	5/8	KENT	90004153	661230	10.0	11.5	115.00%	6/22/2001	BADG		10	6/22/2001
00693 001235 2	TRLR	6005 FOREST LAKE DR	5/8	KENT	90004154	595960	5.0	5.0	100.00%	9/13/2000	BADG	32206649	0	4/16/2002
00693 001242 1	TRLR	6009 FOREST LAKE DR	5/8	KENT	90004156	668010	10.0	10.0	100.00%	6/27/2001	BADG	32206651	0	4/16/2002
00693 001243 1	TRLR	6013 FOREST LAKE DR	5/8	KENT	90004144	1224720	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	32206648	0	4/16/2002
00693 001250 1	TRLR	6017 FOREST LAKE DR	5/8	KENT	90004159	633210	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	32206653	0	4/16/2002
00693 001251 1	TRLR	6021 FOREST LAKE DR	5/8	KENT	90004155	219250	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	32371437	0	4/16/2002
00693 001258 1	TRLR	6025 FOREST LAKE DR	5/8	KENT	90004157	434680	10.0	10.1	101.00%	6/27/2001	BADG	32371434	0	4/16/2002
00693 001259 1	TRLR	6029 FOREST LAKE DR	5/8	KENT	990004160	476230	10.0	10.1	101.00%	6/27/2001	BADG	32371390	0	4/16/2002
00693 001266 3	TRLR	6033 FOREST LAKE DR	5/8	KENT	90004150	319820	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	32206735	0	4/16/2002
00693 001267 1	TRLR	6037 FOREST LAKE DR	5/8	KENT	90004147	850240	10.0	10.1	101.00%	6/27/2001	BADG	32371438	0	4/17/2002
00693 001275 2	TRLR	6047 FOREST LAKE DR	5/8	KENT	90004146	225850	10.0	10.0	100.00%	6/27/2001	BADG	32371433	0	4/17/2002
00693 001283 1	TRLR	6057 FOREST LAKE DR	5/8	KENT	90004125	1471920	10.0	9.8	98.00%	6/27/2001	BADG	33112079	0	4/17/2002
00693 001291 1	TRLR	6061 FOREST LAKE DR	5/8	KENT	90004148	372670	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33112107	0	4/17/2002
00693 001318 1	TRLR	6113 FOREST LAKE DR	5/8	KENT	90004127	742600	10.0	10.2	102.00%	6/27/2001	BADG	32206611	10	6/28/2001
00693 001183 2	TRLR	6102 SPRING LAKE CIR	5/8	KENT	90004168	670880	10.0	10.0	100.00%	6/29/2001	BADG	32206740	0	4/16/2002
00693 001180 1	TRLR	6080 SPRING LAKE CIR	5/8	KENT	90004164	506380	10.0	10.4	104.00%	11/15/2001	BADG	32206611	10	6/28/2001
00693 001179 1	TRLR	6074 SPRING LAKE CIR	5/8	KENT	90004141	354230	10.0	10.2	102.00%	11/15/2001	BADG	32206739	0	4/16/2002
00693 001176 2	TRLR	6068 SPRING LAKE CIR	5/8	KENT	90004140	1201730	10.0	10.0	100.00%	11/13/2001	BADG	32206532	0	11/15/2001

LABRADOR UTILITIES, INC.
DOCKET NO. 030443-WS

METER CHANGE-OUT GUIDELINES

RANGE OF RESULTS - 95% - 101.5%

CHANGE OUT IF LESS THAN 9.5 OR 10.2 OR GREATER

OF METERS OUTSIDE PSC LIMITS

SLOW METERS 19

FAST METERS 126

TOTAL TESTED 800

RESPONSE TO PAA ACTION REQUEST - ISSUE #1 - METER FLOW TEST RESULTS

ACCOUNT NUMB	TYPE	SERVICE ADDRESS	SIZE	MAKE	SERIAL #	METER READ	VOLUME IN GALLONS		RESULTS				NEW METER READ	DATE CHANGED OUT
							PTM TESTER	CUSTOMER METER	% OF ACCURACY	DATE TESTED	MAKE	NEW SERIAL #		
00693 001175 1	TRLR	6062 SPRING LAKE CIR	5/8	KENT	90004131	829960	5.0	5.0	100.00%	9/14/2000	BADG	32206739	0	4/16/2002
00693 001172 1	TRLR	6056 SPRING LAKE CIR	5/8	KENT	90004132	1294100	10.0	10.0	100.00%	11/13/2001	BADG	32206758	0	11/15/2001
00693 001168 1	TRLR	6044 SPRING LAKE CIR	5/8	KENT	90004122	254290	10.0	10.1	101.00%	11/13/2001	BADG	32206738	0	4/16/2002
00693 001221 1	TRLR	6053 TWILIGHT DR	5/8	KENT	90004119	288420	10.0	10.0	100.00%	7/12/2001	BADG	32206515	0	11/13/2001
00693 001174 1	TRLR	6061 SPRING LAKE CIR	5/8	KENT	90004162	999270	10.0	10.1	101.00%	11/13/2001	BADG	32206510	0	11/13/2001
00693 001185 1	TRLR	6115 SPRING LAKE CIR	5/8	KENT	90004130	905060	10.0	10.1	101.00%	7/12/2001	BADG	32206738	0	4/16/2002
00693 001192 1	TRLR	6143 SPRING LAKE CIR	5/8	KENT	90004142	373460	10.0	10.1	101.00%	11/13/2001	BADG	32206756	0	11/13/2001
00693 001197 1	TRLR	6155 SPRING LAKE CIR	5/8	KENT	90004138	860800	10.0	10.0	100.00%	7/12/2001	BADG	32206650	0	4/16/2002
00693 001198 1	TRLR	6161 SPRING LAKE CIR	5/8	KENT	90004137	432740	10.0	10.1	101.00%	11/13/2001	BADG	32206760	0	11/13/2001
00693 001201 1	TRLR	6167 SPRING LAKE CIR	5/8	KENT	90004165	763180	10.0	10.2	102.00%	11/13/2001	BADG	32206652	0	4/16/2002
00693 001202 1	TRLR	6201 SPRING LAKE CIR	5/8	KENT	90004166	82820	10.0	10.1	101.00%	11/13/2001	BADG	32206761	0	11/13/2001
00693 001205 1	TRLR	6207 SPRING LAKE CIR	5/8	KENT	90004161	861320	10.0	9.8	98.00%	7/12/2001	BADG	32206652	0	4/16/2002
00693 001209 1	TRLR	6219 SPRING LAKE CIR	5/8	KENT	90004121	487180	5.0	5.0	100.00%	9/13/2000	BADG	32206732	0	4/10/2002
00693 001210 2	TRLR	6225 SPRING LAKE CIR	5/8	KENT	90004124	649340	10.0	10.0	100.00%	7/12/2001	BADG	32206737	0	4/10/2002
00693 001214 1	TRLR	6237 SPRING LAKE CIR	5/8	KENT	90084120	964390	10.0	9.8	98.00%	7/12/2001	BADG	32206734	0	4/10/2002
00693 001108 1	TRLR	6308 TWILIGHT DR	5/8	KENT	90004139	532000	10.0	10.0	100.00%	7/19/2001	BADG	32206734	0	4/10/2002
00693 001121 1	TRLR	41050 BREAM CIR	5/8	KENT	90004167	924030	10.0	10.1	101.00%	7/19/2001	BADG	32206733	0	4/10/2002
00693 001145 1	TRLR	6125 TWILIGHT DR	5/8	KENT	90004149	448470	10.0	10.1	101.00%	11/14/2001	BADG	32206585	0	12/20/2001
00693 001143 2	TRLR	6137 TWILIGHT DR	5/8	KENT	90004122	324770	10.0	10.1	101.00%	7/19/2001	BADG	32206733	0	4/10/2002
00693 001127 1	TRLR	41023 BREAM CIR	5/8	KENT	90004136	1053960	10.0	10.0	100.00%	7/19/2001	BADG	32206641	0	11/14/2001
00693 001107 1	TRLR	6395 SPRING LAKE CIR	5/8	KENT	90004135	691830	10.0	10.1	101.00%	11/14/2001	BADG	32371424	0	4/9/2002
00693 001012 1	TRLR	6429 FOREST LAKE DR	5/8	MAST	1059516	840310	10.0	0.7	7.00%	3/9/2001	BADG	30223640	10	4/9/2002
00693 001015 1	TRLR	6424 PRESIDENTIAL CIR	5/8	MAST	1042967	473450	9.5	10.0	105.26%	2/3/2001	BADG	30223635	10	2/6/2001
00693 001017 1	TRLR	6408 PRESIDENTIAL CIR	5/8	MAST	1046076	785340	9.8	10.0	102.04%	2/3/2001	BADG	30223651	10	2/15/2001
00693 001023 1	TRLR	41243 WHITMER DR	5/8	MAST	1042774	699490	9.7	10.0	103.09%	2/15/2001	BADG	30223639	10	2/15/2001

LABRADOR UTILITIES, INC.
DOCKET NO. 030443-WS

METER CHANGE-OUT GUIDELINES

RANGE OF RESULTS - 95% - 101.5%

CHANGE OUT IF LESS THAN 9.5 OR 10.2 OR GREATER

OF METERS OUTSIDE PSC LIMITS

SLOW METERS	19
FAST METERS	126
TOTAL TESTED	800

RESPONSE TO PAA ACTION REQUEST - ISSUE #1 - METER FLOW TEST RESULTS

ACCOUNT NUMB	TYPE	SERVICE ADDRESS	SIZE	MAKE	SERIAL #	METER READ	VOLUME IN GALLONS		RESULTS		MAKE	NEW SERIAL #	NEW METER READ	DATE CHANGED OUT
							PTM TESTER	CUSTOMER METER	% OF ACCURACY	DATE TESTED				
00693 001024 1	TRLR	41249 WHITMER DR	5/8	MAST	1042776	729990	10.0	0.1	1.00%	1/15/2001	BADG	19616967	10	2/1/2001
00693 001025 1	TRLR	41255 WHITMER DR	5/8	MAST	1059502	547540	10.0	10.1	101.00%	12/19/2001	BADG	32206744	10	12/19/2001
00693 001026 2	TRLR	41261 WHITMER DR	5/8	MAST	1053399	843560	10.0	10.1	101.00%	12/19/2001	BADG	32206746	10	12/19/2001
00693 001028 2	TRLR	41288 WHITMER DR	5/8	MAST	1053402	267420	10.0	9.5	95.00%	4/14/2001	BADG	32206770	10	4/14/2001
00693 001031 2	TRLR	41270 XENON WAY	5/8	MAST	1042785	760130	10.0	10.1	101.00%	8/29/2001	BADG	32206495	10	8/29/2001
00693 001032 2	TRLR	41266 XENON WAY	5/8	MAST	10459507	333830	10.0	10.5	105.00%	5/18/2001	BADG	32206730	10	5/18/2001
00693 001033 1	TRLR	41262 XENON WAY	5/8	MAST	1053397	1314810	10.0	11.1	111.00%	5/18/2001	BADG	32206731	10	5/18/2001
00693 001034 1	TRLR	41258 XENON WAY	5/8	MAST	19616992	18760	10.0	10.0	100.00%	5/18/2001	BADG	32371424	0	4/9/2002
00693 001047 1	TRLR	6343 PRESIDENTIAL CIR	5/8	MAST	1046071	538260	10.0	10.1	101.00%	11/14/2001	BADG	32206529	0	11/14/2001
00693 001069 1	TRLR	6359 PRESIDENTIAL CIR	5/8	MAST	1059512	622940	10.0	10.1	101.00%	9/20/2001	BADG	32371431	10	9/20/2001
00693 001070 2	TRLR	6365 PRESIDENTIAL CIR	5/8	MAST	1059511	320230	10.0	10.1	101.00%	9/20/2001	BADG	32206511	10	9/20/2001
00693 001071 2	TRLR	6371 PRESIDENTIAL CIR	5/8	MAST	1046074	389990	10.0	0.0	0.00%	6/14/2001	BADG	32206550	10	6/14/2001
00693 001073 1	TRLR	6415 PRESIDENTIAL CIR	5/8	MAST	1042739	961960	10.0	10.5	105.00%	6/14/2001	BADG	32206689	10	7/14/2001
00693 001081 1	TRLR	6364 FOREST LAKE DR	5/8	MAST	1042775	1103980	10.0	10.3	103.00%	6/14/2001	BADG	32206547	10	6/15/2001
00693 001082 3	TRLR	6358 FOREST LAKE DR	5/8	MAST	1042741	1234520	10.0	0.0	0.00%	11/14/2001	BADG	32206528	0	11/14/2001
00693 001085 1	TRLR	6352 FOREST LAKE DR	5/8	MAST	1059508	1119490	10.0	10.5	105.00%	6/14/2001	BADG	32206787	10	6/15/2001
00693 001086 1	TRLR	6346 FOREST LAKE DR	5/8	MAST	1042773	372410	10.0	0.0	0.00%	11/14/2001	BADG	32206780	0	11/14/2001
00693 001062 1	TRLR	6336 FOREST LAKE DR	5/8	MAST	1046077	557190	10.0	10.1	101.00%	6/14/2001	BADG	32206748	0	12/19/2001
00693 001038 1	TRLR	41222 XENON WAY	5/8	MAST	1042737	483570	10.0	10.1	101.00%	12/19/2001	BADG	32206747	0	12/19/2001
00693 001045 3	TRLR	6329 FOREST LAKE DR	5/8	MAST	1053393	1504550	10.0	10.5	105.00%	11/15/2001	BADG	32206576	0	11/15/2001
00693 001087 1	TRLR	6345 FOREST LAKE DR	5/8	MAST	32206516	184890	10.0	10.0	100.00%	6/28/2001	BADG	32206516	10	3/31/2001
00693 001084 3	TRLR	6351 FOREST LAKE DR	5/8	MAST	32206517	321440	10.0	10.0	100.00%	6/28/2001	BADG	32206517	10	3/31/2001
00693 001083 1	TRLR	6357 FOREST LAKE DR	5/8	MAST	1042779	1072430	10.0	10.4	104.00%	11/15/2001	BADG	32206574	0	11/15/2001
00693 001080 1	TRLR	6363 FOREST LAKE DR	5/8	MAST	1046069	495020	10.0	10.5	105.00%	11/15/2001	BADG	32206575	0	11/15/2001
00693 001076 1	TRLR	6407 FOREST LAKE DR	5/8	MAST	1053400	778140	10.0	10.5	105.00%	6/28/2001	BADG	32206588	10	6/29/2001

LABRADOR UTILITIES, INC.
DOCKET NO. 030443-WS

METER CHANGE-OUT GUIDELINES

RANGE OF RESULTS - 95% - 101.5%

CHANGE OUT IF LESS THAN 9.5 OR 10.2 OR GREATER

OF METERS OUTSIDE PSC LIMITS

SLOW METERS 19

FAST METERS 126

TOTAL TESTED 800

RESPONSE TO PAA ACTION REQUEST - ISSUE #1 - METER FLOW TEST RESULTS

ACCOUNT NUMB	TYPE	SERVICE ADDRESS	SIZE	MAKE	SERIAL #	METER READ	VOLUME IN GALLONS		RESULTS		MAKE	NEW SERIAL #	NEW METER READ	DATE CHANGED OUT
							PTM TESTER	CUSTOMER METER	% OF ACCURACY	DATE TESTED				
00693 001075 3	TRLR	6413 FOREST LAKE DR	5/8	MAST	1059526	1355910	10.0	10.5	105.00%	6/28/2001	BADG	32206592	10	6/29/2001
00693 001089 1	TRLR	6334 SPRING LAKE CIR	5/8	MAST	1046075	361140	10.0	10.3	103.00%	11/15/2001	BADG	32206573	0	11/15/2001
00693 001065 1	TRLR	6322 SPRING LAKE CIR	5/8	MAST	1059504	979070	5.0	5.0	100.00%	9/14/2000	BADG	32206504	0	7/26/2001
00693 001220 1	TRLR	6256 SPRING LAKE CIR	5/8	MAST	1059521	1303940	10.0	11.1	111.00%	6/29/2001	BADG	32206593	10	7/10/2001
00693 001217 1	TRLR	6244 SPRING LAKE CIR	5/8	MAST	1050267	1955220	10.0	10.4	104.00%	6/29/2001	BADG	32206590	10	6/30/2001
00693 001215 1	TRLR	6238 SPRING LAKE CIR	5/8	MAST	1059517	823430	10.0	10.3	103.00%	11/15/2001	BADG	32206572	0	11/15/2001
00693 001212 1	TRLR	6232 SPRING LAKE CIR	5/8	MAST	UNKNOWN	977020	10.0	10.4	104.00%	6/29/2001	BADG	32206591	10	7/10/2001
00693 001211 1	TRLR	6226 SPRING LAKE CIR	5/8	MAST	UNKNOWN	527820	10.0	10.5	105.00%	6/29/2001	BADG	32206581	10	7/10/2001
00693 001208 2	TRLR	6220 SPRING LAKE CIR	5/8	MAST	1050270	536150	10.0	9.7	97.00%	7/10/2001	BADG	32206749	0	12/19/2001
00693 001207 1	TRLR	6214 SPRING LAKE CIR	5/8	MAST	1050271	750090	10.0	9.7	97.00%	7/10/2001	BADG	32206582	0	12/19/2001
00693 001191 1	TRLR	6132 SPRING LAKE CIR	5/8	MAST	1050204	499800	10.0	10.3	103.00%	11/15/2001	BADG	32206571	0	11/15/2001
00693 001190 1	TRLR	6126 SPRING LAKE CIR	5/8	MAST	1050273	466410	10.0	10.2	102.00%	11/15/2001	BADG	32206570	0	11/15/2001
00693 001167 1	TRLR	6038 SPRING LAKE CIR	5/8	MAST	1050222	218020	10.0	10.2	102.00%	11/13/2001	BADG	32206677	0	11/9/2001
00693 001164 1	TRLR	6032 SPRING LAKE CIR	5/8	MAST	1050265	317080	10.0	10.3	103.00%	6/29/2001	BADG	32206676	0	11/9/2001
00693 001163 1	TRLR	6026 SPRING LAKE CIR	5/8	MAST	1050258	809000	10.0	0.0	0.00%	7/12/2001	BADG	32206684	0	7/13/2001
00693 001160 1	TRLR	6020 SPRING LAKE CIR	5/8	MAST	1050201	80	10.0	10.0	100.00%	11/9/2001	BADG	32206675	0	11/9/2001
00693 001156 1	TRLR	6008 SPRING LAKE CIR	5/8	MAST	1050199	341000	10.0	10.1	101.00%	11/9/2001	BADG	32206634	0	11/9/2001
00693 001149 1	TRLR	6101 TWILIGHT DR	5/8	MAST	50277	486840	10.0	10.3	103.00%	7/12/2001	BADG	32206688	0	7/14/2001
00693 001148 1	TRLR	6107 TWILIGHT DR	5/8	MAST	1050278	718750	10.0	10.1	101.00%	11/9/2001	BADG	32206638	0	11/9/2001
00693 001154 1	TRLR	6001 SPRING LAKE CIR	5/8	MAST	1050272	430970	10.0	10.1	101.00%	11/9/2001	BADG	32206672	0	11/9/2001
00693 001157 2	TRLR	6007 SPRING LAKE CIR	5/8	MAST	1050206	420240	10.0	10.1	101.00%	11/9/2001	BADG	32206673	0	11/9/2001
00693 001158 2	TRLR	6013 SPRING LAKE CIR	5/8	MAST	1059523	484490	10.0	10.3	103.00%	7/12/2001	BADG	32206685	0	7/13/2001
00693 001161 2	TRLR	6019 SPRING LAKE CIR	5/8	MAST	1050224	632200	10.0	10.1	101.00%	7/12/2001	BADG	32206583	0	12/20/2001
00693 001169 1	TRLR	6043 SPRING LAKE CIR	5/8	MAST	UNKNOWN	381530	10.0	10.1	101.00%	11/18/2001	BADG	32206512	0	11/18/2001
00693 001170 1	TRLR	6049 SPRING LAKE CIR	5/8	MAST	1050276	435130	10.0	10.1	101.00%	11/13/2001	BADG	32206513	0	11/13/2001

LABRADOR UTILITIES, INC.
DOCKET NO. 030443-WS

METER CHANGE-OUT GUIDELINES

RANGE OF RESULTS - 95% - 101.5%

CHANGE OUT IF LESS THAN 9.5 OR 10.2 OR GREATER

OF METERS OUTSIDE PSC LIMITS

SLOW METERS	19
FAST METERS	126
TOTAL TESTED	800

RESPONSE TO PAA ACTION REQUEST - ISSUE #1 - METER FLOW TEST RESULTS

ACCOUNT NUMB	TYP E	SERVICE ADDRESS	SIZ E	MA KE	SERIAL #	METER READ	VOLUME IN GALLONS		RESULTS		MA KE	NEW SERIAL #	NEW METER READ	DATE CHANGED OUT
							PTM TESTER	CUSTOMER METER	% OF ACCURACY	DATE TESTED				
00693 001173 2	TRLR	6055 SPRING LAKE CIR	5/8	MAST	1059565	740620	10.0	10.1	101.00%	11/13/2001	BADG	32206514	0	11/13/2001
00693 001182 2	TRLR	6107 SPRING LAKE CIR	5/8	MAST	1050223	650890	10.0	10.1	101.00%	11/13/2001	BADG	32206757	0	11/13/2001
00693 001189 1	TRLR	6133 SPRING LAKE CIR	5/8	MAST	1050203	631450	10.0	10.1	101.00%	11/13/2001	BADG	32206159	0	11/13/2001
00693 001213 1	TRLR	6231 SPRING LAKE CIR	5/8	MAST	1050264	990990	10.0	0.0	0.00%	7/12/2001	BADG	32206687	0	7/14/2001
00693 001216 1	TRLR	6243 SPRING LAKE CIR	5/8	MAST	1050267	1136490	10.0	5.0	50.00%	7/12/2001	BADG	32206740	0	11/7/2001
00693 001219 1	TRLR	6253 SPRING LAKE CIR	5/8	MAST	1050260	524350	10.0	10.3	103.00%	7/12/2001	BADG	32206686	0	7/14/2001
00693 001041 2	TRLR	6255 SPRING LAKE CIR	5/8	MAST	1050210	471560	10.0	11.0	110.00%	7/12/2001	BADG	32206558	0	7/17/2001
00693 001043 1	TRLR	6309 SPRING LAKE CIR	5/8	MAST	1042733	643040	10.0	10.5	105.00%	7/12/2001	BADG	32206559	0	7/17/2001
00693 001093 2	TRLR	6313 SPRING LAKE CIR	5/8	MAST	1053403	1072500	10.0	10.2	102.00%	11/14/2001	BADG	32206639	0	11/14/2001
00693 001096 1	TRLR	6331 SPRING LAKE CIR	5/8	MAST	1046073	578470	10.0	10.9	109.00%	7/12/2001	BADG	32206562	0	7/17/2001
00693 001098 1	TRLR	6343 SPRING LAKE CIR	5/8	MAST	1046078	1098720	10.0	10.1	101.00%	11/14/2001	BADG	32206783	0	11/14/2001
00693 001103 2	TRLR	6371 SPRING LAKE CIR	5/8	MAST	1053394	1453280	10.0	10.1	101.00%	11/9/2001	BADG	32206705	0	11/9/2001
00693 001106 1	TRLR	6389 SPRING LAKE CIR	5/8	MAST	1053395	572350	10.0	10.2	102.00%	7/19/2001	BADG	32206613	10	7/25/2001
00693 001114 1	TRLR	6246 TWILIGHT DR	5/8	MAST	1059506	1007400	10.0	10.2	102.00%	7/19/2001	BADG	32206616	10	7/25/2001
00693 001115 2	TRLR	41086 BREAM CIR	5/8	MAST	1050279	346310	10.0	10.3	103.00%	7/19/2001	BADG	32206682	0	7/25/2001
00693 001116 1	TRLR	41080 BREAM CIR	5/8	MAST	1059503	414860	10.0	10.1	101.00%	7/25/2001	BADG	32206681	0	7/25/2001
00693 001118 1	TRLR	41068 BREAM CIR	5/8	MAST	1050269	524790	10.0	10.3	103.00%	7/19/2001	BADG	32206674	0	7/25/2001
00693 001119 1	TRLR	41062 BREAM CIR	5/8	MAST	1059566	775660	10.0	10.1	101.00%	7/25/2001	BADG	32206683	0	7/25/2001
00693 001120 1	TRLR	41056 BREAM CIR	5/8	MAST	1059567	971580	10.0	10.2	102.00%	7/19/2001	BADG	32206687	0	7/25/2001
00693 001123 3	TRLR	41038 BREAM CIR	5/8	MAST	1059534	449380	10.0	10.1	101.00%	7/27/2001	BADG	32206507	0	7/27/2001
00693 001126 2	TRLR	41020 BREAM CIR	5/8	MAST	1059520	373880	10.0	10.3	103.00%	7/19/2001	BADG	32206617	10	7/27/2001
00693 001150 1	TRLR	6132 TWILIGHT DR	5/8	MAST	159515	392520	10.0	10.1	101.00%	7/27/2001	BADG	32206508	0	7/27/2001
00693 001151 1	TRLR	6126 TWILIGHT DR	5/8	MAST	1059519	459720	10.0	10.1	101.00%	7/27/2001	BADG	32206506	0	7/27/2001
00693 001146 1	TRLR	6119 TWILIGHT DR	5/8	MAST	1050209	372460	10.0	10.1	101.00%	8/10/2001	BADG	32206509	0	8/10/2001
00693 001144 1	TRLR	6131 TWILIGHT DR	5/8	MAST	1059514	302680	10.0	10.1	101.00%	8/10/2001	BADG	32206505	0	8/10/2001

LABRADOR UTILITIES, INC.
DOCKET NO. 030443-WS

METER CHANGE-OUT GUIDELINES

RANGE OF RESULTS - 95% - 101.5%
CHANGE OUT IF LESS THAN 9.5 OR 10.2 OR GREATER

OF METERS OUTSIDE PSC LIMITS

SLOW METERS	19
FAST METERS	126
TOTAL TESTED	800

RESPONSE TO PAA ACTION REQUEST - ISSUE #1 - METER FLOW TEST RESULTS

ACCOUNT NUMB	TYPE	SERVICE ADDRESS	SIZE	MAKE	SERIAL #	METER READ	VOLUME IN GALLONS		RESULTS		MAKE	NEW SERIAL #	NEW METER READ	DATE CHANGED OUT
							PTM TESTER	CUSTOMER METER	% OF ACCURACY	DATE TESTED				
00693 001140 1	TRLR	6155 TWILIGHT DR	5/8	MAST	1059522	908880	10.0	10.5	105.00%	7/19/2001	BADG	32206693	0	8/10/2001
00693 001139 1	TRLR	6201 TWILIGHT DR	5/8	MAST	1059513	1515030	NOT TESTED/NO HOME ON LOT				BADG	32206694	0	8/10/2001
00693 001137 2	TRLR	6211 TWILIGHT DR	5/8	MAST	1050202	422280	NOT TESTED/HOUSE EMPTY/OFF AT HOUSE				BADG	32206690	0	8/14/2001
00693 001128 1	TRLR	41037 BREAM CIR	5/8	MAST	1050232	352630	NOT TESTED/HOUSE EMPTY/OFF AT HOUSE				BADG	32206534	0	8/15/2001
00693 001130 1	TRLR	41067 BREAM CIR	5/8	MAST	1059485	2066170	10.0	0.0	0.00%	7/19/2001	BADG	32206535	0	8/15/2001
00693 001131 2	TRLR	41083 BREAM CIR	5/8	MAST	1050228	585500	NOT TESTED/HOUSE EMPTY/OFF AT HOUSE				BADG	32206536	0	8/15/2001
00693 001136 1	TRLR	6217 TWILIGHT DR	5/8	MAST	1050229	365790	NOT TESTED/HOUSE EMPTY/OFF AT HOUSE				BADG	32206633	0	8/14/2001
00693 001135 1	TRLR	6223 TWILIGHT DR	5/8	MAST	1050266	518220	10.0	10.3	103.00%	7/19/2001	BADG	32206692	0	8/14/2001
00693 001134 1	TRLR	6229 TWILIGHT DR	5/8	MAST	1050362	410980	10.0	10.4	104.00%	7/19/2001	BADG	32206634	0	8/14/2001
00693 001449 1	TRLR	5904 UTOPIA DR	5/8	BADG	92114034	404200					BADG	30223671	10	3/17/2001
00693 001133 1	TRLR	6233 TWILIGHT DR	5/8	MAST	1050237	384510	NOT TESTED/HOUSE EMPTY/OFF AT HOUSE				BADG	32206635	0	8/14/2001
00693 001132 1	TRLR	6239 TWILIGHT DR	5/8	MAST	1050281	228620	5.0	5.0	100.00%	9/14/2000	BADG	32206539	0	8/16/2001
00693 001113 1	TRLR	6245 TWILIGHT DR	5/8	MAST	1050230	611570	NOT TESTED/HOUSE EMPTY/OFF AT HOUSE				BADG	32206538	0	8/16/2001
00693 001112 2	TRLR	6249 TWILIGHT DR	5/8	MAST	1050223	778130	NOT TESTED/HOUSE EMPTY/OFF AT HOUSE				BADG	32206630	0	8/15/2001
00693 001111 1	TRLR	6255 TWILIGHT DR	5/8	MAST	1050268	993740	10.0	10.4	104.00%	7/19/2001	BADG	32206631	0	8/15/2001
00693 001059 1	TRLR	41216 WHITMER DR	5/8	MAST	1042778	552870	10.0	10.1	101.00%	8/29/2001	BADG	32206493	0	8/29/2001
00693 001060 1	TRLR	6352 PRESIDENTIAL CIR	5/8	MAST	1059509	325910	10.0	10.1	101.00%	8/29/2001	BADG	32206497	0	8/29/2001
00693 001049 1	TRLR	41253 XENON WAY	5/8	MAST	1042764	540070	10.0	10.4	104.00%	7/19/2001	BADG	32206632	0	8/15/2001
00693 001050 1	TRLR	41259 XENON WAY	5/8	MAST	1053392	784080	10.0	7.5	75.00%	7/19/2001	BADG	32206561	10	7/19/2001
00693 001052 1	TRLR	41271 XENON WAY	5/8	MAST	1042368	343590	NOT TESTED/HOUSE EMPTY/OFF AT HOUSE				BADG	32206537	0	8/16/2001
00693 001056 1	TRLR	41232 WHITMER DR	5/8	MAST	105950	519550	10.0	10.1	101.00%	11/14/2001	BADG	32206530	0	11/14/2001
00693 001058 1	TRLR	41222 WHITMER DR	5/8	MAST	1046072	616240	10.0	10.1	101.00%	11/14/2001	BADG	32206531	0	11/15/2001
00693 001001 1	TRLR	6462 PRESIDENTIAL CIR	5/8	NEPT	UNKNOWN	110400	10.0	9.8	98.00%	3/9/2001				
00693 001002 2	TRLR	6460 PRESIDENTIAL CIR	5/8	NEPT	33862266	167320	10.0	9.6	96.00%	3/9/2001				
00693 001003 1	TRLR	6458 PRESIDENTIAL CIR	5/8	NEPT	33379186	214340	10.0	9.6	96.00%	3/9/2001				

LABRADOR UTILITIES, INC.
DOCKET NO. 030443-WS

METER CHANGE-OUT GUIDELINES
RANGE OF RESULTS - 95% - 101.5%
CHANGE OUT IF LESS THAN 9.5 OR 10.2 OR GREATER

OF METERS OUTSIDE PSC LIMITS

SLOW METERS	19
FAST METERS	126
TOTAL TESTED	800

RESPONSE TO PAA ACTION REQUEST - ISSUE #1 - METER FLOW TEST RESULTS

ACCOUNT NUMB	TYPE	SERVICE ADDRESS	SIZE	MAKE	SERIAL #	METER READ	VOLUME IN GALLONS		RESULTS		MAKE	NEW SERIAL #	NEW METER READ	DATE CHANGED OUT
							PTM TESTER	CUSTOMER METER	% OF ACCURACY	DATE TESTED				
00693 001006 1	TRLR	6452 PRESIDENTIAL CIR	5/8	NEPT	46466657	99840	10.0	10.0	100.00%	3/9/2001				
00693 001007 1	TRLR	6450 PRESIDENTIAL CIR	5/8	NEPT	46466690	212200	10.0	9.8	98.00%	3/9/2001				
00693 001008 1	TRLR	6448 PRESIDENTIAL CIR	5/8	NEPT	32884249	443350	10.0	10.0	100.00%	3/9/2001				
00693 001009 2	TRLR	6446 PRESIDENTIAL CIR	5/8	NEPT	46466655	340810	10.0	9.9	99.00%	3/9/2001				
00693 001010 1	TRLR	6444 PRESIDENTIAL CIR	5/8	NEPT	46466644	178510	10.0	9.9	99.00%	3/9/2001				
00693 001011 1	TRLR	6442 PRESIDENTIAL CIR	5/8	NEPT	46466673	108850	10.0	9.9	99.00%	3/9/2001				
00693 001013 1	TRLR	6434 PRESIDENTIAL CIR	5/8	NEPT	39605831	222420	10.0	10.0	100.00%	3/9/2001				
00693 001014 1	TRLR	6428 PRESIDENTIAL CIR	5/8	NEPT	39605800	269870	10.0	9.8	98.00%	3/9/2001				
00693 001016 1	TRLR	6416 PRESIDENTIAL CIR	5/8	NEPT	40002850	173760	10.0	9.6	96.00%	3/9/2001				
00693 001018 1	TRLR	41215 WHITMER DR	5/8	NEPT	40002584	132130	10.0	9.8	98.00%	3/10/2001				
00693 001844 2	TRLR	41313 WHITMER DR	5/8	NEPT	39605828	270420	10.0	9.9	99.00%	3/10/2001				
00693 001846 2	TRLR	41323 WHITMER DR	5/8	NEPT	74377346	48210	10.0	9.9	99.00%	3/10/2001				
00693 001851 2	TRLR	6406 UTOPIA DR	5/8	NEPT	41960500	82770	10.0	10.6	106.00%	3/10/2001	BADG	30223643	10	3/10/2001
00693 001855 1	TRLR	6332 UTOPIA DR	5/8	NEPT	41853429	286870	10.0	13.7	137.00%	3/13/2001	BADG	30223641	10	3/14/2001
00693 001867 1	TRLR	6234 UTOPIA DR	5/8	NEPT	41960472	150370	10.0	9.8	98.00%	3/13/2001				
00693 001875 1	TRLR	6162 UTOPIA DR	5/8	NEPT	74377023	25250	10.0	9.8	98.00%	3/14/2001				
00693 001899 0	MISC	UTOPIA DR	2	NEPT	60278179	212600	WWTP METER, INSTALLED 2004							
00693 001752 1	TRLR	5633 VIAU WAY	5/8	NEPT	74377011	1449860	10.0	9.9	99.00%	9/13/2000				
00693 001748 1	TRLR	5637 VIAU WAY	5/8	NEPT	38643160	190890	10.0	11.2	112.00%	3/14/2001	BADG	30223698	10	3/15/2001
00693 001744 1	TRLR	5641 VIAU WAY	5/8	NEPT	UNKNOWN	311180	10.0	10.1	101.00%	3/14/2001				
00693 001741 1	TRLR	5645 VIAU WAY	5/8	NEPT	39379136	523460	10.0	10.1	101.00%	4/20/2002				
00693 001739 1	TRLR	5647 VIAU WAY	5/8	NEPT	38955502	664110	10.0	10.0	100.00%	3/14/2001				
00693 001737 1	TRLR	5649 VIAU WAY	5/8	NEPT	38955579	253840	10.0	10.0	100.00%	3/14/2001				
00693 001734 2	TRLR	5701 VIAU WAY	5/8	NEPT	39379108	276610	10.0	10.0	100.00%	3/14/2001				
00693 001731 1	TRLR	5703 VIAU WAY	5/8	NEPT	74377029	1120	10.0	10.0	100.00%	12/19/2001				

LABRADOR UTILITIES, INC.
DOCKET NO. 030443-WS

METER CHANGE-OUT GUIDELINES

RANGE OF RESULTS - 95% - 101.5%
CHANGE OUT IF LESS THAN 9.5 OR 10.2 OR GREATER

OF METERS OUTSIDE PSC LIMITS

SLOW METERS	19
FAST METERS	126
TOTAL TESTED	800

RESPONSE TO PAA ACTION REQUEST - ISSUE #1 - METER FLOW TEST RESULTS

ACCOUNT NUMB	TYPE	SERVICE ADDRESS	SIZE	MAKE	SERIAL #	METER READ	VOLUME IN GALLONS		RESULTS				NEW SERIAL #	NEW METER READ	DATE CHANGED OUT
							PTM TESTER	CUSTOMER METER	% OF ACCURACY	DATE TESTED	MAKE				
00693 001727 2	TRLR	5707 VIAU WAY	5/8	NEPT	38955620	706690	10.0	9.9	99.00%	3/14/2001					
00693 001726 2	TRLR	5709 VIAU WAY	5/8	NEPT	39605154	210190	10.0	10.0	100.00%	3/14/2001					
00693 001723 1	TRLR	5711 VIAU WAY	5/8	NEPT	38955625	230250	10.0	9.8	98.00%	3/14/2001					
00693 001722 3	TRLR	5713 VIAU WAY	5/8	NEPT	39605160	134280	10.0	11.2	112.00%	3/14/2001	BADG	30223687	10	3/17/2001	
00693 001719 2	TRLR	5715 VIAU WAY	5/8	NEPT	38955634	168090	10.0	9.9	99.00%	3/16/2001					
00693 001718 2	TRLR	5717 VIAU WAY	5/8	NEPT	38955601	536390	10.0	13.7	137.00%	3/21/2001	BADG	30223675	10	3/21/2001	
00693 001716 3	TRLR	5719 VIAU WAY	5/8	NEPT	39370052	664020	10.0	10.0	100.00%	3/21/2001					
00693 001713 2	TRLR	5721 VIAU WAY	5/8	NEPT	39379104	628900	10.0	10.0	100.00%	3/21/2001					
00693 001712 1	TRLR	5723 VIAU WAY	5/8	NEPT	38955626	541180	10.0	10.0	100.00%	3/21/2001					
00693 001707 1	TRLR	5729 VIAU WAY	5/8	NEPT	38955632	1075490	10.0	10.0	100.00%	3/21/2001					
00693 001693 1	TRLR	5741 VIAU WAY	5/8	NEPT	39379060	596520	10.0	9.9	99.00%	3/21/2001					
00693 001688 2	TRLR	5747 VIAU WAY	5/8	NEPT	39379053	253450	10.0	10.0	100.00%	3/21/2001					
00693 001686 2	TRLR	5750 VIAU WAY	5/8	NEPT	39379107	120230	10.0	10.0	100.00%	3/22/2001					
00693 001687 1	TRLR	5748 VIAU WAY	5/8	NEPT	39605137	670990	10.0	9.9	99.00%	3/22/2001					
00693 001690 2	TRLR	5746 VIAU WAY	5/8	NEPT	39605826	188740	10.0	10.0	100.00%	3/22/2001					
00693 001691 1	TRLR	5744 VIAU WAY	5/8	NEPT	32829906	40	NOT TESTED/VACANT LOT								
00693 001694 1	TRLR	5742 VIAU WAY	5/8	NEPT	37797403	40	NOT TESTED/VACANT LOT								
00693 001695 1	TRLR	5740 VIAU WAY	5/8	NEPT	39690023	60	NOT TESTED/VACANT LOT								
00693 001697 1	TRLR	5738 VIAU WAY	5/8	NEPT	32829829	30	NOT TESTED/VACANT LOT								
00693 001699 1	TRLR	5736 VIAU WAY	5/8	NEPT	34594308	30	NOT TESTED/VACANT LOT								
00693 001701 1	TRLR	5734 VIAU WAY	5/8	NEPT	34594308	30	NOT TESTED/VACANT LOT								
00693 001704 1	TRLR	5732 VIAU WAY	5/8	NEPT	40177401	30	NOT TESTED/VACANT LOT								
00693 001705 1	TRLR	5730 VIAU WAY	5/8	NEPT	46186497	40	NOT TESTED/VACANT LOT								
00693 001706 1	TRLR	5728 VIAU WAY	5/8	NEPT	40466697	40	10.0	10.1	101.00%	10/18/2001	BADG	32206614	0	10/18/2001	
00693 001709 1	TRLR	5726 VIAU WAY	5/8	NEPT	46466655	40	NOT TESTED/VACANT LOT								

LABRADOR UTILITIES, INC.
DOCKET NO. 030443-WS

METER CHANGE-OUT GUIDELINES
RANGE OF RESULTS - 95% - 101.5%
CHANGE OUT IF LESS THAN 9.5 OR 10.2 OR GREATER

OF METERS OUTSIDE PSC LIMITS

SLOW METERS	19
FAST METERS	126
TOTAL TESTED	800

RESPONSE TO PAA ACTION REQUEST - ISSUE #1 - METER FLOW TEST RESULTS

ACCOUNT NUMB	TYPE	SERVICE ADDRESS	SIZE	MAKE	SERIAL #	METER READ	VOLUME IN GALLONS		RESULTS		MAKE	NEW SERIAL #	NEW METER READ	DATE CHANGED OUT
							PTM TESTER	CUSTOMER METER	% OF ACCURACY	DATE TESTED				
00693 001710 1	TRLR	5724 VIAU WAY	5/8	NEPT	46466645	110	NOT TESTED/VACANT LOT							
00693 001714 1	TRLR	5722 VIAU WAY	5/8	NEPT	39605824	137240	10.0	9.9	99.00%	3/22/2001				
00693 001717 1	TRLR	5718 VIAU WAY	5/8	NEPT	38955584	226880	10.0	9.9	99.00%	3/22/2001				
00693 001720 1	TRLR	5716 VIAU WAY	5/8	NEPT	38955582	216160	10.0	9.9	99.00%	3/22/2001				
00693 001721 2	TRLR	5714 VIAU WAY	5/8	NEPT	38955585	257930	NOT TESTED/VACANT LOT							
00693 001724 1	TRLR	5712 VIAU WAY	5/8	NEPT	39605140	141410	10.0	10.0	100.00%	3/22/2001				
00693 001725 1	TRLR	5710 VIAU WAY	5/8	NEPT	39379192	398710	10.0	10.0	100.00%	3/22/2001				
00693 001728 1	TRLR	5708 VIAU WAY	5/8	NEPT	38955581	522480	10.0	10.0	100.00%	3/22/2001				
00693 001729 1	TRLR	5706 VIAU WAY	5/8	NEPT	39379195	241790	10.0	11.0	110.00%	3/22/2001	BADG	32206542	10	3/23/2001
00693 001732 2	TRLR	5704 VIAU WAY	5/8	NEPT	39379159	212680	10.0	10.0	100.00%	3/22/2001				
00693 001733 1	TRLR	5702 VIAU WAY	5/8	NEPT	39605135	170300	10.0	10.0	100.00%	3/22/2001				
00693 001736 1	TRLR	5650 VIAU WAY	5/8	NEPT	39605133	162580	10.0	9.9	99.00%	3/23/2001				
00693 001740 1	TRLR	5646 VIAU WAY	5/8	NEPT	38955609	264110	10.0	9.8	98.00%	3/23/2001				
00693 001749 1	TRLR	5638 VIAU WAY	5/8	NEPT	38955636	515540	NOT TESTED/VACANT LOT							
00693 001750 1	TRLR	5636 VIAU WAY	5/8	NEPT	38955612	1916870	10.0	9.9	99.00%	3/23/2001				
00693 001672 1	TRLR	5862 NAPLES DR	5/8	NEPT	38955627	232770	10.0	11.9	119.00%	3/23/2001	BADG	32206602	10	3/27/2001
00693 001673 1	TRLR	5860 NAPLES DR	5/8	NEPT	39605132	152600	10.0	10.0	100.00%	3/23/2001				
00693 001658 4	TRLR	5858 NAPLES DR	5/8	NEPT	39615153	230690	10.0	9.9	99.00%	3/23/2001				
00693 001650 1	TRLR	5854 NAPLES DR	5/8	NEPT	39379191	198230	10.0	9.9	99.00%	3/23/2001				
00693 001649 1	TRLR	5852 NAPLES PL	5/8	NEPT	39379196	417290	10.0	14.5	145.00%	3/23/2001	BADG	32206601	10	3/27/2001
00693 001642 2	TRLR	5850 NAPLES DR	5/8	NEPT	39379193	308610	10.0	12.5	125.00%	3/23/2001	BADG	32206604	10	3/27/2001
00693 001641 1	TRLR	5848 NAPLES DR	5/8	NEPT	39379200	182710	10.0	12.2	122.00%	3/23/2001	BADG	30223662	10	3/27/2001
00693 001634 1	TRLR	5846 NAPLES DR	5/8	NEPT	36905796	197390	10.0	10.0	100.00%	3/23/2001				
00693 001633 2	TRLR	5844 NAPLES DR	5/8	NEPT	39379198	238810	10.0	13.5	135.00%	3/23/2001	BADG	30223677	10	3/27/2001
00693 001629 2	TRLR	5842 NAPLES DR	5/8	NEPT	39605134	149230	10.0	9.8	98.00%	3/23/2001				

LABRADOR UTILITIES, INC.
DOCKET NO. 030443-W5

METER CHANGE-OUT GUIDELINES

RANGE OF RESULTS - 95% - 101.5%

CHANGE OUT IF LESS THAN 9.5 OR 10.2 OR GREATER

OF METERS OUTSIDE PSC LIMITS

SLOW METERS	19
FAST METERS	126

RESPONSE TO PAA ACTION REQUEST - ISSUE #1 - METER FLOW TEST RESULTS

ACCOUNT NUMB	TYPE	SERVICE ADDRESS	SIZE	MAKE	SERIAL #	METER READ	VOLUME IN GALLONS		RESULTS		MAKE	NEW SERIAL #	NEW METER READ	DATE CHANGED OUT
							PTM TESTER	CUSTOMER METER	% OF ACCURACY	DATE TESTED				
00693 001628 1	TRLR	5840 NAPLES DR	5/8	NEPT	39605798	99960	NOT TESTED/VACANT LOT							
00693 001620 1	TRLR	5838 NAPLES DR	5/8	NEPT	38955580	223160	10.0	9.9	99.00%	3/23/2001				
00693 001619 1	TRLR	5836 NAPLES DR	5/8	NEPT	39379055	540640	10.0	12.5	125.00%	3/23/2001	BADG	30223676	10	3/27/2001
00693 001613 3	TRLR	5834 NAPLES DR	5/8	NEPT	39379194	160450	10.0	9.9	99.00%	3/23/2001				
00693 001612 1	TRLR	5832 NAPLES DR	5/8	NEPT	39604139	600750	10.0	14.3	143.00%	3/23/2001	BADG	30223678	10	3/27/2001
00693 001605 1	TRLR	5830 NAPLES DR	5/8	NEPT	41960468	107560	10.0	9.9	99.00%	3/23/2001				
00693 001604 1	TRLR	5828 NAPLES DR	5/8	NEPT	41960496	295440	10.0	13.5	135.00%	3/23/2001	BADG	30223680	10	3/27/2001
00693 001603 1	TRLR	5826 NAPLES DR	5/8	NEPT	39605830	237210	10.0	9.9	99.00%	3/28/2001				
00693 001596 2	TRLR	5824 NAPLES DR	5/8	NEPT	39605799	269980	10.0	10.0	100.00%	3/28/2001				
00693 001595 2	TRLR	5822 NAPLES DR	5/8	NEPT	38955578	185380	10.0	9.6	96.00%	3/28/2001				
00693 001588 1	TRLR	5820 NAPLES DR	5/8	NEPT	39605136	435040	10.0	10.5	105.00%	3/28/2001	BADG	32206522	10	3/29/2001
00693 001587 1	TRLR	5818 NAPLES DR	5/8	NEPT	39605827	89830	10.0	16.8	168.00%	3/28/2001	BADG	32206525	10	3/29/2001
00693 001580 1	TRLR	5816 NAPLES DR	5/8	NEPT	39605807	150020	10.0	10.0	100.00%	3/28/2001				
00693 001579 2	TRLR	5814 NAPLES DR	5/8	NEPT	39605823	214760	10.0	15.5	155.00%	3/28/2001	BADG	30223681	10	3/29/2001
00693 001564 1	TRLR	5808 NAPLES DR	5/8	NEPT	39605822	167720	10.0	9.8	98.00%	3/28/2001				
00693 001563 1	TRLR	5806 NAPLES DR	5/8	NEPT	39605794	163900	10.0	14.5	145.00%	3/28/2001	BADG	32206527	10	3/29/2001
00693 001556 1	TRLR	5804 NAPLES DR	5/8	NEPT	38955577	128270	10.0	10.4	104.00%	3/28/2001	BADG	32206526	10	3/29/2001
00693 001557 2	TRLR	5803 NAPLES DR	5/8	NEPT	39379086	509180	10.0	10.0	100.00%	12/19/2001				
00693 001565 2	TRLR	5807 NAPLES DR	5/8	NEPT	39379089	186220	10.0	10.3	103.00%	3/31/2001	BADG	32206524	10	4/5/2001
00693 001570 1	TRLR	5809 NAPLES DR	5/8	NEPT	39379101	180350	10.0	10.1	101.00%	3/31/2001				
00693 001573 2	TRLR	5811 NAPLES DR	5/8	NEPT	39379110	358720	10.0	10.1	101.00%	3/31/2001				
00693 001578 2	TRLR	5813 NAPLES DR	5/8	NEPT	38955605	115300	10.0	10.1	101.00%	3/31/2001				
00693 001602 2	TRLR	5825 NAPLES DR	5/8	NEPT	38955606	199500	10.0	10.1	101.00%	4/6/2001				
00693 001606 1	TRLR	5827 NAPLES DR	5/8	NEPT	38955599	270930	10.0	10.2	102.00%	4/6/2001	BADG	30223667	10	4/7/2001
00693 001611 1	TRLR	5829 NAPLES DR	5/8	NEPT	38955604	152040	10.0	10.2	102.00%	4/6/2001	BADG	30223665	10	4/7/2001

TOTAL TESTED 800

LABRADOR UTILITIES, INC.
DOCKET NO. 030443-W5

METER CHANGE-OUT GUIDELINES

RANGE OF RESULTS - 95% - 101.5%
CHANGE OUT IF LESS THAN 9.5 OR 10.2 OR GREATER

OF METERS OUTSIDE PSC LIMITS

SLOW METERS	19
FAST METERS	126
TOTAL TESTED	800

RESPONSE TO PAA ACTION REQUEST - ISSUE #1 - METER FLOW TEST RESULTS

ACCOUNT NUMB	TYP E	SERVICE ADDRESS	SIZ E	MA KE	SERIAL #	METER READ	VOLUME IN GALLONS		RESULTS				MA KE	NEW SERIAL #	NEW METER READ	DATE CHANGED OUT
							PTM TESTER	CUSTOMER METER	% OF ACCURACY	DATE TESTED						
00693 001614 1	TRLR	5831 NAPLES DR	5/8	NEPT	38955603	564660	10.0	10.3	103.00%	4/6/2001	BADG	30223668	10	4/7/2001		
00693 001621 1	TRLR	5835 NAPLES DR	5/8	NEPT	38955631	142850	10.0	10.0	100.00%	4/20/2002						
00693 001627 1	TRLR	5837 NAPLES DR	5/8	NEPT	38955600	98730	10.0	10.0	100.00%	4/6/2001						
00693 001630 1	TRLR	5839 NAPLES DR	5/8	NEPT	39379082	335300	NOT TESTED/VACANT LOT									
00693 001632 2	TRLR	5841 NAPLES DR	5/8	NEPT	39379084	224940	NOT TESTED/VACANT LOT									
00693 001635 1	TRLR	5843 NAPLES DR	5/8	NEPT	39379051	300780	10.0	10.3	103.00%	4/6/2001	BADG	32223669	10	4/7/2001		
00693 001640 1	TRLR	5845 NAPLES DR	5/8	NEPT	39379102	173720	10.0	10.1	101.00%	4/6/2001						
00693 001643 1	TRLR	5847 NAPLES DR	5/8	NEPT	39379133	371440	10.0	10.1	101.00%	4/6/2001						
00693 001648 1	TRLR	5849 NAPLES PL	5/8	NEPT	93979134	539880	10.0	10.3	103.00%	4/6/2001	BADG	30223666	10	4/7/2001		
00693 001651 1	TRLR	5851 NAPLES DR	5/8	NEPT	39605152	349500	10.0	10.1	101.00%	4/6/2001						
00693 001656 1	TRLR	5853 NAPLES DR	5/8	NEPT	39379109	140490	10.0	10.1	101.00%	4/6/2001						
00693 001659 1	TRLR	5855 NAPLES DR	5/8	NEPT	39605161	358100	10.0	10.3	103.00%	4/6/2001	BADG	30223706	10	4/10/2001		
00693 001669 1	TRLR	5861 NAPLES DR	5/8	NEPT	38955608	446380	10.0	10.1	101.00%	4/6/2001						
00693 001666 1	TRLR	5956 BENZ PL	5/8	NEPT	39371397	116960	NOT TESTED/VACANT LOT									
00693 001655 3	TRLR	5952 BENZ PL	5/8	NEPT	39379056	165360	10.0	10.1	101.00%	4/6/2001						
00693 001652 2	TRLR	5950 BENZ PL	5/8	NEPT	39379059	140130	10.0	10.3	103.00%	4/6/2001	BADG	30223707	10	4/10/2001		
00693 001647 2	TRLR	5948 BENZ PL	5/8	NEPT	38955611	170330	10.0	10.3	103.00%	4/6/2001	BADG	30223708	10	4/10/2001		
00693 001644 2	TRLR	5946 BENZ PL	5/8	NEPT	39379088	185190	10.0	10.1	101.00%	4/6/2001						
00693 001639 1	TRLR	5944 BENZ PL	5/8	NEPT	39379090	383590	10.0	10.2	102.00%	4/6/2001	BADG	30223711	10	4/10/2001		
00693 001631 2	TRLR	5940 BENZ PL	5/8	NEPT	39379105	266820	10.0	10.2	102.00%	4/6/2001	BADG	30223710	10	4/10/2001		
00693 001626 1	TRLR	5938 BENZ PL	5/8	NEPT	38955607	177550	10.0	10.4	104.00%	4/6/2001	BADG	30223709	10	4/10/2001		
00693 001622 3	TRLR	5936 BENZ PL	5/8	NEPT	38955610	202730	10.0	10.3	103.00%	4/6/2001	BADG	32206778	10	4/10/2001		
00693 001617 1	TRLR	5934 BENZ PL	5/8	NEPT	39379085	187240	NOT TESTED/VACANT LOT									
00693 001615 2	TRLR	5932 BENZ PL	5/8	NEPT	38955616	267930	10.0	10.0	100.00%	4/11/2001						
00693 001593 1	TRLR	5922 BENZ PL	5/8	NEPT	39879054	264270	10.0	10.2	102.00%	4/11/2001	BADG	32206776	10	4/12/2001		

LABRADOR UTILITIES, INC.
DOCKET NO. 030443-WS

METER CHANGE-OUT GUIDELINES

RANGE OF RESULTS - 95% - 101.5%
CHANGE OUT IF LESS THAN 9.5 OR 10.2 OR GREATER

OF METERS OUTSIDE PSC LIMITS

SLOW METERS	19
FAST METERS	126
TOTAL TESTED	800

RESPONSE TO PAA ACTION REQUEST - ISSUE #1 - METER FLOW TEST RESULTS

ACCOUNT NUMB	TYPE	SERVICE ADDRESS	SIZE	MAKE	SERIAL #	METER READ	VOLUME IN GALLONS		RESULTS		MAKE	NEW SERIAL #	NEW METER READ	DATE CHANGED OUT
							PTM TESTER	CUSTOMER METER	% OF ACCURACY	DATE TESTED				
00693 001585 2	TRLR	5918 BENZ PL	5/8	NEPT	38955618	199760	10.0	10.0	100.00%	12/19/2001				
00693 001582 1	TRLR	5916 BENZ PL	5/8	NEPT	41960501	229910	10.0	10.0	100.00%	4/12/2001				
00693 001569 1	TRLR	5910 BENZ PL	5/8	NEPT	41960470	767770	10.0	9.9	99.00%	12/19/2001				
00693 001552 1	TRLR	5901 BENZ PL	5/8	NEPT	38955629	813640	10.0	9.8	98.00%	4/12/2001				
00693 001583 1	TRLR	5915 BENZ PL	5/8	NEPT	38955624	1122760	10.0	9.9	99.00%	12/19/2001				
00693 001591 2	TRLR	5919 BENZ PL	5/8	NEPT	38955625	300830	10.0	10.1	101.00%	4/12/2001				
00693 001592 1	TRLR	5921 BENZ PL	5/8	NEPT	38955622	147280	10.0	10.1	101.00%	12/19/2001				
00693 001600 1	TRLR	5925 BENZ PL	5/8	NEPT	38955635	691570	5.0	5.0	100.00%	9/13/2000				
00693 001608 2	TRLR	5927 BENZ PL	5/8	NEPT	38955617	549720	10.0	10.0	100.00%	12/19/2001				
00693 001624 1	TRLR	5935 BENZ PL	5/8	NEPT	89565628	150530	10.0	9.9	99.00%	12/19/2001				
00693 001625 1	TRLR	5937 BENZ PL	5/8	NEPT	38955583	236680	10.0	10.2	102.00%	4/18/2001	BADG	32206722	10	4/19/2001
00693 001638 2	TRLR	5941 BENZ PL	5/8	NEPT	39855613	236040	10.0	10.2	102.00%	4/18/2001	BADG	32206724	10	4/19/2001
00693 001645 1	TRLR	5943 BENZ PL	5/8	NEPT	31955615	304630	10.0	10.1	101.00%	4/18/2001				
00693 001646 1	TRLR	5945 BENZ PL	5/8	NEPT	38955614	243150	10.0	10.1	101.00%	4/18/2001				
00693 001654 1	TRLR	5949 BENZ PL	5/8	NEPT	46156508	89550	10.0	10.1	101.00%	4/18/2001				
00693 001663 2	TRLR	5955 BENZ PL	5/8	NEPT	39379103	231030	10.0	10.2	102.00%	4/18/2001	BADG	32206725	10	4/19/2001
00693 001535 1	TRLR	5936 UTOPIA DR	5/8	NEPT	46466622	225030	10.0	10.3	103.00%	4/18/2001	BADG	32206723	10	4/19/2001
00693 001683 1	TRLR	5841 TWILIGHT DR	5/8	NEPT	39379106	359690	10.0	10.1	101.00%	4/19/2001				
00693 001682 2	TRLR	5843 TWILIGHT DR	5/8	NEPT	39379057	753750	10.0	10.2	102.00%	4/19/2001	BADG	32206642	10	4/20/2001
00693 001681 1	TRLR	5845 TWILIGHT DR	5/8	NEPT	39379058	217270	10.0	10.1	101.00%	4/20/2002				
00693 001680 2	TRLR	5847 TWILIGHT DR	5/8	NEPT	39605138	115510	10.0	10.1	101.00%	4/20/2001				
00693 001679 1	TRLR	5849 TWILIGHT DR	5/8	NEPT	38955683	173220	10.0	10.4	104.00%	4/20/2001	BADG	32206644	10	4/21/2001
00693 001678 1	TRLR	5851 TWILIGHT DR	5/8	NEPT	39379087	484620	10.0	10.1	101.00%	11/27/2001				
00693 001677 1	TRLR	5901 TWILIGHT DR	5/8	NEPT	38955621	546650	10.0	10.1	101.00%	4/20/2001				
00693 001675 1	TRLR	5905 TWILIGHT DR	5/8	NEPT	38955630	340450	10.0	10.1	101.00%	4/20/2001				

LABRADOR UTILITIES, INC.
DOCKET NO. 030443-WS

METER CHANGE-OUT GUIDELINES

RANGE OF RESULTS - 95% - 101.5%

CHANGE OUT IF LESS THAN 9.5 OR 10.2 OR GREATER

OF METERS OUTSIDE PSC LIMITS

SLOW METERS	19
FAST METERS	126

RESPONSE TO PAA ACTION REQUEST - ISSUE #1 - METER FLOW TEST RESULTS

TOTAL TESTED 800

ACCOUNT NUMB	TYPE	SERVICE ADDRESS	SIZE	MAKE	SERIAL #	METER READ	VOLUME IN GALLONS		RESULTS		MAKE	NEW SERIAL #	NEW METER READ	DATE CHANGED OUT
							PTM TESTER	CUSTOMER METER	% OF ACCURACY	DATE TESTED				
00693 001801 2	TRLR	6047 UTOPIA DR	5/8	NEPT	41960473	133540	10.0	9.8	98.00%	4/20/2002				
00693 001828 2	TRLR	6249 UTOPIA DR	5/8	NEPT	UNKNOWN	124370	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256571	0	4/30/2002
00693 001422 2	TRLR	6350 JESSUP DR	5/8	NEPT	33111627	78270	10.0	9.9	99.00%	11/27/2001				
00693 001428 2	TRLR	6316 JESSUP DR	5/8	NEPT	39605825	296470	10.0	10.1	101.00%	5/10/2001				
00693 001430 1	TRLR	6306 JESSUP DR	5/8	NEPT	39605829	328090	10.0	10.0	100.00%	11/27/2001				
00693 001434 2	TRLR	6240 JESSUP DR	5/8	NEPT	41960466	327660	10.0	9.9	99.00%	11/27/2001				
00693 001437 2	TRLR	6226 JESSUP DR	5/8	NEPT	74045696	122960	10.0	10.0	100.00%	5/10/2001				
00693 001438 1	TRLR	6220 JESSUP DR	5/8	NEPT	41960502	85570	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256573	0	4/30/2002
00693 001443 3	TRLR	6162 JESSUP DR	5/8	NEPT	41960499	423050	10.0	9.9	99.00%	11/27/2001				
00693 001497 1	TRLR	5930 JESSUP DR	5/8	NEPT	41960474	161250	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256609	0	5/3/2002
00693 001403 2	TRLR	6247 JESSUP DR	5/8	NEPT	74045706	64350	10.0	9.9	99.00%	4/25/2002	BADG	33256681	10	5/17/2002
00693 001404 1	TRLR	6251 JESSUP DR	5/8	NEPT	34377336	260070	10.0	10.1	101.00%	5/12/2001				
00693 001409 1	TRLR	6323 JESSUP DR	5/8	NEPT	46466659	449000	10.0	10.3	103.00%	5/19/2001	BADG	32206720	0	5/19/2001
00693 001030 1	TRLR	41276 XENON WAY	5/8	NEPT	30223689	2300	10.0	10.0	100.00%	5/19/2001				
00693 001035 1	TRLR	41252 XENON WAY	5/8	NEPT	30223628	9760	10.0	10.0	100.00%	5/18/2001				
00693 001373 1	TRLR	6326 PRESIDENTIAL CIR	5/8	NEPT	74377344	95080	10.0	9.7	97.00%	4/26/2002	BADG	33256628	0	5/17/2002
00693 001377 2	TRLR	6306 PRESIDENTIAL CIR	5/8	NEPT	30131988	2840	10.0	10.0	100.00%	5/18/2001				
00693 001382 2	TRLR	6238 PRESIDENTIAL CIR	5/8	NEPT	41420201	624580	10.0	10.0	100.00%	5/18/2001				
00693 001775 1	TRLR	6052 PRESIDENTIAL CIR	5/8	NEPT	74377357	45900	10.0	9.7	97.00%	4/26/2002				
00693 001270 1	TRLR	6020 PRESIDENTIAL CIR	5/8	NEPT	37386293	166250	10.0	10.0	100.00%	5/25/2001				
00693 001263 1	TRLR	6018 PRESIDENTIAL CIR	5/8	NEPT	38955598	224660	NOT TESTED/VACANT LOT							
00693 001304 1	TRLR	6041 PRESIDENTIAL CIR	5/8	NEPT	41960497	161500	10.0	9.6	96.00%	4/26/2002				
00693 001758 1	TRLR	6049 PRESIDENTIAL CIR	5/8	NEPT	41960498	85520	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	32371400	0	5/23/2002
00693 001360 1	TRLR	6209 PRESIDENTIAL CIR	5/8	NEPT	35153354	272030	10.0	10.0	100.00%	6/13/2001				
00693 001363 1	TRLR	6227 PRESIDENTIAL CIR	5/8	NEPT	41420200	155660	10.0	9.8	98.00%	4/26/2002				

LABRADOR UTILITIES, INC.
DOCKET NO. 030443-WS

METER CHANGE-OUT GUIDELINES

RANGE OF RESULTS - 95% - 101.5%

CHANGE OUT IF LESS THAN 9.5 OR 10.2 OR GREATER

OF METERS OUTSIDE PSC LIMITS

SLOW METERS 19

FAST METERS 126

TOTAL TESTED 800

RESPONSE TO PAA ACTION REQUEST - ISSUE #1 - METER FLOW TEST RESULTS

ACCOUNT NUMB	TYPE	SERVICE ADDRESS	SIZE	MAKE	SERIAL #	METER READ	VOLUME IN GALLONS		RESULTS		MAKE	NEW SERIAL #	NEW METER READ	DATE CHANGED OUT		
							PTM TESTER	CUSTOMER METER	% OF ACCURACY	DATE TESTED						
00693 001369 1	TRLR	6305 PRESIDENTIAL CIR	5/8	NEPT	41420798	250810	10.0	9.9	99.00%	11/13/2001						
00693 001372 1	TRLR	6325 PRESIDENTIAL CIR	5/8	NEPT	40002582	1301060	10.0	10.0	100.00%	11/13/2001						
00693 001037 1	TRLR	41232 XENON WAY	5/8	NEPT	40002581	258710	10.0	10.3	103.00%	6/15/2001	BADG	32206789	10	6/15/2001		
00693 001067 2	TRLR	6340 FOREST LAKE DR	5/8	NEPT	39605808	318440	10.0	10.2	102.00%	6/14/2001	BADG	32206786	10	6/15/2001		
00693 001352 1	TRLR	6202 FOREST LAKE DR	5/8	NEPT	45737052	381330	10.0	10.0	100.00%	6/14/2001						
00693 001355 1	TRLR	6156 FOREST LAKE DR	5/8	NEPT	47909372	78630	10.0	10.0	100.00%	11/7/2001						
00693 001317 3	TRLR	6112 FOREST LAKE DR	5/8	NEPT	41960471	167690	10.0	10.0	100.00%	11/15/2001						
00693 001274 1	TRLR	6043 FOREST LAKE DR	5/8	NEPT	45737051	25020	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256633	0	5/17/2002		
00693 001331 1	TRLR	6215 FOREST LAKE DR	5/8	NEPT	39582393	23680	10.0	10.1	101.00%	4/24/2002						
00693 001335 2	TRLR	6239 FOREST LAKE DR	5/8	NEPT	41960505	172940	10.0	9.8	98.00%	4/24/2002						
00693 001338 1	TRLR	6301 FOREST LAKE DR	5/8	NEPT	46186478	465780	10.0	9.9	99.00%	4/24/2002	BADG	33256632	10	5/17/2002		
00693 001339 1	TRLR	6309 FOREST LAKE DR	5/8	NEPT	3884177	43680	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256679	0	5/22/2002		
00693 001039 1	TRLR	41210 XENON WAY	5/8	NEPT	41420203	123000	10.0	10.0	100.00%	6/28/2001						
00693 001077 1	TRLR	6401 FOREST LAKE DR	5/8	NEPT	41960530	744090	10.0	10.2	102.00%	6/28/2001	BADG	32206608	10	6/25/2001		
00693 001896 1	POOL	6443 PRESIDENTIAL CIR	1	NEPT	33025796	4997560	10.0	10.1	101.00%	11/15/2001						
00693 001196 1	IRRG	6360 SPRING LAKE CIR IRF	2	NEPT	47121370	500	LARGE METER TESTER NEEDED TO TEST IN FIELD									
00693 001092 2	TRLR	6352 SPRING LAKE CIR	5/8	NEPT	74377016	101460	10.0	10.0	100.00%	6/28/2001						
00693 001090 1	TRLR	6340 SPRING LAKE CIR	5/8	NEPT	40002631	71010	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256678	0	5/17/2002		
00693 001088 1	TRLR	6328 SPRING LAKE CIR	5/8	NEPT	39605792	119230	10.0	10.0	100.00%	11/15/2001						
00693 001064 2	TRLR	6316 SPRING LAKE CIR	5/8	NEPT	4000583	182210	NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	33256677	0	5/17/2002		
00693 001044 1	TRLR	6310 SPRING LAKE CIR	5/8	NEPT	39605801	233210	10.0	10.1	101.00%	6/29/2001						
00693 001193 4	TRLR	6138 SPRING LAKE CIR	5/8	NEPT	45737050	234660	10.0	10.1	101.00%	4/24/2002						
00693 001186 1	TRLR	6114 SPRING LAKE CIR	5/8	NEPT	41960469	1301380	5.0	5.0	100.00%	9/14/2000						
00693 001162 1	TRLR	6025 SPRING LAKE CIR	5/8	NEPT	UNKNOWN	554320	10.0	10.1	101.00%	7/12/2001						
00693 001095 1	TRLR	6325 SPRING LAKE CIR	5/8	NEPT	41420284	164640	10.0	10.1	101.00%	7/12/2001						

LABRADOR UTILITIES, INC.
DOCKET NO. 030443-WS

METER CHANGE-OUT GUIDELINES

RANGE OF RESULTS - 95% - 101.5%

CHANGE OUT IF LESS THAN 9.5 OR 10.2 OR GREATER

OF METERS OUTSIDE PSC LIMITS

SLOW METERS 19

FAST METERS 126

TOTAL TESTED 800

RESPONSE TO PAA ACTION REQUEST - ISSUE #1 - METER FLOW TEST RESULTS

ACCOUNT NUMB	TYP E	SERVICE ADDRESS	SIZ E	MA KE	SERIAL #	METER READ	VOLUME IN GALLONS		RESULTS		MA KE	NEW SERIAL #	NEW METER READ	DATE CHANGED OUT
							PTM TESTER	CUSTOMER METER	% OF ACCURACY	DATE TESTED				
00693 001099 1	TRLR	6351 SPRING LAKE CIR	5/8	NEPT	41420205	169010	10.0	10.0	100.00%	7/12/2001				
00693 001117 1	TRLR	41074 BREAM CIR	5/8	NEPT	39636501	83410	10.0	10.1	101.00%	7/19/2001				
00693 001124 2	TRLR	41032 BREAM CIR	5/8	NEPT	79377354	83320	10.0	9.9	99.00%	4/24/2002				
00693 001005 1	TRLR	6454 PRESIDENTIAL CIR	5/8	PREC	8449469	888600	10.0	10.1	101.00%	3/9/2001	BADG	32206494	0	8/29/2001
00693 001019 1	TRLR	41221 WHITMER DR	5/8	PREC	8808413	825460	10.0	10.1	101.00%	8/29/2001	BADG	32206612	10	8/29/2001
00693 001020 1	TRLR	41227 WHITMER DR	5/8	PREC	8811179	645760	10.0	10.1	101.00%	3/10/2001	BADG	32206615	10	8/29/2001
00693 001021 1	TRLR	41231 WHITMER DR	5/8	PREC	8808411	711920	9.8	10.0	102.04%	2/15/2001	BADG	30223693	10	2/15/2001
00693 001022 1	TRLR	41237 WHITMER DR	5/8	PREC	8449467	1449760	10.0	13.1	131.00%	3/10/2001	BADG	30223645	10	3/13/2001
00693 001027 2	TRLR	41303 WHITMER DR	5/8	PREC	8449414	505390	10.0	10.0	100.00%	3/10/2001	BADG	32206745	10	12/19/2001
00693 001078 2	TRLR	6374 FOREST LAKE DR	5/8	PREC	8811176	453780	10.0	10.5	105.00%	6/14/2001	BADG	32206551	10	6/15/2001
00693 001046 2	TRLR	6330 FOREST LAKE DR	5/8	PREC	8449470	693660	10.0	10.5	105.00%	6/14/2001	BADG	32206790	10	6/15/2001
00693 001079 1	TRLR	6373 FOREST LAKE DR	5/8	PREC	8811183	1218340	10.0	10.4	104.00%	6/28/2001	BADG	32206607	10	6/28/2001
00693 001042 1	TRLR	6303 SPRING LAKE CIR	5/8	PREC	8811174	627200	10.0	10.3	103.00%	11/7/2001	BADG	32206782	0	11/7/2001
00693 001094 1	TRLR	6319 SPRING LAKE CIR	5/8	PREC	8811182	681960	10.0	10.1	101.00%	7/12/2001	BADG	32206584	0	12/20/2001
00693 001097 2	TRLR	6335 SPRING LAKE CIR	5/8	PREC	8449416	535080	10.0	10.3	103.00%	7/12/2001	BADG	32206563	0	7/17/2001
00693 001100 1	TRLR	6359 SPRING LAKE CIR	5/8	PREC	8811177	1244560	10.0	10.1	101.00%	11/7/2001	BADG	32206785	0	11/7/2001
00693 001102 1	TRLR	6365 SPRING LAKE CIR	5/8	PREC	8811178	991310	10.0	10.2	102.00%	11/9/2001	BADG	32206706	0	11/9/2001
00693 001109 1	TRLR	6304 TWILIGHT DR	5/8	PREC	8811180	395890	10.0	10.1	101.00%	7/25/2001	BADG	32206680	10	7/25/2001
00693 001138 1	TRLR	6207 TWILIGHT DR	5/8	PREC	8449466	936440	10.0	10.0	100.00%	7/19/2001	BADG	32206691	0	8/14/2001
00693 001053 1	TRLR	41277 XENON WAY	5/8	PREC	8811185	1033450	5.0	5.0	100.00%	9/13/2000	BADG	32371398	0	4/18/2002
00693 009000 1	COMI	6420 FOREST LAKE	6		9931296	6393000	LARGE MTR/FLD TESTED, REPLACED				BADG	2006128406	27	5/9/2002
00693 001571 1	TRLR	5810 NAPLES DR	5/8				NOT TESTED/OFF AT HOUSE/REPLACED PER				BADG	18721944	40	4/18/2002
00693 001435 2	TRLR	6238 JESSUP DR	5/8		32206523	2340	10.0	10.0	100.00%	5/10/2001	BADG	32206523	33590	4/18/2002
00693 001900 0	COMI	6360 SPRING LAKE DR	1		16649670	127510	10.0	10.0	100.00%	11/15/2001	BADG			
00693 001105 1	TRLR	6383 SPRING LAKE CIR	5/8		909996810	403580	10.0	10.1	101.00%	7/19/2001	BADG	32206736	0	4/10/2002