

ORIGINAL

STATE OF FLORIDA

COMMISSIONERS:  
LISA POLAK EDGAR, CHAIRMAN  
J. TERRY DEASON  
ISILIO ARRIAGA  
MATTHEW M. CARTER II  
KATRINA J. TEW



TIMOTHY DEVLIN, DIRECTOR  
DIVISION OF ECONOMIC REGULATION  
(850) 413-6900

RECEIVED FPSC  
05 NOV 21 PM 3:47

Public Service Commission

COMMISSION  
CLERK

November 21, 2006

Mr. Martin Friedman  
Rose, Sundstrom & Bentley, LLP  
2180 W. State Road 434, Suite 2118  
Longwood, Florida 32779

Re: Docket No. 060253-WS - Application for increase in water and wastewater rates in Marion, Orange, Pasco, Pinellas, and Seminole Counties by Utilities, Inc. of Florida.

Dear Mr. Friedman:

We have reviewed the additional explanations, schedules and data submitted by Utilities, Inc. of Florida (UIF) on November 13, 2006, to satisfy the minimum filing requirements (MFRs). However, after reviewing this information, we still find the MFRs to be deficient. The specific deficiency is identified as follows:

Chemicals Used in Marion, Orange, Pasco, Pinellas, and Seminole Counties

Tab 2 of Volume III – Chemicals Used

As required by Rule 25-30.440(2), F.A.C., each applicant for a rate increase shall provide the Commission a list of chemicals used for water and wastewater treatment, by type, showing the dollar amount and quantity purchased, the unit prices paid and the dosage rates utilized. The quantity purchased for counties indicates a per unit cost; however, the type of unit is not identified such as gallons or pounds and the dosage rate utilized was not provided. In order to assist in meeting the requirements of this Rule, please provide all information necessary in the same or similar format as shown on Attachment A. Attachment A is the list of chemicals submitted in Docket No. 050281-WS which satisfies the requirements of Rule 25-30.440(2), F.A.C.

- CMP \_\_\_\_\_
- COM \_\_\_\_\_
- CTR \_\_\_\_\_
- ECR \_\_\_\_\_
- GCL \_\_\_\_\_
- OPC \_\_\_\_\_
- RCA \_\_\_\_\_
- SCR \_\_\_\_\_
- SGA \_\_\_\_\_
- SEC   1
- OTH \_\_\_\_\_

CAPITAL CIRCLE OFFICE CENTER • 2540 SHUMARD OAK BOULEVARD • TALLAHASSEE, FL 32399-0850

An Affirmative Action / Equal Opportunity Employer

PSC Website: <http://www.floridapsc.com>

Internet E-mail: [contact@psc.state.fl.us](mailto:contact@psc.state.fl.us)

DOCUMENT NUMBER - DATE


10707 NOV 21 06

FPSC-COMMISSION CLERK

Mr. Martin Friedman  
Page 2  
November 21, 2006

If any above corrections require a corresponding change to any MFR schedules, those corrected schedules must also be submitted. Your petition will not be deemed filed until the deficiency identified in this letter has been corrected. These corrections should be submitted no later than December 21, 2006.

Sincerely,

A handwritten signature in black ink that reads "Tim Devlin" followed by a stylized flourish.

Timothy Devlin  
Director

TD:kk

Attachment

cc: Division of Economic Regulation (Willis, Bulecza-Banks, Bruce, Daniel, Rendell, Slemkewicz, Fletcher, Gardner, Kaproth, Marsh, Redemann, Romig)  
Office of the General Counsel (Jaeger)  
Division of the Commission Clerk and Administrative Services ✓

ATTACHMENT A

Plantation Bay Utility Company, Inc  
 Schedule of Chemicals  
 Docket No. 050281-WS  
 January 1, 2004 - December 31, 2004

	Aqua Mag		SM Hical Pebble QL		Chlorine Gas		HTH Shock Treatment		Total
	55 Gal Drum	Amount	Tons	Amount	150# Cylinder	Amount	100#	Amount	Amount
1/16/2004	1	759.00							759.00
1/20/2004			26.26	3,296.59					3,296.59
1/27/2004					8	560.00			560.00
2/13/2004	1	808.34							808.34
3/2/2004					8	560.00			560.00
3/26/2004					8	560.00			560.00
5/6/2004	1	808.34							808.34
4/22/2004					8	560.00			560.00
5/21/2004					8	600.00			600.00
6/16/2004					8	600.00			600.00
7/1/2004	1	808.34							808.34
7/7/2004					8	600.00			600.00
7/29/2004							2	195.96	195.96
7/26/2004			24.94	3,149.59					3,149.59
8/6/2004					8	600.00			600.00
9/13/2004					8	600.00			600.00
10/6/2004					8	600.00			600.00
10/20/2004	1	808.34							808.34
11/4/2004					10	750.00			750.00
11/3/2004			26.56	3,384.20					3,384.20
11/24/2004					8	600.00			600.00
12/16/2004					8	600.00			600.00
12/17/2004	1	808.34							808.34
	<b>6</b>	<b>\$4,800.70</b>	<b>77.76</b>	<b>\$9,830.38</b>	<b>108</b>	<b>\$7,790.00</b>	<b>2</b>	<b>\$195.96</b>	<b>\$22,617.94</b>
Quantity Purchased	330		78		15,900		200		
Unit of Measure	Gallons		Tons		Pounds		Pounds		
Avg Cost per Unit	\$ 14.55		\$ 126.42		\$ 0.49		\$ 0.96		
Where Used (Specify Water Plant, Sewer Plant, Ponds, etc)	Water Plant		Water Plant		60% Water, 40% Sewer		Sewer		
Specify dosage rate:									
Water	2.67 gallons per 1 million gals.		1,760 lbs per 1 million gals.		25 lbs per day		N/A		
Sewer	N/A		N/A		18 lbs. per day		As needed to clean weirs		