

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

DOCKET NO. 060658

Submitted for filing: January 16, 2007

**In Re: Petition on behalf of Citizens of
the State of Florida to require
Progress Energy Florida, Inc. to
refund to customers \$143 million**

**DIRECT TESTIMONY
OF
CLIFFORD WAYNE TOMS
ON BEHALF OF
PROGRESS ENERGY FLORIDA**

R. ALEXANDER GLENN
JOHN BURNETT
PROGRESS ENERGY SERVICE
COMPANY, LLC
P.O. Box 14042
St. Petersburg, Florida 33733
Telephone: (727) 820-5180
Facsimile: (727) 820-5519

JAMES MICHAEL WALLS
Florida Bar No. 706272
DIANNE M. TRIPLETT
Florida Bar No. 0872431
CARLTON FIELDS, P.A.
Post Office Box 3239
Tampa, FL 33601
Telephone: (813) 223-7000
Telecopier: (813) 229-4133

DOCUMENT NUMBER-DATE

00435 JAN 16 8

FPSC-COMMISSION OF PUBLIC UTILITIES

**IN RE: PETITION ON BEHALF OF CITIZENS OF THE
STATE OF FLORIDA TO REQUIRE PROGRESS ENERGY
FLORIDA, INC. TO REFUND CUSTOMERS \$143 MILLION**

FPSC DOCKET NO. 060658

DIRECT TESTIMONY OF

CLIFFORD WAYNE TOMS

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16

I. INTRODUCTION AND QUALIFICATIONS

Q. Please state your name and business address.

A. My name is Wayne Toms. My business address is 15760 West Power Line St.,
Crystal River, Florida 34428.

Q. Please tell us how you are employed and describe your background.

A. I am employed by Progress Energy Florida (“PEF” or the “Company”), currently
serving as the Manager of Shift Operations for the Crystal River fossil units. Prior to
this role, I was the operations and maintenance superintendent at Anclote Power
Plant, the superintendent of technical services for Crystal River fossil units, and the
training manager for Florida Power Corporation. I have a Bachelors of Science in
Human Resources and management and an MBA. I have been employed by PEF
since 1992.

1 **II. PURPOSE AND SUMMARY OF TESTIMONY**

2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22

Q. What is the purpose of your testimony?

A. I will explain the current and historical operation of Crystal River Units 4 and 5 (“CR4” and “CR5”) as part of PEF’s generation system. CR4 and CR5 are base load units and as such they are important to PEF’s generation fleet and to PEF’s customers. I will also discuss the generation output from these units, how these units have historically performed, and how they are expected to perform. I will explain that the historical and current performance and Company expectations for the performance of CR4 and CR5 are dependent on the quality and efficiency of our operation and maintenance of the units and the quality of the coal product put in the units.

 I will also describe the process that PEF uses when it considers burning a new type of coal in CR4 and CR5. From our perspective, with the operational obligations at the plant, we will require some demonstration of the probable performance impacts of any new coal and especially a new coal type at CR4 and CR5, so that we can evaluate those impacts and make a decision about the coal. Typically, this means a “test burn” needs to be conducted. I will explain why test burns are needed from an operational and safety perspective. I will also explain our goals with respect to any such test burn.

 Finally, I will discuss issues raised by the potential use of PRB coal blends at CR4 and CR5. These issues have been addressed by expert consultants retained by

1 the Company, first Sargent & Lundy and now Rod Hatt, but I will again provide a
2 perspective from fossil operations.

3

4 **Q. Are you sponsoring any exhibits with your testimony?**

5 **A.** Yes. I am sponsoring the following exhibits that I prepared or that were prepared
6 under my supervision and control, or they represent business records prepared at or
7 near the time of the events recorded in the records, which records it was a regular
8 practice for me or those who worked with me to keep to perform our responsibilities:

- 9 • Exhibit No. ____ (CWT-1), which is an aerial map of the Crystal River Energy
10 Complex; and
- 11 • Exhibit No. ____ (CWT-2), which are the original Babcock & Wilcox boiler
12 design documents for CR4 and CR5.

13 These exhibits are true and correct.

14

15 **Q. Please summarize your testimony.**

16 **A.** CR4 and CR5 are base load, coal-fired units that have historically operated at
17 overpressure to produce between a gross 750 megawatts (MW) and 770MW at full
18 capacity when called on to provide that level of capacity and energy to customers.
19 The original boiler and turbine design was 665MW gross energy production at full
20 capacity. The design and construction of the units, in particular the large boilers, and
21 the high quality, high Btu content bituminous coal historically used by PEF, have
22 allowed PEF to achieve these levels of gross energy production. Customers have

1 benefited from this level of production by receiving additional base load generation
2 capacity and energy at a lower relative cost to other generation on PEF's system.

3 We are, as a result, concerned with changes in the quality and type of coals for
4 CR4 and CR5. Such changes can impact the safe and efficient operations at the units
5 and their performance. Before coals with different qualities or of a different type than
6 what we have specified and used are burned, we will want to evaluate the impact of
7 those differences on the operations at and production in the units before making any
8 commitment to purchase such coals. This is particularly true with respect to sub-
9 bituminous coals from the Powder River Basin (PRB), which are dusty, volatile,
10 difficult to handle, low Btu content, and high moisture content coals. We will want to
11 know how these PRB coals affect our responsibility to safely and efficiently operate
12 the units, affect their commercial availability when called upon to produce energy,
13 and affect their production at between a gross 750MW and 770MW when called upon
14 to produce at full capacity to meet customer load.

15 There are safety issues, cost issues, and performance issues with PRB coals at
16 CR4 and CR5. Capital upgrades are necessary to safely and efficiently handle such
17 coals on site. Capital upgrades are also necessary to ensure that the coals can be
18 safely and efficiently burned in the units. De-rates or loss of load can be expected.
19 Finally, there will additional training of employees to handle PRB coals and
20 additional maintenance at all points on site affected by the PRB coals. Time is
21 required to implement the additional capital and maintenance necessary to safely and
22 efficiently handle the PRB coals and operate the units with PRB coal blends. An

1 estimate of the time to accomplish the necessary changes for PRB coals is between 18
2 months and 30 months.

3
4 **III. CR4 AND CR5 OPERATION**

5
6 **Q. What are Crystal River Units 4 and 5?**

7 **A.** CR4 and CR5 are two of four coal-fired units located at the Crystal River Energy
8 Complex. They are located north of the other units, coal-fired units 1 and 2 and unit
9 3, the nuclear unit, and thus are sometimes referred to as Crystal River North. They
10 were built and operational in 1982 and 1984, respectively, and have been providing
11 PEF and its customers with base load electrical capacity and energy ever since then.
12 An accurate aerial photograph of the Crystal River Energy Complex showing the
13 location of CR4 and CR5, as well as the other units and related facilities at the site, is
14 Exhibit No. ___ (CWT-1) to my testimony.

15
16 **Q. What are base load units?**

17 **A.** Base load units are those units that are called on first to meet the load or customer
18 demand for electrical energy on the system. They are called on first because they
19 have a relatively low incremental cost for producing electrical energy. All units are
20 placed in the dispatch stack and called on by the Energy Control Center (ECC) based
21 on the incremental cost of producing energy from the unit.

22 ECC is responsible for ensuring that the production of energy is equal to the
23 load, or demand for energy by PEF's customers, every hour of every day. The unit

1 with the lowest incremental cost will be called on first, followed by the next lowest
2 cost unit on the system, and so on until the customers' energy needs are met. CR4
3 and CR5 are very low in the dispatch stack, typically following only the nuclear unit.

4 Base load fossil units like CR4 and CR5 generally operate all hours over the
5 course of the year except for forced outages due to equipment issues or failures or
6 scheduled outages for maintenance.

7
8 **Q. When Units 4 and 5 are called on, how much electrical energy do they produce?**

9 **A.** Units 4 & 5 regularly produce at full capacity between 750MW and 770MW. These
10 are gross numbers, however, representing the total production of electrical energy at
11 full capacity. The units also supply the power to operate the units themselves and
12 provide power for use at the Crystal River Energy Complex. If these power needs are
13 accounted for, the production from the two units will typically produce about 735MW
14 and 732MW at full capacity. This is called the net MW production and is what PEF
15 customers receive.

16
17 **Q. What were the boilers for Units 4 and 5 designed to produce?**

18 **A.** The original Babcock & Wilcox design of the boilers and associated turbine was for a
19 gross production of 665MW for each unit at full capacity, under perfect conditions.
20 This design guaranty was based on a coal blend of western sub-bituminous coal and
21 eastern bituminous coal with a heating value of 10,285 Btu/lb. The Btu content per
22 ton measures the amount of energy that is derived from burning a ton of that coal. A

1 copy of the Babcock & Wilcox design documents is Exhibit No. ___ (CWT-2) to my
2 testimony.

3
4 **Q. How can PEF obtain up to 770MW from Units 4 and 5 at full capacity if the
5 design guaranty was only for 665MW at full capacity?**

6 **A.** The design guaranty for the CR4 and CR5 boilers was for an equal blend of
7 bituminous and western sub-bituminous coal. Bituminous coal has a higher Btu
8 content than western sub-bituminous coal. The boiler design took this lower Btu
9 content of western sub-bituminous coal into account by providing for larger boilers
10 than you find in a boiler design for only bituminous coal. In other words, CR4 and
11 CR5 were designed and built with over-sized boilers by industry standards for
12 pulverized coal units that burn only bituminous coals.

13 Other elements of the units were also included in the design for this same
14 reason, namely to accommodate burning the design blend of sub-bituminous and
15 bituminous coals, and many but not all of these elements were included in the
16 construction of the two units. These attributes of CR4 and CR5, in particular the
17 large boilers, set the units apart from other pulverized coal units of the same vintage
18 that were designed with smaller boilers to handle bituminous coals. The Company
19 can burn large quantities of bituminous coal in the boilers because they are large
20 boilers and, as a result, the Company can generate more thermal energy by burning
21 more coal than other boiler units of the same vintage that were designed only for
22 bituminous coals.

1 Another important contributing factor for the Company to obtain up to
2 770MW at full capacity in the units is the quality of the coal that PEF has burned at
3 CR4 and CR5. PEF has typically burned a high Btu, low moisture, low volatility,
4 bituminous compliance coal with good ash characteristics. For example, only
5 recently has the Btu content dropped below 12,000 Btu/ton for the bituminous coals
6 used at the plant, and historically the units have received bituminous coals above
7 12,500 Btu/ton. A higher Btu/ton content coal means more energy is generated per
8 ton of coal burned than a lower Btu/ton content coal. CR4 and CR5 have also
9 received low moisture bituminous coals, which means less thermal energy is
10 necessary to dry and burn the coals, which also contributes to the energy per ton of
11 coal burned. These quality characteristics have been incorporated into the coal
12 specifications for the units and there is no doubt that a quality coal product, in
13 particular a high Btu, low moisture content coal, plays a significant role in the ability
14 of CR4 and CR5 to exceed their design basis in energy production.

15 With more thermal energy generated by the boilers from large quantities of
16 high quality bituminous coals, the CR4 and CR5 units are capable of operating at
17 “overpressure” on a sustained basis, thereby producing more steam and more energy.
18 CR4 and CR5 typically operate at overpressure at full capacity and have done so for
19 years. The result is sustained energy production at full capacity of between 750 and
20 770MW.

21 If PEF were burning a blend of even a high quality, high bituminous coal --
22 for example, a 12,500 Btu/ton bituminous coal -- and a high, 8,800 Btu/ton sub-
23 bituminous coal at CR4 and CR5, however, the Company could not go to

1 overpressure and generate the gross 750MW to 770MW at full capacity that it has
2 historically produced at the units.

3

4 **Q. What do you mean by “overpressure?”**

5 **A.** Overpressure is the term we use to designate when we have deviated from the design
6 bases pressure setpoint of 2,400 pounds pressure at the first stage steam turbine.

7 When we have all the critical equipment in operation, we are allowed by Babcock &
8 Wilcox to operate the boiler at 105 percent of design bases pressure setpoint.

9 Applying 105 percent times 2,400 pounds pressure equals 2,520 pounds pressure at
10 the first stage turbine blades. Once this pressure is reached by the boiler and turbine,
11 the units are producing around 750MW. As I mentioned though, all critical
12 equipment must be operable. We must have all six pulverizers, both condensate
13 pumps, both high pressure and low pressure heater drain pumps, and all eight feed
14 water heaters in service to be able by the technical manual to go to overpressure.

15

16 **Q. Is it safe?**

17 **A.** Absolutely. It merely reflects the ability to operate above what was considered
18 “normal” operation of the units but still well within the design capabilities from a
19 safety perspective. The units have been consistently operating at overpressure at full
20 capacity for years; in fact back to the late 80’s, and producing more energy than
21 contemplated under the original design.

22

1 Q. You mentioned that some but not all of the design elements were included in
2 CR4 and CR5. Was something included in the design that was needed that was
3 not built?

4 A. No, nothing that was needed to operate the units safely and efficiently in the design
5 documents for the units was excluded when the units were built. However, several
6 years passed between the design and construction of the units. During that time, I
7 understand that the Company determined a sufficient supply of bituminous coals
8 existed and that it was economical to commence operations with bituminous coals.
9 As a result, certain design elements that were necessary only if the units commenced
10 operation with an equal blend of bituminous and sub-bituminous coals, such as, for
11 example, a seventh pulverizer and the inert steam to the pulverizer, were not built.

12 This is not unusual. The actual construction of power plants often differs
13 from the design because any number of factors can affect the expected actual
14 operation of the units and lead to construction changes. There is no reason to
15 construct and charge the utility customers for something in the design of the units, for
16 example, that is not expected to be needed for the actual safe and efficient operation
17 of the units.

18 There is, however, space at CR4 and CR5 to add these additional design
19 elements should the Company decide to go to operation with an equal blend of sub-
20 bituminous and bituminous coals. But the units were not constructed with everything
21 that would be needed to safely and efficiently operate with an equal blend of sub-
22 bituminous and bituminous coals because that was not the expected operation of the
23 units at the time of construction.

1 **Q. Has PEF relied on the extra megawatts of energy production from CR4 and CR5**
2 **for its generation system?**

3 **A.** Yes. The Company has three expectations for the CR4 and CR5 units. First, we are
4 expected to safely and efficiently handle the coal and operate the units. Our
5 employees are our most valuable resource so their safety is a primary concern. Of
6 course, safety issues can affect unit operation as well if a problem with safely
7 handling the coal product requires us to take the unit off line to deal with the problem.

8 Second, the units are expected to be commercially available all the time when
9 they are not out of service for maintenance. This means that they are expected to
10 respond when called upon by the ECC for service. As I mentioned, the ECC controls
11 the order of bringing units on line and up to the required production to meet the load
12 24 hours a day, every day of the year. ECC will call on units based on their
13 incremental cost of energy production. Because CR4 and CR5 have a low relative
14 incremental cost of producing energy to most other units on PEF's generation system,
15 they are expected to be commercially available most of the time during the course of
16 the year. This is what it means for them to be base load units.

17 Additionally, the Company expects CR4 and CR5 to produce energy at
18 between 750MW and 770MW when called on by ECC. More recently the units have
19 been generating 768MW and 763MW, respectively, when called on by ECC for
20 commercial availability at full capacity. This gross energy production is necessary
21 for the Company to meet its expected net production. I understand that the
22 Company's resource planning group relies on the production today of 735MW and
23 732MW, respectively, from CR4 and CR5. These are the net energy production

1 numbers if the units produce 768MW and 763MW, respectively, on a gross basis at
2 full capacity.

3 It is my obligation as the Manager of Shift Operations for the fossil units,
4 including CR4 and CR5, to ensure that the Company's expectations for CR4 and CR5
5 are met.

6
7 **Q. What do you need to satisfy the Company's expectations for CR4 and CR5?**

8 **A.** I must continue to maintain and operate the units as efficiently and effectively as we
9 have been doing for years to continue to meet the expectations for base load energy
10 production that the Company has for CR4 and CR5. Any changes in the coal product
11 or units themselves that alter the maintenance and operation of the units will have an
12 impact on the ability to maintain the energy production that is expected from the
13 units.

14 The quality of the coal product will have an impact on the ability to meet the
15 expectations for energy production from CR4 and CR5. Changes in the Btu content,
16 moisture content, or other characteristics of the coal procured for the units will affect
17 the maintenance, operation, and energy production at CR4 and CR5. We know, for
18 example, that if the Btu content of the coal burned at CR4 and CR5 falls below a
19 range between 11,000 Btus/ton and 11,300 Btus/ton, we will not be able to operate at
20 overpressure and meet the expected energy production requirements at full capacity.
21 Other changes in the quality of the coal burned at CR4 and CR5, such as higher
22 moisture content than specified and generally expected, will also have an adverse
23 impact on the energy production from the units. As a general rule, then, from an

1 operational perspective we prefer to have a coal product that more closely matches
2 the typical specifications that we have historically burned at the units.

3

4 **Q. Do customers benefit if the Company's expectations for CR4 and CR5 are met?**

5 **A.** Yes, they do. As I have explained, CR4 and CR5 are base load units because they are
6 relatively more economical than other generation alternatives on PEF's system.

7 Therefore, more production from a base load unit, like CR4 and CR5, to meet the
8 load means less energy production is needed from more expensive production sources
9 available to PEF to meet customer energy needs. By producing energy at
10 overpressure at full capacity on a consistent basis, PEF has provided its customers
11 with a more economical source of energy production than they otherwise would have
12 had at the production level the units were originally designed to achieve at full
13 capacity.

14

15 **IV. CHANGES IN COAL PRODUCTS AT CR4 AND CR5**

16

17 **Q. Are you concerned about changes in the type and quality of coal products for**
18 **CR4 and CR5?**

19 **A.** Yes. From an operational perspective, we always want to understand what is being
20 procured for CR4 and CR5 and how it will affect the maintenance and operation of
21 the units and the production of energy from the units. So, we will want to know what
22 the supplier considers to be the "typical" quality of the coal offered and how that
23 "typical" coal offered varies from our coal specifications and historical experience.

1 We have even been wary when existing suppliers of bituminous coals switch mines or
2 new bituminous suppliers are added. In those situations, we have asked for smaller
3 shipments of their coals to be brought on site and evaluated those limited shipments
4 before the full shipments of what has been purchased is brought on site. This is
5 because there can be variations in the quality of the coal product provided, even from
6 existing suppliers with new mines, from what they have provided to the Company in
7 typical specifications for their coal products.

8 When the quality of the coal or type of coal changes on the typical
9 specifications offered by the supplier from what we have specified and historically
10 used, we will want to evaluate the impact of those changes on the units and the
11 production from those units before any commitment is made to purchase coal of that
12 quality or type. We have required this evaluation even for significant changes in the
13 quality of bituminous coals. In the past few years, we have been offered import
14 bituminous coals that had a lower Btu and higher moisture content from our
15 specification and experience with domestic bituminous coals. Before those low Btu
16 content, higher moisture content import coals were purchased we requested and
17 performed a test burn of the coals at one of the units to evaluate the impact of those
18 coals on operation and energy production.

19
20 **Q. What are “test burns?”**

21 **A.** A test burn is a process where PEF obtains a small quantity of a new quality or type
22 of coal that it is considering burning on a long-term basis and burns that coal in one
23 of the units for which the coal is being considered. During this time, PEF monitors

1 handling and safety issues, unit operation and performance, and environmental
2 emissions. The test burn can either be on a short-term or long-term basis. Typically,
3 when first evaluating a coal product of different quality or type, a short-term test of
4 two to three days will be conducted. The purpose of a short-term test burn is to see if
5 any immediate handling, performance, environmental, or safety issues are present.
6 Short-term test burns are also sometimes required for environmental permitting.

7 A long-term test burn can last anywhere between three and six months. The
8 purpose of a long-term test burn is to see how the unit will perform over a sustained
9 period of operation and under variations in environmental conditions that the units
10 typically experience over a longer period of time. With long-term test burns, PEF can
11 get a good idea of whether a new type of coal will be suitable for PEF to use in the
12 plants on an extended basis.

13
14 **Q. Why is it important for PEF to conduct test burns prior to introducing a new**
15 **type or quality of coal into the units?**

16 **A.** Certain equipment in the plants, such as the boiler and electrostatic precipitator for
17 example, are especially sensitive to changes in coal quality and types. It is important,
18 therefore, for PEF to know how the plants will react to new types and qualities of coal
19 on a short- and long-term basis. New coal products may cause de-rates (or loss of
20 energy production or load) or forced outages in the units. Either way, the units are
21 not producing the energy that is expected from them. Test burns allow PEF to
22 identify any such operational and production issues prior to making a full-scale
23 commitment to switch to or use a new coal product.

1 The Company further needs to know if changes in the quality or type of coal
2 will affect the cost of handling the coal or operating the units. Coals with higher
3 moisture content than historically specified and used at the units, for example, create
4 handling and operational issues. Additional effort will need to be made on the coal
5 piles in handling the coal to assist in drying it out, and more heat will need to be used
6 at the pulverizers to dry the coal out before it is blown into the boilers to be burned.
7 This will increase the maintenance costs and increase the wear and tear on certain
8 equipment, like the pulverizers, in the units. These impacts are important to know
9 because they may lead to additional forced outage and maintenance time and cost.

10 Test burns can also be important from a safety perspective because certain
11 types of coal require different handling and use procedures. This is particularly true
12 for sub-bituminous coals from the PRB, which are dustier, more volatile, and thus
13 more difficult to handle from a safety standpoint than bituminous coals. Test burns
14 allow PEF to become accustomed to such changes in use and handling procedures,
15 and to adjust them as necessary from actual experience, prior to full-scale use.

16
17 **Q. What are your goals with respect to test burns for new coal products at CR4 and**
18 **CR5?**

19 **A.** I want to know how the new coal product is going to affect my responsibilities to
20 safely and efficiently operate CR4 and CR5, make CR4 and CR5 commercially
21 available for ECC, and to achieve full capacity production at between 750MW and
22 770MW when called upon to do so to meet customer load. If there is an impact on
23 our ability to safely and efficiently handle the new coal product, or our ability to

1 operate the plants and meet our performance obligations, we would expect our
2 concerns and costs to be taken into account in any decision weighing the costs and
3 benefits of using the new type or quality of coal at CR4 and CR5.

4
5 **V. PRB COALS AT CR4 AND CR5**

6
7 **Q. Are you aware that the Company has considered PRB coals for CR4 and CR5?**

8 **A.** Yes. I am aware of and I have had some involvement with the Company's evaluation
9 of a possible switch to a PRB coal blend at Crystal River.

10
11 **Q. Was a test burn conducted for PRB coals?**

12 **A.** Yes, a short-term test burn was conducted at CR5 with a small blend of PRB with
13 bituminous coals in May 2006. I also am aware of an earlier test burn at CR4 in 2004
14 using a blend of PRB and bituminous coals.

15
16 **Q. Has the Company evaluated the use of PRB coals at CR4 and CR5?**

17 **A.** Yes. The Company has designated internal engineers and other employees from
18 various operational groups in the Company to focus on evaluating the issues
19 surrounding the use of a PRB blend of coal at CR4 and CR5, and the Company hired
20 an outside consultant, Sargent & Lundy, to assist the Company in this evaluation. I
21 further understand that the Company has hired a recognized PRB coal expert, Mr.
22 Rod Hatt, to look at the issues surrounding the use of PRB coals at CR4 and CR5.
23 The retention of such experts to assist the Company in evaluating potential fuel and

1 other changes that impact the operation and performance of the Company's fossil
2 units is typical Company practice and consistent with the utility industry practice.

3

4 **Q. What do you know about PRB coals?**

5 **A.** I know that PRB coals have different qualities from the bituminous compliance coal
6 products we are used to handling and burning at CR4 and CR5 that will present a
7 number of safety, handling, operational, and performance issues for us at CR4 and
8 CR5. PRB coals are more volatile and dustier, they have a higher moisture content
9 and are more susceptible to absorbing moisture, they have a lower Btu content, and
10 they have a lower ash quality than the bituminous coal products we have historically
11 used at CR4 and CR5.

12

13 **Q. What are your issues with PRB coals?**

14 **A.** I have a number of issues with the use of PRB coals at CR4 and CR5. First, the
15 volatility and dustiness of PRB coals presents significant safety and handling issues
16 for the operational group at CR4 and CR5. PRB coals can spontaneously combust.
17 As a result, additional care and maintenance will have to be taken with the PRB coals
18 from the moment they arrive on site at the barge unloader, to their placement on the
19 conveyors to the north yard for blending, to the coal piles and blending operations,
20 and to their placement on conveyors to the units for storage and burning. As you can
21 see from Exhibit No. ___ (CWT-1) to my testimony, the use of PRB coals in CR4 and
22 CR5 would involve nearly the entire Crystal River site.

1 This is a safety issue and a cost issue. We would have to improve the barge
2 unloader, conveyors, and transfer stations on the conveyors to suppress the dust and
3 control spillage. We would have to have additional employees trained specifically in
4 handling PRB coals to monitor and control for dust and spillage to prevent potential
5 fires. We would also need additional equipment and trained employees to monitor
6 and take care of any PRB coal pile for the same reason. This would require constant
7 packing of the PRB coal on the pile and maintenance of the pace of the PRB coal use
8 in the yard and to the plants.

9 Our current equipment on site is inadequate to handle PRB coal piles and
10 blend PRB coals. The existing dozers and stacker reclaimers were acquired and are
11 used for dealing with less volatile and dusty bituminous coals. Stacker reclaimers are
12 large pieces of equipment with spinning buckets to move coal from piles onto
13 conveyor belts. The stacker reclaimers are not and never were intended to be
14 precision blending equipment since their real purpose is simply to move coal quickly
15 from the piles on the ground onto the conveyors. We would need equipment for pile
16 maintenance and blending specifically designed for handling and blending PRB coals.

17 I have similar safety and cost issues when the PRB coal is transported to the
18 cascade rooms in the units and then to the silos until the coals can be sent to the
19 pulverizers for grinding and burning in the units. Dust and fire suppression upgrades
20 and additional maintenance by employees trained to deal with PRB coals are
21 necessary there too in order to prevent PRB dust and coals from spontaneously
22 combusting and causing fires.

1 There are also a number of operational and performance concerns with
2 burning a PRB coal blend. The higher moisture and lower Btu content of PRB coals
3 means that there will be problems pushing enough coal through the pulverizers,
4 drying and crushing it, and blowing it into the boilers on a consistent basis to
5 maintain our load at overpressure. We can expect de-rates then from the units if an
6 equal blend of PRB coals and bituminous coals are used. Also, the PRB coals are a
7 higher slagging and fouling coal than bituminous coals, which means that we may
8 also suffer de-rates from additional time off line to clean the boilers. These issues
9 also mean that all boiler-related equipment in the units used to generate energy, from
10 the pulverizers to the soot blowers to the boilers themselves, will have to work harder
11 and require more maintenance because PRB coals are being used. This adds
12 additional wear and tear and additional maintenance costs to these internal parts of
13 the units if PRB coals are used.

14 These are some of the issues that I am concerned about if PRB coals are used
15 at CR4 and CR5. Sargent & Lundy and Mr. Hatt have addressed some of these same
16 issues, and additional issues, in greater detail. In sum, though, I can say that PRB is a
17 maintenance and operational nightmare from my perspective as the person
18 responsible for the operation and performance of CR4 and CR5. In addition, the units
19 will be scrubbed in 2009 and 2010 so I am not sure if it makes sense to continue to
20 consider PRB coals for CR4 and CR5. With scrubbers on the units we will be able to
21 move to higher sulfur coals and burn them at the units.

22

1 Q. **Have you reviewed the modifications that Mr. Hatt says are necessary to safely**
2 **handle and burn PRB coals at the Crystal River site?**

3 A. Yes, I have.
4

5 Q. **How would you go about making these modifications if you had to do them?**

6 A. Before making any modifications to the coal handling and operational systems at CR4
7 and CR5, a significant amount of planning must be done to ensure that the work can
8 be done efficiently so that the base load units are taken off line for as short a time as
9 possible. Scheduled maintenance for the units, for example, occurs during the
10 “shoulder,” not the “peak” months of the year. The “peak” months are the months
11 where the customer demand for energy is at its highest, in the winter and summer
12 months, and the units are needed to produce energy to meet the load. The “shoulder”
13 months occur in the spring and fall when temperatures and conditions in Florida are
14 mild and not all generation units are needed to meet customer demand for energy.
15 Still, care is taken to ensure that both base load units are not down at the same time,
16 even in the “shoulder” months, because they are still base load units and generally
17 needed whenever there is customer demand for energy on the Company’s system.

18 As a result, the necessary work to handle and operate with PRB coals at CR4
19 and CR5 will probably occur sequentially at the units so that they are not off line at
20 the same time. Additionally, there are other operating units at the site, including the
21 nuclear unit, which present issues regarding the scheduling of work for CR4 and CR5
22 to handle and operate on PRB coals. Careful planning will be necessary to ensure
23 that any work for CR4 and CR5 does not interfere with the operation of these other

1 units, which are also base load units. The fact that there is a nuclear unit on site will
2 also present security issues that must be taken into account in any construction project
3 at the site requiring off-site employees, material, and equipment being brought onto
4 the site.

5 Finally, there are always the issues of including the time to design or identify,
6 order, and purchase necessary equipment and material for the work and to identify
7 and contract for the necessary labor and contractors. All of this needs to be included
8 in developing any timeline for the work contemplated to ensure that the PRB coals
9 can be safely and efficiently handled and burned in the CR4 and CR5 units.

10

11 **Q. How long would it take to make the modifications?**

12 **A.** No determination has been made because no decision has been made for a fuel
13 switch. The Company, however, has engaged in other large construction and
14 maintenance projects at the fossil units at the Crystal River Energy Complex in the
15 past and, based on that experience, I have provided a rough estimate of the time to
16 make the modifications recommended by Mr. Hatt to the units in order for them to
17 handle and burn PRB coals at the site. That estimate is anywhere from 18 months to
18 30 months.

19

20 **Q. Does this conclude your testimony?**

21 **A.** Yes.

22

CRYSTAL RIVER ENERGY COMPLEX



BARGE UNLOADER

COAL STAGING AREA

CR 182

500KV SWITCHYARD

230KV SWITCHYARD

CR 485


CRUSHER HOUSE

NORTH COAL YARD

CR3

TRAIN UNLOADER

RAIL LOOP



Instructions

for the

Care and Operation

of

Babcock & Wilcox
Equipment

furnished on Contract

RB-588

for

Florida Power Corporation
Crystal River Plant
Unit 4



UNIT DESCRIPTION

PLANT

This unit is installed as Unit No. 4 at the Crystal River Plant located near Crystal River, Florida. Plant elevation is 11 feet above sea level.

The unit supplies steam to a GE turbine rated at 665 MW. The consulting engineer is Black & Veatch, Kansas City, Missouri.

BOILER

This is a semi-indoor, balanced draft Carolina Type Radiant Boiler designed for pulverized coal firing. The unit has 54 Dual-Register burners arranged in three rows of nine burners each on both the front and rear walls. Furnace dimensions are 79 feet wide, 57 feet deep, and 201 feet from the centerline of the lower wall headers to the drum centerline. The steam drum is 72 inches ID.

The maximum continuous rating is 5,239,600 lb/hr of main steam flow at 2640 psig and 1005° F at the superheater outlet with a reheat flow of 4,344,700 lb/hr at 493 psig and 1005° F with a normal feedwater temperature of 546° F. This is a 5% overpressure condition. The full load rating is 4,737,900 lb/hr of main steam flow at 2500 psig and 1005° F with a reheat flow of 3,959,800 lb/hr at 449 psig and 1005° F with a normal feedwater temperature of 535° F. Main steam and reheat steam temperatures are controlled to 1005° F from MCR load down to half load (2,368,900 lb/hr) by a combination of gas recirculation and spray attenuation.

The unit is designed for cycling service and is provided with a full boiler by-pass system. The unit can be operated with either constant or variable turbine throttle pressure from 63% of full load on down.

The design pressures of the boiler, economizer, and reheater are 2975, 3050, and 750 psig respectively.

Steam for boiler soot blowing is taken off the primary superheater outlet header. Steam for air heater soot blowing is taken off the secondary superheater outlet.

SCOPE OF SUPPLY

The major items of equipment supplied by B&W include:

- RBC unit pressure parts including boiler, primary and secondary superheater, economizer, and reheater.
- Fifty-four Dual-Register burners and lighters.
- Six MPS-89GR pulverizers and piping to burners.
- By-pass system including valves and piping.
- Two stages of superheat attenuators (first stage tandem) and one stage of reheat attenuation (2 nozzles); nozzles only, no block or control valves or spray water piping.
- Three Rothemuhle air heaters (one primary and two secondary).
- Ducts from secondary air heaters to windbox.

RB-588 Sept 81

PER-FUEL-002658



Progress Energy

Docket No. 060658
Progress Energy Florida
Exhibit No. _____ (CWT-2)
Page 2 of 13



RB-588 Sept 81

- Primary air system: two TLT centrifugal PA fans and ducts from fans to pulverizers.
- Gas recirculation system: one TLT centrifugal GR fan, one dust collector and flues.
- Six Stock gravimetric coal feeders and drives.
- Bailey burner controls.
- Safety valves and ERV.
- Brickwork, refractory, insulation and lagging (BRIL).
- Seal air piping and fans.
- Erection.
- Recommended spare parts.

FUEL

The guarantees for this unit are based on firing a 50/50 blend of Eastern bituminous and Western sub-bituminous coal. The performance coal is classified as high slagging and medium fouling. Performance was also checked on Illinois deep-mined coal which is classified as severe slagging and high fouling. The furnace and convection pass are designed for a severe slagging and severe fouling coal.

Ultimate Analysis: % by Weight

	Performance	Illinois
Ash	7.90	13.00
Sulfur	0.49	4.20
Hydrogen	3.90	4.40
Carbon	58.80	62.00
Chlorine	0.03	0.02
Water	18.50	10.00
Nitrogen	1.10	1.38
Oxygen	9.28	5.00
Total	100.00	100.00
Higher Heating Value	10285 Btu/lb	11000 Btu/lb

FUEL AS FURNED				PREDICTED PERFORMANCE			EQUIPMENT PER UNIT	
ANALYSIS				2368.9	4737.9	5239.6	TYPE RADIANT	
50/50 BLEND, EASTERN & WESTERN				2063.8	3959.8	4344.7	SIZE RBC 57 HB	
KIND				PC	PC	PC	DESIGN PRESSURE - 2,975 PSIC	
CLASS				CONT.	CONT.	CONT.	WATER COOLED SCREEN (CIRCUMFERENTIAL)	
GROUP				35	20	20	WATER COOLED (PROJECTED) 48,736	
MINE				45	54	54	SUPERHEATER (CIRCUMFERENTIAL)	
SEAM				3348	6053	6581	SUPERHEATER (PROJECTED) 46,442	
DISTRICT				3615	6367	6886	TOTAL FURNACE HEATING SURFACE 95,178	
COUNT							SATURATED (CIRCUMFERENTIAL) 10,386	
STATE							SUPERHEATER (CIRCUMFERENTIAL) 243,015	
SIZE							REHEATER 1 (CIRCUMFERENTIAL) 331,919	
URRIBABILITY				48			REHEATER 2 (CIRCUMFERENTIAL)	
SURFACE MOISTURE, %				PERF.			ECONOMIZER 46,519	
ASH SOFT. TEMP., F (REDUCING)							TOTAL CONVECTION HEATING SURFACE 674,039	
MOISTURE, TOTAL				18.5			TOTAL FURN. & CONV. PRESSURE PART, HTC, SURF. 729,217	
VOLATILE MATTER				31.0			FLAT PROJECTED FURNACE HEATING SURFACE	
FIXED CARBON				42.6			TO FACE OF PLATES (24" CTR) 73,581	
ASH				7.9			TO FACE OF CONVECTION SURFACE 101,501	
TOTAL				100.0			FURNACE VOLUME, CU FT 734,185	
FUEL							TYPE ROTHENHILF REGENERATIVE NO. 1 - PRI, 2 - SEC.	
WT.	BIT.	SUB-BIT.	WT.				TOTAL HEATING SURFACE, SQ FT PRI - 250,522	
10.0	5.0		7.90				SEC. - 824,850	
0.5	0.48		0.49				PRI. SIZE - 10.6 Vn 56	
4.4	3.4		3.90				SEC. SIZE - 12.5 Vn 68	
69.0	48.5		58.60				TYPE DUAL REGISTER	
							NO. 54	
							TYPE MPS SIZE BSG NO. 6	
							CAPACITY OF 5 PULV. IS 5239 X LB STEAM/HR BASED ON 68 GR/HR	
							10,285 BTU COAL AT 65 # THRU 200 U.S.S. SIEVE	
							FOR 0.924 LB COAL/PULV. - MR AT 65# THRU 200 U.S.S. SIEVE MIN. GRIND	
							IS 42 MAXIMUM TOTAL MOISTURE IS 18% REQUIRING 570 F AIR	
							MAIN STEAM BY SPRAY ATTENUATION	
							REHEAT BY GAS RECIRCULATION	
							MEMBRANE WALLS	
							BALANCE DRAFT	
							NO. DESCRIPTION AT RATE	
							FLORIDA POWER CORP.	
							CRYSTAL RIVER, UNIT #4	

PER-FUEL-003738

DWFP 31/51-3

THE BABCOCK & WILCOX COMPANY
 FOSSIL POWER GENERATION DIVISION
 CONTRACT INFORMATION SHEET

A.O.

TURBINE								
MFG: G.E.								
NAME-PLATE RATING: 665,000 KW								
HEAT BALANCE — PERFORMANCE DESIGN DATA								
SPECIFIED BY: <input checked="" type="checkbox"/> PURCHASER <input checked="" type="checkbox"/> TURBINE <input type="checkbox"/> BOILER DESIGN <input type="checkbox"/>								
4	RATING: PERF. AT TERMINALS	GUAR. LOAD	PEAK LOAD	MAX. CONTINUOUS LOAD	LOW LOAD CONTROL	20% O. Guar.		MAX CONT HEAT INPUT
5			— HRS.	LOAD				
6	FUEL: FUEL QUANTITY	Blend		Blend	Blend	Blend		
	MLB/HR							
7	MAIN STEAM FLOW	4737.9		5239.6	2368.9	947.6		
	MLB/HR							
8	OPR. PRESS. @S.H. OUT.	2500		2640	2425	2406		
	PSIG							
9	STEAM TEMP. @S.H. OUT.	1005		1005	1005	990		
	°F							
10	1ST REHT. STEAM FLOW	3959.8		4344.7	2063.8	842.1		
	MLB/HR							
11	1ST REHT. ENTR. PRESS.	474		520	240	84		
	PSIG							
12	1ST REHT. ENTR. TEMP.	598		604	528	410		
	°F							
13	1ST REHT. OUT. PRESS.	449		493	227	79		
	PSIG							
14	1ST REHT. OUT. TEMP.	1005		1005	1005	950		
	°F							
15	1ST REHT ENTR. ENTH	1298.7		1299.2	1279.3	1232.6		
16	2ND REHT. STEAM FLOW							
	MLB/HR							
17	2ND REHT. ENTR. PRESS.							
	PSIG							
18	2ND REHT. ENTR. TEMP.							
	°F							
19	2ND REHT. OUT. PRESS.							
	PSIG							
20	2ND REHT. OUT. TEMP.							
	°F							
21	FEEDWATER ENTH.							
	BTU/LB							
22	FEEDWATER TEMP.	534.8		546.4	459.4	372.3		
	°F							
23	FEEDWATER FLOW	4737.9		5239.6	2368.9	947.6		
	M LB/HR							
24	S.H. SPRAY WATER TEMP.	355		362	310	265		
	°F							
25	PRESS. @ SOURCE							
26	1ST REHT. SPRAY WATER TEMP.	355		362	310	265		
	°F							
27	PRESS. @ SOURCE							
28	2ND REHT. SPRAY WATER TEMP.							
	°F							
29	PRESS. @ SOURCE							
30	QTY., TYPE & SIZE CUST. FEED PUMPS: QTY., TYPE & SIZE CUST. START UP PUMPS:							
STEAM TEMPERATURE CONTROL								
31		METHOD			RANGE		REMARKS	
32	MAIN STEAM	Spray Attenuation			2368.9M To 5239.6M			
33	1ST REHT.	Spray Attenuation and Gas Recirculation			2368.9M To 5239.6M		45	
34	2ND REHT.							
SPECIAL PERFORMANCE OR DESIGN REQ'MNTS. PERF. CURVES & DATA SHEETS								
<input type="checkbox"/> NOT REQD. <input checked="" type="checkbox"/> REQD.: SEE CIS-14.0 SEE CIS-100 SERIES								
REL. NO. AND DATE 1. 5-25-78 2. 6-5-79				CONTRACT NO.		FILE NO.		
3 4-15-80				334-0588		RB-588		

UNIT PERFORMANCE DESIGN DATA


PEP-FUEL-003740

FPGD CIS-13.0 Q

THE BABCOCK & WILCOX COMPANY
 FOSSIL POWER GENERATION DIVISION
CONTRACT INFORMATION SHEET

BWFP 33027-3

A.O.



PIPING DESIGN CONDITIONS		
LOC.	PRESS	TEMP
ATTEMP	2975	850
SOURCE	"	"
ELEVATIONS		
LOCATION	ELEVATION	
ATTEMP NOZ	321'6"	
B&W FEED T	225'9"	
SOURCE	"	
ATTEMP SYSTEM VALVES		
VALVE	TYPE	CIS
c	CONTROL	CUST
b	BLOCK	"
i	ISOLATION	"
k	CHECK	"

18	FUEL			P.C.		P.C.	
19	MAIN STEAM FLOW	MLB/HR	5240 (MCR)		4738 (GOAR)		
20	AUXILIARY STEAM FLOW	MLB/HR					
21	SPRAY WATER TEMPERATURE	F.	362		355		
22				Installed Capacity		Installed Capacity	
23				Min.	Max.	Capacity	Min.
24	TOTAL SPRAY WATER FLOW AT SOURCE	MLB/HR	79.3	432.0	641.6	107.9	530.5
25	SPRAY WATER FLOW THIS ATTEMPERATOR / NOZZLE	MLB/HR	26.2	108.0	117.4	26.9	132.6
26	SPRAY WATER PRESS. AT SOURCE (Based on following)	PSIG *					
27	DRUM PRESSURE	PSIG	2829	2829	2829	2655	2655
28	ECONOMIZER ΔP (Incl. Static Head)	PSI	71.2	71.2	71.2	63.9	63.9
29	FEED VALVES AND PIPING ΔP (Incl. Static Head)	PSI	12.7	12.7	12.7	10.1	10.1
30	EXPECTED PRESS AT B&W FEED INLET TERMINAL	PSIG	2912.9	2912.9	2912.9	2729	2729
31	STEAM PRESSURE AT ATTEMPERATOR	PSIG	2785	2785	2785	2619	2619
32	ΔP THRU WATER NOZZLE NOTE 4	PSI	1	35.8	35.8	2.2	51
33	REQ'D SPRAY WATER PRESS AT ATTEMP INLET	PSIG	2786	2820.8	2820.8	2621.2	2670
34	PRESS DROP AVAIL FOR ATTEMP. SYSTEM (26-33)	PSI *					
35	STATIC HEAD, SOURCE TO ATTEMP. NOZZLE.	PSI *					
36	PRESS DROP AVAIL FOR PIPING AND VALVES (34-35)	PSI *					
37	ΔP B&W PIPING	PSI	0	0	0	0	0
38	ΔP CUST PIPING	PSI *					
39	TOTAL PIPING LOSS	PSI *					
40	PRESS DROP AVAIL FOR VALVES (36-39)	PSI *					
41	ΔP B&W VALVES (Excluding control valve)	PSI	0	0	0	0	0
42	ΔP CUST VALVES (Excluding control valve)	PSI *					
43	TOTAL VALVE LOSS (Excluding control valve)	PSI *					
44	PRESS DIFF. ACROSS CONTROL VALVE (40-43)	PSI *					
45	MIN. REQ'D PRESS DROP ACROSS CONTROL VALVE	PSI	40	155	195	40	242

Notes

- * Indicates information to be completed by customer. → SUGGESTED CONTROL VALVE ΔP
- Piping and valves to be sized for design capacity.
- Control valve internals may be sized for "Installed maximum capacity" provided internals suitable for design capacity may be installed in the control valve body.
- DESIGN CAPACITY NOZZLE PRESSURE DROP IS BASED ON REDRILLING ORIFICE TO SIZE SHOWN ON CIS 37.00

ATTEMPERATOR TYPE: SINGLE STAGE TANDEM FIRST STAGE TWO STAGE

ATTEMPERATOR IDENTIFICATION: DOWNSTREAM (1st in Control) FIRST STAGE (1st in Control)


UPSTREAM (2nd in Control) SECOND STAGE (2nd in Control)

REL. NO. AND DATE: 4(3-19-80) 5(4-24-80) CODE NO. 334-0588 COMP. NO. RB-588 FILE NO.

THE BABCOCK & WILCOX COMPANY
 FOSSIL POWER GENERATION DIVISION
CONTRACT INFORMATION SHEET

BWFP 33027-3

A.C.



PIPING DESIGN CONDITIONS		
LOC.	PRESS	TEMP
ATTEMP	2975	850
SOURCE	*	*
ELEVATIONS		
LOCATION	ELEVATION	
ATTEMP NOZ	321'-6"	
B&W FEED T	225'-9"	
SOURCE	*	
ATTEMP SYSTEM VALVES		
VALVE	DESIGN	CIS
c CONTROL	CUST	
b BLOCK	"	
i ISOLATION	"	
k CHECK	"	

18	FUEL								
19	MAIN STEAM FLOW	MLB/HR		P.C.		P.C.			
20	AUXILIARY STEAM FLOW	MLB/HR		2369 (RHCL)		2369 (RHCL-V.P)			
21	SPRAY WATER TEMPERATURE	F		310		310			
22				Installed Capacity	Design Capacity	Installed Capacity	Design Capacity		
23				Min.	Max.	Min.	Max.		
24	TOTAL SPRAY WATER FLOW AT SOURCE	MLB/HR	239.8	398.5	493.2	312.4	466.8	561.6	
26	SPRAY WATER FLOW THIS ATTEMPERATOR / NOZZLE	MLB/HR	59.9	97.6	99.2	75.5	98.1	99.1	
27	SPRAY WATER PRESS. AT SOURCE (Based on following)	PSIG *							
27	Boiler DRUM PRESSURE	PSIG	2446	2446	2446	1960	1960	1960	
28	Pres. ECONOMIZER ΔP (Incl. Static Head)	PSI	40.3	40.3	40.3	40.3	40.3	40.3	
29	FEED VALVES AND PIPING ΔP (Incl. Static Head)	PSI	2.4	2.4	2.4	2.4	2.4	2.4	
30	EXPECTED PRESS AT B&W FEED INLET TERMINAL	PSIG	2488.7	2488.7	2488.7	2002.7	2002.7	2002.7	
31	STEAM PRESSURE AT ATTEMPERATOR	PSIG	2455	2455	2455	1973	1973	1973	
32	ΔP THRU WATER NOZZLE NOTE 4	PSI	10.6	28.3	24.0	16.4	28.3	24.0	
33	REQ'D SPRAY WATER PRESS AT ATTEMP INLET	PSIG	2465.6	2483.3	2479	1989.9	2001.3	1997	
34	PRESS DROP AVAIL FOR ATTEMP. SYSTEM (26-33)	PSI *							
35	STATIC HEAD, SOURCE TO ATTEMP. NOZZLE.	PSI *							
36	PRESS DROP AVAIL FOR PIPING AND VALVES (34-35)	PSI *							
37	ΔP B&W PIPING	PSI	0	0	0	0	0	0	
38	ΔP CUST PIPING	PSI *							
39	TOTAL PIPING LOSS	PSI *							
40	PRESS DROP AVAIL FOR VALVES (36-39)	PSI *							
41	ΔP B&W VALVES (Excluding control valve)	PSI	0	0	0	0	0	0	
42	ΔP CUST VALVES (Excluding control valve)	PSI *							
43	TOTAL VALVE LOSS (Excluding control valve)	PSI *							
44	PRESS DIFF. ACROSS CONTROL VALVE (40-43)	PSI *							
45	MIN. REQ'D PRESS DROP ACROSS CONTROL VALVE	PSI	50	140	141	75	140	141	
46	Notes	1. * Indicates information to be completed by customer. → SUGGESTED CONTROL VALVE ΔP 2. Piping and valves to be sized for design capacity. 3. Control valve internals may be sized for "Installed maximum capacity" provided internals suitable for design capacity may be installed in the control valve body. 4. DESIGN CAPACITY NOZZLE PRESSURE DROP IS BASED ON REDRILLING ORIFICE TO SIZE SHOWN ON CIS 37.00							
53	ATTEMPERATOR TYPE:	<input type="checkbox"/> SINGLE STAGE <input checked="" type="checkbox"/> TANDEM FIRST STAGE <input type="checkbox"/> TWO STAGE							
55	ATTEMPERATOR IDENTIFICATION:	<input type="checkbox"/> DOWNSTREAM (1st in Control) <input checked="" type="checkbox"/> FIRST STAGE (1st in Control) <input type="checkbox"/> UPSTREAM (2nd in Control) <input type="checkbox"/> SECOND STAGE (2nd in Control)							
56	REL. NO. AND DATE	4(3-19-80)		CODE NO.	334-0588		COMP. NO.	RB-588	

SUPERHEATER ATTEMPERATOR SYSTEM DATA SHEET
 (FIRST STAGE ATTEMPERATOR)


FPGD CIS-38.0 L

PEF-FUEL-003742

THE BABCOCK & WILCOX COMPANY
 FOSSIL POWER GENERATION DIVISION
CONTRACT INFORMATION SHEET

DWFP 33027-3

A.O.



PIPING DESIGN CONDITIONS		
LOC.	PRESS	TEMP
ATTEMP	2975	850
SOURCE	"	
ELEVATIONS		
LOCATION	ELEVATION	
ATTEMP NOZ	321'-6"	
B&W FEED (I)	225'-9"	
SOURCE	"	
ATTEMP SYSTEM VALVES		
VALVE	DESIGN	CIS
c CONTROL	CUST	
b BLOCK	"	
l ISOLATION	"	
k CHECK	"	

18	FUEL		P.C.					
19	MAIN STEAM FLOW	MLB/HR	1310 (25% V.P.)					
20	AUXILIARY STEAM FLOW	MLB/HR						
21	SPRAY WATER TEMPERATURE	F	275					
22			Installed Capacity	Design Capacity	Installed Capacity	Design Capacity		
23			Min.	Max.	Min.	Max.		
24	TOTAL SPRAY WATER FLOW AT SOURCE	MLB/HR	159.1	262.9	315.3			
25	SPRAY WATER FLOW THIS ATTEMPERATOR / NOZZLE	MLB/HR	79.5	106.9	120.1			
26	SPRAY WATER PRESS. AT SOURCE (Based on following)	PSIG *						
27	Boiler DRUM PRESSURE	PSIG	1117	1117	1117			
28	Press. ECONOMIZER ΔP (Incl. Static Head)	PSI	36.3	36.3	36.3			
29	FEED VALVES AND PIPING ΔP (Incl. Static Head)	PSI	0.7	0.7	0.7			
30	EXPECTED PRESS AT B&W FEED INLET TERMINAL	PSIG	1154	1154	1154			
31	STEAM PRESSURE AT ATTEMPERATOR	PSIG	1109	1109	1109			
32	ΔP THRU WATER NOZZLE NOTE 4	PSI	18.2	32.1	33.2			
33	REQ'D SPRAY WATER PRESS AT ATTEMP INLET	PSIG	1127.2	1141.1	1142.2			
34	PRESS DROP AVAIL FOR ATTEMP. SYSTEM (26-33)	PSI *						
35	STATIC HEAD, SOURCE TO ATTEMP. NOZZLE	PSI *						
36	PRESS DROP AVAIL FOR PIPING AND VALVES (34-36)	PSI *						
37	Piping ΔP B&W PIPING	PSI	0	0	0			
38	ΔP CUST PIPING	PSI *						
39	TOTAL PIPING LOSS	PSI *						
40	PRESS DROP AVAIL FOR VALVES (36-39)	PSI *						
41	Valves ΔP B&W VALVES (Excluding control valve)	PSI	0	0	0			
42	ΔP CUST VALVES (Excluding control valve)	PSI *						
43	TOTAL VALVE LOSS (Excluding control valve)	PSI *						
44	PRESS DIFF. ACROSS CONTROL VALVE (40-43)	PSI *						
45	MIN. REQ'D PRESS DROP ACROSS CONTROL VALVE	PSI	85	150	192			

46 Notes
 47 1. * Indicates information to be completed by customer. → SUGGESTED CONTROL VALVE ΔP.
 48 2. Piping and valves to be sized for design capacity.
 49 3. Control valve internals may be sized for "Installed maximum capacity" provided
 50 internals suitable for design capacity may be installed in the control valve body.
 51 4 DESIGN CAPACITY NOZZLE PRESSURE DROP IS BASED ON REBRILLING ORIFICES TO SIZE SHOWN ON CIS 37.00

52
 53
 54 ATTEMPERATOR TYPE: SINGLE STAGE TANDEM FIRST STAGE TWO STAGE
 55 DOWNSTREAM (1st in Control) FIRST STAGE (4th in Control)
 56 ATTEMPERATOR IDENTIFICATION: UPSTREAM (2nd in Control) SECOND STAGE (2nd in Control)
 57 REL. NO. AND DATE 4/13-19-80 CODE NO. 334-0588 COMP. NO. RB-588 FILE NO.

SUPERHEATER ATTEMPERATOR SYSTEM DATA SHEET
 (FIRST STAGE ATTEMPERATOR)


FPGD CIS-38.0.2

PEF-FUEL-003743

THE BABCOCK & WILCOX COMPANY
 FOSSIL POWER GENERATION DIVISION
CONTRACT INFORMATION SHEET

UMFP 33027-3

A.O.



PIPING DESIGN CONDITIONS		
LOC.	PRESS	TEMP
ATTEMP	2975	850
SOURCE	"	"
ELEVATIONS		
LOCATION	ELEVATION	
ATTEMP NOZ	321'-6"	
B&W FEED	225'-9"	
SOURCE	"	
ATTEMP SYSTEM VALVES		
VALVE		CIS
c CONTROL	CUST	
b BLOCK	"	
i ISOLATION	"	
k CHECK	"	


18	FUEL				P.C.		P.C.
19	MAIN STEAM FLOW	MLB/HR	2369 (RHCL)		2369 (RHCL-V.P.)		
20	AUXILIARY STEAM FLOW	MLB/HR					
21	SPRAY WATER TEMPERATURE	F		310		310	
22				Installed Capacity	Design Capacity	Installed Capacity	Design Capacity
23				Min.	Max.	Min.	Max.
24	TOTAL SPRAY WATER FLOW AT SOURCE	MLB/HR	239.8	398.5	493.2	312.4	466.8
25	SPRAY WATER FLOW THIS ATTEMPERATOR / NOZZLE	MLB/HR	6.5	97.9	97.9	30.7	125.3
26	SPRAY WATER PRESS. AT SOURCE (Based on following)	PSIG *					
27	DRUM PRESSURE	PSIG	2446	2446	2446	1960	1960
28	ECONOMIZER ΔP (Incl. Static Head)	PSI	40.3	40.3	40.3	40.3	40.3
29	FEED VALVES AND PIPING ΔP (Incl. Static Head)	PSI	2.4	2.4	2.4	2.4	2.4
30	EXPECTED PRESS AT B&W FEED INLET TERMINAL	PSIG	2488.7	2488.7	2488.7	2002.7	2002.7
31	STEAM PRESSURE AT ATTEMPERATOR	PSIG	2443	2443	2443	1956	1956
32	ΔP THRU WATER NOZZLE	PSI	1	18	18	1.7	29.4
33	REQ'D SPRAY WATER PRESS AT ATTEMP INLET	PSIG	2444	2461	2461	1957.7	1985.4
34	PRESS DROP AVAIL FOR ATTEMP. SYSTEM (26-33)	PSI *					
35	STATIC HEAD, SOURCE TO ATTEMP. NOZZLE	PSI *					
36	PRESS DROP AVAIL FOR PIPING AND VALVES (34-35)	PSI *					
37	ΔP B&W PIPING	PSI	0	0	0	0	0
38	ΔP CUST PIPING	PSI *					
39	TOTAL PIPING LOSS	PSI *					
40	PRESS DROP AVAIL FOR VALVES (36-39)	PSI *					
41	ΔP B&W VALVES (Excluding control valve)	PSI	0	0	0	0	0
42	ΔP CUST VALVES (Excluding control valve)	PSI *					
43	TOTAL VALVE LOSS (Excluding control valve)	PSI *					
44	PRESS DIFF. ACROSS CONTROL VALVE (40-43)	PSI *					
45	MIN. REQ'D PRESS DROP ACROSS CONTROL VALVE	PSI	40	180	180	40	250
46	Notes	1. * Indicates information to be completed by customer. 2. Piping and valves to be sized for design capacity. 3. Control valve internals may be sized for "Installed maximum capacity" provided Internals suitable for design capacity may be installed in the control valve body.					
47							
48							
49							
50							
51							
52							
53							
54	ATTEMPERATOR TYPE:	<input type="checkbox"/> SINGLE STAGE		<input type="checkbox"/> TANDEM		<input type="checkbox"/> TWO STAGE	
55		<input type="checkbox"/> DOWNSTREAM (1st in Control)		<input type="checkbox"/> FIRST STAGE (1st in Control)			
56	ATTEMPERATOR IDENTIFICATION:	<input type="checkbox"/> UPSTREAM (2nd in Control)		<input type="checkbox"/> SECOND STAGE (2nd in Control)			
57	REL. NO. AND DATE	3(3-19-80) 4(4-24-80)		CODE NO.	COMP. NO.	FILE NO.	
58				334-0588		RB-588	

SUPERHEATER ATTEMPERATOR SYSTEM DATA SHEET FPGD CIS-38.0 4

THE BABCOCK & WILCOX COMPANY
 FOSSIL POWER GENERATION DIVISION
 CONTRACT INFORMATION SHEET

BWFP 33027-3

A.O.



PIPING DESIGN CONDITIONS		
LOC.	PRESS	TEMP
ATTEMP	2975	850
SOURCE	*	*
ELEVATIONS		
LOCATION	ELEVATION	
ATTEMP NOZ	321'-6"	
B&W FEED (T)	225'-9"	
SOURCE	*	
ATTEMP SYSTEM VALVES		
VALVE	DESIGN	CIS
c CONTROL	CUST	
b BLOCK	"	
i ISOLATION	"	
k CHECK	"	

18	FUEL						
19	MAIN STEAM FLOW	MLB/HR	P.C.				
20	AUXILIARY STEAM FLOW	MLB/HR	1310 (2530 V.P.)				
21	SPRAY WATER TEMPERATURE	F	275				
22			Installed Capacity	Design Capacity	Installed Capacity	Design Capacity	
23			Min.	Max.	Min.	Max.	
24	TOTAL SPRAY WATER FLOW AT SOURCE	MLB/HR	159.1	262.9	315.3		
25	SPRAY WATER FLOW THIS ATTEMPERATOR / NOZZLE	MLB/HR	11.9	67.6	67.6		
26	SPRAY WATER PRESS. AT SOURCE (Based on following)	PSIG *					
27	DRUM PRESSURE	PSIG	1117	1117	1117		
28	ECONOMIZER ΔP (Incl. Static Head)	PSI	36.3	36.3	36.3		
29	FEED VALVES AND PIPING ΔP (Incl. Static Head)	PSI	.7	.7	.7		
30	EXPECTED PRESS AT B&W FEED INLET TERMINAL	PSIG	1159	1159	1159		
31	STEAM PRESSURE AT ATTEMPERATOR	PSIG	1099	1099	1099		
32	ΔP THRU WATER NOZZLE	PSI	1.1	34.2	34.2		
33	REQ'D SPRAY WATER PRESS AT ATTEMP INLET	PSIG	1100.1	1133.2	1133.2		
34	PRESS DROP AVAIL FOR ATTEMP. SYSTEM (26-33)	PSI *					
35	STATIC HEAD, SOURCE TO ATTEMP. NOZZLE	PSI *					
36	PRESS DROP AVAIL FOR PIPING AND VALVES (34-36)	PSI *					
37	ΔP B&W PIPING	PSI	0	0	0		
38	ΔP CUST PIPING	PSI *					
39	TOTAL PIPING LOSS	PSI *					
40	PRESS DROP AVAIL FOR VALVES (36-39)	PSI *					
41	ΔP B&W VALVES (Excluding control valve)	PSI	0	0	0		
42	ΔP CUST VALVES (Excluding control valve)	PSI *					
43	TOTAL VALVE LOSS (Excluding control valve)	PSI *					
44	PRESS DIFF. ACROSS CONTROL VALVE (40-43)	PSI *					
45	MIN. REQ'D PRESS DROP ACROSS CONTROL VALVE	PSI	90	75	75		

Notes:
 1. * Indicates information to be completed by customer. → SUGGESTED CONTROL VALVE ΔP
 2. Piping and valves to be sized for design capacity.
 3. Control valve Internals may be sized for "Installed maximum capacity" provided internals suitable for design capacity may be installed in the control valve body.

46

47

48

49

50

51

52

53

54 ATTEMPERATOR TYPE: SINGLE STAGE TANDEM TWO STAGE

55 DOWNSTREAM (1st in Control) FIRST STAGE (1st in Control)

56 UPSTREAM (2nd in Control) SECOND STAGE (2nd in Control)

REL. NO. AND DATE 3(3-19-80) CODE NO. 334-0588 COMP. NO. RB-588 FILE NO.