

ORIGINAL

River Grove

Docket No. 060368-WS

Application to Increase Rates and Charges
For a "Class A" Utility
In

Florida

VOLUME 6

Book 7

Set 40 of 57

Containing
Additional Engineering Requirements

Monthly Operating Reports

CMP _____

COM _____

CTR _____

ECR 1

GCL _____

OPC _____

RCA _____

SCR _____

SGA _____

SEC _____

OTH _____

Aqua Utilities Florida, Inc.

DOCUMENT NUMBER-DATE

00870 JAN 26 8

FPSC-COMMISSION CLERK

Aqua Utilities Florida, Inc. Monthly Operating Reports

River Grove

	Tab Number	Page Number
Year: 2004		
January	1	3
February	2	5
March	3	7
April	4	9
May	5	11
June	6	13
July	7	14
August	8	16
September	9	18
October	10	20
November	11	22
December	12	24
Year: 2005		
January	1	26
February	2	28
March	3	30
April	4	32
May	5	34
June	6	36
July	7	38
August	8	40
September	9	42
October	10	44
November	11	46
December	12	48

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2540959 Plant Name: River Grove

III. Daily Data for the Month/Year of: January, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*								Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation		
				CT Calculations				UV Dose							
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²			Minimum UV Dose Required, mW-sec/cm ²	
1	X	24.0	11,320		2.0									1.0	
2	X	24.0	22,620		2.3									1.0	
3		24.0	17,707												
4		24.0	17,707												
5	X	24.0	17,707		2.2									1.0	
6	X	24.0	15,400		2.4									1.0	
7	X	24.0	14,770		1.7									1.0	
8	X	24.0	14,760		1.9									1.1	
9	X	24.0	17,890		2.3									1.0	
10		24.0	19,143												
11		24.0	19,143												
12	X	24.0	19,143		2.2									1.2	
13	X	24.0	18,320		2.4									1.4	
14	X	24.0	15,170		2.1									1.3	
15	X	24.0	15,330		2.5									1.3	
16	X	24.0	22,420		2.2									1.0	
17		24.0	14,697												
18		24.0	14,697												
19	X	24.0	14,697		2.5									1.2	
20	X	24.0	16,820		2.0									1.2	
21	X	24.0	12,830		2.4									1.3	
22	X	24.0	14,760		2.0									1.3	
23	X	24.0	13,900		2.4									1.3	
24		24.0	26,747												
25		24.0	26,747												
26		24.0	26,747		1.7									1.0	
27		24.0	23,490		2.5									1.2	
28		24.0	14,860		2.7									1.3	
29		24.0	22,190		2.5									1.3	
30		24.0	14,860		2.6									1.3	
31		24.0													
Total			536,590												
Average			17,309												
Maximum			26,747												

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PW'SS TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number 2540959 Plant Name River Grove February, 2004

III. Daily Data for the Month/year of: February, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal	Peak Flow Rate, gpd	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Before or at Customer First Disinfectant	Temp of Water, °C	pH of Water, if applicable	Minimum CT Required, mg-min/L	Lowest UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²	Remotest Point in Distribution System, mg/L	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*		CT Calculations	
													UV Dose	UV Dose	UV Dose	UV Dose
1	X	24.0	24.290	3.0												
2	X	24.0	24.290	15.080	2.7											
3	X	24.0	15.080	23.590	1.5											
4	X	24.0	23.590	24.0	1.6											
5	X	24.0	19.380	24.0	1.7											
6	X	24.0	15.950	24.0	2.0											
7		24.0	18.127	24.0												
8		24.0	18.127	24.0												
9	X	24.0	18.127	24.0	2.2											
10	X	24.0	18.840	24.0	1.8											
11	X	24.0	11.100	24.0	1.6											
12	X	24.0	14.860	24.0	2.0											
13	X	24.0	15.070	24.0	2.0											
14		24.0	14.540	24.0												
15		24.0	14.540	24.0												
16	X	24.0	14.540	24.0	2.0											
17	X	24.0	18.520	24.0	1.7											
18	X	24.0	19.090	24.0	2.0											
19	X	24.0	18.710	24.0	2.0											
20	X	24.0	18.950	24.0	2.0											
21		24.0	16.120	24.0												
22		24.0	16.120	24.0												
23	X	24.0	16.120	24.0	1.8											
24	X	24.0	15.070	24.0	2.0											
25	X	24.0	14.750	24.0	2.0											
26	X	24.0	14.440	24.0	1.8											
27	X	24.0	15.180	24.0	2.2											
28		24.0		24.0												
29		24.0		24.0												
Total		463,520														
Average		15,983														
Maximum		24,290														

* Refer to the instructions for this report to determine which plants must provide this information

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2540959 Plant Name: River Grove

III. Daily Data for the Month/Year of: March, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions; Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations					UV Dose							
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²				
1	X	24.0	48,660		1.9										0.9	
2	X	24.0	14,740		1.9										0.9	
3	X	24.0	14,970		2.3										0.8	
4	X	24.0	14,320		2.3										1.0	
5	X	24.0	14,750		2.3										1.0	
6		24.0	17,653													
7		24.0	17,653													
8	X	24.0	17,653		1.9										0.8	
9	X	24.0	15,510		2.4										1.0	
10	X	24.0	18,970		2.0										1.2	
11	X	24.0	22,640		2.4										1.0	
12	X	24.0	15,100		2.0										1.0	
13		24.0	21,907													
14		24.0	21,907													
15	X	24.0	21,907		1.9										1.1	
16	X	24.0	15,540		2.1										1.1	
17	X	24.0	11,010		2.0										1.0	
18	X	24.0	18,330		2.0										1.0	
19	X	24.0	14,760		2.4										1.2	
20		24.0	17,837													
21		24.0	17,837													
22	X	24.0	17,837		2.2										1.2	
23	X	24.0	13,890		2.4										1.2	
24	X	24.0	11,730		2.2										1.2	
25	X	24.0	16,600		2.1										1.2	
26	X	24.0	13,050		2.0										1.0	
27		24.0	21,977													
28		24.0	21,977													
29	X	24.0	21,977		2.4										1.0	
30	X	24.0	19,650		2.1										1.1	
31	X	24.0	17,510		2.5										1.0	
Total			569,850													
Average			18,382													
Maximum			48,660													

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2540959 Plant Name: River Grove

III. Daily Data for the Month/Year of: April, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*								Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions; Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations				UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²			Minimum UV Dose Required, mW-sec/cm ²
1	X	24.0	21,500		2.4								1.0	
2	X	24.0	23,360		2.2								1.1	
3		24.0	25,823											
4		24.0	25,823											
5	X	24.0	25,823		2.8								1.2	
6	X	24.0	28,260		2.3								0.9	
7	X	24.0	29,450		2.5								1.0	
8	X	24.0	16,000		2.0								0.6	
9	X	24.0	27,750		2.3								0.8	
10		24.0	25,527											
11		24.0	25,527											
12	X	24.0	25,527		1.8								0.6	
13	X	24.0	11,150		2.0								0.5	plant outage / bactis
14	X	24.0	15,160		1.2								0.5	bactis for plant outage
15	X	24.0	19,060		1.5								0.8	
16	X	24.0	20,020		1.5								0.8	
17		24.0	25,850											
18		24.0	25,850											
19	X	24.0	25,850		2.3								1.0	
20	X	24.0	20,260		1.5								0.6	
21	X	24.0	20,600		2.1								0.8	
22	X	24.0	26,890		2.3								1.0	
23	X	24.0	36,120		1.8								0.8	
24		24.0	25,387											
25		24.0	25,387											
26	X	24.0	25,387		1.8								0.9	
27	X	24.0	22,440		1.8								0.9	
28	X	24.0	24,180		1.8								1.0	
29	X	24.0	15,850		2.2								1.0	
30		24.0	19,520		1.9								1.0	
Total			705,330											
Average			23,511											
Maximum			36,120											

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PW'SS TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2540959 Plant Name: River Grove May, 2004

III. Daily Data for the Month/Year of:

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Started or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal	Peak Flow Rate, gpd	Lowest Residual Disinfectant Concentration (C) Before or at First Customer Measurement (T) at C	Disinfectant Contact Time	Lowest CT Before or at First Customer Measurement	Flow, mg-min/L	Temp of Water, °C	pH of Water, If Applicable	Minimum CT Required, mg-min/L	Lowest UV Dose Operating	Minimum UV Dose Required, mW-sec/cm ²	Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions; Repair or Maintenance Work that Involves Taking Water System Components Out of Operation

1		24.0	18,897											
2	X	24.0	18,897											
3	X	24.0	18,897											
4	X	24.0	9,960											1.8
5	X	24.0	16,330											1.2
6	X	24.0	15,250											1.0
7	X	24.0	22,700											1.0
8		24.0	23,720											
9		24.0	23,720											
10	X	24.0	23,720											1.0
11	X	24.0	15,460											1.2
12	X	24.0	22,500											1.6
13	X	24.0	10,710											2.2
14	X	24.0	19,030											0.6
15		24.0	23,267											
16		24.0	23,267											
17	X	24.0	23,267											0.8
18	X	24.0	15,040											1.0
19	X	24.0	14,720											1.0
20	X	24.0	18,720											1.1
21	X	24.0	19,270											1.1
22		24.0	29,263											
23		24.0	29,263											
24	X	24.0	29,263											1.0
25	X	24.0	40,170											1.0
26	X	24.0	30,760											1.0
27	X	24.0	33,480											0.8
28	X	24.0	42,700											1.0
29		24.0	39,400											
30		24.0	39,400											
31	X	24.0	39,400											1.0
Total			750,440											
Average			24.208											
Maximum			42,700											

* Refer to the instructions for this report to determine which plants must provide this information

Docket No. 060368-WS

**Application to Increase Rates and Charges
For a "Class A" Utility
In**

Florida

Report Missing:

Monthly Operating Report

River Grove

June 2004

Aqua Utilities Florida, Inc.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: July, 2004

A. Public Water System (PWS) Information

PWS Name: River Grove		PWS Identification Number: 2540959	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 106		Total Population Served at End of Month: 263	
PWS Owner: Florida Water Services			
Contact Person: Craig Anderson		Contact Person's Title: VP Environmental Services	
Contact Person's Mailing Address: P.O. Box 609520		City: Orlando	State: Florida
		Zip Code: 32860-9520	
Contact Person's Telephone Number: (407) 598-4199		Contact Person's Fax Number: (407) 598-4217	
Contact Person's E-Mail Address: craiga@florida-water.com			

B. Water Treatment Plant Information

Plant Name: River Grove		Plant Telephone Number: 904-329-1122		
Plant Address: River Drive		City: East Palatka	State: Florida	
		Zip Code: 32131		
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water				
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 200,000				
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): C		
Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	Paul Thompson	A	7251	Days 1st Shift
Other Operators:	Donald Holcomb	A	5091	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date

Mark March

Printed or Typed Name

C-8287

License Number

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: September, 2004

A. Public Water System (PWS) Information

PWS Name:	River Grove	PWS Identification Number:	2540959
PWS Type:	<input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive		
Number of Service Connections at End of Month:	106	Total Population Served at End of Month:	263
PWS Owner:	Florida Water Services		
Contact Person:	Craig Anderson	Contact Person's Title:	VP Environmental Services
Contact Person's Mailing Address:	P.O. Box 609520	City:	Orlando
		State:	Florida
		Zip Code:	32860-9520
Contact Person's Telephone Number:	(407) 598-4199	Contact Person's Fax Number:	(407) 598-4217
Contact Person's E-Mail Address:	<u>craig@florida-water.com</u>		

B. Water Treatment Plant Information

Plant Name:	River Grove	Plant Telephone Number:	904-329-1122
Plant Address:	River Drive	City:	East Palatka
		State:	Florida
Type of Water Treatment by Plant:	<input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water	Zip Code:	32131
Permitted Maximum Day Operating Capacity of Plant, gallons per day:	200,000		
Plant Category (per subsection 62-699.310(4), F.A.C.):	IV	Plant Class (per subsection 62-699.310(4), F.A.C.):	C

Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	Mark March	C	8287	Days 1st Shift
Other Operators:	Paul Thompson	A	7251	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	<u>Mark March</u>	<u>C-8287</u>
	Printed or Typed Name	License Number

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2540959 Plant Name: River Grove

III. Daily Data for the Month/Year of: September, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Stuffed or Visited by Operator ("X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Measurement Point During Peak Flow.	Contact Time (T) at C	Lowest CT Provided Before or at First Customer During Peak Flow, mg-minutes	Temp of Water, °C	pH of Water, If Applicable	Minimum CT Required, mg-min/L	Operating UV Dose, mW-sec/cm ²	Required UV Dose, mW-sec/cm ²	Lowest Residual Disinfectant Concentration at Remote Point in Distribution Involves Taking Water System Components Out of Operation	Emergency or Abnormal Operating Conditions: Repair or Maintenance Work that	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*		
															Lowest Residual Disinfectant Concentration at Remote Point in Distribution Involves Taking Water System Components Out of Operation	Emergency or Abnormal Operating Conditions: Repair or Maintenance Work that	UV Dose
1	X		18,970	24.0	2.5												
2	X		34,610	24.0	2.5												
3	X		22,740	24.0	2.3												
4			14,457	24.0													
5			14,457	24.0													
6	X		14,457	24.0	2.0												
7	X		30,700	24.0	2.0												
8	X		18,970	24.0	2.2												
9	X		26,400	24.0	2.2												
10	X		14,870	24.0	2.6												
11			17,413	24.0													
12			17,413	24.0													
13	X		17,413	24.0	2.5												
14	X		30,360	24.0	2.4												
15	X		15,500	24.0	2.6												
16	X		22,720	24.0	2.0												
17	X		15,280	24.0	2.0												
18			18,767	24.0													
19			18,767	24.0													
20	X		18,767	24.0	2.0												
21	X		22,830	24.0	2.0												
22	X		10,860	24.0	2.4												
23	X		18,740	24.0	1.8												
24	X		17,760	24.0	2.2												
25			17,937	24.0													
26			17,937	24.0													
27	X		17,937	24.0	1.4												
28	X		20,880	24.0	1.9												
29	X		16,670	24.0	2.4												
30	X		48,120	24.0	2.3												
31			24.0														
Total			612,700														
Average			19,765														
Maximum			48,120														

* Refer to the instructions for this report to determine which plants must provide this information

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2540959 Plant Name: River Grove

III. Daily Data for the Month/year of: October, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal	Peak Flow Rate, gpd	Lowest Residual Disinfectant Concentration (C) Before or at First Disinfectant Contact Time	Disinfectant Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C If Applicable	pH of Water, If Applicable	Minimum CT Required, mg-min/L	Lowest UV Dose, mW-sec/cm ²	Minimum UV Dose, mW-sec/cm ²	Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, If Applicable*		CT Calculations	
													Disinfectant Contact Time	Disinfectant Provided Before or at First Customer	Disinfectant Measurement (T) at C	Point During Peak Flow, minutes
1	X	16,780	24.0													
2		17,250	24.0													
3		17,250	24.0													
4	X	17,250	24.0	2.4												
5	X	18,620	24.0	2.4												
6	X	14,940	24.0	2.3												
7	X	15,070	24.0	2.2												
8	X	18,600	24.0	2.4												
9		21,083	24.0													
10		21,083	24.0													
11	X	21,083	24.0	2.2												
12	X	14,190	24.0	2.5												
13	X	16,670	24.0	2.5												
14	X	18,820	24.0	2.3												
15	X	19,030	24.0	2.2												
16		19,037	24.0													
17		19,037	24.0													
18	X	19,037	24.0	2.3												
19	X	14,730	24.0	2.1												
20	X	14,730	24.0	2.0												
21	X	14,740	24.0	1.8												
22	X	14,730	24.0	2.0												
23		19,103	24.0													
24		19,103	24.0													
25	X	19,103	24.0	2.4												
26	X	19,570	24.0	2.8												
27	X	19,790	24.0	2.2												
28	X	19,570	24.0	2.3												
29	X	24,090	24.0	2.3												
30		12,688	24.0													
31		12,689	24.0													
Total		549,467														
Average		17,725														
Maximum		24,090														

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2540959 Plant Name: River Grove

III. Daily Data for the Month/Year of: November, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Started or Operator Visited by (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal	Peak Flow Rate, gpd	Disinfectant Residual Provided	Disinfectant Contact Time	Lowest CT Before or at First Customer Measurement (T) at C	Peak Flow, Point During Peak Flow, min/L	Temp of Water, °C	pH of Water, If Applicable	Minimum CT Required, mg·min/L	CT Calculations		Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
											Lowest UV Dose, mW-sec/cm ²	Lowest Operating UV Dose, mW-sec/cm ²	
1	X	76,130	24.0	1.8									
2	X	19,030	24.0	2.0									
3	X	10,970	24.0	2.0									
4	X	18,820	24.0	1.9									
5	X	19,030	24.0	0.6									
6		17,597	24.0										
7		17,597	24.0										
8	X	17,597	24.0	1.6									
9	X	15,070	24.0	1.7									
10	X	17,740	24.0	1.4									
11	X	22,590	24.0	1.6									
12	X	18,920	24.0	1.4									
13		14,913	24.0										
14		14,913	24.0										
15	X	14,913	24.0	2.6									
16	X	19,140	24.0	2.0									
17	X	14,630	24.0	2.4									
18	X	20,200	24.0	2.1									
19	X	21,410	24.0	2.3									
20		21,130	24.0										
21	X	21,130	24.0	2.2									
22	X	11,290	24.0	2.0									
23	X	23,560	24.0	2.3									
24	X	18,600	24.0	2.2									
25		20,705	24.0										
26	X	20,705	24.0	2.2									
27		14,983	24.0										
28		14,983	24.0										
29	X	14,983	24.0	2.5									
30	X	14,730	24.0	2.4									
31		24.0											
Total		588,010											
Average		18,968											
Maximum		76,130											

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



Polymer Page 3 Due in December

See Pages 4 for Instructions.

I. General Information for the Month/Year of: December, 2004

A. Public Water System (PWS) Information

PWS Name:	River Grove	PWS Identification Number:	2540959
PWS Type:	<input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive		
Number of Service Connections at End of Month:	106	Total Population Served at End of Month:	263
PWS Owner:	Aqua Utilities Florida		
Contact Person:	Brian Heath	Contact Person's Title:	Area Manager
Contact Person's Mailing Address:	1343 NE 17th Road	City:	Ocala
		State:	Florida
		Zip Code:	34470
Contact Person's Telephone Number:	(352) 732-6027	Contact Person's Fax Number:	(352) 732-3213
Contact Person's E-Mail Address:	beheath@aquaaamerica.com		

B. Water Treatment Plant Information

Plant Name:	River Grove	Plant Telephone Number:	904-329-1122
Plant Address:	River Drive	City:	East Palatka
		State:	Florida
		Zip Code:	32131
Type of Water Treatment by Plant:	<input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water		
Permitted Maximum Day Operating Capacity of Plant, gallons per day:	200,000		
Plant Category (per subsection 62-699.310(4), F.A.C.):	IV	Plant Class (per subsection 62-699.310(4), F.A.C.):	C

Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	Mark March	C	8287	Days 1st Shift
Other Operators:	Paul Thompson	A	7251	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	_____ Mark March Printed or Typed Name	_____ C8287 License Number
--------------------	--	----------------------------------

MONTHLY OPERATION REPORT FOR PW'SS TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2540959 Plant Name: River Grove

III. Daily Data for the Month/year of: December, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Started or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer Measurement (1) at C	Disinfectant Contact Time Provided Before or at First Customer Measurement (T) During Peak Flow, minutes	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*	
												UV Dose	CT Calculations
1	X	24.0	18,600	2.4								2.4	
2	X	24.0	14,950	2.7								2.7	
3	X	24.0	14,630	2.8								2.8	
4		24.0	17,350										
5		24.0	17,350										
6	X	24.0	17,350	2.3									
7	X	24.0	18,710	2.4									
8	X	24.0	14,730	1.7									
9	X	24.0	14,730	2.4									
10	X	24.0	22,600	2.2									
11		24.0	17,690										
12		24.0	17,690										
13	X	24.0	17,690	2.0									
14	X	24.0	19,840	2.0									
15	X	24.0	13,970	2.0									
16	X	24.0	18,950	2.0									
17	X	24.0	14,750	2.0									
18		24.0	18,767										
19		24.0	18,767										
20	X	24.0	18,767	1.8									
21	X	24.0	23,040	2.0									
22	X	24.0	14,970	2.0									
23	X	24.0	23,040	2.2									
24	X	24.0	18,530	2.4									
25		24.0	10,520										
26		24.0	10,520										
27	X	24.0	10,520	1.8									
28	X	24.0	43,380	1.8									
29	X	24.0	27,120	1.9									
30	X	24.0	81,040	1.4									
31	X	24.0	30,770	1.3									
Total		641,330											
Average		20,688											
Maximum		81,040											

* Refer to the instructions for this report to determine which plants must provide this information

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2540959 Plant Name: River Grove

III. Daily Data for the Month/Year of: January, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal	Peak Flow Rate, gpd	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest UV Dose, mW-sec/cm ²	UV Dose Required, mW-sec/cm ²	System, mg/L	Emergency or Abnormal Operating Conditions; Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*			CT Calculations		
														UV Dose	UV Dose	UV Dose	UV Dose	UV Dose	UV Dose
1		24.0	23,087	24.0	23,087														
2		24.0	23,087	24.0	23,087														
3	X	24.0	23,087	24.0	18,930	1.8							0.6						
4	X	24.0	18,930	24.0	15,380	2.3							0.6						
5	X	24.0	15,380	24.0	19,360	2.2							1.0						
6	X	24.0	19,360	24.0	17,750	2.0							1.1						
7	X	24.0	17,750	24.0	19,007														
8		24.0	19,007	24.0	19,007														
9		24.0	19,007	24.0	19,007														
10	X	24.0	19,007	24.0	23	2.3							1.0						
11	X	24.0	29,740	24.0	1.8	1.8							1.6						
12	X	24.0	11,800	24.0	3.5	3.5							2.8						
13	X	24.0	18,290	24.0	2.0	2.0							1.0						
14	X	24.0	14,030	24.0	1.4	1.4							0.9						
15		24.0	17,343	24.0	17,343														
16		24.0	17,343	24.0	17,343														
17	X	24.0	17,343	24.0	1.7	1.7							0.6						
18	X	24.0	27,630	24.0	1.8	1.8							1.4						
19	X	24.0	6,790	24.0	1.8	1.8							0.8						
20	X	24.0	21,180	24.0	1.7	1.7							0.7						
21	X	24.0	15,800	24.0	1.8	1.8							0.8						
22		24.0	20,003	24.0	20,003														
23		24.0	20,003	24.0	20,003														
24	X	24.0	20,003	24.0	1.8	1.8							0.7						
25	X	24.0	18,940	24.0	1.8	1.8							0.7						
26	X	24.0	18,710	24.0	1.9	1.9							0.6						
27	X	24.0	22,600	24.0	1.8	1.8							0.7						
28	X	24.0	20,270	24.0	1.7	1.7							0.7						
29		24.0	18,600	24.0	18,600														
30		24.0	18,600	24.0	18,600														
31	X	24.0	18,600	24.0	1.8	1.8							0.8						
Total			591,320																
Average			19,075																
Maximum			29,740																

* Refer to the instructions for this report to determine which plants must provide this information

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: February, 2005

A. Public Water System (PWS) Information

PWS Name:	River Grove			PWS Identification Number:	2540959
PWS Type:	<input checked="" type="checkbox"/> Community	<input type="checkbox"/> Non-Transient Non-Community	<input type="checkbox"/> Transient Non-Community	<input type="checkbox"/> Consecutive	
Number of Service Connections at End of Month:	107			Total Population Served at End of Month:	375
PWS Owner:	Aqua Utilities Florida				
Contact Person:	Brian Heath			Contact Person's Title:	Area Manager
Contact Person's Mailing Address:	PO Box 490310	City:	Leesburg	State:	Florida
Contact Person's Telephone Number:	(352) 787-0980			Contact Person's Fax Number:	(352) 787-6333
Contact Person's E-Mail Address:	beheath@aquaaamerica.com				

B. Water Treatment Plant Information

Plant Name:	River Grove			Plant Telephone Number:	(352) 787-0980	
Plant Address:	River Drive			City:	East Palatka	
Type of Water Treatment by Plant:	<input checked="" type="checkbox"/> Raw Ground Water	<input type="checkbox"/> Purchased Finished Water				
Permitted Maximum Day Operating Capacity of Plant, gallons per day:	200,000					
Plant Category (per subsection 62-699.310(4), F.A.C.):	IV			Plant Class (per subsection 62-699.310(4), F.A.C.):	C	
Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked		
Lead/Chief Operator:	Paul Thompson	A	7251	Days 1st Shift		
Other Operators:						

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date

Paul Thompson

Printed or Typed Name

A7251

License Number

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2540959 Plant Name: River Grove

III. Daily Data for the Month/year of: February, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Visited or Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal	Peak Flow Rate, gpd	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Contact Time (T) at C	Disinfectant Provided Before or at First Customer During Peak Flow, mg-minutes	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest UV Dose, mW-sec/cm	UV Dose Required, mW-sec/cm	Minimum Disinfectant Concentration at Remove Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
1	X	24.0	17,960	1.8								0.7	
2	X	24.0	18,830	1.8								0.8	
3	X	24.0	14,950	1.7								0.8	
4	X	24.0	25,920	1.7								0.7	
5		24.0	16,210										
6		24.0	16,210										
7	X	24.0	16,210	1.8								0.7	
8	X	24.0	18,500	1.8								0.7	
9	X	24.0	19,050	2.2								0.8	
10	X	24.0	14,870	2.3								0.9	
11	X	24.0	19,530	2.0								0.9	
12		24.0	19,967										
13		24.0	19,967										
14	X	24.0	19,967	1.8								0.7	
15	X	24.0	14,650	2.3								1.0	
16	X	24.0	18,330	2.0								0.9	
17	X	24.0	18,970	2.3								1.0	
18	X	24.0	18,650	2.2								0.9	
19		24.0	17,943										
20		24.0	17,943										
21	X	24.0	17,943	2.2								0.9	
22	X	24.0	24,210	2.0								0.8	
23	X	24.0	22,210	1.8								0.8	
24	X	24.0	23,750	1.7								0.8	
25	X	24.0	23,310	1.8								0.8	
26		24.0	18,660										
27		24.0	18,660										
28	X	24.0	18,660	1.7								0.7	
29		24.0											
30		24.0											
31		24.0											
Total		532,030											
Average		17,162											
Maximum		25,920											

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: March, 2005

A. Public Water System (PWS) Information

PWS Name: River Grove		PWS Identification Number: 2540959	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 107		Total Population Served at End of Month: 375	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: PO Box 490310		City: Leesburg	State: Florida Zip Code: 34749
Contact Person's Telephone Number: (352) 787-0980		Contact Person's Fax Number: (352) 787-6333	
Contact Person's E-Mail Address: beheath@aquaamerica.com			

B. Water Treatment Plant Information

Plant Name: River Grove		Plant Telephone Number: (352) 787-0980	
Plant Address: River Drive		City: East Palatka	State: Florida Zip Code: 32131
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water			
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 200,000		Plant Class (per subsection 62-699.310(4), F.A.C.): C	
Plant Category (per subsection 62-699.310(4), F.A.C.): IV			
Licensed Operators	Name	License Class	License Number Day(s)/Shift(s) Worked
Lead/Chief Operator:	Paul Thompson	A	7251 Days 1st Shift
Other Operators:			

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date

Paul Thompson

Printed or Typed Name

A7251

License Number

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2540959 Plant Name: River Grove

III. Daily Data for the Month/Year of: March, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*								Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations				UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²			Minimum UV Dose Required, mW-sec/cm ²
1	X	24.0	18,750		1.6								0.7	
2	X	24.0	18,970		1.6								0.7	
3	X	24.0	22,950		1.6								1.0	
4	X	24.0	14,980		1.6								0.7	
5		24.0	19,103											
6		24.0	19,103											
7	X	24.0	19,103		1.7								0.7	
8	X	24.0	18,430		1.9								0.7	
9	X	24.0	18,630		1.7								0.6	
10	X	24.0	14,700		1.7								0.4	
11	X	24.0	19,670		1.4								0.6	
12		24.0	21,440											
13		24.0	21,440											
14	X	24.0	21,440		1.6								0.5	
15	X	24.0	22,940		2.0								0.8	
16	X	24.0	14,970		1.4								0.6	
17	X	24.0	14,770		1.4								0.5	
18	X	24.0	18,310		1.3								0.7	
19		24.0	18,707											
20	X	24.0	18,707											
21	X	24.0	18,707		1.2								0.7	
22	X	24.0	23,270		1.5								0.4	
23	X	24.0	22,830		1.3								0.9	
24	X	24.0	17,780		1.7								0.7	
25	X	24.0	16,370		1.7								0.8	
26		24.0	17,557											
27		24.0	17,557											
28	X	24.0	17,557		1.6								0.5	
29	X	24.0	22,730		1.5								0.7	
30	X	24.0	13,890		1.6								0.6	
31	X	24.0	16,480		1.4								0.6	
Total			581,840											
Average			18,769											
Maximum			23,270											

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: April, 2005

A. Public Water System (PWS) Information

PWS Name: River Grove		PWS Identification Number: 2540959	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 107		Total Population Served at End of Month: 375	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: PO Box 490310		City: Leesburg	State: Florida
		Zip Code: 34749	
Contact Person's Telephone Number: (352) 787-0980		Contact Person's Fax Number: (352) 787-6333	
Contact Person's E-Mail Address: beheath@aquamerica.com			

B. Water Treatment Plant Information

Plant Name: River Grove		Plant Telephone Number: (352) 787-0980	
Plant Address: River Drive		City: East Palatka	State: Florida
		Zip Code: 32131	
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water			
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 200,000			
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): C	
Licensed Operators	Name	License Class	License Number
Lead/Chief Operator:	Larry White	C	7082
Other Operators:	Paul Thompson	A	7251

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date

Larry White

Printed or Typed Name

C7082

License Number

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2540959 Plant Name: River Grove

III. Daily Data for the Month/year of: April, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

CT Calculations, or UV Dose, to Demonstrate Four-Log Virus Inactivation, if Applicable* UV Dose

Days Plant Started or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal	Peak Flow Rate, gpd	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C	Lowest CT Provided or at First Customer During Peak Flow, mg-minutes	Temp of Water, °C	pH of Water, If Applicable	Minimum CT Required, mg-minutes	Lowest Operating UV Dose, mW-sec/cm ²	UV Dose Required, mW-sec/cm ²	Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions/Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
													Emergency or Abnormal Operating Conditions/Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	Emergency or Abnormal Operating Conditions/Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
1	X	24.0	25,850	1.9										
2		24.0	17,843											
3		24.0	17,843											
4	X	24.0	17,843	2.0										
5	X	24.0	18,840	2.3										
6	X	24.0	18,840	2.0										
7	X	24.0	18,850	2.1										
8	X	24.0	14,970	2.2										
9		24.0	18,843											
10		24.0	18,843											
11	X	24.0	18,843	1.9										
12	X	24.0	18,830	2.0										
13	X	24.0	15,950	2.0										
14	X	24.0	18,620	1.8										
15	X	24.0	14,860	1.8										
16		24.0	17,657											
17		24.0	17,657											
18	X	24.0	17,657	1.6										
19	X	24.0	18,520	2.0										
20	X	24.0	23,050	1.7										
21	X	24.0	18,750	1.5										
22	X	24.0	18,860	1.8										
23		24.0	20,567											
24		24.0	20,567											
25	X	24.0	20,567	2.1										
26	X	24.0	19,750	1.6										
27	X	24.0	26,210	1.8										
28	X	24.0	15,320	2.0										
29	X	24.0	22,980	2.0										
30		24.0	34,093											
31		24.0												
Total			587,873											
Average			18,964											
Maximum			34,093											

* Refer to the instructions for this report to determine which plants must provide this information

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2540959 | Plant Name: River Grove

III. Daily Data for the Month/year of: May, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C	Flow, mg-min/L	Temp of Water, °C if Applicable	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Operating UV Dose, mW-sec/cm ²	Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions; Repair or Maintenance Work that Involves Taking Water System Components Out of Operation

1	X	24.0	51,140		2.0							1.3	
2	X	24.0	19,100		2.2							1.3	
3	X	24.0	18,660		2.1							1.4	
4	X	24.0	14,990		2.1							1.4	
5	X	24.0	14,670		2.0							1.3	
6	X	24.0	20,170										
7		24.0	20,170										
8		24.0	20,170										
9	X	24.0	20,170		2.2							1.5	
10	X	24.0	22,620		2.3							1.3	
11	X	24.0	14,640		2.1							1.2	
12	X	24.0	15,500		2.2							1.3	
13	X	24.0	18,310		1.6							1.0	
14		24.0	23,443										
15		24.0	23,443										
16	X	24.0	23,443		1.6							1.1	
17	X	24.0	18,520		1.8							1.2	
18	X	24.0	27,690		1.4							1.0	
19	X	24.0	17,340		1.6							1.1	
20	X	24.0	28,550		2.1							1.3	
21		24.0	18,043										
22		24.0	18,043										
23	X	24.0	18,043		1.7							1.1	
24	X	24.0	22,530		1.9							1.3	
25	X	24.0	22,760		1.9							1.2	
26	X	24.0	23,610		1.8							1.2	
27	X	24.0	19,400		1.9							1.3	
28		24.0	26,383										
29		24.0	26,383										
30	X	24.0	26,383		1.7							1.0	
31	X	24.0	24,270		1.8							1.3	
Total			709,560										
Average			22,889										
Maximum			51,140										

* Refer to the instructions for this report to determine which plants must provide this information

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: June, 2005

A. Public Water System (PWS) Information

PWS Name: River Grove		PWS Identification Number: 2540959	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community		<input type="checkbox"/> Consecutive	
Number of Service Connections at End of Month: 107		Total Population Served at End of Month: 375	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: PO Box 490310		City: Leesburg	State: Florida
Contact Person's Telephone Number: (352) 787-0980		Contact Person's Fax Number: (352) 787-6333	
Contact Person's E-Mail Address: beheath@aquaamerica.com			

B. Water Treatment Plant Information

Plant Name: River Grove		Plant Telephone Number: (352) 787-0980		
Plant Address: River Drive		City: East Palatka	State: Florida	
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water				
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 200,000				
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): C		
Licensed Operators	Name	License Class	License Number	Day(s)/ Shift(s) Worked
Lead/Chief Operator:	Larry White	C	7082	Days 1st Shift
Other Operators:	Paul Thompson	A	7251	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Larry White Printed or Typed Name	C7082 License Number
--------------------	--------------------------------------	-------------------------

MONTHLY OPERATION REPORT FOR PW'SS TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2540959 Plant Name: River Grove June, 2005

III. Daily Data for the Month/Year of:

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal	Peak Flow Rate, gpd	Peak Flow, mg/L	Disinfectant Residual (C) at C	Disinfectant Contact Time Provided Before or at First Measurement (T) at C	Lowest CT	Disinfectant Flow, mg. During Peak	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg. min/L	UV Dose, mW-sec/cm ²	Lowest UV Dose Required, mW-sec/cm ²	Minimum Disinfectant Concentration at Remote Point in Distribution System, mg/L	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*	
															UV Dose	UV Dose
1	X	14,770	24.0	1.2											0.8	
2	X	18,070	24.0	1.2											0.9	
3	X	12,660	24.0	1.2											0.8	
4		17,930	24.0													
5		17,930	24.0													
6	X	17,930	24.0	1.3											1.0	
7	X	15,530	24.0	1.2											1.2	
8	X	17,250	24.0	1.4											1.2	
9	X	14,600	24.0	1.3											1.1	
10	X	22,770	24.0	1.4											1.2	
11		17,550	24.0													
12		17,550	24.0													
13	X	17,550	24.0	1.2											0.8	
14	X	18,220	24.0	1.2											0.7	
15	X	14,990	24.0	1.3											1.0	
16	X	18,650	24.0	1.2											1.2	
17	X	15,200	24.0	2.0											1.4	
18		20,193	24.0													
19		20,193	24.0													
20	X	20,193	24.0	2.1											1.6	
21	X	18,970	24.0	2.2											1.9	
22	X	14,960	24.0	2.1											1.8	
23	X	23,050	24.0	1.8											1.5	
24	X	15,080	24.0	2.0											1.6	
25		18,877	24.0													
26		18,877	24.0													
27	X	18,877	24.0	2.0											1.6	
28	X	22,390	24.0	1.5											1.3	
29	X	14,750	24.0	2.1											1.5	
30	X	18,840	24.0	1.5											1.0	
31			24.0													
		Total	534,400													
		Average	17,239													
		Maximum	23,050													

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2540959 Plant Name: River Grove July, 2005

III. Daily Data for the Month/Year of:

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal	Peak Flow Rate, gpd	Lowest Residual Disinfectant Concentration (C) Before or at First Customer Measurement (T) at C	Disinfectant Contact Time Provided Before or at First Customer Measurement	Flow, mg-min/L During Peak	Temp of Water, °C If Applicable	pH of Water	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²	Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*	
													UV Dose	CT Calculations
1	X	24.0	21,100	1.5								1.1		
2		24.0	15,323											
3		24.0	15,323											
4	X	24.0	15,323	1.7								1.3		
5	X	24.0	24,770	1.8								1.3		
6	X	24.0	20,880	1.5								1.2		
7	X	24.0	15,510	1.7								1.2		
8	X	24.0	17,980	1.5								1.1		
9		24.0	20,060											
10		24.0	20,060											
11	X	24.0	20,060	1.5								1.0		
12	X	24.0	15,180	1.7								1.3		
13	X	24.0	18,730	1.7								1.3		
14	X	24.0	15,070	1.5								1.1		
15	X	24.0	14,750	1.6								1.1		
16		24.0	19,880											
17		24.0	19,880											
18	X	24.0	19,880	1.0								0.6		
19	X	24.0	14,640	0.8								0.4		
20	X	24.0	18,940	0.6								0.3		
21	X	24.0	17,760	2.1								1.4		
22	X	24.0	19,060	2.4								1.9		
23		24.0	28,670											
24		24.0	28,670											
25	X	24.0	28,670	2.6								1.9		
26	X	24.0	19,590	2.1								1.4		
27	X	24.0	19,810	2.1								1.4		
28	X	24.0	27,560	1.6								1.0		
29	X	24.0	27,230	0.9								0.5		
30		24.0	19,163											
31		24.0	19,163											
Total		618,686												
Average		19,958												
Maximum		28,670												

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: August, 2005

A. Public Water System (PWS) Information

PWS Name:	River Grove			PWS Identification Number:	2540959	
PWS Type:	<input checked="" type="checkbox"/> Community	<input type="checkbox"/> Non-Transient Non-Community	<input type="checkbox"/> Transient Non-Community	<input type="checkbox"/> Consecutive		
Number of Service Connections at End of Month:	107			Total Population Served at End of Month:	375	
PWS Owner:	Aqua Utilities Florida					
Contact Person:	Brian Heath			Contact Person's Title:	Area Manager	
Contact Person's Mailing Address:	PO Box 490310		City:	Leesburg	State:	Florida
Contact Person's Telephone Number:	(352) 787-0980			Contact Person's Fax Number:	(352) 787-6333	
Contact Person's E-Mail Address:	beheath@aquaaamerica.com					

B. Water Treatment Plant Information

Plant Name:	River Grove			Plant Telephone Number:	(352) 787-0980	
Plant Address:	River Drive		City:	East Palatka	State:	Florida
Type of Water Treatment by Plant:	<input checked="" type="checkbox"/> Raw Ground Water	<input type="checkbox"/> Purchased Finished Water				
Permitted Maximum Day Operating Capacity of Plant, gallons per day:	200,000					
Plant Category (per subsection 62-699.310(4), F.A.C.):	IV			Plant Class (per subsection 62-699.310(4), F.A.C.):	C	
Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked		
Lead/Chief Operator:	Paul Thompson	A	7251	Days 1st Shift		
Other Operators:	Larry White	C	7082	Days 1st Shift		
	David Haring	C	14091	Days 1st Shift		

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date

Paul Thompson

Printed or Typed Name

A7251

License Number

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2540959 Plant Name: River Grove

III. Daily Data for the Month/Year of: August, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation		
				CT Calculations					UV Dose							
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²	Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L			
1	X	24.0	28,745		0.8										0.5	
2	X	24.0	20,780		1.6										1.0	
3	X	24.0	18,290		1.0										0.6	
4	X	24.0	18,840		1.3										0.7	
5	X	24.0	14,740		2.4										1.7	
6		24.0	21,710													
7		24.0	21,710													
8	X	24.0	21,710		1.6										0.9	
9	X	24.0	18,080		0.9										0.5	
10	X	24.0	14,970		0.9										0.5	
11	X	24.0	17,970		1.8										1.0	
12	X	24.0	14,530		2.0										1.0	
13		24.0	20,777													
14		24.0	20,777													
15	X	24.0	20,777		1.9										1.0	
16	X	24.0	22,820		0.8										0.4	
17	X	24.0	20,120		2.1										1.3	
18	X	24.0	33,800		2.0										1.3	
19	X	24.0	20,140		0.8										0.4	
20		24.0	23,750													
21		24.0	23,750													
22	X	24.0	23,750		1.8										1.2	
23	X	24.0	23,360		1.6										1.2	
24	X	24.0	23,250		0.8										0.4	
25	X	24.0	26,260		1.4										0.7	
26	X	24.0	15,940		1.5										0.7	
27		24.0	19,767													
28		24.0	19,767													
29	X	24.0	19,767		1.3										0.6	
30	X	24.0	18,840		1.4										0.8	
31	X	24.0	18,620		0.9										0.5	
Total			648,105													
Average			20,907													
Maximum			33,800													

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2540959 Plant Name: River Grove

III. Daily Data for the Month/Year of: September, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal	Peak Flow Rate, gpd	Lowest Residual Disinfectant Concentration (C) (T) at C	Disinfectant Contact Time	Lowest CT Provided Before or at First	Temp of Water, °C	pH of Water, If Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Required UV Dose, mW-sec/cm ²	Lowest Residual Disinfectant Concentration at Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	System, mg/L	Total		Average		Maximum
														671,480	21,661	48,840		
1	X	24.0	48,840	0.8														
2	X	24.0	19,480	1.8														
3		24.0	25,980															
4		24.0	25,980															
5	X	24.0	25,980	2.4														
6	X	24.0	23,780	2.4														
7	X	24.0	29,940	2.2														
8	X	24.0	27,110	2.0														
9	X	24.0	26,800	1.7														
10		24.0	18,153															
11		24.0	18,153															
12	X	24.0	18,153	1.7														
13	X	24.0	18,830	2.5														
14	X	24.0	15,180	1.8														
15	X	24.0	22,490	1.6														
16	X	24.0	19,700	1.2														
17		24.0	22,780															
18		24.0	22,780															
19	X	24.0	22,780	2.8														
20	X	24.0	24,000	1.9														
21	X	24.0	15,500	1.7														
22	X	24.0	22,490	1.8														
23	X	24.0	10,770	1.8														
24		24.0	19,300															
25		24.0	19,300															
26	X	24.0	19,300	1.4														
27	X	24.0	31,110	1.5														
28	X	24.0	14,740	1.4														
29	X	24.0	26,800	1.3														
30	X	24.0	15,280	1.3														
31		24.0																
														671,480	21,661	48,840		

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: October, 2005

A. Public Water System (PWS) Information

PWS Name: River Grove		PWS Identification Number: 2540959	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 107		Total Population Served at End of Month: 375	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: PO Box 490310		City: Leesburg	State: Florida
		Zip Code: 34749	
Contact Person's Telephone Number: (352) 787-0980		Contact Person's Fax Number: (352) 787-6333	
Contact Person's E-Mail Address: beheath@aquamerica.com			

B. Water Treatment Plant Information

Plant Name: River Grove		Plant Telephone Number: (352) 787-0980	
Plant Address: River Drive		City: East Palatka	State: Florida
		Zip Code: 32131	
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water			
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 200,000			
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): C	
Licensed Operators	Name	License Class	License Number
Lead/Chief Operator:	Paul Thompson	A	7251
Other Operators:	Larry White	C	7082
	David Haring	C	14091

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Paul Thompson Printed or Typed Name	A7251 License Number
--------------------	--	-------------------------

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2540959 Plant Name: River Grove

III. Daily Data for the Month/Year of: October, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Staffed or Visited by Operator ("X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal	Peak Flow Rate, gpd	Lowest Residual Disinfectant Concentration (C) Before or at First Measurement (T) at C	Disinfectant Contact Time Before or at Lowest CT	Customer First Disinfectant Provided	Flow, mg-min/L During Peak Customer	Temp of Water, °C	pH of Water, If Applicable	Minimum CT Required, mg-min/L	Operating UV Dose, mW-sec/cm ²	Required UV Dose, mW-sec/cm ²	Remote Point in Distribution System, mg/L	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, If Applicable*	
														UV Dose	UV Dose
1		24.0	20,553												
2		24.0	20,553												
3	X	24.0	20,553		1.3										
4	X	24.0	13,560		1.6										
5	X	24.0	16,680		1.5										
6	X	24.0	14,310		1.7										
7	X	24.0	18,500		1.5										
8		24.0	17,007												
9		24.0	17,007												
10	X	24.0	17,007		1.5										
11	X	24.0	17,000		1.5										
12	X	24.0	18,510		1.5										
13	X	24.0	16,030		1.5										
14	X	24.0	18,300		1.4										
15		24.0	17,540												
16		24.0	17,540												
17	X	24.0	17,540		1.5										
18	X	24.0	18,610		1.7										
19	X	24.0	22,700		1.4										
20	X	24.0	9,800		1.6										
21	X	24.0	17,110		1.5										
22		24.0	20,437												
23		24.0	20,437												
24	X	24.0	20,437		2.5										
25	X	24.0	23,690		1.8										
26	X	24.0	16,900		2.2										
27	X	24.0	10,970		1.6										
28	X	24.0	18,290		2.0										
29		24.0	21,487												
30		24.0	21,487												
31	X	24.0	21,487		1.6										
Total		562,030													
Average		18,130													
Maximum		23,690													

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: November, 2005

A. Public Water System (PWS) Information

PWS Name: River Grove		PWS Identification Number: 2540959	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community		<input type="checkbox"/> Consecutive	
Number of Service Connections at End of Month: 107		Total Population Served at End of Month: 375	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: PO Box 490310		City: Leesburg	State: Florida
Contact Person's Telephone Number: (352) 787-0980		Zip Code: 34749	
Contact Person's E-Mail Address: beheath@aquaaamerica.com		Contact Person's Fax Number: (352) 787-6333	

B. Water Treatment Plant Information

Plant Name: River Grove		Plant Telephone Number: (352) 787-0980		
Plant Address: River Drive		City: East Palatka	State: Florida	
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water		Zip Code: 32131		
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 200,000				
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): C		
Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	Paul Thompson	A	7251	Days 1st Shift
Other Operators:	Larry White	C	7082	Days 1st Shift
	David Haring	C	14091	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Paul Thompson Printed or Typed Name	A7251 License Number
--------------------	--	-------------------------

MONTHLY OPERATION REPORT FOR PW'SS TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2540959 Plant Name: River Grove

III. Daily Data for the Month/Year of: November, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Started or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	Peak Flow Rate, gpd.	Peak Flow, mg/L	Customer During Before or at First Disinfectant Contact Time	Measurement (T) at C	Point During Peak Flow, mg/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg·min/L	Operating UV Dose, mW-sec/cm ²	Required UV Dose, mW-sec/cm ²	Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	CT Calculations		UV Dose															
																Disinfectant Provided	Lowest CT	UV Dose	UV Dose														
1	X		16,520	24.0	1.0																												
2	X		20,380	24.0	2.0																												
3	X		14,960	24.0	2.0																												
4	X		22,700	24.0	2.0																												
5			22,197	24.0																													
6	X		22,197	24.0																													
7	X		22,197	24.0	1.8																												
8	X		25,070	24.0	2.3																												
9	X		31,850	24.0	2.2																												
10	X		40,460	24.0	1.6																												
11	X		7,740	24.0	1.5																												
12			18,833	24.0																													
13			18,833	24.0																													
14	X		18,833	24.0	2.8																												
15	X		18,610	24.0	1.2																												
16	X		19,040	24.0	1.2																												
17	X		26,790	24.0	1.3																												
18	X		10,970	24.0	1.7																												
19			17,503	24.0																													
20			17,503	24.0																													
21	X		17,503	24.0	1.9																												
22	X		14,960	24.0	1.7																												
23	X		16,780	24.0	1.7																												
24	X		27,160	24.0	1.8																												
25	X		9,320	24.0	1.7																												
26			17,643	24.0																													
27			17,643	24.0																													
28	X		17,643	24.0	1.8																												
29	X		14,530	24.0	1.7																												
30	X		14,140	24.0	1.6																												
31			40,460	18.726																													
Total													580,510																				
Average													18,726																				
Maximum													40,460																				

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



Polymer Page 3 Due in December

See Pages 4 for Instructions.

I. General Information for the Month/Year of: December, 2005

A. Public Water System (PWS) Information

PWS Name: River Grove		PWS Identification Number: 2540959	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community		<input type="checkbox"/> Consecutive	
Number of Service Connections at End of Month: 107		Total Population Served at End of Month: 375	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: PO Box 490310		City: Leesburg	State: Florida
Contact Person's Telephone Number: (352) 787-0980		Zip Code: 34749	
Contact Person's E-Mail Address: beheath@aquaamerica.com		Contact Person's Fax Number: (352) 787-6333	

B. Water Treatment Plant Information

Plant Name: River Grove		Plant Telephone Number: (352) 787-0980		
Plant Address: River Drive		City: East Palatka	State: Florida	
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water		Zip Code: 32131		
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 200,000				
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): C		
Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	Paul Thompson	A	7251	Days 1st Shift
Other Operators:	Larry White	C	7082	Days 1st Shift
	David Haring	C	14091	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Paul Thompson Printed or Typed Name	A7251 License Number
--------------------	--	-------------------------

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2540959 Plant Name: River Grove

III. Daily Data for the Month/Year of: December, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Emergency or Abnormal Operating Conditions; Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations					UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²	Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L		
1	X	24.0	11,080		1.4									0.5	
2	X	24.0	10,010		1.8									0.6	
3		24.0	17,930												
4		24.0	17,930												
5	X	24.0	17,930		1.8									0.6	
6	X	24.0	14,640		1.7									0.7	
7	X	24.0	19,040		1.8									0.7	
8	X	24.0	18,140		1.6									0.7	
9	X	24.0	11,290		1.8									0.7	
10		24.0	17,930												
11		24.0	17,930												
12	X	24.0	17,930		2.0									0.6	
13	X	24.0	15,070		1.8									0.6	
14	X	24.0	19,040		1.7									0.4	
15	X	24.0	14,740		1.7									0.4	
16	X	24.0	18,720		2.0									0.6	
17		24.0	17,427												
18		24.0	17,427												
19	X	24.0	17,427		1.5									0.5	
20	X	24.0	24,380		1.5									0.4	
21	X	24.0	5,640		1.8									0.6	
22	X	24.0	19,150		1.5									0.4	
23	X	24.0	14,520		1.5									0.4	
24		24.0	18,903												
25		24.0	18,903												
26	X	24.0	18,903		1.8									0.5	
27	X	24.0	14,740		2.0									0.5	
28	X	24.0	17,210		2.0									0.5	
29	X	24.0	16,670		2.0									0.6	
30	X	24.0	18,630		1.8									0.4	
31		24.0	17,316												
Total			516,596												
Average			16,664												
Maximum			24,380												

* Refer to the instructions for this report to determine which plants must provide this information.