

ORIGINAL

Silver Lake Estates/Western Shores

Docket No. 060368-WS

Application to Increase Rates and Charges
For a "Class A" Utility
In

Florida

VOLUME 6

Book 7

Set 43 of 57

Containing
Additional Engineering Requirements

Monthly Operating Reports

CMP _____

COM _____

CTR _____

ECR 1

GCL _____

OPC _____

RCA _____

SCR _____

SGA _____

SEC _____

OTH _____

Aqua Utilities Florida, Inc.

DOCUMENT NUMBER DATE

00873 JAN 26 8

FPSC-COMMISSION CLERK

Aqua Utilities Florida, Inc. Monthly Operating Reports

Silver Lake Estates/Western Shores

	Tab Number	Page Number
Year: 2004		
January	1	3
February	2	5
March	3	7
April	4	9
May	5	11
June	6	13
July	7	14
August	8	16
September	9	18
October	10	20
November	11	22
December	12	24
Year: 2005		
January	1	26
February	2	28
March	3	30
April	4	32
May	5	34
June	6	36
July	7	38
August	8	40
September	9	42
October	10	44
November	11	46
December	12	48

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: January, 2004

A. Public Water System (PWS) Information

PWS Name:	Silver Lake Oaks	PWS Identification Number:	2544258
PWS Type:	<input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive		
Number of Service Connections at End of Month:	38	Total Population Served at End of Month:	94
PWS Owner:	Florida Water Services		
Contact Person:	Craig Anderson	Contact Person's Title:	VP Environmental Services
Contact Person's Mailing Address:	P.O. Box 609520	City:	Orlando
		State:	Florida
		Zip Code:	32860-9520
Contact Person's Telephone Number:	(407) 598-4199	Contact Person's Fax Number:	(407) 598-4217
Contact Person's E-Mail Address:	craigca@florida-water.com		

B. Water Treatment Plant Information

Plant Name:	Silver Lake Oaks	Plant Telephone Number:	386-329-1122
Plant Address:	7017 Silver Lake Drive	City:	Palatka
		State:	Florida
		Zip Code:	32177
Type of Water Treatment by Plant:	<input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water		
Permitted Maximum Day Operating Capacity of Plant, gallons per day:	100,800		
Plant Category (per subsection 62-699.310(4), F.A.C.):	IV	Plant Class (per subsection 62-699.310(4), F.A.C.):	D

Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	Paul Thompson	A	7251	Days 1st Shift
Other Operators:	Donald Holcomb	A	5091	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date

Paul Thompson

Printed or Typed Name

A-7251

License Number

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2544258 Plant Name: Silver Lake Oaks

III. Daily Data for the Month/Year of: January, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*								Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions: Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations				UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Minimum CT Required, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Lowest Operating UV Dose, mW-sec/cm ²			Minimum UV Dose Required, mW ² -sec/cm ²
1	X	24.0	4,500		2.3								1.3	
2	X	24.0	3,900		2.8								1.2	
3		24.0	4,500											
4		24.0	4,500											
5	X	24.0	4,500		2.3								1.3	
6	X	24.0	3,900		2.4								1.2	
7	X	24.0	3,600		2.5								1.2	
8	X	24.0	3,600		2.2								1.1	
9	X	24.0	3,500		2.4								1.4	
10		24.0	4,100											
11		24.0	4,100											
12	X	24.0	4,100		2.3								1.4	
13	X	24.0	3,500		2.4								1.4	
14	X	24.0	3,300		2.5								1.5	
15	X	24.0	4,100		2.4								1.3	
16	X	24.0	3,700		2.4								1.3	
17		24.0	4,200											
18		24.0	4,200											
19	X	24.0	4,200		2.4								1.4	
20	X	24.0	3,700		2.2								1.1	
21	X	24.0	4,000		2.0								1.1	
22	X	24.0	3,000		2.0								1.0	
23	X	24.0	3,800		2.2								1.2	
24		24.0	3,767											
25		24.0	3,767											
26	X	24.0	3,767		2.3								1.2	
27	X	24.0	3,400		2.0								1.0	
28	X	24.0	4,600		2.4								1.2	
29	X	24.0	3,000		2.3								1.1	
30	X	24.0	4,600		2.2								1.1	
31		24.0												
Total			117,400											
Average			3,787											
Maximum			4,600											

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: February, 2004

A. Public Water System (PWS) Information

PWS Name: Silver Lake Oaks		PWS Identification Number: 2544258	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community		<input type="checkbox"/> Consecutive	
Number of Service Connections at End of Month: 38		Total Population Served at End of Month: 94	
PWS Owner: Florida Water Services			
Contact Person: Craig Anderson		Contact Person's Title: VP Environmental Services	
Contact Person's Mailing Address: P.O. Box 609520		City: Orlando	State: Florida
Contact Person's Telephone Number: (407) 598-4199		Zip Code: 32860-9520	
Contact Person's E-Mail Address: craiga@florida-water.com		Contact Person's Fax Number: (407) 598-4217	

B. Water Treatment Plant Information

Plant Name: Silver Lake Oaks		Plant Telephone Number: 386-329-1122	
Plant Address: 7017 Silver Lake Drive		City: Palatka	State: Florida
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water		Zip Code: 32177	
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 100,800			
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): D	
Licensed Operators	Name	License Class	License Number / Day(s) / Shift(s) Worked
Lead/Chief Operator:	Paul Thompson	A	7251 / Days 1st Shift
Other Operators:	Donald Holcomb	A	5091 / Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Paul Thompson Printed or Typed Name	A-7251 License Number
--------------------	--	--------------------------

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2544258 Plant Name: Silver Lake Oaks

III. Daily Data for the Month/Year of: February, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions: Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
				CT Calculations					UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm	Minimum UV Dose Required, mW-sec/cm			
1		24.0	6,350												
2	X	24.0	6,350		2.5										1.4
3	X	24.0	4,400		2.5										1.3
4	X	24.0	4,100		2.0										1.1
5	X	24.0	4,000		2.0										1.0
6	X	24.0	4,200		2.2										1.0
7		24.0	4,600												
8		24.0	4,600												
9	X	24.0	4,600		2.5										1.1
10	X	24.0	3,600		2.0										1.0
11	X	24.0	3,700		2.4										1.2
12	X	24.0	3,800		2.5										1.2
13	X	24.0	4,100		2.3										1.3
14		24.0	3,467												
15		24.0	3,467												
16	X	24.0	3,467		2.0										1.0
17	X	24.0	2,800		2.2										1.0
18	X	24.0	4,100		2.5										1.2
19	X	24.0	3,200		2.3										1.2
20	X	24.0	4,100		2.6										1.3
21		24.0	3,933												
22		24.0	3,933												
23	X	24.0	3,933		2.5										1.3
24	X	24.0	4,300		2.5										1.2
25	X	24.0	3,400		3.5										2.0
26	X	24.0	3,900		2.0										1.0
27	X	24.0	4,000		2.0										1.0
28		24.0													
29		24.0													
Total:			110,400												
Average:			3,807												
Maximum:			6,350												

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: March, 2004

A. Public Water System (PWS) Information

PWS Name: <u>Silver Lake Oaks</u>		PWS Identification Number: <u>2544258</u>	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: <u>38</u>		Total Population Served at End of Month: <u>94</u>	
PWS Owner: <u>Florida Water Services</u>			
Contact Person: <u>Craig Anderson</u>		Contact Person's Title: <u>VP Environmental Services</u>	
Contact Person's Mailing Address: <u>P.O. Box 609520</u>		City: <u>Orlando</u>	State: <u>Florida</u> Zip Code: <u>32860-9520</u>
Contact Person's Telephone Number: <u>(407) 598-4199</u>		Contact Person's Fax Number: <u>(407) 598-4217</u>	
Contact Person's E-Mail Address: <u>craig@florida-water.com</u>			

B. Water Treatment Plant Information

Plant Name: <u>Silver Lake Oaks</u>		Plant Telephone Number: <u>386-329-1122</u>		
Plant Address: <u>7017 Silver Lake Drive</u>		City: <u>Palatka</u>	State: <u>Florida</u> Zip Code: <u>32177</u>	
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water				
Permitted Maximum Day Operating Capacity of Plant, gallons per day: <u>100,800</u>				
Plant Category (per subsection 62-699.310(4), F.A.C.): <u>IV</u>		Plant Class (per subsection 62-699.310(4), F.A.C.): <u>D</u>		
Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	<u>Paul Thompson</u>	<u>A</u>	<u>7251</u>	<u>Days 1st Shift</u>
Other Operators:	<u>Donald Holcomb</u>	<u>A</u>	<u>5091</u>	<u>Days 1st Shift</u>

II Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	<u>Donald Holcomb</u> Printed or Typed Name	<u>A-5091</u> License Number
--------------------	--	---------------------------------

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: April, 2004

A. Public Water System (PWS) Information

PWS Name: Silver Lake Oaks		PWS Identification Number: 2544258	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 38		Total Population Served at End of Month: 94	
PWS Owner: Florida Water Services			
Contact Person: Craig Anderson		Contact Person's Title: VP Environmental Services	
Contact Person's Mailing Address: P.O. Box 609520		City: Orlando	State: Florida
		Zip Code: 32860-9520	
Contact Person's Telephone Number: (407) 598-4199		Contact Person's Fax Number: (407) 598-4217	
Contact Person's E-Mail Address: craiga@florida-water.com			

B. Water Treatment Plant Information

Plant Name: Silver Lake Oaks		Plant Telephone Number: 386-329-1122		
Plant Address: 7017 Silver Lake Drive		City: Palatka	State: Florida	
		Zip Code: 32177		
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water				
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 100,800				
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): D		
Licensed Operators	Name	License Class	License Number	Day(s)/Shift(s) Worked
Lead/Chief Operator:	Paul Thompson	A	7251	Days 1st Shift
Other Operators:	Donald Holcomb	A	5091	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Paul Thompson	A-7251
	Printed or Typed Name	License Number

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2544258 Plant Name: Silver Lake Oaks
 III. Daily Data for the Month/year of: April, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Staffed or Visited by Operator (Place "X")	Hours plant Operation	Net Quantity of Finished Water Produced	Peak Flow Rate, gpd.	Peak Flow, mg/L	Customer During Peak Flow	Point During Peak Flow	Measurement (T) at Customer	Contact Time Before or at Customer	Disinfectant Provided	Lowest CT	Flow, mg-min/L	Temp of Water, °C	pH of Water, If Applicable	Minimum CT Required, mg-min/L	Operating UV Dose, mW-sec/cm ²	Required UV Dose, mW-sec/cm ²	Remote Point in Distribution	Emergency or Abnormal Operating Conditions: Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*		
																			UV Dose	UV Dose	
1	X	24.0	3,900	1.5																	
2	X	24.0	4,800	1.0																	
3		24.0	4,933																		
4		24.0	4,933																		
5	X	24.0	4,933	1.0																	
6	X	24.0	4,700	2.0																	
7	X	24.0	4,000	1.5																	
8	X	24.0	4,200	1.3																	
9	X	24.0	3,700	1.8																	
10		24.0	4,600																		
11		24.0	4,600																		
12	X	24.0	4,600	1.5																	
13	X	24.0	5,100	1.7																	
14	X	24.0	4,700	1.0																	
15	X	24.0	3,600	2.0																	
16	X	24.0	4,300	2.0																	
17		24.0	5,667																		
18		24.0	5,667																		
19	X	24.0	5,667	2.0																	
20	X	24.0	2,400	2.3																	
21	X	24.0	4,700	2.1																	
22	X	24.0	4,500	2.0																	
23	X	24.0	4,300	1.8																	
24		24.0	4,800																		
25		24.0	4,800																		
26	X	24.0	4,800	1.5																	
27	X	24.0	4,400	2.0																	
28	X	24.0	3,900	2.4																	
29	X	24.0	4,800	2.2																	
30	X	24.0	4,300	2.2																	
Total		136,300																			
Average		4,543																			
Maximum		5,667																			

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: May, 2004

A. Public Water System (PWS) Information

PWS Name: Silver Lake Oaks		PWS Identification Number: 2544258	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 38		Total Population Served at End of Month: 94	
PWS Owner: Florida Water Services			
Contact Person: Craig Anderson		Contact Person's Title: VP Environmental Services	
Contact Person's Mailing Address: P.O. Box 609520		City: Orlando	State: Florida
Contact Person's Telephone Number: (407) 598-4199		Zip Code: 32860-9520	
Contact Person's E-Mail Address: craiga@florida-water.com		Contact Person's Fax Number: (407) 598-4217	

B. Water Treatment Plant Information

Plant Name: Silver Lake Oaks		Plant Telephone Number: 386-329-1122	
Plant Address: 7017 Silver Lake Drive		City: Palatka	State: Florida
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water		Zip Code: 32177	
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 100,800			
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): C	

Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	Paul Thompson	A	7251	Days 1st Shift
Other Operators:	Donald Holcomb	A	5091	Days 1st Shift
	Grant Newlin	C	12423	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Paul Thompson Printed or Typed Name	A-7251 License Number
--------------------	--	--------------------------

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2544258 Plant Name: Silver Lake Oaks

III. Daily Data for the Month/Year of: May, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions: Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
				CT Calculations					UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²			
1		24.0	5,033												
2		24.0	5,033												
3	X	24.0	5,033		2.0									0.9	
4	X	24.0	2,800		1.8									0.8	
5	X	24.0	4,700		1.9									0.8	
6	X	24.0	4,200		2.0									0.9	
7	X	24.0	4,600		2.0									1.2	
8		24.0	5,867												
9		24.0	5,867												
10	X	24.0	5,867		1.8									0.9	
11	X	24.0	4,900		2.0									0.9	
12	X	24.0	4,500		2.8									1.4	
13	X	24.0	4,800		2.0									1.0	
14	X	24.0	4,400		2.0									1.3	
15		24.0	6,367												
16		24.0	6,367												
17	X	24.0	6,367		2.2									2.0	
18	X	24.0	4,400		2.0									1.0	
19	X	24.0	4,700		2.5									1.2	
20	X	24.0	4,900		2.0									0.9	
21	X	24.0	6,900		2.1									0.4	
22		24.0	5,000												
23		24.0	5,000												
24	X	24.0	5,000		2.5									1.2	
25	X	24.0	5,100		2.0									1.0	
26	X	24.0	4,200		2.5									1.2	
27	X	24.0	3,900		2.0									1.0	
28	X	24.0	4,500		2.7									1.4	
29		24.0	3,933												
30		24.0	3,933												
31	X	24.0	3,933		2.4									1.0	
Total			152,100												
Average			4,906												
Maximum			6,900												

* Refer to the instructions for this report to determine which plants must provide this information.

Docket No. 060368-WS

**Application to Increase Rates and Charges
For a "Class A" Utility
In**

Florida

Report Missing:

Monthly Operating Report

Silver Lake Oaks

June 2004

Aqua Utilities Florida, Inc.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: July, 2004

A. Public Water System (PWS) Information

PWS Name:	Silver Lake Oaks	PWS Identification Number:	2544258
PWS Type:	<input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive		
Number of Service Connections at End of Month:	38	Total Population Served at End of Month:	94
PWS Owner:	Aqua Utilities Florida		
Contact Person:	Mike Fitzgerald	Contact Person's Title:	Area Manager
Contact Person's Mailing Address:	1343 NE 17th Road	City:	Leesburg
		State:	Florida
		Zip Code:	34472
Contact Person's Telephone Number:	(352) 732-6027	Contact Person's Fax Number:	(352) 732-3213
Contact Person's E-Mail Address:	mvfitzgerald@aquaamerica.com		

B. Water Treatment Plant Information

Plant Name:	Silver Lake Oaks	Plant Telephone Number:	386-329-1122
Plant Address:	7017 Silver Lake Drive	City:	Palatka
		State:	Florida
		Zip Code:	32177
Type of Water Treatment by Plant:	<input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water		
Permitted Maximum Day Operating Capacity of Plant, gallons per day:	100,800		
Plant Category (per subsection 62-699.310(4), F.A.C.):	IV	Plant Class (per subsection 62-699.310(4), F.A.C.):	D

Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	Mark March	C	8287	
Other Operators:	Paul Thompson	A	7251	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date _____ Mark March _____ C-8287 _____
 Printed or Typed Name License Number

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2544258 Plant Name: Silver Lake Oaks

III. Daily Data for the Month/Year of: July, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*								Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations				UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²			Minimum UV Dose Required, mW-sec/cm ²
1	X	24.0	5,100		2.0								1.1	
2	X	24.0	4,100		3.5								3.0	
3		24.0	4,800											
4		24.0	4,800											
5	X	24.0	4,800		1.7								1.1	
6	X	24.0	5,800		2.3								1.2	
7	X	24.0	2,600		2.1								1.1	
8	X	24.0	5,400		1.8								1.4	
9	X	24.0	5,400		2.0								1.2	
10		24.0	3,667											
11		24.0	3,667											
12	X	24.0	3,667		2.2								1.2	
13	X	24.0	3,800		2.0								1.0	
14	X	24.0	4,700		1.9								1.0	
15	X	24.0	3,200		1.8								1.0	
16	X	24.0	4,300		1.6								0.8	
17		24.0	3,500											
18		24.0	3,500											
19	X	24.0	3,500		1.6								0.8	
20	X	24.0	3,700		1.5								0.8	
21	X	24.0	3,900		1.6								0.8	
22	X	24.0	3,800		2.4								1.0	
23	X	24.0	3,800		2.5								1.4	
24		24.0	4,233											
25		24.0	4,233											
26	X	24.0	4,233		2.5								1.3	
27	X	24.0	4,300		1.6								0.8	
28	X	24.0	4,700		1.7								0.8	
29	X	24.0	4,900		1.7								0.7	
30	X	24.0	4,600		1.8								0.7	
31		24.0	5,500											
Total			132,200											
Average			4,265											
Maximum			5,800											

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: August, 2004

A. Public Water System (PWS) Information

PWS Name: Silver Lake Oaks		PWS Identification Number: 2544258	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community		<input type="checkbox"/> Consecutive	
Number of Service Connections at End of Month: 38		Total Population Served at End of Month: 94	
PWS Owner: Aqua Utilities Florida			
Contact Person: Mike Fitzgerald		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: 1343 NE 17th Road		City: Leesburg	State: Florida Zip Code: 34472
Contact Person's Telephone Number: (352) 732-6027		Contact Person's Fax Number: (352) 732-3213	
Contact Person's E-Mail Address: mvfitzgerald@aquaaamerica.com			

B. Water Treatment Plant Information

Plant Name: Silver Lake Oaks		Plant Telephone Number: 386-329-1122	
Plant Address: 7017 Silver Lake Drive		City: Palatka	State: Florida Zip Code: 32177
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water			
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 100,800			
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): D	
Licensed Operators	Name	License Class	License Number
Lead/Chief Operator:	Mark March	C	8287
Other Operators:	Paul Thompson	A	7251
			Days 1st Shift

II Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date: _____ Printed or Typed Name: Mark March License Number: C-8287

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2544258 Plant Name: Silver Lake Oaks

III. Daily Data for the Month/Year of: August, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*								Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
				CT Calculations				UV Dose					
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²		
1		24.0	7,350										
2	X	24.0	7,350		1.8							0.7	
3	X	24.0	4,900		1.6							8.0	
4	X	24.0	6,200		2.0							0.9	
5	X	24.0	4,800		1.9							1.0	
6	X	24.0	6,400		1.8							1.0	
7		24.0	5,133										
8		24.0	5,133										
9	X	24.0	5,133		1.7							1.0	
10	X	24.0	4,500		1.7							1.0	
11	X	24.0	6,200		2.0							1.0	
12	X	24.0	5,900		2.0							1.0	
13	X	24.0	4,900		1.8							1.0	
14		24.0	4,833										
15		24.0	4,833										
16	X	24.0	4,833		1.7							0.8	
17	X	24.0	6,100		1.7							0.8	
18	X	24.0	5,300		1.7							0.8	
19	X	24.0	4,700		1.7							0.8	
20	X	24.0	4,600		1.6							0.8	
21		24.0	5,000										
22		24.0	5,000										
23	X	24.0	5,000		1.6							0.8	
24	X	24.0	4,900		1.4							0.8	
25	X	24.0	4,500		2.0							1.0	
26	X	24.0	4,700		2.0							1.0	
27	X	24.0	4,300		2.0							1.0	
28		24.0	5,400										
29		24.0	5,400										
30	X	24.0	5,400		2.0							1.0	
31	X	24.0	5,600		2.0							1.0	
Total			164,300										
Average			5,300										
Maximum			7,350										

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: September, 2004

A. Public Water System (PWS) Information

PWS Name: Silver Lake Oaks		PWS Identification Number: 2544258	
PWS Type:	<input checked="" type="checkbox"/> Community	<input type="checkbox"/> Non-Transient Non-Community	<input type="checkbox"/> Transient Non-Community
Number of Service Connections at End of Month: 38		Total Population Served at End of Month: 94	
PWS Owner: Aqua Utilities Florida			
Contact Person: Mike Fitzgerald		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: 1343 NE 17th Road		City: Leesburg	State: Florida
Contact Person's Telephone Number: (352) 732-6027		Contact Person's Fax Number: (352) 732-3213	
Contact Person's E-Mail Address: mvfitzgerald@aquaamerica.com			

B. Water Treatment Plant Information

Plant Name: Silver Lake Oaks		Plant Telephone Number: 386-329-1122	
Plant Address: 7017 Silver Lake Drive		City: Palatka	State: Florida
Type of Water Treatment by Plant:		<input checked="" type="checkbox"/> Raw Ground Water	<input type="checkbox"/> Purchased Finished Water
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 100,800			
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): D	
Licensed Operators	Name	License Class	License Number
Lead/Chief Operator:	Mark March	C	8287
Other Operators:	Paul Thompson	A	7251
			Day(s) / Shift(s) Worked
			Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Mark March Printed or Typed Name	C-8287 License Number
--------------------	-------------------------------------	--------------------------

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2544258 Plant Name: Silver Lake Oaks

III. Daily Data for the Month/year of: September, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal	Peak Flow Rate, gpd	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time Before or at First Customer During Peak Flow, minutes	Lowest CT	Temp of Water, °C	pH of Water, If Applicable	Minimum CT Required, mg·min/L	Operating UV Dose, mW·sec/cm ²	Required UV Dose, mW·sec/cm ²	Lowest Residual Disinfectant Concentration at Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	Day of the Month	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*			CT Calculations		
														Peak Flow, mg/L	Customer During Peak Flow, mg/L	Point During Peak Flow, mg/L	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time Before or at First Customer During Peak Flow, minutes	Lowest CT
X		6,000		2.0									1	2.0	2.0	2.0			
X		24.0		0.8									2	2.0	2.0	2.0			
X		3,500											3	6,300	2.8	2.8			
X		24.0											4	3,233					
X		24.0											5	3,233					
X		24.0											6	3,233					
X		24.0											7						
X		24.0											8						
X		24.0											9	3,500	0.8	0.8			
X		24.0											10	4,200	3.0	3.0			
X		24.0											11	5,833					
X		24.0											12	5,833					
X		24.0											13	5,833	3.0	3.0			
X		24.0											14	4,200	3.5	3.5			
X		24.0											15	3,200	2.8	2.8			
X		24.0											16	5,200	3.0	3.0			
X		24.0											17	3,200	3.0	3.0			
X		24.0											18	5,367					
X		24.0											19	5,367					
X		24.0											20	5,367	2.6	2.6			
X		24.0											21	4,200	2.8	2.8			
X		24.0											22	5,100	2.8	2.8			
X		24.0											23	6,100	2.6	2.6			
X		24.0											24	5,500					
X		24.0											25	6,733					
X		24.0											26	6,733					
X		24.0											27	6,733	2.7	2.7			
X		24.0											28	4,400	2.8	2.8			
X		24.0											29	7,000	2.8	2.8			
X		24.0											30	3,500					
		141,300											Total	141,300					
		Average											Average	4,558					
		Maximum											Maximum	7,000					

* Refer to the instructions for this report to determine which plants must provide this information

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: October, 2004

A. Public Water System (PWS) Information

PWS Name:	Silver Lake Oaks				PWS Identification Number:	2544258	
PWS Type:	<input checked="" type="checkbox"/> Community	<input type="checkbox"/> Non-Transient Non-Community	<input type="checkbox"/> Transient Non-Community	<input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month:	38			Total Population Served at End of Month:	94		
PWS Owner:	Aqua Utilities Florida						
Contact Person:	Mike Fitzgerald			Contact Person's Title:	Area Manager		
Contact Person's Mailing Address:	1343 NE 17th Road			City:	Leesburg	State:	Florida
Contact Person's Telephone Number:	(352) 732-6027			Contact Person's Fax Number:	(352) 732-3213		
Contact Person's E-Mail Address:	mvfitzgerald@aquaamerica.com						

B. Water Treatment Plant Information

Plant Name:	Silver Lake Oaks			Plant Telephone Number:	386-329-1122		
Plant Address:	7017 Silver Lake Drive			City:	Palatka	State:	Florida
Type of Water Treatment by Plant:	<input checked="" type="checkbox"/> Raw Ground Water	<input type="checkbox"/> Purchased Finished Water					
Permitted Maximum Day Operating Capacity of Plant, gallons per day:	100,800						

Plant Category (per subsection 62-699.310(4), F.A.C.):	IV			Plant Class (per subsection 62-699.310(4), F.A.C.):	D		
Licensed Operators:	Name	License Class	License Number	Day(s)/ Shift(s) Worked			
Lead/Chief Operator:	Mark March	C	8287				
Other Operators:	Paul Thompson	A	7251	Days 1st Shift			

II Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

	Mark March	C-8287
Signature and Date	Printed or Typed Name	License Number

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2544258 Plant Name: Silver Lake Oaks

III. Daily Data for the Month/Year of: October, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*								Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations				UV Dose						
				Peak Flow Rate, gpd	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²			Minimum UV Dose Required, mW-sec/cm ²
1	X	24.0	3,200		3.5								2.0	
2		24.0	3,800											
3		24.0	3,800											
4	X	24.0	3,800		3.2								1.8	
5	X	24.0	3,600		0.6								1.0	
6	X	24.0	3,300		3.0								1.4	
7	X	24.0	3,900		2.7								1.2	
8	X	24.0	3,700		3.5								2.2	
9		24.0	3,867											
10		24.0	3,867											
11	X	24.0	3,867		3.0								2.0	
12	X	24.0	4,300		2.0								1.2	
13	X	24.0	3,000		2.0								1.2	
14	X	24.0	3,700		1.4								0.9	
15	X	24.0	2,700		2.0								1.0	
16		24.0	3,900											
17		24.0	3,900											
18	X	24.0	3,900		2.0								0.9	
19	X	24.0	3,600		2.0								1.1	
20	X	24.0	3,400		2.3								0.8	
21	X	24.0	4,200		2.4								1.0	
22	X	24.0	3,300		2.0								1.0	
23		24.0	3,767											
24		24.0	3,767											
25	X	24.0	3,767		2.7								1.1	
26	X	24.0	7,500		2.4								1.1	
27	X	24.0	3,100		2.6								1.0	
28	X	24.0	4,700		2.4								0.9	
29	X	24.0	3,100		2.5								1.0	
30		24.0	3,366											
31		24.0	3,367											
Total			117,033											
Average			3,775											
Maximum			7,500											

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: November, 2004

A. Public Water System (PWS) Information

PWS Name:	Silver Lake Oaks	PWS Identification Number:	2544258
PWS Type:	<input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community	<input type="checkbox"/> Consecutive	
Number of Service Connections at End of Month:	38	Total Population Served at End of Month:	94
PWS Owner:	Aqua Utilities Florida		
Contact Person:	Brian Heath	Contact Person's Title:	Area Manager
Contact Person's Mailing Address:	1343 NE 17th Road	City:	Leesburg
		State:	Florida
		Zip Code:	34472
Contact Person's Telephone Number:	(352) 732-6027	Contact Person's Fax Number:	(352) 732-3213
Contact Person's E-Mail Address:	beheath@aquaaamerica.com		

B. Water Treatment Plant Information

Plant Name:	Silver Lake Oaks	Plant Telephone Number:	386-329-1122
Plant Address:	7017 Silver Lake Drive	City:	Palatka
		State:	Florida
		Zip Code:	32177
Type of Water Treatment by Plant:	<input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water		
Permitted Maximum Day Operating Capacity of Plant, gallons per day:	100,800		
Plant Category (per subsection 62-699.310(4), F.A.C.):	IV	Plant Class (per subsection 62-699.310(4), F.A.C.):	D

Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	Mark March	C	8287	
Other Operators:	Paul Thompson	A	7251	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Mark March	C-8287
	Printed or Typed Name	License Number

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2544258 Plant Name: Silver Lake Oaks

III. Daily Data for the Month/Year of: November, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*								Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions; Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations				UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²			Minimum UV Dose Required, mW-sec/cm ²
1	X	24.0	10,100		2.2								0.8	
2	X	24.0	3,700		2.4								1.2	
3	X	24.0	3,700		2.2								1.2	
4	X	24.0	3,900		1.5								0.6	
5	X	24.0	3,900		1.8								0.8	
6		24.0	3,633											
7		24.0	3,633											
8	X	24.0	3,633		2.5								1.0	
9	X	24.0	3,400		1.0								0.4	
10	X	24.0	4,000		0.8								0.7	
11	X	24.0	3,400		1.4								0.7	
12	X	24.0	4,200		2.2								0.7	
13		24.0	3,667											
14		24.0	3,667											
15	X	24.0	3,667		0.6								0.4	
16	X	24.0	3,900		1.5								0.7	
17	X	24.0	2,800		2.2								0.6	
18	X	24.0	4,600		2.2								0.6	
19	X	24.0	2,800		2.2								0.8	
20		24.0	4,567											
21		24.0	4,567											
22	X	24.0	4,567		2.6								0.8	
23	X	24.0	2,800		2.4								1.4	
24	X	24.0	4,400		2.4								0.8	
25	X	24.0	6,400		2.2								0.8	
26	X	24.0	3,400		2.2								0.7	
27		24.0	3,833											
28		24.0	3,833											
29	X	24.0	3,833		2.3								0.6	
30	X	24.0	3,200		2.5								1.2	
31		24.0												
Total			121,700											
Average			3,926											
Maximum			10,100											

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



Polymer Page 3 Due in December

See Pages 4 for Instructions.

I. General Information for the Month/Year of: December, 2004

A. Public Water System (PWS) Information

PWS Name:	Silver Lake Oaks	PWS Identification Number:	2544258
PWS Type:	<input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community	<input type="checkbox"/> Consecutive	
Number of Service Connections at End of Month:	38	Total Population Served at End of Month:	94
PWS Owner:	Aqua Utilities Florida		
Contact Person:	Brian Heath	Contact Person's Title:	Area Manager
Contact Person's Mailing Address:	1343 NE 17th Road	City:	Leesburg
		State:	Florida
Contact Person's Telephone Number:	(352) 732-6027	Zip Code:	34472
Contact Person's E-Mail Address:	beheath@aquaaamerica.com		
		Contact Person's Fax Number:	(352) 732-3213

B. Water Treatment Plant Information

Plant Name:	Silver Lake Oaks	Plant Telephone Number:	386-329-1122
Plant Address:	7017 Silver Lake Drive	City:	Palatka
		State:	Florida
Type of Water Treatment by Plant:	<input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water		
Permitted Maximum Day Operating Capacity of Plant, gallons per day:	100,800		
Plant Category (per subsection 62-699.310(4), F.A.C.):	IV	Plant Class (per subsection 62-699.310(4), F.A.C.):	D

Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	Mark March	C	8287	Days 1st Shift
Other Operators:	Paul Thompson	A	7251	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date _____ Mark March _____ C8287 _____
 Printed or Typed Name License Number

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2544258 Plant Name: Silver Lake Oaks
 III. Daily Data for the Month/Year of: December, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

CT Calculations, or UV Dose, to Demostatate Four-Log Virus Inactivation, if Applicable*
 CT Calculations
 UV Dose

Days Plant Started or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C If Applicable	pH of Water	Minimum CT Required, mg-min/L	Lowest UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²	Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
1	X	24.0	3,300	2.5									
2	X	24.0	3,600	2.3									
3	X	24.0	3,900	2.5									
4		24.0	4,567										
5		24.0	4,567										
6	X	24.0	4,567	2.6									
7	X	24.0	4,200	2.4									
8	X	24.0	2,600	2.2									
9	X	24.0	3,000	2.2									
10	X	24.0	3,100	2.0									
11		24.0	3,333										
12	X	24.0	3,333	2.4									
13	X	24.0	3,333	2.4									
14	X	24.0	3,200	2.4									
15	X	24.0	3,900	2.4									
16	X	24.0	3,000	2.4									
17	X	24.0	2,900	2.5									
18		24.0	3,700										
19		24.0	3,700										
20	X	24.0	3,700	2.2									
21	X	24.0	3,100	2.5									
22	X	24.0	3,400	2.5									
23	X	24.0	4,700	2.0									
24	X	24.0	2,400	2.1									
25		24.0	4,433										
26		24.0	4,433										
27	X	24.0	4,433	2.6									
28	X	24.0	3,400	2.4									
29	X	24.0	4,900	2.3									
30	X	24.0	4,100	2.3									
31	X	24.0	4,400	2.2									
Total		115,200											
Average		3,716											
Maximum		4,900											

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2544258 Plant Name: Silver Lake Oaks

III. Daily Data for the Month/Year of: January, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
				CT Calculations					UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²			
1		24.0	4,167												
2		24.0	4,167												
3	X	24.0	4,167		2.3									1.0	
4	X	24.0	5,400		2.2									1.0	
5	X	24.0	3,600		2.3									1.0	
6	X	24.0	4,500		2.5									1.0	
7	X	24.0	4,100		2.2									1.1	
8		24.0	4,900												
9		24.0	4,900												
10	X	24.0	4,900	3.5+									3.5+		
11	X	24.0	4,600		1.6									1.2	
12	X	24.0	4,100		1.8									0.8	
13	X	24.0	3,900		0.7									0.7	
14	X	24.0	3,600		1.0									0.9	
15		24.0	3,867												
16		24.0	3,867												
17	X	24.0	3,867		1.5									0.8	
18	X	24.0	4,300		1.5									1.2	
19	X	24.0	3,800		1.8									0.8	
20	X	24.0	6,400		1.8									1.0	
21	X	24.0	3,300		1.8									0.8	
22		24.0	4,400												
23		24.0	4,400												
24	X	24.0	4,400		2.0									1.0	
25	X	24.0	12,600		2.0									1.2	
26	X	24.0	3,100		1.6									0.8	
27	X	24.0	4,200		1.9									0.8	
28	X	24.0	4,100		1.8									0.8	
29		24.0	4,267												
30		24.0	4,267												
31	X	24.0	4,267		1.8									0.7	
Total			140,400												
Average			4,529												
Maximum			12,600												

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: February, 2005

A. Public Water System (PWS) Information

PWS Name: Silver Lake Oaks		PWS Identification Number: 2544258	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community		<input type="checkbox"/> Consecutive	
Number of Service Connections at End of Month: 51		Total Population Served at End of Month: 153	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: PO Box 490310		City: Leesburg	State: Florida
Contact Person's Telephone Number: (352) 787-0980		Contact Person's Fax Number: (352) 787-6333	
Contact Person's E-Mail Address: beheath@aquaaamerica.com			

B. Water Treatment Plant Information

Plant Name: Silver Lake Oaks		Plant Telephone Number: (352) 787-0980	
Plant Address: 7017 Silver Lake Drive		City: Palatka	State: Florida
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water			
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 100,800			
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): D	
Licensed Operators	Name	License Class	License Number
Lead/Chief Operator:	Paul Thompson	A	7251
Other Operators:			

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Paul Thompson	A7251
	Printed or Typed Name	License Number

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2544258 Plant Name: Silver Lake Oaks

III. Daily Data for the Month/Year of: February, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*								Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations				UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C if Applicable	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²			Minimum UV Dose Required, mW-sec/cm ²
1	X	24.0	4,400		1.8								0.9	
2	X	24.0	2,900		1.8								0.7	
3	X	24.0	3,900		2.4								1.2	
4	X	24.0	4,600		2.8								1.4	
5		24.0	3,600											
6		24.0	3,600											
7	X	24.0	3,600		2.2								1.0	
8	X	24.0	5,100		2.5								2.0	
9	X	24.0	2,200		2.0								1.0	
10	X	24.0	4,200		2.5								1.4	
11	X	24.0	7,800		2.2								0.8	
12		24.0	7,267											
13		24.0	7,267											
14	X	24.0	7,267		0.5								0.5	
15	X	24.0	4,300		2.8								1.4	
16	X	24.0	3,400		2.6								1.0	
17	X	24.0	4,300		2.0								1.6	
18	X	24.0	3,500		2.4								1.2	
19		24.0	7,933											
20		24.0	7,933											
21	X	24.0	7,933		2.4								1.0	
22	X	24.0	7,800		2.2								0.9	
23	X	24.0	3,500		2.3								0.9	
24	X	24.0	5,800		2.4								1.2	
25	X	24.0	2,300		2.3								1.2	
26		24.0	4,000											
27		24.0	4,000											
28	X	24.0	4,000		2.2								1.0	
29		24.0												
30		24.0												
31		24.0												
Total			138,400											
Average			4,465											
Maximum			7,933											

* Refer to the instructions for this report to determine which plants must provide this information

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: March, 2005

A. Public Water System (PWS) Information

PWS Name: Silver Lake Oaks		PWS Identification Number: 2544258	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community		<input type="checkbox"/> Consecutive	
Number of Service Connections at End of Month: 38		Total Population Served at End of Month: 94	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: PO Box 490310		City: Leesburg	State: Florida
Contact Person's Telephone Number: (352) 787-0980		Zip Code: 34749	
Contact Person's E-Mail Address: beheath@aquaaamerica.com		Contact Person's Fax Number: (352) 787-6333	

B. Water Treatment Plant Information

Plant Name: Silver Lake Oaks		Plant Telephone Number: (352) 787-0980		
Plant Address: 7017 Silver Lake Drive		City: Palatka	State: Florida	
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water		Zip Code: 32177		
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 100,800				
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): D		
Licensed Operators	Name	License Class	License Number	Day(s)/Shift(s) Worked
Lead/Chief Operator:	Paul Thompson	A	7251	Days 1st Shift
Other Operators:				

II Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

	Paul Thompson	A7251
Signature and Date	Printed or Typed Name	License Number

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2544258 Plant Name: Silver Lake Oaks

III. Daily Data for the Month/Year of: March, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demstrate Four-Log Virus Inactivation, if Applicable*										Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation		
				CT Calculations					UV Dose							
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²	Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L			
1	X	24.0	2,800		1.6										1.0	
2	X	24.0	3,500		2.2										1.0	
3	X	24.0	5,300		1.8										1.2	
4	X	24.0	3,100		2.3										1.0	
5		24.0	3,633													
6		24.0	3,633													
7	X	24.0	3,633		2.0										1.0	
8	X	24.0	5,100		1.8										0.5	
9	X	24.0	2,800		2.3										0.7	
10	X	24.0	4,200		2.4										1.2	
11	X	24.0	3,000		2.3										0.7	
12		24.0	4,300													
13		24.0	4,300													
14	X	24.0	4,300		2.5										0.8	
15	X	24.0	4,300		2.2										0.7	
16	X	24.0	5,100		2.0										0.8	
17	X	24.0	4,100		2.0										1.4	
18	X	24.0	3,600		2.0										1.2	
19		24.0	3,767													
20		24.0	3,767													
21	X	24.0	3,767		2.1										1.0	
22	X	24.0	3,500		2.2										1.7	
23	X	24.0	5,500		1.0										0.4	
24	X	24.0	3,600		2.9										2.2	
25	X	24.0	3,300		2.9										2.5	
26		24.0	3,533													
27		24.0	3,533													
28	X	24.0	3,533		2.8										2.3	
29	X	24.0	5,600		2.9										2.0	
30	X	24.0	4,100		2.0										1.0	
31	X	24.0	5,000		1.6										1.0	
Total			123,200													
Average			3,974													
Maximum			5,600													

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: April, 2005

A. Public Water System (PWS) Information

PWS Name: Silver Lake Oaks		PWS Identification Number: 2544258	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 38		Total Population Served at End of Month: 94	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: PO Box 490310		City: Leesburg	State: Florida
Contact Person's Telephone Number: (352) 787-0980		Zip Code: 34749	
Contact Person's E-Mail Address: beheath@aquaamerica.com		Contact Person's Fax Number: (352) 787-6333	

B. Water Treatment Plant Information

Plant Name: Silver Lake Oaks		Plant Telephone Number: (352) 787-0980	
Plant Address: 7017 Silver Lake Drive		City: Palatka	State: Florida
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water		Zip Code: 32177	
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 100,800			
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): D	
Licensed Operators	Name	License Class	License Number
Lead/Chief Operator:	Larry White	C	7082
Other Operators:	Paul Thompson	A	7251

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

	Larry White	C7082
Signature and Date	Printed or Typed Name	License Number

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2544258 Plant Name: Silver Lake Oaks

III. Daily Data for the Month/Year of: April, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*								Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations				UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C if Applicable	pH of Water	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²			Minimum UV Dose Required, mW-sec/cm ²
1	X	24.0	4,300		1.7								1.0	
2		24.0	3,533											
3		24.0	3,533											
4	X	24.0	3,533		1.6								0.9	
5	X	24.0	4,500		2.0								1.4	
6	X	24.0	5,800		1.6								1.0	
7	X	24.0	3,000		1.4								1.1	
8	X	24.0	4,800		1.8								1.2	
9		24.0	3,833											
10		24.0	3,833											
11	X	24.0	3,833		1.6								1.0	
12	X	24.0	5,000		1.7								1.2	
13	X	24.0	4,600		1.4								1.0	
14	X	24.0	4,300		1.5								1.2	
15	X	24.0	4,000		1.5								1.0	
16		24.0	3,967											
17		24.0	3,967											
18	X	24.0	3,967		1.7								1.3	
19	X	24.0	3,400		1.8								1.4	
20	X	24.0	6,100		1.8								1.4	
21	X	24.0	2,600		1.8								1.4	
22	X	24.0	4,600		1.4								1.1	
23		24.0	5,000											
24		24.0	5,000											
25	X	24.0	5,000		1.2								0.8	
26	X	24.0	5,000		1.6								1.1	
27	X	24.0	5,000		1.4								1.0	
28	X	24.0	4,500		1.4								1.0	
29	X	24.0	4,000		1.5								0.9	
30		24.0	5,333											
31		24.0												
Total			129,833											
Average			4,188											
Maximum			6,100											

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2544258 Plant Name: Silver Lake Oaks

III. Daily Data for the Month/Year of: May, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*								Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations				UV Dose						
				Peak Flow Rate, gpd	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²	Temp of Water, °C	pH of Water, if Applicable			Minimum CT Required, mg-min/L
1		24.0	8,000											
2	X	24.0	8,000		1.6								1.0	
3	X	24.0	4,500		1.6								1.2	
4	X	24.0	4,000		1.8								1.4	
5	X	24.0	3,700		1.8								1.4	
6	X	24.0	4,200		1.5								1.1	
7		24.0	5,367											
8		24.0	5,367											
9	X	24.0	5,367		1.6								1.2	
10	X	24.0	5,400		1.6								1.3	
11	X	24.0	4,100		1.8								1.4	
12	X	24.0	6,900		1.8								1.3	
13	X	24.0	4,200		1.5								1.0	
14		24.0	5,000											
15		24.0	5,000											
16	X	24.0	5,000		1.2								0.9	
17	X	24.0	5,000		1.4								1.0	
18	X	24.0	4,300		1.4								1.1	
19	X	24.0	4,500		1.3								1.1	
20	X	24.0	6,400		1.6								1.2	
21		24.0	5,400											
22		24.0	5,400											
23	X	24.0	5,400		1.2								0.8	
24	X	24.0	6,000		0.7								0.7	
25	X	24.0	5,100		1.0								0.7	
26	X	24.0	4,600		1.8								1.5	
27	X	24.0	5,600		1.4								1.2	
28		24.0	5,333											
29		24.0	5,333											
30	X	24.0	5,333		1.5								1.1	
31	X	24.0	3,400		1.7								1.3	
Total			161,200											
Average			5,200											
Maximum			8,000											

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: June, 2005

A. Public Water System (PWS) Information

PWS Name: Silver Lake Oaks		PWS Identification Number: 2544258	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community		<input type="checkbox"/> Consecutive	
Number of Service Connections at End of Month: 38		Total Population Served at End of Month: 94	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: PO Box 490310		City: Leesburg	State: Florida
Contact Person's Telephone Number: (352) 787-0980		Contact Person's Fax Number: (352) 787-6333	
Contact Person's E-Mail Address: beheath@aquamerica.com			

B. Water Treatment Plant Information

Plant Name: Silver Lake Oaks		Plant Telephone Number: (352) 787-0980		
Plant Address: 7017 Silver Lake Drive		City: Palatka	State: Florida	
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water				
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 100,800				
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): D		
Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	Larry White	C	7082	Days 1st Shift
Other Operators:	Paul Thompson	A	7251	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

	Larry White	C7082
Signature and Date	Printed or Typed Name	License Number

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2544258 Plant Name: Silver Lake Oaks June, 2005

III. Daily Data for the Month/Year of:

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Started or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at Contact Time	Disinfectant (T) at C	Customer First Disinfectant Measurement Point During Peak Flow, minutes	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg·min/L	Lowest UV Dose, mW·sec/cm	Minimum UV Dose Required, mW·sec/cm	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*		UV Dose	
													CT Calculations	UV Dose	UV Dose	UV Dose
1	X	24.0	6.700	2.0										2.0		1.6
2	X	24.0	5.200	2.0										2.0		1.6
3	X	24.0	4.600	2.1										2.1		1.5
4		24.0	4.767													
5		24.0	4.767													
6	X	24.0	4.767	1.9										1.9		1.4
7	X	24.0	4.500	1.8										1.8		1.4
8	X	24.0	5.000	2.0										2.0		1.6
9	X	24.0	4.300	1.8										1.8		1.2
10	X	24.0	5.800	1.7										1.7		1.2
11		24.0	6.033													
12		24.0	6.033													
13	X	24.0	6.033	1.7										1.7		1.3
14	X	24.0	7.500	2.0										2.0		1.5
15	X	24.0	3.700	2.0										2.0		1.6
16	X	24.0	10.300	2.2										2.2		2.0
17	X	24.0	4.300	1.9										1.9		1.7
18		24.0	5.733													
19	X	24.0	5.733	1.8										1.8		1.4
20	X	24.0	5.733	1.8										1.8		1.4
21	X	24.0	6.600	1.8										1.8		1.3
22	X	24.0	4.900	1.7										1.7		1.3
23	X	24.0	7.000	1.6										1.6		1.1
24	X	24.0	5.100	1.7										1.7		1.1
25		24.0	4.367													
26		24.0	4.367													
27	X	24.0	4.367	1.6										1.6		1.2
28	X	24.0	8.000	1.6										1.6		1.2
29	X	24.0	12.800	1.6										1.6		1.0
30	X	24.0	10.300	1.6										1.6		1.2
31		24.0														
Total		179,299														
Average		5,784														
Maximum		12,800														

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2544258 Plant Name: Silver Lake Oaks

III. Daily Data for the Month/year of: July, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer Point During Peak Flow, mg/L	Disinfectant Measurement (T) at C Contact Time Before or at Customer First	Flow, mg-min/L	Temp of Water, °C if Applicable	pH of Water	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Required UV Dose, mW-sec/cm ²	Minimum Disinfectant Concentration at Remote Point in Distribution System, mg/L	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*		
													UV Dose	CT Calculations	
-2		24.0	4,700												
-1	X	16,000		1.6											
2		24.0	4,700												
3		24.0	4,700												
4	X	4,700	1.6												
5	X	4,300	1.4												
6	X	6,500	1.4												
7	X	8,000	1.5												
8	X	9,000	1.2												
9		24.0	5,867												
10		24.0	5,867												
11	X	24.0	5,867	1.4											
12	X	4,200	1.3												
13	X	3,900	1.2												
14	X	4,400	1.2												
15	X	24.0	3,800	1.2											
16		24.0	5,300												
17		24.0	5,300												
18	X	24.0	5,300	1.1											
19	X	24.0	4,300	1.1											
20	X	24.0	4,000	1.2											
21	X	24.0	4,600	1.4											
22	X	24.0	3,700	1.9											
23		24.0	4,533												
24		24.0	4,533												
25	X	24.0	4,533	1.7											
26	X	24.0	3,700	1.8											
27	X	24.0	3,400	1.6											
28	X	24.0	3,700	1.5											
29	X	24.0	4,500	1.5											
30		24.0	4,433												
31		24.0	4,433												
Total		162,066													
Average		5,228													
Maximum		16,000													

* Refer to the instructions for this report to determine which plants must provide this information

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: August, 2005

A. Public Water System (PWS) Information

PWS Name: Silver Lake Oaks		PWS Identification Number: 2544258	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 38		Total Population Served at End of Month: 94	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: PO Box 490310		City: Leesburg	State: Florida
Contact Person's Telephone Number: (352) 787-0980		Contact Person's Fax Number: (352) 787-6333	
Contact Person's E-Mail Address: beheath@aquaaamerica.com			

B. Water Treatment Plant Information

Plant Name: Silver Lake Oaks		Plant Telephone Number: (352) 787-0980		
Plant Address: 7017 Silver Lake Drive		City: Palatka	State: Florida	
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water				
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 100,800				
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): D		
Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	Paul Thompson	A	7251	Days 1st Shift
Other Operators:	Larry White	C	7082	Days 1st Shift
	David Haring	C	14091	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Paul Thompson Printed or Typed Name	A7251 License Number
--------------------	--	-------------------------

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2544258 Plant Name: Silver Lake Oaks

III. Daily Data for the Month/Year of: August, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*								Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions; Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations				UV Dose						
				Peak Flow Rate, gpd	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²			Minimum UV Dose Required, mW-sec/cm ²
1	X	24.0	6,650		1.6								1.2	
2	X	24.0	3,200		1.4								1.0	
3	X	24.0	4,500		1.4								1.1	
4	X	24.0	7,000		1.4								1.1	
5	X	24.0	2,800		1.4								1.1	
6		24.0	4,600											
7		24.0	4,600											
8	X	24.0	4,600		1.0								0.8	
9	X	24.0	4,000		1.1								0.8	
10	X	24.0	4,500		1.2								0.9	
11	X	24.0	6,600		1.3								0.9	
12	X	24.0	3,300		1.2								0.8	
13		24.0	5,133											
14		24.0	5,133											
15	X	24.0	5,133		1.3								0.9	
16	X	24.0	7,200		1.1								1.0	
17	X	24.0	6,100		1.2								1.0	
18	X	24.0	5,600		1.2								1.0	
19	X	24.0	7,000		1.2								1.0	
20		24.0	4,733											
21		24.0	4,733											
22	X	24.0	4,733		1.3								1.1	
23	X	24.0	4,800		1.2								1.1	
24	X	24.0	4,000		0.7								0.4	
25	X	24.0	5,000		1.2								1.0	
26	X	24.0	4,200		1.2								1.0	
27		24.0	4,667											
28		24.0	4,667											
29	X	24.0	4,667		1.2								0.9	
30	X	24.0	4,200		1.2								1.0	
31	X	24.0	6,000		1.1								0.9	
Total			154,050											
Average			4,969											
Maximum			7,200											

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: September, 2005

A. Public Water System (PWS) Information

PWS Name: Silver Lake Oaks		PWS Identification Number: 2544258	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 38		Total Population Served at End of Month: 94	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: PO Box 490310		City: Leesburg	State: Florida
Contact Person's Telephone Number: (352) 787-0980		Contact Person's Fax Number: (352) 787-6333	
Contact Person's E-Mail Address: beheath@aquamerica.com			

B. Water Treatment Plant Information

Plant Name: Silver Lake Oaks		Plant Telephone Number: (352) 787-0980	
Plant Address: 7017 Silver Lake Drive		City: Palatka	State: Florida
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water			
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 100,800			

Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): D		
Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	Paul Thompson	A	7251	Days 1st Shift
Other Operators:	Larry White	C	7082	Days 1st Shift
	David Haring	C	14091	Days 1st Shift

II Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Paul Thompson Printed or Typed Name	A7251 License Number
--------------------	--	-------------------------

MONTHLY OPERATION REPORT FOR PW'SS TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2544258 Plant Name: Silver Lake Oaks

III. Daily Data for the Month/year of: September, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time Before or at First Customer During Peak Flow, minutes	Lowest CT Provided	Temp of Water, °C if Applicable	pH of Water, if Applicable	Minimum CT Required, mg·min/L	Lowest UV Dose Operating, mW·sec/cm ²	Minimum UV Dose Required, mW·sec/cm ²	Remote Point in Distribution System, mg/L	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*				
													UV Dose	UV Dose	UV Dose		
1	X	5,300	24.0	1.1													
2	X	5,800	24.0	1.1													
3		5,400	24.0														
4		5,400	24.0														
5	X	5,400	24.0	1.0													
6	X	5,200	24.0	1.0													
7	X	7,100	24.0	1.0													
8	X	5,800	24.0	0.9													
9	X	3,900	24.0	0.9													
10		6,100	24.0														
11		6,100	24.0														
12	X	6,100	24.0	0.8													
13	X	6,400	24.0	0.8													
14	X	5,200	24.0	1.1													
15	X	5,800	24.0	1.2													
16	X	4,900	24.0	1.0													
17		5,033	24.0														
18		5,033	24.0														
19	X	5,033	24.0	1.2													
20	X	4,500	24.0	1.2													
21	X	5,100	24.0	1.2													
22	X	6,800	24.0	1.2													
23	X	3,500	24.0	1.2													
24		3,833	24.0														
25		3,833	24.0														
26	X	3,833	24.0	1.2													
27	X	4,900	24.0	1.2													
28	X	4,300	24.0	1.2													
29	X	3,600	24.0	1.1													
30	X	4,600	24.0	1.1													
31		153,800	24.0														
		Total	153,800														
		Average	4,961														
		Maximum	7,100														

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: October, 2005

A. Public Water System (PWS) Information

PWS Name: Silver Lake Oaks		PWS Identification Number: 2544258	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 38		Total Population Served at End of Month: 94	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: PO Box 490310		City: Leesburg	State: Florida
Contact Person's Telephone Number: (352) 787-0980		Zip Code: 34749	
Contact Person's E-Mail Address: beheath@aquaaamerica.com		Contact Person's Fax Number: (352) 787-6333	

B. Water Treatment Plant Information

Plant Name: Silver Lake Oaks		Plant Telephone Number: (352) 787-0980		
Plant Address: 7017 Silver Lake Drive		City: Palatka	State: Florida	
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water		Zip Code: 32177		
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 100,800				
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): D		
Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	Paul Thompson	A	7251	Days 1st Shift
Other Operators:	Larry White	C	7082	Days 1st Shift
	David Haring	C	14091	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

	Paul Thompson	A7251
Signature and Date	Printed or Typed Name	License Number

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2544258 Plant Name: Silver Lake Oaks

III. Daily Data for the Month/Year of: October, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*								Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions: Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
				CT Calculations				UV Dose					
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²			
1		24.0	4,767										
2		24.0	4,767										
3	X	24.0	4,767		1.0							0.9	
4	X	24.0	7,800		1.0							0.9	
5	X	24.0	5,000		2.0							1.5	
6	X	24.0	4,600		0.7							0.6	
7	X	24.0	4,000		1.0							0.9	
8		24.0	5,133										
9		24.0	5,133										
10	X	24.0	5,133		0.5							0.4	
11	X	24.0	5,200		1.4							1.1	
12	X	24.0	5,700		1.4							1.1	
13	X	24.0	5,500		1.6							1.4	
14	X	24.0	4,900		1.6							1.5	
15		24.0	5,333										
16		24.0	5,333										
17	X	24.0	5,333		1.5							1.0	
18	X	24.0	7,400		1.6							1.4	
19	X	24.0	3,700		1.0							1.0	
20	X	24.0	5,000		0.9							1.0	
21	X	24.0	5,600		1.1							0.8	
22		24.0	6,067										
23		24.0	6,067										
24	X	24.0	6,067		1.2							1.1	
25	X	24.0	8,400		1.5							1.3	
26	X	24.0	4,700		1.7							1.5	
27	X	24.0	7,100		1.2							0.7	
28	X	24.0	4,100		1.0							0.7	
29		24.0	5,367										
30		24.0	5,367										
31	X	24.0	5,367		0.8							0.5	
Total			168,700										
Average			5,442										
Maximum			8,400										

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: November, 2005

A. Public Water System (PWS) Information

PWS Name:	Silver Lake Oaks			PWS Identification Number:	2544258
PWS Type:	<input checked="" type="checkbox"/> Community	<input type="checkbox"/> Non-Transient Non-Community	<input type="checkbox"/> Transient Non-Community	<input type="checkbox"/> Consecutive	
Number of Service Connections at End of Month:	38			Total Population Served at End of Month:	94
PWS Owner:	Aqua Utilities Florida				
Contact Person:	Brian Heath			Contact Person's Title:	Area Manager
Contact Person's Mailing Address:	PO Box 490310	City:	Leesburg	State:	Florida
				Zip Code:	34749
Contact Person's Telephone Number:	(352) 787-0980			Contact Person's Fax Number:	(352) 787-6333
Contact Person's E-Mail Address:	beheath@aquaamerica.com				

B. Water Treatment Plant Information

Plant Name:	Silver Lake Oaks		Plant Telephone Number:	(352) 787-0980	
Plant Address:	7017 Silver Lake Drive		City:	Palatka	State: Florida
			Zip Code:	32177	
Type of Water Treatment by Plant:	<input checked="" type="checkbox"/> Raw Ground Water		<input type="checkbox"/> Purchased Finished Water		
Permitted Maximum Day Operating Capacity of Plant, gallons per day:	100,800				
Plant Category (per subsection 62-699.310(4), F.A.C.):	IV		Plant Class (per subsection 62-699.310(4), F.A.C.):	D	
Licensed Operators:	Name	License Class	License Number	Day(s) / Shift(s) Worked	
Lead/Chief Operator:	Paul Thompson	A	7251	Days 1st Shift	
Other Operators:	Larry White	C	7082	Days 1st Shift	
	David Haring	C	14091	Days 1st Shift	

II Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Paul Thompson Printed or Typed Name	A7251 License Number
--------------------	--	-------------------------

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2544258 Plant Name: Silver Lake Oaks

III. Daily Data for the Month/year of: November, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Started or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Measurement Point During Disinfectant Contact Time	Disinfectant Provided Before or at First Measurement Point During Peak Flow, mg./min/L	Temp of Water, °C if Applicable	pH of Water	Minimum CT Required, mg./min/L	Lowest UV Dose Required, mW-sec/cm ²	UV Dose Provided, mW-sec/cm ²	Remote Point in Distribution System, mg/L	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*			
												Lowest Residual Disinfectant Concentration at Emergencly or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	UV Dose	CT Calculations	
1	X	240	5,000	0.7											
2	X	240	6,500	1.0											
3	X	240	3,300	1.0											
4	X	240	3,800	0.9											
5		240	6,167												
6		240	6,167												
7	X	240	6,167	1.2											
8	X	240	5,200	1.2											
9	X	240	6,700	0.9											
10	X	240	5,600	1.0											
11	X	240	4,700	1.2											
12		240	4,033												
13		240	4,033												
14	X	240	4,033	1.2											
15	X	240	6,400	1.5											
16	X	240	5,300	1.2											
17	X	240	5,200	1.2											
18	X	240	4,700	1.2											
19		240	4,300												
20		240	4,300												
21	X	240	4,300	1.0											
22	X	240	4,500	0.6											
23	X	240	4,100	1.0											
24	X	240	3,700	1.1											
25	X	240	7,000	1.2											
26		240	6,767												
27		240	6,767												
28	X	240	6,767	0.7											
29	X	240	5,200	1.4											
30	X	240	5,200	1.5											
31		240													
Total		155,900													
Average		5,029													
Maximum		7,000													

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



Polymer Page 3 Due in December

See Pages 4 for Instructions.

I. General Information for the Month/Year of: December, 2005

A. Public Water System (PWS) Information

PWS Name:	Silver Lake Oaks	PWS Identification Number:	2544258
PWS Type:	<input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive		
Number of Service Connections at End of Month:	38	Total Population Served at End of Month:	94
PWS Owner:	Aqua Utilities Florida		
Contact Person:	Brian Heath	Contact Person's Title:	Area Manager
Contact Person's Mailing Address:	PO Box 490310	City:	Leesburg
		State:	Florida
		Zip Code:	34749
Contact Person's Telephone Number:	(352) 787-0980	Contact Person's Fax Number:	(352) 787-6333
Contact Person's E-Mail Address:	beheath@aquamerica.com		

B. Water Treatment Plant Information

Plant Name:	Silver Lake Oaks	Plant Telephone Number:	(352) 787-0980
Plant Address:	7017 Silver Lake Drive	City:	Palatka
		State:	Florida
		Zip Code:	32177
Type of Water Treatment by Plant:	<input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water		
Permitted Maximum Day Operating Capacity of Plant, gallons per day:	100,800		
Plant Category (per subsection 62-699.310(4), F.A.C.):	IV	Plant Class (per subsection 62-699.310(4), F.A.C.):	D

Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	Paul Thompson	A	7251	Days 1st Shift
Other Operators:	Larry White	C	7082	Days 1st Shift
	David Haring	C	14091	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Paul Thompson Printed or Typed Name	A7251 License Number
--------------------	--	-------------------------

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2544258 Plant Name: Silver Lake Oaks

III. Daily Data for the Month/Year of: December, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations					UV Dose							
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg·min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg·min/L	Lowest Operating UV Dose, mW·sec/cm ²	Minimum UV Dose Required, mW·sec/cm ²				
1	X	24.0	7,000		1.4										1.2	
2	X	24.0	3,000		1.4										1.0	
3		24.0	6,167													
4		24.0	6,167													
5	X	24.0	6,167		0.6										0.4	
6	X	24.0	9,300		0.8										0.4	
7	X	24.0	4,300		1.4										0.6	
8	X	24.0	3,300		1.4										1.0	
9	X	24.0	4,400		1.3										1.0	
10		24.0	5,167													
11		24.0	5,167													
12	X	24.0	5,167		1.2										0.9	
13	X	24.0	3,700		1.2										0.8	
14	X	24.0	4,000		1.6										1.3	
15	X	24.0	4,200		1.2										0.7	
16	X	24.0	3,500		1.4										1.4	
17		24.0	4,267													
18		24.0	4,267													
19	X	24.0	4,267		0.9										0.7	
20	X	24.0	3,800		1.7										1.2	
21	X	24.0	3,700		1.8										1.4	
22	X	24.0	3,700		1.6										1.3	
23	X	24.0	4,200		1.6										1.2	
24		24.0	7,033													
25		24.0	7,033													
26	X	24.0	7,033		1.6										1.4	
27	X	24.0	8,800		1.5										1.2	
28	X	24.0	8,700		1.4										1.0	
29	X	24.0	1,500		1.4										0.8	
30	X	24.0	7,000		1.2										1.2	
31		24.0	5,200													
Total			161,200													
Average			5,200													
Maximum			9,300													

* Refer to the instructions for this report to determine which plants must provide this information.