

ORIGINAL

Tomoka/Twin Rivers

Docket No. 060368-WS

Application to Increase Rates and Charges
For a "Class A" Utility
In

Florida

VOLUME 6

Book 7

Set 51 of 57

Containing
Additional Engineering Requirements

Monthly Operating Reports

- CMP _____
- COM _____
- CTR _____
- ECR 1
- GCL _____
- OPC _____
- RCA _____
- SCR _____
- SGA _____
- SEC _____
- OTH _____

Aqua Utilities Florida, Inc.

DOCUMENT NUMBER-DATE

00881 JAN 26 8

FPSC-COMMISSION OF FRK

Aqua Utilities Florida, Inc. Monthly Operating Reports

Tomoka/Twin Rivers

	Tab Number	Page Number
Year: 2004		
January	1	3
February	2	7
March	3	11
April	4	15
May	5	19
June	6	23
July	7	24
August	8	28
September	9	32
October	10	36
November	11	40
December	12	43
Year: 2005		
January	1	47
February	2	51
March	3	54
April	4	58
May	5	62
June	6	66
July	7	70
August	8	74
September	9	78
October	10	82
November	11	86
December	12	90

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641373 Plant Name: Tomoka View

III. Daily Data for the Month/Year of: January, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions: Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
				CT Calculations					UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²			
1	X	24.0	57,800		3.2									2.5	
2	X	24.0	72,000		2.0									1.5	
3	X	24.0	39,800		2.2									1.7	
4		24.0	67,950												
5	X	24.0	67,950		2.3									1.7	
6	X	24.0	57,400		1.7									1.2	
7	X	24.0	44,200		1.8									1.0	
8	X	24.0	53,100		2.7									1.0	
9	X	24.0	55,000		2.2									1.0	
10	X	24.0	32,900		2.6									1.0	
11		24.0	59,200												
12	X	24.0	59,200		2.0									0.9	
13	X	24.0	41,200		2.2									1.1	
14	X	24.0	47,100		2.0									1.0	
15	X	24.0	41,400		2.3									1.4	
16	X	24.0	49,700		3.5									1.8	
17	X	24.0	41,100		2.8									2.5	
18		24.0	54,200												
19	X	24.0	54,200		2.5									2.0	
20	X	24.0	31,700		2.0									1.0	
21	X	24.0	37,400		2.1									1.0	
22	X	24.0	48,200		2.0									0.9	
23	X	24.0	39,800		2.3									1.6	
24	X	24.0	51,300		2.0									1.0	
25		24.0	54,350												
26	X	24.0	54,350		2.0									1.2	
27	X	24.0	36,300		2.0									1.2	
28	X	24.0	40,200		2.0									1.1	
29	X	24.0	41,200		2.1									1.1	
30	X	24.0	50,700		3.5									1.8	
31	X	24.0	34,800		2.8									2.0	
Total			1,515,700												
Average			48,894												
Maximum			72,000												

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641373 Plant Name: Tomoka View

III. Daily Data for the Month/Year of: January, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*								Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions; Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations				UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²			Minimum UV Dose Required, mW-sec/cm ²
1	X	24.0	57,800		3.2								2.5	
2	X	24.0	72,000		2.0								1.5	
3	X	24.0	39,800		2.2								1.7	
4		24.0	67,950											
5	X	24.0	67,950		2.3								1.7	
6	X	24.0	57,400		1.7								1.2	
7	X	24.0	44,200		1.8								1.0	
8	X	24.0	53,100		2.7								1.0	
9	X	24.0	55,000		2.2								1.0	
10	X	24.0	32,900		2.6								1.0	
11		24.0	59,200											
12	X	24.0	59,200		2.0								0.9	
13	X	24.0	41,200		2.2								1.1	
14	X	24.0	47,100		2.0								1.0	
15	X	24.0	41,400		2.3								1.4	
16	X	24.0	49,700		3.5								1.8	
17	X	24.0	41,100		2.8								2.5	
18		24.0	54,200											
19	X	24.0	54,200		2.5								2.0	
20	X	24.0	31,700		2.0								1.0	
21	X	24.0	37,400		2.1								1.0	
22	X	24.0	48,200		2.0								0.9	
23	X	24.0	39,800		2.3								1.6	
24	X	24.0	51,300		2.0								1.0	
25		24.0	54,350											
26	X	24.0	54,350		2.0								1.2	
27	X	24.0	36,300		2.0								1.2	
28	X	24.0	40,200		2.0								1.1	
29	X	24.0	41,200		2.1								1.1	
30	X	24.0	50,700		3.5								1.8	
31	X	24.0	34,800		2.8								2.0	
Total			1,515,700											
Average			48,894											
Maximum			72,000											

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: January, 2004

A. Public Water System (PWS) Information

PWS Name:	Twin Rivers			PWS Identification Number:	3641399
PWS Type:	<input checked="" type="checkbox"/> Community	<input type="checkbox"/> Non-Transient Non-Community	<input type="checkbox"/> Transient Non-Community	<input type="checkbox"/> Consecutive	
Number of Service Connections at End of Month:	76			Total Population Served at End of Month:	175
PWS Owner:	Florida Water Services				
Contact Person:	Craig Anderson			Contact Person's Title:	VP Environmental Services
Contact Person's Mailing Address:	P.O. Box 609520		City:	Orlando	State: Florida Zip Code: 32860-9520
Contact Person's Telephone Number:	(407) 598-4199			Contact Person's Fax Number:	(407) 598-4217
Contact Person's E-Mail Address:	craig@florida-water.com				

B. Water Treatment Plant Information

Plant Name:	Twin Rivers			Plant Telephone Number:	(386) 437-1027
Plant Address:	8 Riverdale Avenue		City:	Ormond	State: Florida Zip Code: 32174
Type of Water Treatment by Plant:	<input checked="" type="checkbox"/> Raw Ground Water		<input type="checkbox"/> Purchased Finished Water		
Permitted Maximum Day Operating Capacity of Plant, gallons per day:	100,000				
Plant Category (per subsection 62-699.310(4), F.A.C.):	IV			Plant Class (per subsection 62-699.310(4), F.A.C.): C	
Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked	
Lead/Chief Operator:	Paul Thompson	A	7251	Days 1st Shift	
Other Operators:	Donald Holcomb	A	5091	Days 1st Shift	
	Grant Newlin	C	12423	Days 1st Shift	

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date _____ Paul Thompson _____ A-7251 _____
 Printed or Typed Name License Number

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641399 Plant Name: Twin Rivers

III. Daily Data for the Month/Year of: January, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Emergency or Abnormal Operating Conditions: Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations					UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²	Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L		
1	X	24.0	18,500		2.8										2.0
2	X	24.0	24,300		2.4										1.7
3	X	24.0	9,200		2.4										1.7
4		24.0	23,000												
5	X	24.0	23,000		2.7										2.3
6	X	24.0	20,600		2.8										1.8
7	X	24.0	15,400		2.4										1.6
8	X	24.0	22,400		2.7										1.8
9	X	24.0	19,200		2.4										1.6
10	X	24.0	9,500		2.0										1.6
11		24.0	21,000												
12	X	24.0	21,000		2.2										1.5
13	X	24.0	17,900		1.8										1.4
14	X	24.0	14,000		2.4										1.5
15	X	24.0	19,600		2.5										1.8
16	X	24.0	14,900		2.5										1.8
17	X	24.0	14,000		2.5										1.9
18		24.0	15,200												
19	X	24.0	15,200		2.2										1.6
20	X	24.0	15,200		1.7										1.3
21	X	24.0	14,100		2.1										1.4
22	X	24.0	18,700		2.0										1.0
23	X	24.0	19,200		1.5										0.5
24	X	24.0	13,400		1.2										0.4
25		24.0	20,200												
26	X	24.0	20,200		1.0										0.5
27	X	24.0	14,700		2.0										1.5
28	X	24.0	10,100		2.0										1.7
29	X	24.0	14,100		2.4										1.7
30	X	24.0	13,300		2.9										1.8
31	X	24.0	14,000		2.4										1.7
Total			525,100												
Average			16,939												
Maximum			24,300												

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: February, 2004

A. Public Water System (PWS) Information

PWS Name: Tomoka View		PWS Identification Number: 3641373	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community		<input type="checkbox"/> Consecutive	
Number of Service Connections at End of Month:		Total Population Served at End of Month:	
PWS Owner: Florida Water Services			
Contact Person: Craig Anderson		Contact Person's Title: VP Environmental Services	
Contact Person's Mailing Address: P.O. Box 609520		City: Orlando	State: Florida
Contact Person's Telephone Number: (407) 598-4199		Zip Code: 32860-9520	
Contact Person's E-Mail Address: craiga@florida-water.com		Contact Person's Fax Number: (407) 598-4217	

B. Water Treatment Plant Information

Plant Name: Tomoka View		Plant Telephone Number: (386) 446-6138		
Plant Address: 339 Apache Trail		City: Ormond	State: Florida	
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water		Zip Code: 32174		
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 100,000				
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): C		
Licensed Operators	Name	License Class	License Number	Day(s)/ Shift(s) Worked
Lead/Chief Operator:	Paul Thompson	A	7251	Days 1st Shift
Other Operators:	Donald Holcomb	A	5091	Days 1st Shift
	Grant Newlin	C	12423	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Paul Thompson Printed or Typed Name	A-7251 License Number
--------------------	--	--------------------------

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641373 Plant Name: Tomoka View

III. Daily Data for the Month/Year of: February, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)

Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Emergency or Abnormal Operating Conditions; Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations					UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²	Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L		
1		24.0	47,300												
2	X	24.0	47,300		2.0									1.5	
3	X	24.0	50,200		2.4									1.9	
4	X	24.0	29,800		2.3									1.8	
5	X	24.0	38,600		2.3									1.7	
6	X	24.0	33,100		2.5									1.6	
7	X	24.0	38,600		2.4									1.6	
8		24.0	45,650												
9	X	24.0	45,650		2.3									1.5	
10	X	24.0	31,200		2.3									1.5	
11	X	24.0	41,200		2.3									0.8	
12	X	24.0	39,600		2.0									0.7	
13	X	24.0	49,100		2.0									0.7	
14	X	24.0	36,900		2.0									0.8	
15		24.0	44,050												
16	X	24.0	44,050		2.2									0.9	
17	X	24.0	41,500		2.2									0.8	
18	X	24.0	32,400		1.8									0.8	
19	X	24.0	48,600		2.0									1.7	
20	X	24.0	48,600		2.6									1.8	
21	X	24.0	39,100		2.5									1.7	
22		24.0	61,700												
23	X	24.0	61,700		3.5									2.4	
24	X	24.0	38,800		2.0									1.5	
25	X	24.0	39,900		1.8									1.0	
26	X	24.0	31,800		2.4									1.7	
27	X	24.0	42,200		2.3									1.6	
28		24.0	43,000												
29	X	24.0	43,000		2.3									1.5	
Total			1,234,600												
Average			42,572												
Maximum			61,700												

* Refer to the instructions for this report to determine which plants must provide this information

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: February, 2004

A. Public Water System (PWS) Information

PWS Name:	Twin Rivers			PWS Identification Number:	3641399
PWS Type:	<input checked="" type="checkbox"/> Community	<input type="checkbox"/> Non-Transient Non-Community	<input type="checkbox"/> Transient Non-Community	<input type="checkbox"/> Consecutive	
Number of Service Connections at End of Month:				Total Population Served at End of Month:	
PWS Owner:	Florida Water Services				
Contact Person:	Craig Anderson			Contact Person's Title:	VP Environmental Services
Contact Person's Mailing Address:	P.O. Box 609520	City:	Orlando	State:	Florida
Contact Person's Telephone Number:	(407) 598-4199	Contact Person's Fax Number:	(407) 598-4217		
Contact Person's E-Mail Address:	craiga@florida-water.com				

B. Water Treatment Plant Information

Plant Name:	Twin Rivers			Plant Telephone Number:	(386) 437-1027
Plant Address:	8 Riverdale Avenue			City:	Ormond
Type of Water Treatment by Plant:	<input checked="" type="checkbox"/> Raw Ground Water	<input type="checkbox"/> Purchased Finished Water			
Permitted Maximum Day Operating Capacity of Plant, gallons per day:	100,000				
Plant Category (per subsection 62-699.310(4), F.A.C.):	IV			Plant Class (per subsection 62-699.310(4), F.A.C.):	
				C	
Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked	
Lead/Chief Operator:	Paul Thompson	A	7251	Days 1st Shift	
Other Operators:	Donald Holcomb	A	5091	Days 1st Shift	
	Grant Newlin	C	12423	Days 1st Shift	

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	<u>Paul Thompson</u>	<u>A-7251</u>
	Printed or Typed Name	License Number

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641399	Plant Name: Twin Rivers
------------------------------------	-------------------------

III. Daily Data for the Month/Year of: February, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*								Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
				CT Calculations				UV Dose					
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²			
1		24.0	19,000										
2	X	24.0	19,000		2.5							1.8	
3	X	24.0	18,800		2.8							1.8	
4	X	24.0	9,700		2.6							1.7	
5	X	24.0	14,700		2.5							1.7	
6	X	24.0	15,900		2.4							1.8	
7	X	24.0	14,500		2.2							1.8	
8		24.0	19,100										
9	X	24.0	19,100		2.3							1.7	
10	X	24.0	9,400		2.4							1.8	
11	X	24.0	19,100		2.4							1.8	
12	X	24.0	13,900		2.5							1.8	
13	X	24.0	19,100		2.6							1.9	
14	X	24.0	10,300		2.5							1.8	
15		24.0	17,500										
16	X	24.0	17,500		2.3							1.8	
17	X	24.0	13,700		2.3							1.8	
18	X	24.0	13,600		2.4							1.7	
19	X	24.0	18,100		2.4							1.6	
20	X	24.0	11,500		2.6							1.5	
21	X	24.0	17,800		2.2							1.6	
22		24.0	22,400										
23	X	24.0	22,400		2.4							1.7	
24	X	24.0	15,400		2.1							1.6	
25	X	24.0	14,600		2.4							1.7	
26	X	24.0	11,000		2.6							1.8	PLANNED OUTAGE
27	X	24.0	31,100		3.5							2.0	
28		24.0	14,800										
29	X	24.0	14,800		2.5							1.7	
Total			477,800										
Average			16,476										
Maximum			31,100										

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: March, 2004

A. Public Water System (PWS) Information

PWS Name: Tomoka View		PWS Identification Number: 3641373	
PWS Type: <input checked="" type="checkbox"/> Community		<input type="checkbox"/> Non-Transient Non-Community	
<input type="checkbox"/> Transient Non-Community		<input type="checkbox"/> Consecutive	
Number of Service Connections at End of Month:		Total Population Served at End of Month:	
PWS Owner: Florida Water Services			
Contact Person: Craig Anderson		Contact Person's Title: VP Environmental Services	
Contact Person's Mailing Address: P.O. Box 609520		City: Orlando	State: Florida
Contact Person's Telephone Number: (407) 598-4199		Zip Code: 32860-9520	
Contact Person's E-Mail Address: craiga@florida-water.com		Contact Person's Fax Number: (407) 598-4217	

B. Water Treatment Plant Information

Plant Name: Tomoka View		Plant Telephone Number: (386) 446-6138		
Plant Address: 339 Apache Trail		City: Ormond	State: Florida	
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water		<input type="checkbox"/> Purchased Finished Water		
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 100,000		Plant Class (per subsection 62-699.310(4), F.A.C.): C		
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): C		
Licensed Operators:	Name	License Class	License Number	Day(s)/Shift(s) Worked
Lead/Chief Operator:	Paul Thompson	A	7251	Days 1st Shift
Other Operators:	Grant Newlin	C	12423	Days 1st Shift
	Donald Holcomb	A	5091	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Donald Holcomb Printed or Typed Name	A-5091 License Number
--------------------	---	--------------------------

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641373 Plant Name: Tomoka View

III. Daily Data for the Month/Year of: March, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions; Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
				CT Calculations					UV Dose						
				Peak Flow Rate, gpd	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²			
1	X	24.0	97,100		3.4									2.0	
2	X	24.0	75,200		2.5									1.5	
3	X	24.0	125,800		2.5									1.5	
4	X	24.0	109,200		3.0									1.6	
5	X	24.0	89,400		2.6									1.7	
6	X	24.0	112,000		2.3									1.4	
7		24.0	117,800												
8	X	24.0	117,800		2.3									1.3	
9	X	24.0	125,700		2.0									1.4	
10	X	24.0	97,100		2.4									1.4	
11	X	24.0	110,200		2.0									1.3	
12	X	24.0	92,300		2.0									1.4	
13	X	24.0	106,800		2.2									1.3	
14		24.0	133,350												
15	X	24.0	133,350		1.6									0.6	
16	X	24.0	108,600		3.5									1.4	
17	X	24.0	79,500		1.5									0.8	
18	X	24.0	92,000		2.2									1.2	
19	X	24.0	125,300		2.2									1.2	
20	X	24.0	80,500		2.6									1.2	
21		24.0	114,250												
22	X	24.0	114,250		2.6									1.4	
23	X	24.0	130,000		2.6									1.5	
24	X	24.0	106,000		2.5									1.4	
25	X	24.0	99,700		2.5									1.5	
26	X	24.0	83,900		3.0									1.5	
27	X	24.0	99,100		2.6									1.4	
28		24.0	129,700												
29	X	24.0	129,700		2.8									1.7	
30	X	24.0	123,100		2.6									1.7	
31	X	24.0	92,000		2.8									1.8	
Total			3,350,700												
Average			108,087												
Maximum			133,350												

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: March, 2004

A. Public Water System (PWS) Information

PWS Name: Twin Rivers		PWS Identification Number: 3641399	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community		<input type="checkbox"/> Consecutive	
Number of Service Connections at End of Month:		Total Population Served at End of Month:	
PWS Owner: Florida Water Services			
Contact Person: Craig Anderson		Contact Person's Title: VP Environmental Services	
Contact Person's Mailing Address: P.O. Box 609520		City: Orlando	State: Florida
Contact Person's Telephone Number: (407) 598-4199		Zip Code: 32860-9520	
Contact Person's E-Mail Address: craiga@florida-water.com		Contact Person's Fax Number: (407) 598-4217	

B. Water Treatment Plant Information

Plant Name: Twin Rivers		Plant Telephone Number: (386) 437-1027	
Plant Address: 8 Riverdale Avenue		City: Ormond	State: Florida
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water		Zip Code: 32174	
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 100,000		Plant Class (per subsection 62-699.310(4), F.A.C.): C	
Plant Category (per subsection 62-699.310(4), F.A.C.): IV			

Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	Paul Thompson	A	7251	Days 1st Shift
Other Operators:	Donald Holcomb	A	5091	Days 1st Shift
	Grant Newlin	C	12423	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Donald Holcomb Printed or Typed Name	A-5091 License Number
--------------------	---	--------------------------

MONTHLY OPERATION REPORT FOR PW'SS TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641399 Plant Name: Twin Rivers

III. Daily Data for the Month/Year of: March, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer Measurement	Disinfectant Contact Time Before or at First Customer Measurement	Temp of Water, mg-Point During Peak Flow, min/L	pH of Water, °C If Applicable	Minimum CT Required, mg-min/L	Lowest UV Dose, mW-sec/cm ²	Minimum UV Dose, mW-sec/cm ²	Remote Point in Distribution System, mg/L	CT Calculations	
												UV Dose	UV Dose
1	X	24.0	23,200	2.6	2.6								
2	X	24.0	18,300	2.5	2.5								
3	X	24.0	13,600	2.0	2.0								
4	X	24.0	18,100	3.0	3.0								
5	X	24.0	24,700	2.5	2.5								
6	X	24.0	14,400	2.4	2.4								
7		24.0	23,050										
8	X	24.0	23,050	2.4	2.4								
9	X	24.0	23,400	2.4	2.4								
10	X	24.0	12,800	2.3	2.3								
11	X	24.0	16,900	2.0	2.0								
12	X	24.0	24,600	2.8	2.8								
13	X	24.0	17,700	2.5	2.5								
14		24.0	22,200										
15	X	24.0	22,200	2.2	2.2								
16	X	24.0	18,600	2.2	2.2								
17	X	24.0	13,700	2.6	2.6								
18	X	24.0	13,300	2.4	2.4								
19	X	24.0	17,300	2.2	2.2								
20	X	24.0	9,300	2.4	2.4								
21		24.0	21,950										
22	X	24.0	21,950	2.2	2.2								
23	X	24.0	18,700	2.3	2.3								
24	X	24.0	16,500	2.3	2.3								
25	X	24.0	16,600	2.4	2.4								
26	X	24.0	13,800	2.0	2.0								
27	X	24.0	18,900	2.1	2.1								
28		24.0	29,500										
29	X	24.0	29,500	2.2	2.2								
30	X	24.0	27,300	2.2	2.2								
31	X	24.0	22,200	1.8	1.8								
Total			607,300										
Average			19,590										
Maximum			29,500										

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: April, 2004

A. Public Water System (PWS) Information

PWS Name: Tomoka View		PWS Identification Number: 3641373	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 189		Total Population Served at End of Month: 443	
PWS Owner: Florida Water Services			
Contact Person: Craig Anderson		Contact Person's Title: VP Environmental Services	
Contact Person's Mailing Address: P.O. Box 609520		City: Orlando	State: Florida
Contact Person's Telephone Number: (407) 598-4199		Zip Code: 32860-9520	
Contact Person's E-Mail Address: craiga@florida-water.com		Contact Person's Fax Number: (407) 598-4217	

B. Water Treatment Plant Information

Plant Name: Tomoka View		Plant Telephone Number: (386) 446-6138		
Plant Address: 339 Apache Trail		City: Ormond	State: Florida	
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water		Zip Code: 32174		
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 100,000				
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): C		
Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	Paul Thompson	A	7251	Days 1st Shift
Other Operators:	Donald Holcomb	A	5091	Days 1st Shift
	Grant Newlin	C	12423	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Paul Thompson Printed or Typed Name	A-7251 License Number
--------------------	--	--------------------------

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641373 Plant Name: Tomoka View

III. Daily Data for the Month/Year of: April, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
				CT Calculations					UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²			
1	X	24.0	59,300		2.8									1.8	
2	X	24.0	55,900		2.5									1.5	
3	X	24.0	34,300		2.5									1.5	
4		24.0	69,850												
5	X	24.0	69,850		2.4									1.4	
6	X	24.0	44,900		2.0									1.8	
7	X	24.0	52,800		1.8									1.4	
8	X	24.0	47,400		1.8									1.3	
9	X	24.0	66,400		2.8									1.5	
10		24.0	62,650												
11	X	24.0	62,650		2.8									1.5	
12	X	24.0	67,600		2.7									1.5	
13	X	24.0	72,500		2.7									1.5	
14	X	24.0	37,600		1.8									1.0	
15	X	24.0	48,600		1.8									1.0	
16	X	24.0	52,700		1.8									0.8	
17	X	24.0	38,800		1.7									0.8	
18		24.0	63,700												
19	X	24.0	63,700		1.8									0.9	
20	X	24.0	54,800		1.8									0.9	
21	X	24.0	51,300		2.5									1.2	
22	X	24.0	65,100		2.4									1.2	
23	X	24.0	57,900		2.0									1.0	
24	X	24.0	46,900		2.0									1.2	
25		24.0	85,000												
26	X	24.0	85,000		1.8									1.0	
27	X	24.0	45,000		2.7									0.5	
28	X	24.0	48,300		2.2									0.9	
29	X	24.0	50,000		2.2									1.0	
30	X	24.0	56,600		1.8									0.9	
Total			1,717,100												
Average			57,237												
Maximum			85,000												

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: April, 2004

A. Public Water System (PWS) Information

PWS Name: Twin Rivers		PWS Identification Number: 3641399	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 76		Total Population Served at End of Month: 175	
PWS Owner: Florida Water Services			
Contact Person: Craig Anderson		Contact Person's Title: VP Environmental Services	
Contact Person's Mailing Address: P.O. Box 609520		City: Orlando	State: Florida
Contact Person's Telephone Number: (407) 598-4199		Zip Code: 32860-9520	
Contact Person's E-Mail Address: craiga@florida-water.com		Contact Person's Fax Number: (407) 598-4217	

B. Water Treatment Plant Information

Plant Name: Twin Rivers		Plant Telephone Number: (386) 437-1027		
Plant Address: 8 Riverdale Avenue		City: Ormond	State: Florida	
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water		Zip Code: 32174		
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 100,000				
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): C		
Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	Paul Thompson	A	7251	Days 1st Shift
Other Operators:	Donald Holcomb	A	5091	Days 1st Shift
	Grant Newlin	C	12423	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Paul Thompson Printed or Typed Name	A-7251 License Number
--------------------	--	--------------------------

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641399 Plant Name: Twin Rivers

III. Daily Data for the Month/Year of: April, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations					UV Dose							
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²				
1	X	24.0	23,700		1.0										0.8	
2	X	24.0	18,400		2.4										1.4	
3	X	24.0	17,500		2.4										1.7	
4		24.0	32,150													
5	X	24.0	32,150		2.3										1.6	
6	X	24.0	23,200		2.7										1.7	
7	X	24.0	27,800		2.4										1.7	
8	X	24.0	24,700		2.5										1.8	
9	X	24.0	23,800		2.5										1.8	
10		24.0	22,550													
11	X	24.0	22,550		2.0										1.5	
12	X	24.0	28,700		2.4										1.8	
13	X	24.0	20,500		2.3										1.7	
14	X	24.0	16,200		2.3										1.7	
15	X	24.0	18,100		2.4										1.8	
16	X	24.0	22,600		2.0										1.6	
17	X	24.0	14,600		2.0										1.6	
18		24.0	27,050													
19	X	24.0	27,050		1.9										1.6	
20	X	24.0	25,000		2.0										1.7	
21	X	24.0	26,200		2.0										1.7	
22	X	24.0	49,400		2.0										1.7	
23	X	24.0	29,600		2.0										1.8	
24	X	24.0	15,300		1.8										1.6	
25		24.0	33,300													
26	X	24.0	33,300		2.0										1.6	
27	X	24.0	26,200		2.4										2.0	
28	X	24.0	29,200		2.3										2.6	
29	X	24.0	26,700		2.3										2.0	
30	X	24.0	25,600		2.3										2.0	

Total	763,100
Average	25,437
Maximum	49,400

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: May, 2004

A. Public Water System (PWS) Information

PWS Name: Tomoka View		PWS Identification Number: 3641373	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 189		Total Population Served at End of Month: 443	
PWS Owner: Florida Water Services			
Contact Person: Craig Anderson		Contact Person's Title: VP Environmental Services	
Contact Person's Mailing Address: P.O. Box 609520		City: Orlando	State: Florida
		Zip Code: 32860-9520	
Contact Person's Telephone Number: (407) 598-4199		Contact Person's Fax Number: (407) 598-4217	
Contact Person's E-Mail Address: craiga@florida-water.com			

B. Water Treatment Plant Information

Plant Name: Tomoka View		Plant Telephone Number: (386) 446-6138	
Plant Address: 339 Apache Trail		City: Ormond	State: Florida
		Zip Code: 32174	
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water			
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 100,000			
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): C	
Licensed Operators	Name	License Class	License Number
Lead/Chief Operator:	Paul Thompson	A	7251
Other Operators:	Donald Holcomb	A	5091
	Grant Newlin	C	12423

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Paul Thompson Printed or Typed Name	A-7251 License Number
--------------------	--	--------------------------

MONTHLY OPERATION REPORT FOR PW'SS TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number 3641373 Plant Name: Tomoka View

III. Daily Data for the Month/year of: May, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal	Peak Flow Rate, gpd	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C if Applicable	pH of Water	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²	Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	CT Calculations	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*	
														UV Dose	UV Dose
1		47,367	24.0	47,367											
2		24.0		47,367											
3	X	24.0		47,367											
4	X	24.0		36,600											
5	X	24.0		43,100											
6	X	24.0		44,800											
7	X	24.0		60,500											
8	X	24.0		24,000											
9		24.0		74,950											
10	X	24.0		74,950											
11	X	24.0		47,300											
12	X	24.0		51,000											
13	X	24.0		63,400											
14	X	24.0		60,000											
15	X	24.0		54,400											
16		24.0		84,750											
17	X	24.0		84,750											
18	X	24.0		84,800											
19	X	24.0		84,700											
20	X	24.0		60,900											
21	X	24.0		56,100											
22	X	24.0		41,500											
23		24.0		84,050											
24	X	24.0		84,050											
25	X	24.0		74,400											
26	X	24.0		63,500											
27	X	24.0		75,000											
28	X	24.0		68,500											
29	X	24.0		53,300											
30		24.0		76,600											
31	X	24.0		76,600											
Total		1,930,600													
Average		62.277													
Maximum		84,800													

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: May, 2004

A. Public Water System (PWS) Information

PWS Name: <u>Twin Rivers</u>		PWS Identification Number: <u>3641399</u>	
PWS Type: <input checked="" type="checkbox"/> Community		<input type="checkbox"/> Non-Transient Non-Community	
<input type="checkbox"/> Transient Non-Community		<input type="checkbox"/> Consecutive	
Number of Service Connections at End of Month: <u>76</u>		Total Population Served at End of Month: <u>175</u>	
PWS Owner: <u>Florida Water Services</u>			
Contact Person: <u>Craig Anderson</u>		Contact Person's Title: <u>VP Environmental Services</u>	
Contact Person's Mailing Address: <u>P.O. Box 609520</u>		City: <u>Orlando</u>	State: <u>Florida</u>
Contact Person's Telephone Number: <u>(407) 598-4199</u>		Zip Code: <u>32860-9520</u>	
Contact Person's E-Mail Address: <u>craig@florida-water.com</u>		Contact Person's Fax Number: <u>(407) 598-4217</u>	

B. Water Treatment Plant Information

Plant Name: <u>Twin Rivers</u>		Plant Telephone Number: <u>(386) 437-1027</u>		
Plant Address: <u>8 Riverdale Avenue</u>		City: <u>Ormond</u>	State: <u>Florida</u>	
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water		<input type="checkbox"/> Purchased Finished Water		
Permitted Maximum Day Operating Capacity of Plant, gallons per day: <u>100,000</u>				
Plant Category (per subsection 62-699.310(4), F.A.C.): <u>IV</u>		Plant Class (per subsection 62-699.310(4), F.A.C.): <u>C</u>		
Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	<u>Paul Thompson</u>	<u>A</u>	<u>7251</u>	<u>Days 1st Shift</u>
Other Operators:	<u>Donald Holcomb</u>	<u>A</u>	<u>5091</u>	<u>Days 1st Shift</u>
	<u>Grant Newlin</u>	<u>C</u>	<u>12423</u>	<u>Days 1st Shift</u>

II Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	<u>Paul Thompson</u> Printed or Typed Name	<u>A-7251</u> License Number
--------------------	---	---------------------------------

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641399 Plant Name: Twin Rivers May, 2004

III. Daily Data for the Month Year of:

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Visited or Operator ("X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Measurement (T) at C	Contact Time	Lowest CT	Provided	Before or at First	Customer During Peak	Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT	Operating UV Dose, mW-sec/cm	Required UV Dose, mW-sec/cm	Lowest UV Dose, mW-sec/cm	Required UV Dose, mW-sec/cm	Minimum UV Dose, mW-sec/cm	Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
																						CT Calculations
1			24.0	24.367																		
2	X		24.0	24.367																		
3	X		24.0	24.367																		
4	X		24.0	15,800																		2.0
5	X		24.0	11,900																		1.6
6	X		24.0	21,600																		1.7
7	X		24.0	28,400																		1.8
8	X		24.0	25,800																		1.6
9			24.0	35,350																		
10	X		24.0	35,350																		1.4
11	X		24.0	24,100																		1.7
12	X		24.0	21,900																		1.5
13	X		24.0	26,200																		1.7
14	X		24.0	25,800																		1.6
15	X		24.0	20,600																		1.6
16			24.0	37,150																		
17	X		24.0	37,150																		0.7
18	X		24.0	25,000																		1.2
19	X		24.0	30,900																		1.3
20	X		24.0	28,200																		1.2
21	X		24.0	39,200																		1.4
22	X		24.0	28,200																		1.4
23			24.0	36,850																		
24	X		24.0	36,850																		1.3
25	X		24.0	37,800																		1.4
26	X		24.0	27,300																		1.4
27	X		24.0	50,900																		1.4
28	X		24.0	24,000																		1.5
29	X		24.0	36,000																		1.4
30			24.0	40,650																		
31	X		24.0	40,650																		1.6
Total			922,700																			
Average			29,765																			
Maximum			50,900																			

* Refer to the instructions for this report to determine which plants must provide this information.

Docket No. 060368-WS
Application to Increase Rates and Charges
For a "Class A" Utility
In
Florida

Report Missing:
Monthly Operating Report
Tomoka/Twin Rivers
June 2004

Aqua Utilities Florida, Inc.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: July, 2004

A. Public Water System (PWS) Information

PWS Name: Tomoka View		PWS Identification Number: 3641373	
PWS Type:	<input checked="" type="checkbox"/> Community	<input type="checkbox"/> Non-Transient Non-Community	<input type="checkbox"/> Transient Non-Community
Number of Service Connections at End of Month: 189		Total Population Served at End of Month: 443	
PWS Owner: Aqua Utilities Florida			
Contact Person: Michael Fitzgerald		Contact Person's Title: Area Manager	
Contact Person's Mailing Address:	1343 NE 17th Road	City: Ocala	State: Florida
Contact Person's Telephone Number:	(352) 732-6027	Contact Person's Fax Number:	(352) 732-3213
Contact Person's E-Mail Address:	mvfitzgerald@aquaaamerica.com		

B. Water Treatment Plant Information

Plant Name: Tomoka View		Plant Telephone Number: (386) 446-6138	
Plant Address: 339 Apache Trail		City: Ormond	State: Florida
Type of Water Treatment by Plant:		<input checked="" type="checkbox"/> Raw Ground Water	<input type="checkbox"/> Purchased Finished Water
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 100,000			
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): C	

Licensed Operators	Name	License Class	License Number	Day(s)/Shift(s) Worked
Lead/Chief Operator:	Mark March	C	8287	
Other Operators:	Paul Thompson	A	7251	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

	Mark March	C-8287
Signature and Date	Printed or Typed Name	License Number

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641373 Plant Name: Tomoka View July, 2004

III. Daily Data for the Month/year of:

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Measurement	Disinfectant Contact Time Before or at First Measurement (T) at C	Lowest CT Provided	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg·min/L	Operating UV Dose, mW·sec/cm ²	Required UV Dose, mW·sec/cm ²	CT Calculations, if Applicable*		Emergency or Abnormal Operating Conditions: Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
												UV Dose	System, mg/L	
1	X	42,000	24.0	2.1										
2	X	48,300	24.0	2.4										
3	X	55,600	24.0	2.3										
4		32,550	24.0											
5	X	32,550	24.0	1.6										
6	X	46,000	24.0	2.0										
7	X	34,400	24.0	2.3										
8	X	42,400	24.0	1.9										
9	X	30,900	24.0	1.5										
10	X	35,800	24.0	1.2										
11		46,850	24.0											
12	X	46,850	24.0	1.6										
13	X	30,600	24.0	1.8										
14	X	51,700	24.0	2.3										
15	X	42,800	24.0	2.8										
16	X	34,600	24.0	3.0										
17	X	24,200	24.0	3.0										
18		48,600	24.0											
19	X	48,600	24.0	3.0										
20	X	44,800	24.0	3.0										
21	X	35,500	24.0	3.2										
22	X	46,100	24.0	3.2										
23	X	50,400	24.0	3.2										
24	X	37,500	24.0	3.4										
25		64,000	24.0											
26	X	64,000	24.0	3.3										
27	X	55,200	24.0	3.0										
28	X	41,900	24.0	3.2										
29	X	54,100	24.0	3.5										
30	X	64,400	24.0	2.4										
31	X	49,500	24.0	2.5										
Total		1,382,700												
Average		44,603												
Maximum		64,400												

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: July, 2004

A. Public Water System (PWS) Information

PWS Name:	Twin Rivers			PWS Identification Number:	3641399
PWS Type:	<input checked="" type="checkbox"/> Community	<input type="checkbox"/> Non-Transient Non-Community	<input type="checkbox"/> Transient Non-Community	<input type="checkbox"/> Consecutive	
Number of Service Connections at End of Month:	76			Total Population Served at End of Month:	175
PWS Owner:	Aqua Utilities Florida				
Contact Person:	Michael Fitzgerald			Contact Person's Title:	Area Manager
Contact Person's Mailing Address:	1343 NE 17th Road	City:	Ocala	State:	Florida
Contact Person's Telephone Number:	(352) 732-6027			Contact Person's Fax Number:	(352) 732-3213
Contact Person's E-Mail Address:	mvfitzgerald@aquaaamerica.com				

B. Water Treatment Plant Information

Plant Name:	Twin Rivers			Plant Telephone Number:	(386) 437-1027	
Plant Address:	8 Riverdale Avenue			City:	Ormond	
Type of Water Treatment by Plant:	<input checked="" type="checkbox"/> Raw Ground Water	<input type="checkbox"/> Purchased Finished Water				
Permitted Maximum Day Operating Capacity of Plant, gallons per day:	100,000					
Plant Category (per subsection 62-699.310(4), F.A.C.):	IV			Plant Class (per subsection 62-699.310(4), F.A.C.):	C	
Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked		
Lead/Chief Operator:	Mark March	C	8287			
Other Operators:	Paul Thompson	A	7251	Days 1st Shift		

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

	Mark March	C-8287
Signature and Date	Printed or Typed Name	License Number

MONTHLY OPERATION REPORT FOR PW'SS TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641399 Plant Name: Twin Rivers

III. Daily Data for the Month/Year of: July, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer Measurement Point During Peak Flow, mg-minutes	Disinfectant Contact Time Provided Before or at First Customer Measurement Point During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²	Lowest Residual Disinfectant Concentration at Distribution	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	CT Calculations		Total	Average	Maximum
													UV Dose	CT Calculations			
1	X	18,400	24.0	2.9	2.9										662,800	21,381	30,100
2	X	29,400	24.0	3.1	2.9										19,700	24.0	24.0
3	X	30,100	24.0	2.9	2.9										28,900	24.0	24.0
4		18,000	24.0												21,900	24.0	24.0
5	X	18,000	24.0	2.5	2.5										24,700	24.0	24.0
6	X	29,600	24.0	2.6	2.6										18,900	24.0	24.0
7	X	28,700	24.0	2.6	2.6										30,050	24.0	24.0
8	X	21,500	24.0	2.7	2.7										30,050	24.0	24.0
9	X	15,600	24.0	2.0	2.0										18,800	24.0	24.0
10	X	13,100	24.0	2.0	2.0										21,200	24.0	24.0
11		19,600	24.0												22,200	24.0	24.0
12	X	19,600	24.0	1.7	1.7										18,700	24.0	24.0
13	X	13,900	24.0	2.0	2.0										22,200	24.0	24.0
14	X	26,100	24.0	1.8	1.8										18,700	24.0	24.0
15	X	14,500	24.0	2.0	2.0										21,900	24.0	24.0
16	X	16,600	24.0	1.8	1.8										24,700	24.0	24.0
17	X	10,700	24.0	2.0	2.0										21,900	24.0	24.0
18		24,100	24.0												24,700	24.0	24.0
19	X	24,100	24.0	2.2	2.2										18,900	24.0	24.0
20	X	16,100	24.0	2.4	2.4										30,050	24.0	24.0
21	X	18,700	24.0	2.4	2.4										30,050	24.0	24.0
22	X	22,200	24.0	2.5	2.5										18,800	24.0	24.0
23	X	21,200	24.0	2.2	2.2										21,200	24.0	24.0
24	X	18,800	24.0	2.3	2.3										30,050	24.0	24.0
25		30,050	24.0												30,050	24.0	24.0
26	X	30,050	24.0	2.3	2.3										19,700	24.0	24.0
27	X	18,900	24.0	2.3	2.3										21,900	24.0	24.0
28	X	24,700	24.0	2.2	2.2										21,900	24.0	24.0
29	X	21,900	24.0	2.0	2.0										21,900	24.0	24.0
30	X	28,900	24.0	2.0	2.0										21,900	24.0	24.0
31	X	19,700	24.0	2.0	2.0										19,700	24.0	24.0

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: August, 2004

A. Public Water System (PWS) Information

PWS Name: Tomoka View		PWS Identification Number: 3641373	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 189		Total Population Served at End of Month: 443	
PWS Owner: Aqua Utilities Florida			
Contact Person: Michael Fitzgerald		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: 1343 NE 17th Road		City: Ocala	State: Florida Zip Code: 34470
Contact Person's Telephone Number: (352) 732-6027		Contact Person's Fax Number: (352) 732-3213	
Contact Person's E-Mail Address: mvfitzgerald@aquaaamerica.com			

B. Water Treatment Plant Information

Plant Name: Tomoka View		Plant Telephone Number: (386) 446-6138		
Plant Address: 339 Apache Trail		City: Ormond	State: Florida Zip Code: 32174	
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water				
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 100,000				
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): C		
Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	Mark March	C	8287	
Other Operators:	Paul Thompson	A	7251	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date _____ Mark March _____ C-8287 _____
 Printed or Typed Name License Number

MONTHLY OPERATION REPORT FOR PW'SS TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641373 Plant Name: Tomoka View August, 2004

III. Daily Data for the Month/year of:

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	Peak Flow, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C If Applicable	pH of Water	Minimum CT Required, mg-min/L	Operating UV Dose, mW-sec/cm ²	Required UV Dose, mW-sec/cm ²	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*		Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
												Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	UV Dose	

1	X	24.0	50,100	2.0										
2	X	24.0	50,100	2.0										
3	X	24.0	43,300	3.2										1.8
4	X	24.0	56,900	3.0										1.8
5	X	24.0	31,600	3.3										2.0
6	X	24.0	38,100	3.5										2.0
7	X	24.0	25,800	3.3										2.0
8		24.0	44,750											
9	X	24.0	44,750	3.3										2.0
10	X	24.0	31,100	3.2										2.2
11	X	24.0	26,400	3.0										2.0
12	X	24.0	44,800	3.2										2.2
13	X	24.0	33,700	3.2										2.0
14	X	24.0	32,900	3.0										2.0
15		24.0	35,950											
16	X	24.0	35,950	3.0										2.0
17	X	24.0	29,200	3.0										2.0
18	X	24.0	38,200	3.2										2.0
19	X	24.0	36,000	2.8										2.0
20	X	24.0	40,500	3.0										2.0
21	X	24.0	27,700	3.0										2.0
22		24.0	43,350											
23	X	24.0	43,350	1.8										1.2
24	X	24.0	31,700	2.0										1.0
25	X	24.0	55,700	1.8										1.0
26	X	24.0	36,300	1.6										1.0
27	X	24.0	33,200	2.8										1.2
28	X	24.0	25,100	2.7										1.2
29		24.0	47,200											
30	X	24.0	47,200	2.8										1.2
31	X	24.0	31,000	2.5										
Total		1,191,900												
Average		38,448												
Maximum		56,900												

* Refer to the instructions for this report to determine which plants must provide this information

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: August, 2004

A. Public Water System (PWS) Information

PWS Name:	Twin Rivers			PWS Identification Number:	3641399
PWS Type:	<input checked="" type="checkbox"/> Community	<input type="checkbox"/> Non-Transient Non-Community	<input type="checkbox"/> Transient Non-Community	<input type="checkbox"/> Consecutive	
Number of Service Connections at End of Month:	76			Total Population Served at End of Month:	175
PWS Owner:	Aqua Utilities Florida				
Contact Person:	Michael Fitzgerald			Contact Person's Title:	Area Manager
Contact Person's Mailing Address:	1343 NE 17th Road	City:	Ocala	State:	Florida
Contact Person's Telephone Number:	(352) 732-6027			Contact Person's Fax Number:	(352) 732-3213
Contact Person's E-Mail Address:	mvfitzgerald@aquaaamerica.com				

B. Water Treatment Plant Information

Plant Name:	Twin Rivers			Plant Telephone Number:	(386) 437-1027
Plant Address:	8 Riverdale Avenue			City:	Ormond
Type of Water Treatment by Plant:	<input checked="" type="checkbox"/> Raw Ground Water	<input type="checkbox"/> Purchased Finished Water			
Permitted Maximum Day Operating Capacity of Plant, gallons per day:	100,000				
Plant Category (per subsection 62-699.310(4), F.A.C.):	IV			Plant Class (per subsection 62-699.310(4), F.A.C.):	
				C	
Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked	
Lead/Chief Operator:	Mark March	C	8287		
Other Operators:	Paul Thompson	A	7251	Days 1st Shift	

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Mark March	C-8287
	Printed or Typed Name	License Number

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641399 Plant Name: Twin Rivers

III. Daily Data for the Month/year of: August, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C	Lowest CT Provided Before or at Customer First	Temp of Water, °C	pH of Water, If Applicable	Minimum CT Required, mg-min/L	Lowest UV Dose, mW-sec/cm ²	Required UV Dose, mW-sec/cm ²	Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, If Applicable*		Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
													CT Calculations	UV Dose		
1		24,000	23,300		2.2											
2	X	24,000	23,300		2.2											
3	X	24,000	19,600		2.3											
4	X	24,000	22,900		2.3											
5	X	24,000	25,200		2.0											
6	X	24,000	18,100		2.0											
7	X	24,000	13,300		2.0											
8	X	24,000	20,550		2.2											
9	X	24,000	20,550		2.2											
10	X	24,000	21,200		2.3											
11	X	24,000	17,100		2.0											
12	X	24,000	21,900		2.2											
13	X	24,000	17,200		2.2											
14	X	24,000	17,200		2.0											
15	X	24,000	17,500		2.3											
16	X	24,000	17,500		2.3											
17	X	24,000	17,200		2.4											
18	X	24,000	14,400		2.3											
19	X	24,000	20,500		2.3											
20	X	24,000	19,700		2.3											
21	X	24,000	6,200		2.0											
22		24,000	23,450													
23	X	24,000	23,450		2.0											
24	X	24,000	14,000		1.0											
25	X	24,000	16,800		0.8											
26	X	24,000	13,600		2.0											
27	X	24,000	12,400		2.0											
28	X	24,000	15,500		2.0											
29		24,000	21,350													
30	X	24,000	21,350		2.4											
31	X	24,000	18,800		2.4											
Total		575,100														
Average		18,552														
Maximum		25,200														

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: September, 2004

A. Public Water System (PWS) Information

PWS Name:	Tomoka View			PWS Identification Number:	3641373
PWS Type:	<input checked="" type="checkbox"/> Community	<input type="checkbox"/> Non-Transient Non-Community	<input type="checkbox"/> Transient Non-Community	<input type="checkbox"/> Consecutive	
Number of Service Connections at End of Month:	189			Total Population Served at End of Month:	443
PWS Owner:	Aqua Utilities Florida				
Contact Person:	Michael Fitzgerald			Contact Person's Title:	Area Manager
Contact Person's Mailing Address:	1343 NE 17th Road	City:	Ocala	State:	Florida
Contact Person's Telephone Number:	(352) 732-6027			Contact Person's Fax Number:	(352) 732-3213
Contact Person's E-Mail Address:	mvfitzgerald@aquaaamerica.com				

B. Water Treatment Plant Information

Plant Name:	Tomoka View			Plant Telephone Number:	(386) 446-6138	
Plant Address:	339 Apache Trail	City:	Ormond	State:	Florida	
Type of Water Treatment by Plant:	<input checked="" type="checkbox"/> Raw Ground Water	<input type="checkbox"/> Purchased Finished Water				
Permitted Maximum Day Operating Capacity of Plant, gallons per day:	100,000					
Plant Category (per subsection 62-699.310(4), F.A.C.):	IV			Plant Class (per subsection 62-699.310(4), F.A.C.):	C	
Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked		
Lead/Chief Operator:	Mark March	C	8287			
Other Operators:	Paul Thompson	A	7251	Days 1st Shift		

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

	Mark March	C-8287
Signature and Date	Printed or Typed Name	License Number

MONTHLY OPERATION REPORT FOR PW'SS TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641373 Plant Name: Tomoka View

III. Daily Data for the Month/Year of: September, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal	Peak Flow Rate, gpd	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time Before or at First Customer During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, If Applicable	Minimum CT Required, mg-min/L	Lowest UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²	Remote Point in Distribution Involves Taking Water System Components Out of Operation	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*		UV Dose	
														CT Calculations	UV Dose	CT Calculations	UV Dose
1	X	24,000	33,300	1.9										1.2			
2	X	44,200	24,000	2.0										1.0			
3	X	25,300	24,000	2.0										1.0			
4	X	35,900	24,000	1.9										1.0			
5		31,100	24,000														
6	X	31,100	24,000	2.0										1.0			
7	X	45,400	24,000	1.6										1.0			
8	X	31,800	24,000	2.5										1.4			
9	X	30,600	24,000	3.0										1.8			
10	X	23,600	24,000	3.5										2.0			
11	X	18,400	24,000	3.5										2.0			
12		38,100	24,000														
13	X	38,100	24,000	3.5										2.2			
14	X	35,400	24,000	3.5										2.4			
15	X	26,000	24,000	3.0										2.2			
16	X	40,600	24,000	3.5										2.2			
17	X	33,100	24,000	3.5										3.0			
18	X	24,700	24,000	2.0										1.4			
19		52,750	24,000														
20	X	52,750	24,000	2.0										1.2			
21	X	29,900	24,000	2.0										1.0			
22	X	36,200	24,000	1.6										0.8			
23	X	43,700	24,000	1.8										0.8			
24	X	38,800	24,000	1.8										0.8			
25	X	30,900	24,000	1.9										1.0			
26		37,150	24,000														
27	X	37,150	24,000	1.6										1.0			
28	X	36,600	24,000	1.8										1.0			
29	X	38,300	24,000	1.0										0.4			
30	X	33,400	24,000	2.7										1.3			
31		24,000	24,000														
Total		1,054,300															
Average		34,010															
Maximum		52,750															

* Refer to the instructions for this report to determine which plants must provide this information

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: September, 2004

A. Public Water System (PWS) Information

PWS Name:	Twin Rivers			PWS Identification Number:	3641399
PWS Type:	<input checked="" type="checkbox"/> Community	<input type="checkbox"/> Non-Transient Non-Community	<input type="checkbox"/> Transient Non-Community	<input type="checkbox"/> Consecutive	
Number of Service Connections at End of Month:	76			Total Population Served at End of Month:	175
PWS Owner:	Aqua Utilities Florida				
Contact Person:	Michael Fitzgerald			Contact Person's Title:	Area Manager
Contact Person's Mailing Address:	1343 NE 17th Road	City:	Ocala	State:	Florida
Contact Person's Telephone Number:	(352) 732-6027			Contact Person's Fax Number:	(352) 732-3213
Contact Person's E-Mail Address:	mvfitzgerald@aquaaamerica.com				

B. Water Treatment Plant Information

Plant Name:	Twin Rivers			Plant Telephone Number:	(386) 437-1027	
Plant Address:	8 Riverdale Avenue			City:	Ormond	
Type of Water Treatment by Plant:	<input checked="" type="checkbox"/> Raw Ground Water	<input type="checkbox"/> Purchased Finished Water				
Permitted Maximum Day Operating Capacity of Plant, gallons per day:	100,000					
Plant Category (per subsection 62-699.310(4), F.A.C.):	IV			Plant Class (per subsection 62-699.310(4), F.A.C.):	C	
Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked		
Lead/Chief Operator:	Mark March	C	8287			
Other Operators:	Paul Thompson	A	7251	Days 1st Shift		

II Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

	Mark March	C-8287
Signature and Date	Printed or Typed Name	License Number

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641399 Plant Name: Twin Rivers

III. Daily Data for the Month/Year of: September, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions; Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
				CT Calculations					UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm	Minimum UV Dose Required, mW-sec/cm			
1	X	24.0	16,500		2.2									1.2	
2	X	24.0	24,600		2.0									1.2	
3	X	24.0	5,800		2.1									1.2	
4	X	24.0	19,900		2.0									1.0	
5		24.0	13,100												
6	X	24.0	13,100		2.0									1.1	
7	X	24.0	18,700		1.0									0.8	
8	X	24.0	17,200		1.8									1.0	
9	X	24.0	16,300		2.0									1.0	
10	X	24.0	16,200		2.0									1.0	
11	X	24.0	6,200		2.0									1.0	
12		24.0	18,350												
13	X	24.0	18,350		1.8									1.0	
14	X	24.0	14,300		1.8									1.0	
15	X	24.0	18,000		2.0									1.0	
16	X	24.0	34,300		2.2									1.2	
17	X	24.0	10,700		1.8									1.0	
18	X	24.0	6,400		1.8									1.0	
19		24.0	19,600												
20	X	24.0	19,600		2.0									1.0	
21	X	24.0	16,100		2.1									0.8	
22	X	24.0	8,500		2.0									1.0	
23	X	24.0	17,700		1.8									1.0	
24	X	24.0	21,200		1.9									1.0	
25	X	24.0	5,800		1.8									1.0	
26		24.0	14,500												
27	X	24.0	14,500		1.8									1.0	
28	X	24.0	20,600		2.0									1.0	
29	X	24.0	15,300		2.2									2.0	
30	X	24.0	14,000		2.0									1.2	
31		24.0													
Total			475,400												
Average			15,335												
Maximum			34,300												

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: October, 2004

A. Public Water System (PWS) Information

PWS Name: Tomoka View		PWS Identification Number: 3641373	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 189		Total Population Served at End of Month: 443	
PWS Owner: Aqua Utilities Florida			
Contact Person: Michael Fitzgerald		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: 1343 NE 17th Road		City: Ocala	State: Florida Zip Code: 34470
Contact Person's Telephone Number: (352) 732-6027		Contact Person's Fax Number: (352) 732-3213	
Contact Person's E-Mail Address: mvfitzgerald@aquaamerica.com			

B. Water Treatment Plant Information

Plant Name: Tomoka View		Plant Telephone Number: (386) 446-6138	
Plant Address: 339 Apache Trail		City: Ormond	State: Florida Zip Code: 32174
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water			
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 100,000			
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): C	
Licensed Operators	Name	License Class	License Number / Day(s) / Shift(s) Worked
Lead/Chief Operator:	Mark March	C	8287
Other Operators:	Paul Thompson	A	7251 Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Mark March Printed or Typed Name	C-8287 License Number
--------------------	-------------------------------------	--------------------------

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641373 Plant Name: Tomoka View

III. Daily Data for the Month/year of: October, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Measurement (C)	Disinfectant Contact Time Before or at First Measurement (T) at C	Lowest CT Disinfectant Provided Before or at First Measurement (T) at C	Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	UV Dose Required, mW-sec/cm ²	Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*	
														UV Dose	UV Dose
1	X	24.0	37,300	2.8											
2	X	24.0	25,300	2.8											
3		24.0	45,550												
4	X	24.0	45,550	2.2											
5	X	24.0	36,600	2.4											
6	X	24.0	38,800	1.8											
7	X	24.0	37,000	3.2											
8	X	24.0	31,700	3.5											
9	X	24.0	35,600	3.5											
10		24.0	47,250												
11	X	24.0	47,250	2.2											
12	X	24.0	30,000	2.0											
13	X	24.0	41,900	1.6											
14	X	24.0	38,300	1.8											
15	X	24.0	35,600	1.9											
16	X	24.0	32,400	2.3											
17		24.0	50,800												
18	X	24.0	50,800	2.0											
19	X	24.0	38,200	2.0											
20	X	24.0	35,800	1.8											
21	X	24.0	35,200	1.4											
22	X	24.0	36,200	2.5											
23	X	24.0	31,400	2.4											
24		24.0	47,300												
25	X	24.0	47,300	2.6											
26	X	24.0	37,800	2.4											
27	X	24.0	42,900	2.4											
28	X	24.0	38,500	2.0											
29	X	24.0	38,100	2.3											
30	X	24.0	36,900	2.2											
31		24.0	28,675												
Total		1,201,975													
Average		38,773													
Maximum		50,800													

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of:	October, 2004
--	---------------

A. Public Water System (PWS) Information

PWS Name: Twin Rivers		PWS Identification Number: 3641399	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 76		Total Population Served at End of Month: 175	
PWS Owner: Aqua Utilities Florida			
Contact Person: Michael Fitzgerald		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: 1343 NE 17th Road		City: Ocala	State: Florida
Contact Person's Telephone Number: (352) 732-6027		Zip Code: 34470	
Contact Person's E-Mail Address: mvfitzgerald@aquaamerica.com		Contact Person's Fax Number: (352) 732-3213	

B. Water Treatment Plant Information

Plant Name: Twin Rivers		Plant Telephone Number: (386) 437-1027	
Plant Address: 8 Riverdale Avenue		City: Ormond	State: Florida
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water		Zip Code: 32174	
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 100,000			
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): C	
Licensed Operators	Name	License Class	License Number
Lead/Chief Operator:	Mark March	C	8287
Other Operators:	Paul Thompson	A	7251
			Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Mark March Printed or Typed Name	C-8287 License Number
--------------------	-------------------------------------	--------------------------

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641399 Plant Name: Twin Rivers October, 2004

III. Daily Data for the Month/Year of: October, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)

Ultraviolet Radiation

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Started or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal	Peak Flow Rate, gpd	Lowest Residual Disinfectant Concentration (C)	Disinfectant (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at Customer First Disinfectant Contact Time	Minimum CT Required, mg-min/L	Lowest UV Dose Operating UV Dose, mW-sec/cm ²	Remote Point in Distribution System, mg/L	CT Calculations, or UV Dose, to Demonstrate Four-Log Virus Inactivation, if Applicable*		Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
										UV Dose	UV Dose	
1	X	24.0	13,400	2.0								
2	X	24.0	6,800	2.0								
3		24.0	18,300									
4	X	24.0	18,300	2.0								
5	X	24.0	21,400	2.0								
6	X	24.0	11,400	2.0								
7	X	24.0	21,300	2.0								
8	X	24.0	14,400	2.0								
9	X	24.0	14,300	2.2								
10		24.0	20,850									
11	X	24.0	20,850	1.8								
12	X	24.0	15,200	2.0								
13	X	24.0	15,500	2.4								
14	X	24.0	15,000	2.1								
15	X	24.0	13,700	2.0								
16	X	24.0	12,900	2.0								
17		24.0	20,300									
18	X	24.0	20,300	2.0								
19	X	24.0	15,000	2.2								
20	X	24.0	19,800	2.0								
21	X	24.0	18,500	2.1								
22	X	24.0	14,000	2.2								
23	X	24.0	8,900	2.2								
24		24.0	19,400									
25	X	24.0	19,400	2.3								
26	X	24.0	13,500	2.2								
27	X	24.0	18,900	2.3								
28	X	24.0	14,400	2.3								
29	X	24.0	14,400	2.2								
30	X	24.0	9,900	2.2								
31		24.0	10,425									
Total			490,725									
Average			15,830									
Maximum			21,400									

* Refer to the instructions for this report to determine which plants must provide this information

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: November, 2004

A. Public Water System (PWS) Information

PWS Name: Tomoka View		PWS Identification Number: 3641373	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 189		Total Population Served at End of Month: 443	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: 1343 NE 17th Road		City: Ocala	State: Florida
Contact Person's Telephone Number: (352) 732-6027		Zip Code: 34470	
Contact Person's E-Mail Address: beheath@aquaaamerica.com		Contact Person's Fax Number: (352) 732-3213	

B. Water Treatment Plant Information

Plant Name: Tomoka View		Plant Telephone Number: (386) 446-6138		
Plant Address: 339 Apache Trail		City: Ormond	State: Florida	
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water		Zip Code: 32174		
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 100,000				
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): C		
Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	Mark March	C	8287	
Other Operators:	Paul Thompson	A	7251	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Mark March Printed or Typed Name	C-8287 License Number
--------------------	-------------------------------------	--------------------------

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641373 Plant Name: Tomoka View

III. Daily Data for the Month/Year of: November, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*								Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions; Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations				UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²	Temp of Water, °C if Applicable			pH of Water, if Applicable
1	X	24.0	114,700		2.0								1.0	
2	X	24.0	36,500		2.0								1.0	
3	X	24.0	41,300		2.5								1.1	
4	X	24.0	49,600		3.5								1.4	
5	X	24.0	45,400		3.5								1.4	
6	X	24.0	28,900		2.0								1.0	
7		24.0	52,450											
8	X	24.0	52,450		2.0								0.8	
9	X	24.0	44,900		2.0								1.0	
10	X	24.0	38,700		2.0								0.9	
11	X	24.0	42,500		2.0								0.8	
12	X	24.0	44,800		3.3								0.8	
13	X	24.0	32,100		3.1								0.8	
14		24.0	47,800											
15	X	24.0	47,800		3.0								0.8	
16	X	24.0	38,400		3.0								0.7	
17	X	24.0	45,200		3.2								0.8	
18	X	24.0	64,000		2.6								1.3	
19	X	24.0	27,100		2.1								1.3	
20	X	24.0	35,300		2.3								1.0	
21	X	24.0	64,100		3.0								1.0	
22	X	24.0	39,200		3.0								0.8	
23	X	24.0	42,600		2.8								0.8	
24	X	24.0	45,200		2.8								0.8	
25		24.0	43,250											
26	X	24.0	43,250		2.6								0.8	
27	X	24.0	32,300		1.6								0.8	
28		24.0	44,850											
29	X	24.0	44,850		1.0								0.4	
30	X	24.0	36,800		3.0								0.7	
31		24.0												
Total			1,366,300											
Average			44,074											
Maximum			114,700											

* Refer to the instructions for this report to determine which plants must provide this information.

Docket No. 060368-WS

**Application to Increase Rates and Charges
For a "Class A" Utility
In**

Florida

Report Missing:

Monthly Operating Report

Twin Rivers

November 2004

Aqua Utilities Florida, Inc.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



Polymer Page 3 Due in December

See Pages 4 for Instructions.

I. General Information for the Month/Year of: December, 2004

A. Public Water System (PWS) Information

PWS Name: Tomoka View		PWS Identification Number: 3641373	
PWS Type:	<input checked="" type="checkbox"/> Community	<input type="checkbox"/> Non-Transient Non-Community	<input type="checkbox"/> Transient Non-Community
Number of Service Connections at End of Month: 189		Total Population Served at End of Month: 443	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: 1343 NE 17th Road		City: Ocala	State: Florida
Contact Person's Telephone Number: (352) 732-6027		Zip Code: 34470	
Contact Person's E-Mail Address: beheath@aquaamerica.com		Contact Person's Fax Number: (352) 732-3213	

B. Water Treatment Plant Information

Plant Name: Tomoka View		Plant Telephone Number: (386) 446-6138	
Plant Address: 339 Apache Trail		City: Ormond	State: Florida
Type of Water Treatment by Plant:		<input checked="" type="checkbox"/> Raw Ground Water	<input type="checkbox"/> Purchased Finished Water
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 100,000			
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): C	

Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	Mark March	C	8287	Days 1st Shift
Other Operators:	Paul Thompson	A	7251	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Mark March	C8287
	Printed or Typed Name	License Number

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641373 Plant Name: Tomoka View

III. Daily Data for the Month/year of: December, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal	Peak Flow Rate, gpd	Lowest Residual Disinfectant Concentration (C) at C	Disinfectant Contact Time Before or at First Customer Measurement (T) at C	Point During Peak Flow, minutes	Temp. of Water, °C If Applicable	pH of Water, If Applicable	Minimum CT Required, mg-min/L	Operating UV Dose, mW-sec/cm ²	Lowest Disinfectant Concentration at Remove Point in Distribution System, mg/L	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*		Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
													UV Dose	CT Calculations	
1	X		32,000	24.0			2.5					3.0			
2	X		54,400	24.0			2.0					0.5			
3	X		33,100	24.0			3.5					2.4			
4	X		30,500	24.0			2.8					1.8			
5			46,350	24.0											
6	X		46,350	24.0			2.2					0.7			
7	X		36,700	24.0			2.3					0.9			
8	X		43,600	24.0			2.4					0.9			
9	X		44,400	24.0			2.0					0.7			
10	X		34,800	24.0			2.2					0.7			
11	X		29,500	24.0			2.2					0.7			
12	X		48,600	24.0			2.2					0.7			
13	X		39,800	24.0			2.0					0.6			
14			35,800	24.0											
15	X		35,800	24.0			2.0					0.6			
16	X		36,700	24.0			1.9					1.0			
17	X		38,300	24.0			3.5					1.4			
18	X		30,400	24.0			2.0					0.4			
19	X		51,800	24.0			2.8					0.4			
20	X		56,400	24.0			2.4					2.4			
21	X		27,300	24.0			2.3					1.1			
22	X		43,700	24.0			2.4					1.8			
23	X		45,500	24.0			2.5					1.0			
24	X		34,700	24.0			2.0					0.8			
25			45,150	24.0											
26	X		45,150	24.0			2.3					0.9			
27	X		38,500	24.0			1.2					0.4			
28	X		30,700	24.0			1.6					0.6			
29	X		37,000	24.0			2.5					1.0			
30	X		41,800	24.0			2.5					0.9			
31			31,500	24.0											
Total			1,226,300												
Average			39,558												
Maximum			56,400												

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



Polymer Page 3 Due in December

See Pages 4 for Instructions.

I. General Information for the Month/Year of:	December, 2004
--	----------------

A. Public Water System (PWS) Information

PWS Name: Twin Rivers		PWS Identification Number: 3641399	
PWS Type:	<input checked="" type="checkbox"/> Community	<input type="checkbox"/> Non-Transient Non-Community	<input type="checkbox"/> Transient Non-Community
Number of Service Connections at End of Month: 76		Total Population Served at End of Month: 175	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address:	1343 NE 17th Road	City: Ocala	State: Florida
Contact Person's Telephone Number:	(352) 732-6027	Contact Person's Fax Number:	(352) 732-3213
Contact Person's E-Mail Address:	beheath@aquaamerica.com		

B. Water Treatment Plant Information

Plant Name: Twin Rivers		Plant Telephone Number: (386) 437-1027	
Plant Address: 8 Riverdale Avenue		City: Ormond	State: Florida
Type of Water Treatment by Plant:		<input checked="" type="checkbox"/> Raw Ground Water	<input type="checkbox"/> Purchased Finished Water
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 100,000			
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): C	

Licensed Operators	Name	License Class	License Number	Day(s)/Shift(s) Worked
Lead/Chief Operator:	Mark March	C	8287	Days 1st Shift
Other Operators:	Paul Thompson	A	7251	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Mark March Printed or Typed Name	C8287 License Number
--------------------	-------------------------------------	-------------------------

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641399 Plant Name: Twin Rivers

III. Daily Data for the Month/Year of: December, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Started or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal	Peak Flow Rate, gpd	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Measurement (T) at C During Point During Peak Flow, mg/L	Lowest CT Provided Before or at First Customer During Peak Flow, minutes	Temp of Water, °C if Applicable	pH of Water, if Applicable	Minimum CT Required, mg·min/L	Operating UV Dose, mW·sec/cm ²	Required UV Dose, mW·sec/cm ²	Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	CT Calculations, or UV Dose, to Demonstrate Four-Log Virus Inactivation, if Applicable*	
													UV Dose	UV Dose
1	X	16,400	24.0	1.6										
2	X	24,800	24.0	2.2										1.0
3	X	20,200	24.0	2.2										0.6
4	X	14,300	24.0	2.2										0.7
5		23,650	24.0											
6	X	23,650	24.0	2.2										0.6
7	X	19,000	24.0	2.2										0.6
8	X	20,400	24.0	2.2										0.6
9	X	18,100	24.0	2.2										0.7
10	X	18,400	24.0	2.2										0.7
11	X	12,500	24.0	2.2										0.7
12	X	25,700	24.0	2.2										0.7
13	X	18,300	24.0	1.5										0.5
14		19,400	24.0											
15	X	19,400	24.0	1.4										0.5
16	X	22,900	24.0	1.6										0.5
17	X	22,400	24.0	2.0										0.6
18	X	11,000	24.0	2.2										0.6
19	X	27,700	24.0	1.6										0.4
20	X	20,900	24.0	1.3										0.5
21	X	14,000	24.0	1.5										0.4
22	X	27,200	24.0	1.8										0.5
23	X	18,200	24.0	1.8										0.5
24	X	19,000	24.0	2.2										0.5
25		23,750	24.0											
26	X	23,750	24.0	2.2										0.7
27	X	17,100	24.0	1.3										0.5
28	X	18,000	24.0	1.4										0.5
29	X	17,900	24.0	1.4										0.5
30	X	19,000	24.0	1.4										0.5
31		18,850	24.0											
Total		615,850												
Average		19,866												
Maximum		27,700												

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: January, 2005

A. Public Water System (PWS) Information

PWS Name:	Tomoka View	PWS Identification Number:	3641373
PWS Type:	<input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive		
Number of Service Connections at End of Month:	189	Total Population Served at End of Month:	443
PWS Owner:	Aqua Utilities Florida		
Contact Person:	Brian Heath	Contact Person's Title:	Area Manager
Contact Person's Mailing Address:	PO Box 490310	City:	Leesburg State: Florida Zip Code: 34749
Contact Person's Telephone Number:	(352) 787-0980	Contact Person's Fax Number:	(352) 787-6333
Contact Person's E-Mail Address:	beheath@aquaaamerica.com		

B. Water Treatment Plant Information

Plant Name:	Tomoka View	Plant Telephone Number:	(352) 787-0980
Plant Address:	339 Apache Trail	City:	Ormond State: Florida Zip Code: 32174
Type of Water Treatment by Plant:	<input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water		
Permitted Maximum Day Operating Capacity of Plant, gallons per day:	100,000		
Plant Category (per subsection 62-699.310(4), F.A.C.):	IV	Plant Class (per subsection 62-699.310(4), F.A.C.):	C
Licensed Operators	Name	License Class	License Number
Lead/Chief Operator:	Paul Thompson	A	7251
Other Operators:			

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

_____	<u>Paul Thompson</u>	_____
Signature and Date	Printed or Typed Name	License Number
		A7251

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641373 Plant Name: Tomoka View

III. Daily Data for the Month/Year of: January, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations					UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²	Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L		
1	X	24.0	63,000		1.4										0.4
2		24.0	50,750												
3	X	24.0	50,750		1.0										0.4
4	X	24.0	44,200		2.8										1.8
5	X	24.0	33,400		2.5										1.3
6	X	24.0	50,100		2.6										1.3
7	X	24.0	32,000		2.4										1.2
8	X	24.0	36,700		2.4										1.2
9		24.0	55,500												
10	X	24.0	55,500		2.4										0.8
11	X	24.0	44,600		1.8										0.8
12	X	24.0	36,200		2.6										0.7
13	X	24.0	43,800		2.2										0.6
14	X	24.0	35,900		2.3										0.6
15	X	24.0	24,000		2.1										0.5
16		24.0	39,150												
17	X	24.0	39,150		2.2										0.8
18	X	24.0	19,400		2.2										0.8
19	X	24.0	41,500		1.9										0.6
20	X	24.0	35,200		2.5										0.7
21	X	24.0	36,000		2.8										1.6
22	X	24.0	19,600		2.5										0.9
23		24.0	48,800												
24	X	24.0	48,800		2.7										0.9
25	X	24.0	36,700		2.6										0.8
26	X	24.0	43,600		2.8										1.0
27	X	24.0	44,700		2.5										0.8
28	X	24.0	35,900		2.7										0.9
29	X	24.0	35,200		2.7										0.7
30		24.0	53,950												
31	X	24.0	53,950		2.4										0.7
Total			1,288,000												
Average			41,548												
Maximum			63,000												

* Refer to the instructions for this report to determine which plants must provide this information

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: January, 2005

A. Public Water System (PWS) Information

PWS Name: Twin Rivers		PWS Identification Number: 3641399	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 76		Total Population Served at End of Month: 175	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: PO Box 490310		City: Leesburg	State: Florida
Contact Person's Telephone Number: (352) 787-0980		Contact Person's Fax Number: (352) 787-6333	
Contact Person's E-Mail Address: beheath@aquaamerica.com			

B. Water Treatment Plant Information

Plant Name: Twin Rivers		Plant Telephone Number: (352) 787-0980	
Plant Address: 8 Riverdale Avenue		City: Ormond	State: Florida
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water			
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 100,000			
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): C	

Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	Paul Thompson	A	7251	Days 1st Shift
Other Operators:				

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Paul Thompson Printed or Typed Name	A7251 License Number
--------------------	--	-------------------------

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641399 Plant Name: Twin Rivers

III. Daily Data for the Month/year of: January, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Started or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal	Peak Flow Rate, gpd	Lowest Residual Disinfectant Concentration (C) at C	Disinfectant Contact Time Before or at First Measurement (T) at C	During Peak Customer First	Lowest CT	CT Calculations				Temp of Water, °C	pH of Water, If Applicable	Minimum CT Required, mg/mL	Operating UV Dose, mW-sec/cm ²	Lowest UV Dose, mW-sec/cm ²	Remote Point in Distribution Involves Taking Water System Components Out of Operation?	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation?	
								Disinfectant Provided Before or at First Measurement (T) at C	During Peak Customer First	Point During Peak Flow, minutes	Peak Flow, mg/L								Peak Flow, mg/L
1	X	24.0	37,700	24.0	1.6														
2		24.0	24,950	24.0	1.5														
3	X	24.0	24,950	24.0	1.5														
4	X	24.0	22,900	24.0	1.5														
5	X	24.0	14,600	24.0	2.2														
6	X	24.0	19,100	24.0	2.2														
7	X	24.0	19,900	24.0	2.2														
8	X	24.0	14,300	24.0	2.2														
9		24.0	26,050	24.0	2.2														
10	X	24.0	26,050	24.0	2.2														
11	X	24.0	25,200	24.0	2.2														
12	X	24.0	15,900	24.0	2.2														
13	X	24.0	21,200	24.0	2.2														
14	X	24.0	18,800	24.0	2.2														
15	X	24.0	14,200	24.0	2.2														
16		24.0	25,650	24.0															
17	X	24.0	25,650	24.0	2.2														
18	X	24.0	14,700	24.0	2.2														
19	X	24.0	31,100	24.0	2.2														
20	X	24.0	19,900	24.0	2.2														
21	X	24.0	27,700	24.0	2.2														
22	X	24.0	12,900	24.0	2.2														
23		24.0	22,100	24.0															
24	X	24.0	22,100	24.0	2.2														
25	X	24.0	19,000	24.0	2.2														
26	X	24.0	22,700	24.0	2.2														
27	X	24.0	17,700	24.0	2.2														
28	X	24.0	18,200	24.0	2.2														
29	X	24.0	8,800	24.0	2.0														
30		24.0	21,700	24.0															
31	X	24.0	21,700	24.0	2.2														
Total			657,400																
Average			21,206																
Maximum			37,700																

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: February, 2005

A. Public Water System (PWS) Information

PWS Name:	Tomoka View	PWS Identification Number:	3641373
PWS Type:	<input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive		
Number of Service Connections at End of Month:	184	Total Population Served at End of Month:	644
PWS Owner:	Aqua Utilities Florida		
Contact Person:	Brian Heath	Contact Person's Title:	Area Manager
Contact Person's Mailing Address:	PO Box 490310	City:	Leesburg
Contact Person's Telephone Number:	(352) 787-0980	State:	Florida
Contact Person's E-Mail Address:	beheath@aquaaamerica.com	Zip Code:	34749
		Contact Person's Fax Number:	(352) 787-6333

B. Water Treatment Plant Information

Plant Name:	Tomoka View	Plant Telephone Number:	(352) 787-0980
Plant Address:	339 Apache Trail	City:	Ormond
Type of Water Treatment by Plant:	<input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water	State:	Florida
Permitted Maximum Day Operating Capacity of Plant, gallons per day:	100,000	Zip Code:	32174
Plant Category (per subsection 62-699.310(4), F.A.C.):	IV	Plant Class (per subsection 62-699.310(4), F.A.C.):	C

Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	Paul Thompson	A	7251	Days 1st Shift
Other Operators:				

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date

Paul Thompson

Printed or Typed Name

A7251

License Number

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641373 Plant Name: Tomoka View February, 2005

III. Daily Data for the Month/year of: Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Started or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Measurement Point During Peak Flow, mg/L	Disinfectant Contact Time (T) at C	Lowest CT Before or at First Customer Flow, mg-min/L	Temp of Water, °C	pH of Water, If Applicable	Minimum CT Required, mg-min/L	Lowest UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²	Remote Point in Distribution System, mg/L	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, If Applicable*	
													UV Dose	UV Dose
1	X	34,700	24.0	2.4										
2	X	32,900	24.0	2.5										
3	X	44,400	24.0	2.5										
4	X	21,400	24.0	2.4										
5	X	39,100	24.0	2.3										
6		47,400	24.0											
7	X	47,400	24.0	2.2										
8	X	36,900	24.0	2.2										
9	X	31,400	24.0	2.4										
10	X	36,800	24.0	2.4										
11	X	35,000	24.0	2.3										
12		23,500	24.0											
13		49,700	24.0											
14	X	49,700	24.0	2.4										
15	X	46,900	24.0	2.4										
16	X	42,700	24.0	2.3										
17	X	50,600	24.0	2.5										
18	X	34,900	24.0	2.5										
19	X	28,400	24.0	2.6										
20		54,800	24.0											
21	X	54,800	24.0	2.4										
22	X	49,800	24.0	2.5										
23	X	50,300	24.0	2.4										
24	X	34,200	24.0	2.3										
25	X	37,800	24.0	2.4										
26	X	40,000	24.0	2.6										
27		42,950	24.0											
28	X	42,950	24.0	1.8										
29			24.0											
30			24.0											
31			24.0											
Total		1,141,400												
Average		36,819												
Maximum		54,800												

* Refer to the instructions for this report to determine which plants must provide this information

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: February, 2005

A. Public Water System (PWS) Information

PWS Name: Twin Rivers		PWS Identification Number: 3641399	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community		<input type="checkbox"/> Consecutive	
Number of Service Connections at End of Month: 85		Total Population Served at End of Month: 298	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: PO Box 490310		City: Leesburg	State: Florida
Contact Person's Telephone Number: (352) 787-0980		Contact Person's Fax Number: (352) 787-6333	
Contact Person's E-Mail Address: beheath@aquamerica.com			

B. Water Treatment Plant Information

Plant Name: Twin Rivers		Plant Telephone Number: (352) 787-0980	
Plant Address: 8 Riverdale Avenue		City: Ormond	State: Florida
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water			
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 100,000			
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): C	
Licensed Operators	Name	License Class	License Number / Day(s) / Shift(s) Worked
Lead/Chief Operator:	Paul Thompson	A	7251 / Days 1st Shift
Other Operators:			

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date

Paul Thompson

Printed or Typed Name

A7251

License Number

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: March, 2005

A. Public Water System (PWS) Information

PWS Name: Tomoka View		PWS Identification Number: 3641373	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community		<input type="checkbox"/> Consecutive	
Number of Service Connections at End of Month: 184		Total Population Served at End of Month: 644	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: PO Box 490310		City: Leesburg	State: Florida
Contact Person's Telephone Number: (352) 787-0980		Contact Person's Fax Number: (352) 787-6333	
Contact Person's E-Mail Address: beheath@aquaaamerica.com			

B. Water Treatment Plant Information

Plant Name: Tomoka View		Plant Telephone Number: (352) 787-0980		
Plant Address: 339 Apache Trail		City: Ormond	State: Florida	
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water				
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 100,000				
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): C		
Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	Paul Thompson	A	7251	Days 1st Shift
Other Operators:				

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Paul Thompson Printed or Typed Name	A7251 License Number
--------------------	--	-------------------------

MONTHLY OPERATION REPORT FOR PW'SS TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641373 Plant Name: Tomoka View

III. Daily Data for the Month/Year of: March, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Started or Visited by Operator (Place "X")	Hours plant in operation	Net Quantity of Finished Water Produced, gal	Peak Flow Rate, gpd	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time Before or at First Customer Measurement (T) at C	Lowest CT Disinfectant Provided	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Operating UV Dose, mW-sec/cm ²	Required UV Dose, mW-sec/cm ²	Remote Point in Distribution System, mg/L	CT Calculations, or UV Dose, to Demonstrate Four-Log Virus Inactivation, if Applicable*	
													UV Dose	UV Dose
1	X	24.0	36,300	1.6								0.7		
2	X	24.0	37,700	2.5								0.7		
3	X	24.0	45,700	2.5								0.9		
4	X	24.0	36,800	2.2								0.9		
5	X	24.0	35,000	2.0								0.8		
6		24.0	45,000											
7	X	24.0	45,000	2.3								0.8		
8	X	24.0	36,200	2.3								0.6		
9	X	24.0	38,800	2.5								0.9		
10	X	24.0	40,300	1.9								0.7		
11	X	24.0	36,300	1.9								0.6		
12	X	24.0	37,800	1.8								0.7		
13		24.0	51,850											
14	X	24.0	51,850	2.5								1.7		
15	X	24.0	50,300	1.8								0.9		
16	X	24.0	45,900	1.8								0.7		
17	X	24.0	37,500	2.2								1.0		
18	X	24.0	35,400	3.0								2.0		
19	X	24.0	38,000	1.5								0.9		
20		24.0	49,050											
21	X	24.0	49,050	1.5								0.8		
22	X	24.0	37,200	0.8								0.9		
23	X	24.0	23,900	3.0								0.4		
24	X	24.0	38,500	2.3								2.0		
25	X	24.0	30,100	1.5								0.9		
26	X	24.0	44,200	1.7								0.8		
27		24.0	37,350											
28	X	24.0	37,350	1.4								0.5		
29	X	24.0	48,400	1.7								0.9		
30	X	24.0	54,100	1.8								1.0		
31	X	24.0	33,700	1.2								0.6		

Total	1,264,600	40,794	54,100
Average			
Maximum			

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: March, 2005

A. Public Water System (PWS) Information

PWS Name: Twin Rivers		PWS Identification Number: 3641399	
PWS Type:	<input checked="" type="checkbox"/> Community	<input type="checkbox"/> Non-Transient Non-Community	<input type="checkbox"/> Transient Non-Community
Number of Service Connections at End of Month: 85		Total Population Served at End of Month: 298	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: PO Box 490310		City: Leesburg	State: Florida
Contact Person's Telephone Number: (352) 787-0980		Zip Code: 34749	
Contact Person's E-Mail Address: beheath@aquaamerica.com		Contact Person's Fax Number: (352) 787-6333	

B. Water Treatment Plant Information

Plant Name: Twin Rivers		Plant Telephone Number: (352) 787-0980	
Plant Address: 8 Riverdale Avenue		City: Ormond	State: Florida
Type of Water Treatment by Plant:		<input checked="" type="checkbox"/> Raw Ground Water	<input type="checkbox"/> Purchased Finished Water
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 100,000			
Plant Category (per subsection 62-699.310(4), F.A.C.):		Plant Class (per subsection 62-699.310(4), F.A.C.):	
IV		C	
Licensed Operators	Name	License Class	License Number
Lead/Chief Operator:	Paul Thompson	A	7251
Other Operators:			

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Paul Thompson Printed or Typed Name	A7251 License Number
--------------------	--	-------------------------

MONTHLY OPERATION REPORT FOR PW'SS TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641399 Plant Name: Twin Rivers March 2005

III. Daily Data for the Month/year of:

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Staffed or Visited by Operator	Hours plant in Operation	Net Quantity of Finished Water Produced, gal	Peak Flow Rate, gpd	Lowest Residual Disinfectant Concentration (C) Before or at First Customer Measurement (T) at C	Disinfectant Contact Time Provided Before or at First Customer Measurement	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg·min/L	Lowest UV Dose, mW-sec/cm ²	Required UV Dose, mW-sec/cm ²	System, mg/L	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*	
												UV Dose	CT Calculations
1	X	24.0	13,900	1.4							0.7		
2	X	24.0	18,400	1.8							0.7		
3	X	24.0	19,200	1.7							0.7		
4	X	24.0	15,500	1.7							0.7		
5	X	24.0	15,400	1.7							0.7		
6		24.0	22,000										
7	X	24.0	22,000	1.5							0.6		
8	X	24.0	19,400	1.6							0.6		
9	X	24.0	14,400	1.3							0.6		
10	X	24.0	18,500	2.2							0.9		
11	X	24.0	14,800	1.6							0.6		
12	X	24.0	6,000	2.2							1.0		
13		24.0	27,550										
14	X	24.0	27,550	0.7							0.7		
15	X	24.0	19,600	1.2							1.0		
16	X	24.0	18,900	1.5							1.0		
17	X	24.0	18,200	1.6							0.5		
18	X	24.0	18,100	1.8							0.7		
19	X	24.0	9,000	2.2							0.9		
20		24.0	28,200										
21	X	24.0	28,200	2.3							1.1		
22	X	24.0	21,400	1.0							0.5		
23	X	24.0	14,700	0.2							1.0		
24	X	24.0	16,100	2.5							1.4		
25	X	24.0	18,200	2.5							1.9		
26	X	24.0	15,200	2.1							1.5		
27		24.0	19,050										
28	X	24.0	19,050	2.2							1.7		
29	X	24.0	14,900	2.1							1.8		
30	X	24.0	19,500	2.4							1.9		
31	X	24.0	14,800	2.5							2.0		
Total			567,700										
Average			18,313										
Maximum			28,200										

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: April, 2005

A. Public Water System (PWS) Information

PWS Name:	Tomoka View	PWS Identification Number:	3641373
PWS Type:	<input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive		
Number of Service Connections at End of Month:	184	Total Population Served at End of Month:	644
PWS Owner:	Aqua Utilities Florida		
Contact Person:	Brian Heath	Contact Person's Title:	Area Manager
Contact Person's Mailing Address:	PO Box 490310	City:	Leesburg
		State:	Florida
		Zip Code:	34749
Contact Person's Telephone Number:	(352) 787-0980	Contact Person's Fax Number:	(352) 787-6333
Contact Person's E-Mail Address:	beheath@aquaamerica.com		

B. Water Treatment Plant Information

Plant Name:	Tomoka View	Plant Telephone Number:	(352) 787-0980
Plant Address:	339 Apache Trail	City:	Ormond
		State:	Florida
		Zip Code:	32174
Type of Water Treatment by Plant:	<input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water		
Permitted Maximum Day Operating Capacity of Plant, gallons per day:	100,000		
Plant Category (per subsection 62-699.310(4), F.A.C.):	IV	Plant Class (per subsection 62-699.310(4), F.A.C.):	C

Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	Larry White	C	7082	Days 1st Shift
Other Operators:	Paul Thompson	A	7251	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date

Larry White

Printed or Typed Name

C7082

License Number

MONTHLY OPERATION REPORT FOR PW'SS TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641373 Plant Name: Tomoka View

III. Daily Data for the Month/Year of: April, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Visited or Hours plant in Operation	Net Quantity of Finished Water Produced, gal	Peak Flow Rate, gpd	Lowest Residual Disinfectant Concentration (C) Before or at First Measurement Point During Peak Flow, mg-minutes	Disinfectant Contact Time Before or at Lowest CT	Temp of Water, °C if Applicable	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Operating UV Dose, mW-sec/cm ²	Required UV Dose, mW-sec/cm ²	Remote Point in Distribution System, mg/L	CT Calculations	
											Lowest Residual Disinfectant Concentration at Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	UV Dose
1	24.0	38,800	1.3	1.3						0.7		
2	24.0	37,200	1.3									
3	24.0	52,750		3.1								
4	24.0	52,750		3.1								
5	24.0	33,700		3.0								
6	24.0	46,800		3.0								
7	24.0	61,500		1.1								
8	24.0	41,400		2.9								
9	24.0	38,100		1.4								
10	24.0	67,850										
11	24.0	67,850		1.2								
12	24.0	49,700		1.2								
13	24.0	30,700		1.4								
14	24.0	56,800		1.4								
15	24.0	51,800		2.5								
16	24.0	37,500		2.4								
17	24.0	66,550										
18	24.0	66,550		2.2								
19	24.0	54,600		2.1								
20	24.0	52,000		2.0								
21	24.0	72,800		1.9								
22	24.0	58,200		1.5								
23	24.0	66,100		2.2								
24	24.0	54,750										
25	24.0	54,750		1.6								
26	24.0	69,800		1.8								
27	24.0	44,200		2.3								
28	24.0	58,100		1.5								
29	24.0	41,600		1.6								
30	24.0	40,200		1.7								
31	24.0											
Total		1,565,400										
Average		50,497										
Maximum		72,800										

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: April, 2005

A. Public Water System (PWS) Information

PWS Name: Twin Rivers		PWS Identification Number: 3641399	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 85		Total Population Served at End of Month: 298	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: PO Box 490310		City: Leesburg	State: Florida
Contact Person's Telephone Number: (352) 787-0980		Zip Code: 34749	
Contact Person's E-Mail Address: beheath@aquaamerica.com		Contact Person's Fax Number: (352) 787-6333	

B. Water Treatment Plant Information

Plant Name: Twin Rivers		Plant Telephone Number: (352) 787-0980		
Plant Address: 8 Riverdale Avenue		City: Ormond	State: Florida	
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water		Zip Code: 32174		
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 100,000				
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): C		
Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	Larry White	C	7082	Days 1st Shift
Other Operators:	Paul Thompson	A	7251	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Larry White Printed or Typed Name	C7082 License Number
--------------------	--------------------------------------	-------------------------

MONTHLY OPERATION REPORT FOR PW'SS TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641399 Plant Name: Twin Rivers

III. Daily Data for the Month/Year of: April, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Started or Visited by Operator ("X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	Peak Flow Rate, gpd.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*					UV Dose	Days Plant Started or Visited by Operator ("X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Measurement (T) at Contact Time	Disinfectant Provided Before or at Lowest CT	Disinfectant Measurement (T) at C	Temp of Water, mg. Flow, mg. min/L	Temp of Water, °C if Applicable	pH of Water, min/L	Minimum CT Required, mg. UV Dose, mW-sec/cm	Operating UV Dose, mW-sec/cm	Lowest UV Dose Required, mW-sec/cm	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation				
					Lowest Residual Disinfectant Concentration at First Disinfectant UV Dose Required, mW-sec/cm																							
1	X		15,500	24.0	1.8																							
2	X		16,300	24.0	2.2																							
3			20,250	24.0																								
4	X		20,250	24.0	1.3																							
5	X		11,700	24.0	2.4																							
6	X		22,100	24.0	1.4																							
7	X		16,000	24.0	1.2																							
8	X		14,500	24.0	1.3																							
9	X		14,300	24.0	1.1																							
10			21,650	24.0																								
11	X		21,650	24.0	1.2																							
12	X		14,800	24.0	1.2																							
13	X		14,900	24.0	1.3																							
14	X		17,100	24.0	1.4																							
15	X		18,400	24.0	2.0																							
16	X		16,900	24.0	2.2																							
17			26,900	24.0																								
18	X		26,900	24.0	1.9																							
19	X		16,800	24.0	2.2																							
20	X		20,400	24.0	2.4																							
21	X		26,300	24.0	1.6																							
22	X		23,000	24.0	2.4																							
23	X		26,800	24.0	1.0																							
24			21,700	24.0																								
25	X		21,700	24.0	1.2																							
26	X		19,100	24.0	1.4																							
27	X		23,000	24.0	1.1																							
28	X		29,600	24.0	1.2																							
29	X		18,700	24.0	1.3																							
30	X		9,200	24.0	1.1																							
31			29,600	24.0																								
												Total	586,400															
												Average	18,916															
												Maximum	29,600															

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: May, 2005

A. Public Water System (PWS) Information

PWS Name: Tomoka View		PWS Identification Number: 3641373	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 184		Total Population Served at End of Month: 644	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: PO Box 490310		City: Leesburg	State: Florida
		Zip Code: 34749	
Contact Person's Telephone Number: (352) 787-0980		Contact Person's Fax Number: (352) 787-6333	
Contact Person's E-Mail Address: beheath@aquaamerica.com			

B. Water Treatment Plant Information

Plant Name: Tomoka View		Plant Telephone Number: (352) 787-0980	
Plant Address: 339 Apache Trail		City: Ormond	State: Florida
		Zip Code: 32174	
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water			
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 100,000			
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): C	
Licensed Operators	Name	License Class	License Number / Day(s) / Shift(s) Worked
Lead/Chief Operator:	Paul Thompson	A	7251 / Days 1st Shift
Other Operators:			

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Paul Thompson Printed or Typed Name	A7251 License Number
--------------------	--	-------------------------

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number:	3641373	Plant Name:	Tornoka View
----------------------------	---------	-------------	--------------

III. Daily Data for the Month/Year of: May, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe): _____

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions; Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
				CT Calculations					UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²			
1			50,550												
2	X		50,550		2.0									1.6	
3	X		46,000		1.9									1.3	
4	X		31,900		1.8									1.3	
5	X		39,700		1.5									0.9	
6	X		49,000		2.2									1.4	
7	X		36,100		2.3									1.4	
8			54,150												
9	X		54,150		2.2									1.3	
10	X		52,700		1.8									1.3	
11	X		38,800		2.2									1.4	
12	X		53,900		1.9									1.2	
13	X		56,700		1.8									1.1	
14	X		20,400		1.4									0.9	
15			63,800												
16	X		63,800		1.3									0.9	
17	X		59,300		1.4									0.6	
18	X		46,700		1.3									0.8	
19	X		48,100		1.5									0.9	
20	X		37,700		1.7									1.0	
21	X		72,600		1.6									0.9	
22			39,850												
23	X		39,850		1.5									0.9	
24	X		31,300		1.4									0.5	
25	X		38,300		1.1									0.4	
26	X		75,500		1.9									0.9	
27	X		61,000		1.6									0.8	
28	X		73,700		2.3									1.4	
29			51,550												
30	X		51,550		1.9									1.1	
31	X		77,500		2.3									1.6	
Total			1,566,700												
Average			50,539												
Maximum			77,500												

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: May, 2005

A. Public Water System (PWS) Information

PWS Name: Twin Rivers		PWS Identification Number: 3641399	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 85		Total Population Served at End of Month: 298	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: PO Box 490310		City: Leesburg	State: Florida Zip Code: 34749
Contact Person's Telephone Number: (352) 787-0980		Contact Person's Fax Number: (352) 787-6333	
Contact Person's E-Mail Address: beheath@aquaamerica.com			

B. Water Treatment Plant Information

Plant Name: Twin Rivers		Plant Telephone Number: (352) 787-0980	
Plant Address: 8 Riverdale Avenue		City: Ormond	State: Florida Zip Code: 32174
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water			
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 100,000			
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): C	
Licensed Operators	Name	License Class	License Number / Day(s) / Shift(s) Worked
Lead/Chief Operator:	Paul Thompson	A	7251 / Days 1st Shift
Other Operators:	Larry White	C	7082 / Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Paul Thompson Printed or Typed Name	A7251 License Number
--------------------	--	-------------------------

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641399 Plant Name: Twin Rivers

III. Daily Data for the Month/Year of: May, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions: Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
				CT Calculations					UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²			
1		24.0	23,400												
2	X	24.0	23,400		1.1									0.5	
3	X	24.0	17,000		1.1									0.6	
4	X	24.0	16,600		1.0									0.5	
5	X	24.0	10,100		1.0									0.4	
6	X	24.0	20,400		1.6									1.1	
7	X	24.0	12,300		2.1									1.8	
8		24.0	20,000												
9	X	24.0	20,000		1.4									1.1	
10	X	24.0	15,000		0.9									0.8	
11	X	24.0	10,800		0.9									0.8	
12	X	24.0	25,600		0.9									0.8	
13	X	24.0	20,600		1.6									1.2	
14	X	24.0	5,900		1.3									0.8	
15		24.0	23,950												
16	X	24.0	23,950		1.3									0.9	
17	X	24.0	17,400		1.0									0.8	
18	X	24.0	21,400		1.1									0.5	
19	X	24.0	18,000		1.3									0.9	
20	X	24.0	17,400		2.3									1.6	
21	X	24.0	25,200		2.0									1.5	
22		24.0	16,250												
23	X	24.0	16,250		1.2									0.8	
24	X	24.0	10,500		1.1									0.8	
25	X	24.0	21,500		1.3									0.9	
26	X	24.0	24,900		0.9									0.7	
27	X	24.0	25,900		1.1									0.8	
28	X	24.0	44,000		2.2									1.8	
29		24.0	24,000												
30	X	24.0	24,000		0.9									0.7	
31	X	24.0	22,900		1.0									0.8	
Total			618,600												
Average			19,955												
Maximum			44,000												

* Refer to the instructions for this report to determine which plants must provide this information

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: June, 2005

A. Public Water System (PWS) Information

PWS Name: Tomoka View		PWS Identification Number: 3641373	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 184		Total Population Served at End of Month: 644	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: PO Box 490310		City: Leesburg	State: Florida
Contact Person's Telephone Number: (352) 787-0980		Zip Code: 34749	
Contact Person's E-Mail Address: beheath@aquaamerica.com		Contact Person's Fax Number: (352) 787-6333	

B. Water Treatment Plant Information

Plant Name: Tomoka View		Plant Telephone Number: (352) 787-0980		
Plant Address: 339 Apache Trail		City: Ormond	State: Florida	
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water				
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 100,000				
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): C		
Licensed Operators	Name	License Class	License Number	Day(s)/Shift(s) Worked
Lead/Chief Operator:	Larry White	C	7082	Days 1st Shift
Other Operators:	Paul Thompson	A	7251	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

	Larry White	C7082
Signature and Date	Printed or Typed Name	License Number

MONTHLY OPERATION REPORT FOR PW'SS TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641373 Plant Name: Tomoka View

III. Daily Data for the Month/year of: June, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal	Peak Flow Rate, gpd	Lowest Residual Disinfectant Concentration (C) at C	Disinfectant Measurement (T) at C	Customer Disinfectant Before or at Lowest CT	Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest UV Dose, mW-sec/cm ²	Required UV Dose, mW-sec/cm ²	System, mg/L	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*	
															UV Dose	UV Dose
1	X		48,600	24.0			1.5							1.1		
2	X		33,900	24.0			2.2							1.6		
3	X		40,200	24.0			1.9							1.4		
4	X		45,100	24.0			1.7							1.3		
5			39,600	24.0												
6	X		39,600	24.0			1.5							1.0		
7	X		31,100	24.0			2.5							1.9		
8	X		57,300	24.0			2.3							1.5		
9	X		37,700	24.0			2.6							1.2		
10	X		58,300	24.0			1.3							1.1		
11	X		28,900	24.0			1.2							1.0		
12			42,950	24.0												
13	X		42,950	24.0			1.5							1.1		
14	X		29,500	24.0			1.4							0.8		
15	X		47,300	24.0			2.1							1.6		
16	X		29,000	24.0			1.7							1.0		
17	X		52,400	24.0			1.5							0.8		
18	X		27,400	24.0			1.6							0.9		
19			43,800	24.0												
20	X		43,800	24.0			1.4							0.8		
21	X		39,700	24.0			1.9							1.2		
22	X		51,900	24.0			1.4							0.8		
23	X		31,500	24.0			2.0							1.6		
24	X		50,800	24.0			1.9							1.7		
25	X		36,400	24.0			1.8							1.5		
26			46,050	24.0												
27	X		46,050	24.0			1.3							1.0		
28	X		22,500	24.0			1.5							0.9		
29	X		43,200	24.0			1.3							0.5		
30	X		38,200	24.0			1.2							0.4		
31				24.0												
Total			1,225,700													
Average			39,539													
Maximum			58,300													

* Refer to the instructions for this report to determine which plants must provide this information

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: June, 2005

A. Public Water System (PWS) Information

PWS Name:	Twin Rivers			PWS Identification Number:	3641399		
PWS Type:	<input checked="" type="checkbox"/> Community	<input type="checkbox"/> Non-Transient Non-Community	<input type="checkbox"/> Transient Non-Community	<input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month:	85			Total Population Served at End of Month:	298		
PWS Owner:	Aqua Utilities Florida						
Contact Person:	Brian Heath			Contact Person's Title:	Area Manager		
Contact Person's Mailing Address:	PO Box 490310	City:	Leesburg	State:	Florida	Zip Code:	34749
Contact Person's Telephone Number:	(352) 787-0980			Contact Person's Fax Number:	(352) 787-6333		
Contact Person's E-Mail Address:	beheath@aquaamerica.com						

B. Water Treatment Plant Information

Plant Name:	Twin Rivers			Plant Telephone Number:	(352) 787-0980		
Plant Address:	8 Riverdale Avenue			City:	Ormond	Zip Code:	32174
Type of Water Treatment by Plant:	<input checked="" type="checkbox"/> Raw Ground Water			<input type="checkbox"/> Purchased Finished Water			
Permitted Maximum Day Operating Capacity of Plant, gallons per day:	100,000						
Plant Category (per subsection 62-699.310(4), F.A.C.):	IV			Plant Class (per subsection 62-699.310(4), F.A.C.):	C		
Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked			
Lead/Chief Operator:	Larry White	C	7082	Days 1st Shift			
Other Operators:	Paul Thompson	A	7251	Days 1st Shift			

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

_____ Signature and Date	Larry White _____ Printed or Typed Name	C7082 _____ License Number
-----------------------------	---	----------------------------------

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641399 Plant Name: Twin Rivers

III. Daily Data for the Month/Year of: June, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demstrate Four-Log Virus Inactivation, if Applicable*										Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
				CT Calculations					UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²			
1	X	24.0	18,500		2.3									1.0	
2	X	24.0	19,200		1.0									0.6	
3	X	24.0	22,900		1.9									1.3	
4	X	24.0	11,000		1.2									1.0	
5		24.0	19,600												
6	X	24.0	19,600		1.2									0.9	
7	X	24.0	11,700		1.4									1.0	
8	X	24.0	32,900		2.7									2.3	
9	X	24.0	22,800		2.0									2.8	
10	X	24.0	24,900		1.9									1.5	
11	X	24.0	11,100		1.4									1.2	
12		24.0	21,050												
13	X	24.0	21,050		1.0									0.8	
14	X	24.0	17,000		1.8									1.3	
15	X	24.0	16,700		1.2									1.0	
16	X	24.0	12,900		1.0									0.8	
17	X	24.0	18,300		1.0									0.8	
18	X	24.0	10,900		1.2									0.9	
19		24.0	14,900												
20	X	24.0	14,900		1.0									0.8	
21	X	24.0	18,200		1.3									1.1	
22	X	24.0	23,300		2.0									1.6	
23	X	24.0	16,000		2.1									1.8	
24	X	24.0	15,700		1.0									0.9	
25	X	24.0	22,200		2.0									1.5	
26		24.0	25,300												
27	X	24.0	25,300		1.3									1.1	
28	X	24.0	10,800		1.2									0.9	
29	X	24.0	10,800		2.0									1.6	
30	X	24.0	26,000		1.0									0.7	
31		24.0													
Total			555,500												
Average			17,919												
Maximum			32,900												

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: July, 2005

A. Public Water System (PWS) Information

PWS Name: Tomoka View		PWS Identification Number: 3641373	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community		<input type="checkbox"/> Consecutive	
Number of Service Connections at End of Month: 184		Total Population Served at End of Month: 644	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: PO Box 490310		City: Leesburg	State: Florida
		Zip Code: 34749	
Contact Person's Telephone Number: (352) 787-0980		Contact Person's Fax Number: (352) 787-6333	
Contact Person's E-Mail Address: beheath@aquaaamerica.com			

B. Water Treatment Plant Information

Plant Name: Tomoka View		Plant Telephone Number: (352) 787-0980	
Plant Address: 339 Apache Trail		City: Ormond	State: Florida
		Zip Code: 32174	
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water			

Permitted Maximum Day Operating Capacity of Plant, gallons per day: 100,000

Plant Category (per subsection 62-699.310(4), F.A.C.): IV Plant Class (per subsection 62-699.310(4), F.A.C.): C

Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	Paul Thompson	A	7251	Days 1st Shift
Other Operators:	Larry White	C	7082	Days 1st Shift
	Daivd Haring	C	14091	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

	Paul Thompson	A7251
Signature and Date	Printed or Typed Name	License Number

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641373	Plant Name: Tomoka View
------------------------------------	-------------------------

III. Daily Data for the Month/Year of: July, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations					UV Dose							
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²				
1	X	24.0	27,600		1.2										0.3	
2	X	24.0	55,200		1.3										0.4	
3		24.0	21,950													
4	X	24.0	21,950		1.3										0.4	
5	X	24.0	50,100		1.5										0.6	
6	X	24.0	31,400		1.5										0.8	
7	X	24.0	50,700		1.3										0.6	
8	X	24.0	29,200		2.0										1.2	
9	X	24.0	39,300		2.0										1.6	
10		24.0	39,100													
11	X	24.0	39,100		1.5										0.9	
12	X	24.0	22,100		2.0										0.5	
13	X	24.0	38,200		1.9										1.0	
14	X	24.0	46,700		2.0										0.6	
15	X	24.0	35,800		1.3										0.9	
16	X	24.0	55,000		1.3										0.7	
17		24.0	42,750													
18	X	24.0	42,750		1.0										0.2	
19	X	24.0	45,700		2.3										0.9	
20	X	24.0	62,800		2.2										0.8	
21	X	24.0	57,300		2.3										0.6	
22	X	24.0	52,700		1.5										1.1	
23	X	24.0	70,600		1.8										1.2	
24		24.0	35,900													
25	X	24.0	35,900		2.3										1.4	
26	X	24.0	55,400		2.2										1.5	
27	X	24.0	57,100		1.3										1.6	
28	X	24.0	78,400		2.5										1.8	
29	X	24.0	44,100		2.3										1.5	
30	X	24.0	10,300		1.5										1.0	
31		24.0	27,750													
Total			1,322,850													
Average			42,673													
Maximum			78,400													

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: July, 2005

A. Public Water System (PWS) Information

PWS Name:	Twin Rivers			PWS Identification Number:	3641399	
PWS Type:	<input checked="" type="checkbox"/> Community	<input type="checkbox"/> Non-Transient Non-Community	<input type="checkbox"/> Transient Non-Community	<input type="checkbox"/> Consecutive		
Number of Service Connections at End of Month:	85			Total Population Served at End of Month:	298	
PWS Owner:	Aqua Utilities Florida					
Contact Person:	Brian Heath			Contact Person's Title:	Area Manager	
Contact Person's Mailing Address:	PO Box 490310		City:	Leesburg	State:	Florida
Contact Person's Telephone Number:	(352) 787-0980		Contact Person's Fax Number:	(352) 787-6333		
Contact Person's E-Mail Address:	beheath@aquaamerica.com					

B. Water Treatment Plant Information

Plant Name:	Twin Rivers			Plant Telephone Number:	(352) 787-0980	
Plant Address:	8 Riverdale Avenue		City:	Ormond	State:	Florida
Type of Water Treatment by Plant:	<input checked="" type="checkbox"/> Raw Ground Water	<input type="checkbox"/> Purchased Finished Water				
Permitted Maximum Day Operating Capacity of Plant, gallons per day:	100,000					
Plant Category (per subsection 62-699.310(4), F.A.C.):	IV			Plant Class (per subsection 62-699.310(4), F.A.C.):		
				C		
Licensed Operators:	Name	License Class	License Number	Day(s) / Shift(s) Worked		
Lead/Chief Operator:	Paul Thompson	A	7251	Days 1st Shift		
Other Operators:	Larry White	C	7082	Days 1st Shift		
	David Haring	C	14091	Days 1st Shift		

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date

Paul Thompson

Printed or Typed Name

A7251

License Number

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641399 Plant Name: Twin Rivers July, 2005

III. Daily Data for the Month/year of:

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Started or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Measurement	Point During Peak Flow, minutes	Temp. of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	UV Dose Required, mW-sec/cm ²	Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	CT Calculations	
												Lowest CT Provided Before or at First Measurement	Lowest CT Required
1	X	13,200	24.0	1.0							0.6		
2	X	27,000	24.0	2.1							1.7		
3		24.0	12,350	1.0							0.5		
4	X	24.0	12,350	1.0							0.5		
5	X	24.0	28,000	1.6							1.1		
6	X	24.0	16,700	1.2							0.9		
7	X	24.0	19,300	1.1							0.8		
8	X	24.0	10,100	1.2							0.6		
9	X	24.0	17,200	1.3							0.8		
10		24.0	15,500								0.7		
11	X	24.0	15,500	1.4							0.8		
12	X	24.0	12,000	1.3							0.8		
13	X	24.0	22,500	1.6							0.9		
14	X	24.0	16,400	1.3							0.6		
15	X	24.0	15,700	1.3							0.5		
16	X	24.0	27,300	2.3							1.2		
17		24.0	18,600										
18	X	24.0	18,600	1.5							0.6		
19	X	24.0	15,400	1.5							0.5		
20	X	24.0	27,900	1.0							0.4		
21	X	24.0	24,000	2.1							1.0		
22	X	24.0	26,100	1.8							1.0		
23	X	24.0	25,200	1.5							0.6		
24		24.0	19,500										
25	X	24.0	19,500	1.3							0.7		
26	X	24.0	24,100	1.5							0.8		
27	X	24.0	32,100	2.1							0.9		
28	X	24.0	27,000	1.3							0.8		
29	X	24.0	22,100	2.2							1.5		
30	X	24.0	31,500	2.3							1.8		
31		24.0	15,720										
Total		628,420											
Average		20,272											
Maximum		32,100											

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of:	August, 2005
--	--------------

A. Public Water System (PWS) Information

PWS Name: Tomoka View		PWS Identification Number: 3641373	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 184		Total Population Served at End of Month: 644	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: PO Box 490310		City: Leesburg	State: Florida
		Zip Code: 34749	
Contact Person's Telephone Number: (352) 787-0980		Contact Person's Fax Number: (352) 787-6333	
Contact Person's E-Mail Address: beheath@aquamerica.com			

B. Water Treatment Plant Information

Plant Name: Tomoka View		Plant Telephone Number: (352) 787-0980		
Plant Address: 339 Apache Trail		City: Ormond	State: Florida	
		Zip Code: 32174		
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water				
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 100,000				
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): C		
Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	Paul Thompson	A	7251	Days 1st Shift
Other Operators:	Larry White	C	7082	Days 1st Shift
	Daivd Haring	C	14091	Days 1st Shift

II Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Paul Thompson Printed or Typed Name	A7251 License Number
--------------------	--	-------------------------

MONTHLY OPERATION REPORT FOR PW'SS TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641373 | Plant Name: Tomoka View | August, 2005

III. Daily Data for the Month/year of:

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Operating UV Dose, mW-sec/cm	Required UV Dose, mW-sec/cm	Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions: Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	CT Calculations		UV Dose	
														CT Calculations	UV Dose		
1	X	55,500	24.0	1.9													
2	X	59,100	24.0	2.0													
3	X	60,900	24.0	1.8													
4	X	45,500	24.0	1.9													
5	X	67,000	24.0	1.7													
6	X	56,300	24.0	1.8													
7	X	53,450	24.0	1.6													
8	X	53,450	24.0	1.6													
9	X	43,200	24.0	1.2													
10	X	48,100	24.0	2.1													
11	X	47,000	24.0	2.3													
12	X	49,300	24.0	1.4													
13	X	60,500	24.0	1.4													
14		79,000	24.0														
15	X	79,000	24.0	1.5													
16	X	63,900	24.0	1.0													
17	X	59,500	24.0	1.9													
18	X	55,600	24.0	1.7													
19	X	64,600	24.0	1.6													
20	X	65,800	24.0	1.8													
21		69,000	24.0														
22	X	69,000	24.0	1.2													
23	X	76,300	24.0	1.3													
24	X	84,500	24.0	1.0													
25	X	66,700	24.0	2.3													
26	X	64,400	24.0	2.0													
27	X	59,700	24.0	1.8													
28		72,400	24.0														
29	X	72,400	24.0	1.5													
30	X	41,200	24.0	1.1													
31	X	43,500	24.0	1.8													
Total		1,885,800															
Average		60,832															
Maximum		84,500															

* Refer to the instructions for this report to determine which plants must provide this information

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: August, 2005

A. Public Water System (PWS) Information

PWS Name:	Twin Rivers			PWS Identification Number:	3641399
PWS Type:	<input checked="" type="checkbox"/> Community	<input type="checkbox"/> Non-Transient Non-Community	<input type="checkbox"/> Transient Non-Community	<input type="checkbox"/> Consecutive	
Number of Service Connections at End of Month:	85			Total Population Served at End of Month:	298
PWS Owner:	Aqua Utilities Florida				
Contact Person:	Brian Heath			Contact Person's Title:	Area Manager
Contact Person's Mailing Address:	PO Box 490310	City:	Leesburg	State:	Florida
				Zip Code:	34749
Contact Person's Telephone Number:	(352) 787-0980			Contact Person's Fax Number:	(352) 787-6333
Contact Person's E-Mail Address:	beheath@aquaaamerica.com				

B. Water Treatment Plant Information

Plant Name:	Twin Rivers			Plant Telephone Number:	(352) 787-0980	
Plant Address:	8 Riverdale Avenue	City:	Ormond	State:	Florida	
				Zip Code:	32174	
Type of Water Treatment by Plant:	<input checked="" type="checkbox"/> Raw Ground Water	<input type="checkbox"/> Purchased Finished Water				
Permitted Maximum Day Operating Capacity of Plant, gallons per day:	100,000					
Plant Category (per subsection 62-699.310(4), F.A.C.):	IV			Plant Class (per subsection 62-699.310(4), F.A.C.):	C	
Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked		
Lead/Chief Operator:	Paul Thompson	A	7251	Days 1st Shift		
Other Operators:	Larry White	C	7082	Days 1st Shift		
	David Haring	C	14091	Days 1st Shift		

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date

Paul Thompson

Printed or Typed Name

A7251

License Number

MONTHLY OPERATION REPORT FOR PW'SS TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641399 Plant Name: Twin Rivers August, 2005

Means of Achieving Four-log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at Measurement Point During Peak Flow, minutes	Flow, mg-min/L	Temp of Water, °C	pH of Water, If Applicable	Minimum CT Required, mg-min/L	Lowest UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²	Lowest Residual Disinfectant Concentration at Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	CT Calculations, if Applicable*	
													UV Dose	CT Calculations
1	X	15,950	24.0	1.9									1.0	1.0
2	X	22,100	24.0	1.8									1.0	1.0
3	X	18,500	24.0	1.6									0.9	1.0
4	X	14,400	24.0	1.7									1.0	1.0
5	X	18,900	24.0	1.6									0.8	1.0
6	X	27,500	24.0	1.8									1.0	1.0
7	X	16,150	24.0	2.0									1.1	1.1
8	X	16,150	24.0	2.0									0.9	1.1
9	X	16,800	24.0	1.4									0.9	1.2
10	X	22,800	24.0	2.2									0.9	1.2
11	X	15,800	24.0	2.2									0.9	2.2
12	X	20,900	24.0	2.2									0.9	2.2
13	X	16,300	24.0	2.2									0.9	2.2
14	X	25,850	24.0	2.3									1.1	2.3
15	X	25,850	24.0	2.3									1.1	2.3
16	X	22,900	24.0	2.3									1.2	2.3
17	X	17,200	24.0	2.2									1.1	2.2
18	X	15,300	24.0	1.7									1.0	1.7
19	X	22,300	24.0	2.0									1.2	2.0
20	X	27,400	24.0	2.0									1.3	2.0
21	X	19,300	24.0	2.3									1.5	2.3
22	X	19,300	24.0	2.3									1.6	2.3
23	X	29,100	24.0	1.9									1.6	1.9
24	X	35,700	24.0	1.9									1.5	1.9
25	X	18,100	24.0	1.6									1.3	1.6
26	X	25,100	24.0	2.3									1.6	2.3
27	X	14,000	24.0	2.3									1.7	2.3
28	X	24,950	24.0	2.3									1.7	2.3
29	X	24,950	24.0	2.3									1.6	2.3
30	X	14,500	24.0	2.4									1.8	2.4
31	X	13,000	24.0	1.2									1.0	1.2
Total		637,050												
Average		20,550												
Maximum		35,700												

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: September, 2005

A. Public Water System (PWS) Information

PWS Name: Tomoka View		PWS Identification Number: 3641373	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 184		Total Population Served at End of Month: 644	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: PO Box 490310		City: Leesburg	State: Florida
Contact Person's Telephone Number: (352) 787-0980		Zip Code: 34749	
Contact Person's E-Mail Address: beheath@aquaamerica.com		Contact Person's Fax Number: (352) 787-6333	

B. Water Treatment Plant Information

Plant Name: Tomoka View		Plant Telephone Number: (352) 787-0980	
Plant Address: 339 Apache Trail		City: Ormond	State: Florida
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water		Zip Code: 32174	
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 100,000			
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): C	

Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	Paul Thompson	A	7251	Days 1st Shift
Other Operators:	Larry White	C	7082	Days 1st Shift
	Daivd Haring	C	14091	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Paul Thompson Printed or Typed Name	A7251 License Number
--------------------	--	-------------------------

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641373 Plant Name: Tomoka View

III. Daily Data for the Month/Year of: September, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L.	Emergency or Abnormal Operating Conditions; Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations					UV Dose							
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²				
1	X	24.0	29,300		1.5										0.9	
2	X	24.0	43,400		1.4										0.8	
3	X	24.0	33,200		1.2										0.5	
4		24.0	48,950													
5	X	24.0	48,950		1.6										0.9	
6	X	24.0	51,300		2.0										1.1	
7	X	24.0	39,500		1.3										1.0	
8	X	24.0	41,000		2.3										2.0	
9	X	24.0	36,700		2.2										1.9	
10	X	24.0	55,800		2.0										1.8	
11	X	24.0	65,800		1.8										1.7	
12	X	24.0	65,800		1.8										1.7	
13	X	24.0	26,100		2.2										1.9	
14	X	24.0	37,900		2.2										1.9	
15	X	24.0	47,400		2.2										2.0	
16	X	24.0	42,300		2.4										2.1	
17	X	24.0	46,700		2.2										2.0	
18		24.0	51,850													
19	X	24.0	51,850		1.0										0.5	
20	X	24.0	52,500		1.7										0.9	
21	X	24.0	34,300		1.9										1.0	
22	X	24.0	36,400		2.3										1.5	
23	X	24.0	43,200		1.5										0.9	
24	X	24.0	36,400		1.5										0.9	
25		24.0	51,950													
26	X	24.0	51,950		2.4										1.8	
27	X	24.0	44,900		2.6										2.0	
28	X	24.0	47,000		0.8										0.7	
29	X	24.0	38,700		1.5										1.0	
30	X	24.0	58,900		1.3										1.0	
31		24.0														
Total			1,360,000													
Average			43,871													
Maximum			65,800													

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: September, 2005

A. Public Water System (PWS) Information

PWS Name:	Twin Rivers			PWS Identification Number:	3641399
PWS Type:	<input checked="" type="checkbox"/> Community	<input type="checkbox"/> Non-Transient Non-Community	<input type="checkbox"/> Transient Non-Community	<input type="checkbox"/> Consecutive	
Number of Service Connections at End of Month:	85			Total Population Served at End of Month:	298
PWS Owner:	Aqua Utilities Florida				
Contact Person:	Brian Heath			Contact Person's Title:	Area Manager
Contact Person's Mailing Address:	PO Box 490310	City:	Leesburg	State:	Florida
Contact Person's Telephone Number:	(352) 787-0980			Contact Person's Fax Number:	(352) 787-6333
Contact Person's E-Mail Address:	beheath@aquaamerica.com				

B. Water Treatment Plant Information

Plant Name:	Twin Rivers			Plant Telephone Number:	(352) 787-0980
Plant Address:	8 Riverdale Avenue			City:	Ormond
Type of Water Treatment by Plant:	<input checked="" type="checkbox"/> Raw Ground Water	<input type="checkbox"/> Purchased Finished Water			
Permitted Maximum Day Operating Capacity of Plant, gallons per day:	100,000				
Plant Category (per subsection 62-699.310(4), F.A.C.):	IV			Plant Class (per subsection 62-699.310(4), F.A.C.):	
				C	
Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked	
Lead/Chief Operator:	Paul Thompson	A	7251	Days 1st Shift	
Other Operators:	Larry White	C	7082	Days 1st Shift	
	David Haring	C	14091	Days 1st Shift	

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

_____ Signature and Date	<u>Paul Thompson</u> Printed or Typed Name	<u>A7251</u> License Number
-----------------------------	---	--------------------------------

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641399 Plant Name: Twin Rivers

III. Daily Data for the Month/Year of: September, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions: Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
				CT Calculations					UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²			
1	X	24.0	15,500		1.4									1.1	
2	X	24.0	17,900		1.6									1.2	
3	X	24.0	18,300		1.9									1.3	
4		24.0	22,650												
5	X	24.0	22,650		1.5									1.1	
6	X	24.0	23,100		1.6									1.2	
7	X	24.0	17,600		1.9									1.4	
8	X	24.0	11,700		2.0									1.5	
9	X	24.0	19,800		1.5									1.2	
10	X	24.0	28,600		1.6									1.2	
11		24.0	17,900												
12	X	24.0	17,900		1.6									1.1	
13	X	24.0	34,500		2.2									1.5	
14	X	24.0	22,500		2.2									0.8	
15	X	24.0	32,600		2.4									1.9	
16	X	24.0	23,400		1.9									1.5	
17	X	24.0	25,300		1.8									1.5	
18		24.0	22,400												
19	X	24.0	22,400		0.9									0.4	
20	X	24.0	22,500		2.1									1.1	
21	X	24.0	12,100		1.3									0.9	
22	X	24.0	22,300		2.0									1.0	
23	X	24.0	16,100		2.3									1.5	
24	X	24.0	10,400		2.2									1.6	
25		24.0	12,750												
26	X	24.0	12,750		2.4									1.7	
27	X	24.0	32,600		1.5									1.3	
28	X	24.0	18,000		0.9									0.9	
29	X	24.0	16,000		0.9									0.7	
30	X	24.0	16,100		1.7									1.4	
31		24.0													
Total			608,300												
Average			19,623												
Maximum			34,500												

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: October, 2005

A. Public Water System (PWS) Information

PWS Name: Tomoka View		PWS Identification Number: 3641373	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 184		Total Population Served at End of Month: 644	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: PO Box 490310		City: Leesburg	State: Florida
		Zip Code: 34749	
Contact Person's Telephone Number: (352) 787-0980		Contact Person's Fax Number: (352) 787-6333	
Contact Person's E-Mail Address: beheath@aquaaamerica.com			

B. Water Treatment Plant Information

Plant Name: Tomoka View		Plant Telephone Number: (352) 787-0980		
Plant Address: 339 Apache Trail		City: Ormond	State: Florida	
		Zip Code: 32174		
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water				
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 100,000				
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): C		
Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	Paul Thompson	A	7251	Days 1st Shift
Other Operators:	Larry White	C	7082	Days 1st Shift
	Daivd Haring	C	14091	Days 1st Shift

II Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

	Paul Thompson	A7251
Signature and Date	Printed or Typed Name	License Number

MONTHLY OPERATION REPORT FOR PW'SS TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641373 Plant Name: Tomoka View

III. Daily Data for the Month/year of: October, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time Before or at First Customer During Peak Flow, minutes	Temp of Water, °C if Applicable	Minimum CT Required, mg-min/L	Operating UV Dose, mW-sec/cm ²	Lowest UV Dose Required, mW-sec/cm ²	Lowest Residual Disinfectant Concentration at Remote Point to Distribution Involves Taking Water System Components Out of Operation	CT Calculations	UV Dose	
												System, mg/L	1.0
1	X	24.0	36,100	1.4									
2		24.0	41,850										
3	X	24.0	41,850	0.6									
4	X	24.0	40,700	0.8									
5	X	24.0	35,200	1.0									
6	X	24.0	36,600	1.1									
7	X	24.0	31,200	0.8									
8	X	24.0	33,600	2.0									
9		24.0	46,950										
10	X	24.0	46,950	2.4									
11	X	24.0	73,000	2.6									
12	X	24.0	18,500	2.6									
13	X	24.0	41,100	2.4									
14	X	24.0	33,400	2.8									
15	X	24.0	37,900	1.0									
16		24.0	48,800										
17	X	24.0	48,800	1.3									
18	X	24.0	30,800	1.6									
19	X	24.0	47,400	1.3									
20	X	24.0	44,000	1.3									
21	X	24.0	44,500	2.6									
22	X	24.0	44,000	2.4									
23		24.0	43,900										
24	X	24.0	43,900	2.4									
25	X	24.0	40,800	1.2									
26	X	24.0	32,200	1.7									
27	X	24.0	46,800	0.9									
28	X	24.0	35,900	1.0									
29	X	24.0	31,600	1.4									
30		24.0	52,400										
31	X	24.0	52,400	1.0									
Total			1,283,100										
Average			41,390										
Maximum			73,000										

* Refer to the instructions for this report to determine which plants must provide this information

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: October, 2005

A. Public Water System (PWS) Information

PWS Name: Twin Rivers		PWS Identification Number: 3641399	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community		<input type="checkbox"/> Consecutive	
Number of Service Connections at End of Month: 85		Total Population Served at End of Month: 298	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: PO Box 490310		City: Leesburg	State: Florida
Contact Person's Telephone Number: (352) 787-0980		Zip Code: 34749	
Contact Person's E-Mail Address: beheath@aquaaamerica.com		Contact Person's Fax Number: (352) 787-6333	

B. Water Treatment Plant Information

Plant Name: Twin Rivers		Plant Telephone Number: (352) 787-0980	
Plant Address: 8 Riverdale Avenue		City: Ormond	State: Florida
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water		Zip Code: 32174	
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 100,000			
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): C	
Licensed Operators	Name	License Class	License Number
Lead/Chief Operator:	Paul Thompson	A	7251
Other Operators:	Larry White	C	7082
	David Haring	C	14091

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Paul Thompson Printed or Typed Name	A7251 License Number
--------------------	--	-------------------------

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641399 Plant Name: Twin Rivers

III. Daily Data for the Month/Year of: October, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Staffed or Visited by Operator ("X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal	Peak Flow Rate, gpd	Lowest Residual Disinfectant Concentration (C) at Customer Measurement Point During Peak Flow, mg/L	Disinfectant Contact Time Before or at First Customer Measurement Point During Peak Flow, minutes	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²	Remote Point in Distribution System, mg/L	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*		
												UV Dose	CT Calculations	
1	X	16,800	24.0	2.6										
2		19,600	24.0	2.5										
3	X	19,600	24.0	2.5										
4	X	13,500	24.0	2.8										
5	X	18,000	24.0	2.5										
6	X	16,500	24.0	2.8										
7	X	9,100	24.0	2.0										
8	X	14,000	24.0	1.8										
9		15,800	24.0	1.9										
10	X	15,800	24.0	1.9										
11	X	20,000	24.0	1.2										
12	X	6,200	24.0	1.2										
13	X	16,900	24.0	1.4										
14	X	16,300	24.0	1.0										
15	X	11,500	24.0	1.4										
16		18,600	24.0											
17	X	18,600	24.0	1.3										
18	X	16,600	24.0	1.3										
19	X	18,600	24.0	1.3										
20	X	14,800	24.0	2.1										
21	X	16,100	24.0	0.7										
22	X	14,400	24.0	1.4										
23		14,150	24.0											
24	X	14,150	24.0	1.4										
25	X	17,100	24.0	1.9										
26	X	9,400	24.0	1.1										
27	X	14,000	24.0	1.5										
28	X	17,100	24.0	1.5										
29	X	9,400	24.0	1.7										
30		17,900	24.0											
31	X	17,900	24.0	1.5										
Total		478,400												
Average		15,432												
Maximum		20,000												

* Refer to the instructions for this report to determine which plants must provide this information

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: November, 2005

A. Public Water System (PWS) Information

PWS Name: Tomoka View		PWS Identification Number: 3641373	
PWS Type:	<input checked="" type="checkbox"/> Community	<input type="checkbox"/> Non-Transient Non-Community	<input type="checkbox"/> Transient Non-Community
Number of Service Connections at End of Month: 184		Total Population Served at End of Month: 644	
PWS Owner: Aqua Utilities Florida		Contact Person's Title: Area Manager	
Contact Person: Brian Heath	Contact Person's Mailing Address: PO Box 490310	City: Leesburg	State: Florida
Contact Person's Telephone Number: (352) 787-0980	Contact Person's E-Mail Address: beheath@aquaamerica.com	Zip Code: 34749	Contact Person's Fax Number: (352) 787-6333

B. Water Treatment Plant Information

Plant Name: Tomoka View		Plant Telephone Number: (352) 787-0980	
Plant Address: 339 Apache Trail		City: Ormond	State: Florida
Type of Water Treatment by Plant:		<input checked="" type="checkbox"/> Raw Ground Water	<input type="checkbox"/> Purchased Finished Water
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 100,000		Plant Class (per subsection 62-699.310(4), F.A.C.): C	
Plant Category (per subsection 62-699.310(4), F.A.C.): IV			
Licensed Operators	Name	License Class	License Number
Lead/Chief Operator:	Paul Thompson	A	7251
Other Operators:	Larry White	C	7082
	Daivd Haring	C	14091

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Paul Thompson Printed or Typed Name	A7251 License Number
--------------------	--	-------------------------

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641373 Plant Name: Tomoka View

III. Daily Data for the Month/year of: November, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Visited or Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) (T) at C	Disinfectant Contact Time	Lowest CT Provided or at Customer First Measurement	Point During Peak Flow, minutes	Temp of Water, °C	pH of Water, If Applicable	Minimum CT Required, mg	Lowest UV Dose, mW-sec/cm ²	UV Dose, mW-sec/cm ²	Remote Point in Distribution System, mg/L	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*	
														UV Dose	UV Dose
1	X	24.0	35,900	0.8										0.8	
2	X	24.0	20,800	0.9										0.9	
3	X	24.0	41,100	1.0										1.0	
4	X	24.0	34,900	0.9										0.9	
5	X	24.0	32,700	0.7										0.7	
6		24.0	47,450												
7	X	24.0	47,450	0.6										0.6	
8	X	24.0	37,600	0.5										0.5	
9	X	24.0	39,300	0.6										0.6	
10	X	24.0	44,300	0.6										0.6	
11	X	24.0	32,100	0.5										0.5	
12	X	24.0	29,300	3.5										3.5	
13		24.0	52,700												
14	X	24.0	52,700	2.8										2.8	
15	X	24.0	50,600	0.6										0.6	
16	X	24.0	26,300	1.4										1.4	
17	X	24.0	52,400	1.6										1.6	
18	X	24.0	30,800	1.5										1.5	
19	X	24.0	28,300	1.5										1.5	
20		24.0	49,750												
21	X	24.0	49,750	1.6										1.6	
22	X	24.0	31,200	1.8										1.8	
23	X	24.0	36,400	1.8										1.8	
24	X	24.0	55,300	1.8										1.8	
25	X	24.0	34,800	1.4										1.4	
26	X	24.0	35,300	1.8										1.8	
27		24.0	47,250												
28	X	24.0	47,250	2.5										2.5	
29	X	24.0	30,500	2.8										2.8	
30	X	24.0	36,100	2.6										2.6	
31		24.0													
Total		1,190,300													
Average		38,397													
Maximum		55,300													

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: November, 2005

A. Public Water System (PWS) Information

PWS Name:	Twin Rivers			PWS Identification Number:	3641399
PWS Type:	<input checked="" type="checkbox"/> Community	<input type="checkbox"/> Non-Transient Non-Community	<input type="checkbox"/> Transient Non-Community	<input type="checkbox"/> Consecutive	
Number of Service Connections at End of Month:	85			Total Population Served at End of Month:	298
PWS Owner:	Aqua Utilities Florida				
Contact Person:	Brian Heath			Contact Person's Title:	Area Manager
Contact Person's Mailing Address:	PO Box 490310	City:	Leesburg	State:	Florida
Contact Person's Telephone Number:	(352) 787-0980			Contact Person's Fax Number:	(352) 787-6333
Contact Person's E-Mail Address:	beheath@aquaamerica.com				

B. Water Treatment Plant Information

Plant Name:	Twin Rivers			Plant Telephone Number:	(352) 787-0980
Plant Address:	8 Riverdale Avenue	City:	Ormond	State:	Florida
Type of Water Treatment by Plant:	<input checked="" type="checkbox"/> Raw Ground Water			<input type="checkbox"/> Purchased Finished Water	
Permitted Maximum Day Operating Capacity of Plant, gallons per day:	100,000				
Plant Category (per subsection 62-699.310(4), F.A.C.):	IV			Plant Class (per subsection 62-699.310(4), F.A.C.):	
				C	
Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked	
Lead/Chief Operator:	Paul Thompson	A	7251	Days 1st Shift	
Other Operators:	Larry White	C	7082	Days 1st Shift	
	David Haring	C	14091	Days 1st Shift	

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

	Paul Thompson	A7251
Signature and Date	Printed or Typed Name	License Number

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641399 Plant Name: Twin Rivers

III. Daily Data for the Month/Year of: November, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*								Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions; Repair or Maintenance Work that Involves Taking Water System Components Out of Operation.	
				CT Calculations				UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²			Minimum UV Dose Required, mW-sec/cm ²
1	X	24.0	14,600		1.2								0.6	
2	X	24.0	11,300		1.2								0.7	
3	X	24.0	12,700		1.4								0.7	
4	X	24.0	15,800		1.6								0.8	
5	X	24.0	10,600		1.6								1.0	
6		24.0	17,800											
7	X	24.0	17,800		1.6								1.2	
8	X	24.0	10,000		1.5								0.5	
9	X	24.0	16,600		1.5								0.9	
10	X	24.0	18,500		1.5								0.6	
11	X	24.0	10,700		1.6								0.8	
12	X	24.0	16,700		1.5								0.6	
13		24.0	22,150											
14	X	24.0	22,150		1.5								0.7	
15	X	24.0	17,400		1.5								0.9	
16	X	24.0	11,200		1.4								0.7	
17	X	24.0	25,500		1.5								1.0	
18	X	24.0	22,300		1.4								0.3	
19	X	24.0	17,800		1.7								0.6	
20		24.0	28,000											
21	X	24.0	28,000		1.6								0.4	
22	X	24.0	35,500		1.8								0.6	
23	X	24.0	40,800		1.6								0.6	
24	X	24.0	15,700		1.8								0.7	
25	X	24.0	16,200		2.0								0.7	
26	X	24.0	10,900		2.0								0.5	
27		24.0	24,150											
28	X	24.0	24,150		2.8								1.0	
29	X	24.0	16,100		2.8								1.2	
30	X	24.0	16,200		2.8								1.5	
31		24.0												
Total			567,300											
Average			18,300											
Maximum			40,800											

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



Polymer Page 3 Due in December

See Pages 4 for Instructions.

I. General Information for the Month/Year of: December, 2005

A. Public Water System (PWS) Information

PWS Name: Tomoka View		PWS Identification Number: 3641373	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 184		Total Population Served at End of Month: 644	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: PO Box 490310		City: Leesburg	State: Florida
		Zip Code: 34749	
Contact Person's Telephone Number: (352) 787-0980		Contact Person's Fax Number: (352) 787-6333	
Contact Person's E-Mail Address: beheath@aquamerica.com			

B. Water Treatment Plant Information

Plant Name: Tomoka View		Plant Telephone Number: (352) 787-0980	
Plant Address: 339 Apache Trail		City: Ormond	State: Florida
		Zip Code: 32174	
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water			
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 100,000			
Plant Category (per subsection 62-699.310(4), F.A.C.): IV		Plant Class (per subsection 62-699.310(4), F.A.C.): C	

Licensed Operators	Name	License Class	License Number	Day(s)/Shift(s) Worked
Lead/Chief Operator:	Paul Thompson	A	7251	Days 1st Shift
Other Operators:	Larry White	C	7082	Days 1st Shift
	Daivd Haring	C	14091	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Paul Thompson Printed or Typed Name	A7251 License Number
--------------------	--	-------------------------

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641373 Plant Name: Tomoka View

December, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

CT Calculations, or UV Dose, to Demonstrate Four-Log Virus Inactivation, if Applicable* UV Dose

III. Daily Data for the Month/Year of:

Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal	Peak Flow Rate, gpd	Lowest Residual Disinfectant Concentration (C) Before or at First Measurement	Contact Time (T) at C	Disinfectant Provided Before or at First Measurement	Flow, mg./min./L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg./min./L	Lowest Operating UV Dose, mW-sec/cm	Minimum UV Dose Required, mW-sec/cm	Lowest Residual Disinfectant Concentration at Distribution Remote Point in Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
1	X	24,000	37,400	2.4									1.0
2	X	24,000	34,700	1.0									0.5
3	X	24,000	35,400	1.0									0.5
4		24,000	47,000										
5	X	24,000	47,000	1.0									0.4
6	X	24,000	22,200	2.0									0.8
7	X	24,000	46,900	1.7									0.9
8	X	24,000	35,400	1.8									1.0
9	X	24,000	29,000	1.7									0.9
10	X	24,000	30,800	1.1									0.7
11		24,000	38,400										
12	X	24,000	38,400	1.6									0.9
13	X	24,000	38,300	0.6									0.3
14	X	24,000	36,900	0.6									0.3
15	X	24,000	36,000	1.5									0.2
16	X	24,000	36,100	2.4									1.0
17	X	24,000	36,800	1.0									0.4
18		24,000	37,000										
19	X	24,000	37,000	1.4									0.6
20	X	24,000	32,300	1.1									0.2
21	X	24,000	47,000	1.4									0.5
22	X	24,000	37,700	0.7									0.2
23	X	24,000	32,600	0.9									0.2
24	X	24,000	39,300	1.0									0.2
25		24,000	51,200										
26	X	24,000	51,200	1.6									0.4
27	X	24,000	54,600	2.1									0.8
28	X	24,000	51,400	2.2									0.4
29	X	24,000	53,100	1.7									0.5
30	X	24,000	54,900	1.5									0.5
31	X	24,000	54,000	2.1									0.4
Total		1,260,000											
Average		40.645											
Maximum		54.900											

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



Polymer Page 3 Due in December

See Pages 4 for Instructions.

I. General Information for the Month/Year of: December, 2005

A. Public Water System (PWS) Information

PWS Name:	Twin Rivers			PWS Identification Number:	3641399
PWS Type:	<input checked="" type="checkbox"/> Community	<input type="checkbox"/> Non-Transient Non-Community	<input type="checkbox"/> Transient Non-Community	<input type="checkbox"/> Consecutive	
Number of Service Connections at End of Month:	85			Total Population Served at End of Month:	298
PWS Owner:	Aqua Utilities Florida				
Contact Person:	Brian Heath			Contact Person's Title:	Area Manager
Contact Person's Mailing Address:	PO Box 490310	City:	Leesburg	State:	Florida
Contact Person's Telephone Number:	(352) 787-0980			Contact Person's Fax Number:	(352) 787-6333
Contact Person's E-Mail Address:	beheath@aquaamerica.com				

B. Water Treatment Plant Information

Plant Name:	Twin Rivers			Plant Telephone Number:	(352) 787-0980	
Plant Address:	8 Riverdale Avenue			City:	Ormond	
Type of Water Treatment by Plant:	<input checked="" type="checkbox"/> Raw Ground Water	<input type="checkbox"/> Purchased Finished Water				
Permitted Maximum Day Operating Capacity of Plant, gallons per day:	100,000					
Plant Category (per subsection 62-699.310(4), F.A.C.):	IV			Plant Class (per subsection 62-699.310(4), F.A.C.):	C	
Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked		
Lead/Chief Operator:	Paul Thompson	A	7251	Days 1st Shift		
Other Operators:	Larry White	C	7082	Days 1st Shift		
	David Haring	C	14091	Days 1st Shift		

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date

Paul Thompson

Printed or Typed Name

A7251

License Number

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3641399 Plant Name: Twin Rivers

III. Daily Data for the Month/Year of: December, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions: Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations					UV Dose							
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²				
1	X	24.0	11,200		2.6										1.2	
2	X	24.0	20,200		2.4										1.2	
3	X	24.0	12,100		2.4										1.2	
4		24.0	22,050													
5	X	24.0	22,050		2.5										0.5	
6	X	24.0	14,800		4.0										1.2	
7	X	24.0	16,500		2.6										1.4	
8	X	24.0	15,900		2.8										0.8	
9	X	24.0	15,600		2.6										1.4	
10	X	24.0	10,600		2.6										1.0	
11		24.0	18,250													
12	X	24.0	18,250		2.5										1.4	
13	X	24.0	15,000		2.4										1.2	
14	X	24.0	13,900		2.4										1.5	
15	X	24.0	15,000		2.3										1.0	
16	X	24.0	15,000		2.4										1.2	
17	X	24.0	13,900		2.4										1.0	
18		24.0	15,000													
19	X	24.0	15,000		2.0										0.5	
20	X	24.0	14,900		2.0										0.6	
21	X	24.0	15,100		2.0										0.6	
22	X	24.0	19,100		1.8										0.2	
23	X	24.0	14,400		2.2										0.5	
24	X	24.0	14,200		2.0										0.7	
25		24.0	19,400													
26	X	24.0	19,400		2.0										0.4	
27	X	24.0	20,000		2.0										0.4	
28	X	24.0	19,000		2.2										0.5	
29	X	24.0	13,300		2.2										0.5	
30	X	24.0	15,200		2.2										0.4	
31	X	24.0	14,400		1.8										0.2	
Total			498,700													
Average			16,087													
Maximum			22,050													

* Refer to the instructions for this report to determine which plants must provide this information.