

State of Florida



Public Service Commission

CAPITAL CIRCLE OFFICE CENTER • 2540 SHUMARD OAK BOULEVARD
TALLAHASSEE, FLORIDA 32399-0850

-M-E-M-O-R-A-N-D-U-M-

DATE: October 23, 2008
TO: Ann Cole, Commission Clerk - PSC, Office of Commission Clerk
FROM: Connie S. Kummer, Chief of Certification & Tariffs, Division of Economic Regulation *CK*
RE: Revision to Page 5, Attachment E of Document No. 04237-08 in Docket No. 080193-EQ

The attached document was submitted by Florida Power & Light on October 22, 2008, as a revision to Page 5 of Attachment E of Document No. 04237-08 filed on May 20, 2008 in Docket No. 080193-EQ. This document revises costs estimates supporting FPL's Standard Offer contract. Please add this document to the docket file. Thank you.

DOCUMENT NUMBER - DATE

10083 OCT 23 8

FPSC-COMMISSION CLERK



Kory Dubin
Florida Power & Light Company
P.O. Box 29100
Miami, FL 33102
(305)552-4910

October 22, 2008

-VIA HAND DELIVERY-

Mr. John Baxter
Division of Economic Regulation
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399-0850

Re: Docket No. 080193-EQ, Petition for Approval of Renewable Energy Tariff
and Standard Offer Contract, by Florida Power & Light Company

Dear Mr. Baxter:

Enclosed is the revised page number five (5) for Attachment E in the above
referenced docket. Please replace the current page number 5 found in Attachment E with
the enclosed page 5.

If you have any questions, please contact me at (305)552-4910. Your assistance
in this matter is greatly appreciated.

Sincerely,

A handwritten signature in black ink, appearing to read 'Kory Dubin', followed by a small flourish.

Kory Dubin

RECEIVED
FLORIDA PUBLIC SERVICE
COMMISSION
DIVISION OF
ECONOMIC REGULATION

08 OCT 22 PM 4: 26

Florida Power & Light Company
Standard Offer Contract

Unit Information

Plant Name (Type): Combined Cycle
Net Capacity (MW): 1219 MW
Book Life (Years): 25

Installed Cost (In-Service Year 2014)

Total Installed Cost (\$/kW)	994.00
Direct Construction Cost (\$/kW-00)	866.00
AFUDC Amount (\$/kW)	128.00
Fixed O&M (\$/kW-Yr.) (In-Service Year)	6.00
Capital Replacement	8.38
Variable O&M (cents/kWH)	.080
Average Capacity Factor of Avoided Unit for first 10 years of operation	92
K Factor	1.4807