

BEFORE THE  
FLORIDA PUBLIC SERVICE COMMISSION

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

In the Matter of:


REVIEW OF 2010 ELECTRIC INFRASTRUCTURE STORM HARDENING PLAN FILED PURSUANT TO RULE 25-6.0342, F.A.C., SUBMITTED BY PROGRESS ENERGY FLORIDA, INC. DOCKET NO. 100262-EI

REVIEW OF 2010 ELECTRIC INFRASTRUCTURE STORM HARDENING PLAN FILED PURSUANT TO RULE 25-6.0342, F.A.C., SUBMITTED BY TAMPA ELECTRIC COMPANY. DOCKET NO. 100263-EI

REVIEW OF 2010 ELECTRIC INFRASTRUCTURE STORM HARDENING PLAN FILED PURSUANT TO RULE 25-6.0342, F.A.C., SUBMITTED BY FLORIDA PUBLIC UTILITIES COMPANY. DOCKET NO. 100264-EI

REVIEW OF 2010 ELECTRIC INFRASTRUCTURE STORM HARDENING PLAN FILED PURSUANT TO RULE 25-6.0342, F.A.C., SUBMITTED BY GULF POWER COMPANY. DOCKET NO. 100265-EI

REVIEW OF 2010 ELECTRIC INFRASTRUCTURE STORM HARDENING PLAN FILED PURSUANT TO RULE 25-6.0342, F.A.C., SUBMITTED BY FLORIDA POWER & LIGHT COMPANY. DOCKET NO. 100266-EI



PROCEEDINGS: IOUS STORM HARDENING WORKSHOP

DATE: Thursday, June 10, 2010

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

TIME: Commenced at 9:30 a.m.  
Concluded at 11:29 a.m.

PLACE: Betty Easley Conference Center  
Room 148  
4075 Esplanade Way  
Tallahassee, Florida

REPORTED BY: JANE FAUROT, RPR  
Official FPSC Reporter  
(850) 413-6732

	PRESENTATIONS BY:	PAGE
1		
2	David T. Bromley, Florida Power and Light	6
3	Eric Sachon, Progress Energy Florida, Inc.	22
4	T.J. Szelistowski, Tampa Electric Company	42
5	Ed Battaglia, Gulf Power Company	58
6	Jorge Puentes, Florida Public Utilities Company	72

7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

## P R O C E E D I N G S

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

**MS. L'AMOREAUX:** Okay. Before we get started, I'm just going to go over some housekeeping items. There is a sign-in sheet and the copies of the presentations to your right. If everyone can please sign in and get a copy, then we will begin.

Good morning, everybody. I'm Melissa L'Amoreaux with staff. Following the 2004/2005 hurricane season, the Florida Public Service Commission took several steps to minimize future storm damage to electric infrastructure and resulting outages to customers. In addition to requiring pole inspections, vegetation management, and other actions, on February 27th, 2006, the Commission directed staff to begin rulemaking proceedings to require electric utilities to strengthen Florida's electrical transmission and distribution infrastructure to better withstand severe weather events. The Florida Public Service Commission also issued an order that required investor-owned utilities to file plans and estimate implementation costs for the ten on-going storm preparedness initiatives.

On May 7th, 2007, Florida Power and Light,



1 Progress Energy Florida, Tampa Electric Company, and  
2 Gulf Power each filed their respective 2007 electric  
3 infrastructure storm hardening plan, which included  
4 wooden pole inspection programs and the ten on-going  
5 initiatives. On December 28th, 2007, the Commission  
6 voted to approve all four plans.

7 Florida Public Utilities Company requested and  
8 was allowed to file its storm hardening plan as part of  
9 its general rate case. Florida Public Utilities  
10 Company's storm hardening plan was approved May 19th,  
11 2008. Consistent with Rule 25-6.0342, also known as the  
12 Storm Hardening Rule, the Commission order approving the  
13 storm hardening plans require that each plan be updated  
14 and filed with the Commission every three years.

15 The first plan updates for the IOUs were filed  
16 May 3rd, 2010. The storm hardening rule requires that  
17 each plan contain a description of the IOU's  
18 construction standards, policies, practices, and  
19 procedures to enhance the reliability of overhead and  
20 underground electrical transmission and distribution  
21 facilities.

22 We are here today pursuant to notice issued  
23 May 11th, 2010. This time and place has been set for  
24 the review of the 2010 electric infrastructure storm  
25 hardening plan updates filed pursuant to the storm

1 hardening rule. By letter dated May 21st, 2010, staff  
2 has asked each IOU to discuss five key topics at today's  
3 workshop. Those topics are briefly discuss the ten  
4 on-going initiatives; compare and contrast the approved  
5 plans versus the updated plans; address any budget  
6 concerns and impacts of any changes to the updated  
7 plans; briefly explain any struggles encountered in  
8 achieving the ten on-going initiatives; and explain how  
9 restoration and hardening is improving the overall  
10 system.

11 The letter also indicated that staff proposed  
12 the presentations be in this order: Florida Power and  
13 Light, Progress Energy Florida, Tampa Electric Company,  
14 Gulf Power, and FPUC. With that, I'll hand it off to  
15 David Bromley with Florida Power and Light.

16 **MR. BROMLEY:** Good morning. My name is David  
17 Bromley. I'm the Manager of Regulatory Activities for  
18 Distribution Business for FPL. I'm going to try to  
19 provide you an update today on our storm preparedness  
20 initiatives as well as our hardening plans.

21 The initiatives and hardening plans cover  
22 various departments within FPL's distribution and  
23 transmission business units. While we haven't been able  
24 -- weren't able to bring everybody associated with  
25 implementing these plans, we did bring some individuals

1 to potentially help answer any questions you all may  
2 have. As to the extent that you have questions we can't  
3 answer today, we certainly would be glad to answer them  
4 subsequently.

5 I'm planning to cover first the ten storm  
6 preparedness initiatives, and then we will go into the  
7 specific hardening plans. Storm preparedness Initiative  
8 No. 1 deal with our vegetation management initiative.  
9 We are continuing to maintain our feeders on a  
10 three-year average cycle. Our laterals are continuing  
11 to ramp up to reach a six-year average cycle by 2013,  
12 and we are continuing to emphasize removing trees when  
13 we can with customers in order to avoid problem trees.  
14 This certainly is our most costly initiative of the ten  
15 storm preparedness initiatives. In 2010, we expect or  
16 plan to spend around \$61 million associated with this  
17 plan.

18 This is consistent with what was previously  
19 approved by the Commission in 2007. All of our storm  
20 preparedness initiatives as well as our hardening plan  
21 are really a continuation of what was approved back in  
22 2007 with the exception of one, which I will get into  
23 later, small tweak associated with a transmission pole  
24 replacement. Our plans are essentially the same. We  
25 are continuing the same path as what we had originally

1       been approved for.

2               Joint use, Initiative No. 2, is associated  
3 with two initiatives in that plan. One is looking at  
4 viewing on a five-year cycle all of the attachments to  
5 FPL's facilities. And really this is for primarily  
6 billing purposes as well as assuring that the  
7 attachments have been authorized to attach to FPL  
8 facilities. So every five years we complete a cycle  
9 through our old system and those billings are trued up  
10 and any unauthorized attachments are identified and  
11 taken care of and addressed with attachers.

12               Historically our number of unauthorized  
13 attachments is very small. We have a permitting process  
14 that we use and it seems to work very well and it's not  
15 a concern for FPL. We also conduct as part of the pole  
16 inspection program the same pole strength and loading  
17 inspections on these joint use poles as we do all the  
18 other poles throughout our system. As you would expect,  
19 we do find a little bit higher failures associated with  
20 loading failures on our poles with joint facilities more  
21 so than, you know, those that don't have attachments.  
22 But essentially 95 percent of these, you know, these  
23 poles are, you know, pass inspection.

24               Initiative No. 3, transmission inspections.  
25 All of our lines, substations, and structures are

1 inspected on a six-year cycle, and we're completing  
2 that -- we're in the process of completing that six-year  
3 cycle. Everything is on schedule there. As things are  
4 identified for failures, they are -- you know, they are  
5 identified for failure and then replaced the following  
6 year, either the same year or the following year.

7 Initiative No. 4, transmission hardening.  
8 This is the one area we had a slight tweak to a  
9 previously approved plan. Initially as a result of the  
10 2004 and 2005 storms, we saw in our transmission system  
11 some issues associated with single pole unguyed  
12 transmission structures, so we initially set out to  
13 replace those. However, a year or two later we modified  
14 that, and we are now replacing all wood transmission  
15 structures in our system. Additionally, we saw some  
16 failures associated with ceramic post insulators on  
17 concrete poles, and we are continuing to replace those  
18 throughout our system.

19 Initiative No. 5 deals with developing and  
20 maintaining a distribution GIS system. We have  
21 essentially incorporated into that all of the data  
22 associated with our distribution facilities. We have  
23 now added all of the joint use information showing poles  
24 that have attachments on them. We've included the  
25 hardening information associated with, you know,

1 projects since 2007. All of our pole inspection data is  
2 now being incorporated into that as well as our  
3 streetlight data which was recently added to our  
4 systems. So we have essentially caught up with loading  
5 our system and now are in the process of maintaining  
6 that and updating it for new information, including  
7 hardening, pole inspections, joint use, and so forth, as  
8 well as day-to-day activities.

9 Initiatives No. 6 and 7 really have to do with  
10 evaluating our facilities after a storm has passed  
11 through our service territory. Fortunately, we haven't  
12 had the ability to test this yet, but we do have systems  
13 in place to gather -- forensics teams have been  
14 identified, data collection processes have been  
15 established, a database has been established. Annually  
16 when we go through our hurricane dry run we also test  
17 those systems, as well. And the same goes for, you  
18 know, looking at our overhead versus underground  
19 performance of those facilities, as well.

20 Initiative No. 8, increased government  
21 coordination. Since 2004 and 2005, we have really done  
22 a lot to try to improve our coordination and  
23 communication with governmental agencies. We saw as a  
24 result of those storms it was important to keep them  
25 informed as to what was going on, what we were doing,

1 what the plans were, what the activities were. So in  
2 addition to our normal process where we have, you know,  
3 representatives in our external affairs departments as  
4 well as our customer service people who deal with  
5 governmental agencies. We also work with EOCs in  
6 staffing those accordingly. We have EOCs throughout the  
7 27 counties in our service territory. We have a group  
8 of 80 people that are assigned when storms or events  
9 occur that are ready to staff those facilities and have  
10 people there, you know, around the clock as necessary to  
11 support them.

12 The EOCs also help us in identifying critical  
13 infrastructure facilities for us, which helps us to  
14 prioritize and identify hardening projects in their  
15 locales. So, additionally, community outreach teams  
16 were developed. Last year in 2009, we had approximately  
17 168 presentations done throughout our service territory  
18 on various electric issues, but also including storm  
19 preparedness plans and activities. These are like the  
20 homeowner associations as well as city and county  
21 government meetings.

22 We also enhanced an e-mail process and  
23 established a specific governmental update website so  
24 when we do have storms there are places that they can go  
25 and find out specific information about our plans, where

1 our service locations are in their areas as the storm  
2 occurs, estimated time of restoration for their  
3 particular locales. A lot of information that's  
4 available to them that previous to 2004 and 2005 was not  
5 available.

6 Continue our research with PURC. The  
7 beginning of this year we signed another memorandum of  
8 understanding along with the other IOUs, co-ops, and  
9 munies in Florida. There are efforts that have been  
10 taking place regarding undergrounding, wind, the  
11 evaluation of wind.

12 Initiative No. 10. Every year we update and  
13 review our plans, disaster recovery plans, and those are  
14 provided. I think a copy of that is provided on file  
15 for the Commission. This includes primarily plans  
16 associated with the distribution and transmission  
17 facilities dealing with major weather events and fires.

18 All of our ten preparedness initiatives we  
19 believe are on target. As I mentioned, they are  
20 consistent with what was previously approved. Our plans  
21 for 2010 are consistent with what we have done in 2007  
22 through 2009, with the small exception with the  
23 transmission pole replacements. I think that's it for  
24 the storm prep plans.

25 I'm going to move on to hardening. We are



1 continuing our approach with hardening, our three-prong  
2 approach, and that is we're going to continue to  
3 strengthen our critical infrastructure facilities to  
4 extreme wind loading. We are going to apply incremental  
5 hardening which strengthens specific feeders associated  
6 with community projects along major thoroughfares, drug  
7 stores, gas stations, pharmacies. And incremental  
8 hardening can include strengthening that feeder up to  
9 and including extreme wind. And then we're continuing  
10 to apply extreme wind for all of our new overhead  
11 construction, including major plan work, relocation  
12 projects as well as daily work activities.

13 We are continuing to apply over three wind  
14 regions these specific wind profiles which would include  
15 105, 130, 145, depending on the area within our service  
16 territory. The 105 mile per hour extreme wind loading  
17 criteria is primarily in the northern central part of  
18 our territory. The 130 covers the northeastern/central  
19 part of our service territory, and then the 145 covers  
20 the southern part of the territory. Again, this is  
21 consistent with what we had previously approved, so we  
22 are continuing with that plan.

23 Just to give you an idea of what we've  
24 accomplished to date through the first three-year cycle  
25 of the hardening plan, we've hardened to extreme wind

1 loading for 227 feeders serving 266 critical  
2 infrastructure customers. We've hardened 103 highway  
3 crossings and 192 O1 (phonetic) switches, which is  
4 essentially the first pole out of a transmission  
5 substation. We have completed all of the hardening  
6 associated with acute care facilities and hospitals as a  
7 result -- at the end of 2009 in our service territory.

8 In 2010, we will almost complete all of our  
9 911 centers, and then in 2011 we will complete all of  
10 our 911 centers as well as all the EOC facilities in our  
11 service territory.

12 We applied incremental hardening to 68 feeders  
13 that are serving community needs, and we applied to all  
14 new construction, major planning work and relocation our  
15 extreme wind loading criteria. Our total cost for 2007  
16 to 2009 was \$162 million for these activities. That  
17 relates to primarily the -- or solely the hardening  
18 extreme wind loading as well as the incremental  
19 hardening. There is also some additional costs  
20 associated with new construction, but we don't track  
21 what it would have cost to build that, you know, under  
22 our old construction standards versus what it would have  
23 cost to build it under extreme wind. So that's not  
24 something that we track, so there is some additional  
25 money associated with hardening that we can't

1 specifically incrementally track, but there is an  
2 addition to that 162 million.

3 Our plans for 2010 are to harden 39 feeders  
4 serving 52 critical infrastructure customers, 16 highway  
5 crossings, and 20 01 switches. We are also going to  
6 incrementally harden five feeders serving community  
7 needs. And, of course, continue to apply extreme wind  
8 loading to all new construction.

9 Our plans for 2011 and 2012 still would be to  
10 develop -- we are actually starting the 2011 budget  
11 process now. Those will be firmed up subsequently, but  
12 we have, you know, have a target of how much we think we  
13 will be doing during 2011 and 2012, and our estimates  
14 for costs for these for the next three years is in the  
15 135 million to \$163 million range.

16 During the initial hardening planned workshops  
17 back in 2007, and in review of those plans, there was a  
18 lot of issues associated with attaching entities. So as  
19 a result of the outcome of those plans, we have worked  
20 very closely with attaching entities in making sure that  
21 they're kept up to date with what our plans are, what  
22 our costs are, that they have inputs into the  
23 development of our plans. At the beginning of this  
24 year, in March we send out 93 packages of our hardening  
25 filing, a draft at that time, seeking input, if any,

1 from our attaching entities. This would include cable  
2 companies, telephone companies, local government, anyone  
3 attached to our facilities have the opportunity to  
4 review those and provide input to us. We did receive  
5 feedback from eight of those entities. Some of them  
6 range from, you know, we got your filing, thanks. There  
7 was a couple of clarifying questions. No one expressed  
8 any issues with our plans.

9           Additionally, we're continuing to comply with  
10 the process that was established as a result of the last  
11 three-year cycle where in the September time frame of a  
12 given year we provide preliminary plans to our attaching  
13 entities of what we're planning to do the following  
14 year, which includes a listing of the specific projects,  
15 their locations, what our plans are. You know, whether  
16 it is extreme wind, incremental hardening. And then  
17 when our plans are finalized for the budget process,  
18 generally in the December time frame, they are provided  
19 those final plans, as well.

20           Additionally, when we're constructing or  
21 getting ready to construct these projects, we hold  
22 meetings with our attachers. They are invited to attend  
23 prior to design as well as construction -- prior to  
24 construction so that any issues are identified and  
25 resolved prior to those things taking place. And then,

1 of course, coordination takes place during the actual  
2 construction, as well.

3 Benefits of hardening. As I mentioned  
4 earlier, we haven't really had any storm activity since  
5 2004/2005, so we are continuing to rely on that  
6 information that we had available back then to continue  
7 with our plans, and this includes the experience of the  
8 2004/2005 storm seasons. It includes a report that was  
9 done by an outside firm, KEMA, back in the -- I'm not  
10 sure of the exact date, but subsequent to the storms  
11 that looked at the forensics associated with  
12 particularly Wilma, but looked at also some of the '04  
13 storms and really served as a basis for a lot of our  
14 hardening plans and initiatives.

15 Also, during Wilma we saw that our  
16 transmission poles performed much better than the  
17 distribution poles. Of course, transmission poles are  
18 already constructed at the extreme wind loading  
19 criteria, and so that served as a basis for us moving  
20 that to our distribution facilities.

21 And then there was analysis done by a  
22 consulting firm, Davies, that indicated that stronger  
23 poles, in this case FPL's Grade B poles at the time,  
24 performed better than lesser strength Grade C poles,  
25 which the majority of utilities throughout the country

1 built to. We believe that hardening will reduce the  
2 number and the duration of outages, both on a storm as  
3 well as nonstorm basis. That restoration costs will  
4 also be reduced, and an analysis that FPL performed  
5 showed that we expect hardened feeders to save  
6 restoration costs.

7 We think our plan is cost-effective and that  
8 it focuses on certain critical infrastructure that we  
9 are dealing with initially as well as community  
10 projects, and then, of course, over the long-term as we  
11 build new facilities that will be built to extreme wind  
12 that eventually, you know, our system will be built to  
13 extreme wind. That's the end of the presentation.

14 **MS. L'AMOREAUX:** Okay. We have a few  
15 questions for you --

16 **MR. BROMLEY:** Okay.

17 **MS. L'AMOREAUX:** -- or the people that you're  
18 with. One is how does FPL determine the amount of  
19 feeder and lateral miles the company must maintain for  
20 the approved years if there is an increase or decrease  
21 in feeder miles within that given year?

22 **MR. BROMLEY:** Say that again.

23 **MS. L'AMOREAUX:** Okay. If you have a feeder  
24 and you have so many miles, and you increase those  
25 miles, do you count those for that three-year cycle or

1 do you wait until the next cycle to clear them?

2 **MR. BROMLEY:** Are you talking about  
3 vegetation?

4 **MS. L'AMOREAUX:** Vegetation management, yes.

5 **MR. BROMLEY:** Okay. Our vegetation management  
6 cycle, of course, is an average three-year cycle. So  
7 just to make sure we are all understanding what that  
8 means, we could have some feeders on a two-year average,  
9 some feeders might be on a three-year average, and some  
10 feeders might be on a four-year average. So we're  
11 looking at our feeders primarily based on that.

12 The miles is really an outcome of addressing  
13 feeders when they need to be addressed on their cycles.  
14 So I'm not sure -- we don't let the miles force us or  
15 direct us as far as our budgeting process. I mean, it  
16 is a function of it, but we really focus on when does  
17 that feeder need to be trimmed and what is the resulting  
18 miles. You know, we report resulting miles on that.

19 As a result of the average cycle, miles can  
20 change, miles trimmed can change from year to year. It  
21 is not always going to be one-third of the system. So  
22 what drives our feeder cycles or our feeder trimming is  
23 really, you know, when those feeders need to be trimmed  
24 and the miles is really an outcome result of what got  
25 trimmed.

1           **MS. L'AMOREAUX:** The next question we have is  
2 FPL states that neither the company nor the other  
3 utilities generally have much experience with hardened  
4 distribution facilities. Based on the company's  
5 experience, what difficulties does FPL encounter with  
6 hardening just distribution facilities?

7           **MR. BROMLEY:** Well, certainly budget dollars  
8 are always a factor in really just about anything we do,  
9 so that certainly comes into play. Most recently, we  
10 have seen an increase in permitting issues that is  
11 making us -- making it more difficult for us to complete  
12 projects in the time lines that we would like to  
13 complete them. We are seeing a lot of permitting, new  
14 permitting requirements at local and county levels that  
15 didn't used to be there. Whether it's associated with,  
16 you know, revenue, additional revenue for these cities  
17 and counties may be part of it, but that is something  
18 that we are seeing increasingly making it more difficult  
19 for us to complete -- complete our projects on a timely  
20 basis.

21           Without any storm experience, we have seen  
22 that hardening is giving us some benefits. We have seen  
23 on a nonstorm basis hardened feeders showing an increase  
24 reliability performance a year after they're hardened  
25 versus the year before they are hardened. So we feel



1 like even on a nonstorm basis we are seeing some  
2 benefits associated with that.

3 **MS. L'AMOREAUX:** Well, you kind of answered my  
4 third question, which was since no named hurricanes have  
5 affected Florida since 2005, does FPL have any evidence  
6 of its hardening efforts to enhance its service quality,  
7 but I think you kind of covered that.

8 **MR. BROMLEY:** Yes. Additionally, I know  
9 within our service territory, and I am not sure if it  
10 was a year -- the exact time -- but we did have a  
11 tornado event come through. And I don't know whether we  
12 had any specific comparisons, forensic data that showed,  
13 you know, hardened feeder versus a nonhardened feeder.  
14 But I know in the specific area where there was  
15 extensive damage, our hardened feeder that was in that  
16 area did perform well. There was some damage associated  
17 with some of the facilities, but the poles themselves,  
18 you know, were not damaged. And all around them, you  
19 know, we saw extensive damage with the trees and so  
20 forth. So there was one, you know, side event that we  
21 were able to see some, you know, some of the benefits of  
22 hardening.

23 **MS. L'AMOREAUX:** Well, thank you for your  
24 presentation.

25 **MR. BROMLEY:** Thank you.

1           **MS. L'AMOREAUX:** Next we will have Eric Sachon  
2 from Progress Energy Florida.

3           **MR. SACHON:** Ladies and gentlemen, good  
4 morning. Before I get started, I'd like to introduce a  
5 couple of colleagues of mine who have joined me here  
6 today. Charlene Rubano is the Manager of Asset  
7 Performance in our transmission organization, and Nabil  
8 Benwahoud is the senior engineer within our distribution  
9 systems engineering organization.

10           My name is Eric Sachon, and I am the Manager  
11 of the Distribution Systems Organization. On behalf of  
12 Charlene and Nabil, we certainly appreciate the  
13 opportunity to come here to speak about our storm  
14 hardening plan, the ten on-going initiatives, and our  
15 reliability and the hardening efforts in 2010.

16           Before I get started, I'd like to -- okay.  
17 There we go. Thank you -- I'd like to go over the  
18 outline of what we are going to present today, and that  
19 is I'm going to talk a little bit about at a high level  
20 what our hardening strategy is and the components that  
21 make up our hardening strategy. We will also go into  
22 the ten point on-going -- or ten-point plan and the  
23 on-going initiatives, and we will cover the 2010 through  
24 2012 storm hardening plan and how that compares and  
25 contrasts to the '07 through '09 plan, and then we'll

1 touch on a little bit of the reliability and hardening  
2 efforts that we are employing here at Progress Energy  
3 Florida.

4 As you can see on the slide, there are three  
5 main components to our hardening strategy. The  
6 ten-point plan is something we will discuss in-depth  
7 today. The wood pole inspection program is also a  
8 component, and that is something we'll not really touch  
9 on today. And the third component is the storm  
10 hardening plan, which we will go over in some detail as  
11 well today.

12 So let's go ahead and get started on the  
13 on-going initiatives. Just to preface a little bit, I'm  
14 going to talk about the first eight initiatives, and  
15 then I will hand it over to Charlene to talk about the  
16 two transmission initiatives.

17 From a vegetation management perspective, the  
18 PEF integrated vegetation management program consists of  
19 five sub-programs. The five sub-programs consist of  
20 production trimming, demand trimming, herbicide  
21 application, vine removal, and mowing. The objectives  
22 of this plan are simply safety from both the customer as  
23 well as the employee perspective and reliability from  
24 the perspective of mitigating or minimizing tree-caused  
25 outages. Certainly customer satisfaction is another

1 component of the objective, and we want to make sure  
2 that we maintain costs in a cost containment effort.

3 We do have a vegetation management program  
4 that consists of a three-year and a five-year cycle.  
5 The three-year cycle is for our feeders and our backbone  
6 infrastructure. The five-year cycle is for our laterals  
7 or branch line infrastructure.

8 From a vegetation management perspective and  
9 the challenges that we foresee, there are numerous  
10 variables that can come into play. Some of those can  
11 include resource constraints, changes in our philosophy  
12 on what we want to do for that particular year from a  
13 prioritization perspective, and certainly the impact of  
14 a major storm can have some play with regards to  
15 vegetation management efforts. However, I will say that  
16 if we feel we have not met our obligation in any one  
17 given year, that in the subsequent years we will make up  
18 for that loss of not completing our expected budget  
19 expenditures and meeting that cycle.

20 The next initiative is joint use audits.  
21 Progress Energy Florida has committed to auditing all of  
22 our distribution and transmission poles that have joint  
23 use attachments within an eight-year cycle. There are  
24 approximately 500,000 distribution poles with joint use  
25 attachers and approximately 2,500 transmission poles

1 with joint use attachers. At this time, we do not  
2 foresee any major challenges with the joint use audits  
3 other than this thing that I mentioned with regards to  
4 vegetation management, and resource constraints, and  
5 potential major storm implications.

6 From a GIS upgrade perspective, that is the  
7 next initiative, in 2008, Progress Energy Florida  
8 completed the changeout of our GIS system. We went from  
9 a frame system to a geoelectric system. We are  
10 currently in the process of replacing our work  
11 management asset management system. The expectation is  
12 by the end of this year in the fourth quarter we will  
13 complete one of our four regions, the south coastal  
14 region with this new work management system. The  
15 expectation is to committee the other three regions by  
16 the end of 2011. At this point from a GIS perspective,  
17 we do not foresee any challenges to not meeting this  
18 opportunity.

19 The next initiative, forensic analysis.  
20 Progress Energy Florida has initiated a forensic  
21 analysis program within our storm plan. The forensic  
22 analysis program is a process that we employ immediately  
23 following the impact of a major storm. We have two  
24 person teams that are designed to go out throughout the  
25 service territory in generally the same location where

1 the storm has impacted our service territory and record  
2 any type of pole infrastructure damages, whether that be  
3 leaning or broken. They are to collect demographic  
4 information such as size, height, clearance, conductor,  
5 number of conductors primary, number of joint users,  
6 where the pole broke, and a host of other pieces of  
7 information.

8 The teams comprise of an engineer that is a  
9 Progress Energy employee, and the intent there is to put  
10 the right resource in the right place. There is not a  
11 better resource that understands how our design  
12 characteristics nor our components, so they will  
13 definitely understand whether the pole is actually  
14 leaning or has broken and, in essence, what caused the  
15 break from a perspective of attachers, tree debris, et  
16 cetera.

17 The other individual on these teams is a meter  
18 reading representative. Again, the right resource being  
19 the fact that we have a representative who knows the  
20 area and is very familiar with the area and can meander  
21 throughout the county or the area in the event that  
22 there are obstacles in the way such as a fallen tree.  
23 They can find an alternate route very quickly.

24 The areas that they will do some forensic  
25 analysis or conduct a forensic analysis consists of

1 certainly the path of the storm, whether it's the  
2 eyewall of the hurricane, or the direction and the  
3 impact of a tornado and the path that the tornado took.  
4 They will generally get in those areas and look for  
5 downed poles and damaged poles.

6           There is another component that these teams  
7 will look at, though, and that is our storm hardening  
8 projects that we have completed since 2007. We are  
9 asking these forensic analysis teams to identify these  
10 particular projects, access those particular projects,  
11 rather, and identify any type of performance issues with  
12 regards to these projects resulting from the impact of  
13 the storm.

14           Unfortunately or fortunately, however you want  
15 to look at it, we have not had a major storm impact our  
16 service territory to really see how our storm hardening  
17 projects have performed, and that is a good thing, I  
18 guess, and we will see as time goes on if we do have  
19 some storm impacts and how our projects have withstood.

20           The next initiative -- and by the way, from a  
21 challenges perspective on forensic analysis, we do not  
22 see any type of issues or concerns with regard to  
23 meeting this obligation and this initiative.

24           Coordination with local governments. Progress  
25 Energy takes pride in the fact that we try to

1 collaborate as best we can with our local governments.  
2 We have a 70-member team that is in place throughout our  
3 service organization that meets with all the local  
4 governments to talk about our hurricane and storm  
5 preparedness prior to, during, and after the impact of a  
6 major storm. With regards to challenges with this  
7 initiative, we see no issues or concerns with continuing  
8 and meeting this obligation.

9           From an overhead and underground reliability  
10 initiative, Progress Energy Florida collects a  
11 tremendous amount of data to review the percentage  
12 impact -- or outages, rather -- I should say a  
13 percentage of outages as a result of the storm impact to  
14 both our underground as well as our overhead  
15 distribution systems. There are three -- basically  
16 three systems that we look at. One is our outage  
17 management system that basically tells us how our  
18 facilities are connected to each other; the customer  
19 service system, which pretty much tells us which  
20 customers are tied to which transformer. The view  
21 behind that is that our outage management system is able  
22 to, when we get customer calls, identify the upstream  
23 device that is most likely the device that has tripped  
24 as a result of the outage or the fault. And finally,  
25 our GIS, our geographic information system is utilized



1 to check all the data points of our infrastructure on  
2 our distribution system. From a challenges perspective,  
3 we see no challenges in continuing this initiative.

4 The collaborative research initiative.

5 Progress Energy is continuing our efforts to work with  
6 the academic community from a collaborative perspective.  
7 We have sponsorship with regards to the University of  
8 Florida's Public Utility Research Center, otherwise  
9 known as PURC. We have members on the team that work  
10 with the initiatives.

11 The PURC team members have looked at and  
12 researched as mentioned in the previous presentation.  
13 Some of those certainly include the fact that there is a  
14 modeling system with regards to undergrounding that is  
15 still on-going to see the benefits and the costs  
16 associated with that. There is also, as was mentioned  
17 previously, a wind monitoring initiative that was  
18 completed, and there is a host of wind monitors  
19 throughout the state that we have access to so we can  
20 identify what the wind speeds are when a major event  
21 occurs, whether it's a tornado or a hurricane. We can  
22 then see how our infrastructure has withstood those  
23 amounts of winds, those significant winds, which we  
24 haven't had in the past. We really had no idea what  
25 wind level had some type of impact on our distribution

1 facilities. Now we do.

2 Two other issues with regard to collaborative  
3 research include the forensic analysis. We improved  
4 that process and try to maintain some consistency  
5 throughout the organization and other utilities. And  
6 the other is certainly vegetation management. As far as  
7 a challenge, we see no challenge with this initiative.  
8 We feel very comfortable and appreciate the opportunity  
9 to serve on this team.

10 From a hurricane preparedness perspective,  
11 Progress Energy prides itself in being prepared for  
12 hurricanes. We have a storm plan that's in place. We  
13 have an annual drill that occurs regularly. This year,  
14 as a matter of fact, we had the distribution drill on  
15 April 22nd. We also had a transmission storm  
16 preparedness drill that occurred on May 19th.

17 Some of the things that go into our  
18 preparedness include the fact that we stage materials or  
19 talk with our material vendors to make sure we have  
20 materials on-site or available in the event of an impact  
21 of a major storm event. We discuss with fuel vendors to  
22 make sure we have enough fuel for our fleet. We also  
23 actually during the off season meet with vendors and  
24 contractors to help train them in our damage assessment  
25 philosophy so that when we do have an impact that we can

1 leverage these individuals and they are familiar with  
2 our processes on conducting the pole-to-pole patrols and  
3 what devices they need to look for.

4 From a resource perspective, we have certainly  
5 engaged in the regional municipal -- I can't remember  
6 what that name is. Excuse me. The regional mutual  
7 assistance organizations where we make sure that we have  
8 negotiated relationships with other organizations so  
9 that if we are impacted they will send crews to our  
10 service territory, and likewise in the same situation.  
11 With regards to challenges with the hurricane  
12 preparedness, we see no concerns and we expect to  
13 continue maintaining our preparedness on the hurricane  
14 initiative.

15 For the next two initiatives, I will turn it  
16 over to Charlene Rubano.

17 **MS. RUBANO:** Good morning. Our PEF  
18 transmission system is inspected every year by two  
19 methods. We have area patrols where we will patrol  
20 approximately two times a year our circuits. The other  
21 method that we use is ground line inspections, and that  
22 is we will patrol approximately one-third to one-fifth  
23 of our transmission circuits every year by ground line  
24 inspections. These ground line inspections are looking  
25 for deficiencies in the structures and the assets that

1 are on the structures, such as insulators. These ground  
2 line patrols will collect the data of these deficiencies  
3 and categorize the amount of deficiencies into levels  
4 two through five, and we will prioritize based on those  
5 results to have those replaced within the year and  
6 within subsequent years.

7 Also, transmission structures are hardened  
8 through a few methods. Through our ground line  
9 inspections, when we realize that poles need to be  
10 replaced from those ground line inspections we will  
11 replace wood poles with either steel or concrete poles,  
12 and they are prioritized based on the highest need of  
13 deficiency in any given year.

14 The second method for hardening our existing  
15 structures would be through customer or DOT type  
16 requests where we would rebuild those lines and move  
17 those lines, and we would build those structures to our  
18 existing standards, which either meet or exceed the NESC  
19 code.

20 The third way that we harden our transmission  
21 structures are through our planning projects, which will  
22 be either rebuilds or new circuits. And, again, those  
23 will be constructed to meet or exceed our NESC  
24 guidelines. And then anytime we relocate, or we  
25 rebuild, or build new, we are building to steel or

1 concrete structures. So those are our two methods in  
2 transmission in the ten-point plan that we are  
3 existingly doing.

4 The challenges that we -- we don't really see  
5 any challenges for either of those other than any  
6 resource constraints or schedule changes from the  
7 customer requests, or any resource issues, we may need  
8 to change our schedule based on some of those resource  
9 issues.

10 Next we will talk about some similarities and  
11 some differences in our 2010 plan from our 2007 plan,  
12 and I will start with the transmission hardening  
13 philosophy, and then Eric will go into the rest of the  
14 distribution philosophy. The transmission hardening  
15 philosophy has not changed since our 2007 plan. We are  
16 still looking to inspect our transmission structures and  
17 change our wood pole structures as needed to steel or  
18 concrete poles to harden that system. We are also  
19 utilizing the relocation requests, and our planning  
20 projects with the rebuilds and our new projects to build  
21 to our existing NESC standards, whether they meet or  
22 exceed those standards, and we will utilize concrete and  
23 steel structures for those philosophies. So that  
24 particular philosophy has not changed for our 2010 plan.

25 And next I'll let Eric talk about

1 distribution.

2 **MR. SACHON:** With regards to our 2010 plan,  
3 there are many, many similarities to the 2007 plan. I'm  
4 just going to highlight a couple of similarities. And  
5 the first one I would like to say is that we have not  
6 changed or deviated from our philosophy on construction  
7 standards. They are the same as the '07 plan, so  
8 nothing has changed in regard to our construction  
9 philosophy.

10 The other issue is we utilized in 2007 the  
11 Davies Consulting incorporation prioritization model.  
12 We will continue to utilize that prioritization model,  
13 as well, in the 2010 plan.

14 With regards to variations to the plan, three  
15 main situations, three main areas that we have changed.  
16 From the prioritization model that I just mentioned from  
17 Davies Consulting, we actually will be utilizing that  
18 prioritization model, but we have enhanced and improved  
19 that utilizing or adding additional criteria to help us  
20 prioritize our projects.

21 From a geomeia perspective, we are utilizing  
22 geomeia in the plan this year to help us identify where  
23 our distribution areas are prone to flooding and surge.  
24 This is going to help us prioritize as well as identify  
25 areas for our submersible projects. And, finally,

1 another hardening alternative that we have actually  
2 implemented into the plan is feeder ties. Although we  
3 know that feeder ties will not mitigate outages, we do  
4 know that part of outages that customers are frustrated  
5 with is the duration that they are out for. And feeder  
6 ties will provide us with another opportunity to  
7 reconnect some of our customers in a much more expedient  
8 manner of time. Those are the main variations of the  
9 plan.

10 **MS. RUBANO:** We are next going to talk about  
11 restoration and hardening efforts that are existing  
12 today. Again, I will talk about transmission briefly  
13 and then Eric will finish up. The transmission  
14 hardening plan has not changed since our 2007 plan. We  
15 are continuing to prioritize based on needs and  
16 deficiencies that we see in our system and also our  
17 planning needs and customer requests.

18 Our main difference that we saw in our 2007  
19 plan to now is our spending has increased in our  
20 hardening effort on the transmission side mainly due to  
21 the number of projects and the number of requests that  
22 are from the DOT projects, customer request projects,  
23 and also from our planning projects. We did not  
24 anticipate that kind of increase when we filed in 2007,  
25 and our actual spending in 2008 and 2009 were higher due

1 to that number of projects. And next I'll let Eric  
2 finish.

3 **MR. SACHON:** A continuous focus on  
4 restoration. We have implemented several changes this  
5 year with regards to our efforts on restoring power and  
6 changing our philosophies on how we respond and restore  
7 power to our customers. One of those situations  
8 involves our trouble men (phonetic). We recognized very  
9 quickly that most of our outages are occurring during  
10 the week day not the weekends. We did have and we  
11 continue to have trouble men working during the  
12 weekends, but we have changed those schedules on some of  
13 those trouble men to stay on more of a week-day shift  
14 rather than weekend shift. This is going to provide a  
15 greater response rate to our customers that are  
16 sustaining outages during the week day, which is, again,  
17 where we see most of our outages occurring, as well as  
18 provide the restoration needs improving the customer  
19 satisfaction.

20 The second area that we worked on or focused  
21 on restoration involved our new service crews. We  
22 typically have had a crew work five eight-hour days  
23 during the week. We have changed that schedule. Not in  
24 all of our regions, but in most our regions we have  
25 changed that schedule to a four ten-hour day. This



1 helps with addressing appointments later on in the day  
2 improving customer satisfaction and helping to reduce  
3 costs.

4           The last one deals with our call-out process,  
5 our call-out procedure. Typically, when an outage  
6 occurs in the past what we have done is had the  
7 distribution control center dispatcher contact our  
8 trouble men to access the site, identify the issue, and  
9 then if other resources were needed, call in the other  
10 resources. We recognize that in some of the larger  
11 impacted outages where we had a high degree of customers  
12 impacted that routinely we were calling out another unit  
13 to help in the restoration efforts. So in light of that  
14 fact we decided that with high customer impact outages  
15 we are not only going to dispatch the trouble men, we  
16 are also going to dispatch a two-person crew to the  
17 scene at the same time. This is going to help, again,  
18 with response rate as well as restoration improving  
19 customer satisfaction.

20           The other focus is a reliability engagement  
21 model. We just initiated that this year. What that  
22 involves is in the past we have had staff really review  
23 outages from a system perspective to see trends and  
24 issues of repairs and recommendations on how to mitigate  
25 these outages. What we have done with this reliability

1 engagement model is actually put more eyes on these  
2 outages. And we focused in three areas. The first area  
3 is high customer minutes of interpretation impact,  
4 otherwise known as CMI impacts. The second area  
5 involved customers that were out of power for at least  
6 three hours or more. And the third one involved, again,  
7 high impact customers where we had outages that had a  
8 large number of customers go out at the same time.

9           What we are doing with that now is it is not  
10 just a system staff engineer perspective where they are  
11 looking at it, we are having eyes from the operation  
12 center personnel, DOMs, distribution operation managers.  
13 We have incorporated an outage champion at each of the  
14 op centers to review these. All of these outages that I  
15 mentioned in the three different areas are looked at and  
16 viewed on a daily basis by all of these different  
17 entities. The intent there is more eyes on these  
18 outages will help to address these concerns, issues, and  
19 projects that are needed to mitigate and resolve these  
20 outages.

21           From a targeted hardening perspective, we  
22 still continue to focus our hardening efforts on the  
23 reliability side of the fence. Since 2007, we have  
24 completed 48 storm hardening projects. In the 2010 plan  
25 we have proposed 61 -- I should say we have identified

1 and proposed 61 projects then to be done over the next  
2 three years from a hardening perspective, as well.

3 That concludes our presentation, so I will  
4 open it up for questions.

5 **MS. L'AMOREAUX:** Thank you very much.

6 Just a few questions. Can you please briefly  
7 explain why PEF has not adopted extreme wind standards  
8 for all distribution construction, including critical  
9 infrastructure?

10 **MR. SACHON:** Yes, absolutely. It is our  
11 belief and experience from the '04 and '05 hurricanes  
12 that distribution facilities generally are damaged not  
13 as a result of wind, but more as a result of flying  
14 debris, trees, et cetera. The installation of extreme  
15 wind loading facilities would not alleviate that  
16 situation. If a tree is going to fall on that pole,  
17 that pole is coming down. So we felt from that  
18 perspective that really what we would be doing if we  
19 went to that level of extreme wind loading on the  
20 distribution system would be complicating our  
21 restoration practice even more so from the perspective  
22 of that we were having -- we would have to be now not  
23 only staging material for our normal construction, but  
24 we are also having to stage material for wind loading  
25 facilities. So, again, we do not feel from our

1 experience as well as industry experts we have contacted  
2 that on the distribution system extreme wind loading is  
3 of benefit to our customers.

4 Other issues that we have seen is the  
5 situation where extreme wind loading requires larger  
6 sized poles, and that is going to cause some issues with  
7 customers in particular in the more urban areas where  
8 the span lengths are not quite as long, and so you may  
9 have several poles that are very close together. And  
10 these are larger-sized poles, it becomes an aesthetic  
11 problem for some customers as we have recognized in some  
12 of our storm hardening efforts. So that generally is  
13 the reason why we've decided not to go to an extreme  
14 wind loading philosophy on the distribution system. We  
15 do have that on the transmission system, though.

16 **MS. L'AMOREAUX:** My next question you touched  
17 on it a little bit about the feeder ties, but can you  
18 please discuss the use of feeder ties as a hardening  
19 alternative and why PEF believes this concept is  
20 beneficial and cost-effective?

21 **MR. SACHON:** A great question. You know, we  
22 know that outages are going to occur when a major storm  
23 impacts our service territory. It's a foregone  
24 conclusion. We also know that we have facilities that  
25 are called radials. Basically, they are not tied to any

1 other feeders. When the radial goes out, literally that  
2 feeder and those customers are out of power until we are  
3 able to repair that radial. Feeder ties gives us a  
4 contingency that we did not have in the past,  
5 particularly on radials, but it also provides a greater  
6 contingency effort for those feeders that are looped.  
7 And what I mean by that is if a feeder were to go out  
8 and we have identified the fault, very quickly we can do  
9 some switching and we can refeed the tail end of that  
10 feeder from another feeder if we have the feeder tie.

11 And that is why we feel -- again, we know that  
12 it is not going to mitigate the outage, that is not the  
13 intent, but we also know that duration is a concern of  
14 our customers, and this will certainly reduce  
15 considerably the duration those customers would have  
16 been out had we not had the feeder ties.

17 **MS. L'AMOREAUX:** This question is kind of for  
18 everybody, but since no named hurricanes have affected  
19 Florida since 2005, discuss how PEF -- discuss PEF has  
20 any evidence in hardening efforts and has it enhanced  
21 its service quality? Do you want me to restate?

22 **MR. SACHON:** Could you please restate.

23 **MS. L'AMOREAUX:** Sorry. Yes. Since no named  
24 hurricanes have affected Florida since 2005, does PEF  
25 have any evidence of hardening efforts and has it

1 enhanced its service quality?

2 **MR. SACHON:** I wish I could say that we do  
3 have evidence, unfortunately we have not had situations  
4 to impact our service territory to actually look at the  
5 performance of our storm hardening projects since 2007.  
6 So, unfortunately, I do not have an answer to give you  
7 other than we're waiting on the impact of an event and  
8 then we will monitor and identify the performance of  
9 those projects.

10 **MS. L'AMOREAUX:** That's all the questions I  
11 have.

12 **MR. SACHON:** Thank you.

13 **MS. L'AMOREAUX:** Next up is Tampa Electric,  
14 T.J. He told me not to say his last name.

15 **MR. SZELISTOWSKI:** Thank you.

16 T.J. Szelistowski -- and T.J. works great -- I  
17 am the Director of Engineering for Tampa Electric  
18 Company in the Energy Delivery Department, and I'm happy  
19 this morning to share with you Tampa Electric's storm  
20 hardening update, our 2010 plan.

21 As requested of the company, I'm going to  
22 cover a number of things. The status of the ten-point  
23 initiatives and our on-going efforts there; our  
24 three-year storm hardening plan in two parts. I'll  
25 touch on the 2007 to 2009 plan as well as the 2010 to

1 '12 plan and the differences between those; and then  
2 touch also on the improvements to the overall system  
3 based on those hardening efforts.

4 A key part of Tampa Electric's hardening  
5 effort in the ten-point plan as well as in our hardening  
6 effort overall is our vegetation management. We have  
7 made a significant investment in vegetation management.  
8 Tampa Electric Company has a three-year vegetation  
9 management plan both on the feeders, on the main feeder  
10 lines as well as on the laterals.

11 We started in the 2007 plan. As we put that  
12 forth we said we would be transitioning to a three-year  
13 plan. This year we are on track to complete one-third  
14 of our system, both feeders and laterals together, and  
15 we have over 225 tree-trimming resources on site working  
16 toward that end. In addition, we have reactive trimmers  
17 that when we have either customer complaints or specific  
18 construction projects that require tree trimming, we  
19 also apply tree trimmers to those areas, as well.

20 We continue to work with local governments in  
21 terms of vegetation management, tree planting guides,  
22 address concerns from local governments in terms of  
23 trees. Tree trimming is kind of a two-edged sword. On  
24 the one hand it certainly helps with your liability, on  
25 the other hand from an aesthetic standpoint in some

1 areas, park areas, those type of things, there's a lot  
2 of customer concerns with trimming, especially getting  
3 adequate tree trim clearances. The aesthetics involved  
4 with that sometimes are a challenge. And so we continue  
5 to work with our local governments to make sure that we  
6 are balancing that.

7 Another part of the ten-point initiatives  
8 involves a joint use attachment audit. We completed  
9 that, our last one in 2008. We have a commitment to do  
10 that at least every eight years, and our next one will  
11 be starting in 2011 or 2012, so we will be doing it  
12 before the eight-year cycle, but we do have that coming  
13 up in the near future.

14 In the meantime whenever we have as part of  
15 our pole inspection program as we have joint users on  
16 poles, we do a comprehensive loading analysis on those  
17 poles to ensure that we don't have undue stresses on the  
18 poles due to joint attachers as we go through that  
19 inspection process.

20 Transmission inspections is another point of  
21 the ten-point plan initiatives. Specifically, the six  
22 year inspection comprehensive inspection cycle we do  
23 generally by helicopter. We have in the past done a  
24 climbing inspection, but generally by helicopter and do  
25 a comprehensive inspection, one-sixth of the system



1 every year. And, in addition, we, of course, have the  
2 eight year ground line inspection cycle for transmission  
3 and distribution. And we also every year do two things  
4 on the transmission system. We do an infrared patrol by  
5 helicopter where we identify any unnatural heating of  
6 connection elements. In addition to that we have a  
7 ground patrol once a year on the entire transmission  
8 system.

9 In terms of transmission hardening, Tampa  
10 Electric Company since the early 1990s has installed  
11 non-wood poles for all transmission. They are either  
12 concrete or steel. We continue to do that as part of  
13 our ten-point initiatives and overall hardening. We  
14 use, again, generally concrete or steel, but either --  
15 both in new construction as well as maintenance  
16 change-outs we replace poles and add new poles for  
17 transmission.

18 GIS. Tampa Electric Company accepted its GIS  
19 program officially from the vendor in the fall of 2009.  
20 And so we do have the GIS system implemented as was part  
21 of the ten-point plan initiatives. We continue to work  
22 with that program to make sure it is as efficient and  
23 user friendly as possible with our system and with our  
24 designers.

25 Post-storm data collection forensics, another

1 name for the same thing. We have a contract in place.  
2 We have not had to use it yet, but we have a contract in  
3 place with a vendor to come in after the storm, after  
4 any hurricane or large storm effects Tampa Electric's  
5 service territory and do the storm data collection and  
6 forensic analysis on the structures. In addition, we  
7 are set up so that we can do outage data collection for  
8 overhead versus underground after a major storm event.

9 Increased coordination with local government.  
10 We have always had strong relationships with the local  
11 governments. We have continued to increase that  
12 coordination since the 2004/2005 hurricanes, and we have  
13 a number of events every year that we hold with local  
14 governments, both storm related and nonstorm related,  
15 including mock storm events, exercises, that type thing  
16 to make sure that we are working closely and in  
17 conjunction with the local government.

18 Collaborative research. PURC was mentioned  
19 several times. We have been involved with that  
20 throughout the last three years and we will continue to  
21 be involved, both on the underground to overhead or  
22 overhead versus underground tool that was developed as  
23 well as the vegetation management.

24 And the disaster preparedness plan. We have  
25 exercised that plan this year. Every year we revisit it

1 and come up with lessons learned and improve that plan  
2 every year. And we have done that and are well prepared  
3 for storm season for this year.

4 In a nutshell, we are on track in all the  
5 areas with the ten-point storm initiatives. We believe  
6 that those ten points have improved our overall system  
7 both for storms as well as for every day operation.

8 I will go now into the three-year storm  
9 hardening plan, 2007 plan versus the 2010 plan. And I  
10 will talk about, again, some specifics in those plans as  
11 well as the status of where we are and what we have  
12 coming for the 2010/2012 plan.

13 Both plans, the plans are very similar in  
14 their design. They focus in three distinct areas,  
15 construction standards, the deployment strategy, as well  
16 as attachment standards and procedures, and I will talk  
17 about each of those. Under distribution design, Tampa  
18 Electric Company since the early '70s has built to Grade  
19 B construction, National Electric Safety Code, Grade B.  
20 Generally, distribution facilities are required to be  
21 built to Grade C, which is a lesser standard, or not as  
22 strong a standard as Grade B. There are certain  
23 distribution facilities that do require a Grade B, but  
24 Tampa Electric Company designs and constructs all of its  
25 distribution to the higher standard, to Grade B

1 construction.

2 In addition, we have gone to stainless steel  
3 construction on our underground switched gear and  
4 transformers, and that is a slight change from our 2007  
5 plan. In the 2007 plan the switchgear was stainless  
6 steel as well as the outside of the transformers, but we  
7 have now gone to a stainless steel tank, as well, and  
8 that is something new for us.

9 On the transmission side, I mentioned that our  
10 standard is non-wood construction for all installations,  
11 both replacement as well as new construction. That  
12 includes maintenance replacement as well as road  
13 widenings, and then, of course, new construction.

14 We use extreme wind for all the transmission.  
15 In addition, transmission construction at Tampa Electric  
16 for our 230kV, which is our backbone, we go to an even  
17 higher standard. The extreme wind in Tampa, the extreme  
18 National Electrical Safety Code extreme wind would  
19 require anywhere between 110 and 120-mile per hour wind  
20 speed design depending on how far you are from the  
21 water. And the first point is we use the 120-mile per  
22 hour wind across the entire service territory, so we  
23 use -- we err on the side of the higher wind speed. In  
24 addition to that, for all of our bulk 230 transmission,  
25 we design all of that at 133-mile per hour design wind

1 speed.

2 Getting now into the deployment strategy a  
3 little bit. Vegetation management I mentioned. Again,  
4 we are very proud and a significant part of our  
5 hardening commitment is in our vegetation management  
6 with the three-year both on the laterals as well as the  
7 feeders. And, again, in 2010, we believe we are on  
8 track to get to one-third of our system in terms of that  
9 vegetation management.

10 Inspection and maintenance. Certainly we will  
11 continue with that. I mentioned the transmission  
12 inspection before, and, of course, we have the eight  
13 year distribution inspection cycle on the ground line  
14 and we will continue that.

15 We did 12 overhead-to-underground conversions  
16 of crossings. These are interstate crossings in the  
17 Tampa area along major evacuation routes, and we have  
18 completed the undergrounding of all of those, all of  
19 those 12 that were in the original 2007 plan.

20 We have several extreme wind pilot hardening  
21 projects. Tampa Electric Company identified several  
22 critical facilities, one of which is St. Joseph's  
23 Hospital, I'll talk about that in a minute, the Port of  
24 Tampa, and then another project that we have involving  
25 Tampa International Airport, and I'll go into detail

1 about all three of those.

2 St. Joseph's Hospital is a Level II trauma  
3 center in Tampa. We rebuilt the feed to that to an  
4 extreme wind feed. The distribution feed to that  
5 involved a number of transmission poles that we changed  
6 to non-wood structures as well as quite a few  
7 distribution poles, again, to bring that up to extreme  
8 wind design. We completed that in 2008.

9 The Port of Tampa hardening was divided into  
10 three phases. The Port of Tampa is a critical port to  
11 Florida. Approximately 40 percent of the gasoline for  
12 the state comes in through that facility, so it is very  
13 critical to the state after a hurricane. A lot of times  
14 lack of fuel is a big hindrance in terms of restoration  
15 efforts from the community standpoint. We completed the  
16 first phase in 2008, where we rebuilt some transmission  
17 to non-wood where we had distribution lines underneath  
18 the transmission conductors, and changed out a number of  
19 distribution poles, as well.

20 There are actually three circuits in that area  
21 that serve the port, and so those were the three phases.  
22 We completed the first phase in 2008 and the second  
23 phase in 2009. We replaced quite a few transmission  
24 poles and distribution poles again to bring that up to  
25 extreme wind. And we are in the process now for Phase

1 3. We will complete that by the end of this year. It  
2 says transmission poles. There are also 30 or so  
3 distribution poles that would be replaced, as well. And  
4 again, this project will bring the distribution that  
5 feeds that Port of Tampa area up to extreme wind design.

6 Tampa International Airport. This was in our  
7 2007 to 2009 plan, and I've got some diagrams here to go  
8 through, but the original plan was to harden the source  
9 to the airport. And we've talked to the airport  
10 facility and our planners and we came up with what we  
11 think is a much improved plan, and that is what we have  
12 embarked on, so I will talk about that a little bit.

13 This picture, a real basic schematic of the  
14 way Tampa International Airport is fed. It's fed out of  
15 a substation that is not dedicated specifically to the  
16 airport. It serves some other load in the area. And  
17 the dashed line is really -- it represents  
18 six distribution circuits that feed the airport. The  
19 lines to the left on this diagram show the transmission  
20 lines that are brought into that substation. The bold  
21 line is the line that in our original plan we were going  
22 to rebuild with non-wood structures. These are older  
23 lines. And as we looked at that design, while there are  
24 multiple transmission feeds to that substation, we did  
25 have some concern that we were feeding the airport --

1 continuing to feed the airport with this design out of  
2 the same substation and that gave us some concern.

3 So the next slide is actually the improved  
4 design. What we have done is we have added three  
5 distribution, underground distribution feeds from a  
6 second substation. We have left the ones in from the  
7 west, but, in addition -- and this was an existing  
8 substation, but we have added -- we are adding a second  
9 transformer at the new substation, or at the second  
10 substation, and in addition are building a new line into  
11 that substation.

12 What this does for us is you can see pretty  
13 plainly on the diagram is it provides us duplicate  
14 service to the airport so we can feed the entire airport  
15 from either direction. A much improved design, and we  
16 are in the process of finishing that now. We have done  
17 the distribution work and are in the process of doing  
18 the substation transmission work before the end of this  
19 year.

20 Attachment standards and procedures, part of  
21 our hardening. We have a very good relationship with  
22 our joint use attachers. We have a good process for  
23 having them make us aware of requests to attach to our  
24 poles. We have improved the relationship with those  
25 folks, I believe, over the last three years. And I know



1 that overlashing has been an issue after 2004 and 2005.  
2 We had 1,000 instances of overlashing requests being  
3 made to the company, and so we believe the communication  
4 is good between the joint users and Tampa Electric  
5 Company, and we continue the good relationship there.

6 As we have requests for attachments to our  
7 poles, we have an electronic means of communication back  
8 and forth for the permitting process as well as the  
9 communication if they want to attach additional  
10 facilities on a pole. Now, in some cases, depending on  
11 the structures, they can attach without any changes. In  
12 some cases there is make ready that needs to be done.  
13 Poles need to be changed out or strengthened, and that's  
14 all part of our process. And, again, that works very  
15 well for us, and we are pleased with that.

16 Joint use attachment audits. I mentioned  
17 before there is a commitment for once every eight years.  
18 Our last one was in 2008. There is something on the  
19 horizon that gives a little bit of caution and concern  
20 at Tampa Electric Company in terms of joint use. The  
21 FCC broadband plan you may be familiar with has a  
22 potential with the rulemaking to allow what is called  
23 boxing and bracketing, which is essentially putting more  
24 joint use attachments in the same space on either side  
25 of the pole or out on cross-arms. And we have some

1 concern with that for a number of reasons, one of which  
2 is storm restoration. We are talking about hardening  
3 today. Storm restoration is you add facilities on both  
4 sides of the structure; it makes replacing that  
5 structure when they go down much more difficult. We  
6 have some real concerns and we will be happy to share  
7 more of our concerns with the staff at a later date.  
8 But, again, our relationship with our joint users is  
9 very good and we continue to work with them on  
10 attachments.

11 This next chart -- the next two charts,  
12 actually, show the 2007 and 2009 plan and the difference  
13 between that plan and the 2010 plan. The first one  
14 shows the things that -- the one-time projects that we  
15 have completed, or the status of those projects from the  
16 first plan. The 12 interstate crossings I mentioned.  
17 Conversion of 4 kV system we did in the last three  
18 years. We converted the last of Tampa Electric's 4 kV  
19 distribution system to 13 kV. Our system, our  
20 distribution system is 13 kV, and that allows us to have  
21 backup supplies and backup material, so we no longer  
22 have any 4 kV distribution on our system.

23 St. Joseph's Hospital. Source hardening I  
24 mentioned. That's complete. Two of the three phases of  
25 the Port of Tampa are complete. The third one will be

1 complete by the end of this year.

2           This is one thing I didn't mention. We talked  
3 about the joint research with PURC. Now we are doing  
4 some stuff on our own, as well. We have installed 26  
5 breakaway service connectors as a test. The service  
6 connector -- our service line is the line from the pole,  
7 the transformer to the individual residence, and  
8 sometimes after a hurricane you will have a limb or  
9 something that will fall on that service connector that  
10 will pull away the mast from the house. And what  
11 happens is even though we may be ready to put power back  
12 to the house, because of damage to that facility the  
13 customer can't receive power, and that is ultimately  
14 what we are trying to do. And so we have tested, we  
15 have put in 26 of these breakaway connectors as a test  
16 that will essentially -- there is a force fitting that  
17 give way and pull the wire away from itself rather than  
18 pull the mast away from the house. And we are testing  
19 those to see how they work under normal summer storm  
20 conditions as well as if we have a hurricane to see if  
21 we have those in place if that avoids that breakage of  
22 that mast or that damage to the home.

23           And the last item on here, the improved plan  
24 for the Tampa International Airport, again, will be  
25 completed this year. And then the host of things that

1 we are going to continue on. I have talked about the  
2 Grade B construction for our distribution. Extreme wind  
3 for transmission, both for maintenance as well as new  
4 construction. The same for the above extreme wind case  
5 for the 230 kV; our non-wood construction for  
6 transmission and special maintenance programs; our  
7 vegetation management as well as our attachment  
8 standards and procedures.

9 Overall, you all had asked what we see in  
10 terms of improvements with this hardening effort, and we  
11 believe that with the commitment we have made on the  
12 transmission system, we have a strong transmission  
13 system. It performed very well in the hurricanes of  
14 2004 and 2005; and, again, we are going to continue our  
15 efforts there. We have hardened sources to some  
16 critical facilities, and while those haven't been tested  
17 it really will take some wind to see if those really do  
18 hold up better or if the wind-borne debris really is the  
19 governing issue with the distribution.

20 And our system in terms of tree trimming, and  
21 that is one that we do see some everyday improvement to.  
22 You know, before and after the trim of a circuit, we see  
23 significant difference in the reliability of that  
24 circuit. So while we are spending significant dollars  
25 on our tree trimming and a significant investment there,

1 it's not just the benefit that we see with a hurricane.  
2 We also see some day-to-day benefit for our customers.

3 In summary, we are going to continue with the  
4 ten-point plan initiatives as I have outlined. We are  
5 going to implement the 2010 plan, assuming approval from  
6 the Commission, and we believe that will result in  
7 improved system performance not only after a storm, but  
8 during normal operations. So we ask that you consider  
9 the plan for approval.

10 With that, I'll be happy to answer any  
11 questions.

12 **MS. L'AMOREAUX:** I just have one question for  
13 you. In the updated plan, TECO states that the company  
14 will conduct audits on all pole attachments on an  
15 eight-year cycle. In addition, the company states that  
16 it reserves the right to complete this audit on an  
17 annual basis. Under what circumstances would TECO  
18 choose to do an audit on an annual basis?

19 **MR. SZELISTOWSKI:** I don't expect for us to do  
20 something on an annual basis. It's a pretty big effort,  
21 and generally the attachments that go up on an annual  
22 basis, if we are being communicated with well, there is  
23 really not a reason to do it on an annual basis. You do  
24 an audit to find things that have been put up that  
25 you -- because you are inspecting the same system,

1 obviously. So if you are doing things -- you're doing  
2 that to find things that have been put up without your  
3 knowledge.

4 And so to do that every year is probably too  
5 much. If we have instances where we have seen a lot of  
6 attachments going up that we weren't informed about,  
7 then we might move it up. But, again, at this point we  
8 feel that every four or five years is adequate.

9 **MS. L'AMOREAUX:** Thank you.

10 **MR. SZELISTOWSKI:** Sure.

11 **MS. L'AMOREAUX:** Next we have Gulf Power  
12 Company, Ed Battaglia.

13 **MR. BATTAGLIA:** Good morning. My name is Ed  
14 Battaglia, and I'm the Technical Services Manager for  
15 Gulf Power, and I'll be presenting Gulf's storm  
16 hardening plan. And we have brought a few added folks  
17 as far as technical support to help with any questions  
18 that staff may have. And, also, please excuse me if I  
19 have to clear my throat a little bit every once in  
20 awhile; I'm trying to get over a little bit of a cold.

21 Gulf Power's updated storm hardening plan  
22 reflects Gulf's commitment to continuous improvement by  
23 building on its experiences, by learning from data  
24 collected each year of the plan's implementation, and by  
25 research that addresses the potential benefits of

1 initiatives. Gulf recognizes the need to address the  
2 concerns expressed by both its customers and the Florida  
3 Public Service Commission to find ways to storm harden  
4 its system which could lead to less frequent outages and  
5 improved continuity of service during major  
6 storm-related events. At the same time, Gulf is  
7 obligated to balance storm hardening with the need to  
8 maintain reasonable costs and still achieve the expected  
9 results.

10 In these first two slides, I will brief  
11 discuss the ten on-going initiatives. Gulf's vegetation  
12 management plan consists of a three-year main feeder  
13 trim cycle, a six-year lateral trim cycle, and a program  
14 for removing hazard trees outside the normally trimmed  
15 zone. In addition, Gulf performs an annual pre-storm  
16 season inspection and corrective action program on the  
17 remaining two-thirds of mainline feeders.

18 In respect to joint use attachment audits,  
19 Gulf Power has in its current joint use contract  
20 agreements to conduct a field audit of the joint use  
21 poles every five years. The last audit was in 2006 with  
22 the next one scheduled for 2011. A pole strength load  
23 assessment pilot program was initiated by Gulf in 2007  
24 based on the 2006 joint use field audit survey.

25 Inspection cycle of transmission structures

1 and storm hardening activities for transmission  
2 structures. Gulf Power's transmission inspection plans  
3 meet or exceed the approved six-year inspection cycle.  
4 Gulf completed the replacement of 774 wood crossarms and  
5 storm guyed 700 structures at an annual estimated cost  
6 of \$600,000 as part of the company's approved storm  
7 hardening plan.

8           Geographic information systems, or GIS. Gulf  
9 Power's transmission and distribution data essential for  
10 its asset management programs and forensic data analysis  
11 have been mapped into its GIS application as part of the  
12 company's approved storm hardening plan.

13           Post-storm data collection and forensic  
14 activities. Gulf worked with industry vendors, such as  
15 OSMOSE, Incorporated, and KEMA, Incorporated, to develop  
16 and establish a post-storm forensic process for the  
17 company. It has been successfully tested and refresher  
18 training completed.

19           Outage data differentiating between overhead  
20 and underground systems. Gulf Power developed a process  
21 and made needed programming changes to its trouble call  
22 management system to establish a means to collect this  
23 added data. We continue to collect this outage data as  
24 events occur.

25           Coordination with local governments. Gulf



1 Power representatives are assigned to county Emergency  
2 Operations Centers, EOCs, in northwest Florida. They  
3 assist city and county agencies and officials during  
4 emergencies that warrant activation of the county EOCs.  
5 Gulf Power will provide on-going communications,  
6 pre-storm communications, and post-storm communications  
7 through our corporate communications department.

8 Collaborative research. Gulf Power  
9 participated in collaborative efforts to conduct  
10 research and development on the effects of major  
11 hurricanes on the electrical systems throughout the  
12 state of Florida.

13 Disaster preparedness and recovery plans.  
14 Gulf Power uses the plans described in its storm  
15 recovery plan to respond to any natural disaster that  
16 may occur within its service area. As part of its  
17 annual operations, Gulf conducts yearly storm drills and  
18 continues to refine its planning and preparations for  
19 the possibility of a natural disaster within Gulf  
20 Power's service area. All of these ten initiatives are  
21 on target.

22 In the next few slides I compare Gulf's  
23 approved plan versus the updated plan. Whenever you see  
24 any kind of red font, that indicates that initiative was  
25 changed. Gulf's current vegetation management plan

1 consists of a three-year main feeder trim cycle, a  
2 six-year lateral trim cycle, and a program for removing  
3 hazard trees outside the normally trimmed zone.

4 Analysis of data shows that 65 percent of  
5 Gulf's related mainline outages are now being caused by  
6 the failure of large overhanging limbs. Based on this  
7 analysis of data, Gulf proposes placing greater emphasis  
8 on overhanging limb removal on mainline feeders in  
9 conjunction with a continued danger tree removal during  
10 its annual mainline inspection. Gulf will continue with  
11 its three-year cycle on mainline feeders.

12 Gulf found that establishing a trim back  
13 distance, which will provide six years of clearance to  
14 be extremely difficult. Also, danger tree removal in  
15 residential areas served by laterals has proven to be  
16 very challenging. Customer acceptance of these  
17 practices has not been positive. In response to this  
18 data, Gulf proposes to shorten the trim cycle length on  
19 lateral lines to four years and reduce emphasis on  
20 lateral danger tree removal.

21 Joint use attachment audits. Gulf Power has  
22 in its current joint use contract agreements to conduct  
23 a field audit of the joint use poles every five years.  
24 And, again, the last audit was in 2006 with the next one  
25 scheduled for 2011. Gulf Power recommended and received

1 approval from the Commission for a random sampling for  
2 pole strength load assessment on five percent or  
3 approximately 500 joint use poles. Gulf initiated this  
4 strength load assessment pilot program in 2007. Again,  
5 based on the analysis of data, the low failure rates,  
6 and the fact that all new construction and maintenance  
7 work are constructed to Grade B construction, which Gulf  
8 is transitioning to, Gulf proposes to discontinue the  
9 random pole strength pilot project activity for the  
10 updated storm hardening plan. This continuation of the  
11 pole strength pilot project will save approximately  
12 100,000 over the 2010/2012 time frame.

13 There are no proposed changes with the next  
14 three initiatives, inspection cycle of transmission  
15 structures, storm hardening activities for transmission  
16 structures, and with our GIS system.

17 With these next five initiatives, again, Gulf  
18 is not proposing any changes as far as data collection,  
19 outage data differentiating between overhead and  
20 underground, our coordination with local governments,  
21 collaborative research, and the disaster preparedness  
22 and recovery plans.

23 Gulf plans to continue its pole inspection  
24 program on an eight-year cycle utilizing the same  
25 inspection matrix approved by the Commission in 2007

1 with one minor exception. As a result of the findings  
2 during the past three years, Gulf plans to discontinue  
3 the one percent sample of nonexcavated CCA poles that  
4 are less than 15 years old. Gulf performed full  
5 excavation and treatment on 954 CCA poles that initially  
6 passed the visual inspection. None of the excavated  
7 poles were rejected, and only minor decay was noted on  
8 some of these poles. This sample clearly indicated that  
9 Gulf's inspection matrix is effective in assuring that  
10 no defective poles remain in service.

11 Since this program adds costs without  
12 providing additional benefits, Gulf proposes to  
13 discontinue the one percent sample program for the  
14 updated storm hardening plan. This will result in an  
15 estimated annual savings of approximately \$7,500. Gulf  
16 will continue all other elements of the current wood  
17 pole inspection program, which has been so successful  
18 over the past three years.

19 Compliance with National Electric Safety Code,  
20 NESC. Gulf Power's transmission system, substations,  
21 and distribution system are designed to meet the  
22 National Electric Safety Code. In respect to  
23 distribution, exceeds the NESC with Gulf's transition to  
24 Grade B construction on all new construction, major  
25 projects, and maintenance work. There are no proposed

1 changes in this initiative.

2 Extreme wind loading standards. Gulf's  
3 approved storm-hardening plan exceeded the National  
4 Electric Safety Code by transitioning to Grade B  
5 construction on distribution construction. Gulf Power  
6 plans to continue this transition to Grade B  
7 construction standards on all new construction, major  
8 projects, and maintenance work.

9 As part of its approved storm hardening plan,  
10 Gulf also constructed extreme wind loading pilot  
11 projects for distribution facilities serving critical  
12 infrastructures such as hospitals, fuel depots, sewage  
13 treatment plants, and major roadway crossings. Gulf  
14 proposes to change its approach by expanding its Grade B  
15 initiative to target critical pole lines with multiple  
16 feeders on them and convert them to Grade B  
17 construction.

18 In addition, the existing wood poles will be  
19 replaced with concrete poles from the substations to  
20 strategic operational points on the feeders. This  
21 initiative is taking design concepts which we know work  
22 well in the transmission and substation areas and  
23 carries them to the distribution side. Gulf has  
24 budgeted approximately \$2.3 million for this initiative  
25 over the three-year period covered by the plan.

1 There are no changes to the next two initiatives,  
2 mitigation of damage to underground facilities and  
3 supporting T&D facilities due to flooding and storm  
4 surges, and the placement of new and replacement  
5 distribution facilities to facilitate access.

6 Other key elements. Gulf proposes no changes  
7 to the feeder patrols and infrared patrols which are  
8 completed annually prior to June 1st. In respect to  
9 wind monitors, Gulf completed the installation of 19  
10 wind monitors as outlined in the approved storm  
11 hardening plan and will maintain those wind stations as  
12 part of the updated storm hardening plan. The wind  
13 speed data gathered from these monitors, along with the  
14 forensic data gathered after a major storm event, will  
15 help determine the effectiveness of the storm hardening  
16 initiatives, such as the Grade B construction and the  
17 pilot programs where we constructed facilities to the  
18 extreme wind loading standards.

19 Additional proposed storm hardening  
20 initiatives, conversion of 4 kV distribution. Gulf  
21 proposes to convert its remaining three 4 kV  
22 distribution feeders to its standard 12.47 kV  
23 distribution voltage. These conversions will reduce  
24 potential outages and facilitate improved restoration  
25 times by converting to Gulf's standard specifications

1 and materials which will be more readily available after  
2 a major storm. In addition, the added clearance  
3 requirements and increased insulation levels for 12.47  
4 kV will reduce potential outage causes.

5 Also, any needed pole replacements as a result  
6 of the conversion would be built to the stronger Grade B  
7 conversion, which would help to accelerate Gulf's  
8 transition to Grade B construction. Gulf plans to  
9 convert one feeder per year at an approximately average  
10 cost of \$300,000.

11 Distribution automation. Gulf proposes to  
12 install reclosers or automated switches at approximately  
13 the midway point on distribution feeders. Additional  
14 switches would be deployed on long or critical feeders  
15 to further segment the feeder for outage restoration.  
16 These devices which protect downstream from temporary  
17 faults will be controlled remotely by Gulf's  
18 distribution control center personnel and/or placed in  
19 an automated restoration scheme. Gulf's estimated cost  
20 per year to implement this is \$2 million.

21 Strategic installation of automated fault  
22 circuit indicators, or FCIs. These are devices designed  
23 to provide a visual indication of an outage if it  
24 occurred beyond their location. They will help to  
25 expedite the location of outage causes and the isolation

1 of the problem so that service can be restored to some  
2 customers while the problem is being corrected.  
3 Initially, Gulf proposed to install FCIs at 20 locations  
4 on its system. The estimated annual cost is  
5 approximately \$20,000.

6 Development of a distribution supervisory  
7 control and data acquisition system, or DSCADA system.  
8 In order to reduce storm restoration times, Gulf  
9 proposes to develop and to begin implementation of the  
10 systems and application that would permit the monitoring  
11 and remote control of the distribution automation  
12 devices that I mentioned earlier. The estimated annual  
13 cost of this activity is \$217,000.

14 This chart shows Gulf's estimated cost for the  
15 updated storm hardening plan versus the estimated cost  
16 for the approved plan and actual cost of the approved  
17 plan. As you can see, Gulf is proposing to increase its  
18 commitment to storm hardening its system. Gulf's  
19 updated plan makes adjustments based on lessons learned  
20 from the approved plan and expands the number of  
21 initiatives which we feel will improve the reliability  
22 of its system and increase its storm resistance.

23 This map illustrates Gulf's service areas, and  
24 I know it is a little difficult to see as far as on the  
25 screen there, and it indicates locations of projects



1 completed in the approved plan. And we also went ahead  
2 and plotted projects proposed in the updated plan.  
3 Gulf's initiatives and projects are dispersed across its  
4 system so that in the event of a major storm there will  
5 be opportunities to test how well the various storm  
6 hardening options perform.

7 In respect to struggles or challenges to  
8 achieving the ten initiatives, the uncertainty related  
9 to material and labor is one. With most utilities  
10 focusing on the same issues, the availability of the  
11 needed materials and skilled labor is a concern. And,  
12 of course, in the event of a major storm, it could  
13 reduce the availability of needed resources creating  
14 work delays in implementing the plan.

15 Another struggle is with city ordinances,  
16 existing ones, and possibly expanded city ordinances.  
17 They impact the possible effectiveness of some of the  
18 initiatives and impact work schedules. An example of  
19 this would be, say, the trimming and removal of trees.  
20 Power restoration and hardening is improving overall on  
21 Gulf's system. For Gulf, the initiatives such as  
22 extreme wind loading and Grade B construction, those are  
23 pilot projects in the sense that based on Gulf's  
24 experience and knowledge over many years of storm  
25 restoration activities, that what we have seen that it

1 predominately is not the pure wind, it's the debris  
2 carried on the wind that causes the outage problems. So  
3 for Gulf in an analysis of actual storm data collected  
4 over time, it is essential to try to determine their  
5 benefits. And, of course, and I'll say fortunately Gulf  
6 has not experienced any major storms to test these  
7 initiatives. And this may address the question that you  
8 were putting out there as far as for all utilities.

9 In respect to Gulf's vegetation management  
10 plan, Gulf is seeing reduced customer interruptions and  
11 reduced customer minutes of interruption due to tree  
12 outages when you focus on that one particular  
13 initiative. So, again, we feel that is an improvement.  
14 And as we stated, we are looking to try to make more  
15 gains by reducing our lateral trim cycle from six to  
16 four years.

17 T&D inspections. The initiatives involving  
18 T&D inspections, which that includes the patrols as far  
19 as digital patrols, the infrared patrols that I  
20 mentioned earlier as far as other key elements where we  
21 do those before the start of storm season. The six-year  
22 transmission inspection and eight-year distribution wood  
23 pole inspection, all of those contribute to possible  
24 outages by being proactive in the maintenance of Gulf's  
25 T&D systems, so we feel those are real positives.

1 And that concludes my presentation. Are there any  
2 questions?

3 **MS. L'AMOREAUX:** I have a couple of questions.  
4 A couple of them you have already answered, so that is  
5 kind of good. In the updated plan, and as you spoke in  
6 your presentation, you have specific changes to your  
7 trim cycle. What experience has Gulf encountered that  
8 has led to these changes?

9 **MR. BATTAGLIA:** Predominately as far as our  
10 experience there for changing from the six to four year  
11 lateral is the dramatic increase in what we're having to  
12 do in spot tickets to trim those areas, which is  
13 indicating clearly to us that the current cycle is not  
14 adequate. So the number of those tickets that have  
15 dramatically risen has driven us to say we need to do  
16 something else there. And then also the amount of  
17 clearance, as I mentioned earlier, as far that is needed  
18 on a six-year versus a four-year cycle, and the other  
19 element was the removal of danger trees on laterals. As  
20 far as the amount of customer resistance to those type  
21 of activities, we basically said to improve our plan we  
22 needed to shorten that cycle.

23 **MS. L'AMOREAUX:** And can you briefly discuss  
24 how Gulf's new storm hardening initiatives are  
25 beneficial and cost-effective?

1           **MR. BATTAGLIA:** Well, predominately overall,  
2 as I mentioned earlier on that last slide, you know, to  
3 determine the actual benefits of the initiatives such at  
4 Grade B construction, the extreme wind loading projects,  
5 those types of initiatives that are our high cost as far  
6 as needing forensic analysis of that after a major storm  
7 to try to determine if there are benefits there. But  
8 there are elements of the plan, such as the inspections  
9 that I mentioned, such as vegetation management, and  
10 with the added elements of the plan that we're proposing  
11 such as the 4 kV conversion, the distribution  
12 automation, the SCADA system that we feel will achieve  
13 as far as what our expectations for storm hardening,  
14 expediting restoration of service, but at the same time  
15 add what we feel is a better cost/benefit ratio for our  
16 customers.

17           **MS. L'AMOREAUX:** That's all the questions I  
18 have. Thank you.

19           **MR. BATTAGLIA:** Thank you.

20           **MS. L'AMOREAUX:** Next up is Florida Public  
21 Utilities Company, Mr. Puentes.

22           **MR. PUENTES:** Good morning, staff. My name is  
23 Jorge Puentes. I'm the Northeast Division Electric  
24 Operations Manager. I would also like to acknowledge  
25 the presence of Mark Cutshaw, who is our Northeast

1 General Manager, as well as Buddy Shelley, who is the  
2 Northwest General Manager.

3 We appreciate the opportunity to come and  
4 participate in the workshop, but before I give you the  
5 status update on our storm hardening plan and give you  
6 the highlights, the differences between what was  
7 approved and what has been updated, I would just like to  
8 give you a brief overview of our company.

9 We are a very small investor-owned utility.  
10 As of October of 2009, we are a wholly-owned subsidiary  
11 of Chesapeake Utilities. Our electric customer base is  
12 only 28,000 customers and our territory is small. We  
13 have about 15 in the northeast division, which is a  
14 coastal territory, and 13,000 of them are in northwest  
15 Florida, which is more of a rural territory.

16 Now, as I pass on to provide you the status  
17 update on our storm hardening initiatives, I'd like to  
18 start with the vegetation management. I'd like to also  
19 note that during the 2008 rate case there was a change  
20 to our original 2007 plan in this area where we agreed  
21 to implement the three-year cycle of tree trimming for  
22 feeders and the six-year cycle for laterals. Initially,  
23 we were planning to do this with seven crews and at the  
24 end we agreed to do it with five crews. We continue to  
25 be on target with this initiative. Since 2008 and up to

1 2009, we have removed about 530 danger trees, and also  
2 we have trimmed in both divisions a total of 119 miles  
3 of feeders and about 100, almost 200 miles of laterals.  
4 And up to this year we have trimmed about 34 miles of  
5 feeders and seven miles of laterals. That's up to the  
6 end of May.

7 In terms of the joint use pole attachment  
8 audit, since 2008 and 2009, we have identified our  
9 contractor, working with our contractor we have  
10 identified about 53 poles having third-party attachments  
11 that had some loading issues. And what we plan to do  
12 with those is do further analysis by using software. We  
13 have Pole-Foreman, and after we obtain the results we  
14 will then work with our current agreements and try to  
15 let them know what attachments will have to be moved and  
16 we will make those facilities more strengthened.

17 In terms of the other initiative, number  
18 three, of transmission inspections, we are doing this on  
19 a six-year basis. We have performed in 2008 and 2009  
20 visual inspections, but the plan is to begin climbing  
21 inspections from this year on.

22 In terms of the GIS information system, in  
23 2008 we were able to install that in the northwest  
24 division, and in 2009 we had that implemented in the  
25 northeast division. The northwest division has a little

1 bit more improvement because they have SCADA  
2 capabilities, and we're looking to see if we can  
3 implement SCADA in the northeast division. But it's a  
4 very useful tool that we use also for outage management,  
5 and we're using it to report now our yearly performance  
6 indicators using that software now.

7 In this other initiative about the  
8 transmission storm hardening, I also would like to make  
9 a note that during the 2000 rate case there was a change  
10 from our original 2007 plan where we were proposing to  
11 replace about 190 wood poles on our 69 kV system, and we  
12 were planning to do this over a 15-year period. At the  
13 end, in 2008, we agreed to change that to a -- to change  
14 25 of those poles on a ten-year cycle, more or less  
15 going and changing about 2.5 poles per year. We have  
16 accelerated this by changing several poles. For  
17 example, in 2009 we completed a project along our  
18 coastal area where we replaced 14 69 kV wood poles with  
19 spun concrete. This year we also changed another  
20 additional three wood poles with concrete, spun concrete  
21 poles in another project. We did these two projects  
22 using the extreme wind loading criteria, which we are  
23 applying to the northeast division to be 130 miles per  
24 hour, and for the northwest division we are implementing  
25 120 miles per hour.

1           We also applied this criteria to the  
2 distribution facilities that are critical to our  
3 customers. For example, the hospitals, the highways  
4 along major -- feeders along major highways, and also  
5 feeders to sewer plants and other facilities.

6           In terms of the post-storm data collection  
7 forensics, we have established a procedure, and we plan  
8 to use a contractor. However, we haven't had as much --  
9 as other companies have reported, we haven't had  
10 experience with hurricanes since the 2005 period, but  
11 once we have some information on this we will report it  
12 to the Commission.

13           Going on with our storm hardening initiatives,  
14 by using our outage management system we are able to  
15 also comply by providing the overhead and underground  
16 system information. We're providing that on a yearly  
17 basis.

18           We also like to coordinate very closely with  
19 our EOCs. We attend all their meetings. We also  
20 provide safety training to them. We have a program  
21 where we go and explain to them the hazards of wires  
22 down and what they should do in cases like that when  
23 their crews, their tree-removing crews, or construction  
24 crews are close to them. We also participate in any of  
25 their events.



1           We work closely with them on vegetation, and  
2 we have a good understanding of what they also need from  
3 us, because we also are going to provide some personnel  
4 like never before in terms of when hurricanes happen  
5 they will be over there located, and they will be able  
6 to inform them of what's going on with our utility in  
7 terms of outages.

8           In terms of the collaborative research, we are  
9 active in that area. We attend their workshops, and we  
10 support their initiatives and research. We have been  
11 active in the tree trimming, underground, and wind  
12 loading areas.

13           In terms of the disaster preparedness and  
14 recovery, we have developed plans. We update these  
15 annually, and we review them with our employees, and we  
16 have training with them so that everyone knows what they  
17 are supposed to do in case we have an emergency. We  
18 ensure that material for storms is available and it is  
19 reviewed. We review our trucks, our radio communication  
20 equipment, and we ensure the readiness of all personnel.

21           As we contrast the approved plan versus the  
22 updated plan, there is one major change that we are  
23 proposing for your approval. This has to do in terms of  
24 the wood pole inspections. Currently we are doing  
25 detail -- we are doing detailed inspections about

1 one-eighth of them on an eight-year cycle. We have used  
2 OSMOSE as our contractor, and since then we have  
3 inspected about 5,815 poles.

4 And during this period of inspections between  
5 2008 and 2009, we were able to uncover some evidence  
6 that allowed us to make this proposal, and this has to  
7 do with detailed inspections for CCA, less detailed  
8 inspections for CCA poles. What we found is that out of  
9 nearly half, about 2,625 CCA poles that were inspected,  
10 none of them had failures. And the ages of those poles  
11 inspected were between one year and 28 years, and that  
12 is outlined in our plan.

13 And we are saying that based on these new  
14 facts we would like to propose to do a less detailed  
15 inspection for CCA poles under 16 years of age. And in  
16 an effort to be consistent with what other IOUs are  
17 doing, we would like to augment the inspections by  
18 one percent of CCA poles not requiring a detailed  
19 inspection.

20 To summarize what our plan has been  
21 accomplishing as we continue to implement this plan, at  
22 this point we have not found any issues in achieving  
23 these ten initiatives. In terms of the budgeting or the  
24 costs, we continue to monitor those costs, and at this  
25 point those costs that are monitoring have been

1 estimated and they were included in that 2008 rate case  
2 proceeding. And in terms of some of your questions that  
3 if we believe that this plan hardens the infrastructure,  
4 we believe it does. Certainly we believe that we will  
5 see benefits. Again, I can say that we haven't had any  
6 storms hitting our -- major storms hitting our  
7 territory, but we believe that it does create a stronger  
8 system.

9 That concludes my presentation, and I'd like  
10 to ask you if you have any questions.

11 **MS. L'AMOREAUX:** I just have one question.

12 **MR. PUENTES:** Yes.

13 **MS. L'AMOREAUX:** Can you explain why there is  
14 a shortage of tree trimming crews in your area?

15 **MR. PUENTES:** A shortage of tree trimming  
16 crews meaning --

17 **MS. L'AMOREAUX:** In your amended updated plan  
18 you said that current tree trimming crews, there was a  
19 shortage of them, and if and when they become available  
20 you will work to trim trees.

21 **MR. PUENTES:** I think that was mainly in the  
22 first plan -- and correct me, Mark, if I'm not -- in the  
23 first plan we wrote that, but I think in the updated  
24 plan, or after the 2008 rate case, we came to an  
25 agreement that we would do this three-year cycle on

1 feeders and six-year cycle on laterals with five  
2 tree-trimming crews, and since then we haven't had that  
3 shortage.

4 **MS. L'AMOREAUX:** I'll check into that.

5 **MR. PUENTES:** Sure.

6 **MS. L'AMOREAUX:** Do you have any questions,  
7 Dave? Lisa?

8 All right. Well, if there's no more  
9 questions --

10 **MR. PUENTES:** Thank you.

11 **MS. L'AMOREAUX:** Oh, thank you.

12 **MR. PUENTES:** Thank you very much.

13 **MS. L'AMOREAUX:** I would first like to thank  
14 everybody here today, especially the presenters for  
15 giving very informative presentations. Staff is still  
16 reviewing the updated storm hardening plans, and after  
17 which we will be sending maybe one or more rounds of  
18 discovery. Our target is to bring a recommendation to  
19 agenda probably around August, no later than September.

20 In addition, if the parties want to submit any  
21 post-workshop comments, we ask that you submit those by  
22 June 28th, 2010. And with that, this workshop is  
23 adjourned. Thank you.

24 (The workshop concluded at 11:29 a.m.)

25

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

STATE OF FLORIDA        )  
                                  :  
                                  )  
COUNTY OF LEON        )

I, JANE FAUROT, RPR, Chief, Hearing Reporter Services Section, FPSC Division of Commission Clerk, do hereby certify that the foregoing proceeding was heard at the time and place herein stated.

IT IS FURTHER CERTIFIED that I stenographically reported the said proceedings; that the same has been transcribed under my direct supervision; and that this transcript constitutes a true transcription of my notes of said proceedings.

I FURTHER CERTIFY that I am not a relative, employee, attorney or counsel of any of the parties, nor am I a relative or employee of any of the parties' attorney or counsel connected with the action, nor am I financially interested in the action.

DATED THIS 24th day of June, 2010.

  
\_\_\_\_\_  
JANE FAUROT, RPR  
Official FPSC Hearings Reporter  
(850) 413-6732



# FPSC Storm Hardening Workshop

June 10, 2010

Parties/Staff Handout  
on 6/10/10

## 10 Storm Preparedness Initiatives

- **Initiative No. 1 – Vegetation Management**
  - Feeders on 3-year average cycle
  - Laterals on schedule to achieve 6-year average cycle by 2013
  - Tree removals/“Right Tree Right Place”
- **Initiative No. 2 – Joint Use**
  - 5-year cycle for joint use/attachment surveys
  - Pole strength / loading inspections
- **Initiative No. 3 – Transmission Inspections**
  - 6-year cycle for lines, substations and structures
- **Initiative No. 4 – Transmission Hardening**
  - Replacing wood structures
  - Replacing ceramic post insulators (concrete poles)
- **Initiative No. 5 – Distribution GIS**
  - Joint use, hardening, pole inspection & streetlight data added



## 10 Storm Preparedness Initiatives

- **Initiative No. 6 – Post-Storm Forensics**
  - Teams, data collection process and database established
- **Initiative No. 7 – OH vs. UG Storm Performance Data**
  - Using laterals to evaluate OH vs. UG performance
- **Initiative No. 8 – Increased Government Coordination**
  - EOCs staffed / critical infrastructure identified
  - Community Outreach Teams
  - Enhanced e-mail process & governmental update website
- **Initiative No. 9 – Collaborative Research**
  - Continued efforts with PURC
- **Initiative No. 10 – Natural Disaster Prep/Recovery Plan**
  - Reviewed/updated annually
- **CONTINUING WITH PREVIOUSLY APPROVED PLANS, ALL INITIATIVES IN COMPLIANCE AND ON TARGET**



## FPL's 2010-2012 Hardening Plan

- **Continuation of Previously-approved Plan**

- **3-prong approach:**

- (1) Apply EWL to existing CIF

- (2) Apply Incremental Hardening to “Community Projects”

- (3) Apply Design Guidelines utilizing EWL for all new overhead facilities, major planned work, relocation projects as well as daily work activities

- **Apply EWL / Incremental Hardening Over 3 Wind Regions:**

- 105 mph / 105 mph (north)

- 130 mph / 115 mph (central)

- 145 mph / 125 mph (south)

## FPL's 2010-2012 Hardening Plan

- **2007–2009 Hardening Results:**
  - Hardened to EWL: 227 feeders (over 500 miles) serving 266 CIF customers; 103 highway crossings; and 192 “01 switches”
  - Applied Incremental Hardening to 68 feeders (approx. 180 miles) serving community needs
  - Applied EWL to all new construction, major planned work, relocations and daily work
  - Total costs for 2007-2009 (EWL/Incremental Hardening) - \$162M

## FPL's 2010-2012 Hardening Plan

- **Hardening Plans for 2010-2012:**
  - 2010
    - Apply EWL to 39 feeders serving 52 CIF customers, 16 highway crossings and 20 01 switches
    - Apply Incremental Hardening to 5 feeders serving community needs
    - Apply design guidelines to all new construction
  - 2011 and 2012
    - Harden 40-55 feeders annually
  - Total 2010-2012 costs (EWL/Incremental Hardening) - \$135M-165M

## FPL's 2010-2012 Hardening Plan

### ▪ **Attaching Entities**

- Provided filing to all 93 attaching entities in March 2010 – 8 entities contacted FPL – no issues
- Complying with “Process to Engage 3rd Party Attachments” (provides hardening plan details for the upcoming year)
- Hold meetings prior to design & construction of all hardening projects



## FPL's 2010-2012 Hardening Plan


### ▪ **Benefits of Hardening**

- In the absence of significant new data, continue to rely on:
  - (1) 2004-2005 storms experience
  - (2) KEMA report
  - (3) performance of transmission poles (built to EWL) vs. distribution poles during Hurricane Wilma
  - (4) Davies Consulting analysis - FPL's poles (Grade B) performed better than other electric companies (Grade C)
- Reduction in number/duration of outages, storm/non-storm
- Reduction in restoration costs, storm/non-storm
- Restoration Costs Savings per mile of hardened feeder - estimated to be approximately 45%-70% of the cost to harden that mile of feeder
- FPL's plan is cost-effective - focuses on CIF / Community Projects

**Progress Energy Florida**

Florida Public Service Commission  
Storm Hardening Workshop

Thursday, June 10, 2010



---

---

---

---

---


---

---

---

**Outline**

- Hardening Strategy
- Ten Point Plan
- 2010-2012 Storm Hardening Plan
- Reliability Focus
- Questions & Answers



---

---

---

---

---

---

---

---

**Hardening Strategy**



---

---

---

---

---

---

---


---


Parties/Staff Handout  
on 6/10/10



**Restoration and Hardening**

- Transmission hardening
- Continuous focus on restoration
- Reliability Engagement Model
- Targeted Hardening
  - 48 Projects completed since 2007
  - 61 proposed for next 3 years



 **Progress Energy**

---

---

---

---


---


---

---

---

**Questions & Answers**



 **Progress Energy**

---

---

---

---

---

---

---

---



33:52

# Progress Energy Florida

---

## Florida Public Service Commission Storm Hardening Workshop

Thursday , June 10, 2010

Parties/Staff Handout  
on 6/10/10




# Outline

---

- Hardening Strategy
- Ten Point Plan
- 2010-2012 Storm Hardening Plan
- Reliability Focus
- Questions & Answers

# Hardening Strategy

---



# Ten Point Plan

---

- Vegetation Management
- Joint Use Survey
- GIS upgrade
- Forensic Analysis
- Coordination With Local Governments
- OH/UG Reliability
- Collaborative Research
- Hurricane Preparedness
- Transmission Inspections
- Hardening of Transmission structures

# Storm Hardening Plan - Similarities


- Transmission Hardening philosophy
- Systematic and analytical approach
- Prioritization model





# Storm Hardening Plan - Variations

- Improved and enhanced prioritization model
- Geo Media
- Hardening alternatives




# Restoration and Hardening

- Transmission hardening
- Continuous focus on restoration
- Reliability Engagement Model
- Targeted Hardening
  - 48 Projects completed since 2007
  - 61 proposed for next 3 years



# Questions & Answers

---





# Tampa Electric Storm Hardening Update

**T.J. Szelistowski, P.E.**  
**Director, Energy Delivery**  
**June 10, 2010**

Parties Staff Handout  
on 6/10/10



# Storm Hardening Update

- Ten Point Storm Initiatives
- Three-Year Storm Hardening Plan
  - 2007-2009 and 2010-2012
  - Improvements to Overall System

# Ten Point Plan Initiatives

## ■ Vegetation Management

- Three-Year Vegetation Management Plan
- Feeder and Laterals



# Vegetation Management

- Transition to Three-Year Plan
  - 2010: One-Third of System
- Reactive Trimming
- Over 225 Tree Trimmers
- Work with Local Governments

# Ten Point Plan Initiatives

- Joint Use Pole Attachment Audit
  - Completed in 2008
  - Minimum of Every Eight Years
  - Comprehensive Loading Analysis

# Ten Point Plan Initiatives

## ■ Transmission Inspections

- One, Six and Eight Year Cycles

## ■ Transmission Hardening

- New Construction and Maintenance

# Ten Point Plan Initiatives

- GIS
- Post-Storm Data Collection
- Outage Data for Overhead and Underground

# Ten Point Plan Initiatives

- Increased Coordination with Local Governments
- Collaborative Research
- Disaster Preparedness Plan



# Ten Point Storm Initiatives Summary

- On Track in All Areas
- Improvements to Overall System

# Storm Hardening Update

- Three-Year Storm Hardening Plan
  - 2007-2009 Plan
  - 2010-2012 Plan

# Three-Year Storm Hardening Plans

- Construction Standards
- Deployment Strategy
- Attachment Standards and Procedures

# Construction Standards

- Distribution Design
  - NESC Grade B Construction
  - Underground: Stainless Steel

# Construction Standards

- Transmission Design
  - Non-Wood Construction
  - Extreme Wind for All Transmission
  - Even Stronger for all 230 kV
    - 133 mph design

# Deployment Strategy

- Vegetation Management
- Inspection and Maintenance
- OH – UG Conversion of Crossings

# Deployment Strategy

- Extreme Wind Pilot Hardening Projects
  - Saint Joseph's Hospital
  - Port of Tampa
- Tampa International Airport

# St. Joseph's Hospital

- Level Two Trauma Center
- Rebuilt Feed – Now Extreme Wind
  - Six Transmission Poles
  - Thirty-Seven Distribution Poles
- Completed in 2008



# Port of Tampa Hardening


## ■ Three Phases

- Phase I: Rebuilt One Mile Trans and 48 Dist Poles (2008)
- Phase II: Replaced 41 Trans Poles and 30 Dist Poles (2009)
- Phase III: Replace 17 Trans Poles (2010)


# Deployment Strategy

- Tampa International Airport
  - Original plan was to harden source to airport
  - Improved plan provides 2<sup>nd</sup> hardened source

# Tampa International Airport Original Design



# Tampa International Airport Improved Design



# Attachment Standards and Procedures

- Access to Poles
- Make Ready
- Joint Use Attachment Audits

# Plan Comparison

2007-2009 Plan Item	2010 – 2012 Update
Twelve Interstate Crossings Converted to UG	Complete
Conversion of 4 kV System	Complete
St. Joseph Hospital Source Hardening	Complete
Port of Tampa Phase I Hardening	Complete
Port of Tampa Phase II Hardening	Complete
Port of Tampa Phase III Hardening	To be Completed in 2010
Breakaway Service Connector Test Installation	Complete
Tampa International Airport	Improved Plan – to be completed in 2010

# Plan Comparison

2007-2009 Plan Item	2010 – 2012 Update
Grade B Construction Standard	Continue
Extreme Wind for Transmission	Continue
Extreme Wind + for 230 kV	Continue
Non-Wood Construction for Transmission	Continue
Inspection and Maintenance	Continue
Vegetation Management	Continue
Attachment Standards/Procedures	Continue

# Improvements to Overall System

- Strong Transmission System
- Hardened Sources to Critical Facilities
- Trimmed System – ready for storms



# Summary

- Continue Ten Point Plan Initiatives
- Implement 2010 Hardening Plan
- Results: Improved System Performance – Storms and Normal Operations

Questions?



*PRIDE IN THE SYSTEM*

**Gulf Power Company**  
**June 10, 2010**  
**Storm Hardening Workshop**



Parties/Staff Handout

on 6/10/10



# The Ten Initiatives Overview

*PRIDE IN THE SYSTEM*

- Vegetation Management Plan
  - Three-year trim cycle on main line feeders
  - Six-year trim cycle on laterals
  - Danger Tree Removal
  
- Joint-Use Attachment Audits
  
- Inspection Cycle of Transmission Structures
  
- Storm Hardening Activities for Transmission Structures
  
- Geographic Information Systems



# The Ten Initiatives Overview

## *PRIDE IN THE SYSTEM*

- Post-Storm data Collection and Forensic activities
- Outage Data Differentiating Between Overhead and Underground Systems
- Coordination with Local Governments
- Collaborative Research
- Disaster Preparedness and Recovery Plans

# Approved Plan vs. Updated plan

## *PRIDE IN THE SYSTEM*

- Vegetation Management Plan
  - Three-year trim cycle on main line feeders
  - Six-year trim cycle on laterals - **Changing to Four-year cycle**
  - Danger tree Removal – **Reduce emphasis in residential areas**
  
- Joint-Use Attachment Audits – **Discontinue third party strength analysis**
  
- Inspection Cycle of Transmission Structures
  
- Storm Hardening Activities for Transmission Structures
  
- Geographic Information Systems

# Approved Plan vs. Updated plan

*PRIDE IN THE SYSTEM*

- Post-Storm data Collection and Forensic activities
- Outage Data Differentiating Between Overhead and Underground Systems
- Coordination with Local Governments
- Collaborative Research
- Disaster Preparedness and Recovery Plans



# Approved Plan vs. Updated plan

*PRIDE IN THE SYSTEM*

- Eight-year Wood Pole Inspection process
  - 1% Sample of Non-excavated CCA poles program –  
**Discontinue**
- Compliance with National Electric Safety Code (NESC)
- **Extreme Wind Loading Standards**
- Mitigation of Damage to Underground Facilities and supporting T&D facilities due to flooding and storm surges
- Placement of new and replacement distribution facilities to facilitate access



# Approved Plan vs. Updated plan

*PRIDE IN THE SYSTEM*

- Other Key Elements
  - Feeder patrols
  - Infrared patrols
  - Wind Monitors
  - Additional Proposed Storm Hardening Initiatives
    - Conversion of 4kV Distribution Feeders
    - Distribution Automation
    - Strategic Installation of automated Fault Circuit Indicators
    - Development of a Distribution Supervisory Control and Data Acquisition System (DSCADA)

# Approved Plan Costs vs. Updated Plan Costs


*PRIDE IN THE SYSTEM*

Approved Plan	2007	2008	2009	Total Cost	Cost per Customer per Year
Estimated Costs	\$19,218,504	\$20,106,312	\$20,345,837	\$59,670,653	\$46
Actual Costs	\$26,633,997	\$26,334,845	\$35,814,695	\$88,783,537	\$71
Updated Plan	2010	2011	2012	Total Cost	Cost per Customer per Year
Estimated Costs	\$35,814,695	\$35,455,157	\$36,332,586	\$107,602,438	\$84






# GULF POWER DISTRICT SERVICE AREAS



**Legend**

- Extreme Wind Loading Standards Specified by the NESC
- Major Roads
  - County Road
  - State Road
  - U.S. Road
  - Interstate
- Cities and Towns
- Counties
- Service Area Districts
  - WESTERN
  - CENTRAL
  - EASTERN

- ★ Denotes Completed 2007-2008 Overhead Extreme Wind Loading Projects and Grade B Construction
- ★ Denotes Completed 2007-2008 Underground Pilot Projects
- ★ Denotes Proposed 2010-2012 Underground Projects
- ★ Denotes Major Proposed 2010-2012 Overhead Grade B Construction Projects



# Struggles Towards Achieving the Ten Initiatives

*PRIDE IN THE SYSTEM*

- Uncertainty related to material and labor
- City ordinances



# How Restoration and Hardening is Improving Overall System

*PRIDE IN THE SYSTEM*

- Analysis of actual storm data collected over time is needed to determine benefits
  
- Vegetation Management Plan
  - Reduced tree-related outages
  
- T & D Inspections

*PRIDE IN THE SYSTEM*

**QUESTIONS?**



# 2010 Storm Hardening Workshop

## Florida Public Utilities Company

Jorge Puentes

Electric Operations Manager – Northeast Division

June 10, 2010



Parties Staff Handout

on 6/10/10






# Florida Public Utilities Company Description

- Small Investor Owned Electric Utility
- Approximately 28,000 Customers
- Small Service Territory
  - Northeast Florida Division - Amelia Island and Fernandina Beach
  - Northwest Florida Division – Parts of Jackson, Calhoun and Liberty Counties




# Status - Storm Hardening Initiatives

- Vegetation Management – Ongoing implementation of the 3/6 year cycle. 
- Joint-use Pole Attachment Audit – Current agreements to be used. Pole loading issues identified.
- Transmission Inspections (6 year cycle) - Visual Inspections Completed in 2008 and 2009. Climbing Inspections in accordance with Storm Plan to begin during 2010.

# Status - Storm Hardening Initiatives

- GIS and Outage Management - Northeast Florida Division
- GIS, Outage Management, and SCADA - Northwest Florida Division



# Status - Storm Hardening Initiatives

- Transmission Storm Hardening - Several projects completed.



- Post Storm Data Collection & Forensics - Procedure established and plan to use a contractor.



# Status - Storm Hardening Initiatives

- Outage Data for OH and UG Systems – Collection and reporting has been implemented.
- Coordination with Local Governments – Proactive participation with local EOC's.
- Collaborative Research – Active involvement with PURC.



# Status - Storm Hardening Initiatives

- Disaster Preparedness and Recovery – Plans were developed and implemented.





# Plans' Contrast - Approved vs. Updated

- Wood Pole Inspections:
  - Currently doing detailed inspections of all poles (1/8 per year) since 2008.
  - During 2008 and 2009 Inspections - Evidence to support a less detailed inspection of CCA poles was obtained:
    - No failures of 2,625 CCA poles inspected.
    - Age range was from 1 to 28 years old.



# Plans' Contrast - Approved vs. Updated

- Wood Pole Inspections (continued...):
  - Based on new facts:
    - FPUC proposes to perform a less detailed inspection for CCA poles under 16 years of age and...
    - Augment detailed inspections by 1% of CCA poles not requiring a detailed inspection.
  - Consistent with other IOUs.



# Summary

- Currently, as FPUC diligently continues to implement its Storm Hardening Plan:
  - Has not found any issues in achieving the 10 initiatives.
  - Continues to monitor cost impacts - Estimated cost of initiatives were included in 2008 rate proceeding.
  - Believes that implementation of this plan will improve the strength of the overall system.





QUESTIONS ??