BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

DOCKET NO. 120015-EI FLORIDA POWER & LIGHT COMPANY

IN RE: PETITION FOR RATE INCREASE BY FLORIDA POWER & LIGHT COMPANY

COM	5
APA	1
ECR	10
GCL	1
RAD	1
SRC	1
ADM	
OPC	
CLK	1
Crt Rep.	
- 1H	

TESTIMONY & EXHIBITS OF:

MANUEL B. MIRANDA

01614 MAR 19 2 FPSC-COMMISSION CLERK

ATE

DOCUMENT NUMBER-

1	BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION
2	FLORIDA POWER & LIGHT COMPANY
3	DIRECT TESTIMONY OF MANUEL B. MIRANDA
4	DOCKET NO. 120015-EI
5	
6	
7	
8	
9	
10	
11	
12	
13	
14	
15	
16	
17	
18	
19	
20	
21	
22	
23	
24	

1	TABLE OF CONTENTS
2	
3	I. INTRODUCTION1
4	II. RELIABILITY
5	III. INFRASTRUCTURE IMPROVEMENTS – STORM RESILIENCY 12
6	IV. REGULATORY COMPLIANCE 13
7	V. TRANSMISSION O&M EXPENSE 15
8	VI. TRANSMISSION CAPITAL EXPENDITURES 17
9	
10	
11	
12	
13	
14	
15	
16	
17	
18	
19	
20	
21	
22	

1		I. INTRODUCTION
2		
3	Q.	Please state your name and business address.
4	A.	My name is Manuel B. Miranda. My business address is Florida Power & Light
5		Company, 700 Universe Boulevard, Juno Beach, Florida 33408.
6	Q.	By whom are you employed and what is your position?
7	A.	I am employed by Florida Power & Light Company ("FPL" or the "Company") as
8		Vice President of Transmission and Substation.
9	Q.	Please describe your duties and responsibilities in that position.
10	A.	I am responsible for FPL's bulk and regional transmission planning, operations,
11		maintenance, engineering and construction activities, including ensuring the
12	·	reliability and security of the FPL transmission and substation facilities in a safe
13		and effective manner, consistent with the applicable reliability standards.
14	Q.	Please describe your educational background and professional experience.
15	A.	I joined FPL in 1982 and have served in a variety of positions within Customer
16		Service, Distribution and Transmission. These positions include engineering,
17		dispatch operations, commercial and industrial manager, Director of Distribution
18		Operations and Vice President of Distribution System Performance, responsible
19		for FPL's Storm Secure initiative to substantially strengthen the distribution
20		infrastructure against future hurricanes. My current position is Vice President of
21		Transmission & Substation.

1		I have a Bachelor of Science in Mechanical Engineering from the University of		
2		Miami and a Master's in Business Administration from Nova Southeastern		
3		University.		
4	Q.	Are you sponsoring any exhibits in this case?		
5	A.	Yes. I am sponsoring the following exhibits, which are attached to my direct		
6		testimony:		
7		• MM-1, Summary of Sponsored MFRs		
8		• MM-2, 2011 SGS Statistical Services ("SGS") Transmission Reliability		
9		Benchmarking Study All Voltages 2008-2010 (3 years)		
10	Q.	Are you sponsoring or co-sponsoring any Minimum Filing Requirements		
11		("MFRs") filed in this case?		
12	А.	Yes. Exhibit MM-1 shows my co-sponsorship of MFRs.		
13	Q.	What is the purpose of your testimony?		
14	A.	The purpose of my testimony is to: (1) describe the solid track record of the		
15		Transmission and Substation Business Unit ("Transmission"), based on system		
16		performance and reliability, including the programs that help to provide FPL		
17		customers with a high level of reliable service in a cost-effective manner; (2)		
18		address the initiatives that improve the storm resiliency of the transmission		
19		system's infrastructure; (3) explain the ongoing need for capital investments		
20		required to maintain FPL's high level of reliability for customers; (4) describe		
21		how Transmission effectively manages Operations & Maintenance ("O&M")		
22		expenses for the 2013 test period compared to the Commission Benchmark; and		

- (5) discuss FPL's efforts to meet its commitments to customers and to ensure
 compliance with all applicable regulatory and reliability standards.
- 3

Q. Please summarize your testimony.

- A. Transmission provides a high level of reliable service through a proactive
 approach to reliability. Transmission has consistently provided customers with a
 superior level of reliable service in a cost-effective manner. The requested base
 rate increase will permit FPL to maintain this level of reliability for customers
 while promoting compliance with all applicable regulatory commitments.
- 9

10 In a 2011 industry transmission reliability benchmarking study conducted by SGS 11 Statistical Services ("SGS"), FPL's System Average Interruption Duration Index 12 ("SAIDI") for 2010 data and for aggregate data from 2008 through 2010 was in 13 the top 10% of survey participants. In 2010, FPL's Transmission SAIDI was 14 3.99, improving in 2011 to a SAIDI of 3.17 (21% improvement from 2010). 15 During the five years ending with 2010, Transmission had the best average 16 Transmission SAIDI of the Florida investor-owned utilities. This overall performance is a direct result of the commitment of FPL's management and 17 18 employees to providing superior reliability and service at a reasonable cost.

19

The foundation of Transmission's reliability program is condition-based maintenance which is used to evaluate equipment and determine remaining useful life. Combining equipment assessment with a comprehensive risk management approach leads to the development of an appropriate, cost-effective plan to extend

the life of FPL's transmission and substation assets and replace those assets only when appropriate. An important part of this process involves the Company's use of both FPL and industry experience to focus on predictive maintenance and prevention of recurrence of events to reduce the frequency and duration of customer outages.

6

7 Notwithstanding these programs, Transmission will require funding to maintain 8 the level of system stability and service reliability that customers expect. The 9 required capital expenditures are driven by the need for transmission 10 infrastructure improvements, storm hardening efforts, and regulatory 11 commitments. While FPL must continue to refurbish or replace aging facilities, 12 the Company also must invest in transmission system expansion projects and 13 added capacity where technology improvements and equipment upgrades already 14 have maximized the efficiency of the existing infrastructure. Given current 15 capacity limitations and FPL's assessment of its system, the Company has 16 developed a sound plan to replace infrastructure and add new capacity through projects that I will describe later in my testimony. FPL must responsibly move 17 18 forward with this work to maintain a safe and reliable system for the benefit of its 19 current and future customers.

20

1		II. RELIABILITY
2		
3	Q.	Please describe the FPL transmission and substation system.
4	A.	As of January 1, 2012, the FPL transmission and substation system was
5		comprised of 6,721 circuit miles of transmission lines operating at voltages from
6		69 kiloVolt ("kV") to 500 kV, 518 distribution substations and 98 transmission
7		substations. The FPL transmission system is designed to integrate all of FPL's
8		generation resources in a reliable and cost-effective manner to serve FPL's
9		customers. FPL is required to plan, design, construct, operate and maintain its
10		transmission and substation system to meet all applicable reliability standards.
11	Q.	How is Transmission's reliability performance measured, and how does FPL
12		compare to other electric utilities?
13	A.	To evaluate reliability performance, FPL uses standard industry measures for
14		frequency and duration of outages such as SAIDI. These standard industry
15		measurements provide a comprehensive and useful indication of the level of
16		reliability FPL provides to its customers.
17		
18		In a 2011 industry transmission reliability benchmarking study conducted by
19		SGS, FPL's SAIDI for 2010 data and for aggregate data from 2008 through 2010
20		was in the top 10% of survey participants. In 2010, FPL's Transmission SAIDI
21		was 3.99, improving in 2011 to a SAIDI of 3.17 (21% improvement from 2010).
22		During the five years ending with 2010, Transmission had the best average
23		Transmission SAIDI of the Florida investor-owned utilities. This overall

2

- performance is a direct result of the commitment of FPL's management and employees to providing superior reliability and service at a reasonable cost.
- 3 Q. Please describe Transmission's reliability programs.

4 Transmission reliability programs are Facility/System Assessments, Targeted A. 5 Maintenance, Prevention through Prediction, Prevention of Recurrence, 6 Vegetation Management, and Smart Grid Technology. These programs utilize 7 diagnostic tools to assess equipment and facility conditions. The information 8 obtained from these assessments is used to develop a plan for maintenance and 9 replacement. Resulting processes and initiatives are executed in a cost-effective 10 manner that maintains grid reliability and reduces the frequency and duration a 11 customer is without electricity due to transmission and substation events. The 12 two main processes used to execute these programs are the Condition Assessment 13 Process and Event Response Process.

14

15 The Condition Assessment Process has three main components that involve 16 transmission line and substation assessments, remaining useful life determination 17 for assets, and risk management. The second key process, Event Response 18 Process, is designed to determine the root cause for every unplanned outage of 19 transmission and substation equipment. Each event is recorded, classified and The results of each outage cause analysis are then used in the 20 analyzed. 21 Condition Assessment Process and incorporated into the design and engineering of future facilities. 22 This approach supports prevention of recurrence and 23 mitigation of future events, together with a resulting reduction in the frequency and duration of customer outages. These two processes support Transmission's
 reliability programs.

Q. Please provide some examples of Transmission's reliability programs and explain how these programs benefit FPL's customers.

5 A. The following are some examples of Transmission's reliability programs:

- 6
- 7 Facility/System Assessments – Transmission line and substation assessments 8 are conducted using equipment diagnostics and both on-site and remote 9 system surveillance. The assessments include oil sampling and testing, 10 equipment and protective system testing, thermal imaging of components, and 11 climbing inspections and station assessments, all of which provide 12 information used to prevent or predict equipment or facility failures. Part of 13 system surveillance is accomplished through equipment performance 14 monitoring and diagnostics, consistent with Smart Grid initiatives, using 15 remote monitoring tools and analysis programs which are deployed in the 16 Transmission and Performance Diagnostic Center ("TPDC").
- 17

Targeted Maintenance – Information obtained during condition assessment
 is evaluated using predictive models. A plan is then developed to replace or
 conduct targeted maintenance on major equipment and facilities. Targeted
 maintenance for equipment and facilities extends the useful life of the
 equipment while minimizing cost and significantly deferring the need for
 substantial investment in new equipment and capital projects.

1 Prevention through Prediction – By combining remaining useful life • 2 determination with risk assessment of the transmission system, a plan is developed to replace major equipment and facilities in a predictive manner. 3 Predictive replacements minimize customer impact and cost while 4 maximizing asset utilization. When predictive replacements are made, 5 6 customers benefit from FPL's use of technological advances and design 7 improvements. These improvements reduce the likelihood of interruptions and mitigate the effects on customers when interruptions do occur. 8

9

Prevention of Recurrence – Through the use of the Event Response Process
 described above, Transmission develops countermeasures to prevent the
 recurrence of similar events that could cause outages.

13

14 Smart Grid Technology – FPL is incorporating intelligent technology into 15 the substation systems to improve reliability and to better anticipate and 16 respond to system disturbances. For example, Distribution Substation 17 Transformer Relay Scheme upgrades will utilize microprocessor-based 18 systems to gather power system data, assess equipment operating conditions and enable the use of auto-restoration and self-healing systems. In addition to 19 20 improvements in reliability, the project aims to increase the situational 21 awareness of grid operations and optimize asset utilization.

22

1		• Vegetation Management – The growth of vegetation into overhead power		
2		lines represents a major challenge to electric utilities. This is particularly true		
3		in much of Florida with the year-round growing season. Transmission's		
4		Vegetation Management Program involves trimming and right-of-way		
5		clearance and has two main focuses: System Stability and Customer Impact		
6		Reliability. From the perspective of System Stability, this work focuses on		
7		preserving right-of-way requirements for higher voltage transmission lines		
8		(500 kV and 230 kV) that can affect the entire system. The Customer Impact		
9		Reliability work includes condition assessments of the lower voltage		
10		transmission lines, in order to determine appropriate maintenance trimming		
11		requirements.		
12				
13		In summary, FPL's reliability initiatives significantly contribute to the prevention		
14		and minimization of outages and customer inconvenience, while at the same time		
15		extending the life of equipment and infrastructure in an appropriate and cost-		
16		effective manner.		
17	Q.	How has FPL used technology to improve the monitoring and control of its		
18		transmission system?		
19	А.	FPL is implementing the following initiatives to improve the overall reliability of		
20		the transmission system:		
21				
22		• FPL System Control Center – The FPL System Control Center ("SCC") is a		
23		state-of-the-art facility that plays a key role in the efficient operation of FPL's		

transmission and substation systems. The quality and availability of tools and
 information on the status of FPL's system are hallmarks of FPL's SCC.
 Coordination among FPL and the other members of the Florida Reliability
 Coordinating Council to improve system management demonstrates FPL's
 continuous commitment to the reliable operation of the electric system.

- 6
- FPL operates its transmission system in full compliance with all applicable 7 standards. The North American Electric Reliability Corporation ("NERC") 8 9 Critical Infrastructure Protection ("CIP") standards provide a cyber security framework for the identification and protection of critical cyber assets to 10 support the reliable operation of the Bulk Electric System ("BES"). The CIP 11 12 standards include controlling and monitoring both physical and electronic 13 access to the related cyber asset in support of the SCC. The CIP standards also require procedures for securing these cyber assets and training programs 14 15 to instruct operations employees on expectations. Transmission has implemented cyber security measures to fully comply with the NERC CIP 16 17 standards.
- 18

Transmission and Performance Diagnostic Center – Another example of a
 major transmission reliability initiative is the creation of the TPDC. The
 TPDC is a center for monitoring the critical operating parameters of
 transmission equipment and performing analyses. Current and near-future
 assessment methods provide early prediction of asset failures by monitoring

and using real-time statistical analysis of equipment performance to identify
 abnormal conditions. Through the use of dashboards and other informational
 displays, the health of transmission and substation equipment is continuously
 monitored. The TPDC also provides analyses of system events and acts as a
 transmission and substation support team.

The TPDC enhances FPL's predictive capabilities by providing remote 7 analysis of transmission and substation asset performance. 8 The actual 9 performance of equipment is compared to various equipment technical operating parameters to determine the present condition of installed 10 Deviations from the technical operating parameters of the 11 equipment. 12 equipment can then be further assessed and investigated to minimize impacts on the system. 13

14

6

15 The TPDC also coordinates with the SCC and Distribution Dispatch to 16 respond with analyses of system events. TPDC personnel gather relay targets, sequence of events from the Supervisory Control and Data Acquisition system 17 18 and other pertinent forensic information immediately following an outage, all 19 while the first responder is still in route to the site of the event. Armed with 20 this information upon arrival, first responders are able to perform the 21 restoration more quickly than in the past. In fact, for feeder breaker failures, 22 the contributions from TPDC have resulted in an improvement in restoration 23 times.

2

Q. Please provide an update on efforts to improve the strength and resiliency of FPL transmission infrastructure in the event of a major storm.

A. In April of 2006, the Florida Public Service Commission issued Order No. PSC-06-0351-PAA-EI, requiring investor-owned electric utilities to file plans for ten
(10) ongoing storm preparedness initiatives. As a result of initiative four (4) in
this order, FPL accelerated two (2) programs for strengthening and improving
resiliency of existing transmission structures in the event of a major storm. These
programs are described as follows:

11

12 . Replacement of Wood Transmission Structures: FPL has implemented 13 plans to replace all wood transmission structures throughout its service 14 territory. New structures are made from engineered materials (such as concrete or steel). FPL transmission line structural designs are governed by 15 16 Florida Statute Section 366.04. Under this Statute, all high voltage 17 transmission structures must satisfy the requirements as specified by the National Electrical Safety Code ("NESC", an American National Standard 18 19 Institute ("ANSI") publication, C 2). The ANSI C 2 document addresses 20 extreme wind load criteria (Rule 250 C) which covers all wind sensitive 21 factors and wind related effects that need to be considered in the design 22 calculations. Between January 1, 2006 and December 31, 2011, the number of wood transmission structures at FPL decreased from 26,147 to 15,542. 23

1 FPL has committed to replace all wood structures. As of December 31, 2011, 2 over 75% of the transmission structures at FPL are made from either concrete 3 or steel. 4 Replacement of Ceramic Post Insulators on Concrete Structures: FPL is 5 • 6 also replacing ceramic post insulators on concrete structures. New insulators 7 are made from polymer materials, meet current design standards, and 8 minimize cascading type events. Between January 1, 2006 and December 31, 9 2011, the number of concrete transmission structures with ceramic post 10 insulators at FPL decreased from 5,562 to 2,139. As of December, 31 2011, less than 4% of FPL's transmission structures are concrete with ceramic post 11 12 insulators. 13 IV. **REGULATORY COMPLIANCE** 14 15 16 Please describe how federal regulations impact FPL's transmission business. **Q**. Transmission is a heavily regulated sector of the electric utility industry. Under 17 A. 18 the direction of the Federal Energy Regulatory Commission ("FERC"), NERC 19 has developed and issued 116 reliability standards, of which 104 standards, 20 containing 1,080 requirements and sub-requirements govern FPL's Transmission 21 operation and maintenance of the BES. NERC's purpose for implementing these

23 planned and unplanned contingencies. Compliance with these enforceable

standards is to ensure the provision of reliable electric service while allowing for

1 standards and requirements incrementally increases both capital and O&M 2 expenditures for new and existing assets, the institution of enhanced processes and related training. Additionally, new NERC CIP standards, dealing with cyber 3 security of the BES, are requiring significant incremental resources to protect 4 5 FPL's most critical transmission assets from malicious cyber attack. NERC also imposes initiatives, for example, the recent Facilities Ratings, which further 6 7 impacts the resource requirements of the Transmission business unit. For 8 example, NERC's Facilities Rating Alert involves verification of transmission 9 line compliance with NERC's method of determining electrical ratings. FPL is 10 contracting aircraft to fly 6,721 miles of transmission lines from 2011 through 11 2013 while utilizing Light Detection and Ranging ("LiDAR") technology to capture the actual location of the lines. Conflicts identified from the LiDAR 12 13 assessment are followed up to verify any NERC defined discrepancies. Should any NERC defined discrepancies be verified, FPL has one year, from the date of 14 15 identification, to remediate. The projected incremental cost for this remediation 16 through 2014 is \$26 million.

17

18 These mandatory reliability measures, administrative requirements, associated 19 processes and required training associated with compliance to NERC Reliability 20 Standards place an ongoing and incremental resource impact on Transmission 21 which will continue to evolve as NERC's compliance enforcement program 22 grows.

23

1		V. TRANSMISSION O&M EXPENSE			
2					
3	Q.	Comparing the 2013 Test Year to the 2012 Prior Year, are there any			
4		accounts in which the change to Transmission's non-fuel O&M expenses			
5		exceeds the threshold defined in MFR C-8?			
6	A.	No. Transmission has no accounts where the change in non-fuel expenses			
7		exceeds the threshold as defined on MFR C-8.			
8					
9	Q.	What are some of the major components associated with Transmission O&M			
10		expense actual and projected costs?			
11	A.	In order to maintain FPL's high level of reliable service while at the same time			
12		addressing aging infrastructure, Transmission engages in a number of initiatives			
13		which impact Transmission O&M expenses. These initiatives generally fall into			
14		the following categories:			
15					
16		• Enhanced Transmission and Substation Maintenance and Condition			
17		Assessment Activities: As transmission and substation facilities age, the			
18		maintenance costs increase. In order to maximize the life of major			
19		transmission and substation equipment, proper and timely maintenance is			
20		required. Transmission's Condition Assessment Program uses risk			
21		assessments, life-cycle projections and predictive techniques to prioritize			
22		maintenance activities and equipment repair on an appropriate schedule to			
23		extend the life of the equipment. Without this program, FPL's costs would be			

- 1greater because equipment replacement costs are higher than life extension2costs.
- 3

System Control Center: SCC operations require around the clock support of
 major computer systems, complex technical applications, infrastructure and a
 team of control center operators and computer systems support personnel.
 The SCC operators are required to have certification from the NERC and
 annual training is required as part of the NERC operator certification. The
 SCC computer system support personnel are highly skilled in power system
 operation tools, infrastructure support and NERC CIP requirements.

11

Regulatory: Regulatory commitments include compliance oversight and
 computer enhancements, vegetation management programs, training
 certification and re-certification programs, and storm hardening and pole
 inspection programs.

16 Q. How do FPL's projected 2013 O&M expenses for the Transmission
17 functional area compare to the Commission Benchmark (MFR C-41; using
18 the 2010 rate case decision adjusted for inflation and customer growth)?

A. FPL's projected 2013 O&M expenses for the Transmission functional area are
below the Commission Benchmark. FPL's O&M expenses for the Transmission
functional area result from aggressively managing operating cost.

1		VI. TRANSMISSION CAPITAL EXPENDITURES
2		
3	Q.	What are Transmission's capital expenditures for 2013.
4	А.	Transmission's capital expenditures for the 2013 test year are projected to be
5		\$183 million.
6	Q.	What are the major cost drivers for Transmission's capital expenditures?
7	А.	The major cost drivers associated with Transmission's capital expenditures are:
8		
9		• Infrastructure replacement refurbishment and reliability, \$53 million: As
10		substation equipment such as transformers, breakers, capacitor banks and
11		other associated equipment approach the end of their useful life, FPL
12		optimizes the replacement process with respect to interruption avoidance,
13		resource allocation, and asset utilization. Replacement and refurbishment of
14		substation equipment will minimize service interruptions to customers. The
15		opportunities to improve transmission line reliability are identified through an
16		analysis of existing system performance. Based on the analysis, reliability
17		improvement projects are developed to reduce the major cause of poor
18		reliability on the worst performing facilities.
19		
20		The Substation Reliability Improvement program uses innovative technology
21		and systems upgrades to enhance and improve the reliability experienced by
22		our customers and simultaneously reduces the reliability exposure of our
23		critical multi-million dollar transformer fleet. Through this program,

imminent issues are either identified early to preempt occurrence of an event, or in the occurrence of an event, the upgrades significantly improve restoration time and thereby reduce customer outage and dissatisfaction.

4

5

6

7

8

9

10

11

12

1

2

3

- Projects to meet transmission system requirements, \$35 million: While load growth has slowed recently, over the next several years load is forecasted to increase again. NERC reliability standards mandate minimum requirements to accommodate system load growth. To meet these requirements, FPL has developed a phased-in plan to expand facilities and add new capacity through system expansion requiring capital expenditures in 2013 of \$35 million, \$29 million of which is the Bobwhite-Manatee 230 kV Line, as described below.
- 13 Bobwhite-Manatee 230 kV Line, \$29 million: Additional capability Ο of the transmission network serving the Southwest area is needed to 14 comply with NERC standards and provide transmission customer 15 service connection requests. This project was subject to the Florida 16 Transmission Line Siting Act guidelines, which provides for 17 18 certification of electrical transmission lines which are 230 kV or 19 larger; cross a county line; and are 15 miles or longer. Prior to 20 issuance of a corridor certification, the Department of Environmental Protection, Fish and Wildlife Conservation Commission, Department 21 22 of Community Affairs, Public Service Commission, local 23 governments, water management districts, and regional planning

1	councils through the jurisdiction in which the corridor would pass are
2	required to assess the potential effects of the proposed transmission
3	lines to ensure through available and reasonable methods that the
4	location of transmission line corridors and construction and
5	maintenance of transmission lines will produce minimal adverse
6	effects on the environment and public health, safety, and welfare.
7	
8	Bobwhite-Manatee was certified by the Siting Board (Governor and
9	Cabinet) on November 6, 2008. This project will improve the
10	reliability as well as serve local and wholesale transmission customers
11	in the Manatee-Sarasota area. The total cost of the project is estimated
12	at \$47.6 million, \$29 million in the test year, and it is scheduled to be
13	completed in 2014.
14	
15	• FPSC mandated programs, \$31 million: The transmission infrastructure
16	requires refurbishment to keep the facilities serviceable and to maintain
17	reliability. The replacement of all wooden transmission structures over the
18	next 25 – 30 years is in progress to address Transmission's storm hardening.
19	Inspections of transmission facilities through reliability programs or following
20	an outage event have identified the need for follow-up refurbishment work.
21	These refurbishments are major cost drivers which involve all types of
22	components associated with the transmission system such as cross arms,
23	insulators, overhead ground wires, poles and splices with a capital expenditure

of \$26 million in 2013. In addition, in order to maintain our long term hardening goal, capital expenditures of \$2.0 million to replace wooden transmission structures and \$1.7 million to replace ceramic post insulators on concrete poles are projected for 2013. Capital expenditures of \$0.8 million in 2013 are projected for substation insulator replacement to reduce failures due to windblown salt and other contaminants.

- 7
- 8 Projects to meet distribution system requirements, \$23 million: As part of 0 9 its annual capacity planning process, FPL examines existing and projected 10 loading conditions and evaluates the need for additional distribution 11 substations, expansion and/or modification of existing distribution substations, 12 and the need for additional feeders to ensure that increased capacity 13 requirements are met and reliable electric service is maintained. FPL's plans 14 for 2013 may include the site preparation of one new distribution substation, 15 increasing capacity and/or modifying 11 existing distribution substations, and 16 adding six new feeders.
- 17
- 18

• Projects resulting from revisions to FERC/NERC standards, \$19 million:

19 These projects are improvements to FPL's system to meet NERC and FERC 20 standards in addition to projects planned to meet transmission system 21 requirements. They include protection redundancy, Digital Fault Recorders, 22 Breaker/Bus Rating and Coupling Capacitor Voltage Transformer

2

replacements. They also include projects resulting from the recent NERC initiative Facilities Rating alerts previously discussed.

3

4 Projects related to technology upgrades to FPL's SCC, \$8 million: Technology capital budget and plan is driven by three main factors: (1) 5 6 replacement and/or upgrade of technology components for FPL's SCC due to 7 obsolescence or end-of-life; (2) major technology upgrades to add or improve functionality 8 for SCC applications; infrastructure, and associated 9 communication systems and networks; and (3) other technology projects that 10 support the business unit mission in improving its operational efficiency. The 11 technology budget for 2013 includes the following major projects: (1) SCC 12 equipment replacements and/or upgrades due to end-of-life (e.g., network 13 infrastructure equipment and application servers); (2) replacement for the Unit 14 Commitment application; (3) cyber security enhancements; and (4) the 15 conversion of the substation communications infrastructure from a Frame 16 Relay technology to either the Multiprotocol Label switching or fiber optic 17 technology.

- 18
- 19

• Transmission 500 kV System Program, \$8 million

FPL will continue its reliability initiatives on the 500 kV transmission line system. Replacement of insulators and vibration spacer-damper systems are planned for 2013 with a projected expenditure of \$4.4 million. Replacement of structures and structural components are also planned for 2013 with a projected expenditure of \$3.6 million. FPL requires a reliable 500 kV system
for bulk transmission power flow within its service area and to meet
regulatory commitments and maintain transmission grid stability. These
replacements are part of FPL's ongoing 500 kV reliability plan which is based
on the previously described Condition Assessment Process.

- 6
- Non-Reimbursable Relocations, \$6 million: Forced relocations are the result
 of siting transmission facilities in right-of-ways where FPL does not have a
 compensable interest, most common being road rights-of-way. FPL has the
 legal obligation to State and county governments to relocate facilities located
 in road right-of-way when these facilities are in conflict with proposed road
 improvements. Failure to execute projects as scheduled may result in road
 contractor delay claims.

14 Q. Please summarize Transmission's accomplishments.


15 A. In summary, Transmission's accomplishments and operations are an example to 16 the industry. We work hard every day to maintain the current high level of 17 reliability our customers expect and deserve while promoting compliance with all 18 applicable regulatory commitments. We have maintained this excellent record 19 while carefully selecting where we must expand, replace, and refurbish the 20 transmission system for the benefit of our customers now and in the future. 21 Finally, we have accomplished the results and implemented the initiatives, 22 processes and procedures described in my testimony while minimizing the costs 23 for our customers.

- 1 Q. Does this conclude your direct testimony?
- 2 A. Yes.

MFRs SPONSORED AND CO-SPONSORED BY MANUEL MIRANDA

MFR #	PERIOD	TITLE
CO-SPON	SOR	
B-13	Test	Construction Work in Progress
B-15	Test	Property Held for Future Use – 13 Month
	Prior	Average
C-8	Prior	Detail of Changes in Expenses
	Test	
C-15	Test	Industry Association Dues
C-16	Prior	Outside Professional Services
	Test	
C-34	Historic 5 years	Statistical Information
C-41	Test	O&M Benchmark Variance by Function
	Benchmark	

The FPL Transmission SAIDI compares favorably in recent industry benchmarking studies.



Group

For industry comparisons, SAIDI is calculated for outages greater than or equal to five minutes versus FPSC definition of SAIDI of greater than or equal to one minute.