

Sunshine Utilities

10230 E. Hwy. 25 · Belleview, FL 34420-5531
Office (352) 347-8228 · Fax (352) 347-6915

RECEIVED-FPSC

APR 17 AM 8:21

COMMISSION
CLERK

April 16, 2012

Office of Commission Clerk
Florida Public Service Commission
2540 Shurnard Oak Boulevard
Tallahassee, FL 32399-0870

RE: Docket No. 100048-WU Correction of Sanitary Survey for Winding Waters

Dear Ms. Cole:

I would like to submit a correction to the sanitary survey on the Docket No. 100048-WU for Winding Waters Subdivision. The Sanitary survey that was submitted shows two pumps for a total of 811 gallons per minute, which is incorrect. The sanitary survey also shows a 40 HP pump as one of the pumps and the other pump is unknown, which is also incorrect.

The pump station has a 20 HP pump with a total head of 185 feet that produces 160 gallons per minute. The Station also has a 30 HP pump with a total head of 120 feet that produces 600 gallons per minute.

The two pumps total 760 gallons per minute of pumping capacity. I will contact the Florida Department of Environmental Protection to clarify these mistakes.

Winding Waters also showed a maximum day pumping of 118,000 on January 19, 2010 according to the Monthly Operating Reports, this high use was caused by a main line leak that occurred on that day. The second highest use in 2010 was 99,000 gallons on May 18, 2010, which was caused by a service line leak. The greatest amount pumped without any explanation was 95,000 on January 14, 2010.

Thank you,



Dewaine Christmas
Sunshine Utilities of Central Florida, Inc.
Manager

DOCUMENT NUMBER DATE

02334 APR 17 2012

FPSC-COMMISSION CLERK