

State of Florida



Public Service Commission

CAPITAL CIRCLE OFFICE CENTER • 2540 SHUMARD OAK BOULEVARD
TALLAHASSEE, FLORIDA 32399-0850

-M-E-M-O-R-A-N-D-U-M-

RECEIVED-FPSC
13 JAN 23 PM 1:14
COMMISSION
CLERK

DATE: January 23, 2013
TO: Ann Cole, Commission Clerk, Office of Commission Clerk
FROM: James E. McRoy, Utility System/Engineering Specialist, Division of Engineering
RE: Docket No. 120078-SU; Application for staff-assisted rate case in Brevard County by TKCB.

Attached is a response from the Department of Environmental Protection (DEP) regarding Staff's request for additional information concerning TKCB. Please place the attached document in the docket file.

Should you have any questions, regarding this matter, please contact me.

Attachment

DOCUMENT NUMBER-DATE
00417 JAN 23 2013
FPSC-COMMISSION CLERK

James McRoy

From: Powers, Tom [Tom.Powers@dep.state.fl.us]
Sent: Wednesday, January 23, 2013 10:52 AM
To: James McRoy
Subject: RE: D#120078-SU, TKCB Rate Case.

James,

The communitor installation was a recommendation that I made following last year's inspection dated 5/22/12. It is not necessary for the facility to have a communitor. The extra bar screens Jerry has installed to remove debris should be sufficient. However, more work for him. Any further questions or concerns, please contact me. Thanks! tp

Please take a few minutes to share your comments on the service you received from the department by clicking on this link. [DEP Customer Survey](#).

From: James McRoy [mailto:JMcroy@PSC.STATE.FL.US]
Sent: Wednesday, January 23, 2013 9:50 AM
To: Powers, Tom
Cc: Paul Vickery; Shannon Hudson
Subject: D#120078-SU, TKCB Rate Case.

Tom,

Per my conversation with Mr. Jerry Padrick (TKCB's Plant Operator) this morning he informed me that DEP was not requiring TKCB to install a Communitor for the surge tank per your inspection reported dated May 22, 2012. Mr. Padrick further stated that he has installed screens at the tank and is manually removing debris that collects there which he believes alleviates the need to install the communitor. Please provide me an official response to the need of the communitor being installed and if the screens installed at the plant meet your approval. Thank you.

DOCUMENT NUMBER-DATE

00417 JAN 23 2013

FPSC-COMMISSION CLERK

1/23/2013