

AUSLEY & McMULLEN

ATTORNEYS AND COUNSELORS AT LAW

123 SOUTH CALHOUN STREET
P.O. BOX 391 (ZIP 32302)
TALLAHASSEE, FLORIDA 32301
(850) 224-9115 FAX (850) 222-7560

March 15, 2013

HAND DELIVERED

RECEIVED--FPSC
13 MAR 15 PM 2:25
COMMISSION
CLERK

Ms. Ann Cole, Director
Division of Commission Clerk
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, FL 32399-0850

Re: Fuel and Purchased Power Cost Recovery Clause with Generating
Performance Incentive Factor; FPSC Docket No. 130001-EI

Dear Ms. Cole:

Enclosed for filing in the above docket on behalf of Tampa Electric Company are the original and fifteen (15) copies of each of the following:

1. Petition for Approval of Generating Performance Incentive Factor Results for the Twelve Month Period Ending December 2012.
2. Prepared Direct Testimony and Exhibit (BSB-1) of Brian S. Buckley regarding Generating Performance Incentive Factor True-Up for the period January 2012 through December 2012.

Please acknowledge receipt and filing of the above by stamping the duplicate copy of this letter and returning same to this writer.

Thank you for your assistance in connection with this matter.

Sincerely,


James D. Beasley

COM 5 (testimony only)
AFD 9 JDB/pp
APA Enclosures
ECO |
ENG | cc: All parties of record (w/encls.)
GCL |
IDM |
TEL |
CLK | (1-Cl Prep (testimony only))

DOCUMENT NUMBER - DATE

01330 MAR 15 2013

FPSC-COMMISSION CLERK

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

In re: Fuel and Purchased Power)
Cost Recovery Clause and Generating)
Performance Incentive Factor.)
_____)

DOCKET NO. 130001-EI
FILED: March 15, 2013

**TAMPA ELECTRIC COMPANY'S PETITION FOR APPROVAL OF
GENERATING PERFORMANCE INCENTIVE FACTOR RESULTS
FOR THE TWELVE MONTH PERIOD ENDING DECEMBER 2012**

Tampa Electric Company ("Tampa Electric" or "the company") hereby petitions this Commission for approval of the company's results for the twelve-month period ending December 2012. In support of this Petition, Tampa Electric states as follows:

1. By Order No. PSC-12-0664-FOF-E1, dated December 21, 2012, the Commission approved Tampa Electric's GPIF targets for the period January 2012 through December 2012. The application of the GPIF formula to the performance of the company's GPIF units during that period produces a penalty of \$1,777,059. The calculation of the company's GPIF penalty is discussed and supported in the prepared direct testimony and exhibit of Tampa Electric witness Brian S. Buckley, which are being filed together with this petition and incorporated herein by reference.

2. Tampa Electric is not aware of any disputed issues of material fact relative to the relief requested herein.

WHEREFORE, Tampa Electric respectfully requests the Commission to approve \$1,777,059 as its GPIF penalty for the period ending December 2012 and authorize the inclusion of this amount in the calculation of Tampa Electric's fuel factors for the period beginning January 2014.


DOCUMENT NUMBER-DATE

01330 MAR 15 2013

FPSC-COMMISSION CLERK

DATED this 15th day of March 2013.

Respectfully submitted.



JAMES D. BEASLEY
J. JEFFRY WAHLEN
Ausley & McMullen
Post Office Box 391
Tallahassee, Florida 32302
(850) 224-9115

ATTORNEYS FOR TAMPA ELECTRIC COMPANY

CERTIFICATE OF SERVICE

I HEREBY CERTIFY that a true copy of the foregoing Petition, filed on behalf of Tampa Electric Company, has been served by hand delivery (*) or U. S. Mail on this 15th day of March 2013, to the following:

Ms. Martha F. Barrera*
Senior Attorney
Office of the General Counsel
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, FL 32399-0850

Mr. John T. Burnett
Ms. Dianne M. Triplett
Progress Energy Florida, Inc.
Post Office Box 14042
St. Petersburg, FL 33733

Mr. Paul Lewis, Jr.
Progress Energy Florida, Inc.
106 East College Avenue
Suite 800
Tallahassee, FL 32301-7740

Mr. Jon C. Moyle, Jr.
Moyle Law Firm
118 N. Gadsden Street
Tallahassee, FL 32301

Ms. Patricia A. Christensen
Associate Public Counsel
Office of Public Counsel
111 West Madison Street – Room 812
Tallahassee, FL 32399-1400

Ms. Beth Keating
Gunster, Yoakley & Stewart, P.A.
215 S. Monroe St., Suite 601
Tallahassee, FL 32301

Samuel Miller, Capt., USAF
USAF/AFLOA/JAC/ULFSC
139 Barnes Drive, Suite 1
Tyndall AFB, FL 32403-5319

Ms. Cheryl Martin
Director/Regulatory Affairs
Florida Public Utilities Company
1641 Worthington Road, Suite 220
West Palm Beach, FL 33409

Mr. John T. Butler
Assistant General Counsel - Regulatory
Florida Power & Light Company
700 Universe Boulevard
Juno Beach, FL 33408-0420

Mr. Kenneth Hoffman
Vice President, Regulatory Relations
Florida Power & Light Company
215 South Monroe Street, Suite 810
Tallahassee, FL 32301-1859

Mr. Robert L. McGee, Jr.
Regulatory and Pricing Manager
Gulf Power Company
One Energy Place
Pensacola, FL 32520-0780


Mr. Jeffrey A. Stone
Mr. Russell A. Badders
Mr. Steven R. Griffin
Beggs & Lane
Post Office Box 12950
Pensacola, FL 32591-2950

Mr. Robert Scheffel Wright
Mr. John T. LaVia, III
Gardner, Bist, Wiener, Wadsworth,
Bowden, Bush, Dee, LaVia & Wright, P.A.
1300 Thomaswood Drive
Tallahassee, FL 32308

Mr. Randy B. Miller
White Springs Agricultural Chemicals, Inc.
Post Office Box 300
White Springs, FL 32096

Ms. Cecilia Bradley
Senior Assistant Attorney General
Office of the Attorney General
The Capitol – PL01
Tallahassee, FL 32399-1050

Mr. James W. Brew
Mr. F. Alvin Taylor
Brickfield, Burchette, Ritts & Stone, P.C.
1025 Thomas Jefferson Street, NW
Eighth Floor, West Tower
Washington, D.C. 20007-5201



ATTORNEY



BEFORE THE
FLORIDA PUBLIC SERVICE COMMISSION

DOCKET NO. 130001-EI
IN RE: FUEL & PURCHASED POWER COST RECOVERY
AND
CAPACITY COST RECOVERY

GENERATING PERFORMANCE INCENTIVE FACTOR
TRUE-UP
JANUARY 2012 THROUGH DECEMBER 2012

TESTIMONY AND EXHIBIT
OF
BRIAN S. BUCKLEY

DOCUMENT NUMBER-DATE

01330 MAR 15 2012

FPSC-COMMISSION CLERK

1 **BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION**

2 **PREPARED DIRECT TESTIMONY**

3 **OF**

4 **BRIAN S. BUCKLEY**

5
6 **Q.** Please state your name, business address, occupation and
7 employer.

8
9 **A.** My name is Brian S. Buckley. My business address is 702
10 North Franklin Street, Tampa, Florida 33602. I am employed
11 by Tampa Electric Company ("Tampa Electric" or "company") in
12 the position of Manager, Compliance and Performance.

13
14 **Q.** Please provide a brief outline of your educational
15 background and business experience.

16
17 **A.** I received a Bachelor of Science degree in Mechanical
18 Engineering in 1997 from the Georgia Institute of
19 Technology and a Master of Business Administration from the
20 University of South Florida in 2003. I began my career
21 with Tampa Electric in 1999 as an Engineer in Plant
22 Technical Services. I have held a number of different
23 engineering positions at Tampa Electric's power generating
24 stations including Operations Engineer at Gannon Station,
25 Instrumentation and Controls Engineer at Big Bend Station,

1 and Senior Engineer in Operations Planning. In August
2 2008, I was promoted to Manager, Operations Planning.
3 Currently, I am the Manager of Compliance and Performance
4 responsible for unit performance analysis and reporting of
5 generation statistics.
6

7 **Q.** What is the purpose of your testimony?
8

9 **A.** The purpose of my testimony is to present Tampa Electric's
10 actual performance results from unit equivalent availability
11 and heat rate used to determine the Generating Performance
12 Incentive Factor ("GPIF") for the period January 2012
13 through December 2012. I will also compare these results to
14 the targets established prior to the beginning of the
15 period.
16

17 **Q.** Have you prepared an exhibit to support your testimony?
18

19 **A.** Yes, I prepared Exhibit No. _____ (BSB-1), consisting of two
20 documents. Document No. 1, entitled "Tampa Electric Company,
21 Generating Performance Incentive Factor, January 2012 -
22 December 2012 True-up" is consistent with the GPIF
23 Implementation Manual previously approved by the Commission.
24 Document No. 2 provides the company's Actual Unit
25 Performance Data for the 2012 period.

- 1 **Q.** Which generating units on Tampa Electric's system are
2 included in the determination of the GPIF?
3
- 4 **A.** Four of the company's coal-fired units, one integrated
5 gasification combined cycle unit and two natural gas
6 combined cycle units are included. These are Big Bend Units
7 1 through 4, Polk Unit 1 and Bayside Units 1 and 2,
8 respectively.
9
- 10 **Q.** Have you calculated the results of Tampa Electric's
11 performance under the GPIF during the January 2012 through
12 December 2012 period?
13
- 14 **A.** Yes, I have. This is shown on Document No. 1, page 4 of 32.
15 Based upon -1.513 Generating Performance Incentive Points
16 ("GPIP"), the result is a penalty amount of \$1,177,059 for
17 the period.
18
- 19 **Q.** Please proceed with your review of the actual results for
20 the January 2012 through December 2012 period.
21
- 22 **A.** On Document No. 1, page 3 of 32, the actual average common
23 equity for the period is shown on line 14 as \$1,906,970,568.
24 This produces the maximum penalty or reward amount of
25 \$7,780,732 as shown on line 21.

1 **Q.** Will you please explain how you arrived at the actual
2 equivalent availability results for the seven units included
3 within the GPIF?
4

5 **A.** Yes. Operating data for each of the units is filed monthly
6 with the Commission on the Actual Unit Performance Data
7 form. Additionally, outage information is reported to the
8 Commission on a monthly basis. A summary of this data for
9 the 12 months provides the basis for the GPIF.
10

11 **Q.** Are the actual equivalent availability results shown on
12 Document No. 1, page 6 of 32, column 2, directly applicable
13 to the GPIF table?
14

15 **A.** No. Adjustments to actual equivalent availability may be
16 required as noted in section 4.3.3 of the GPIF Manual. The
17 actual equivalent availability including the required
18 adjustment is shown on Document No. 1, page 6 of 32, column
19 4. The necessary adjustments as prescribed in the GPIF
20 Manual are further defined by a letter dated October 23,
21 1981, from Mr. J. H. Hoffsis of the Commission's Staff. The
22 adjustments for each unit are as follows:
23

24 **Big Bend Unit No. 1**

25 On this unit, 504.0 planned outage hours were originally

1 scheduled for 2012. Actual outage activities required 600.0
2 planned outage hours. Consequently, the actual equivalent
3 availability of 67.0 percent is adjusted to 67.8 percent as
4 shown on Document No. 1, page 7 of 32.

5
6 **Big Bend Unit No. 2**

7 On this unit, 504.0 planned outage hours were originally
8 scheduled for 2012. Actual outage activities required 353.5
9 planned outage hours. Consequently, the actual equivalent
10 availability of 78.1 percent is adjusted to 76.7 percent as
11 shown on Document No. 1, page 8 of 32.

12
13 **Big Bend Unit No. 3**

14 On this unit, 576.0 planned outage hours were originally
15 scheduled for 2012. Actual outage activities required 247.3
16 planned outage hours. Consequently, the actual equivalent
17 availability of 72.2 percent is adjusted to 69.3 percent as
18 shown on Document No. 1, page 9 of 32.

19
20 **Big Bend Unit No. 4**

21 On this unit, 576.0 planned outage hours were originally
22 scheduled for 2012. Actual outage activities required 717.1
23 planned outage hours. Consequently, the actual equivalent
24 availability of 75.7 percent is adjusted to 76.9 percent as
25 shown on Document No. 1, page 10 of 32.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

Polk Unit No. 1

On this unit, 960.0 planned outage hours were originally scheduled for 2012. Actual outage activities required 1,115.4 planned outage hours. Consequently, the actual equivalent availability of 70.0 percent is adjusted to 71.5 percent, as shown on Document No. 1, page 11 of 32.

Bayside Unit No. 1

On this unit, 336.0 planned outage hours were originally scheduled for 2012. Actual outage activities required 190.0 planned outage hours. Consequently, the actual equivalent availability of 96.3 percent is adjusted to 94.7 percent, as shown on Document No. 1, page 12 of 32.

Bayside Unit No. 2

On this unit, 1,511.0 planned outage hours were originally scheduled for 2012. Actual outage activities required 1,649.7 planned outage hours. Consequently, the actual equivalent availability of 78.8 percent is adjusted to 80.3 percent, as shown on Document No. 1, page 13 of 32.

- Q. How did you arrive at the applicable equivalent availability points for each unit?
- A. The final adjusted equivalent availabilities for each unit

1 are shown on Document No. 1, page 6 of 32, column 4. This
2 number is entered into the respective GPIIP table for each
3 particular unit, shown on pages 7 of 32 through 13 of 32.
4 Page 4 of 32 summarizes the weighted equivalent availability
5 points to be awarded or penalized.
6

7 **Q.** Will you please explain the heat rate results relative to
8 the GPIIF?
9

10 **A.** The actual heat rate and adjusted actual heat rate for Tampa
11 Electric's seven GPIIF units are shown on Document No. 1,
12 page 6 of 32. The adjustment was developed based on the
13 guidelines of section 4.3.16 of the GPIIF Manual. This
14 procedure is further defined by a letter dated October 23,
15 1981, from Mr. J. H. Hoffsis of the FPSC Staff. The final
16 adjusted actual heat rates are also shown on page 5 of 32,
17 column 9. The heat rate value is entered into the
18 respective GPIIP table for the particular unit, shown on
19 pages 14 through 20 of 32. Page 4 of 32 summarizes the
20 weighted heat rate points to be awarded or penalized.
21

22 **Q.** What is the overall GPIIP for Tampa Electric for the January
23 2012 through December 2012 period?
24

25 **A.** This is shown on Document No. 1, page 2 of 32. Essentially,

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

the weighting factors shown on page 4 of 32, column 3, plus the equivalent availability points and the heat rate points shown on page 4 of 32, column 4, are substituted within the equation found on page 32 of 32. The resulting value, -1.513, is then entered into the GPIF table on page 2 of 32. Using linear interpolation, the penalty amount is \$1,177,059.

Q. Does this conclude your testimony?

A. Yes, it does.

GENERATING PERFORMANCE INCENTIVE FACTOR

INDEX

DOCUMENT NO.	TITLE	BATES STAMPED PAGE NO.
1	GPIF Schedules	10
2	Actual Unit Performance Data	43

EXHIBIT NO. ____ (BSB-1)
TAMPA ELECTRIC COMPANY
DOCKET NO. 130001-EI
GPIF 2012 FINAL TRUE-UP
DOCUMENT NO. 1

EXHIBIT TO THE TESTIMONY OF
BRIAN S. BUCKLEY

DOCKET NO. 130001-EI

TAMPA ELECTRIC COMPANY
GENERATING PERFORMANCE INCENTIVE FACTOR
JANUARY 2012 - DECEMBER 2012
TRUE-UP

DOCUMENT NO. 1
GPIF SCHEDULES

**TAMPA ELECTRIC COMPANY
GENERATING PERFORMANCE INCENTIVE FACTOR
JANUARY 2012 - DECEMBER 2012
TRUE-UP
TABLE OF CONTENTS**

<u>SCHEDULE</u>	<u>PAGE</u>
GPIF REWARD / PENALTY TABLE - ACTUAL	2
GPIF CALCULATION OF MAXIMUM ALLOWED INCENTIVE DOLLARS	3
CALCULATIONS OF SYSTEM GPIF POINTS - ACTUAL	4
GPIF TARGET AND RANGE SUMMARY	5
UNIT PERFORMANCE DATA - ACTUAL	6
ADJUSTMENTS TO PERFORMANCE	7 - 13
ADJUSTMENTS TO HEAT RATE	14 - 20
PLANNED OUTAGE SCHEDULE - ACTUAL	21
CRITICAL PATH METHOD DIAGRAMS	22 - 23
GENERATING PERFORMANCE INCENTIVE POINTS TABLES	24 - 30
COMPARISON OF GPIF TARGETS VS ACTUAL PERFORMANCE	31
GENERATING PERFORMANCE INCENTIVE POINTS CALCULATION	32

**TAMPA ELECTRIC COMPANY
GENERATING PERFORMANCE INCENTIVE FACTOR
REWARD / PENALTY TABLE - ACTUAL
JANUARY 2012 - DECEMBER 2012**

GENERATING PERFORMANCE INCENTIVE POINTS (GPIP)	FUEL SAVINGS / (LOSS) (\$000)	GENERATING PERFORMANCE INCENTIVE FACTOR (\$000)
+10	29,723.5	7,780.7
+9	26,751.2	7,002.7
+8	23,778.8	6,224.6
+7	20,806.5	5,446.5
+6	17,834.1	4,668.4
+5	14,861.8	3,890.4
+4	11,889.4	3,112.3
+3	8,917.1	2,334.2
+2	5,944.7	1,556.1
+1	2,972.4	778.1
0	0.0	0.0
-1	(2,880.4)	(778.1)
-2	(5,760.8)	(1,556.1)
-3	(8,641.1)	(2,334.2)
-4	(11,521.5)	(3,112.3)
-5	(14,401.9)	(3,890.4)
-6	(17,282.3)	(4,668.4)
-7	(20,162.7)	(5,446.5)
-8	(23,043.0)	(6,224.6)
-9	(25,923.4)	(7,002.7)
-10	(28,803.8)	(7,780.7)



**TAMPA ELECTRIC COMPANY
GENERATING PERFORMANCE INCENTIVE FACTOR
CALCULATION OF MAXIMUM ALLOWED INCENTIVE DOLLARS - ACTUAL
JANUARY 2012 - DECEMBER 2012**

Line 1	Beginning of period balance of common equity:		\$ 1,878,993,511
	End of month common equity:		
Line 2	Month of January	2012	\$ 1,890,121,442
Line 3	Month of February	2012	\$ 1,852,302,024
Line 4	Month of March	2012	\$ 1,864,867,823
Line 5	Month of April	2012	\$ 1,876,338,327
Line 6	Month of May	2012	\$ 1,866,350,234
Line 7	Month of June	2012	\$ 1,885,460,709
Line 8	Month of July	2012	\$ 1,911,774,155
Line 9	Month of August	2012	\$ 1,937,479,453
Line 10	Month of September	2012	\$ 1,958,448,602
Line 11	Month of October	2012	\$ 1,904,697,463
Line 12	Month of November	2012	\$ 1,977,729,852
Line 13	Month of December	2012	\$ 1,986,053,783
Line 14	(Summation of line 1 through line 13 divided by 13)		\$ 1,906,970,568
Line 15	25 Basis points		0.0025
Line 16	Revenue Expansion Factor		61.17%
Line 17	Maximum Allowed Incentive Dollars (line 14 times line 15 divided by line 16)		\$ 7,794,243
Line 18	Jurisdictional Sales		18,408,581 MWH
Line 19	Total Sales		18,440,546 MWH
Line 20	Jurisdictional Separation Factor (line 18 divided by line 19)		99.83%
Line 21	Maximum Allowed Jurisdictional Incentive Dollars (line 17 times line 20)		\$ 7,780,732

TAMPA ELECTRIC COMPANY
CALCULATION OF SYSTEM GPIF POINTS - ACTUAL
JANUARY 2012 - DECEMBER 2012

<u>PLANT / UNIT</u>	<u>12 MONTH ADJ. ACTUAL PERFORMANCE</u>		<u>WEIGHTING FACTOR %</u>	<u>UNIT POINTS</u>	<u>WEIGHTED UNIT POINTS</u>
BIG BEND 1	67.8%	EAF	0.30%	-10.000	-0.030
BIG BEND 2	76.7%	EAF	5.09%	1.326	0.067
BIG BEND 3	69.3%	EAF	9.20%	-10.000	-0.920
BIG BEND 4	76.9%	EAF	6.50%	-0.720	-0.047
POLK 1	71.5%	EAF	0.81%	-10.000	-0.081
BAYSIDE 1	94.7%	EAF	1.35%	-0.730	-0.010
BAYSIDE 2	80.3%	EAF	0.95%	2.387	0.023
BIG BEND 1	10467	ANOHR	19.20%	0.000	0.000
BIG BEND 2	10356	ANOHR	12.41%	-0.272	-0.034
BIG BEND 3	10595	ANOHR	12.03%	0.000	0.000
BIG BEND 4	10420	ANOHR	11.77%	1.695	0.200
POLK 1	10619	ANOHR	6.81%	-10.000	-0.681
BAYSIDE 1	7206	ANOHR	6.86%	0.000	0.000
BAYSIDE 2	7286	ANOHR	6.73%	0.000	0.000
			100.00%		-1.513

GPIF REWARD	\$ (1,177,059)
--------------------	-----------------------

**TAMPA ELECTRIC COMPANY
GPIF TARGET AND RANGE SUMMARY**

EQUIVALENT AVAILABILITY (%)

<u>PLANT / UNIT</u>	<u>WEIGHTING FACTOR (%)</u>	<u>EAF TARGET (%)</u>	<u>EAF MAX. (%)</u>	<u>RANGE MIN. (%)</u>	<u>MAX. FUEL SAVINGS (\$000)</u>	<u>MAX. FUEL LOSS (\$000)</u>	<u>EAF ADJUSTED ACTUAL (%)</u>	<u>ACTUAL FUEL SAVINGS/ LOSS (\$000)</u>
BIG BEND 1	0.30%	81.87	84.6	76.3	89.3	(936.3)	67.8%	(936.3)
BIG BEND 2	5.09%	76.18	80.1	68.4	1,512.2	(122.3)	76.7%	16.2
BIG BEND 3	9.20%	79.98	83.0	73.9	2,734.4	(1,685.0)	69.3%	(1,685.0)
BIG BEND 4	6.50%	77.41	80.9	70.3	1,932.3	(1,553.3)	76.9%	(111.9)
POLK 1	0.81%	85.50	86.8	83.0	241.1	(84.9)	71.5%	(84.9)
BAYSIDE 1	1.35%	94.77	95.2	93.8	401.1	(1,665.7)	94.7%	(121.6)
BAYSIDE 2	0.95%	79.96	81.4	77.1	280.9	(224.1)	80.3%	53.5
GPIF SYSTEM	24.19%				7,191.3	(6,271.5)		

AVERAGE NET OPERATING HEAT RATE (Btu/kwh)

<u>PLANT / UNIT</u>	<u>WEIGHTING FACTOR (%)</u>	<u>ANOHR (Btu/kwh)</u>	<u>TARGET NOF (%)</u>	<u>ANOHR TARGET RANGE</u>		<u>MAX. FUEL SAVINGS (\$000)</u>	<u>MAX. FUEL LOSS (\$000)</u>	<u>ACTUAL ADJUSTED ANOHR</u>	<u>ACTUAL FUEL SAVINGS/ LOSS (\$000)</u>
				<u>MIN.</u>	<u>MAX.</u>				
BIG BEND 1	19.20%	10,468	92.9	9.836	11.101	5,705.6	(5,705.6)	10,467	0.0
BIG BEND 2	12.41%	10,272	92.9	9.862	10.682	3,688.3	(3,688.3)	10,356	(100.1)
BIG BEND 3	12.03%	10,614	86.1	10.209	11.018	3,576.1	(3,576.1)	10,595	0.0
BIG BEND 4	11.77%	10,549	88.0	10.157	10.941	3,499.1	(3,499.1)	10,420	593.2
POLK 1	6.81%	10,220	94.2	9.915	10.525	2,023.9	(2,023.9)	10,619	(2,023.9)
BAYSIDE 1	6.86%	7,248	82.6	7.120	7.377	2,040.2	(2,040.2)	7,206	0.0
BAYSIDE 2	6.73%	7,316	83.2	7.189	7.442	1,998.9	(1,998.9)	7,286	0.0
GPIF SYSTEM	75.81%					22,532.3	(22,532.3)		

**TAMPA ELECTRIC COMPANY
UNIT PERFORMANCE DATA - ACTUAL
JANUARY 2012 - DECEMBER 2012**

<u>PLANT / UNIT</u>	<u>ACTUAL EAF (%)</u>	<u>ADJUSTMENTS (1) TO EAF (%)</u>	<u>EAF ADJUSTED ACTUAL (%)</u>
BIG BEND 1	67.0	0.8	67.8
BIG BEND 2	78.1	-1.4	76.7
BIG BEND 3	72.2	-2.9	69.3
BIG BEND 4	75.7	1.2	76.9
POLK 1	70.0	1.5	71.5
BAYSIDE 1	96.3	-1.6	94.7
BAYSIDE 2	78.8	1.5	80.3

<u>PLANT / UNIT</u>	<u>ACTUAL ANOHR (Btu/kwh)</u>	<u>ADJUSTMENTS (2) TO ANOHR (Btu/kwh)</u>	<u>ANOHR ADJUSTED ACTUAL (Btu/kwh)</u>
BIG BEND 1	10479	-12	10467
BIG BEND 2	10391	-35	10356
BIG BEND 3	10637	-42	10595
BIG BEND 4	10437	-17	10420
POLK 1	10696	-77	10619
BAYSIDE 1	7223	-17	7206
BAYSIDE 2	7355	-69	7286

(1) Documentation of adjustments to Actual EAF on pages 7 - 13

(2) Documentation of adjustments to Actual ANOHR on pages 14 - 20

**TAMPA ELECTRIC COMPANY
ADJUSTMENTS TO PERFORMANCE
BIG BEND UNIT NO. 1
JANUARY 2012 - DECEMBER 2012**

WEIGHTING FACTOR = 0.30%

	<u>12 MONTH TARGET</u>	<u>12 MONTH ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
PH	8784.0	8784.0	8784.0
EAF	81.9	67.0	67.8
POH	504.0	600.0	504.0
FOH + EFOH	817.4	2239.0	2265.3
MOH + EMOH	271.6	59.7	60.4
POF	5.7	6.8	5.7
EFOF	9.3	25.5	25.8
EMOF	3.1	0.7	0.7
	-10.000	EQUIVALENT AVAILABILITY POINTS	

ADJUSTMENTS TO ACTUAL EAF FOR COMPARISON

$$\frac{PH - POH_{TARGET}}{PH - POH_{ACTUAL}} \times (FOH + EFOH + MOH + EMOH) = EUOH_{ADJUSTED}$$

$$\frac{8784 - 504}{8784 - 600} \times (2239 + 59.7) = 2325.7$$

$$100 - POF_{TARGET} - \frac{EUOH_{ADJUSTED}}{PH} \times 100 = EAF_{ADJUSTED}$$

$$100 - 5.7 - \frac{2325.7}{8784.0} \times 100 = 67.8$$

PH = PERIOD HOURS
EAF = EQUIVALENT AVAILABILITY FACTOR
POH = PLANNED OUTAGE HOURS
FOH = FORCED OUTAGE HOURS
EFOH = EQUIVALENT FORCED OUTAGE HOURS
MOH = MAINTENANCE OUTAGE HOURS
EMOH = EQUIVALENT MAINTENANCE OUTAGE HOURS
POF = PLANNED OUTAGE FACTOR
EFOF = EQUIVALENT FORCED OUTAGE FACTOR
EMOF = EQUIVALENT MAINTENANCE OUTAGE FACTOR

TAMPA ELECTRIC COMPANY
ADJUSTMENTS TO PERFORMANCE
BIG BEND UNIT NO. 2
JANUARY 2012 - DECEMBER 2012

WEIGHTING FACTOR = 5.09%

	<u>12 MONTH TARGET</u>	<u>12 MONTH ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
PH	8784.0	8784.0	8784.0
EAF	76.2	78.1	76.7
POH	504.0	353.5	504.0
FOH + EFOH	1466.0	1228.1	1206.2
MOH + EMOH	122.2	346.4	340.2
POF	5.7	4.0	5.7
EFOF	16.7	14.0	13.7
EMOF	1.4	3.9	3.9
	1.326	EQUIVALENT AVAILABILITY POINTS	

ADJUSTMENTS TO ACTUAL EAF FOR COMPARISON

$$\frac{PH - POH_{TARGET}}{PH - POH_{ACTUAL}} \times (FOH + EFOH + MOH + EMOH) = EUOH_{ADJUSTED}$$

$$\frac{8784 - 504}{8784 - 353.5} \times (1228.1 + 346.4) = 1546.4$$

$$100 - POF_{TARGET} - \frac{EUOH_{ADJUSTED}}{PH} \times 100 = EAF_{ADJUSTED}$$

$$100 - 5.7 - \frac{1546.4}{8784.0} \times 100 = 76.7$$

PH = PERIOD HOURS
EAF = EQUIVALENT AVAILABILITY FACTOR
POH = PLANNED OUTAGE HOURS
FOH = FORCED OUTAGE HOURS
EFOH = EQUIVALENT FORCED OUTAGE HOURS
MOH = MAINTENANCE OUTAGE HOURS
EMOH = EQUIVALENT MAINTENANCE OUTAGE HOURS
POF = PLANNED OUTAGE FACTOR
EFOF = EQUIVALENT FORCED OUTAGE FACTOR
EMOF = EQUIVALENT MAINTENANCE OUTAGE FACTOR

**TAMPA ELECTRIC COMPANY
ADJUSTMENTS TO PERFORMANCE
BIG BEND UNIT NO. 3
JANUARY 2012 - DECEMBER 2012**

WEIGHTING FACTOR = 9.20%

	<u>12 MONTH TARGET</u>	<u>12 MONTH ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
PH	8784.0	8784.0	8784.0
EAF	80.0	72.2	69.3
POH	576.0	247.3	576.0
FOH + EFOH	974.7	1887.2	1814.5
MOH + EMOH	208.1	310.0	298.1
POF	6.6	2.8	6.6
EFOF	11.1	21.5	20.7
EMOF	2.4	3.5	3.4
	-10.000		EQUIVALENT AVAILABILITY POINTS

ADJUSTMENTS TO ACTUAL EAF FOR COMPARISON

$$\frac{PH - POH_{TARGET}}{PH - POH_{ACTUAL}} \times (FOH + EFOH + MOH + EMOH) = EUOH_{ADJUSTED}$$

$$\frac{8784 - 576}{8784 - 247.3} \times (1887.2 + 310) = 2112.6$$

$$100 - POF_{TARGET} - \frac{EUOH_{ADJUSTED}}{PH} \times 100 = EAF_{ADJUSTED}$$

$$100 - 6.6 - \frac{2112.6}{8784.0} \times 100 = 69.3$$

PH = PERIOD HOURS
EAF = EQUIVALENT AVAILABILITY FACTOR
POH = PLANNED OUTAGE HOURS
FOH = FORCED OUTAGE HOURS
EFOH = EQUIVALENT FORCED OUTAGE HOURS
MOH = MAINTENANCE OUTAGE HOURS
EMOH = EQUIVALENT MAINTENANCE OUTAGE HOURS
POF = PLANNED OUTAGE FACTOR
EFOF = EQUIVALENT FORCED OUTAGE FACTOR
EMOF = EQUIVALENT MAINTENANCE OUTAGE FACTOR

**TAMPA ELECTRIC COMPANY
ADJUSTMENTS TO PERFORMANCE
BIG BEND UNIT NO. 4
JANUARY 2012 - DECEMBER 2012**

WEIGHTING FACTOR = 6.50%

	<u>12 MONTH TARGET</u>	<u>12 MONTH ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
PH	8784.0	8784.0	8784.0
EAF	77.4	75.7	76.9
POH	576.0	717.1	576.0
FOH + EFOH	1111.1	1102.1	1121.4
MOH + EMOH	297.3	318.2	323.8
POF	6.6	8.2	6.6
EFOF	12.6	12.5	12.8
EMOF	3.4	3.6	3.7
	-0.720	EQUIVALENT AVAILABILITY POINTS	

ADJUSTMENTS TO ACTUAL EAF FOR COMPARISON

$$\frac{PH - POH_{TARGET}}{PH - POH_{ACTUAL}} \times (FOH + EFOH + MOH + EMOH) = EUOH_{ADJUSTED}$$

$$\frac{8784 - 576}{8784 - 717.1} \times (1102.1 + 318.2) = 1445.1$$

$$100 - POF_{TARGET} - \frac{EUOH_{ADJUSTED}}{PH} \times 100 = EAF_{ADJUSTED}$$

$$100 - 6.6 - \frac{1445.1}{8784.0} \times 100 = 76.9$$

PH = PERIOD HOURS
EAF = EQUIVALENT AVAILABILITY FACTOR
POH = PLANNED OUTAGE HOURS
FOH = FORCED OUTAGE HOURS
EFOH = EQUIVALENT FORCED OUTAGE HOURS
MOH = MAINTENANCE OUTAGE HOURS
EMOH = EQUIVALENT MAINTENANCE OUTAGE HOURS
POF = PLANNED OUTAGE FACTOR
EFOF = EQUIVALENT FORCED OUTAGE FACTOR
EMOF = EQUIVALENT MAINTENANCE OUTAGE FACTOR

**TAMPA ELECTRIC COMPANY
ADJUSTMENTS TO PERFORMANCE
POLK UNIT NO. 1
JANUARY 2012 - DECEMBER 2012**

WEIGHTING FACTOR = 0.81%

	<u>12 MONTH TARGET</u>	<u>12 MONTH ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
PH	8784.0	8784.0	8784.0
EAF	85.5	70.0	71.5
POH	960.0	1115.4	960.0
FOH + EFOH	177.7	1418.4	1447.1
MOH + EMOH	136.1	99.3	101.3
POF	10.9	12.7	10.9
EFOF	2.0	16.1	16.5
EMOF	1.5	1.1	1.2
	-10.000		EQUIVALENT AVAILABILITY POINTS

ADJUSTMENTS TO ACTUAL EAF FOR COMPARISON

$$\frac{PH - POH_{TARGET}}{PH - POH_{ACTUAL}} \times (FOH + EFOH + MOH + EMOH) = EUOH_{ADJUSTED}$$

$$\frac{8784 - 960}{8784 - 1115.4} \times (1418.4 + 99.3) = 1548.5$$

$$100 - POF_{TARGET} - \frac{EUOH_{ADJUSTED}}{PH} \times 100 = EAF_{ADJUSTED}$$

$$100 - 10.9 - \frac{1548.5}{8784.0} \times 100 = 71.5$$

PH = PERIOD HOURS
EAF = EQUIVALENT AVAILABILITY FACTOR
POH = PLANNED OUTAGE HOURS
FOH = FORCED OUTAGE HOURS
EFOH = EQUIVALENT FORCED OUTAGE HOURS
MOH = MAINTENANCE OUTAGE HOURS
EMOH = EQUIVALENT MAINTENANCE OUTAGE HOURS
POF = PLANNED OUTAGE FACTOR
EFOF = EQUIVALENT FORCED OUTAGE FACTOR
EMOF = EQUIVALENT MAINTENANCE OUTAGE FACTOR

**TAMPA ELECTRIC COMPANY
ADJUSTMENTS TO PERFORMANCE
BAYSIDE UNIT NO. 1
JANUARY 2012 - DECEMBER 2012**

WEIGHTING FACTOR = 1.35%

	<u>12 MONTH TARGET</u>	<u>12 MONTH ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
PH	8784.0	8784.0	8784.0
EAF	94.8	96.3	94.7
POH	336.0	190.0	336.0
FOH + EFOH	30.6	27.4	26.9
MOH + EMOH	92.9	106.1	104.3
POF	3.8	2.2	3.8
EFOF	0.3	0.3	0.3
EMOF	1.1	1.2	1.2
	-0.730		EQUIVALENT AVAILABILITY POINTS

ADJUSTMENTS TO ACTUAL EAF FOR COMPARISON

$$\frac{PH - POH_{TARGET}}{PH - POH_{ACTUAL}} \times (FOH + EFOH + MOH + EMOH) = EUOH_{ADJUSTED}$$

$$\frac{8784 - 336}{8784 - 190} \times (27.4 + 106.1) = 131.2$$

$$100 - POF_{TARGET} - \frac{EUOH_{ADJUSTED}}{PH} \times 100 = EAF_{ADJUSTED}$$

$$100 - 3.8 - \frac{131.2}{8784.0} \times 100 = 94.7$$

PH = PERIOD HOURS
EAF = EQUIVALENT AVAILABILITY FACTOR
POH = PLANNED OUTAGE HOURS
FOH = FORCED OUTAGE HOURS
EFOH = EQUIVALENT FORCED OUTAGE HOURS
MOH = MAINTENANCE OUTAGE HOURS
EMOH = EQUIVALENT MAINTENANCE OUTAGE HOURS
POF = PLANNED OUTAGE FACTOR
EFOF = EQUIVALENT FORCED OUTAGE FACTOR
EMOF = EQUIVALENT MAINTENANCE OUTAGE FACTOR

TAMPA ELECTRIC COMPANY
ADJUSTMENTS TO PERFORMANCE
BAYSIDE UNIT NO. 2
JANUARY 2012 - DECEMBER 2012

WEIGHTING FACTOR = 0.95%

	<u>12 MONTH TARGET</u>	<u>12 MONTH ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
PH	8784.0	8784.0	8784.0
EAF	80.0	78.8	80.3
POH	1511.0	1649.7	1511.0
FOH + EFOH	8.6	101.0	103.0
MOH + EMOH	240.8	115.1	117.3
POF	17.2	18.8	17.2
EFOF	0.1	1.1	1.2
EMOF	2.7	1.3	1.3
	2.387	EQUIVALENT AVAILABILITY POINTS	

ADJUSTMENTS TO ACTUAL EAF FOR COMPARISON

$$\frac{PH - POH_{TARGET}}{PH - POH_{ACTUAL}} \times (FOH + EFOH + MOH + EMOH) = EUOH_{ADJUSTED}$$

$$\frac{8784 - 1511}{8784 - 1649.7} \times (101 + 115.1) = 220.3$$

$$100 - POF_{TARGET} - \frac{EUOH_{ADJUSTED}}{PH} \times 100 = EAF_{ADJUSTED}$$

$$100 - 17.2 - \frac{220.3}{8784.0} \times 100 = 80.3$$

PH = PERIOD HOURS
EAF = EQUIVALENT AVAILABILITY FACTOR
POH = PLANNED OUTAGE HOURS
FOH = FORCED OUTAGE HOURS
EFOH = EQUIVALENT FORCED OUTAGE HOURS
MOH = MAINTENANCE OUTAGE HOURS
EMOH = EQUIVALENT MAINTENANCE OUTAGE HOURS
POF = PLANNED OUTAGE FACTOR
EFOF = EQUIVALENT FORCED OUTAGE FACTOR
EMOF = EQUIVALENT MAINTENANCE OUTAGE FACTOR

**TAMPA ELECTRIC COMPANY
ADJUSTMENTS TO HEAT RATE
BIG BEND UNIT NO. 1
JANUARY 2012 - DECEMBER 2012**

WEIGHTING FACTOR = 19.20%

	<u>12 MONTH TARGET</u>	<u>12 MONTH ACTUAL PERFORMANCE</u>
ANOHR (Btu/kwh)	10468	10479
NET GENERATION (GWH)	2682.5	2154.2
OPERATING BTU (10 ⁹)	27394.1	22572.8
NET OUTPUT FACTOR	92.9	92.3

0.000 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON

CURRENT EQUATION: $NOF * (-18.44) + 12181.88 = ANOHR$

$92.3 * (-18.44) + 12181.88 = 10480$

$10479 - 10480 = -1$

$10468 + -1 = 10467$ ← ADJUSTED ACTUAL HEAT RATE AT TARGET NOF

ANOHR = AVERAGE NET OPERATING HEAT RATE
NOF = NET OPERATING FACTOR

**TAMPA ELECTRIC COMPANY
ADJUSTMENTS TO HEAT RATE
BIG BEND UNIT NO. 2
JANUARY 2012 - DECEMBER 2012**

WEIGHTING FACTOR = 12.41%

	<u>12 MONTH TARGET</u>	<u>12 MONTH ACTUAL PERFORMANCE</u>
ANOHR (Btu/kwh)	10272	10391
NET GENERATION (GWH)	2541.3	2519.2
OPERATING BTU (10 ⁹)	26047.1	26177.2
NET OUTPUT FACTOR	92.9	88.2

-0.272 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON

CURRENT EQUATION: $NOF * (-7.53) + 10970.84 = ANOHR$

$88.2 * (-7.53) + 10970.84 = 10307$

$10391 - 10307 = 84$

$10272 + 84 = 10356$ ← ADJUSTED ACTUAL
HEAT RATE AT
TARGET NOF

ANOHR = AVERAGE NET OPERATING HEAT RATE
NOF = NET OPERATING FACTOR

**TAMPA ELECTRIC COMPANY
ADJUSTMENTS TO HEAT RATE
BIG BEND UNIT NO. 3
JANUARY 2012 - DECEMBER 2012**

WEIGHTING FACTOR = 12.03%

	<u>12 MONTH TARGET</u>	<u>12 MONTH ACTUAL PERFORMANCE</u>
ANOHR (Btu/kwh)	10614	10637
NET GENERATION (GWH)	2292.9	2220.0
OPERATING BTU (10 ⁹)	23882.8	23613.5
NET OUTPUT FACTOR	86.1	84.1

0.000 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON

CURRENT EQUATION: $NOF * (-20.71) + 12396.79 = ANOHR$

$84.1 * (-20.71) + 12396.79 = 10655$

$10637 - 10655 = -18$

$10614 + -18 = 10595$ ← ADJUSTED ACTUAL HEAT RATE AT TARGET NOF

ANOHR = AVERAGE NET OPERATING HEAT RATE
NOF = NET OPERATING FACTOR

**TAMPA ELECTRIC COMPANY
ADJUSTMENTS TO HEAT RATE
BIG BEND UNIT NO. 4
JANUARY 2012 - DECEMBER 2012**

WEIGHTING FACTOR = 11.77%

	<u>12 MONTH TARGET</u>	<u>12 MONTH ACTUAL PERFORMANCE</u>
ANOHR (Btu/kwh)	10549	10437
NET GENERATION (GWH)	2640.4	2622.2
OPERATING BTU (10 ⁹)	27265.0	27367.3
NET OUTPUT FACTOR	88.0	87.4

1.695 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON

CURRENT EQUATION: $NOF * (-30.91) + 13267.86 = ANOHR$

$87.4 * (-30.91) + 13267.86 = 10566$

$10437 - 10566 = -129$

$10549 + -129 = 10420$ ← ADJUSTED ACTUAL HEAT RATE AT TARGET NOF

ANOHR = AVERAGE NET OPERATING HEAT RATE
NOF = NET OPERATING FACTOR

**TAMPA ELECTRIC COMPANY
ADJUSTMENTS TO HEAT RATE
POLK UNIT NO. 1
JANUARY 2012 - DECEMBER 2012**

WEIGHTING FACTOR = 6.81%

	<u>12 MONTH TARGET</u>	<u>12 MONTH ACTUAL PERFORMANCE</u>
ANOHR (Btu/kwh)	10220	10696
NET GENERATION (GWH)	1577.4	1194.9
OPERATING BTU (10 ⁹)	16148.8	12780.5
NET OUTPUT FACTOR	94.2	92.5

-10.000 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON

CURRENT EQUATION: $NOF * (-45.48) + 14503.53 = ANOHR$

$92.5 * (-45.48) + 14503.53 = 10297$

$10696 - 10297 = 399$

$10220 + 399 = 10619$ ← ADJUSTED ACTUAL HEAT RATE AT TARGET NOF

ANOHR = AVERAGE NET OPERATING HEAT RATE
NOF = NET OPERATING FACTOR

**TAMPA ELECTRIC COMPANY
ADJUSTMENTS TO HEAT RATE
BAYSIDE UNIT NO. 1
JANUARY 2012 - DECEMBER 2012**

WEIGHTING FACTOR = 6.86%

	<u>12 MONTH TARGET</u>	<u>12 MONTH ACTUAL PERFORMANCE</u>
ANOHR (Btu/kwh)	7248	7223
NET GENERATION (GWH)	3190.4	3110.8
OPERATING BTU (10 ⁹)	23898.5	22467.8
NET OUTPUT FACTOR	82.6	76.6

0.000 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON

CURRENT EQUATION: $NOF * (-18.44) + 12181.88 = ANOHR$

$76.6 * (-2.82) + 7480.94 = 7265$

$7223 - 7265 = -42$

$7248 + -42 = 7206$ ← ADJUSTED ACTUAL HEAT RATE AT TARGET NOF

ANOHR = AVERAGE NET OPERATING HEAT RATE
NOF = NET OPERATING FACTOR

**TAMPA ELECTRIC COMPANY
ADJUSTMENTS TO HEAT RATE
BAYSIDE UNIT NO. 2
JANUARY 2012 - DECEMBER 2012**

WEIGHTING FACTOR = 6.73%

	<u>12 MONTH TARGET</u>	<u>12 MONTH ACTUAL PERFORMANCE</u>
ANOHR (Btu/kwh)	7316	7355
NET GENERATION (GWH)	4142.3	3931.0
OPERATING BTU (10 ⁹)	30994.1	28910.7
NET OUTPUT FACTOR	83.2	75.0

0.000 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON

CURRENT EQUATION: $NOF * (-18.44) + 12181.88 = ANOHR$

$75 * (-8.47) + 8020.05 = 7385$

$7355 - 7385 = -30$


$7316 + -30 = 7286$ ← ADJUSTED ACTUAL HEAT RATE AT TARGET NOF

ANOHR = AVERAGE NET OPERATING HEAT RATE
NOF = NET OPERATING FACTOR

**TAMPA ELECTRIC COMPANY
PLANNED OUTAGE SCHEDULE (ACTUAL)
GPIF UNITS
JANUARY 2012 - DECEMBER 2012**


<u>PLANT / UNIT</u>	<u>PLANNED OUTAGE DATES</u>	<u>OUTAGE DESCRIPTION</u>
BIG BEND 1	Apr 08 - May 03 Dec 08 - Dec 14	Fuel System Cleanup and Scrubber work Fuel System Cleanup and Scrubber work
BIG BEND 2	Apr 16 - Apr 30	Fuel System Cleanup and Scrubber work
BIG BEND 3	Mar 03 - Mar 13	Fuel System Cleanup and Scrubber work
BIG BEND 4	May 05 - May 18 Sep 26 - Oct 13	Fuel System Cleanup and Scrubber work Fuel System Cleanup and Scrubber work
+ POLK 1	Jan 13 - Feb 28	Commenced Major Outage, Steam Turbine Generator Valve work, Sulfuric Acid Plant catalyst replacement, Carbonyl Sulfide catalyst replacement, Air Separation Unit Big Motor work
BAYSIDE 1	Nov 12 - Nov 18	Fuel System Cleanup
+ BAYSIDE 2	Feb 07 - Apr 08	Commenced Major Outage, GSU replacement, Steam Path inspection, HP/IP/LP Steam Turbine Ring and Seal replacements, Steam Turbine Valve overhauls, Heat Exchanger replacements, Coarse Mesh Screen replacements, CT Major Overhauls and CT Inlet Filter replacements
+ CPM for units with less than or equal to 4 weeks are not included.		

TAMPA ELECTRIC COMPANY
CRITICAL PATH METHOD DIAGRAMS
GPIF UNITS > FOUR WEEKS
JANUARY 2012 - DECEMBER 2012



TAMPA ELECTRIC COMPANY
POLK UNIT 1
PLANNED OUTAGE 2012
ACTUAL CPM

**TAMPA ELECTRIC COMPANY
 CRITICAL PATH METHOD DIAGRAMS
 GPIF UNITS > FOUR WEEKS
 JANUARY 2012 - DECEMBER 2012**



TAMPA ELECTRIC COMPANY
BAYSIDE UNIT 2
PLANNED OUTAGE 2012
ACTUAL CPM

TAMPA ELECTRIC COMPANY
GENERATING PERFORMANCE INCENTIVE POINTS TABLE
JANUARY 2012 - DECEMBER 2012

BIG BEND 1

<u>EQUIVALENT AVAILABILITY POINTS</u>	<u>FUEL SAVINGS / (LOSS) (\$000)</u>	<u>ADJUSTED ACTUAL EQUIVALENT AVAILABILITY</u>	<u>AVERAGE HEAT RATE POINTS</u>	<u>FUEL SAVINGS / (LOSS) (\$000)</u>	<u>ADJUSTED ACTUAL AVERAGE HEAT RATE</u>
+10	89.3	84.6	+10	5,705.6	9,836
+9	80.4	84.4	+9	5,135.1	9,891
+8	71.4	84.1	+8	4,564.5	9,947
+7	62.5	83.8	+7	3,994.0	10,003
+6	53.6	83.5	+6	3,423.4	10,059
+5	44.7	83.2	+5	2,852.8	10,114
+4	35.7	83.0	+4	2,282.3	10,170
+3	26.8	82.7	+3	1,711.7	10,226
+2	17.9	82.4	+2	1,141.1	10,282
+1	8.9	82.1	+1	570.6	10,337
					10,393
0	0.0	81.9	0	0.0	10,468
				AHR POINTS 0.000	Adjusted ANOHR 10,467
-1	(93.6)	81.3	-1	(570.6)	10,599
-2	(187.3)	80.8	-2	(1,141.1)	10,655
-3	(280.9)	80.2	-3	(1,711.7)	10,710
-4	(374.5)	79.7	-4	(2,282.3)	10,766
-5	(468.1)	79.1	-5	(2,852.8)	10,822
-6	(561.8)	78.5	-6	(3,423.4)	10,878
-7	(655.4)	78.0	-7	(3,994.0)	10,933
-8	(749.0)	77.4	-8	(4,564.5)	10,989
-9	(842.7)	76.9	-9	(5,135.1)	11,045
-10	(936.3)	76.3	-10	(5,705.6)	11,101
	EAFF POINTS -10.000	Adjusted EAFF 67.8			

Weighting Factor =

0.30%

Weighting Factor =

19.20%

TAMPA ELECTRIC COMPANY
GENERATING PERFORMANCE INCENTIVE POINTS TABLE
JANUARY 2012 - DECEMBER 2012

BIG BEND 2

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS / (LOSS) (\$000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS / (LOSS) (\$000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	1,512.2	80.1	+10	3,688.3	9,862
+9	1,360.9	79.7	+9	3,319.5	9,895
+8	1,209.7	79.3	+8	2,950.7	9,929
+7	1,058.5	78.9	+7	2,581.8	9,962
+6	907.3	78.5	+6	2,213.0	9,996
+5	756.1	78.1	+5	1,844.2	10,029
+4	604.9	77.7	+4	1,475.3	10,063
+3	453.6	77.4	+3	1,106.5	10,096
+2	302.4	77.0	+2	737.7	10,130
+1	151.2	76.6	+1	368.8	10,163
0	0.0	76.2	0	0.0	10,197
-1	(12.2)	75.4	-1	(368.8)	10,272
-2	(24.5)	74.6	-2	(737.7)	10,347
-3	(36.7)	73.8	-3	(1,106.5)	10,380
-4	(48.9)	73.1	-4	(1,475.3)	10,414
-5	(61.1)	72.3	-5	(1,844.2)	10,448
-6	(73.4)	71.5	-6	(2,213.0)	10,481
-7	(85.6)	70.7	-7	(2,581.8)	10,515
-8	(97.8)	69.9	-8	(2,950.7)	10,548
-9	(110.0)	69.2	-9	(3,319.5)	10,582
-10	(122.3)	68.4	-10	(3,688.3)	10,615
					10,649
					10,682

EAF POINTS 1.136

Adjusted EAF 76.7

AHR POINTS -0.272

Adjusted ANOHR 10,356

Weighting Factor =

5.09%

Weighting Factor =

12.41%

TAMPA ELECTRIC COMPANY
GENERATING PERFORMANCE INCENTIVE POINTS TABLE
JANUARY 2012 - DECEMBER 2012

BIG BEND 3

<u>EQUIVALENT AVAILABILITY POINTS</u>	<u>FUEL SAVINGS / (LOSS) (\$000)</u>	<u>ADJUSTED ACTUAL EQUIVALENT AVAILABILITY</u>	<u>AVERAGE HEAT RATE POINTS</u>	<u>FUEL SAVINGS / (LOSS) (\$000)</u>	<u>ADJUSTED ACTUAL AVERAGE HEAT RATE</u>
+10	2,734.4	83.0	+10	3,576.1	10,209
+9	2,461.0	82.7	+9	3,218.5	10,242
+8	2,187.5	82.4	+8	2,860.9	10,275
+7	1,914.1	82.1	+7	2,503.3	10,308
+6	1,640.6	81.8	+6	2,145.7	10,341
+5	1,367.2	81.5	+5	1,788.1	10,374
+4	1,093.8	81.2	+4	1,430.5	10,407
+3	820.3	80.9	+3	1,072.8	10,440
+2	546.9	80.6	+2	715.2	10,473
+1	273.4	80.3	+1	357.6	10,506
0	0.0	80.0	0	0.0	10,539
-1	(168.5)	79.4	-1	(357.6)	10,614
-2	(337.0)	78.8	-2	(715.2)	10,689
-3	(505.5)	78.2	-3	(1,072.8)	10,722
-4	(674.0)	77.6	-4	(1,430.5)	10,755
-5	(842.5)	77.0	-5	(1,788.1)	10,788
-6	(1,011.0)	76.4	-6	(2,145.7)	10,820
-7	(1,179.5)	75.8	-7	(2,503.3)	10,853
-8	(1,348.0)	75.1	-8	(2,860.9)	10,886
-9	(1,516.5)	74.5	-9	(3,218.5)	10,919
-10	(1,685.0)	73.9	-10	(3,576.1)	10,952

← **AHR POINTS 8.000** →

← **Adjusted ANOHR 10,595** →

← **EAF POINTS -10.000** →

← **Adjusted EAF 69.3** →

Weighting Factor =

9.20%


Weighting Factor =

12.03%

TAMPA ELECTRIC COMPANY
GENERATING PERFORMANCE INCENTIVE POINTS TABLE
JANUARY 2012 - DECEMBER 2012

BIG BEND 4

<u>EQUIVALENT AVAILABILITY POINTS</u>	<u>FUEL SAVINGS / (LOSS) (\$000)</u>	<u>ADJUSTED ACTUAL EQUIVALENT AVAILABILITY</u>	<u>AVERAGE HEAT RATE POINTS</u>	<u>FUEL SAVINGS / (LOSS) (\$000)</u>	<u>ADJUSTED ACTUAL AVERAGE HEAT RATE</u>
+10	1,932.3	80.9	+10	3,499.1	10,157
+9	1,739.1	80.6	+9	3,149.2	10,188
+8	1,545.8	80.2	+8	2,799.3	10,220
+7	1,352.6	79.9	+7	2,449.4	10,252
+6	1,159.4	79.5	+6	2,099.5	10,283
+5	966.1	79.2	+5	1,749.5	10,315
+4	772.9	78.8	+4	1,399.6	10,347
+3	579.7	78.5	+3	1,049.7	10,379
+2	386.5	78.1	+2	699.8	10,410
+1	193.2	77.8	+1	349.9	10,442
					10,474
0	0.0	77.4	0	0.0	10,549
					10,624
-1	(155.3)	76.7	-1	(349.9)	10,656
-2	(310.7)	76.0	-2	(699.8)	10,687
-3	(466.0)	75.3	-3	(1,049.7)	10,719
-4	(621.3)	74.6	-4	(1,399.6)	10,751
-5	(776.6)	73.9	-5	(1,749.5)	10,782
-6	(932.0)	73.2	-6	(2,099.5)	10,814
-7	(1,087.3)	72.5	-7	(2,449.4)	10,846
-8	(1,242.6)	71.8	-8	(2,799.3)	10,878
-9	(1,397.9)	71.0	-9	(3,149.2)	10,909
-10	(1,553.3)	70.3	-10	(3,499.1)	10,941



Weighting Factor =

6.50%

Weighting Factor =

11.77%

TAMPA ELECTRIC COMPANY
GENERATING PERFORMANCE INCENTIVE POINTS TABLE
JANUARY 2012 - DECEMBER 2012

POLK 1

<u>EQUIVALENT AVAILABILITY POINTS</u>	<u>FUEL SAVINGS / (LOSS) (\$000)</u>	<u>ADJUSTED ACTUAL EQUIVALENT AVAILABILITY</u>	<u>AVERAGE HEAT RATE POINTS</u>	<u>FUEL SAVINGS / (LOSS) (\$000)</u>	<u>ADJUSTED ACTUAL AVERAGE HEAT RATE</u>
+10	241.1	86.8	+10	2,023.9	9,915
+9	217.0	86.6	+9	1,821.5	9,938
+8	192.9	86.5	+8	1,619.1	9,961
+7	168.7	86.4	+7	1,416.7	9,984
+6	144.6	86.3	+6	1,214.4	10,007
+5	120.5	86.1	+5	1,012.0	10,030
+4	96.4	86.0	+4	809.6	10,053
+3	72.3	85.9	+3	607.2	10,076
+2	48.2	85.8	+2	404.8	10,099
+1	24.1	85.6	+1	202.4	10,122
0	0.0	85.5	0	0.0	10,145
-1	(8.5)	85.2	-1	(202.4)	10,220
-2	(17.0)	85.0	-2	(404.8)	10,295
-3	(25.5)	84.7	-3	(607.2)	10,318
-4	(33.9)	84.5	-4	(809.6)	10,341
-5	(42.4)	84.2	-5	(1,012.0)	10,364
-6	(50.9)	84.0	-6	(1,214.4)	10,387
-7	(59.4)	83.7	-7	(1,416.7)	10,410
-8	(67.9)	83.5	-8	(1,619.1)	10,433
-9	(76.4)	83.2	-9	(1,821.5)	10,456
-10	(84.9)	83.0	-10	(2,023.9)	10,479

EAFF POINTS
-10,000

Adjusted EAFF
71.5

AHR POINTS
-10,000

Adjusted ANOHR
10,619

Weighting Factor = 0.81%

Weighting Factor = 6.81%

TAMPA ELECTRIC COMPANY
GENERATING PERFORMANCE INCENTIVE POINTS TABLE
JANUARY 2012 - DECEMBER 2012

BAYSIDE 1

<u>EQUIVALENT AVAILABILITY POINTS</u>	<u>FUEL SAVINGS / (LOSS) (\$000)</u>	<u>ADJUSTED ACTUAL EQUIVALENT AVAILABILITY</u>	<u>AVERAGE HEAT RATE POINTS</u>	<u>FUEL SAVINGS / (LOSS) (\$000)</u>	<u>ADJUSTED ACTUAL AVERAGE HEAT RATE</u>
+10	401.1	95.2	+10	2,040.2	7,120
+9	361.0	95.2	+9	1,836.2	7,125
+8	320.9	95.1	+8	1,632.2	7,130
+7	280.8	95.1	+7	1,428.2	7,136
+6	240.7	95.1	+6	1,224.1	7,141
+5	200.6	95.0	+5	1,020.1	7,146
+4	160.4	95.0	+4	816.1	7,152
+3	120.3	94.9	+3	612.1	7,157
+2	80.2	94.9	+2	408.0	7,163
+1	40.1	94.8	+1	204.0	7,168
0	0.0	94.8	0	0.0	7,173
-1	(166.6)	94.7	-1	(204.0)	7,248
-2	(333.1)	94.6	-2	(408.0)	7,323
-3	(499.7)	94.5	-3	(612.1)	7,329
-4	(666.3)	94.4	-4	(816.1)	7,334
-5	(832.8)	94.3	-5	(1,020.1)	7,339
-6	(999.4)	94.2	-6	(1,224.1)	7,345
-7	(1,166.0)	94.1	-7	(1,428.2)	7,350
-8	(1,332.6)	94.0	-8	(1,632.2)	7,355
-9	(1,499.1)	93.9	-9	(1,836.2)	7,361
-10	(1,665.7)	93.8	-10	(2,040.2)	7,366
					7,371
					7,377

**EAF
POINTS
-8.730**

**Adjusted
EAF
94.7**

**AHR
POINTS
8.000**

**Adjusted
AHR
7.206**

Weighting Factor =

1.35%

Weighting Factor =

6.86%

TAMPA ELECTRIC COMPANY
GENERATING PERFORMANCE INCENTIVE POINTS TABLE
JANUARY 2012 - DECEMBER 2012

BAYSIDE 2

<u>EQUIVALENT AVAILABILITY POINTS</u>	<u>FUEL SAVINGS / (LOSS) (\$000)</u>	<u>ADJUSTED ACTUAL EQUIVALENT AVAILABILITY</u>	<u>AVERAGE HEAT RATE POINTS</u>	<u>FUEL SAVINGS / (LOSS) (\$000)</u>	<u>ADJUSTED ACTUAL AVERAGE HEAT RATE</u>
+10	280.9	81.4	+10	1,998.9	7,189
+9	252.8	81.2	+9	1,799.1	7,194
+8	224.7	81.1	+8	1,599.2	7,199
+7	196.6	81.0	+7	1,399.3	7,205
+6	168.5	80.8	+6	1,199.4	7,210
+5	140.5	80.7	+5	999.5	7,215
+4	112.4	80.5	+4	799.6	7,220
+3	84.3	80.4	+3	599.7	7,225
+2	56.2	80.2	+2	399.8	7,230
+1	28.1	80.1	+1	199.9	7,236
0	0.0	80.0	0	0.0	7,241
-1	(22.4)	79.7	-1	(199.9)	7,396
-2	(44.8)	79.4	-2	(399.8)	7,401
-3	(67.2)	79.1	-3	(599.7)	7,406
-4	(89.7)	78.8	-4	(799.6)	7,411
-5	(112.1)	78.5	-5	(999.5)	7,417
-6	(134.5)	78.2	-6	(1,199.4)	7,422
-7	(156.9)	78.0	-7	(1,399.3)	7,427
-8	(179.3)	77.7	-8	(1,599.2)	7,432
-9	(201.7)	77.4	-9	(1,799.1)	7,437
-10	(224.1)	77.1	-10	(1,998.9)	7,442

**RAF
POINTS
2,367**

**Adjusted
RAF
80.5**

**AHR
POINTS
8,000**

**Adjusted
ANOHR
7,286**

Weighting Factor =

0.95%

Weighting Factor =

6.73%

**TAMPA ELECTRIC COMPANY
COMPARISON OF GPIF TARGETS VS ACTUAL PERFORMANCE**

EQUIVALENT AVAILABILITY (%)

PLANT / UNIT	TARGET WEIGHTING FACTOR (%)	NORMALIZED WEIGHTING FACTOR	TARGET PERIOD JAN 12 - DEC 12			ACTUAL PERFORMANCE JAN 12 - DEC 12		
			POF	EUOF	EUOR	POF	EUOF	EUOR
BIG BEND 1	0.30%	1.2%	5.7	12.4	13.2	6.8	26.2	28.1
BIG BEND 2	5.09%	21.0%	5.7	18.1	19.2	4.0	17.9	18.7
BIG BEND 3	9.20%	38.0%	6.6	13.5	14.4	2.8	25.0	25.7
BIG BEND 4	6.50%	26.9%	6.6	16.0	17.2	8.2	16.2	17.6
POLK 1	0.81%	3.4%	10.9	3.6	4.0	12.7	17.3	19.8
BAYSIDE 1	1.35%	5.6%	3.8	3.6	3.7	12.7	17.3	19.8
BAYSIDE 2	0.95%	3.9%	17.2	3.6	4.3	12.7	17.3	19.8
GPIF SYSTEM	24.2%	100.0%	6.8	13.8	14.8	5.8	20.2	21.3
GPIF SYSTEM WEIGHTED EQUIVALENT AVAILABILITY (%)			<u>79.4</u>			<u>74.0</u>		
			<u>3 PERIOD AVERAGE</u>			<u>3 PERIOD AVERAGE</u>		
			<u>POF</u>	<u>EUOF</u>	<u>EUOR</u>	<u>EAF</u>		
			10.1	16.2	18.1	73.7		

AVERAGE NET OPERATING HEAT RATE (Btu/kwh)

PLANT / UNIT	TARGET WEIGHTING FACTOR (%)	NORMALIZED WEIGHTING FACTOR	TARGET	ADJUSTED
			HEAT RATE JAN 12 - DEC 12	ACTUAL HEAT RATE JAN 12 - DEC 12
BIG BEND 1	19.20%	25.3%	10,468	10,467
BIG BEND 2	12.41%	16.4%	10,272	10,356
BIG BEND 3	12.03%	15.9%	10,614	10,595
BIG BEND 4	11.77%	15.5%	10,549	10,420
POLK 1	6.81%	9.0%	10,220	10,619
BAYSIDE 1	6.86%	9.1%	7,248	7,206
BAYSIDE 2	6.73%	8.9%	7,316	7,286
GPIF SYSTEM	75.8%	100.0%		
GPIF SYSTEM WEIGHTED AVERAGE HEAT RATE (Btu/kwh)			<u>9,878</u>	<u>9,898</u>

**TAMPA ELECTRIC COMPANY
GENERATING PERFORMANCE INCENTIVE POINTS CALCULATION
JANUARY 2012 - DECEMBER 2012**

Points are calculated according to the formula:

$$GPIP = \sum_{i=1}^n [a_i(EAP_i) + e_i(AHRP_i)]$$

Where:

GPIP = Generating performance incentive points

a_i Percentage of total system fuel cost reduction attributed to maximum reasonably attainable equivalent availability of unit i during the period

e_i – Percentage of total system fuel cost reduction attributed to minimum reasonably attainable average heat rate of unit i during the period

EAP_i = Equivalent availability points awarded/deducted for unit i

AHRP_i = Average heat rate points awarded/deducted for unit i

Weighting factors and point values are listed on page 4.

<i>GPIP</i>	0.30%	*	(BB 1 EAP)	+	5.09%	*	(BB 2 EAP)	+	9.20%	*	(BB 3 EAP)
+	6.50%	*	(BB 4 EAP)	+	0.81%	*	(PK 1 EAP)	+	1.35%	*	(BAY 1 EAP)
+	0.95%	*	(BAY 2 EAP)	+	19.20%	*	(BB 1 AHRP)	+	12.41%	*	(BB 2 AHRP)
+	12.03%	*	(BB 3 AHRP)	+	11.77%	*	(BB 4 AHRP)	+	6.81%	*	(PK 1 AHRP)
+	6.86%	*	(BAY 1 AHRP)	+	6.73%	*	(BAY 2 AHRP)				

<i>GPIP</i> =	0.30%	*	-10.000	+	5.09%	*	1.326	+	9.20%	*	-10.000
+	6.50%	*	-0.720	+	0.81%	*	-10.000	+	1.35%	*	-0.730
+	0.95%	*	2.387	+	19.20%	*	0.000	+	12.41%	*	-0.272
+	12.03%	*	0.000	+	11.77%	*	1.695	+	6.81%	*	-10.000
+	6.86%	*	0.000	+	6.73%	*	0.000				

<i>GPIP</i> =	-0.030	+	0.067	+	-0.920
+	-0.047	+	-0.081	+	-0.010
+	0.023	+	0.000	+	-0.034
+	0.000	+	0.200	+	-0.681
+	0.000	+	0.000		

GPIP = -1.513 POINTS

REWARD/PENALTY dollar amounts of the Generating Performance Incentive Factor (GPIF) are determined directly from the table for the corresponding Generating Performance Points (GPIP) on page 2.

GPIF PENALTY = (\$1,177,059)

EXHIBIT NO. ____ (BSB-1)
TAMPA ELECTRIC COMPANY
DOCKET NO. 130001-EI
GPIF 2012 FINAL TRUE-UP
DOCUMENT NO. 2

EXHIBIT TO THE TESTIMONY OF
BRIAN S. BUCKLEY

DOCKET NO. 130001-EI

TAMPA ELECTRIC COMPANY
GENERATING PERFORMANCE INCENTIVE FACTOR
JANUARY 2012 - DECEMBER 2012
TRUE-UP

DOCUMENT NO. 2
ACTUAL UNIT PERFORMANCE DATA

ORIGINAL SHEET NO. 8.401.12A
TAMPA ELECTRIC COMPANY

ACTUAL UNIT PERFORMANCE DATA

JANUARY 2012 - DECEMBER 2012

PLANT/UNIT	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	PERIOD
BIG BEND 1	JAN 12	FEB 12	MAR 12	APR 12	MAY 12	JUN 12	JUL 12	AUG 12	SEP 12	OCT 12	NOV 12	DEC 12	2012
1. EAF (%)	66.3	96.1	96.0	4.0	2.0	45.7	84.7	76.1	86.1	98.0	59.1	89.4	67.0
2. PH	744	696	743	720	744	720	744	744	720	744	721	744	8,784
3. SH	524.2	696.0	743.0	28.5	35.8	358.3	634.9	581.6	626.6	744.0	432.3	602.6	6,007.7
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	66.1	66.1
5. UH	219.8	0.0	0.0	691.5	708.2	361.7	109.1	162.4	93.4	0.0	288.7	75.3	2,710.2
6. POH	0.0	0.0	0.0	552.0	48.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	600.0
7. FOH	219.8	0.0	0.0	139.5	660.2	361.7	109.1	162.4	93.4	0.0	288.7	75.3	2,110.2
8. MOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
9. PFOH	295.2	432.5	471.9	0.0	35.8	223.3	7.6	20.7	40.4	81.3	11.1	68.7	1,688.3
10. LR PF (MW)	33.3	15.7	13.7	0.0	227.1	45.8	140.9	87.8	30.2	19.6	140.6	18.5	29.6
11. PMOH	20.4	51.5	47.2	0.0	0.0	5.5	5.8	37.8	9.6	29.0	5.1	0.0	211.8
12. LR PM (MW)	112.3	75.0	110.4	0.0	0.0	165.9	105.0	111.8	134.2	141.2	136.5	0.0	109.4
13. NSC (MW)	395.0	395.0	395.0	385.0	385.0	385.0	385.0	385.0	385.0	385.0	385.0	395.0	388.3
14. OPR BTU(GBTU)	1,880.0	2,568.8	2,753.6	114.3	43.7	1,292.6	2,493.9	2,262.6	2,443.2	2,796.5	1,550.4	2,373.3	22,572.8
15. NET GEN (MWH)	182,370	249,783	267,166	10,989	4,308	121,312	240,845	211,771	227,394	264,740	147,843	225,667	2,154,188
16. ANOHR (BTU/KWH)	10,308.6	10,284.2	10,306.6	10,398.0	10,153.3	10,655.3	10,354.6	10,684.3	10,744.3	10,563.3	10,486.5	10,516.6	10,479.0
17. NOF (%)	88.1	90.9	91.0	100.3	31.3	87.9	98.5	94.6	94.3	92.4	88.8	94.8	92.3
18. NPC (MW)	395.0	395.0	395.0	385.0	385.0	385.0	385.0	385.0	385.0	385.0	385.0	395.0	388.3
19. ANOHR EQUATION	ANOHR = NOF(-18.440)+ 12182												

44

EXHIBIT NO. _____ (BSB-1)
TAMPA ELECTRIC COMPANY
DOCKET NO. 130001 - EI
DOCUMENT NO. 2
PAGE 1 OF 7

ORIGINAL SHEET NO. 8.401.12A
TAMPA ELECTRIC COMPANY

ACTUAL UNIT PERFORMANCE DATA

JANUARY 2012 - DECEMBER 2012

PLANT/UNIT	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	PERIOD
BIG BEND 2	JAN 12	FEB 12	MAR 12	APR 12	MAY 12	JUN 12	JUL 12	AUG 12	SEP 12	OCT 12	NOV 12	DEC 12	2012
1. EAF (%)	95.5	87.9	64.2	50.1	94.3	87.2	86.3	83.9	57.7	92.1	78.4	58.6	78.1
2. PH	744	696	743	720	744	720	744	744	720	744	721	744	8,784
3. SH	736.7	696.0	632.2	366.5	734.1	696.2	696.9	633.6	432.2	709.5	579.9	440.3	7,354.1
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5. UH	7.3	0.0	110.8	353.5	9.9	23.8	47.1	110.4	287.8	34.5	141.1	303.7	1,429.9
6. POH	0.0	0.0	0.0	353.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	353.5
7. FOH	0.0	0.0	0.0	0.0	9.9	23.8	0.0	0.0	287.8	34.5	141.1	303.7	800.8
8. MOH	7.3	0.0	110.8	0.0	0.0	0.0	47.1	110.4	0.0	0.0	0.0	0.0	275.7
9. PFOH	70.2	622.4	550.3	132.5	335.6	690.3	686.9	27.4	7.5	77.1	39.0	18.1	3,257.4
10. LR PF (MW)	70.6	46.6	111.2	13.3	31.3	38.1	29.9	14.7	90.9	81.7	92.0	41.5	50.9
11. PMOH	31.8	26.5	0.0	3.4	8.3	1.0	2.3	23.9	25.7	23.2	14.2	4.3	164.5
12. LR PM (MW)	165.7	159.8	0.0	121.6	236.1	150.2	178.5	134.1	220.6	136.4	153.3	192.4	166.9
13. NSC (MW)	395.0	395.0	395.0	385.0	385.0	385.0	385.0	385.0	385.0	385.0	385.0	395.0	388.3
14. OPR BTU(GBTU)	2,611.9	2,310.8	1,870.2	1,352.5	2,584.3	2,435.7	2,503.3	2,434.2	1,599.2	2,596.0	2,153.5	1,725.8	26,177.2
15. NET GEN (MWH)	261,282	228,186	181,488	133,918	253,136	232,215	237,196	232,530	150,357	241,512	203,738	163,607	2,519,165
16. ANOHR (BTU/KWH)	9,996.6	10,126.7	10,304.6	10,099.1	10,209.0	10,488.9	10,553.7	10,468.5	10,635.9	10,748.8	10,569.8	10,548.3	10,391.0
17. NOF (%)	89.8	83.0	72.7	94.9	89.6	86.6	88.4	95.3	90.4	88.4	91.3	94.1	88.2
18. NPC (MW)	395.0	395.0	395.0	385.0	385.0	385.0	385.0	385.0	385.0	385.0	385.0	395.0	388.3
19. ANOHR EQUATION	ANOHR = NOF(-7.525) + 10971												

45

EXHIBIT NO. _____ (BSB-1)
TAMPA ELECTRIC COMPANY
DOCKET NO. 130001 - EI
DOCUMENT NO. 2
PAGE 2 OF 7

ORIGINAL SHEET NO. 8.401.12A
TAMPA ELECTRIC COMPANY

ACTUAL UNIT PERFORMANCE DATA

JANUARY 2012 - DECEMBER 2012

PLANT/UNIT	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	PERIOD
BIG BEND 3	JAN 12	FEB 12	MAR 12	APR 12	MAY 12	JUN 12	JUL 12	AUG 12	SEP 12	OCT 12	NOV 12	DEC 12	2012
1. EAF (%)	81.7	86.2	58.1	70.7	84.1	48.9	50.9	73.1	81.6	72.4	74.9	84.0	72.2
2. PH	744	696	743	720	744	720	744	744	720	744	721	744	8,784
3. SH	611.8	693.3	495.7	510.1	629.2	392.4	457.6	645.8	720.0	688.2	643.8	744.0	7,231.7
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5. UH	132.3	2.8	247.3	210.0	114.8	327.6	286.4	98.2	0.0	55.9	77.2	0.0	1,552.3
6. POH	0.0	0.0	247.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	247.3
7. FOH	132.3	2.8	0.0	154.6	114.8	327.6	286.4	98.2	0.0	55.9	3.4	0.0	1,175.8
8. MOH	0.0	0.0	0.0	55.4	0.0	0.0	0.0	0.0	0.0	0.0	73.8	0.0	129.2
9. PFOH	3.7	229.7	318.5	7.1	2.0	71.2	429.9	637.6	661.9	318.7	593.8	737.0	4,011.0
10. LR PF (MW)	61.2	116.2	68.1	53.3	102.2	105.8	56.2	56.9	57.4	85.7	59.3	57.1	64.7
11. PMOH	11.6	64.4	9.1	0.0	6.8	76.8	27.7	8.3	58.1	365.2	49.0	7.0	683.8
12. LR PM (MW)	95.4	114.8	173.3	0.0	163.5	95.3	167.6	124.8	176.9	75.0	56.2	206.0	96.5
13. NSC (MW)	365.0	365.0	365.0	365.0	365.0	365.0	365.0	365.0	365.0	365.0	365.0	365.0	365.0
14. OPR BTU(GBTU)	2,168.5	2,204.1	1,575.2	1,832.3	2,329.6	1,311.8	1,449.7	2,099.8	2,297.9	2,032.3	1,972.3	2,340.0	23,613.5
15. NET GEN (MWH)	211,982	212,105	151,091	177,651	221,808	120,084	132,924	192,711	206,929	187,121	186,394	219,202	2,220,002
16. ANOHR BTU/KWH	10,229.5	10,391.4	10,425.4	10,314.1	10,502.6	10,924.1	10,906.6	10,896.3	11,105.0	10,860.8	10,581.3	10,675.0	10,637.0
17. NOF (%)	94.9	83.8	83.5	95.4	96.6	83.8	79.6	81.8	78.7	74.5	79.3	80.7	84.1
18. NPC (MW)	365.0	365.0	365.0	365.0	365.0	365.0	365.0	365.0	365.0	365.0	365.0	365.0	365.0
19. ANOHR EQUATION	ANOHR = NOF(-20.706) + 12397												

ORIGINAL SHEET NO. 8.401.12A
TAMPA ELECTRIC COMPANY

ACTUAL UNIT PERFORMANCE DATA

JANUARY 2012 - DECEMBER 2012

PLANT/UNIT	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	PERIOD
BIG BEND 4	JAN 12	FEB 12	MAR 12	APR 12	MAY 12	JUN 12	JUL 12	AUG 12	SEP 12	OCT 12	NOV 12	DEC 12	2012
1. EAF (%)	97.6	99.3	97.7	79.0	38.1	81.3	61.8	99.4	78.5	54.2	76.3	47.0	75.7
2. PH	744	696	743	720	744	720	744	744	720	744	721	744	8,784
3. SH	740.9	696.0	743.0	712.8	407.5	689.3	516.4	744.0	572.0	414.8	560.3	428.4	7,225.3
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5. UH	3.1	0.0	0.0	7.3	336.5	30.7	227.7	0.0	148.0	329.2	160.7	315.6	1,558.7
6. POH	0.0	0.0	0.0	0.0	323.6	0.0	0.0	0.0	98.8	294.6	0.0	0.0	717.1
7. FOH	3.1	0.0	0.0	7.3	12.9	30.7	227.7	0.0	49.2	34.6	160.7	80.6	606.7
8. MOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	235.0	235.0
9. PFOH	22.3	0.0	271.0	606.9	288.0	402.8	278.4	23.5	218.2	20.8	30.5	288.3	2,450.7
10. LR PF (MW)	43.3	0.0	24.9	98.9	128.2	98.5	62.7	78.5	10.6	197.0	136.2	109.5	84.0
11. PMOH	24.2	9.4	3.2	0.0	61.8	28.7	24.6	0.0	1.6	3.3	0.0	5.8	162.5
12. LR PM (MW)	226.7	232.3	129.3	0.0	240.6	130.5	230.1	0.0	204.8	176.0	0.0	227.7	212.7
13. NSC (MW)	427.0	427.0	427.0	417.0	417.0	417.0	407.0	407.0	407.0	407.0	407.0	417.0	415.3
14. OPR BTU(GBTU)	3,006.3	2,865.8	2,965.9	2,469.2	1,181.7	2,512.5	1,892.8	3,073.4	2,358.9	1,521.7	2,101.7	1,417.4	27,367.3
15. NET GEN (MWH)	289,036	279,663	294,024	236,477	105,642	236,731	181,613	294,808	221,321	145,757	203,116	134,039	2,622,227
16. ANOHR BTU/KWH	10,401.0	10,247.4	10,087.4	10,441.5	11,185.8	10,613.4	10,422.1	10,425.2	10,658.2	10,440.2	10,347.2	10,574.4	10,437.0
17. NOF (%)	91.4	94.1	92.7	79.6	62.2	82.4	86.4	97.4	95.1	86.3	89.1	75.0	87.4
18. NPC (MW)	427.0	427.0	427.0	417.0	417.0	417.0	407.0	407.0	407.0	407.0	407.0	417.0	415.3
19. ANOHR EQUATION	ANOHR = NOF(-30.914) + 13268												

47

EXHIBIT NO. _____ (BSB-1)
TAMPA ELECTRIC COMPANY
DOCKET NO. 130001 - EI
DOCUMENT NO. 2
PAGE 4 OF 7

ORIGINAL SHEET NO. 8 401.12A
TAMPA ELECTRIC COMPANY

ACTUAL UNIT PERFORMANCE DATA

JANUARY 2012 - DECEMBER 2012

PLANT/UNIT	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	PERIOD
POLK 1	JAN 12	FEB 12	MAR 12	APR 12	MAY 12	JUN 12	JUL 12	AUG 12	SEP 12	OCT 12	NOV 12	DEC 12	2012
1. EAF (%)	21.7	1.7	96.3	97.7	73.0	0.0	81.1	100.0	89.3	99.7	92.0	83.3	70.0
2. PH	744	696	743	720	744	720	744	744	720	744	721	744	8,784
3. SH	113.0	2.9	681.9	698.3	563.5	0.0	565.8	744.0	566.8	744.0	666.8	524.6	5,871.6
4. RSH	49.8	9.0	40.1	20.1	0.0	0.0	57.7	0.0	111.6	0.0	0.0	137.7	425.9
5. UH	581.2	684.1	21.1	1.6	180.5	720.0	120.5	0.0	41.6	0.0	54.2	81.7	2,486.5
6. POH	449.0	666.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1,115.4
7. FOH	132.2	0.0	4.1	1.6	180.5	720.0	120.5	0.0	0.0	0.0	54.2	58.7	1,271.8
8. MOH	0.0	17.7	17.0	0.0	0.0	0.0	0.0	0.0	41.6	0.0	0.0	23.0	99.3
9. PFOH	5.8	0.0	27.8	67.6	92.5	0.0	88.8	5.2	249.4	64.6	16.0	188.4	806.0
10. LR PF (MW)	49.1	0.0	49.4	47.6	49.3	0.0	49.0	7.7	31.4	7.7	49.4	49.3	40.0
11. PMOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12. LR PM (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
13. NSC (MW)	220.0	220.0	220.0	220.0	220.0	220.0	220.0	220.0	220.0	220.0	220.0	220.0	220.0
14. OPR BTU(GBTU)	273.3	2.1	1,199.5	1,508.5	1,082.6	0.0	1,253.6	1,769.2	1,301.9	1,672.5	1,507.7	1,209.7	12,780.5
15. NET GEN (MWH)	22,381	-2,681	110,360	148,524	101,347	-4,275	116,387	165,849	116,430	163,044	146,108	111,441	1,194,915
16. ANOHR BTU/KWH	12,209.3	0.0	10,869.2	10,156.8	10,681.8	0.0	10,770.6	10,667.4	11,181.7	10,257.8	10,319.4	10,855.1	10,696.0
17. NOF (%)	90.0	0.0	73.6	96.7	81.7	0.0	93.5	101.3	93.4	99.6	99.6	96.6	92.5
18. NPC (MW)	220.0	220.0	220.0	220.0	220.0	220.0	220.0	220.0	220.0	220.0	220.0	220.0	220.0
19. ANOHR EQUATION	ANOHR = NOF(-45 481) + 14504												

48

EXHIBIT NO. _____ (BSB-1)
TAMPA ELECTRIC COMPANY
DOCKET NO. 130001 - EI
DOCUMENT NO. 2
PAGE 5 OF 7

ORIGINAL SHEET NO. 8.401.12A
TAMPA ELECTRIC COMPANY

ACTUAL UNIT PERFORMANCE DATA

JANUARY 2012 - DECEMBER 2012

PLANT/UNIT	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	PERIOD
BAYSIDE UNIT 1	JAN 12	FEB 12	MAR 12	APR 12	MAY 12	JUN 12	JUL 12	AUG 12	SEP 12	OCT 12	NOV 12	DEC 12	2012
1. EAF (%)	100.0	97.4	100.0	98.4	91.8	99.6	99.3	99.0	99.6	97.4	73.0	100.0	96.3
2. PH	744	696	743	720	744	720	744	744	720	744	721	744	8,784
3. SH	0.0	464.6	630.1	620.2	610.1	640.8	629.5	590.7	595.9	538.3	236.2	0.0	5,556.3
4. RSH	744.0	213.5	112.9	88.4	72.8	76.2	109.2	146.0	121.1	186.1	290.0	744.0	2,904.2
5. UH	0.0	18.0	0.0	11.5	61.1	3.0	5.3	7.3	3.0	19.5	194.8	0.0	323.5
6. POH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	190.0	0.0	190.0
7. FOH	0.0	18.0	0.0	0.0	0.5	0.0	0.0	0.5	0.0	3.5	4.8	0.0	27.4
8. MOH	0.0	0.0	0.0	11.5	60.6	3.0	5.3	6.8	3.0	16.0	0.0	0.0	106.1
9. PFOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.1	0.0	0.0	0.0	1.1
10. LR PF (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.7	0.0	0.0	0.0	0.7
11. PMOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12. LR PM (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
13. NSC (MW)	792.0	792.0	792.0	701.0	701.0	701.0	701.0	701.0	701.0	701.0	701.0	792.0	731.3
14. OPR BTU(GBTU)	0.0	1,851.4	2,604.8	2,689.4	2,542.3	2,741.6	2,645.0	2,369.9	2,460.7	2,029.4	533.3	0.0	22,467.8
15. NET GEN (MWH)	-889	252,257	358,225	375,788	355,736	383,209	368,522	328,239	341,680	278,552	71,528	-2,050	3,110,796
16. ANOHR (BTU/KWH)	0.0	7,339.5	7,271.3	7,156.8	7,146.6	7,154.4	7,177.2	7,220.1	7,201.7	7,285.4	7,455.4	0.0	7,223.0
17. NOF (%)	0.0	68.6	71.8	86.4	83.2	85.3	83.5	79.3	81.8	73.8	43.2	0.0	76.6
18. NPC (MW)	792.0	792.0	792.0	701.0	701.0	701.0	701.0	701.0	701.0	701.0	701.0	792.0	731.3
19. ANOHR EQUATION	ANOHR = NOF(-2.816) + 7481												

ORIGINAL SHEET NO. 8.401.12A
TAMPA ELECTRIC COMPANY

ACTUAL UNIT PERFORMANCE DATA

JANUARY 2012 - DECEMBER 2012

PLANT/UNIT	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	PERIOD
BAYSIDE UNIT 2	JAN 12	FEB 12	MAR 12	APR 12	MAY 12	JUN 12	JUL 12	AUG 12	SEP 12	OCT 12	NOV 12	DEC 12	2012
1. EAF (%)	100.0	18.8	0.0	55.1	88.2	96.4	98.4	100.0	98.5	99.0	98.9	88.7	78.8
2. PH	744	696	743	720	744	720	744	744	720	744	721	744	8,784
3. SH	559.7	90.1	0.0	364.0	606.4	600.4	631.1	566.5	557.6	430.6	438.5	565.9	5,410.7
4. RSH	184.3	40.6	0.0	32.6	50.9	94.2	100.8	177.5	151.8	305.9	274.8	94.2	1,507.6
5. UH	0.0	565.3	743.0	323.4	86.7	25.4	12.1	0.0	10.6	7.5	7.7	84.0	1,865.7
6. POH	0.0	565.3	743.0	282.6	58.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1,649.7
7. FOH	0.0	0.0	0.0	20.7	17.2	8.1	0.2	0.0	0.1	0.0	0.6	53.9	101.0
8. MOH	0.0	0.0	0.0	20.1	10.7	17.3	11.9	0.0	10.5	7.5	7.0	30.0	115.1
9. PFOH	0.0	0.0	0.0	0.0	49.0	8.5	0.0	0.0	0.2	0.0	0.0	0.0	57.7
10. LR PF (MW)	0.0	0.0	0.0	0.0	0.5	0.5	0.0	0.0	0.6	0.0	0.0	0.0	0.5
11. PMOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12. LR PM (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
13. NSC (MW)	1,047.0	1,047.0	1,047.0	929.0	929.0	929.0	929.0	929.0	929.0	929.0	929.0	1,047.0	968.3
14. OPR BTU(GBTU)	3,003.9	440.3	0.0	1,524.7	3,388.3	3,460.8	3,613.2	3,079.2	3,090.3	2,205.3	2,040.5	3,064.2	28,910.7
15. NET GEN (MWH)	410,872	57,812	-2,561	202,074	465,535	474,208	494,379	417,171	420,322	297,191	273,547	420,442	3,930,991
16. ANOHR (BTU/KWH)	7,311.1	7,616.0	0.0	7,545.1	7,278.3	7,298.2	7,308.7	7,381.1	7,352.2	7,420.5	7,459.4	7,288.0	7,355.0
17. NOF (%)	70.1	61.3	0.0	59.8	82.6	85.0	84.3	79.3	81.1	74.3	67.1	71.0	75.0
18. NPC (MW)	1,047.0	1,047.0	1,047.0	929.0	929.0	929.0	929.0	929.0	929.0	929.0	929.0	1,047.0	968.3
19. ANOHR EQUATION	ANOHR = NOF(-8 469) + 8020												

50

EXHIBIT NO. _____ (BSB-1)
TAMPA ELECTRIC COMPANY
DOCKET NO. 130001 - EI
DOCUMENT NO. 2
PAGE 7 OF 7