

VOTE SHEET

October 24, 2013

Docket No. 130198-EI – Petition for prudence determination regarding new pipeline system by Florida Power & Light Company.

Issue 1: Does FPL have a need for additional firm natural gas transportation by 2017?

Recommendation: Yes. FPL has demonstrated a need for 400 MMcf/day of additional firm natural gas transmission capacity by 2017.

APPROVED

Issue 2: Are the Sabal Trail Transmission (Sabal Trail) and Florida Southeast Connection (FSC) combined projects the most cost-effective solution to meet FPL’s need for additional natural gas transportation?

Recommendation: Yes. FPL’s selection of the Sabal Trail and FSC natural gas transportation contracts was based on a fair and open RFP process. The combined projects are projected to save up to \$450 million, net present value, over the term of the contracts when compared to the next most cost-effective proposal. Staff recommends that FPL be eligible to seek recovery of costs associated with these firm natural gas transportation contracts through the fuel clause.

APPROVED

COMMISSIONERS ASSIGNED: All Commissioners

COMMISSIONERS’ SIGNATURES

MAJORITY

DISSENTING

[Handwritten signatures in blue ink over three horizontal lines]

[Empty horizontal lines for dissenting signatures]

REMARKS/DISSENTING COMMENTS:

*oral modification, assigned
DN 06403-13, is attached. -ac*

Vote Sheet

October 24, 2013

Docket No. 130198-EI – Petition for prudence determination regarding new pipeline system by Florida Power & Light Company.

(Continued from previous page)

Issue 3: Should this docket be closed?

Recommendation: Yes. If the Commission approves staff's recommendation on Issues 1 and 2, there are no remaining issues and staff recommends that the docket be closed. The resulting decision will be issued as a Proposed Agency Action. The decision will become final upon issuance of a Consummating Order, if no person whose substantial interests are affected timely files a protest within 21 days of the issuance of the Order.


APPROVED

Ann Cole

From: Mil Jubinsky
Sent: Tuesday, October 22, 2013 3:58 PM
To: Commissioners Advisors; Carlotta Stauffer; Rachel Arnold; Braulio Baez; Tom Ballinger; Patti Zellner; Mary Anne Helton; Terri Fleming; Pamela Paultre; Kay Posey; Betty Leland; Terry Holdnak; Cristina Slaton
Cc: Lisa Harvey; Kate Hamrick; Apryl Lynn; Jacqueline Moore; Ann Cole; Curt Kiser; Marshall Willis; Jim Dean; Lee Eng Tan; Cheryl Bulecza-Banks; Delores Reecy; Veronica Washington
Subject: RE: Request for oral modification to Item # 10, Docket No. 130198-EI - October 24, 2013 Agenda

The attached figure is below – it did not go through on the first email.

Figure 1: Summer Peak Demand Forecasts (2013 – 2042)



Mil Jubinsky

Executive Assistant to
Braulio Baez, Executive Director
Public Service Commission
850-413-6053

From: Mil Jubinsky
Sent: Tuesday, October 22, 2013 3:07 PM
To: Commissioners Advisors; Carlotta Stauffer; Rachel Arnold; Braulio Baez; Tom Ballinger; Patti Zellner; Mary Anne Helton; Terri Fleming; Pamela Paultre; Kay Posey; Betty Leland; Terry Holdnak; Cristina Slaton
Cc: Lisa Harvey; Kate Hamrick; Apryl Lynn; Jacqueline Moore; Ann Cole; Curt Kiser; Marshall Willis; Jim Dean; Lee Eng Tan; Mil Jubinsky; Cheryl Bulecza-Banks; Delores Reecy; Veronica Washington
Subject: Request for oral modification to Item # 10, Docket No. 130198-EI - October 24, 2013 Agenda

Good afternoon – please see below request that was approved.

From: Braulio Baez
Sent: Tuesday, October 22, 2013 10:25 AM
To: Tom Ballinger
Cc: Lisa Harvey; Apryl Lynn; Ann Cole; Curt Kiser; Marshall Willis; Jim Dean; Lee Eng Tan
Subject: RE: Request for oral modification to Item # 10, Docket No. 130198-EI

Approved

From: Tom Ballinger
Sent: 10/22/2013 10:13 AM
To: Braulio Baez
Cc: Lisa Harvey; Apryl Lynn; Ann Cole; Curt Kiser; Marshall Willis; Jim Dean; Lee Eng Tan
Subject: Request for oral modification to Item # 10, Docket No. 130198-EI

On Monday, 10/21, I received a letter from FPL correcting a previous data response which staff had relied upon in its recommendation. Staff would request permission to make an oral modification to the recommendation in order to provide accurate information to the Commissioners. **The modifications do not impact the overall recommendation from staff and are shown below in type and strike format.**

Page 7, First full paragraph and revised Figure 1

Overall, FPL's base case forecast ~~and risk-adjusted forecast~~ for summer peak demand ~~are~~ is down from ~~those~~ that presented in the FESL proceeding. As illustrated in Figure 1, the base case forecast for summer peak demand in 2017 is 7.4 percent lower than the risk-adjusted forecast and ~~25.5~~ 3.7 percent lower than the FESL forecast. By 2040, this gap increases to 13.0 percent for the risk-adjusted forecast and ~~28.4~~ 6.3 percent for the FESL forecast.

Figure 1: Summer Peak Demand Forecasts (2013 – 2042)



Please let me know if you approve.

Tom Ballinger
Director, Division of Engineering
Florida Public Service Commission
(850) 413-6680