

FLORIDA UTILITY SERVICES 1, LLC
3336 GRAND BLVD. SUITE 102
HOLIDAY, FL. 34690
863-904-5574

RECEIVED-PPSC
2016 NOV -7 AM 10:16
COMMISSION
CLERK

November 1, 2016

Commission Clerk
Florida Public Service Commission
2540 Shumard Oak Blvd.
Tallahassee, FL. 32399

RE: Docket # 140175-WU.

Dear Commission Clerk:

Enclosed please find company response to Staff's fourth data request.

On behalf of the utility,



Mike Smallridge

**Docket No. 140175-WU - Application for Staff-Assisted Rate Case in Pasco County by
Crestridge Utilities, LLC.**

1. Did you obtain more than one bid for the replacement of the pumps for well #2 and well #4?

No. Two reasons. The first being Pope's was the original well installer and has been servicing these wells (and just about every other well in Pasco County) since day one and has been used exclusively by myself and all the previous owners of these utilities. Well rehab is very touchy work and regulated so it must be done correctly. I know of no company in the area capable of doing this work to my satisfaction. Pope's will be doing the work at my wells for all my systems in Pasco County.

1. Did you obtain more than one bid for the replacement of the electrical work for well #2 and well #4?

Yes, see enclosed.

On behalf of the utility,


Mike Smallridge

Joseph Gribbin
LIC# EC 1306849
(863)-604-3969
PO Box 1595 Auburndale FL 33823

August 23, 2016

Proposal Submitted to:
Mike Smallridge

RE: Well #4 Upgrade at 4927 Zodiac Holiday FL

Upgrade service to 100 amps and install new 3 phase 100amp 12 circuit panel.
Run new wire from the well to new starter cabinet, add new 3 phase ICM 450 phase loss
monitor per customer request. Install new square D Nema size 3 starter and heaters rated
for a 20 HP pump. Run new circuit to chlorine pump relocate if it is necessary.

Labor:	\$ 1,250.00
Material:	<u>\$ 5,732.00</u>
Total:	\$ 6,982.00

Sincerely, *Joseph Gribbin*

Joseph Gribbin
LIC# EC 1306849
(863)-604-3969
PO Box 1595 Auburndale FL 33823

October 29, 2016

Proposal Submitted to:
Mike Smallridge

RE: Well #2 Upgrade at 4843 Panorama Ave Holiday Fl

Upgrade service to 100 amps and install new 3 phase 100amp 12 circuit panel.
Run new wire from the well to new starter cabinet, add new 3 phase ICM 450 phase loss
monitor per customer request. Install new square D Nema size 2 starter and heaters rated
for a 15 HP pump. Run new circuit to chlorine pump relocate if it is necessary.

Labor:	\$ 1,250.00
Material:	\$ <u>4,679.00</u>
Total:	\$ 5,929.00

Sincerely, *Joseph Gribbin*