

Florida Department of Environmental Protection Safe Drinking Water Program Laboratory Reporting Format

PUBLIC WATER SYSTEM INFORMATION (to be completed by sampler – Please type or print legibly)

System Name: _____ PWS I.D.#:

System Type (check one): Community Nontransient Noncommunity Transient Noncommunity

Address: _____

City: _____ ZIP Code: _____

Phone #: _____ Fax #: _____ E-Mail Address: _____

SAMPLE INFORMATION (to be completed by sampler)

Sample Number: T1918076001 Sample Date: 10/09/2019 Sample Time: 15:50 AM PM (circle one)

Sample Location (be specific): 11619 English Elm C12-2.3 Location Code (if known) : _____

Disinfectant Residual (Required when reporting results for trihalomethanes and haloacetic acids): _____ mg/L Field pH: _____

Sample Type (Check Only One)

- Distribution
- Entry Point (to Distribution)
- Plant Tap (not for compliance with 62-550)
- Raw (at well or intake)
- Max Residence Time
- Ave Residence Time
- Near First Customer

Reason(s) for Sample (Check all that apply)

- Routine Compliance with 62-550
- Confirmation of MCL Exceedance *
- Composite of Multiple Sites **
- Other: _____
- Replacement (of Invalidated Sample)
- Special (not for compliance with 62-550)
- Clearance (permitting)

Sampling Procedure Used or Other Comments: _____

***See 62-550.500(6) for requirements and restrictions.
And 62-550.512(3) for nitrate or nitrite exceedances.**

****See 62-550.550(4) for requirements and
attach a results page for each site.**

SAMPLER CERTIFICATION

I, _____, _____, do HEREBY CERTIFY
(Print Name) (Print Title)

that the above public water system and sample collection information is complete and correct.

Signature: _____ Date: _____

Certified Operator #: _____ Phone #: _____ Sampler's Fax #: _____

Sampler's E-Mail: _____

Florida Department of Environmental Protection Safe Drinking Water Program Laboratory Reporting Format

LABORATORY CERTIFICATION INFORMATION (to be completed by lab – Please type or print legibly)

Lab Name: Advanced Environmental Laboratories, Inc Florida DOH Certification #: E84589 Certification Expiration Date: 06/30/2020

ATTACH CURRENT DOH ANALYTE *

Address: 9610 Princess Palm Ave Tampa, FL 33619 Payments: P.O. Box Phone #: (813)630-9616

Were any analyses subcontracted? Yes No If yes, please provide DOH certification numbers: E82574 E82001

ATTACH DOH ANALYTE SHEET FOR EACH SUBCONTRACTED *

ANALYSIS INFORMATION (to be completed by lab)

Date Sample(s) Received: 10/10/2019

PWS ID (From Page 1): 6511423 Sample Number (From Page 1): T1918076001 Lab Assigned Report # or Job T1918076

Group(s) Analyzed & Results attached for compliance with Chapter 62-550, F.A.C. (Check all that apply):

Inorganics

- All Except Asbestos
 Partial
 Nitrate
 Nitrite
 Asbestos Only

Synthetic Organics

- All 30
 All Except Dioxin
 Partial
 Dioxin Only

Volatile Organics

- All 21
 Partial

Disinfection Byproducts

- Trihalomethanes
 Haloacetic Acids
 Chlorite
 Bromate

Radionuclides

- Single Sample
 Qtrly Composite**

Secondaries

- All 14
 Partial

LAB CERTIFICATION

I, Joseph J. Vondrick, Project Manager, do HEREBY CERTIFY
(Print Name) (Print Title)

that all attached analytical data are correct and unless noted meet all requirements of the National Environmental Laboratory Accreditation Conference

Signature:  Date: 10/24/2019

* Failure to provide a valid and current Florida DOH lab certification number and a current Analyte Sheet for the attached analysis results will result in rejection of the report, possible enforcement against the public water system for failure to sample, and may result in notification of the DOH Bureau of Laboratory Services.

** Please provide radiological sample dates & locations for each quarter.

CONFIRMATION & NOTIFICATION IS REQUIRED WITHIN 24 HRS FOR NITRATE OR NITRITE MCL EXCEEDANCES

NON-DETECTS ARE TO BE REPORTED AS THE MDL WITH A "U" QUALIFIER. (Non-detects reported as "BDL" or with a "<" are not acceptable.)

COMPLIANCE DETERMINATION (to be completed by DEP or DOH -- attach notes as necessary)

Sample Collection & Analysis Satisfactory: Yes No Replacement Sample or Report Requested: Yes No (circle or highlight group(s) above)

Person Notified: _____ Date Notified: _____ DEP/DOH Reviewing Official: _____

Florida Department of Environmental Protection

Safe Drinking Water Program Laboratory Reporting Format

INORGANIC CONTAMINANTS
62-550.310(1)

Report Number / Job ID: T1918076001

PWS ID (From Page 1): 6511423

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	Analysis Date	Analysis Time	DOH Lab Certification
1005	Arsenic	0.010	mg/L	0.00017	I	EPA 200.8	0.000077	10/16/2019	15:27	E82574
1010	Barium	2	mg/L	0.012		EPA 200.8	0.00024	10/16/2019	15:27	E82574
1015	Cadmium	0.005	mg/L	0.000064	U	EPA 200.8	0.000064	10/16/2019	15:27	E82574
1020	Chromium	0.1	mg/L	0.0020	U	EPA 200.7	0.0020	10/15/2019	12:55	E84589
1025	Fluoride	4.0	mg/L	0.31	I	EPA 300.0	0.20	10/18/2019	09:10	E84589
1030	Lead	0.015	mg/L	0.00024	U	EPA 200.8	0.00024	10/16/2019	15:27	E82574
1036	Nickel	0.1	mg/L	0.0044	U	EPA 200.7	0.0044	10/15/2019	12:55	E84589
1045	Selenium	0.05	mg/L	0.00058	U	EPA 200.8	0.00058	10/16/2019	15:27	E82574
1052	Sodium	160	mg/L	30		EPA 200.7	0.50	10/15/2019	12:55	E84589
1074	Antimony	0.006	mg/L	0.00015	I	EPA 200.8	0.00011	10/16/2019	15:27	E82574
1075	Beryllium	0.004	mg/L	0.00029	U	EPA 200.7	0.00029	10/15/2019	12:55	E84589
1085	Thallium	0.002	mg/L	0.000057	U	EPA 200.8	0.000057	10/16/2019	15:27	E82574

Florida Department of Environmental Protection

Safe Drinking Water Program Laboratory Reporting Format

SECONDARY CONTAMINANTS

62-550.320

Report Number / Job ID: T1918076001

PWS ID (From Page 1): 6511423

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	Analysis Date	Analysis Time	DOH Lab Certification #
1002	Aluminum	0.2	mg/L	0.025	U	EPA 200.7	0.025	10/15/2019	12:55	E84589
1017	Chloride	250	mg/L	26		EPA 300.0	2.0	10/18/2019	09:10	E84589
1022	Copper	1	mg/L	0.0014		EPA 200.8	0.00035	10/16/2019	15:27	E82574
1025	Fluoride	2.0	mg/L	0.31	I	EPA 300.0	0.20	10/18/2019	09:10	E84589
1028	Iron	0.3	mg/L	0.071	I	EPA 200.7	0.026	10/15/2019	12:55	E84589
1032	Manganese	0.05	mg/L	0.0025	I	EPA 200.8	0.00055	10/16/2019	15:27	E82574
1050	Silver	0.1	mg/L	0.00030	I	EPA 200.8	0.000068	10/16/2019	15:27	E82574
1055	Sulfate	250	mg/L	81		EPA 300.0	2.0	10/18/2019	09:10	E84589
1095	Zinc	5	mg/L	0.0064	I	EPA 200.8	0.0052	10/16/2019	15:27	E82574
1905	Color	15	PCU	2.7	U	SM 2120 B	2.7	10/09/2019	13:00	E84589
1920	Odor	3	TON @ 40°C	1.0	U	SM 2150 B	1.0	10/10/2019	14:30	E84589
1930	Total Dissolved Solids	500	mg/L	320		SM 2540 C	10	10/15/2019	10:00	E84589
2905	Foaming Agents	0.5	mg/L	0.040	U	SM 5540 C	0.040	10/11/2019	13:42	E82001

*Results must be reported with appropriate qualifiers in accordance with Florida Administrative Code Rule 62-160, Table 1. Results qualified with A, F, H, N, O, T, Z, ?, *, are unacceptable for compliance with 62-550. Results qualified with a J, Q, R, or Y must be accompanied by written justification and will be evaluated on a case by case basis. To avoid a monitoring violation, unacceptable results must be replaced with acceptable results from samples collected during the same monitoring period.

Florida Department of Environmental Protection Safe Drinking Water Program Laboratory Reporting Format

PUBLIC WATER SYSTEM INFORMATION (to be completed by sampler – Please type or print legibly)

System Name: _____ PWS I.D.#:

System Type (check one): Community Nontransient Noncommunity Transient Noncommunity

Address: _____

City: _____ ZIP Code: _____

Phone #: _____ Fax #: _____ E-Mail Address: _____

SAMPLE INFORMATION (to be completed by sampler)

Sample Number: T1918076002 Sample Date: 10/09/2019 Sample Time: 15:40 AM PM (circle one)

Sample Location (be specific): 11704 Rose Tree CI2-3.6 Location Code (if known) : _____

Disinfectant Residual (Required when reporting results for trihalomethanes and haloacetic acids): _____ mg/L Field pH: _____

Sample Type (Check Only One)

- Distribution
- Entry Point (to Distribution)
- Plant Tap (not for compliance with 62-550)
- Raw (at well or intake)
- Max Residence Time
- Ave Residence Time
- Near First Customer

Reason(s) for Sample (Check all that apply)

- Routine Compliance with 62-550
- Confirmation of MCL Exceedance *
- Composite of Multiple Sites **
- Other: _____
- Replacement (of Invalidated Sample)
- Special (not for compliance with 62-550)
- Clearance (permitting)

Sampling Procedure Used or Other Comments: _____

***See 62-550.500(6) for requirements and restrictions.
And 62-550.512(3) for nitrate or nitrite exceedances.**

****See 62-550.550(4) for requirements and
attach a results page for each site.**

SAMPLER CERTIFICATION

I, _____, _____, do HEREBY CERTIFY
(Print Name) (Print Title)

that the above public water system and sample collection information is complete and correct.

Signature: _____ Date: _____

Certified Operator #: _____ Phone #: _____ Sampler's Fax #: _____

Sampler's E-Mail: _____

Florida Department of Environmental Protection Safe Drinking Water Program Laboratory Reporting Format

LABORATORY CERTIFICATION INFORMATION (to be completed by lab – Please type or print legibly)

Lab Name: Advanced Environmental Laboratories, Inc Florida DOH Certification #: E84589 Certification Expiration Date: 06/30/2020

ATTACH CURRENT DOH ANALYTE *

Address: 9610 Princess Palm Ave Tampa, FL 33619 Payments: P.O. Box Phone #: (813)630-9616

Were any analyses subcontracted? Yes No If yes, please provide DOH certification numbers: E82574 E82001

ATTACH DOH ANALYTE SHEET FOR EACH SUBCONTRACTED *

ANALYSIS INFORMATION (to be completed by lab)

Date Sample(s) Received: 10/10/2019

PWS ID (From Page 1): 6511423 Sample Number (From Page 1): T1918076002 Lab Assigned Report # or Job T1918076

Group(s) Analyzed & Results attached for compliance with Chapter 62-550, F.A.C. (Check all that apply):

Inorganics

- All Except Asbestos
 Partial
 Nitrate
 Nitrite
 Asbestos Only

Synthetic Organics

- All 30
 All Except Dioxin
 Partial
 Dioxin Only

Volatile Organics

- All 21
 Partial

Disinfection Byproducts

- Trihalomethanes
 Haloacetic Acids
 Chlorite
 Bromate

Radionuclides

- Single Sample
 Qtrly Composite**

Secondaries

- All 14
 Partial

LAB CERTIFICATION

I, Joseph J. Vondrick, Project Manager, do HEREBY CERTIFY
(Print Name) (Print Title)

that all attached analytical data are correct and unless noted meet all requirements of the National Environmental Laboratory Accreditation Conference

Signature:  Date: 02/24/2018

* Failure to provide a valid and current Florida DOH lab certification number and a current Analyte Sheet for the attached analysis results will result in rejection of the report, possible enforcement against the public water system for failure to sample, and may result in notification of the DOH Bureau of Laboratory Services.

** Please provide radiological sample dates & locations for each quarter.

CONFIRMATION & NOTIFICATION IS REQUIRED WITHIN 24 HRS FOR NITRATE OR NITRITE MCL EXCEEDANCES

NON-DETECTS ARE TO BE REPORTED AS THE MDL WITH A "U" QUALIFIER. (Non-detects reported as "BDL" or with a "<" are not acceptable.)

COMPLIANCE DETERMINATION (to be completed by DEP or DOH -- attach notes as necessary)

Sample Collection & Analysis Satisfactory: Yes No Replacement Sample or Report Requested: Yes No (circle or highlight group(s) above)

Person Notified: _____ Date Notified: _____ DEP/DOH Reviewing Official: _____

Florida Department of Environmental Protection Safe Drinking Water Program Laboratory Reporting Format

INORGANIC CONTAMINANTS
62-550.310(1)

Report Number / Job ID: T1918076002

PWS ID (From Page 1): 6511423

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	Analysis Date	Analysis Time	DOH Lab Certification
1005	Arsenic	0.010	mg/L	0.00024	I	EPA 200.8	0.000077	10/16/2019	15:32	E82574
1010	Barium	2	mg/L	0.012		EPA 200.8	0.00024	10/16/2019	15:32	E82574
1015	Cadmium	0.005	mg/L	0.000064	U	EPA 200.8	0.000064	10/16/2019	15:32	E82574
1020	Chromium	0.1	mg/L	0.0020	U	EPA 200.7	0.0020	10/15/2019	13:07	E84589
1025	Fluoride	4.0	mg/L	0.34	I	EPA 300.0	0.20	10/18/2019	09:26	E84589
1030	Lead	0.015	mg/L	0.00024	U	EPA 200.8	0.00024	10/16/2019	15:32	E82574
1036	Nickel	0.1	mg/L	0.0044	U	EPA 200.7	0.0044	10/15/2019	13:07	E84589
1045	Selenium	0.05	mg/L	0.00058	U	EPA 200.8	0.00058	10/16/2019	15:32	E82574
1052	Sodium	160	mg/L	30		EPA 200.7	0.50	10/15/2019	13:07	E84589
1074	Antimony	0.006	mg/L	0.00011	U	EPA 200.8	0.00011	10/16/2019	15:32	E82574
1075	Beryllium	0.004	mg/L	0.00029	U	EPA 200.7	0.00029	10/15/2019	13:07	E84589
1085	Thallium	0.002	mg/L	0.000057	U	EPA 200.8	0.000057	10/16/2019	15:32	E82574

Florida Department of Environmental Protection

Safe Drinking Water Program Laboratory Reporting Format

SECONDARY CONTAMINANTS

62-550.320

Report Number / Job ID: T1918076002

PWS ID (From Page 1): 6511423

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	Analysis Date	Analysis Time	DOH Lab Certification #
1002	Aluminum	0.2	mg/L	0.025	U	EPA 200.7	0.025	10/15/2019	13:07	E84589
1017	Chloride	250	mg/L	26		EPA 300.0	2.0	10/18/2019	09:26	E84589
1022	Copper	1	mg/L	0.0021		EPA 200.8	0.00035	10/16/2019	15:32	E82574
1025	Fluoride	2.0	mg/L	0.34	I	EPA 300.0	0.20	10/18/2019	09:26	E84589
1028	Iron	0.3	mg/L	0.27		EPA 200.7	0.026	10/15/2019	13:07	E84589
1032	Manganese	0.05	mg/L	0.0051		EPA 200.8	0.00055	10/16/2019	15:32	E82574
1050	Silver	0.1	mg/L	0.00062		EPA 200.8	0.000068	10/16/2019	15:32	E82574
1055	Sulfate	250	mg/L	80		EPA 300.0	2.0	10/18/2019	09:26	E84589
1095	Zinc	5	mg/L	0.0062	I	EPA 200.8	0.0052	10/16/2019	15:32	E82574
1905	Color	15	PCU	2.7	U	SM 2120 B	2.7	10/09/2019	13:00	E84589
1920	Odor	3	TON @ 40°C	1.0	U	SM 2150 B	1.0	10/10/2019	14:30	E84589
1930	Total Dissolved Solids	500	mg/L	350		SM 2540 C	10	10/15/2019	10:00	E84589
2905	Foaming Agents	0.5	mg/L	0.040	U	SM 5540 C	0.040	10/11/2019	13:42	E82001

*Results must be reported with appropriate qualifiers in accordance with Florida Administrative Code Rule 62-160, Table 1. Results qualified with A, F, H, N, O, T, Z, ?, *, are unacceptable for compliance with 62-550. Results qualified with a J, Q, R, or Y must be accompanied by written justification and will be evaluated on a case by case basis. To avoid a monitoring violation, unacceptable results must be replaced with acceptable results from samples collected during the same monitoring period.

Florida Department of Environmental Protection Safe Drinking Water Program Laboratory Reporting Format

PUBLIC WATER SYSTEM INFORMATION (to be completed by sampler – Please type or print legibly)

System Name: _____ PWS I.D.#:

System Type (check one): Community Nontransient Noncommunity Transient Noncommunity

Address: _____

City: _____ ZIP Code: _____

Phone #: _____ Fax #: _____ E-Mail Address: _____

SAMPLE INFORMATION (to be completed by sampler)

Sample Number: T1918076003 Sample Date: 10/09/2019 Sample Time: 15:30 AM PM (circle one)

Sample Location (be specific): 11436 Gold Rd CI2-3.6 Location Code (if known) : _____

Disinfectant Residual (Required when reporting results for trihalomethanes and haloacetic acids): _____ mg/L Field pH: _____

Sample Type (Check Only One)

- Distribution
- Entry Point (to Distribution)
- Plant Tap (not for compliance with 62-550)
- Raw (at well or intake)
- Max Residence Time
- Ave Residence Time
- Near First Customer

Reason(s) for Sample (Check all that apply)

- Routine Compliance with 62-550
- Confirmation of MCL Exceedance *
- Composite of Multiple Sites **
- Other: _____
- Replacement (of Invalidated Sample)
- Special (not for compliance with 62-550)
- Clearance (permitting)

Sampling Procedure Used or Other Comments:

***See 62-550.500(6) for requirements and restrictions.
And 62-550.512(3) for nitrate or nitrite exceedances.**

****See 62-550.550(4) for requirements and
attach a results page for each site.**

SAMPLER CERTIFICATION

I, _____, _____, do HEREBY CERTIFY
(Print Name) (Print Title)

that the above public water system and sample collection information is complete and correct.

Signature: _____ Date: _____

Certified Operator #: _____ Phone #: _____ Sampler's Fax #: _____

Sampler's E-Mail: _____

Florida Department of Environmental Protection Safe Drinking Water Program Laboratory Reporting Format

LABORATORY CERTIFICATION INFORMATION (to be completed by lab – Please type or print legibly)

Lab Name: Advanced Environmental Laboratories, Inc Florida DOH Certification #: E84589 Certification Expiration Date: 06/30/2020

ATTACH CURRENT DOH ANALYTE *

Address: 9610 Princess Palm Ave Tampa, FL 33619 Payments: P.O. Box Phone #: (813)630-9616

Were any analyses subcontracted? Yes No If yes, please provide DOH certification numbers: E82574 E82001

ATTACH DOH ANALYTE SHEET FOR EACH SUBCONTRACTED *

ANALYSIS INFORMATION (to be completed by lab)

Date Sample(s) Received: 10/10/2019

PWS ID (From Page 1): 6511423 Sample Number (From Page 1): T1918076003 Lab Assigned Report # or Job T1918076

Group(s) Analyzed & Results attached for compliance with Chapter 62-550, F.A.C. (Check all that apply):

Inorganics

- All Except Asbestos
 Partial
 Nitrate
 Nitrite
 Asbestos Only

Synthetic Organics

- All 30
 All Except Dioxin
 Partial
 Dioxin Only

Volatile Organics

- All 21
 Partial

Disinfection Byproducts

- Trihalomethanes
 Haloacetic Acids
 Chlorite
 Bromate

Radionuclides

- Single Sample
 Qtrly Composite**

Secondaries

- All 14
 Partial

LAB CERTIFICATION

I, Joseph J. Vondrick, Project Manager, do HEREBY CERTIFY
(Print Name) (Print Title)

that all attached analytical data are correct and unless noted meet all requirements of the National Environmental Laboratory Accreditation Conference

Signature:  Date: 10/24/2019

* Failure to provide a valid and current Florida DOH lab certification number and a current Analyte Sheet for the attached analysis results will result in rejection of the report, possible enforcement against the public water system for failure to sample, and may result in notification of the DOH Bureau of Laboratory Services.

** Please provide radiological sample dates & locations for each quarter.

CONFIRMATION & NOTIFICATION IS REQUIRED WITHIN 24 HRS FOR NITRATE OR NITRITE MCL EXCEEDANCES

NON-DETECTS ARE TO BE REPORTED AS THE MDL WITH A "U" QUALIFIER. (Non-detects reported as "BDL" or with a "<" are not acceptable.)

COMPLIANCE DETERMINATION (to be completed by DEP or DOH -- attach notes as necessary)

Sample Collection & Analysis Satisfactory: Yes No Replacement Sample or Report Requested: Yes No (circle or highlight group(s) above)

Person Notified: _____ Date Notified: _____ DEP/DOH Reviewing Official: _____

Florida Department of Environmental Protection

Safe Drinking Water Program Laboratory Reporting Format

INORGANIC CONTAMINANTS
62-550.310(1)

Report Number / Job ID: T1918076003

PWS ID (From Page 1): 6511423

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	Analysis Date	Analysis Time	DOH Lab Certification
1005	Arsenic	0.010	mg/L	0.00016	I	EPA 200.8	0.000077	10/16/2019	15:37	E82574
1010	Barium	2	mg/L	0.012		EPA 200.8	0.00024	10/16/2019	15:37	E82574
1015	Cadmium	0.005	mg/L	0.000064	U	EPA 200.8	0.000064	10/16/2019	15:37	E82574
1020	Chromium	0.1	mg/L	0.0020	U	EPA 200.7	0.0020	10/15/2019	13:10	E84589
1025	Fluoride	4.0	mg/L	0.27	I	EPA 300.0	0.20	10/18/2019	09:42	E84589
1030	Lead	0.015	mg/L	0.00024	U	EPA 200.8	0.00024	10/16/2019	15:37	E82574
1036	Nickel	0.1	mg/L	0.0044	U	EPA 200.7	0.0044	10/15/2019	13:10	E84589
1045	Selenium	0.05	mg/L	0.00058	U	EPA 200.8	0.00058	10/16/2019	15:37	E82574
1052	Sodium	160	mg/L	30		EPA 200.7	0.50	10/15/2019	13:10	E84589
1074	Antimony	0.006	mg/L	0.00011	U	EPA 200.8	0.00011	10/16/2019	15:37	E82574
1075	Beryllium	0.004	mg/L	0.00029	U	EPA 200.7	0.00029	10/15/2019	13:10	E84589
1085	Thallium	0.002	mg/L	0.000057	U	EPA 200.8	0.000057	10/16/2019	15:37	E82574

*Results must be reported with appropriate qualifiers in accordance with Florida Administrative Code Rule 62-160, Table 1. Results qualified with A, F, H, N, O, T, Z, ?, *, are unacceptable for compliance with 62-550. Results qualified with a J, Q, R, or Y must be accompanied by written justification and will be evaluated on a case by case basis. To avoid a monitoring violation, unacceptable results must be replaced with acceptable results from samples collected during the same monitoring period.

Florida Department of Environmental Protection

Safe Drinking Water Program Laboratory Reporting Format

SECONDARY CONTAMINANTS

62-550.320

Report Number / Job ID: T1918076003

PWS ID (From Page 1): 6511423

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	Analysis Date	Analysis Time	DOH Lab Certification #
1002	Aluminum	0.2	mg/L	0.025	U	EPA 200.7	0.025	10/15/2019	13:10	E84589
1017	Chloride	250	mg/L	26		EPA 300.0	2.0	10/18/2019	09:42	E84589
1022	Copper	1	mg/L	0.0035		EPA 200.8	0.00035	10/16/2019	15:37	E82574
1025	Fluoride	2.0	mg/L	0.27	I	EPA 300.0	0.20	10/18/2019	09:42	E84589
1028	Iron	0.3	mg/L	0.044	I	EPA 200.7	0.026	10/15/2019	13:10	E84589
1032	Manganese	0.05	mg/L	0.0021	I	EPA 200.8	0.00055	10/16/2019	15:37	E82574
1050	Silver	0.1	mg/L	0.0017		EPA 200.8	0.000068	10/16/2019	15:37	E82574
1055	Sulfate	250	mg/L	80		EPA 300.0	2.0	10/18/2019	09:42	E84589
1095	Zinc	5	mg/L	0.0063	I	EPA 200.8	0.0052	10/16/2019	15:37	E82574
1905	Color	15	PCU	2.7	U	SM 2120 B	2.7	10/09/2019	13:00	E84589
1920	Odor	3	TON @ 40°C	1.0	U	SM 2150 B	1.0	10/10/2019	14:30	E84589
1930	Total Dissolved Solids	500	mg/L	350		SM 2540 C	10	10/15/2019	10:00	E84589
2905	Foaming Agents	0.5	mg/L	0.040	U	SM 5540 C	0.040	10/11/2019	13:42	E82001

*Results must be reported with appropriate qualifiers in accordance with Florida Administrative Code Rule 62-160, Table 1. Results qualified with A, F, H, N, O, T, Z, ?, *, are unacceptable for compliance with 62-550. Results qualified with a J, Q, R, or Y must be accompanied by written justification and will be evaluated on a case by case basis. To avoid a monitoring violation, unacceptable results must be replaced with acceptable results from samples collected during the same monitoring period.

Florida Department of Environmental Protection Safe Drinking Water Program Laboratory Reporting Format

PUBLIC WATER SYSTEM INFORMATION (to be completed by sampler – Please type or print legibly)

System Name: _____ PWS I.D.#:

System Type (check one): Community Nontransient Noncommunity Transient Noncommunity

Address: _____

City: _____ ZIP Code: _____

Phone #: _____ Fax #: _____ E-Mail Address: _____

SAMPLE INFORMATION (to be completed by sampler)

Sample Number: T1918076004 Sample Date: 10/09/2019 Sample Time: 16:00 AM PM (circle one)

Sample Location (be specific): 11800 Ivywood CI2-2.4 Location Code (if known) : _____

Disinfectant Residual (Required when reporting results for trihalomethanes and haloacetic acids): _____ mg/L Field pH: _____

Sample Type (Check Only One)

- Distribution
- Entry Point (to Distribution)
- Plant Tap (not for compliance with 62-550)
- Raw (at well or intake)
- Max Residence Time
- Ave Residence Time
- Near First Customer

Reason(s) for Sample (Check all that apply)

- Routine Compliance with 62-550
- Confirmation of MCL Exceedance *
- Composite of Multiple Sites **
- Other: _____
- Replacement (of Invalidated Sample)
- Special (not for compliance with 62-550)
- Clearance (permitting)

Sampling Procedure Used or Other Comments: _____

***See 62-550.500(6) for requirements and restrictions.
And 62-550.512(3) for nitrate or nitrite exceedances.**

****See 62-550.550(4) for requirements and
attach a results page for each site.**

SAMPLER CERTIFICATION

I, _____, _____, do HEREBY CERTIFY
(Print Name) (Print Title)

that the above public water system and sample collection information is complete and correct.

Signature: _____ Date: _____

Certified Operator #: _____ Phone #: _____ Sampler's Fax #: _____

Sampler's E-Mail: _____

Florida Department of Environmental Protection Safe Drinking Water Program Laboratory Reporting Format

LABORATORY CERTIFICATION INFORMATION (to be completed by lab – Please type or print legibly)

Lab Name: Advanced Environmental Laboratories, Inc Florida DOH Certification #: E84589 Certification Expiration Date: 06/30/2020

ATTACH CURRENT DOH ANALYTE *

Address: 9610 Princess Palm Ave Tampa, FL 33619 Payments: P.O. Box Phone #: (813)630-9616

Were any analyses subcontracted? Yes No If yes, please provide DOH certification numbers: E82574 E82001

ATTACH DOH ANALYTE SHEET FOR EACH SUBCONTRACTED *

ANALYSIS INFORMATION (to be completed by lab)

Date Sample(s) Received: 10/10/2019

PWS ID (From Page 1): 6511423 Sample Number (From Page 1): T1918076004 Lab Assigned Report # or Job T1918076

Group(s) Analyzed & Results attached for compliance with Chapter 62-550, F.A.C. (Check all that apply):

Inorganics

- All Except Asbestos
 Partial
 Nitrate
 Nitrite
 Asbestos Only

Synthetic Organics

- All 30
 All Except Dioxin
 Partial
 Dioxin Only

Volatile Organics

- All 21
 Partial

Disinfection Byproducts

- Trihalomethanes
 Haloacetic Acids
 Chlorite
 Bromate

Radionuclides

- Single Sample
 Qtrly Composite**

Secondaries

- All 14
 Partial

LAB CERTIFICATION

I, Joseph J. Vondrick, Project Manager, do HEREBY CERTIFY
(Print Name) (Print Title)

that all attached analytical data are correct and unless noted meet all requirements of the National Environmental Laboratory Accreditation Conference

Signature:  Date: 10/24/2019

* Failure to provide a valid and current Florida DOH lab certification number and a current Analyte Sheet for the attached analysis results will result in rejection of the report, possible enforcement against the public water system for failure to sample, and may result in notification of the DOH Bureau of Laboratory Services.

** Please provide radiological sample dates & locations for each quarter.

CONFIRMATION & NOTIFICATION IS REQUIRED WITHIN 24 HRS FOR NITRATE OR NITRITE MCL EXCEEDANCES

NON-DETECTS ARE TO BE REPORTED AS THE MDL WITH A "U" QUALIFIER. (Non-detects reported as "BDL" or with a "<" are not acceptable.)

COMPLIANCE DETERMINATION (to be completed by DEP or DOH -- attach notes as necessary)

Sample Collection & Analysis Satisfactory: Yes No Replacement Sample or Report Requested: Yes No (circle or highlight group(s) above)

Person Notified: _____ Date Notified: _____ DEP/DOH Reviewing Official: _____

Florida Department of Environmental Protection

Safe Drinking Water Program Laboratory Reporting Format

INORGANIC CONTAMINANTS

62-550.310(1)

Report Number / Job ID: T1918076004

PWS ID (From Page 1): 6511423

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	Analysis Date	Analysis Time	DOH Lab Certification
1005	Arsenic	0.010	mg/L	0.00047	I	EPA 200.8	0.000077	10/16/2019	15:42	E82574
1010	Barium	2	mg/L	0.013		EPA 200.8	0.00024	10/16/2019	15:42	E82574
1015	Cadmium	0.005	mg/L	0.000064	U	EPA 200.8	0.000064	10/16/2019	15:42	E82574
1020	Chromium	0.1	mg/L	0.0020	U	EPA 200.7	0.0020	10/15/2019	13:33	E84589
1025	Fluoride	4.0	mg/L	0.31	I	EPA 300.0	0.20	10/18/2019	09:58	E84589
1030	Lead	0.015	mg/L	0.00028	I	EPA 200.8	0.00024	10/16/2019	15:42	E82574
1036	Nickel	0.1	mg/L	0.0044	U	EPA 200.7	0.0044	10/15/2019	13:33	E84589
1045	Selenium	0.05	mg/L	0.00058	U	EPA 200.8	0.00058	10/16/2019	15:42	E82574
1052	Sodium	160	mg/L	30		EPA 200.7	0.50	10/15/2019	13:33	E84589
1074	Antimony	0.006	mg/L	0.00011	U	EPA 200.8	0.00011	10/16/2019	15:42	E82574
1075	Beryllium	0.004	mg/L	0.00029	U	EPA 200.7	0.00029	10/15/2019	13:33	E84589
1085	Thallium	0.002	mg/L	0.000057	U	EPA 200.8	0.000057	10/16/2019	15:42	E82574

*Results must be reported with appropriate qualifiers in accordance with Florida Administrative Code Rule 62-160, Table 1. Results qualified with A, F, H, N, O, T, Z, ?, *, are unacceptable for compliance with 62-550. Results qualified with a J, Q, R, or Y must be accompanied by written justification and will be evaluated on a case by case basis. To avoid a monitoring violation, unacceptable results must be replaced with acceptable results from samples collected during the same monitoring period.

Florida Department of Environmental Protection

Safe Drinking Water Program Laboratory Reporting Format

SECONDARY CONTAMINANTS

62-550.320

Report Number / Job ID: T1918076004

PWS ID (From Page 1): 6511423

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	Analysis Date	Analysis Time	DOH Lab Certification #
1002	Aluminum	0.2	mg/L	0.025	U	EPA 200.7	0.025	10/15/2019	13:33	E84589
1017	Chloride	250	mg/L	26		EPA 300.0	2.0	10/18/2019	09:58	E84589
1022	Copper	1	mg/L	0.0022		EPA 200.8	0.00035	10/16/2019	15:42	E82574
1025	Fluoride	2.0	mg/L	0.31	I	EPA 300.0	0.20	10/18/2019	09:58	E84589
1028	Iron	0.3	mg/L	1.1		EPA 200.7	0.026	10/15/2019	13:33	E84589
1032	Manganese	0.05	mg/L	0.012		EPA 200.8	0.00055	10/16/2019	15:42	E82574
1050	Silver	0.1	mg/L	0.00038	I	EPA 200.8	0.000068	10/16/2019	15:42	E82574
1055	Sulfate	250	mg/L	80		EPA 300.0	2.0	10/18/2019	09:58	E84589
1095	Zinc	5	mg/L	0.0075	I	EPA 200.8	0.0052	10/16/2019	15:42	E82574
1905	Color	15	PCU	2.7	U	SM 2120 B	2.7	10/09/2019	13:00	E84589
1920	Odor	3	TON @ 40°C	1.0	U	SM 2150 B	1.0	10/10/2019	14:30	E84589
1930	Total Dissolved Solids	500	mg/L	350		SM 2540 C	10	10/15/2019	10:00	E84589
2905	Foaming Agents	0.5	mg/L	0.043	I	SM 5540 C	0.040	10/11/2019	13:42	E82001

*Results must be reported with appropriate qualifiers in accordance with Florida Administrative Code Rule 62-160, Table 1. Results qualified with A, F, H, N, O, T, Z, ?, *, are unacceptable for compliance with 62-550. Results qualified with a J, Q, R, or Y must be accompanied by written justification and will be evaluated on a case by case basis. To avoid a monitoring violation, unacceptable results must be replaced with acceptable results from samples collected during the same monitoring period.

**Florida Department of Environmental Protection
Safe Drinking Water Program Laboratory Reporting Format**

PUBLIC WATER SYSTEM INFORMATION (to be completed by sampler – Please type or print legibly)

System Name: _____ PWS I.D.#:

System Type (check one): Community Nontransient Noncommunity Transient Noncommunity

Address: _____

City: _____ ZIP Code: _____

Phone #: _____ Fax #: _____ E-Mail Address: _____

SAMPLE INFORMATION (to be completed by sampler)

Sample Number: T1918076005 Sample Date: 10/09/2019 Sample Time: 16:30 AM PM (circle one)

Sample Location (be specific): 11219 Merganser CI2-2.5 Location Code (if known) : _____

Disinfectant Residual (Required when reporting results for trihalomethanes and haloacetic acids): _____ mg/L Field pH: _____

Sample Type (Check Only One)

- Distribution
- Entry Point (to Distribution)
- Plant Tap (not for compliance with 62-550)
- Raw (at well or intake)
- Max Residence Time
- Ave Residence Time
- Near First Customer

Reason(s) for Sample (Check all that apply)

- Routine Compliance with 62-550
- Confirmation of MCL Exceedance *
- Composite of Multiple Sites **
- Other: _____
- Replacement (of Invalidated Sample)
- Special (not for compliance with 62-550)
- Clearance (permitting)

Sampling Procedure Used or Other Comments: _____

***See 62-550.500(6) for requirements and restrictions.
And 62-550.512(3) for nitrate or nitrite exceedances.**

****See 62-550.550(4) for requirements and
attach a results page for each site.**

SAMPLER CERTIFICATION

I, _____, _____, do HEREBY CERTIFY
(Print Name) (Print Title)

that the above public water system and sample collection information is complete and correct.

Signature: _____ Date: _____

Certified Operator #: _____ Phone #: _____ Sampler's Fax #: _____

Sampler's E-Mail: _____

Florida Department of Environmental Protection Safe Drinking Water Program Laboratory Reporting Format

LABORATORY CERTIFICATION INFORMATION (to be completed by lab – Please type or print legibly)

Lab Name: Advanced Environmental Laboratories, Inc Florida DOH Certification #: E84589 Certification Expiration Date: 06/30/2020

ATTACH CURRENT DOH ANALYTE *

Address: 9610 Princess Palm Ave Tampa, FL 33619 Payments: P.O. Box Phone #: (813)630-9616

Were any analyses subcontracted? Yes No If yes, please provide DOH certification numbers: E82574 E82001

ATTACH DOH ANALYTE SHEET FOR EACH SUBCONTRACTED *

ANALYSIS INFORMATION (to be completed by lab)

Date Sample(s) Received: 10/10/2019

PWS ID (From Page 1): 6511423 Sample Number (From Page 1): T1918076005 Lab Assigned Report # or Job T1918076

Group(s) Analyzed & Results attached for compliance with Chapter 62-550, F.A.C. (Check all that apply):

Inorganics

- All Except Asbestos
 Partial
 Nitrate
 Nitrite
 Asbestos Only

Synthetic Organics

- All 30
 All Except Dioxin
 Partial
 Dioxin Only

Volatile Organics

- All 21
 Partial

Disinfection Byproducts

- Trihalomethanes
 Haloacetic Acids
 Chlorite
 Bromate

Radionuclides

- Single Sample
 Qtrly Composite**

Secondaries

- All 14
 Partial

LAB CERTIFICATION

I, Joseph J. Vondrick, Project Manager, do HEREBY CERTIFY
(Print Name) (Print Title)

that all attached analytical data are correct and unless noted meet all requirements of the National Environmental Laboratory Accreditation Conference

Signature:  Date: 10/24/2019

* Failure to provide a valid and current Florida DOH lab certification number and a current Analyte Sheet for the attached analysis results will result in rejection of the report, possible enforcement against the public water system for failure to sample, and may result in notification of the DOH Bureau of Laboratory Services.

** Please provide radiological sample dates & locations for each quarter.

CONFIRMATION & NOTIFICATION IS REQUIRED WITHIN 24 HRS FOR NITRATE OR NITRITE MCL EXCEEDANCES

NON-DETECTS ARE TO BE REPORTED AS THE MDL WITH A "U" QUALIFIER. (Non-detects reported as "BDL" or with a "<" are not acceptable.)

COMPLIANCE DETERMINATION (to be completed by DEP or DOH -- attach notes as necessary)

Sample Collection & Analysis Satisfactory: Yes No Replacement Sample or Report Requested: Yes No (circle or highlight group(s) above)

Person Notified: _____ Date Notified: _____ DEP/DOH Reviewing Official: _____

Florida Department of Environmental Protection

Safe Drinking Water Program Laboratory Reporting Format

INORGANIC CONTAMINANTS
62-550.310(1)

Report Number / Job ID: T1918076005

PWS ID (From Page 1): 6511423

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	Analysis Date	Analysis Time	DOH Lab Certification
1005	Arsenic	0.010	mg/L	0.00051	I	EPA 200.8	0.000077	10/16/2019	15:58	E82574
1010	Barium	2	mg/L	0.013		EPA 200.8	0.00024	10/16/2019	15:58	E82574
1015	Cadmium	0.005	mg/L	0.000064	U	EPA 200.8	0.000064	10/16/2019	15:58	E82574
1020	Chromium	0.1	mg/L	0.0020	U	EPA 200.7	0.0020	10/15/2019	13:36	E84589
1025	Fluoride	4.0	mg/L	0.34	I	EPA 300.0	0.20	10/18/2019	11:50	E84589
1030	Lead	0.015	mg/L	0.00027	I	EPA 200.8	0.00024	10/16/2019	15:58	E82574
1036	Nickel	0.1	mg/L	0.0044	U	EPA 200.7	0.0044	10/15/2019	13:36	E84589
1045	Selenium	0.05	mg/L	0.00058	U	EPA 200.8	0.00058	10/16/2019	15:58	E82574
1052	Sodium	160	mg/L	30		EPA 200.7	0.50	10/15/2019	13:36	E84589
1074	Antimony	0.006	mg/L	0.00011	U	EPA 200.8	0.00011	10/16/2019	15:58	E82574
1075	Beryllium	0.004	mg/L	0.00029	U	EPA 200.7	0.00029	10/15/2019	13:36	E84589
1085	Thallium	0.002	mg/L	0.000057	U	EPA 200.8	0.000057	10/16/2019	15:58	E82574

*Results must be reported with appropriate qualifiers in accordance with Florida Administrative Code Rule 62-160, Table 1. Results qualified with A, F, H, N, O, T, Z, ?, *, are unacceptable for compliance with 62-550. Results qualified with a J, Q, R, or Y must be accompanied by written justification and will be evaluated on a case by case basis. To avoid a monitoring violation, unacceptable results must be replaced with acceptable results from samples collected during the same monitoring period.

Florida Department of Environmental Protection

Safe Drinking Water Program Laboratory Reporting Format

SECONDARY CONTAMINANTS

62-550.320

Report Number / Job ID: T1918076005

PWS ID (From Page 1): 6511423

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	Analysis Date	Analysis Time	DOH Lab Certification #
1002	Aluminum	0.2	mg/L	0.025	U	EPA 200.7	0.025	10/15/2019	13:36	E84589
1017	Chloride	250	mg/L	28		EPA 300.0	2.0	10/18/2019	11:50	E84589
1022	Copper	1	mg/L	0.0021		EPA 200.8	0.00035	10/16/2019	15:58	E82574
1025	Fluoride	2.0	mg/L	0.34	I	EPA 300.0	0.20	10/18/2019	11:50	E84589
1028	Iron	0.3	mg/L	0.99		EPA 200.7	0.026	10/15/2019	13:36	E84589
1032	Manganese	0.05	mg/L	0.011		EPA 200.8	0.00055	10/16/2019	15:58	E82574
1050	Silver	0.1	mg/L	0.00034	I	EPA 200.8	0.000068	10/16/2019	15:58	E82574
1055	Sulfate	250	mg/L	84		EPA 300.0	2.0	10/18/2019	11:50	E84589
1095	Zinc	5	mg/L	0.0075	I	EPA 200.8	0.0052	10/16/2019	15:58	E82574
1905	Color	15	PCU	2.7	U	SM 2120 B	2.7	10/09/2019	13:00	E84589
1920	Odor	3	TON @ 40°C	1.0	U	SM 2150 B	1.0	10/10/2019	14:30	E84589
1930	Total Dissolved Solids	500	mg/L	360		SM 2540 C	10	10/15/2019	10:00	E84589
2905	Foaming Agents	0.5	mg/L	0.043	I	SM 5540 C	0.040	10/11/2019	13:42	E82001

*Results must be reported with appropriate qualifiers in accordance with Florida Administrative Code Rule 62-160, Table 1. Results qualified with A, F, H, N, O, T, Z, ?, *, are unacceptable for compliance with 62-550. Results qualified with a J, Q, R, or Y must be accompanied by written justification and will be evaluated on a case by case basis. To avoid a monitoring violation, unacceptable results must be replaced with acceptable results from samples collected during the same monitoring period.

Florida Department of Environmental Protection Safe Drinking Water Program Laboratory Reporting Format

PUBLIC WATER SYSTEM INFORMATION (to be completed by sampler – Please type or print legibly)

System Name: _____ PWS I.D.#:

System Type (check one): Community Nontransient Noncommunity Transient Noncommunity

Address: _____

City: _____ ZIP Code: _____

Phone #: _____ Fax #: _____ E-Mail Address: _____

SAMPLE INFORMATION (to be completed by sampler)

Sample Number: T1918076006 Sample Date: 10/09/2019 Sample Time: 16:20 AM PM (circle one)

Sample Location (be specific): 11001 Kiskadee CI2-2.2 Location Code (if known) : _____

Disinfectant Residual (Required when reporting results for trihalomethanes and haloacetic acids): _____ mg/L Field pH: _____

Sample Type (Check Only One)

- Distribution
- Entry Point (to Distribution)
- Plant Tap (not for compliance with 62-550)
- Raw (at well or intake)
- Max Residence Time
- Ave Residence Time
- Near First Customer

Reason(s) for Sample (Check all that apply)

- Routine Compliance with 62-550
- Confirmation of MCL Exceedance *
- Composite of Multiple Sites **
- Other: _____
- Replacement (of Invalidated Sample)
- Special (not for compliance with 62-550)
- Clearance (permitting)

Sampling Procedure Used or Other Comments: _____

***See 62-550.500(6) for requirements and restrictions.
And 62-550.512(3) for nitrate or nitrite exceedances.**

****See 62-550.550(4) for requirements and
attach a results page for each site.**

SAMPLER CERTIFICATION

I, _____, _____, do HEREBY CERTIFY
(Print Name) (Print Title)

that the above public water system and sample collection information is complete and correct.

Signature: _____ Date: _____

Certified Operator #: _____ Phone #: _____ Sampler's Fax #: _____

Sampler's E-Mail: _____

Florida Department of Environmental Protection Safe Drinking Water Program Laboratory Reporting Format

LABORATORY CERTIFICATION INFORMATION (to be completed by lab – Please type or print legibly)

Lab Name: Advanced Environmental Laboratories, Inc Florida DOH Certification #: E84589 Certification Expiration Date: 06/30/2020

ATTACH CURRENT DOH ANALYTE *

Address: 9610 Princess Palm Ave Tampa, FL 33619 Payments: P.O. Box Phone #: (813)630-9616

Were any analyses subcontracted? Yes No If yes, please provide DOH certification numbers: E82574 E82001

ATTACH DOH ANALYTE SHEET FOR EACH SUBCONTRACTED *

ANALYSIS INFORMATION (to be completed by lab)

Date Sample(s) Received: 10/10/2019

PWS ID (From Page 1): 6511423 Sample Number (From Page 1): T1918076006 Lab Assigned Report # or Job T1918076

Group(s) Analyzed & Results attached for compliance with Chapter 62-550, F.A.C. (Check all that apply):

Inorganics

- All Except Asbestos
- Partial
- Nitrate
- Nitrite
- Asbestos Only

Synthetic Organics

- All 30
- All Except Dioxin
- Partial
- Dioxin Only

Volatile Organics

- All 21
- Partial

Disinfection Byproducts

- Trihalomethanes
- Haloacetic Acids
- Chlorite
- Bromate

Radionuclides

- Single Sample
- Qtrly Composite**

Secondaries

- All 14
- Partial

LAB CERTIFICATION

I, Joseph J. Vondrick, Project Manager, do HEREBY CERTIFY
(Print Name) (Print Title)

that all attached analytical data are correct and unless noted meet all requirements of the National Environmental Laboratory Accreditation Conference

Signature:  Date: 10/24/2019

* Failure to provide a valid and current Florida DOH lab certification number and a current Analyte Sheet for the attached analysis results will result in rejection of the report, possible enforcement against the public water system for failure to sample, and may result in notification of the DOH Bureau of Laboratory Services.

** Please provide radiological sample dates & locations for each quarter.

CONFIRMATION & NOTIFICATION IS REQUIRED WITHIN 24 HRS FOR NITRATE OR NITRITE MCL EXCEEDANCES

NON-DETECTS ARE TO BE REPORTED AS THE MDL WITH A "U" QUALIFIER. (Non-detects reported as "BDL" or with a "<" are not acceptable.)

COMPLIANCE DETERMINATION (to be completed by DEP or DOH -- attach notes as necessary)

Sample Collection & Analysis Satisfactory: Yes No Replacement Sample or Report Requested: Yes No (circle or highlight group(s) above)

Person Notified: _____ Date Notified: _____ DEP/DOH Reviewing Official: _____

Florida Department of Environmental Protection Safe Drinking Water Program Laboratory Reporting Format

INORGANIC CONTAMINANTS
62-550.310(1)

Report Number / Job ID: T1918076006

PWS ID (From Page 1): 6511423

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	Analysis Date	Analysis Time	DOH Lab Certification
1005	Arsenic	0.010	mg/L	0.00032	I	EPA 200.8	0.000077	10/16/2019	16:03	E82574
1010	Barium	2	mg/L	0.012		EPA 200.8	0.00024	10/16/2019	16:03	E82574
1015	Cadmium	0.005	mg/L	0.000064	U	EPA 200.8	0.000064	10/16/2019	16:03	E82574
1020	Chromium	0.1	mg/L	0.0020	U	EPA 200.7	0.0020	10/15/2019	13:40	E84589
1025	Fluoride	4.0	mg/L	0.32	I	EPA 300.0	0.20	10/18/2019	12:06	E84589
1030	Lead	0.015	mg/L	0.00024	U	EPA 200.8	0.00024	10/16/2019	16:03	E82574
1036	Nickel	0.1	mg/L	0.0044	U	EPA 200.7	0.0044	10/15/2019	13:40	E84589
1045	Selenium	0.05	mg/L	0.00058	U	EPA 200.8	0.00058	10/16/2019	16:03	E82574
1052	Sodium	160	mg/L	30		EPA 200.7	0.50	10/15/2019	13:40	E84589
1074	Antimony	0.006	mg/L	0.00011	U	EPA 200.8	0.00011	10/16/2019	16:03	E82574
1075	Beryllium	0.004	mg/L	0.00029	U	EPA 200.7	0.00029	10/15/2019	13:40	E84589
1085	Thallium	0.002	mg/L	0.000057	U	EPA 200.8	0.000057	10/16/2019	16:03	E82574

Florida Department of Environmental Protection

Safe Drinking Water Program Laboratory Reporting Format

SECONDARY CONTAMINANTS

62-550.320

Report Number / Job ID: T1918076006

PWS ID (From Page 1): 6511423

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	Analysis Date	Analysis Time	DOH Lab Certification #
1002	Aluminum	0.2	mg/L	0.025	U	EPA 200.7	0.025	10/15/2019	13:40	E84589
1017	Chloride	250	mg/L	26		EPA 300.0	2.0	10/18/2019	12:06	E84589
1022	Copper	1	mg/L	0.0019		EPA 200.8	0.00035	10/16/2019	16:03	E82574
1025	Fluoride	2.0	mg/L	0.32	I	EPA 300.0	0.20	10/18/2019	12:06	E84589
1028	Iron	0.3	mg/L	0.51		EPA 200.7	0.026	10/15/2019	13:40	E84589
1032	Manganese	0.05	mg/L	0.0084		EPA 200.8	0.00055	10/16/2019	16:03	E82574
1050	Silver	0.1	mg/L	0.00026	I	EPA 200.8	0.000068	10/16/2019	16:03	E82574
1055	Sulfate	250	mg/L	80		EPA 300.0	2.0	10/18/2019	12:06	E84589
1095	Zinc	5	mg/L	0.0070	I	EPA 200.8	0.0052	10/16/2019	16:03	E82574
1905	Color	15	PCU	2.7	U	SM 2120 B	2.7	10/09/2019	13:00	E84589
1920	Odor	3	TON @ 40°C	1.0	U	SM 2150 B	1.0	10/10/2019	14:30	E84589
1930	Total Dissolved Solids	500	mg/L	300		SM 2540 C	10	10/15/2019	10:00	E84589
2905	Foaming Agents	0.5	mg/L	0.086	I	SM 5540 C	0.040	10/11/2019	13:42	E82001

*Results must be reported with appropriate qualifiers in accordance with Florida Administrative Code Rule 62-160, Table 1. Results qualified with A, F, H, N, O, T, Z, ?, *, are unacceptable for compliance with 62-550. Results qualified with a J, Q, R, or Y must be accompanied by written justification and will be evaluated on a case by case basis. To avoid a monitoring violation, unacceptable results must be replaced with acceptable results from samples collected during the same monitoring period.

