



MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

See page 4 for instructions.

I. General Information for the Month/Year of: August, 2020

A. Public Water System (PWS) Information

| | | | |
|--|--|--|--------------------------------|
| PWS Name: Oakland Shores | | PWS Identification Number: 3590912 | |
| PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive | | | |
| Number of Service Connections at End of Month: 226 | | Total Population Served at End of Month: 791 | |
| PWS Owner: Utilities, Inc. of Florida | | | |
| Contact Person: Patrick Flynn | | Contact Person's Title: Vice President | |
| Contact Person's Mailing Address: 200 Weathersfield Ave. | | City: Altamonte Springs | State: Florida Zip Code: 32714 |
| Contact Person's Telephone Number: (866) 842-8432, Ext. 1359 | | Contact Person's Fax Number: (407) 869-6961 | |
| Contact Person's E-Mail Address: Patrick.Flynn@uiwater.com | | | |

B. Water Treatment Plant Information

| Plant Name: Oakland Shores | | Plant Telephone Number: (866) 842-8432 | | |
|--|----------------|---|--------------------------------|------------------------|
| Plant Address: 620 Lake Shore Drive | | City: Maitland | State: Florida Zip Code: 32751 | |
| Type of Water Treated by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water | | | | |
| Permitted Maximum Day Operating Capacity of Plant, gallons per day: 360,000 | | | | |
| Plant Category (per subsection 62-699.310(4), F.A.C.): V | | Plant Class (per subsection 62-699.310(4), F.A.C.): C | | |
| Licensed Operators | Name | License Class | License Number | Day(s)/Shift(s) Worked |
| Lead/Chief Operator: | Don Hasty | A | 6625 | Monday - Friday |
| Other Operators: | Barner Cooks | B | 22170 | Sunday - Saturday |
| | Fred Rodgers | B | 13175 | Sunday - Saturday |
| | Jim Swegheimer | C | 7183 | Monday - Friday |
| | Dean Cowart | C | 23912 | Sunday - Saturday |
| | | | | |

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in Part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to retain these additional operations records at the plant site for at

| | | | |
|--------------------|-------------------|-----------------------|----------------|
| | September 1, 2020 | Don Hasty | A 6625 |
| Signature and Date | | Printed or Typed Name | License Number |

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3590912 Plant Name: Oakland Shores

III. Daily Data for the Month/Year of: Aug, 2020

Means of Achieving Four-Log Virus Inactivation/Removal: * Free Chlorine Chlorine Dioxide Ozone Combine Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combine Chlorine (Chloramines) Chlorine Dioxide

| Day of the Month | Days plant staffed or Visited by Operator (place X) | Hours Plant in Operation | Net Quantity of Finished Water Produced, gal | CT Calculations, or UV Dose, to Demonstrate Four-Log Virus Inactivation, if Applicable* | | | | | | | | | | Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L | Emergency or Abnormal Operating Conditions; Repair or Maintenance Work that Involves Taking Water System Components Out of Operation | |
|------------------|---|--------------------------|--|---|---|--|---|-------------------|----------------------------|-------------------------------|--------------------------------------|--------------------------------------|--|---|--|------------------|
| | | | | CT Calculations | | | | | UV Dose | | | | | | | |
| | | | | Peak Flow Rate, gpm | Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L | Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes | Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L | Temp. of Water, C | pH of Water, if Applicable | Minimum CT Required, mg-min/L | Lowest Operating UV Dose, mW-sec/cm2 | Minimum UV Dose Required, mW-sec/cm2 | | | | |
| 1 | X | 24 | 110,100 | | | | | | | | | | | | 2.0 | |
| 2 | | 24 | 77,900 | | | | | | | | | | | | | |
| 3 | X | 24 | 77,800 | | | | | | | | | | | | 2.4 | |
| 4 | X | 24 | 89,700 | | | | | | | | | | | | 0.7 | Collected bactis |
| 5 | X | 24 | 101,000 | | | | | | | | | | | | 2.6 | |
| 6 | X | 24 | 43,900 | | | | | | | | | | | | 2.7 | |
| 7 | X | 24 | 60,600 | | | | | | | | | | | | 0.8 | |
| 8 | X | 24 | 67,100 | | | | | | | | | | | | 1.7 | |
| 9 | | 24 | 68,400 | | | | | | | | | | | | | |
| 10 | X | 24 | 55,000 | | | | | | | | | | | | 1.4 | |
| 11 | X | 24 | 49,900 | | | | | | | | | | | | 2.2 | |
| 12 | X | 24 | 75,300 | | | | | | | | | | | | 0.4 | |
| 13 | X | 24 | 75,400 | | | | | | | | | | | | 2.5 | |
| 14 | X | 24 | 59,500 | | | | | | | | | | | | 1.2 | |
| 15 | X | 24 | 89,200 | | | | | | | | | | | | 1.5 | |
| 16 | | 24 | 71,900 | | | | | | | | | | | | | |
| 17 | X | 24 | 71,800 | | | | | | | | | | | | 1.8 | |
| 18 | X | 24 | 66,400 | | | | | | | | | | | | 2.2 | |
| 19 | X | 24 | 72,200 | | | | | | | | | | | | 2.7 | |
| 20 | X | 24 | 80,700 | | | | | | | | | | | | 2.5 | |
| 21 | X | 24 | 77,400 | | | | | | | | | | | | 2.7 | |
| 22 | X | 24 | 67,400 | | | | | | | | | | | | 2.8 | |
| 23 | | 24 | 66,100 | | | | | | | | | | | | | |
| 24 | X | 24 | 66,000 | | | | | | | | | | | | 2.3 | |
| 25 | X | 24 | 78,300 | | | | | | | | | | | | 2.2 | |
| 26 | X | 24 | 116,900 | | | | | | | | | | | | 2.4 | |
| 27 | X | 24 | 89,400 | | | | | | | | | | | | 2.3 | |
| 28 | X | 24 | 55,200 | | | | | | | | | | | | 2.4 | |
| 29 | X | 24 | 105,600 | | | | | | | | | | | | 2.6 | |
| 30 | | 24 | 68,800 | | | | | | | | | | | | | |
| 31 | X | 24 | 68,700 | | | | | | | | | | | | 2.4 | |

| | |
|---------|-----------|
| Total | 2,323,600 |
| Average | 74,955 |
| Maximum | 116,900 |

*Refer to the instructions for this report to determine which tests must provide this information.