

COMMISSIONERS:
GARY F. CLARK, CHAIRMAN
ART GRAHAM
ANDREW GILES FAY
MIKE LA ROSA
GABRIELLA PASSIDOMO

STATE OF FLORIDA



DIVISION OF ENGINEERING
TOM BALLINGER
DIRECTOR
(850) 413-6910

Public Service Commission

October 26, 2021

Susan Clark, Esq.
Radey Thomas Yon & Clark, P.A.
301 South Bronough Street, Suite 200
Tallahassee, FL 32301
sclark@radeylaw.com

**STAFF'S SECOND DATA REQUEST
VIA EMAIL**

Re: Docket No. 20210095-WU - Application for transfer of water facilities of Sunshine Utilities of Central Florida, Inc. and Water Certificate No. 363-W to CSWR-Florida Utility Operating Company, LLC, in Marion County.

Dear Ms. Clark:

Please provide the information requested below regarding CSWR-Florida Utility Operating Company, LLC (CSWR or Utility) to the Office of Commission Clerk by **November 16, 2021**.

1. Please provide any additional sanitary surveys or testing that was performed by the Utility or the Department of Environmental Protection (DEP) for any of its systems since the Utility filed its transfer application.
2. The January 23, 2018 Sanitary Survey for the Florida Heights system indicated a tank rupture on December 29, 2017. Please provide any documentation along with a status update regarding the Florida Heights system's hydropneumatic tank or any temporary tank being utilized.
3. The Utility indicated that it plans to install additional infrastructure, such as new flow meters on wells and containment chlorination equipment, where appropriate, to improve water quality. Please identify which systems will receive these improvements.
4. In response to staff's deficiency letter, dated June 24, 2021, the Utility indicated that there have been no consent orders or warning letters in the past five years. However, in response to staff's first data request, "compliance info" attachment, the Utility indicated several monitoring violations for varying systems. Please provide all documentation from the DEP and/or county health department identifying any violations noted.

Susan Clark, Esq.

Page 2

October 26, 2021

Please file all responses electronically at the Commission's website at www.floridapsc.com, by selecting the Clerk's Office and Electronic Filing Web Form. Please contact me by phone at (850) 413-6836 or by email at kmaloy@psc.state.fl.us, if you have any questions.

Sincerely,

/s/Kerri Maloy

Kerri Maloy

Engineering Specialist

KM/jp

cc: Thomas Crabb, Esq. (tcrabb@radeylaw.com)
Office of Commission Clerk (Docket No. 20210095-WU)