



Stephanie A. Cuello
Senior Counsel

October 20, 2022

VIA ELECTRONIC FILING

Mr. Adam Teitzman, Commission Clerk
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399-0850

Re: *Summary of Orange Cogen Event on October 17, 2022; Undocketed*

Dear Mr. Teitzman:

According to FPSC Rule 25-17.086, "Periods During Which Purchases are Not Required", Duke Energy Florida (DEF) is providing notice to the Florida Public Service Commission that Orange Cogen was required to go offline on 10/17/2022 due to required DEF transmission system work that impacted Orange Cogen. The Orange Cogen facility is interconnected to the DEF transmission system at the 69 kV Orange Switching Substation.

A transmission system outage was scheduled for the 69 kV bus at the Orange Switching Station beginning at 0800 hours on 10/17/2022. The scope of work for this outage was to repair the interphase adjuster on switch 3970E located at the Orange Switching Station. Orange Cogen was notified on 10/6/2022 at 1227 hours that this planned outage would require Orange Cogen to be offline for the duration of the outage.

DEF completed the required work and notified Orange Cogen that the outage was complete at 1356 hours on 10/17/2022. Orange Cogen was released to resume normal dispatching and operations effective immediately.

Thank you for your assistance in this matter. Please feel free to call me at (850) 521-1425 should you have any questions concerning this filing.

Respectfully,

s/Stephanie Cuello

Stephanie A. Cuello
Senior Counsel

SAC/vr