



Maria Jose Moncada
Assistant General Counsel
Florida Power & Light Company
700 Universe Boulevard
Juno Beach, FL 33408
(561) 304-5795
(561) 691-7135 (facsimile)
maria.moncada@fpl.com

June 20, 2024

-VIA ELECTRONIC FILING-

Adam Teitzman
Division of Commission Clerk
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, FL 32399-0850

Re: Docket No. 20240001-EI

Dear Mr. Teitzman:

Attached for electronic filing in the above docket are Florida Power & Light Company's GPIF Actual Unit Performance Data Schedules covering the month of May 2024. These schedules are being filed at the same time but separately from the monthly A-Schedules.

If there are any questions regarding this transmittal, please contact me at (561) 304-5795.

Sincerely,

s/ Maria Jose Moncada

Maria Jose Moncada

Attachments

cc: Counsel for Parties of Record (w/ attachment)

Florida Power & Light Company

700 Universe Boulevard, Juno Beach, FL 33408

:2219215

CERTIFICATE OF SERVICE
Docket No. 20240001-EI

I **HEREBY CERTIFY** that a true and correct copy of the foregoing has been furnished by electronic service on this 20th day of June 2024 to the following:

Suzanne Brownless
Ryan Sandy
Office of General Counsel
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399-0850
sbrownle@psc.state.fl.us
rsandy@psc.state.fl.us

J. Jeffrey Wahlen
Malcolm N. Means
Virginia Ponder
Ausley McMullen
Post Office Box 391
Tallahassee, Florida 32302
jwahlen@ausley.com
mmeans@ausley.com
vponder@ausley.com
Attorneys for Tampa Electric Company

Paula K. Brown
Manager, Regulatory Coordination
Tampa Electric Company
Post Office Box 111
Tampa, Florida 33601-0111
regdept@tecoenergy.com

Mike Cassel
Vice President/Governmental
and Regulatory Affairs
Florida Public Utilities Company
208 Wildlight Avenue
Yulee, Florida 32097
mcassel@fpuc.com

Walt Trierweiler
Charles J. Rehwinkel
Mary A. Wessling
Patricia A. Christensen
Octavio Ponce
Austin Watrous
Office of Public Counsel
The Florida Legislature
111 W. Madison Street, Room 812
Tallahassee, Florida 32399
trierweiler.walt@leg.state.fl.us
rehwinkel.charles@leg.state.fl.us
wessling.mary@leg.state.fl.us
christensen.patty@leg.state.fl.us
ponce.octavio@leg.state.fl.us
watrous.austin@leg.state.fl.us
**Attorneys for the Citizens of the State
of Florida**

Matthew R. Bernier
Robert L. Pickels
Stephanie A. Cuello
106 East College Avenue, Suite 800
Tallahassee, Florida 32301
matt.bernier@duke-energy.com
robert.pickels@duke-energy.com
stephanie.cuello@duke-energy.com
FLRegulatoryLegal@duke-energy.com
Attorneys for Duke Energy Florida

Dianne M. Triplett
299 First Avenue North
St. Petersburg, Florida 33701
dianne.triplett@duke-energy.com
Attorney for Duke Energy Florida

Beth Keating
Gunster, Yoakley & Stewart, P.A.
215 South Monroe Street, Suite 601
Tallahassee, Florida 32301-1804
bkeating@gunster.com
**Attorneys for Florida Public Utilities
Company**

Michelle D. Napier
Director, Regulatory Affairs
Florida Public Utilities Company
1635 Meathe Drive
West Palm Beach, Florida 33411
mnapier@fpuc.com

Robert Scheffel Wright
John Thomas LaVia, III
Gardner, Bist, Bowden, Dee, LaVia,
Wright, Perry & Harper, P.A.
1300 Thomaswood Drive
Tallahassee, Florida 32308
schef@gbwlegal.com
jlavia@gbwlegal.com
**Attorneys for the Florida Retail
Federation**

Jon C. Moyle, Jr.
Moyle Law Firm, P.A.
118 North Gadsden Street
Tallahassee, Florida 32301
jmoyle@moylelaw.com
mqualls@moylelaw.com
**Attorneys for Florida Industrial Power
Users Group**

James W. Brew
Laura Wynn Baker
Sarah B. Newman
Stone Mattheis Xenopoulos & Brew, P.C.
1025 Thomas Jefferson Street, NW
Eighth Floor, West Tower
Washington, DC 20007
jbrew@smxblaw.com
lwb@smxblaw.com
sbn@smxblaw.com
**Attorneys for White Springs
Agricultural Chemicals, Inc. d/b/a PCS
Phosphate -White Springs**

Peter J. Mattheis
Michael K. Lavanga
Joseph R. Briscar
Stone Mattheis Xenopoulos & Brew, PC
1025 Thomas Jefferson Street, NW
Eighth Floor, West Tower
Washington, DC 20007
pjm@smxblaw.com
mkl@smxblaw.com
jrb@smxblaw.com
Attorneys for Nucor Steel Florida, Inc.

By: s/ Maria Jose Moncada
Maria Jose Moncada
Florida Bar No. 0773301

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2024 TO: Dec-2024

		PLANT/UNIT: Cape Canaveral - PCC						PCC-03						
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	92.9	97.8	95.5	23.3	51.2	0	0	0	0	0	0	0	72.1
2	PH	744	696	743	720	744	0	0	0	0	0	0	0	3647
3	SH	744	696	743	121.3	398.92	0	0	0	0	0	0	0	2703.22
4	RSH	0	0	0	46.7	0	0	0	0	0	0	0	0	46.7
5	UH	0	0	0	552	345.08	0	0	0	0	0	0	0	897.08
6	POH	0	0	0	552	345.08	0	0	0	0	0	0	0	897.08
7	FOH	0	0	0	0	0	0	0	0	0	0	0	0	0
8	MOH	0	0	0	0	0	0	0	0	0	0	0	0	0
9	PPOH	0	0	0	0	11.4	0	0	0	0	0	0	0	11.4
10	LRPP (MW)	0	0	0	0	731.04	0	0	0	0	0	0	0	731.04
11	PFOH	5.7	0.47	3.95	0	7.73	0	0	0	0	0	0	0	17.85
12	LRPF (MW)	341	426	426	0	423.25	0	0	0	0	0	0	0	397.66
13	PMOH	155.73	45.8	96.42	0	25.95	0	0	0	0	0	0	0	323.9
14	LRPM (MW)	416.06	426	424.76	0	426	0	0	0	0	0	0	0	420.85
15	NSC	1260	1260	1260	1260	1260	0	0	0	0	0	0	0	1260
16	OPER BTU (MBTU)	3,917,684	3,311,532	3,973,781	614,295	2,242,384	0	0	0	0	0	0	0	14,059,676
17	OPER NET GEN (MWH)	589,378	489,081	586,071	90,681	336,168	0	0	0	0	0	0	0	2,091,379
18	ANOHR (BTU/KWH)	6,647	6,771	6,780	6,774	6,670	0	0	0	0	0	0	0	6,723
19	NOF (%)	62.9	55.8	62.6	59.3	66.9	0	0	0	0	0	0	0	61.4
20	NPC (MW)	1260	1260	1260	1260	1260	0	0	0	0	0	0	0	1260

21	ANOHR EQUATION	ANOHR = A+B(N.O.F) A=0 B=0
----	----------------	-------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2024 TO: Dec-2024

		PLANT/UNIT: Fort Myers - PFM						PFM-02						
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	99.3	98.3	60.6	27.1	83.5	0	0	0	0	0	0	0	73.8
2	PH	744	696	743	720	744	0	0	0	0	0	0	0	3647
3	SH	744	696	592.18	506.22	744	0	0	0	0	0	0	0	3282.4
4	RSH	0	0	0	0	0	0	0	0	0	0	0	0	0
5	UH	0	0	150.82	213.78	0	0	0	0	0	0	0	0	364.6
6	POH	0	0	150.82	213.78	0	0	0	0	0	0	0	0	364.6
7	FOH	0	0	0	0	0	0	0	0	0	0	0	0	0
8	MOH	0	0	0	0	0	0	0	0	0	0	0	0	0
9	PPOH	0	0	218.2	506.22	226.42	0	0	0	0	0	0	0	950.83
10	LRPP (MW)	0	0	1090.4	999.1	813.17	0	0	0	0	0	0	0	975.78
11	PFOH	1.85	16.85	5.35	93.92	56.6	0	0	0	0	0	0	0	174.57
12	LRPF (MW)	281.8	150.46	278.08	188	395.24	0	0	0	0	0	0	0	255.33
13	PMOH	27.33	60.18	0	0	0	0	0	0	0	0	0	0	87.52
14	LRPM (MW)	284.8	281.5	0	0	0	0	0	0	0	0	0	0	282.53
15	NSC	1683	1683	1683	1682	1681	0	0	0	0	0	0	0	1682
16	OPER BTU (MBTU)	5,953,407	5,613,259	4,023,993	2,051,456	5,465,079	0	0	0	0	0	0	0	23,107,194
17	OPER NET GEN (MWH)	812,042	773,113	523,262	175,919	771,161	0	0	0	0	0	0	0	3,055,497
18	ANOHR (BTU/KWH)	7,331	7,261	7,690	11,661	7,087	0	0	0	0	0	0	0	7,563
19	NOF (%)	64.9	66.0	52.5	20.7	61.7	0	0	0	0	0	0	0	55.3
20	NPC (MW)	1683	1683	1683	1682	1681	0	0	0	0	0	0	0	1682

21	ANOHR EQUATION	ANOHR = A+B(N.O.F) A=0 B=0
----	----------------	-------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2024 TO: Dec-2024

		PLANT/UNIT: Manatee - PM3						PM3-03						
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	92.8	84	99.1	99.6	99.8	0	0	0	0	0	0	0	95.2
2	PH	744	696	743	720	744	0	0	0	0	0	0	0	3647
3	SH	692.73	622.68	743	720	744	0	0	0	0	0	0	0	3522.42
4	RSH	40.62	0	0	0	0	0	0	0	0	0	0	0	40.62
5	UH	10.65	73.32	0	0	0	0	0	0	0	0	0	0	83.96
6	POH	0	0	0	0	0	0	0	0	0	0	0	0	0
7	FOH	10.65	0	0	0	0	0	0	0	0	0	0	0	10.65
8	MOH	0	73.32	0	0	0	0	0	0	0	0	0	0	73.32
9	PPOH	46.35	0	0	0	0	0	0	0	0	0	0	0	46.35
10	LRPP (MW)	778.4	0	0	0	0	0	0	0	0	0	0	0	778.4
11	PFOH	40.87	0.82	4.52	11.23	7	0	0	0	0	0	0	0	64.43
12	LRPF (MW)	315.88	296.55	309.7	306.5	298.67	0	0	0	0	0	0	0	311.7
13	PMOH	12.68	141.92	21.97	0	0	0	0	0	0	0	0	0	176.57
14	LRPM (MW)	308	326.81	311	0	0	0	0	0	0	0	0	0	323.5
15	NSC	1229	1229	1229	1229	1229	0	0	0	0	0	0	0	1229
16	OPER BTU (MBTU)	3,972,335	3,340,392	5,410,544	5,078,251	5,416,597	0	0	0	0	0	0	0	23,218,119
17	OPER NET GEN (MWH)	576,836	494,601	800,514	751,131	799,468	0	0	0	0	0	0	0	3,422,550
18	ANOHR (BTU/KWH)	6,886	6,754	6,759	6,761	6,775	0	0	0	0	0	0	0	6,784
19	NOF (%)	67.8	64.6	87.7	84.9	87.4	0	0	0	0	0	0	0	79.1
20	NPC (MW)	1229	1229	1229	1229	1229	0	0	0	0	0	0	0	1229

21	ANOHR EQUATION	ANOHR = A+B(N.O.F) A=0 B=0
----	----------------	-------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2024 TO: Dec-2024

		PLANT/UNIT: Martin - PM8					PM8-08							
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	96.7	61.2	32.3	98.6	70.5	0	0	0	0	0	0	0	71.8
2	PH	744	696	743	720	744	0	0	0	0	0	0	0	3647
3	SH	117.22	172.78	282.97	653.75	610.52	0	0	0	0	0	0	0	1837.23
4	RSH	626.78	283.22	0	66.25	0	0	0	0	0	0	0	0	976.25
5	UH	0	240	460.03	0	133.48	0	0	0	0	0	0	0	833.52
6	POH	0	0	20.08	0	0	0	0	0	0	0	0	0	20.08
7	FOH	0	0	0	0	133.48	0	0	0	0	0	0	0	133.48
8	MOH	0	240	439.95	0	0	0	0	0	0	0	0	0	679.95
9	PPOH	0	96	128.23	0	0	0	0	0	0	0	0	0	224.23
10	LRPP (MW)	0	376.5	345.24	0	0	0	0	0	0	0	0	0	358.62
11	PFOH	11.92	1.42	22.28	17.58	244.72	0	0	0	0	0	0	0	297.92
12	LRPF (MW)	331.58	464	227.87	303.11	344.83	0	0	0	0	0	0	0	333.66
13	PMOH	92.6	0	13.45	24	72	0	0	0	0	0	0	0	202.05
14	LRPM (MW)	283.65	0	238.26	305	285	0	0	0	0	0	0	0	283.64
15	NSC	1216	1216	1216	1216	1216	0	0	0	0	0	0	0	1216
16	OPER BTU (MBTU)	313,539	511,922	1,179,893	3,000,437	3,133,811	0	0	0	0	0	0	0	8,139,602
17	OPER NET GEN (MWH)	41,496	60,876	169,052	421,809	465,816	0	0	0	0	0	0	0	1,159,049
18	ANOHR (BTU/KWH)	7,556	8,409	6,979	7,113	6,728	0	0	0	0	0	0	0	7,023
19	NOF (%)	29.1	29.0	49.1	53.1	62.7	0	0	0	0	0	0	0	51.9
20	NPC (MW)	1216	1216	1216	1216	1216	0	0	0	0	0	0	0	1216

21	ANOHR EQUATION	ANOHR = A+B(N.O.F) A=0 B=0
----	----------------	-------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
COMPANY: FLORIDA POWER AND LIGHT
FROM: Jan-2024 TO: Dec-2024

PLANT/UNIT: Okeechobee Energy Center - POK														POK-01
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd	
1	EAF (%)	100	86.3	57.6	87.6	77.6	0	0	0	0	0	0	81.8	
2	PH	744	696	743	720	744	0	0	0	0	0	0	3647	
3	SH	744	621.17	435.82	673.93	744	0	0	0	0	0	0	3218.92	
4	RSH	0	0	0	0	0	0	0	0	0	0	0	0	
5	UH	0	74.83	307.18	46.07	0	0	0	0	0	0	0	428.08	
6	POH	0	0	307.18	36	0	0	0	0	0	0	0	343.18	
7	FOH	0	0	0	0	0	0	0	0	0	0	0	0	
8	MOH	0	74.83	0	10.07	0	0	0	0	0	0	0	84.9	
9	PPOH	0	0	6.52	5.88	0	0	0	0	0	0	0	12.4	
10	LRPP (MW)	0	0	652.87	645.76	0	0	0	0	0	0	0	649.5	
11	PFOH	0	15.3	15.88	0	78.37	0	0	0	0	0	0	109.55	
12	LRPF (MW)	0	481.13	488.24	0	513	0	0	0	0	0	0	504.96	
13	PMOH	0	35.45	0	180.57	428.78	0	0	0	0	0	0	644.8	
14	LRPM (MW)	0	671.57	0	347.44	504	0	0	0	0	0	0	469.37	
15	NSC	1540	1540	1540	1540	1540	0	0	0	0	0	0	1540	
16	OPER BTU (MBTU)	7,018,139	5,449,566	3,641,804	5,909,788	5,619,499	0	0	0	0	0	0	27,638,796	
17	OPER NET GEN (MWH)	1,113,748	858,566	573,311	934,931	889,779	0	0	0	0	0	0	4,370,335	
18	ANOHR (BTU/KWH)	6,301	6,347	6,352	6,321	6,316	0	0	0	0	0	0	6,324	
19	NOF (%)	97.2	89.8	85.4	90.1	77.7	0	0	0	0	0	0	88.2	
20	NPC (MW)	1540	1540	1540	1540	1540	0	0	0	0	0	0	1540	

21	ANOHR EQUATION	ANOHR = A+B(N.O.F) A=0 B=0
----	----------------	-------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
COMPANY: FLORIDA POWER AND LIGHT
FROM: Jan-2024 TO: Dec-2024

		PLANT/UNIT: Port Everglades - PPE						PPE-05						
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	76.7	99.3	77	92.1	99.9	0	0	0	0	0	0	0	88.9
2	PH	744	696	743	720	744	0	0	0	0	0	0	0	3647
3	SH	228.65	696	578.37	720	744	0	0	0	0	0	0	0	2967.02
4	RSH	515.35	0	0	0	0	0	0	0	0	0	0	0	515.35
5	UH	0	0	164.63	0	0	0	0	0	0	0	0	0	164.63
6	POH	0	0	0	0	0	0	0	0	0	0	0	0	0
7	FOH	0	0	0	0	0	0	0	0	0	0	0	0	0
8	MOH	0	0	164.63	0	0	0	0	0	0	0	0	0	164.63
9	PPOH	0	0	0	0	0	0	0	0	0	0	0	0	0
10	LRPP (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0
11	PFOH	535.37	13.75	4.37	0.42	3.5	0	0	0	0	0	0	0	557.4
12	LRPF (MW)	360.39	395.49	356.68	338	151.29	0	0	0	0	0	0	0	359.9
13	PMOH	0	0	9.33	182.9	0	0	0	0	0	0	0	0	192.23
14	LRPM (MW)	0	0	545.24	347.06	0	0	0	0	0	0	0	0	356.68
15	NSC	1112	1112	1112	1112	1112	0	0	0	0	0	0	0	1112
16	OPER BTU (MBTU)	935,863	3,072,773	2,399,123	3,230,915	4,372,156	0	0	0	0	0	0	0	14,010,831
17	OPER NET GEN (MWH)	130,660	434,803	339,252	459,421	636,184	0	0	0	0	0	0	0	2,000,320
18	ANOHR (BTU/KWH)	7,163	7,067	7,072	7,033	6,872	0	0	0	0	0	0	0	7,004
19	NOF (%)	51.4	56.2	52.7	57.4	76.9	0	0	0	0	0	0	0	60.6
20	NPC (MW)	1112	1112	1112	1112	1112	0	0	0	0	0	0	0	1112

21	ANOHR EQUATION	ANOHR = A+B(N.O.F) A=0 B=0
----	----------------	-------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2024 TO: Dec-2024

		PLANT/UNIT: Riviera - PRV					PRV-05							
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	93	87.3	91	98.8	91.6	0	0	0	0	0	0	0	92.4
2	PH	744	696	743	720	744	0	0	0	0	0	0	0	3647
3	SH	744	696	743	720	690.53	0	0	0	0	0	0	0	3593.53
4	RSH	0	0	0	0	0	0	0	0	0	0	0	0	0
5	UH	0	0	0	0	53.47	0	0	0	0	0	0	0	53.47
6	POH	0	0	0	0	0	0	0	0	0	0	0	0	0
7	FOH	0	0	0	0	0	0	0	0	0	0	0	0	0
8	MOH	0	0	0	0	53.47	0	0	0	0	0	0	0	53.47
9	PPOH	0	0	0	0	0	0	0	0	0	0	0	0	0
10	LRPP (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0
11	PFOH	7.93	1.72	4.1	0	8.58	0	0	0	0	0	0	0	22.33
12	LRPF (MW)	431	378.23	412.36	0	421.56	0	0	0	0	0	0	0	419.89
13	PMOH	146.55	240.88	195.9	26.03	10.38	0	0	0	0	0	0	0	619.75
14	LRPM (MW)	431	466.72	426.12	431	723.03	0	0	0	0	0	0	0	448.23
15	NSC	1275	1275	1275	1275	1275	0	0	0	0	0	0	0	1275
16	OPER BTU (MBTU)	3,515,920	3,095,082	3,487,426	3,982,866	4,662,351	0	0	0	0	0	0	0	18,743,644
17	OPER NET GEN (MWH)	525,987	467,558	523,658	602,662	710,490	0	0	0	0	0	0	0	2,830,355
18	ANOHR (BTU/KWH)	6,684	6,620	6,660	6,609	6,562	0	0	0	0	0	0	0	6,622
19	NOF (%)	55.4	52.7	55.3	65.6	80.7	0	0	0	0	0	0	0	61.8
20	NPC (MW)	1275	1275	1275	1275	1275	0	0	0	0	0	0	0	1275

21	ANOHR EQUATION	ANOHR = A+B(N.O.F) A=0 B=0
----	----------------	-------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2024 TO: Dec-2024

PLANT/UNIT: St. Lucie Nuclear - PSL		PSL-01											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	100	100	24.9	54.3	100	0	0	0	0	0	0	75.7
2	PH	744	696	743	720	744	0	0	0	0	0	0	3647
3	SH	744	696	192.02	430.27	744	0	0	0	0	0	0	2806.28
4	RSH	0	0	0	0	0	0	0	0	0	0	0	0
5	UH	0	0	550.98	289.73	0	0	0	0	0	0	0	840.72
6	POH	0	0	550.98	289.73	0	0	0	0	0	0	0	840.72
7	FOH	0	0	0	0	0	0	0	0	0	0	0	0
8	MOH	0	0	0	0	0	0	0	0	0	0	0	0
9	PPOH	0	0	25.78	87.43	0	0	0	0	0	0	0	113.22
10	LRPP (MW)	0	0	258.25	420.16	0	0	0	0	0	0	0	383.29
11	PFOH	0	0	0	45.58	0	0	0	0	0	0	0	45.58
12	LRPF (MW)	0	0	0	38.96	0	0	0	0	0	0	0	38.96
13	PMOH	0	0	0	0	0	0	0	0	0	0	0	0
14	LRPM (MW)	0	0	0	0	0	0	0	0	0	0	0	0
15	NSC	981	981	981	981	981	0	0	0	0	0	0	981
16	OPER BTU (MBTU)	7,614,550	7,120,766	1,830,644	4,027,995	7,660,314	0	0	0	0	0	0	28,254,269
17	OPER NET GEN (MWH)	744,410	697,835	175,705	384,763	743,376	0	0	0	0	0	0	2,746,089
18	ANOHR (BTU/KWH)	10,229	10,204	10,419	10,469	10,305	0	0	0	0	0	0	10,289
19	NOF (%)	102.0	102.2	93.3	91.2	101.9	0	0	0	0	0	0	99.8
20	NPC (MW)	981	981	981	981	981	0	0	0	0	0	0	981

21	ANOHR EQUATION	ANOHR = A+B(N.O.F) A=0 B=0
----	----------------	-------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2024 TO: Dec-2024

		PLANT/UNIT: St. Lucie Nuclear - PSL					PSL-02							
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	73.5	100	100	100	98.3	0	0	0	0	0	0	0	94.2
2	PH	744	696	743	720	744	0	0	0	0	0	0	0	3647
3	SH	553.47	696	743	720	744	0	0	0	0	0	0	0	3456.47
4	RSH	0	0	0	0	0	0	0	0	0	0	0	0	0
5	UH	190.53	0	0	0	0	0	0	0	0	0	0	0	190.53
6	POH	190.53	0	0	0	0	0	0	0	0	0	0	0	190.53
7	FOH	0	0	0	0	0	0	0	0	0	0	0	0	0
8	MOH	0	0	0	0	0	0	0	0	0	0	0	0	0
9	PPOH	17.3	0	0	0	0	0	0	0	0	0	0	0	17.3
10	LRPP (MW)	373.84	0	0	0	0	0	0	0	0	0	0	0	373.84
11	PFOH	0	0	0	0	191.47	0	0	0	0	0	0	0	191.47
12	LRPF (MW)	0	0	0	0	66.43	0	0	0	0	0	0	0	66.43
13	PMOH	0	0	0	0	0	0	0	0	0	0	0	0	0
14	LRPM (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0
15	NSC	986	986	986	986	986	0	0	0	0	0	0	0	986
16	OPER BTU (MBTU)	5,634,913	7,166,308	7,650,018	7,413,064	7,525,396	0	0	0	0	0	0	0	35,389,700
17	OPER NET GEN (MWH)	554,915	709,302	755,401	730,499	727,570	0	0	0	0	0	0	0	3,477,687
18	ANOHR (BTU/KWH)	10,155	10,103	10,127	10,148	10,343	0	0	0	0	0	0	0	10,176
19	NOF (%)	101.7	103.4	103.1	102.9	99.2	0	0	0	0	0	0	0	102.0
20	NPC (MW)	986	986	986	986	986	0	0	0	0	0	0	0	986

21	ANOHR EQUATION	ANOHR = A+B(N.O.F) A=0 B=0
----	----------------	-------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2024 TO: Dec-2024

		PLANT/UNIT: Sanford - PSR						PSR-05						
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	92	87.6	82.4	82.5	99.6	0	0	0	0	0	0	0	88.9
2	PH	744	696	743	720	744	0	0	0	0	0	0	0	3647
3	SH	316.33	219.17	576.78	521.83	732.02	0	0	0	0	0	0	0	2366.13
4	RSH	427.67	476.83	114.42	81.75	11.98	0	0	0	0	0	0	0	1112.65
5	UH	0	0	51.8	116.42	0	0	0	0	0	0	0	0	168.22
6	POH	0	0	0	0	0	0	0	0	0	0	0	0	0
7	FOH	0	0	0	0	0	0	0	0	0	0	0	0	0
8	MOH	0	0	51.8	116.42	0	0	0	0	0	0	0	0	168.22
9	PPOH	0	288	146.8	0	0	0	0	0	0	0	0	0	434.8
10	LRPP (MW)	0	281	565.83	0	0	0	0	0	0	0	0	0	377.17
11	PFOH	9.83	5.82	0	0.45	2.77	0	0	0	0	0	0	0	18.87
12	LRPF (MW)	284	202.83	0	280	61.98	0	0	0	0	0	0	0	226.32
13	PMOH	133.73	79	20.67	37.8	13.75	0	0	0	0	0	0	0	284.95
14	LRPM (MW)	479.9	187	297.35	281.22	256	0	0	0	0	0	0	0	348.3
15	NSC	1126	1126	1127	1127	1127	0	0	0	0	0	0	0	1127
16	OPER BTU (MBTU)	1,108,863	774,024	2,422,169	2,381,142	3,886,103	0	0	0	0	0	0	0	10,572,301
17	OPER NET GEN (MWH)	150,613	103,237	334,345	318,753	541,908	0	0	0	0	0	0	0	1,448,856
18	ANOHR (BTU/KWH)	7,362	7,498	7,245	7,470	7,171	0	0	0	0	0	0	0	7,297
19	NOF (%)	42.3	41.8	51.5	54.2	65.7	0	0	0	0	0	0	0	54.3
20	NPC (MW)	1126	1126	1127	1127	1127	0	0	0	0	0	0	0	1127

21	ANOHR EQUATION	ANOHR = A+B(N.O.F) A=0 B=0
----	----------------	-------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2024 TO: Dec-2024

		PLANT/UNIT: Turkey Point Nuclear - PTN					PTN-03							
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	100	100	100	100	100	0	0	0	0	0	0	0	100
2	PH	744	696	743	720	744	0	0	0	0	0	0	0	3647
3	SH	744	696	743	720	744	0	0	0	0	0	0	0	3647
4	RSH	0	0	0	0	0	0	0	0	0	0	0	0	0
5	UH	0	0	0	0	0	0	0	0	0	0	0	0	0
6	POH	0	0	0	0	0	0	0	0	0	0	0	0	0
7	FOH	0	0	0	0	0	0	0	0	0	0	0	0	0
8	MOH	0	0	0	0	0	0	0	0	0	0	0	0	0
9	PPOH	0	0	0	0	0	0	0	0	0	0	0	0	0
10	LRPP (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0
11	PFOH	0	0	0	0	0	0	0	0	0	0	0	0	0
12	LRPF (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0
13	PMOH	0	0	0	0	0	0	0	0	0	0	0	0	0
14	LRPM (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0
15	NSC	837	837	837	837	837	0	0	0	0	0	0	0	837
16	OPER BTU (MBTU)	6,707,251	6,271,502	6,697,153	6,490,329	6,707,490	0	0	0	0	0	0	0	32,873,724
17	OPER NET GEN (MWH)	652,867	610,834	646,073	626,440	639,013	0	0	0	0	0	0	0	3,175,227
18	ANOHR (BTU/KWH)	10,274	10,267	10,366	10,361	10,497	0	0	0	0	0	0	0	10,353
19	NOF (%)	104.8	104.9	103.9	103.9	102.6	0	0	0	0	0	0	0	104.0
20	NPC (MW)	837	837	837	837	837	0	0	0	0	0	0	0	837

21	ANOHR EQUATION	ANOHR = A+B(N.O.F) A=0 B=0												
----	----------------	-------------------------------	--	--	--	--	--	--	--	--	--	--	--	--

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2024 TO: Dec-2024

		PLANT/UNIT: Turkey Point Nuclear - PTN										PTN-04		
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	100	100	100	100	100	0	0	0	0	0	0	0	100
2	PH	744	696	743	720	744	0	0	0	0	0	0	0	3647
3	SH	744	696	743	720	744	0	0	0	0	0	0	0	3647
4	RSH	0	0	0	0	0	0	0	0	0	0	0	0	0
5	UH	0	0	0	0	0	0	0	0	0	0	0	0	0
6	POH	0	0	0	0	0	0	0	0	0	0	0	0	0
7	FOH	0	0	0	0	0	0	0	0	0	0	0	0	0
8	MOH	0	0	0	0	0	0	0	0	0	0	0	0	0
9	PPOH	0	0	0	0	0	0	0	0	0	0	0	0	0
10	LRPP (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0
11	PFOH	0	0	0	0	0	0	0	0	0	0	0	0	0
12	LRPF (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0
13	PMOH	0	0	0	0	0	0	0	0	0	0	0	0	0
14	LRPM (MW)	0	0	0	0	0	0	0	0	0	0	0	0	0
15	NSC	844	844	844	844	844	0	0	0	0	0	0	0	844
16	OPER BTU (MBTU)	6,706,602	6,273,819	6,697,996	6,492,062	6,707,728	0	0	0	0	0	0	0	32,878,207
17	OPER NET GEN (MWH)	654,315	613,809	650,810	631,662	645,845	0	0	0	0	0	0	0	3,196,441
18	ANOHR (BTU/KWH)	10,250	10,221	10,292	10,278	10,386	0	0	0	0	0	0	0	10,286
19	NOF (%)	104.2	104.5	103.8	103.9	102.9	0	0	0	0	0	0	0	103.8
20	NPC (MW)	844	844	844	844	844	0	0	0	0	0	0	0	844

21	ANOHR EQUATION	ANOHR = A+B(N.O.F) A=0 B=0											
----	----------------	-------------------------------	--	--	--	--	--	--	--	--	--	--	--

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2024 TO: Dec-2024

PLANT/UNIT: West County Energy Center - PWC														PWC-01
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd	
1	EAF (%)	95.3	64.3	93.8	90.2	94	0	0	0	0	0	0	87.8	
2	PH	744	696	743	720	744	0	0	0	0	0	0	3647	
3	SH	665.25	174.83	743	720	744	0	0	0	0	0	0	3047.08	
4	RSH	78.75	374.83	0	0	0	0	0	0	0	0	0	453.58	
5	UH	0	146.34	0	0	0	0	0	0	0	0	0	146.34	
6	POH	0	0	0	0	0	0	0	0	0	0	0	0	
7	FOH	0	0	0	0	0	0	0	0	0	0	0	0	
8	MOH	0	146.33	0	0	0	0	0	0	0	0	0	146.33	
9	PPOH	0	0	0	0	0	0	0	0	0	0	0	0	
10	LRPP (MW)	0	0	0	0	0	0	0	0	0	0	0	0	
11	PFOH	1.12	55.62	3.62	11.17	3.05	0	0	0	0	0	0	74.57	
12	LRPF (MW)	402	567.67	404	404.32	404	0	0	0	0	0	0	526.09	
13	PMOH	96.92	188.72	135.52	200.85	131.35	0	0	0	0	0	0	753.35	
14	LRPM (MW)	435.31	486.28	402.4	404	404	0	0	0	0	0	0	428.35	
15	NSC	1211	1211	1211	1211	1211	0	0	0	0	0	0	1211	
16	OPER BTU (MBTU)	3,231,330	722,842	4,046,948	3,499,494	4,428,930	0	0	0	0	0	0	15,929,544	
17	OPER NET GEN (MWH)	452,711	91,105	571,403	485,444	616,297	0	0	0	0	0	0	2,216,960	
18	ANOHR (BTU/KWH)	7,138	7,934	7,082	7,209	7,186	0	0	0	0	0	0	7,185	
19	NOF (%)	56.2	43.0	63.5	55.7	68.4	0	0	0	0	0	0	60.1	
20	NPC (MW)	1211	1211	1211	1211	1211	0	0	0	0	0	0	1211	

21	ANOHR EQUATION	ANOHR = A+B(N.O.F) A=0 B=0
----	----------------	-------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2024 TO: Dec-2024

PLANT/UNIT: West County Energy Center - PWC													
PWC-02													
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	83.8	96.9	96.2	92	93	0	0	0	0	0	0	92.3
2	PH	744	696	743	720	744	0	0	0	0	0	0	3647
3	SH	662.43	458.27	722.32	687.32	666.95	0	0	0	0	0	0	3197.28
4	RSH	23.32	237.73	9.23	32.68	48	0	0	0	0	0	0	350.97
5	UH	58.25	0	11.45	0	29.05	0	0	0	0	0	0	98.75
6	POH	0	0	0	0	0	0	0	0	0	0	0	0
7	FOH	0	0	11.45	0	0	0	0	0	0	0	0	11.45
8	MOH	58.25	0	0	0	29.05	0	0	0	0	0	0	87.3
9	PPOH	0	0	0	0	0	0	0	0	0	0	0	0
10	LRPP (MW)	0	0	0	0	0	0	0	0	0	0	0	0
11	PFOH	0	2.7	0.47	13.88	20.12	0	0	0	0	0	0	37.17
12	LRPF (MW)	0	404	519.04	48.74	404	0	0	0	0	0	0	272.74
13	PMOH	181.15	63.42	49.35	170.7	59.42	0	0	0	0	0	0	524.03
14	LRPM (MW)	417.78	402	404	406.45	339.12	0	0	0	0	0	0	401.96
15	NSC	1211	1211	1211	1211	1211	0	0	0	0	0	0	1211
16	OPER BTU (MBTU)	3,289,289	2,358,273	4,045,368	3,264,902	4,225,020	0	0	0	0	0	0	17,182,852
17	OPER NET GEN (MWH)	463,854	336,952	581,527	459,469	604,235	0	0	0	0	0	0	2,446,037
18	ANOHR (BTU/KWH)	7,091	6,999	6,956	7,106	6,992	0	0	0	0	0	0	7,025
19	NOF (%)	57.8	60.7	66.5	55.2	74.8	0	0	0	0	0	0	63.2
20	NPC (MW)	1211	1211	1211	1211	1211	0	0	0	0	0	0	1211

21	ANOHR EQUATION	ANOHR = A+B(N.O.F) A=0 B=0
----	----------------	-------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2024 TO: Dec-2024

PLANT/UNIT: West County Energy Center - PWC														PWC-03
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd	
1	EAF (%)	98.4	76.6	94.9	97	99.9	0	0	0	0	0	0	93.5	
2	PH	744	696	743	720	744	0	0	0	0	0	0	3647	
3	SH	744	640.12	743	720	744	0	0	0	0	0	0	3591.12	
4	RSH	0	9.6	0	0	0	0	0	0	0	0	0	9.6	
5	UH	0	46.28	0	0	0	0	0	0	0	0	0	46.28	
6	POH	0	0	0	0	0	0	0	0	0	0	0	0	
7	FOH	0	0	0	0	0	0	0	0	0	0	0	0	
8	MOH	0	46.28	0	0	0	0	0	0	0	0	0	46.28	
9	PPOH	0	0	0	0	0	0	0	0	0	0	0	0	
10	LRPP (MW)	0	0	0	0	0	0	0	0	0	0	0	0	
11	PFOH	0	120.37	6.9	2.27	1.88	0	0	0	0	0	0	131.42	
12	LRPF (MW)	0	240.98	305.03	404	404	0	0	0	0	0	0	249.49	
13	PMOH	34.65	197.23	109.93	63.4	0	0	0	0	0	0	0	405.22	
14	LRPM (MW)	405	570.52	402.05	404	0	0	0	0	0	0	0	484.61	
15	NSC	1211	1211	1211	1211	1211	0	0	0	0	0	0	1211	
16	OPER BTU (MBTU)	3,641,994	2,953,769	3,932,026	3,595,407	4,475,426	0	0	0	0	0	0	18,598,622	
17	OPER NET GEN (MWH)	505,855	412,222	556,575	507,286	642,044	0	0	0	0	0	0	2,623,982	
18	ANOHR (BTU/KWH)	7,200	7,165	7,065	7,088	6,971	0	0	0	0	0	0	7,088	
19	NOF (%)	56.1	53.2	61.9	58.2	71.3	0	0	0	0	0	0	60.3	
20	NPC (MW)	1211	1211	1211	1211	1211	0	0	0	0	0	0	1211	

21	ANOHR EQUATION	ANOHR = A+B(N.O.F) A=0 B=0
----	----------------	-------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2024 TO: Dec-2024

		PLANT/UNIT: Turkey Point - TP5					TP5-05							
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	95.6	66.5	88.1	85.6	99.7	0	0	0	0	0	0	0	87.4
2	PH	744	696	743	720	744	0	0	0	0	0	0	0	3647
3	SH	726.25	361.47	661.1	631.05	744	0	0	0	0	0	0	0	3123.87
4	RSH	17.75	190.52	81.88	3.4	0	0	0	0	0	0	0	0	293.55
5	UH	0	144.01	0.02	85.55	0	0	0	0	0	0	0	0	229.58
6	POH	0	144.02	0.02	0	0	0	0	0	0	0	0	0	144.03
7	FOH	0	0	0	0	0	0	0	0	0	0	0	0	0
8	MOH	0	0	0	85.55	0	0	0	0	0	0	0	0	85.55
9	PPOH	0	190.95	291.87	0	0	0	0	0	0	0	0	0	482.82
10	LRPP (MW)	0	511	363.33	0	0	0	0	0	0	0	0	0	421.73
11	PFOH	2.8	0.12	11.15	21	6.2	0	0	0	0	0	0	0	41.27
12	LRPF (MW)	315	314.05	498.7	345.85	315	0	0	0	0	0	0	0	380.33
13	PMOH	128.85	47.75	0	23.87	2.42	0	0	0	0	0	0	0	202.88
14	LRPM (MW)	315	313	0	669.02	315	0	0	0	0	0	0	0	356.18
15	NSC	1261	1261	1261	1261	1261	0	0	0	0	0	0	0	1261
16	OPER BTU (MBTU)	3,830,031	1,663,394	3,143,285	3,462,055	4,892,276	0	0	0	0	0	0	0	16,991,041
17	OPER NET GEN (MWH)	543,793	228,360	439,358	488,678	706,804	0	0	0	0	0	0	0	2,406,992
18	ANOHR (BTU/KWH)	7,043	7,284	7,154	7,085	6,922	0	0	0	0	0	0	0	7,059
19	NOF (%)	59.4	50.1	52.7	61.4	75.3	0	0	0	0	0	0	0	61.1
20	NPC (MW)	1261	1261	1261	1261	1261	0	0	0	0	0	0	0	1261

21	ANOHR EQUATION	ANOHR = A+B(N.O.F) A=0 B=0
----	----------------	-------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2024 TO: Dec-2024

PLANT/UNIT: Cape Canaveral - PCC		PCC-03		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2024-01-02	PMO	74.1	251.00	PCC32- SNOW- Cond Tube Leak
2024-01-02	PMO	74.1	155.00	PCC32- SNOW- Cond Tube Leak
2024-01-20	PFO	5.7	140.00	PCC30- Derate- 32 HRH Sky vent
2024-01-20	PFO	5.7	78.00	PCC30- Derate- 32 HRH Sky vent
2024-01-20	PFO	5.7	45.00	PCC30- Derate- 32 HRH Sky vent
2024-01-20	PFO	5.7	78.00	PCC30- Derate- 32 HRH Sky vent
2024-01-21	PMO	77.9	269.00	PCC31- SNOW
2024-01-21	PMO	77.9	157.00	PCC31- SNOW
2024-01-25	PMO	3.7	251.00	PCC32- SNOW- Logic Upgrades
2024-01-25	PMO	3.7	157.00	PCC32- SNOW- Logic Upgrades
2024-02-18	PFO	0.4	269.00	PCC33- SU Fail- Gas vent valve
2024-02-18	PFO	0.4	157.00	PCC33- SU Fail- Gas vent valve
2024-02-20	PMO	45.8	269.00	PCC31- SNOW- HRH Sky Vent
2024-02-20	PMO	45.8	157.00	PCC31- SNOW- HRH Sky Vent
2024-03-01	PMO	10.5	269.00	PCC32- SNOW- CT
2024-03-01	PMO	10.5	157.00	PCC32- SNOW- CT
2024-03-05	PFO	3.9	269.00	PCC32-SU Fail- Gas Vent Valve
2024-03-05	PFO	3.9	157.00	PCC32-SU Fail- Gas Vent Valve
2024-03-10	PMO	31.0	269.00	PCC33- SNOW- LF Pump Testing
2024-03-10	PMO	31.0	153.15	PCC33- SNOW- LF Pump Testing
2024-03-14	PMO	47.5	269.00	PCC33- SNOW- FW valve overhaul
2024-03-14	PMO	47.5	157.00	PCC33- SNOW- FW valve overhaul
2024-03-21	PMO	7.2	269.00	PCC33- SNOW- Replace TOT
2024-03-21	PMO	7.2	157.00	PCC33- SNOW- Replace TOT
2024-04-08	PO	552.0	1260.00	PCC33- PO- Spring Outage: April
2024-05-01	PO	240.0	1260.00	PCC33- PO- Spring Outage: May
2024-05-11	PO	58.5	1260.00	PCC33- PE- BOP
2024-05-13	PPO	1.5	471.00	PCC30- PE- BOP
2024-05-13	PPO	1.5	269.00	PCC31- PE- BOP
2024-05-13	PPO	1.5	269.00	PCC33- PE- BOP
2024-05-13	PO	46.5	1260.00	PCC32- PE- BOP
2024-05-15	PPO	6.6	471.00	PCC30- PE- BOP
2024-05-15	PPO	4.3	269.00	PCC31- PE- BOP
2024-05-15	PPO	9.8	251.00	PCC32- PE- BOP
2024-05-22	PFO	1.1	251.00	PCC32- EFOR- HRH Bypass Pos Indicator
2024-05-22	PFO	1.1	157.00	PCC32- EFOR- HRH Bypass Pos Indicator
2024-05-29	PFO	6.5	269.00	PCC31- SU Fail- LP PH Tube Leak
2024-05-29	PFO	6.5	157.00	PCC31- SU Fail- LP PH Tube Leak
2024-05-30	PMO	25.9	269.00	PCC31- SNOW- LP PH Leak
2024-05-30	PMO	25.9	157.00	PCC31- SNOW- LP PH Leak

(1) FFO - FULL FORCED OUTAGE
 PPO - PARTIAL PLANNED OUTAGE
 PMO - PARTIAL MAINTENANCE OUTAGE
 PO - PLANNED OUTAGE
 PFO - PARTIAL FORCED OUTAGE
 FMO - FULL MAINTENANCE OUTAGE

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2024 TO: Dec-2024

PLANT/UNIT: Fort Myers - PFM		PFM-02		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2024-01-12	PFO	1.8	185.00	PFM - 2F SF Due To IGV-VSV
2024-01-12	PFO	1.8	22.79	PFM - 2F SF Due To IGV-VSV
2024-01-12	PFO	1.8	74.00	PFM - 2F SF Due To IGV-VSV
2024-01-27	PMO	27.3	188.00	PFM MO - 2B 1 Lube Oil Pump Has A Short
2024-01-27	PMO	27.3	22.79	PFM MO - 2B 1 Lube Oil Pump Has A Short
2024-01-27	PMO	27.3	74.00	PFM MO - 2B 1 Lube Oil Pump Has A Short
2024-02-01	PMO	60.1	188.00	PFM - 2D MO for IP Tube Leak
2024-02-01	PMO	60.1	21.20	PFM - 2D MO for IP Tube Leak
2024-02-01	PMO	60.1	72.30	PFM - 2D MO for IP Tube Leak
2024-02-19	PFO	1.6	28.00	PFM - 2D Derating
2024-02-19	PFO	1.6	3.15	PFM - 2D Derating
2024-02-19	PFO	1.6	10.76	PFM - 2D Derating
2024-02-19	PFO	8.3	43.00	PFM - 2D Derating
2024-02-19	PFO	8.3	4.87	PFM - 2D Derating
2024-02-19	PFO	8.3	16.62	PFM - 2D Derating
2024-02-23	PFO	6.8	188.00	2A Runback due to Failed Exhaust framer blower
2024-02-23	PFO	6.8	21.17	2A Runback due to Failed Exhaust framer blower
2024-02-23	PFO	6.8	72.32	2A Runback due to Failed Exhaust framer blower
2024-03-04	PFO	4.6	188.00	PFM - FO due to Leak on the HP SH Attemperator
2024-03-04	PFO	4.6	21.17	PFM - FO due to Leak on the HP SH Attemperator
2024-03-04	PFO	4.6	72.32	PFM - FO due to Leak on the HP SH Attemperator
2024-03-06	PFO	0.3	188.00	PFM - 2E tripped due VSV causing Exhaust Spread.
2024-03-06	PFO	0.3	21.17	PFM - 2E tripped due VSV causing Exhaust Spread.
2024-03-06	PFO	0.3	72.32	PFM - 2E tripped due VSV causing Exhaust Spread.
2024-03-07	PFO	0.3	155.00	PFM - 2C CT in runback due to Superheat Spray Regulator
2024-03-07	PFO	0.3	17.87	PFM - 2C CT in runback due to Superheat Spray Regulator
2024-03-07	PFO	0.3	61.12	PFM - 2C CT in runback due to Superheat Spray Regulator
2024-03-12	PFO	0.1	166.00	PFM - 2D Derating due to SH Thermocouple
2024-03-12	PFO	0.1	18.79	PFM - 2D Derating due to SH Thermocouple
2024-03-12	PFO	0.1	64.20	PFM - 2D Derating due to SH Thermocouple
2024-03-16	PPO	62.1	185.00	PFM - 2C Tech 2.0 HGP Upgrade and CT Compartment Upgrade
2024-03-16	PPO	55.7	188.00	PFM - 2E Tech 2.0 HGP Upgrade and CT Compartment Upgrade
2024-03-18	PPO	7.6	188.00	PFM - 2D Blanking Plate Steamer Valve Support Gas Outage Requirements
2024-03-19	PPO	2.2	188.00	PFM - 2A Blanking Plate Steamer Valve Support Gas Outage Requirements
2024-03-19	PPO	0.2	185.00	PFM - 2F Blanking Plate Steamer Valve Support Gas Outage Requirements
2024-03-19	PO	150.8	1683.00	PFM - ST2 steamer Valve Outage
2024-03-25	PPO	156.0	185.00	PFM - 2C Tech 2.0 HGP Upgrade and CT Compartment Upgrade
2024-03-25	PPO	156.0	188.00	PFM - 2E Tech 2.0 HGP Upgrade and CT Compartment Upgrade
2024-03-25	PPO	156.0	188.00	PFM - 2D Blanking Plate Steamer Valve Support Gas Outage Requirements
2024-03-25	PPO	51.3	188.00	PFM - 2A Blanking Plate Steamer Valve Support Gas Outage Requirements
2024-03-25	PPO	156.0	188.00	PFM - 2B Blanking Plate Steamer Valve Support Gas Outage Requirements
2024-03-25	PPO	156.0	127.00	PFM - ST1 Steamer Valve Outage
2024-03-25	PPO	156.0	434.00	PFM - ST2 steamer Valve Outage
2024-04-01	PPO	45.7	185.00	PFM - 2C Tech 2.0 HGP Upgrade and CT Compartment Upgrade
2024-04-01	PPO	45.7	188.00	PFM - 2E Tech 2.0 HGP Upgrade and CT Compartment Upgrade
2024-04-01	PPO	45.7	188.00	PFM - 2D Blanking Plate Steamer Valve Support Gas Outage Requirements

2024-04-01	PPO	45.7	188.00	PFM - 2B Blanking Plate Steamer Valve Support Gas Outage Requirements
2024-04-01	PPO	45.7	127.00	PFM - ST1 Steamer Valve Outage
2024-04-01	PPO	45.7	434.00	PFM - ST2 steamer Valve Outage
2024-04-02	PPO	0.1	185.00	PFM - 2F Blanking Plate Steamer Valve Support Gas Outage Requirements
2024-04-02	PO	213.7	1683.00	PFM - 2A Blanking Plate Steamer Valve Support Gas Outage Requirements
2024-04-11	PPO	76.4	185.00	PFM - 2C Tech 2.0 HGP Upgrade and CT Compartment Upgrade
2024-04-11	PPO	76.4	188.00	PFM - 2E Tech 2.0 HGP Upgrade and CT Compartment Upgrade
2024-04-11	PPO	76.4	188.00	PFM - 2D Blanking Plate Steamer Valve Support Gas Outage Requirements
2024-04-11	PPO	17.3	188.00	PFM - 2B Blanking Plate Steamer Valve Support Gas Outage Requirements
2024-04-11	PPO	76.4	127.00	PFM - ST1 Steamer Valve Outage
2024-04-11	PPO	76.4	434.00	PFM - ST2 steamer Valve Outage
2024-04-11	PPO	0.0	185.00	PFM - 2F Blanking Plate Steamer Valve Support Gas Outage Requirements
2024-04-15	PPO	384.0	188.00	PFM - 2C Tech 2.0 HGP Upgrade and CT Compartment Upgrade
2024-04-15	PPO	384.0	188.00	PFM - 2E Tech 2.0 HGP Upgrade and CT Compartment Upgrade
2024-04-15	PPO	384.0	124.00	PFM - ST1 Steamer Valve Outage
2024-04-15	PPO	384.0	429.00	PFM - ST2 Steamer Valve Outage
2024-04-18	PFO	9.8	188.00	PFM - 2D EFOR due to auxiliary stop and auxiliary vent solenoid failure
2024-04-18	PFO	3.9	188.00	PFM - 2D EFOR due to auxiliary stop and auxiliary vent solenoid failure
2024-04-25	PFO	80.1	188.00	PFM - 2F EFOR due to grounded GSU
2024-05-01	PPO	140.7	124.00	PFM - ST1 Steamer Valve Outage
2024-05-01	PPO	136.5	429.00	PFM - ST2 Steamer Valve Outage
2024-05-01	PPO	130.6	188.00	PFM - 2C Tech 2.0 HGP Upgrade and CT Compartment Upgrade
2024-05-01	PPO	130.9	188.00	PFM - 2E Tech 2.0 HGP Upgrade and CT Compartment Upgrade
2024-05-01	PPO	129.4	188.00	PFM - 2A Blanking Plate Steamer Valve Support Gas Outage Requirements
2024-05-04	PPO	56.2	188.00	PFM - 2F Blanking Plate Steamer Valve Support Gas Outage Requirements
2024-05-06	PPO	0.0	188.00	PFM - 2D Blanking Plate Steamer Valve Support Gas Outage Requirements
2024-05-06	PPO	0.0	20.67	PFM - 2D Blanking Plate Steamer Valve Support Gas Outage Requirements
2024-05-06	PPO	0.0	71.50	PFM - 2D Blanking Plate Steamer Valve Support Gas Outage Requirements
2024-05-06	PPO	57.7	188.00	PFM - 2D Blanking Plate Steamer Valve Support Gas Outage Requirements
2024-05-06	PPO	57.7	20.67	PFM - 2D Blanking Plate Steamer Valve Support Gas Outage Requirements
2024-05-06	PPO	57.7	71.50	PFM - 2D Blanking Plate Steamer Valve Support Gas Outage Requirements
2024-05-12	PFO	8.3	124.00	PFM - ST1 EFOR due to 2F trip
2024-05-12	PFO	6.9	429.00	PFM - ST2 EFOR due to 2F trip
2024-05-12	PFO	22.4	188.00	PFM - 2F EFOR due to Hi Hi Pressure transmitter
2024-05-12	PFO	8.3	20.67	PFM - 2F EFOR due to Hi Hi Pressure transmitter
2024-05-12	PFO	6.9	71.50	PFM - 2F EFOR due to Hi Hi Pressure transmitter
2024-05-12	PFO	3.3	188.00	PFM - 2A EFOR due to runback
2024-05-12	PFO	3.3	20.67	PFM - 2A EFOR due to runback
2024-05-12	PFO	3.3	71.50	PFM - 2A EFOR due to runback
2024-05-12	PFO	15.5	71.50	PFM - 2F EFOR due to Hi Hi Pressure transmitter
2024-05-12	PFO	14.1	20.67	PFM - 2F EFOR due to Hi Hi Pressure transmitter
2024-05-14	PFO	7.5	188.00	PFM - 2B EFOR due to Aux Gas Stop Valve
2024-05-14	PFO	7.5	20.67	PFM - 2B EFOR due to Aux Gas Stop Valve
2024-05-14	PFO	7.5	71.50	PFM - 2B EFOR due to Aux Gas Stop Valve

2024-05-20	PFO	21.6	13.00	PFM - ST2 Condenser Tube Leak
2024-05-20	PFO	21.6	13.00	PFM - ST2 Condenser Tube Leak
2024-05-20	PFO	21.6	13.00	PFM - ST2 Condenser Tube Leak
2024-05-20	PFO	21.6	13.00	PFM - ST2 Condenser Tube Leak
2024-05-20	PFO	21.6	49.00	PFM - ST2 Condenser Tube Leak
2024-05-20	PFO	21.6	204.00	PFM - ST2 Condenser Tube Leak
2024-05-21	PFO	14.2	188.00	PFM - 2D CT has GCV 2 Stuck Open
2024-05-21	PFO	14.2	12.50	PFM - 2D CT has GCV 2 Stuck Open
2024-05-21	PFO	14.2	37.50	PFM - 2D CT has GCV 2 Stuck Open
2024-05-30	PPO	0.0	188.00	PFM - 2B Blanking Plate Steamer Valve Support Gas Outage Requirements
2024-05-30	PPO	0.0	20.67	PFM - 2B Blanking Plate Steamer Valve Support Gas Outage Requirements
2024-05-30	PPO	0.0	71.50	PFM - 2B Blanking Plate Steamer Valve Support Gas Outage Requirements
2024-05-30	PPO	27.8	188.00	PFM - 2B Blanking Plate Steamer Valve Support Gas Outage Requirements
2024-05-30	PPO	27.8	20.67	PFM - 2B Blanking Plate Steamer Valve Support Gas Outage Requirements
2024-05-30	PPO	27.8	71.50	PFM - 2B Blanking Plate Steamer Valve Support Gas Outage Requirements

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2024 TO: Dec-2024

PLANT/UNIT: Manatee - PM3		PM3-03		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2024-01-01	PPO	0.0	190.00	PMT 3C - POE
2024-01-01	PPO	0.0	193.00	PMT 3B - POE
2024-01-01	PPO	0.0	466.00	PMT 3ST - POE
2024-01-01	PPO	30.3	466.00	PMT 3ST - POE
2024-01-01	PPO	3.4	193.00	PMT 3B - POE
2024-01-01	PPO	0.6	190.00	PMT 3C - POE
2024-01-01	PPO	0.0	190.00	PMT 3C - POE
2024-01-01	PPO	38.8	190.00	PMT 3C - POE
2024-01-01	PPO	0.0	193.00	PMT 3B - POE
2024-01-01	PPO	18.0	193.00	PMT 3B - POE
2024-01-02	PPO	0.0	466.00	PMT 3ST - POE
2024-01-02	PPO	0.0	193.00	PMT 3B - POE
2024-01-02	PPO	15.4	466.00	PMT 3ST - POE
2024-01-02	PPO	15.7	193.00	PMT 3B - POE
2024-01-05	PFO	26.0	190.00	3D - MS to CRH Valve Failure
2024-01-05	PFO	26.0	118.00	3D - MS to CRH Valve Failure
2024-01-07	PFO	1.4	190.00	PMT 3C - EFOR due to MS Stop Valve Failure
2024-01-07	PFO	0.5	465.00	PMT 3C - EFOR due to MS Stop Valve Failure
2024-01-07	PFO	1.3	193.00	PMT 3B - EFOR due to MS Stop Valve Failure
2024-01-07	PFO	11.9	465.00	PMT 3B - EFOR due to MS Stop Valve Failure
2024-01-07	PFO	0.8	466.00	PMT ST - EFOR due to MS Stop Valve Failure
2024-01-07	PFO	11.5	192.00	PMT ST - EFOR due to MS Stop Valve Failure
2024-01-07	PFO	11.5	189.00	PMT ST - EFOR due to MS Stop Valve Failure
2024-01-07	PFO	0.8	189.00	PMT ST - EFOR due to MS Stop Valve Failure
2024-01-07	PFO	11.5	465.00	PMT 3C - EFOR due to MS Stop Valve Failure
2024-01-07	PFO	0.2	189.00	PMT ST - EFOR due to MS Stop Valve Failure
2024-01-07	PFO	0.6	190.00	PMT 3A- EFOR due to MS Stop Valve Failure
2024-01-07	PFO	11.3	465.00	PMT 3A- EFOR due to MS Stop Valve Failure
2024-01-07	PFO	11.3	189.00	PMT ST - EFOR due to MS Stop Valve Failure
2024-01-07	FFO	10.6	1229.00	PMT 3D- EFOR due to MS Stop Valve Failure
2024-01-07	PFO	10.6	189.00	PMT ST - EFOR due to MS Stop Valve Failure
2024-01-07	PFO	10.6	465.00	PMT 3D- EFOR due to MS Stop Valve Failure
2024-01-13	PFO	4.0	193.00	PMT 3B- EFOR due to IP Backpressure Valve Positioner
2024-01-13	PFO	4.0	89.27	PMT 3B- EFOR due to IP Backpressure Valve Positioner
2024-01-14	PFO	7.2	190.00	PMT 3C - EFOR Due To IP Backpressure Valve Positioner
2024-01-14	PFO	7.2	47.91	PMT 3C - EFOR Due To IP Backpressure Valve Positioner
2024-01-17	PFO	1.9	193.00	PMT 3B - EFOR due to Trip due to Low LP drum level
2024-01-17	PFO	1.9	47.91	PMT 3B - EFOR due to Trip due to Low LP drum level
2024-01-19	PFO	0.0	177.41	3C - Runback due to IBH Positioner Failure
2024-01-19	PFO	0.0	111.20	3C - Runback due to IBH Positioner Failure
2024-01-27	PFO	0.1	89.31	3A - Runback due to High SH Outlet Temperature
2024-01-27	PFO	0.1	74.00	3A - Runback due to High SH Outlet Temperature
2024-01-31	PMO	12.6	190.00	PMT 3A - MO for Duct burner Pilot valve- HP Superheater Outlet
2024-01-31	PMO	12.6	118.00	PMT 3A - MO for Duct burner Pilot valve- HP Superheater Outlet
2024-02-01	PMO	60.9	190.00	PMT 3A - MOF - Gas Cals. - Duct Burner Pilot Vlv
2024-02-01	PMO	60.9	118.00	PMT 3A - MOF - Gas Cals. - Duct Burner Pilot Vlv
2024-02-04	PFO	0.0	74.00	PMT 3D - Runback due to High SH Temperature
2024-02-04	PFO	0.0	47.02	PMT 3D - Runback due to High SH Temperature
2024-02-06	PFO	0.7	190.00	PMT 3A - Late RFC due to Operator Error
2024-02-06	PFO	0.7	118.00	PMT 3A - Late RFC due to Operator Error
2024-02-07	PMO	62.7	190.00	PMT 3C MOF - MS Stop Check Drain line
2024-02-07	PMO	62.7	118.00	PMT 3C MOF - MS Stop Check Drain line
2024-02-24	PMO	1.7	190.00	PMT 3C - Underground blowdown piping repair
2024-02-24	PMO	1.0	193.00	PMT 3B - Underground Blowdown Piping Repair
2024-02-24	PMO	0.2	466.00	PMT 3ST - Underground blowdown piping repair
2024-02-24	PMO	0.1	190.00	PMT 3D - Underground blowdown piping repair

2024-02-24	FMO	73.3	1229.00	PMT 3A- Underground Blowdown piping repair
2024-02-27	PMO	14.0	193.00	PMT 3B - Underground Blowdown Piping Repair
2024-02-27	PMO	0.4	190.00	PMT 3C - Underground blowdown piping repair
2024-02-27	PMO	16.4	190.00	PMT 3D - Underground blowdown piping repair
2024-02-27	PMO	3.5	466.00	PMT 3ST - Underground blowdown piping repair
2024-03-01	PFO	2.5	193.00	PMT 3B - EFOR due to LP feedwater Valve Positioner Failure
2024-03-01	PFO	2.5	118.00	PMT 3B - EFOR due to LP feedwater Valve Positioner Failure
2024-03-05	PFO	0.6	190.00	PMT 3C - EFOR due to Low HP Drum Level
2024-03-05	PFO	0.6	118.00	PMT 3C - EFOR due to Low HP Drum Level
2024-03-11	PFO	1.2	190.00	PMT 3C - EFOR due to OBB Valve Positioner Failure
2024-03-11	PFO	1.2	118.00	PMT 3C - EFOR due to OBB Valve Positioner Failure
2024-03-14	PMO	21.9	193.00	3B - MO due to BFP Mechanical Seal Failure
2024-03-14	PMO	21.9	118.00	3B - MO due to BFP Mechanical Seal Failure
2024-04-21	PFO	5.8	190.00	PMT 3D - EFOR due to Aux Gas Stop Valve Actuator Failure
2024-04-21	PFO	5.8	116.50	PMT 3D - EFOR due to Aux Gas Stop Valve Actuator Failure
2024-04-24	PFO	5.3	190.00	PMT 3C - Late RFC due to High Haz Gas
2024-04-24	PFO	5.3	116.50	PMT 3C - Late RFC due to High Haz Gas
2024-05-12	PFO	6.4	190.00	PMT 3C - EFOR due to OBB valve Deviation
2024-05-12	PFO	6.4	116.50	PMT 3C - EFOR due to OBB valve Deviation
2024-05-31	PFO	0.5	190.00	PMT 3A - Late RFC due to Haz Gas Sensor
2024-05-31	PFO	0.5	19.75	PMT 3A - Late RFC due to Haz Gas Sensor

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2024 TO: Dec-2024

PLANT/UNIT: Martin - PM8		PM8-08		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2024-01-03	PMO	71.5	189.00	MO: PMR 8C AA heat exchanger
2024-01-03	PMO	5.3	96.00	MO: PMR 8C AA heat exchanger
2024-01-03	PFO	0.8	464.00	EFOR SU Fail: PMR 8ST Hogging ejector isolation valve
2024-01-03	PFO	0.8	162.00	EFOR SU Fail: PMR 8ST Hogging ejector isolation valve
2024-01-03	PFO	0.8	162.00	EFOR SU Fail: PMR 8ST Hogging ejector isolation valve
2024-01-03	PFO	0.8	163.00	EFOR SU Fail: PMR 8ST Hogging ejector isolation valve
2024-01-03	PFO	0.8	163.00	EFOR SU Fail: PMR 8ST Hogging ejector isolation valve
2024-01-03	PMO	0.8	96.00	MO: PMR 8C AA heat exchanger
2024-01-03	PMO	65.3	96.00	MO: PMR 8C AA heat exchanger
2024-01-10	PMO	21.1	187.00	MO: PMR 8A Atomizing Air Expansion Joint
2024-01-10	PMO	21.1	96.00	MO: PMR 8A Atomizing Air Expansion Joint
2024-01-11	PFO	11.0	187.00	EFOR: PMR 8B Suction strainer high dP
2024-01-11	PFO	11.0	96.00	EFOR: PMR 8B Suction strainer high dP
2024-02-09	PFO	0.7	464.00	EFOR SU Failure: PMR 8ST Condenser vacuum
2024-02-14	PFO	0.7	464.00	EFOR: PMR 8ST Trip
2024-02-16	PPO	96.0	187.00	PO: PMR 8A HGP
2024-02-16	PPO	96.0	96.00	PO: PMR 8A HGP
2024-02-18	PPO	48.0	187.00	PO: PMR 8B HGP
2024-02-18	PPO	288.0	96.00	PO: PMR 8B HGP
2024-02-20	FMO	240.0	1216.00	MO: PMR 8D Reliability
2024-02-20	PPO	240.0	96.00	PO: PMR 8A HGP
2024-03-01	FMO	431.0	1216.00	MO: PMR 8D
2024-03-19	FMO	8.9	1216.00	MOE: PMR 8D
2024-03-19	PPO	40.3	96.00	POE: PMR 8A Atomizing Air
2024-03-19	PPO	0.7	464.00	POE: PMR 8ST Temperature matching
2024-03-19	PPO	0.7	187.00	POE: PMR 8A Atomizing Air
2024-03-19	PMO	0.7	189.00	MOE: PMR 8C
2024-03-19	PMO	0.7	189.00	MOE: PMR 8D
2024-03-19	PO	0.0	1216.00	POE: PMR 8B Drum doors
2024-03-19	PO	20.0	1216.00	POE: PMR 8B drum door
2024-03-20	PPO	10.6	464.00	POE: PMR 8ST Temperature matching
2024-03-20	PPO	78.8	187.00	POE: PMR 8A Atomizing Air
2024-03-20	PMO	4.9	189.00	MOE: PMR 8D
2024-03-20	PPO	27.7	187.00	POE: PMR 8B drum door
2024-03-20	PMO	10.5	149.00	MO Derate: PMR 8C
2024-03-20	PMO	10.5	88.02	MO Derate: PMR 8C
2024-03-20	PMO	0.6	126.00	MO Derating: PMR 8C
2024-03-20	PMO	0.1	145.60	MO Derating: PMR 8C
2024-03-20	PPO	0.3	96.00	POE: PMR 8A Atomizing Air
2024-03-20	PMO	0.3	145.60	MO Derating: PMR 8C
2024-03-20	PPO	0.0	464.00	POE: PMR 8ST Temperature Matching
2024-03-20	PPO	3.4	96.00	POE: PMR 8A Atomizing Air
2024-03-20	PMO	0.1	145.60	MO Derating: PMR 8C
2024-03-20	PPO	3.3	464.00	POE: PMR 8ST Temperature Matching
2024-03-20	PMO	1.6	189.00	MOE: PMR 8C
2024-03-20	PPO	64.4	96.00	POE: PMR 8A Atomizing Air
2024-03-21	PFO	8.3	189.00	EFOR: PMR 8D High exhaust pressure
2024-03-21	PFO	8.3	96.00	EFOR: PMR 8D High exhaust pressure
2024-03-22	PFO	6.4	189.00	EFOR: PMR 8D Exhaust Pressure Transmitters
2024-03-22	PFO	6.4	96.00	EFOR: PMR 8D Exhaust Pressure Transmitters
2024-03-23	PPO	0.0	187.00	POE: PMR 8A
2024-03-23	PPO	30.1	187.00	POE: PMR 8A
2024-03-24	PFO	7.4	189.00	EFOR: PMR 8C Trip
2024-03-24	PFO	7.4	116.00	EFOR: PMR 8C Trip
2024-03-24	PPO	0.0	187.00	POE: PMR 8A
2024-03-24	PPO	18.5	187.00	POE: PMR 8A
2024-03-24	PPO	18.5	110.44	POE: PMR 8A
2024-04-05	PFO	0.3	189.00	EFOR: PMR 8D BFP Low Flow
2024-04-05	PFO	0.3	116.00	EFOR: PMR 8D BFP Low Flow
2024-04-11	PFO	16.6	187.00	EFOR: PMR 8A AA Compressor motor overload
2024-04-11	PFO	16.6	116.00	EFOR: PMR 8A AA Compressor motor overload
2024-04-13	PMO	24.0	189.00	MO: PMR 8D High exhaust pressure investigation
2024-04-13	PMO	24.0	116.00	MO: PMR 8D High exhaust pressure investigation

2024-04-27	PFO	0.6	189.00	EFOR: PMR 8D Fuel Gas Auxiliary Stop Valve
2024-04-27	PFO	0.6	116.00	EFOR: PMR 8D Fuel Gas Auxiliary Stop Valve
2024-05-04	PMO	72.0	189.00	MO: PMR 8C Exhaust HRSG
2024-05-04	PMO	72.0	96.00	MO: PMR 8C Exhaust HRSG
2024-05-07	PFO	3.2	187.00	EFOR: PMR 8A Gas Control Valve High Position Deviation
2024-05-07	PFO	3.2	96.00	EFOR: PMR 8A Gas Control Valve High Position Deviation
2024-05-09	PFO	9.3	189.00	EFOR: PMR 8C BFP
2024-05-09	PFO	9.3	116.00	EFOR: PMR 8C BFP
2024-05-16	PFO	1.3	189.00	EFOR: PMR 8C CT Fire
2024-05-16	PFO	1.3	96.00	EFOR: PMR 8C CT Fire
2024-05-16	PFO	0.0	189.00	EFOR: PMR 8D. IMPACT 8D
2024-05-16	PFO	191.2	96.00	EFOR: PMR 8D. IMPACT 8D
2024-05-16	FFO	133.4	1216.00	EFOR: PMR 8ST. IMPACT due to 8C fire
2024-05-16	PFO	138.7	96.00	EFOR: PMR 8C CT Fire
2024-05-16	PFO	134.9	96.00	EFOR: PMR 8A .IMPACT 8C
2024-05-16	PFO	133.4	96.00	EFOR: PMR 8B. IMPACT 8C
2024-05-22	PFO	230.7	189.00	EFOR: PMR 8C CT Fire
2024-05-22	PFO	1.4	187.00	EFOR: PMR 8A .IMPACT 8C
2024-05-22	PFO	57.7	189.00	EFOR: PMR 8D. IMPACT 8D
2024-05-22	PFO	5.2	464.00	EFOR: PMR 8ST. IMPACT due to 8C fire
2024-05-22	PFO	225.5	96.00	EFOR: PMR 8C CT Fire
2024-05-29	PFO	7.1	187.00	EFOR: PMR 8A WI flex hose
2024-05-29	PFO	7.1	96.00	EFOR: PMR 8A WI flex hose

- (1) FFO - FULL FORCED OUTAGE
- PPO - PARTIAL PLANNED OUTAGE
- PMO - PARTIAL MAINTENANCE OUTAGE
- PO - PLANNED OUTAGE
- PFO - PARTIAL FORCED OUTAGE
- FMO - FULL MAINTENANCE OUTAGE

- FILED:
- SUSPENDED:
- EFFECTIVE:
- DOCKET NO:
- ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
COMPANY: FLORIDA POWER AND LIGHT
FROM: Jan-2024 TO: Dec-2024

PLANT/UNIT: Okeechobee Energy Center - POK		POK-01		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2024-02-19	PMO	27.7	342.00	CT 1-3 SNOW - Execution Of Project 9729 STG EHC
2024-02-19	PMO	24.0	169.62	CT 1-3 SNOW - Execution Of Project 9729 STG EHC
2024-02-19	PMO	3.9	342.00	CT 1-1 SNOW - Execution Of Project 9729 STG EHC
2024-02-19	FMO	78.8	169.62	CT 1-1 SNOW - Execution Of Project 9729 STG EHC
2024-02-20	PMO	3.6	514.00	ST SNOW - Execution Of Project 9729 STG EHC Control Fluid Pumps
2024-02-20	PMO	84.3	169.62	CT 1-3 SNOW - Execution Of Project 9729 STG EHC
2024-02-20	FMO	74.8	1540.00	CT 1-2 SNOW - Execution Of Project 9729 STG EHC
2024-02-23	PMO	5.8	342.00	CT 1-3 SNOW - Execution Of Project 9729 STG EHC
2024-02-23	PMO	3.0	342.00	CT 1-2 SNOW - Execution Of Project 9729 STG EHC
2024-02-23	PMO	7.7	514.00	ST SNOW - Execution Of Project 9729 STG EHC Control Fluid Pumps
2024-02-23	PFO	15.3	342.00	Unit 1-1 - Tripped Bearing 3 High Seismic Vibration
2024-02-23	PFO	2.7	169.62	Unit 1-1 - Tripped Bearing 3 High Seismic Vibration
2024-02-23	PFO	12.5	169.62	Unit 1-1 - Tripped Bearing 3 High Seismic Vibration
2024-03-07	PFO	12.4	342.00	EFOR Unit 1-3 IBH Flow Control Valve Erratic Behavior
2024-03-07	PFO	12.4	165.00	EFOR Unit 1-3 IBH Flow Control Valve Erratic Behavior
2024-03-08	PFO	2.3	342.00	EFOR Unit 1-3 LCI Fault 89SS Switch
2024-03-08	PFO	2.3	165.00	EFOR Unit 1-3 LCI Fault 89SS Switch
2024-03-08	PFO	1.1	185.07	Unit 1-3 Runback from 355MW to 283MW.
2024-03-08	PFO	1.1	59.00	Unit 1-3 Runback from 355MW to 283MW.
2024-03-18	PPO	6.5	342.00	Unit 1-1 Planned Outage
2024-03-18	PPO	5.1	164.00	Unit 1-1 Planned Outage
2024-03-19	PPO	1.4	342.00	Unit 1-2 Planned Outage
2024-03-19	PPO	1.3	514.00	Steam Turbine Planned Outage
2024-03-19	PPO	354.6	164.00	Unit 1-1 Planned Outage
2024-03-19	PO	343.1	1540.00	Unit 1-3 Planned Outage
2024-03-19	PPO	355.5	164.00	Unit 1-3 Planned Outage
2024-04-02	FMO	10.0	1540.00	Unit 1-2 SNOW Air Nozzles.
2024-04-02	PMO	15.9	5.62	Unit 1-2 SNOW Air Nozzles.
2024-04-02	PPO	2.2	342.00	Unit 1-3 Planned Outage
2024-04-02	PPO	5.8	514.00	Steam Turbine Planned Outage
2024-04-02	PMO	180.5	342.00	Unit 1-2 SNOW Air Nozzles.
2024-04-03	PMO	174.6	5.62	Unit 1-2 SNOW Air Nozzles.
2024-05-10	PFO	78.3	342.00	EFOR Unit 1-3 Trip Loss of communication with GE Mark VI S Controller.
2024-05-10	PFO	78.3	171.00	EFOR Unit 1-3 Trip Loss of communication with GE Mark VI S Controller.
2024-05-14	PMO	428.7	342.00	SNOW Unit 1-1 Evap cooler filter media and S1 buckets replacement.
2024-05-14	PMO	428.7	162.00	SNOW Unit 1-1 Evap cooler filter media and S1 buckets replacement.

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
COMPANY: FLORIDA POWER AND LIGHT
FROM: Jan-2024 TO: Dec-2024

PLANT/UNIT: Port Everglades - PPE		PPE-05		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2024-01-01	PFO	519.0	360.00	PPE 50 ST - L-0 Blade Root Crack
2024-01-22	PFO	0.7	245.00	PPE 51 - FG Supply Valve CLOSED Trip
2024-01-22	PFO	0.7	94.68	PPE 51 - FG Supply Valve CLOSED Trip
2024-01-22	PFO	1.5	360.00	PPE 50 - ST offline due to 53 GSU fan alarms
2024-01-22	PFO	1.5	111.00	PPE 50 - ST offline due to 53 GSU fan alarms
2024-01-23	PFO	4.8	360.00	PPE 50 - HP CV1 Servo failure
2024-01-23	PFO	4.8	31.00	PPE 50 - HP CV1 Servo failure
2024-01-25	PFO	3.0	360.00	PPE 50 - HP CV1 Servo failure
2024-01-25	PFO	3.0	42.00	PPE 50 - HP CV1 Servo failure
2024-01-27	PFO	4.9	245.00	PPE 52 - FG Assist Testing Trip
2024-01-27	PFO	4.9	94.68	PPE 52 - FG Assist Testing Trip
2024-01-30	PFO	1.2	262.00	PPE 53 SUF - FG ESV Solenoid Loose
2024-02-01	PFO	12.5	245.00	PPE 51 - PT Fuse Blown
2024-02-01	PFO	12.5	120.00	PPE 51 - PT Fuse Blown
2024-02-02	PFO	1.6	262.00	PPE 53 SUF - FG ESV Stuck
2024-02-02	PFO	1.6	120.00	PPE 53 SUF - FG ESV Stuck
2024-02-05	PFO	0.7	262.00	PPE 53 - FG ESV Stuck
2024-02-05	PFO	0.7	120.00	PPE 53 - FG ESV Stuck
2024-02-07	PFO	0.1	245.00	PPE 52 - Liquid Fuel Transfer Testing Trip
2024-02-07	PFO	0.1	94.68	PPE 52 - Liquid Fuel Transfer Testing Trip
2024-02-24	PFO	0.3	245.00	PPE 51 SUF - FG ESV Stuck
2024-02-24	PFO	0.3	94.68	PPE 51 SUF - FG ESV Stuck
2024-03-05	PMO	0.8	262.00	PPE 53 - Block SNOW
2024-03-05	PMO	0.8	245.00	PPE 51 - Block SNOW
2024-03-05	PMO	0.3	360.00	PPE 50 ST - Block SNOW
2024-03-05	FMO	164.6	1112.00	PPE 52 - Block SNOW
2024-03-12	PMO	8.4	262.00	PPE 53 - Block SNOW
2024-03-12	PMO	5.3	360.00	PPE 50 ST - Block SNOW
2024-03-12	PMO	1.4	245.00	PPE 52 - Block SNOW
2024-03-27	PFO	4.3	262.00	PPE 53 - TOT Failure
2024-03-27	PFO	4.3	94.68	PPE 53 - TOT Failure
2024-04-04	PMO	97.4	262.00	PPE 53 SNOW - Tube Leak Repair
2024-04-04	PMO	97.4	93.00	PPE 53 SNOW - Tube Leak Repair
2024-04-12	PMO	59.2	245.00	PPE 51 SNOW - BFP Recirc Valve Repair
2024-04-12	PMO	59.2	93.00	PPE 51 SNOW - BFP Recirc Valve Repair
2024-04-17	PFO	0.4	245.00	PPE 52 SUF - DC LO Pump Pressure Not Met
2024-04-17	PFO	0.4	93.00	PPE 52 SUF - DC LO Pump Pressure Not Met
2024-04-22	PMO	26.1	245.00	PPE 52 SNOW - BFP Recirc and DC LO Pump
2024-04-22	PMO	26.1	93.00	PPE 52 SNOW - BFP Recirc and DC LO Pump
2024-05-03	PFO	0.1	262.00	PPE 53 - LF Transfer Trip
2024-05-03	PFO	0.1	93.00	PPE 53 - LF Transfer Trip
2024-05-04	PFO	0.1	35.89	PPE 51 - VGV1 Runback
2024-05-04	PFO	0.1	75.00	PPE 51 - VGV1 Runback
2024-05-26	PFO	3.1	40.69	PPE 53 Runback - GV1 Cooling Air Pressure Txr BQ
2024-05-26	PFO	3.1	102.00	PPE 53 Runback - GV1 Cooling Air Pressure Txr BQ

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2024 TO: Dec-2024

PLANT/UNIT: Riviera - PRV		PRV-05		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2024-01-04	PFO	0.7	269.00	PRV-52-Received a preventive shutdown due to failure in comp. blowoff v.
2024-01-04	PFO	0.7	162.00	PRV-52-Received a preventive shutdown due to failure in comp. blowoff v.
2024-01-10	PMO	50.7	269.00	PRV-52-Event MOF-FG filter replacement
2024-01-10	PMO	50.7	162.00	PRV-52-Event MOF-FG filter replacement
2024-01-14	PFO	3.7	269.00	PRV-52-Start Up Failure. Blade Path Spread
2024-01-14	PFO	3.7	162.00	PRV-52-Start Up Failure. Blade Path Spread
2024-01-23	PMO	95.8	269.00	PRV-Event MOF-CT Exhaust Bearing Vibration Probes Replacement
2024-01-23	PMO	95.8	162.00	PRV-Event MOF-CT Exhaust Bearing Vibration Probes Replacement
2024-01-29	PFO	2.5	269.00	PRV-52-Startup Failure at 765rpm - GV2 Cooling Air Valve failed
2024-01-29	PFO	2.5	162.00	PRV-52-Startup Failure at 765rpm - GV2 Cooling Air Valve failed
2024-01-31	PFO	0.8	269.00	PRV-52-Tripped due to GV2 cooling air failed to show position
2024-01-31	PFO	0.8	162.00	PRV-52-Tripped due to GV2 cooling air failed to show position
2024-02-01	PMO	114.0	251.00	PRV 51-Event MOF-HRSG SCR and AIG Cleaning
2024-02-01	PMO	114.0	162.00	PRV 51-Event MOF-HRSG SCR and AIG Cleaning
2024-02-11	PMO	75.9	251.00	PRV 51 - Event MOF - HRSG Tube leak.
2024-02-11	PMO	75.9	162.00	PRV 51 - Event MOF - HRSG Tube leak.
2024-02-12	PMO	27.9	269.00	PRV 52 - Event MOF - Cooling Air Valve Positioner and Cables Replacement
2024-02-12	PMO	27.9	162.00	PRV 52 - Event MOF - Cooling Air Valve Positioner and Cables Replacement
2024-02-25	PFO	0.4	80.69	PRV-52-Derating Event-GV2 Cooling Air Valve
2024-02-25	PFO	0.4	149.00	PRV-52-Derating Event-GV2 Cooling Air Valve
2024-02-26	PFO	1.2	269.00	PRV-53-Force Outage-Cold Reheat Block Valve Indication
2024-02-26	PFO	1.2	162.00	PRV-53-Force Outage-Cold Reheat Block Valve Indication
2024-02-27	PMO	50.8	269.00	PRV-52-HRSG Tube Leak Cooling Air Flange Repair And Lube Oil Pump Repl
2024-02-27	PMO	50.8	162.00	PRV-52-HRSG Tube Leak Cooling Air Flange Repair And Lube Oil Pump Repl
2024-03-01	PMO	111.8	269.00	PRV-52-HRSG Tube Leak Cooling Air Flange Repair And Lube Oil Pump Repl
2024-03-01	PMO	111.8	162.00	PRV-52-HRSG Tube Leak Cooling Air Flange Repair And Lube Oil Pump Repl
2024-03-07	PFO	0.9	251.00	PRV-51-Force Outage-GV3-Limit switches failed to indicate closed
2024-03-07	PFO	0.9	162.00	PRV-51-Force Outage-GV3-Limit switches failed to indicate closed
2024-03-20	PMO	33.9	269.00	PRV-52-MOF-HRH Blending Valve MOV Turb. End. Brg Vibration Probes
2024-03-20	PMO	33.9	160.38	PRV-52-MOF-HRH Blending Valve MOV Turb. End. Brg Vibration Probes
2024-03-20	PPO	33.9	-56.63	PRV-52-MOF-HRH Blending Valve MOV Turb. End. Brg Vibration Probes
2024-03-22	PFO	2.4	269.00	PRV-52-Forced Outage due to failed to start due to GV2 failing to open.
2024-03-22	PFO	2.4	162.00	PRV-52-Forced Outage due to failed to start due to GV2 failing to open.
2024-03-26	PFO	0.7	133.05	PRV-51-Derating- GV3 102 Positioner Fault
2024-03-26	PFO	0.7	216.00	PRV-51-Derating- GV3 102 Positioner Fault
2024-03-27	PMO	50.1	251.00	PRV-51-MOF-GV2 cooling air valve flange leak repair
2024-03-27	PMO	50.1	162.00	PRV-51-MOF-GV2 cooling air valve flange leak repair
2024-04-22	PMO	26.0	269.00	PRV 52 - Event MOF - GV2 Cooling Air Valve Actuator Disassembled

2024-04-22	PMO	26.0	162.00	PRV 52 - Event MOF - GV2 Cooling Air Valve Actuator Disassembled
2024-05-04	PFO	0.5	269.00	PRV-52-Startup Failure-Compressor Blow off valve failed to close
2024-05-05	PFO	8.0	269.00	PRV-52-Startup Failure-Tripped due to faulty igniter
2024-05-05	PFO	8.0	162.00	PRV-52-Startup Failure-Tripped due to faulty igniter
2024-05-23	PMO	2.9	269.00	PRV-53-Event MOF-HP Blending Valve- MS-CRH Block Valve Repack
2024-05-23	PMO	2.4	486.00	PRV-50-Event MOF-53 HP Blending Valve Repack
2024-05-23	PMO	2.2	269.00	PRV-52-Event MOF-HP Blending Valve Repack-MS-CRH Block Valve Repack
2024-05-24	FMO	53.4	1275.00	PRV-51-Event MOF-HP Blending Valve- MS-CRH Block Valve Repack
2024-05-26	PMO	7.4	269.00	PRV-53-Event MOF-HP Blending Valve- MS-CRH Block Valve Repack
2024-05-26	PMO	4.0	486.00	PRV-50-Event MOF-53 HP Blending Valve Repack
2024-05-26	PMO	4.0	251.00	PRV-51-Event MOF-HP Blending Valve- MS-CRH Block Valve Repack

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
COMPANY: FLORIDA POWER AND LIGHT
FROM: Jan-2024 TO: Dec-2024

PLANT/UNIT: St. Lucie Nuclear - PSL		PSL-01		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2024-03-07	PPO	5.6	159.40	U1 PEL DN PWR to 76% - MSSV Testing
2024-03-08	PPO	16.1	236.00	U1 PEL MSSV Testing
2024-03-08	PPO	4.0	485.62	U1 PEL Down Power to BO Start SL1-32
2024-03-09	PO	550.9	981.00	U1 PEL SL1-32 March
2024-04-01	PO	289.7	981.00	U1 PEL SL1-32 Apr
2024-04-13	PPO	87.4	420.15	U1 PEL SL1-32 Up Power
2024-04-20	PFO	45.5	38.96	U1 UEL 1A1 Traveling Screen

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
COMPANY: FLORIDA POWER AND LIGHT
FROM: Jan-2024 TO: Dec-2024

PLANT/UNIT: St. Lucie Nuclear - PSL		PSL-02		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2024-01-03	PPO	3.6	353.45	SL2-27 HP Pipe Repair Down Power
2024-01-03	PO	190.5	986.00	SL2-27 HP Pipe Repair Outage
2024-01-11	PPO	13.6	379.23	PEL SL2-27 HP Pipe Repair Ascension
2024-05-21	PFO	191.4	66.42	UEL SL2-27 2A2 Water Box Repair

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2024 TO: Dec-2024

PLANT/UNIT: Sanford - PSR		PSR-05		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2024-01-02	PMO	51.8	382.00	PSR 5ST EVENT MOF - COLLECTOR MAINTENANCE
2024-01-04	PMO	21.3	187.00	PSR 5D EVENT MOF - ADD OIL TO GSU
2024-01-04	PMO	21.3	97.00	PSR 5D EVENT MOF - ADD OIL TO GSU
2024-01-11	PMO	21.5	187.00	PSR 5A EVENT MOF - REPAIR SPEED PICKUP
2024-01-11	PMO	21.5	97.00	PSR 5A EVENT MOF - REPAIR SPEED PICKUP
2024-01-15	PFO	9.8	187.00	PSR 5A EFOR - SHUTDOWN DUE TO GAS LEAK
2024-01-15	PFO	9.8	97.00	PSR 5A EFOR - SHUTDOWN DUE TO GAS LEAK
2024-01-16	PMO	60.2	187.00	PSR 5A EVENT MOF - UNIT OF TO REPAIR GAS LINE
2024-01-16	PMO	60.2	381.00	PSR 5A EVENT MOF - UNIT OF TO REPAIR GAS LINE
2024-02-13	PFO	0.5	382.00	PSR 5ST EFOR - ROTOR LENGTH ISSUE
2024-02-18	PPO	288.0	185.00	PSR 5B - PLANNED TECH 2 OUTAGE
2024-02-18	PPO	288.0	96.00	PSR 5B - PLANNED TECH 2 OUTAGE
2024-02-20	PFO	2.7	185.00	PSR 5C EFOR - STARTUP FAILURE GAS VALVE LEAK
2024-02-20	PFO	2.7	96.00	PSR 5C EFOR - STARTUP FAILURE GAS VALVE LEAK
2024-02-20	PFO	2.6	187.00	PSR 5A EFOR - UNIT TRIPPED DUE TO FIELD BREAKER ISSUE
2024-02-20	PFO	2.6	96.00	PSR 5A EFOR - UNIT TRIPPED DUE TO FIELD BREAKER ISSUE
2024-02-23	PMO	36.7	187.00	PSR 5D EVENT MOF - REPAIR SAFETY VALVES
2024-02-23	PMO	36.7	96.00	PSR 5D EVENT MOF - REPAIR SAFETY VALVES
2024-02-26	PMO	42.3	187.00	PSR 5A EVENT MOF - UNIT OFF FOR THERMOCOUPLE REPAIR
2024-02-26	PMO	42.3	96.00	PSR 5A EVENT MOF - UNIT OFF FOR THERMOCOUPLE REPAIR
2024-03-01	PPO	120.5	185.00	PSR 5B PLANNED OUTAGE TECH 2 UPGRADE
2024-03-01	PPO	120.4	381.00	PSR 5B PLANNED OUTAGE TECH 2 UPGRADE
2024-03-06	PMO	0.5	187.00	PSR 5D EVENT MOF - BLOCK OUTAGE FOR 5C MUV-4 WORK
2024-03-06	PMO	43.6	96.00	PSR 5D EVENT MOF - BLOCK OUTAGE FOR 5C MUV-4 WORK
2024-03-06	PMO	0.0	382.00	PSR 5ST EVENT MOF - BLOCK OUTAGE FOR 5C MUV-4 WORK
2024-03-06	PPO	43.1	381.00	PSR 5B PLANNED OUTAGE TECH 2 UPGRADE
2024-03-06	FMO	43.1	1126.00	PSR 5C EVENT MOF - BLOCK OUTAGE FOR 5C MUV-4 WORK
2024-03-06	PMO	43.1	96.00	PSR 5A EVENT MOF - BLOCK OUTAGE FOR 5C MUV-4 WORK
2024-03-06	PMO	43.1	96.00	PSR 5C EVENT MOF - BLOCK OUTAGE FOR 5C MUV-4 WORK
2024-03-07	PPO	26.2	185.00	PSR 5B PLANNED OUTAGE TECH 2 UPGRADE
2024-03-07	PPO	26.2	381.00	PSR 5B PLANNED OUTAGE TECH 2 UPGRADE
2024-03-22	PMO	18.0	187.00	5B EVENT MOF - UNIT OFF TO REPAIR HYDRAULIC PUMP
2024-03-22	PMO	18.0	95.00	5B EVENT MOF - UNIT OFF TO REPAIR HYDRAULIC PUMP
2024-03-27	PMO	2.1	187.00	PSR 5B EVENT MOF-CONDENSER TUBE LEAK
2024-03-27	PMO	1.8	95.00	PSR 5B EVENT MOF-CONDENSER TUBE LEAK
2024-03-27	PMO	1.4	187.00	PSR 5D EVENT MOF - CONDENSER TUBE LEAK
2024-03-27	PMO	10.1	95.00	PSR 5D EVENT MOF - CONDENSER TUBE LEAK
2024-03-28	PMO	0.2	381.00	PSR 5ST EVENT MOF - CONDENSER TUBE LEAK
2024-03-28	PMO	8.9	95.00	PSR 5B EVENT MOF-CONDENSER TUBE LEAK
2024-03-28	FMO	8.7	1127.00	PSR 5C EVENT MOF - CONDENSER TUBE LEAK
2024-03-28	PMO	8.7	95.00	PSR 5A EVENT MOF - CONDENSER TUBE LEAK

2024-03-28	PMO	8.7	95.00	PSR 5C EVENT MOF - CONDENSER TUBE LEAK
2024-04-05	PFO	0.4	185.00	PSR 5C EFOR - FLAME SCANNER ISSUE
2024-04-05	PFO	0.4	95.00	PSR 5C EFOR - FLAME SCANNER ISSUE
2024-04-06	PMO	23.5	185.00	PSR 5C EVENT MOF - LIFT OIL MAINTENANCE
2024-04-06	PMO	23.5	95.00	PSR 5C EVENT MOF - LIFT OIL MAINTENANCE
2024-04-17	PMO	0.0	381.00	PSR 5ST EVENT MOF - BLOCK FOR CONDENSER REPAIR
2024-04-17	PMO	0.0	187.00	PSR 5A EVENT MOF - BLOCK FOR CONDENSER REPAIR
2024-04-17	PMO	0.0	187.00	PSR 5B EVENT MOF - BLOCK FOR CONDENSER REPAIR
2024-04-17	PMO	0.0	187.00	PSR 5D EVENT MOF - BLOCK FOR CONDENSER REPAIR
2024-04-17	PMO	116.4	95.00	PSR 5A EVENT MOF - BLOCK FOR CONDENSER REPAIR
2024-04-17	PMO	116.4	95.00	PSR 5B EVENT MOF - BLOCK FOR CONDENSER REPAIR
2024-04-17	PMO	116.4	95.00	PSR 5D EVENT MOF - BLOCK FOR CONDENSER REPAIR
2024-04-17	FMO	116.4	1127.00	PSR 5C EVENT MOF - BLOCK FOR CONDENSER REPAIR
2024-04-17	PMO	116.4	95.00	PSR 5C EVENT MOF - BLOCK FOR CONDENSER REPAIR
2024-04-28	PMO	14.2	187.00	PSR 5D EVENT MOF - REPAIR EXHAUST THERMOCOUPLE
2024-04-28	PMO	14.2	95.00	PSR 5D EVENT MOF - REPAIR EXHAUST THERMOCOUPLE
2024-05-12	PMO	13.7	185.00	PSR 5C EVENT MOF - UNIT OFF FOR STEAM VALVE REPAIR
2024-05-12	PMO	13.7	71.00	PSR 5C EVENT MOF - UNIT OFF FOR STEAM VALVE REPAIR
2024-05-23	PFO	2.7	30.00	PSR 5C PARTIAL EFOR - NOX LIMITED
2024-05-23	PFO	2.7	31.98	PSR 5C PARTIAL EFOR - NOX LIMITED

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
COMPANY: FLORIDA POWER AND LIGHT
FROM: Jan-2024 TO: Dec-2024

PLANT/UNIT: Turkey Point Nuclear - PTN		PTN-03		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION

- (1) FFO - FULL FORCED OUTAGE
- PPO - PARTIAL PLANNED OUTAGE
- PMO - PARTIAL MAINTENANCE OUTAGE
- PO - PLANNED OUTAGE
- PFO - PARTIAL FORCED OUTAGE
- FMO - FULL MAINTENANCE OUTAGE

- FILED:
- SUSPENDED:
- EFFECTIVE:
- DOCKET NO:
- ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
COMPANY: FLORIDA POWER AND LIGHT
FROM: Jan-2024 TO: Dec-2024

PLANT/UNIT: Turkey Point Nuclear - PTN		PTN-04		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION

- (1) FFO - FULL FORCED OUTAGE
- PPO - PARTIAL PLANNED OUTAGE
- PMO - PARTIAL MAINTENANCE OUTAGE
- PO - PLANNED OUTAGE
- PFO - PARTIAL FORCED OUTAGE
- FMO - FULL MAINTENANCE OUTAGE

- FILED:
- SUSPENDED:
- EFFECTIVE:
- DOCKET NO:
- ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2024 TO: Dec-2024

PLANT/UNIT: West County Energy Center - PWC				PWC-01
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2024-01-14	PFO	1.1	242.00	PWC-1B-SU Failure-HP Drum Level High
2024-01-14	PFO	1.1	160.00	PWC-1B-SU Failure-HP Drum Level High
2024-01-24	PMO	58.0	242.00	PWC-1A-Event MOF-HP DSH Spary 1SGA-ACV-1008 leaking through
2024-01-24	PMO	58.0	160.00	PWC-1A-Event MOF-HP DSH Spary 1SGA-ACV-1008 leaking through
2024-01-30	PMO	38.9	485.00	PWC 1ST- Event MO-GSU Transformer Maintenance Outage
2024-02-01	PMO	186.7	485.00	PWC 1ST- Event MO-GSU Transformer Maintenance Outage
2024-02-10	PMO	2.0	242.00	PWC 1A - Event MOF - Main Steam side leak repairs
2024-02-10	PMO	1.0	242.00	PWC 1B - Event MOF - Main steam side leak repairs
2024-02-10	PMO	1.0	485.00	PWC 1ST - Event MOF - Main steam side leak repairs
2024-02-10	FMO	146.3	1211.00	PWC 1C - Event MOF - Main Steam Side Leak Repairs
2024-02-23	PFO	43.8	242.00	PWC-1A-Force Outage-Blade Path Spread High
2024-02-23	PFO	43.8	162.00	PWC-1A-Force Outage-Blade Path Spread High
2024-02-24	PFO	34.3	242.00	PWC-1A-Force Outage-Blade Path Spread High
2024-02-24	PFO	34.3	161.00	PWC-1A-Force Outage-Blade Path Spread High
2024-03-02	PFO	0.5	242.00	PWC-1B-Force Outage-High temperatures from HP-CRH bypass leak by
2024-03-02	PFO	0.5	162.00	PWC-1B-Force Outage-High temperatures from HP-CRH bypass leak by
2024-03-06	PFO	1.2	242.00	PWC-1A missed 0600 RFC due to a delay from BFP tripped on low flow
2024-03-06	PFO	1.2	162.00	PWC-1A missed 0600 RFC due to a delay from BFP tripped on low flow
2024-03-08	PFO	1.8	242.00	PWC-1A missed RFC due to a delay from BFP tripped on low flow
2024-03-08	PFO	1.8	162.00	PWC-1A missed RFC due to a delay from BFP tripped on low flow
2024-03-10	PMO	111.0	242.00	PWC 1B - Event MOF -HP FW Control Valve Leak By and BP Spread
2024-03-10	PMO	111.0	160.05	PWC 1B - Event MOF -HP FW Control Valve Leak By and BP Spread
2024-03-28	PMO	24.4	242.00	PWC-1C-MOF-Repair packing leak in valve 1SGA-ABV-3008
2024-03-28	PMO	24.4	162.00	PWC-1C-MOF-Repair packing leak in valve 1SGA-ABV-3008
2024-04-03	PMO	93.3	242.00	PWC-1A-MOF-Repair HRSG tube leak and LP LCV leak-by
2024-04-03	PMO	93.3	162.00	PWC-1A-MOF-Repair HRSG tube leak and LP LCV leak-by
2024-04-16	PFO	0.4	173.00	PWC-1B-Missed RFC due to IP transition to cooling steam delayed
2024-04-16	PFO	0.4	238.97	PWC-1B-Missed RFC due to IP transition to cooling steam delayed
2024-04-16	PMO	107.5	242.00	PWC-1A-MOF-HRSG Tube leaks and - valves packing leaks
2024-04-16	PMO	107.5	162.00	PWC-1A-MOF-HRSG Tube leaks and - valves packing leaks
2024-04-21	PFO	0.9	242.00	PWC-1A-Start Up Failure-Attemperator spray control valve was stuck close
2024-04-21	PFO	0.9	162.00	PWC-1A-Start Up Failure-Attemperator spray control valve was stuck close
2024-04-21	PFO	9.8	242.00	PWC-1C-Force Outage-OST Solenoid Burn Wires
2024-04-21	PFO	9.8	162.00	PWC-1C-Force Outage-OST Solenoid Burn Wires
2024-05-03	PMO	131.3	242.00	PWC-1A-Event MOF-HRSG Tube leaks
2024-05-03	PMO	131.3	162.00	PWC-1A-Event MOF-HRSG Tube leaks
2024-05-09	PFO	1.3	242.00	PWC-1A-Startup Failure-Fuel Ga Pilot Pressure Control Valve Deviation
2024-05-09	PFO	1.3	162.00	PWC-1A-Startup Failure-Fuel Ga Pilot Pressure Control Valve Deviation
2024-05-25	PFO	1.7	242.00	PWC-1C-Startup Failure-Combustor 10 -Igniter Failure
2024-05-25	PFO	1.7	162.00	PWC-1C-Startup Failure-Combustor 10 -Igniter Failure

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2024 TO: Dec-2024

PLANT/UNIT: West County Energy Center - PWC				
			PWC-02	
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2024-01-05	PMO	2.3	242.00	PWC-2A-Event MOF-Condensate Recirc Pipe Repair
2024-01-05	PMO	2.3	160.00	PWC-2A-Event MOF-Condensate Recirc Pipe Repair
2024-01-05	PMO	1.1	242.00	2C-Event MO-Balancing Shot-IGV clips installation
2024-01-05	PMO	1.1	163.00	2C-Event MO-Balancing Shot-IGV clips installation
2024-01-05	PMO	0.1	242.00	PWC-2A-Event MOF-Condensate Recirc Pipe Repair
2024-01-05	PMO	0.1	242.00	2C-Event MO-Balancing Shot-IGV clips installation
2024-01-05	PMO	0.1	485.00	PWC-2ST-Event MOF-Condensate Recirc Pipe Repair
2024-01-05	FMO	58.2	1211.00	PWC-2B-Event MOF-Condensate Recirc Pipe Repair
2024-01-08	PMO	3.0	242.00	2C-Event MO-Balancing Shot-IGV clips installation
2024-01-08	PMO	5.5	242.00	PWC-2B-Event MOF-Condensate Recirc Pipe Repair
2024-01-08	PMO	3.0	485.00	PWC-2ST-Event MOF-Condensate Recirc Pipe Repair
2024-01-08	PMO	101.1	242.00	2C-Event MO-Balancing Shot-IGV clips installation
2024-01-08	PMO	101.1	160.00	2C-Event MO-Balancing Shot-IGV clips installation
2024-01-28	PMO	74.4	242.00	PWC-2B-Event MOF-Borescope inspection
2024-01-28	PMO	74.4	160.00	PWC-2B-Event MOF-Borescope inspection
2024-02-01	PMO	63.4	242.00	PWC-2B-Event MOF-Borescope Inspection
2024-02-01	PMO	63.4	160.00	PWC-2B-Event MOF-Borescope Inspection
2024-02-12	PFO	1.5	242.00	PWC-2C-Force Outage-Condensate Isolation Valve Manual Closed
2024-02-12	PFO	1.5	162.00	PWC-2C-Force Outage-Condensate Isolation Valve Manual Closed
2024-02-12	PFO	1.2	242.00	PWC-2B-Startup Failure-TCA Cooler to the Condenser Valve failed to open
2024-02-12	PFO	1.2	162.00	PWC-2B-Startup Failure-TCA Cooler to the Condenser Valve failed to open
2024-03-19	PFO	0.4	242.00	PWC-U2-Force Outage-Loss of protection from the site to the 500 kV line
2024-03-19	PFO	0.2	485.00	PWC-U2-Force Outage-Loss of protection from the site to the 500 kV line
2024-03-19	PFO	0.1	242.00	PWC-U2-Force Outage-Loss of protection from the site to the 500 kV line
2024-03-19	FFO	11.4	1211.00	PWC-U2-Force Outage-Loss of protection from the site to the 500 kV line
2024-03-22	PMO	49.3	242.00	PWC 2A - Event MOF - HRSG Vent Line Repair
2024-03-22	PMO	49.3	162.00	PWC 2A - Event MOF - HRSG Vent Line Repair
2024-04-23	PMO	111.6	242.00	PWC 2A - Event MOF - SCR System Cleaning
2024-04-23	PMO	111.6	162.00	PWC 2A - Event MOF - SCR System Cleaning
2024-04-26	PFO	0.8	62.00	PWC-2B-Force Derating-SCR NOx Plugging
2024-04-26	PFO	0.8	27.57	PWC-2B-Force Derating-SCR NOx Plugging
2024-04-26	PFO	3.4	27.00	PWC-2B-Force Derating-SCR NOx Plugging
2024-04-26	PFO	3.4	39.58	PWC-2B-Force Derating-SCR NOx Plugging
2024-04-27	PFO	9.6	27.00	PWC-2B-Force Derating-SCR NOx Plugging
2024-04-27	PFO	9.6	12.00	PWC-2B-Force Derating-SCR NOx Plugging
2024-04-27	PMO	39.6	242.00	PWC 2B - Event MOF - SCR System Cleaning
2024-04-27	PMO	39.6	161.00	PWC 2B - Event MOF - SCR System Cleaning
2024-04-29	PMO	58.2	242.00	PWC 2B - Event MOF - SCR System Cleaning
2024-05-02	PMO	24.0	242.00	PWC 2B - Event MOF - SCR System Cleaning
2024-05-03	FMO	14.0	1211.00	PWC-2A-Event MOF-Fiber optical cable repaired by PC
2024-05-03	FMO	15.0	1211.00	PWC-2B-Event MOF-Fiber optical cable repaired by PC
2024-05-04	PMO	6.6	485.00	PWC-2ST-Event MOF-Fiber optical cable repaired by PC
2024-05-04	PMO	10.5	242.00	PWC-2B-Event MOF-Fiber optical cable repaired by PC
2024-05-04	PMO	11.4	242.00	PWC-2A-Event MOF-Fiber optical cable repaired by PC

2024-05-04	PFO	4.2	242.00	PWC-2B-Force Outage-Blade Path Temperature Spread
2024-05-04	PFO	4.2	162.00	PWC-2B-Force Outage-Blade Path Temperature Spread
2024-05-10	PFO	10.7	242.00	PWC-2A-Force Outage-CT Combustor Bypass Valve BQ
2024-05-10	PFO	10.7	162.00	PWC-2A-Force Outage-CT Combustor Bypass Valve BQ
2024-05-29	PFO	5.1	242.00	PWC-2C-Force Outage-Fuel Gas Main B Pressure Control Valve Pos. Div.
2024-05-29	PFO	5.1	162.00	PWC-2C-Force Outage-Fuel Gas Main B Pressure Control Valve Pos. Div.

- (1) FFO - FULL FORCED OUTAGE
- PPO - PARTIAL PLANNED OUTAGE
- PMO - PARTIAL MAINTENANCE OUTAGE
- PO - PLANNED OUTAGE
- PFO - PARTIAL FORCED OUTAGE
- FMO - FULL MAINTENANCE OUTAGE

- FILED:
- SUSPENDED:
- EFFECTIVE:
- DOCKET NO:
- ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
COMPANY: FLORIDA POWER AND LIGHT
FROM: Jan-2024 TO: Dec-2024

PLANT/UNIT: West County Energy Center - PWC		PWC-03		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2024-01-04	PMO	34.6	242.00	PWC-3A-MOF-BFP HP discharge line leak repairs
2024-01-04	PMO	34.6	163.00	PWC-3A-MOF-BFP HP discharge line leak repairs
2024-02-12	PMO	3.2	242.00	PWC 3C - Event MO - Transmission Line Repair
2024-02-12	PMO	3.2	162.00	PWC 3C - Event MO - Transmission Line Repair
2024-02-13	PMO	0.8	242.00	PWC 3B - Event MO - Transmission Line Repair
2024-02-13	PMO	47.1	160.05	PWC 3B - Event MO - Transmission Line Repair
2024-02-13	PMO	0.3	242.00	PWC 3C - Event MO - Transmission Line Repair
2024-02-13	PMO	0.3	485.00	PWC 3ST - Event MO - Transmission Line Repair
2024-02-13	FMO	46.2	1211.00	PWC 3A - Event MO - Transmission Line Repair
2024-02-13	PMO	55.8	160.05	PWC 3A - Event MO - Transmission Line Repair
2024-02-15	PMO	9.6	242.00	PWC 3A - Event MO - Transmission Line Repair
2024-02-15	PMO	12.2	485.00	PWC 3ST - Event MO - Transmission Line Repair
2024-02-19	PFO	0.9	65.00	PWC-3B-Derating Event-Blade Path Spread High
2024-02-19	PFO	0.9	43.42	PWC-3B-Derating Event-Blade Path Spread High
2024-02-20	PMO	181.5	242.00	PWC 3B - Event MOF - Partial Borescope of Combustors and Turbine BP
2024-02-20	PMO	181.5	323.00	PWC 3B - Event MOF - Partial Borescope of Combustors and Turbine BP
2024-02-22	PFO	104.3	242.00	PWC-3C-Force Outage-21kV Protection Device
2024-02-22	PFO	104.3	323.00	PWC-3C-Force Outage-21kV Protection Device
2024-02-26	PFO	15.1	242.00	PWC-3C-Force Outage-GSU Relay Settings
2024-02-26	PFO	15.1	323.00	PWC-3C-Force Outage-GSU Relay Settings
2024-03-05	PFO	1.7	242.00	PWC-3C-Tripped due to condenser protection system
2024-03-05	PFO	1.7	162.00	PWC-3C-Tripped due to condenser protection system
2024-03-21	PMO	109.9	242.00	PWC-3C-MOF-Repair reheat safety valve steam leak
2024-03-21	PMO	109.9	160.05	PWC-3C-MOF-Repair reheat safety valve steam leak
2024-03-24	PFO	4.2	242.00	PWC-3A-Force Outage-LP Drum Level Control Valve Failure
2024-03-24	PFO	4.2	1.94	PWC-3A-Force Outage-LP Drum Level Control Valve Failure
2024-03-30	PFO	0.8	242.00	PWC-3A-Startup Failure due to a high TCA cooled inlet temperature
2024-03-30	PFO	0.8	162.00	PWC-3A-Startup Failure due to a high TCA cooled inlet temperature
2024-04-04	PMO	63.4	242.00	PWC-3A-MOF-Repair HRSG External Leaks And Packing Leaks LP LCV Sticking
2024-04-04	PMO	63.4	162.00	PWC-3A-MOF-Repair HRSG External Leaks And Packing Leaks LP LCV Sticking
2024-04-08	PFO	2.2	242.00	PWC-3A-Force Outage-Condenser Protection
2024-04-08	PFO	2.2	162.00	PWC-3A-Force Outage-Condenser Protection
2024-05-06	PFO	1.8	242.00	PWC-3A-Force Outage-TCA to condenser block valve failed to open
2024-05-06	PFO	1.8	162.00	PWC-3A-Force Outage-TCA to condenser block valve failed to open

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ACTUAL PERFORMANCE DATA
COMPANY: FLORIDA POWER AND LIGHT
FROM: Jan-2024 TO: Dec-2024

PLANT/UNIT: Turkey Point - TP5		TP5-05		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2024-01-06	PMO	33.9	188.00	PTF 5C MO Event - Overboard Bleed valve tracking issue
2024-01-06	PMO	33.9	127.00	PTF 5C MO Event - Overboard Bleed valve tracking issue
2024-01-08	PFO	2.0	188.00	PTF 5C SU Failure - Overboard Bleed valve tracking issue
2024-01-08	PFO	2.0	127.00	PTF 5C SU Failure - Overboard Bleed valve tracking issue
2024-01-18	PMO	47.6	188.00	PTF 5C MO Event - AA valves 20AA replacement
2024-01-18	PMO	47.6	127.00	PTF 5C MO Event - AA valves 20AA replacement
2024-01-22	PMO	47.3	188.00	PTF 5B MO Event - Flame Detector 4 Malfunctioning
2024-01-22	PMO	47.3	127.00	PTF 5B MO Event - Flame Detector 4 Malfunctioning
2024-01-27	PFO	0.7	188.00	PTF 5B EFOR Event - Trip during LF transfer
2024-01-27	PFO	0.7	127.00	PTF 5B EFOR Event - Trip during LF transfer
2024-02-01	PMO	47.7	186.00	PTF 5A MO Event - LF Servo Valve troubleshooting
2024-02-01	PMO	47.7	127.00	PTF 5A MO Event - LF Servo Valve troubleshooting
2024-02-09	PFO	0.1	188.00	PTF 5B EFOR - Exhaust Frame Blower Low Pressure Alarm 63TK-2
2024-02-09	PFO	0.1	126.05	PTF 5B EFOR - Exhaust Frame Blower Low Pressure Alarm 63TK-2
2024-02-16	PPO	190.9	511.00	PTF5 ST PO - MAIN GSU TRANSFORMER TESTING
2024-02-23	PO	144.0	1261.00	5D Planned Outage Block
2024-03-01	PPO	71.9	511.00	PTF5 ST PO - MAIN GSU TRANSFORMER TESTING
2024-03-04	PFO	0.7	188.00	PTF 5C EFOR - High Exhaust Temperature
2024-03-04	PFO	0.7	127.00	PTF 5C EFOR - High Exhaust Temperature
2024-03-04	PFO	10.4	511.00	PTF 5ST EFOR - High HP Differential Expansion
2024-03-07	PPO	219.9	188.00	PTF 5D Planned Outage - LF Water Flush System and FG Valves Upgrade
2024-03-07	PPO	219.9	127.00	PTF 5D Planned Outage - LF Water Flush System and FG Valves Upgrade
2024-04-07	PFO	16.9	188.00	PTF EFOR - 5C IGV actuator connector
2024-04-07	PFO	16.9	127.00	PTF EFOR - 5C IGV actuator connector
2024-04-07	PFO	2.4	188.00	PTF EFOR - 5B High HP drum level due to FW SU reg. vlv leaking through
2024-04-07	PFO	2.4	127.00	PTF EFOR - 5B High HP drum level due to FW SU reg. vlv leaking through
2024-04-07	PFO	1.5	188.00	PTF EFOR - 5B High HP drum level due to FW SU reg. valve leaking through
2024-04-07	PFO	1.1	127.00	PTF EFOR - 5B High HP drum level due to FW SU reg. valve leaking through
2024-04-07	PFO	0.4	127.00	PTF EFOR - 5B High HP drum level due to FW SU reg. valve leaking through
2024-04-11	PMO	10.8	188.00	PTF 5C MO - ST Condenser Tube leak Inspection
2024-04-11	PMO	10.3	127.00	PTF 5C MO - ST Condenser Tube leak Inspection
2024-04-12	PMO	9.0	188.00	PTF 5B MO - ST Condenser Tube leak Inspection
2024-04-12	PMO	8.5	129.00	PTF 5B MO - ST Condenser Tube leak Inspection
2024-04-12	PMO	0.4	511.00	PTF5 MO - ST Condenser Tube leak Inspection
2024-04-12	PMO	0.4	185.00	PTF5 MO - ST Condenser Tube leak Inspection
2024-04-12	PMO	91.0	187.00	PTF5 MO - ST Condenser Tube leak Inspection
2024-04-12	PMO	87.5	187.00	PTF5 MO - ST Condenser Tube leak Inspection
2024-04-12	PMO	0.1	187.00	PTF5 MO - ST Condenser Tube leak Inspection
2024-04-12	PMO	87.5	127.00	PTF 5C MO - ST Condenser Tube leak Inspection
2024-04-12	PMO	91.0	129.00	PTF 5B MO - ST Condenser Tube leak Inspection
2024-04-12	PMO	0.3	188.00	PTF 5D MO - ST Condenser Tube Leak Inspection
2024-04-12	PMO	90.8	187.00	PTF5 MO - ST Condenser Tube leak Inspection
2024-04-12	PMO	90.8	254.90	PTF 5D MO - ST Condenser Tube Leak Inspection

2024-04-12	FMO	85.5	1261.00	PTF 5A MO - ST Condenser Tube Leak Inspection
2024-04-12	PMO	85.5	185.00	PTF5 MO - ST Condenser Tube leak Inspection
2024-04-12	PMO	85.5	510.90	PTF 5A MO - ST Condenser Tube Leak Inspection
2024-04-15	PMO	4.9	511.00	PTF5 MO - ST Condenser Tube leak Inspection
2024-04-15	PMO	7.0	188.00	PTF 5D MO - ST Condenser Tube Leak Inspection
2024-04-15	PMO	1.5	188.00	PTF 5C MO - ST Condenser Tube leak Inspection
2024-04-15	PMO	13.0	188.00	PTF 5B MO - ST Condenser Tube leak Inspection
2024-04-15	PMO	4.9	185.00	PTF5 MO - ST Condenser Tube leak Inspection
2024-04-16	PMO	3.4	187.00	PTF5 MO - ST Condenser Tube leak Inspection
2024-04-16	PMO	0.9	254.90	PTF 5D MO - ST Condenser Tube Leak Inspection
2024-04-16	PMO	0.9	129.00	PTF 5B MO - ST Condenser Tube leak Inspection
2024-04-16	PFO	0.9	511.00	PTF5 EFOR - ST tripped during a Cold Start due to loss of steam from 5A
2024-04-16	PFO	0.6	169.00	PTF5 EFOR - ST tripped during a Cold Start due to loss of steam from 5A
2024-04-16	PFO	0.9	1.00	PTF5 EFOR - ST tripped during a Cold Start due to loss of steam from 5A
2024-04-16	PFO	0.9	1.00	PTF5 EFOR - ST tripped during a Cold Start due to loss of steam from 5A
2024-04-16	PFO	0.9	1.00	PTF5 EFOR - ST tripped during a Cold Start due to loss of steam from 5A
2024-04-16	PMO	0.9	254.90	PTF 5D MO - ST Condenser Tube Leak Inspection
2024-04-16	PMO	0.9	129.00	PTF 5B MO - ST Condenser Tube leak Inspection
2024-04-16	PFO	2.9	186.00	PTF EFOR - 5A tripped due to high HRH temperature
2024-04-16	PFO	0.2	169.00	PTF5 EFOR - ST tripped during a Cold Start due to loss of steam from 5A
2024-04-16	PFO	2.9	127.00	PTF EFOR - 5A tripped due to high HRH temperature
2024-04-16	PMO	0.1	254.90	PTF 5D MO - ST Condenser Tube Leak Inspection
2024-04-16	PMO	6.2	129.00	PTF 5B MO - ST Condenser Tube leak Inspection
2024-05-19	PFO	6.2	188.00	PTF 5C BFP Recirc Valve positioner failure
2024-05-19	PFO	6.2	127.00	PTF 5C BFP Recirc Valve positioner failure
2024-05-31	PMO	2.4	188.00	PTF MO - 5B BFP recirc valve packing leak FWA-ACV-2021
2024-05-31	PMO	2.4	127.00	PTF MO - 5B BFP recirc valve packing leak FWA-ACV-2021

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.