

June 27, 2024

Writer's E-Mail Address: bkeating@gunster.com

VIA E-PORTAL

Mr. Adam Teitzman
Commission Clerk
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, FL 32399-0850


Docket No. 20240000-OT – 2024 Undocketed Filings (FPUC SPP Annual Report)

Dear Mr. Teitzman:

Attached for electronic filing on behalf of Florida Public Utilities Company, please find the Company's Responses to Staff's First Data Requests.

Should you have any questions whatsoever, please do not hesitate to contact me. Thank you for your assistance in this matter.

Sincerely,



Beth Keating
Gunster, Yoakley & Stewart, P.A.
215 South Monroe St., Suite 618
Tallahassee, FL 32301
(850) 521-1706

MEK

Cc:// (PSC Engineering – Buys, Ramos, King)

Docket No. 20240000-OT - Florida Public Utilities Company's 2023 Storm Protection Plan Annual Status Report

Florida Public Utilities Company's Responses to Staff's First Data Request
(2023 SPP Status Report)

1. Is the transmission system on a four year vegetation management cycle similar to the distribution feeder and laterals cycle?

Company Response:

The majority of the FPUC 69 KV transmission system runs along the same right of way as the distribution system, which allows that part of the transmission system to be trimmed on the four-year trim cycle along with the associated distribution system. The 138 KV transmission system, which provides service to Amelia Island is typically trimmed on a four-year cycle but is monitored on an annual basis in order to address any conditions that may impact the reliability of the transmission system.