



Stephanie A. Cuello
SENIOR COUNSEL

June 28, 2024

VIA ELECTRONIC FILING

Adam J. Teitzman, Commission Clerk
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399-0850

Re: *Fuel and Purchased Power Clause with Generating Performance Incentive
Factor; Performance Data Report for May 2024; Docket No. 20240001-EI*

Dear Mr. Teitzman:

Attached for electronic filing in the above-referenced Docket is Duke Energy Florida, LLC's Performance Data Report for May 2024.

Thank you for your assistance in this matter and if you have any questions, please feel free to contact me at (850) 521-1425.

Sincerely,

/s/ Stephanie A. Cuello

Stephanie A. Cuello

SAC/vr
Attachment

CERTIFICATE OF SERVICE

Docket No. 20240001-EI

I HEREBY CERTIFY that a true and correct copy of the foregoing has been furnished via electronic mail to the following this 28th day of June, 2024.

/s/ Stephanie A. Cuello

Stephanie A. Cuello

<p>Suzanne Brownless Ryan Sandy Office of General Counsel FL Public Service Commission 2540 Shumard Oak Blvd. Tallahassee, FL 32399-0850 sbrownle@psc.state.fl.us rsandy@psc.state.fl.us</p> <p>J. Wahlen / M. Means / V. Ponder Ausley McMullen Tampa Electric Company P.O. Box 391 Tallahassee, FL 32302 jwahlen@ausley.com mmeans@ausley.com vponder@ausley.com</p> <p>Kenneth A. Hoffman Florida Power & Light Company 134 W. Jefferson Street Tallahassee, FL 32301-1713 ken.hoffman@fpl.com</p> <p>Jon C. Moyle, Jr. Moyle Law Firm, P.A. FIPUG 118 North Gadsden Street Tallahassee, FL 32301 jmoyle@moylelaw.com mqualls@moylelaw.com</p>	<p>W.Trierweiler / P. Christensen / C. Rehwinkel / M. Wessling / O. Ponce/ A. Watrous Office of Public Counsel 111 W. Madison St., Room 812 Tallahassee, FL 32399-1400 trierweiler.walt@leg.state.fl.us christensen.patty@leg.state.fl.us rehwinkel.charles@leg.state.fl.us wessling.mary@leg.state.fl.us ponce.octavio@leg.state.fl.us watrous.austin@leg.state.fl.us</p> <p>Paula K. Brown Regulatory Affairs Tampa Electric Company P.O. Box 111 Tampa, FL 33601-0111 regdept@tecoenergy.com</p> <p>Maria Moncada / David Lee Florida Power & Light Company 700 Universe Blvd. (LAW/JB) Juno Beach, FL 33408-0420 maria.moncada@fpl.com david.lee@fpl.com</p>	<p>Mike Cassel Florida Public Utilities Company 208 Wildlight Avenue Yulee, FL 32097 mcassel@fpuc.com</p> <p>Michelle D. Napier Florida Public Utilities Company 1635 Meathe Drive West Palm Beach, FL 33411 mnapier@fpuc.com</p> <p>Beth Keating Gunster, Yoakley & Stewart, P.A. FPUC 215 South Monroe Street, Suite 601 Tallahassee, FL 32301 bkeating@gunster.com</p> <p>James W. Brew / Laura Wynn Baker / Sarah B. Newman Stone Mattheis Xenopoulos & Brew, P.C. PCS Phosphate –White Springs 1025 Thomas Jefferson Street, NW Eighth Floor, West Tower Washington, DC 20007 jbrew@smxblaw.com lwb@smxblaw.com sbn@smxblaw.com</p> <p>Peter J. Mattheis / Michael K. Lavanga / Joseph R. Briscar Stone Mattheis Xenopoulos & Brew, PC NUCOR 1025 Thomas Jefferson Street, NW Eighth Floor, West Tower Washington, DC 20007 pjm@smxblaw.com mkl@smxblaw.com jrb@smxblaw.com</p>
--	--	--

Duke Energy

ACTUAL UNIT PERFORMANCE DATA - YEAR 2024

Bartow CC	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-24	Nov-24	Dec-24	Jan - May Period
1. EAF	88.14	97.04	72.93	81.58	98.37	0.00	0.00	0.00	0.00	0.00	0.00	0.00	87.53
2. PH	744.0	696.0	743.0	720.0	744.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3,647.0
3. SH	577.2	572.7	518.9	557.3	721.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2,947.8
4. RSH	88.7	102.7	60.4	49.0	14.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	314.8
5. UH	78.2	20.6	163.7	113.7	8.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	384.4
6. POH	0.0	0.0	147.7	103.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	250.7
7. FOH	41.8	0.1	1.9	1.7	1.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	46.8
8. MOH	36.4	20.5	14.2	8.9	6.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	86.9
9. PPOH	0.0	0.0	334.5	246.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	581.3
10. LR PP (MW)	0.0	0.0	98.0	76.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	88.6
11. PFOH	44.6	0.0	5.8	0.0	28.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	79.1
12. LR PF (MW)	177.0	0.0	126.9	0.0	122.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	153.6
13. PMOH	43.4	0.0	46.3	19.8	11.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	121.1
14. LR PM (MW)	76.0	0.0	175.0	113.7	76.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	120.1
15. NSC (MW)	1,112.00	1,112.00	1,112.00	1,112.00	1,112.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1,112.00
16. OPER MBTU	3,747,910	3,785,240	2,856,110	3,402,820	5,107,740	0	0	0	0	0	0	0	18,899,820
17. NET GEN (MWH)	473,834	502,383	368,136	443,141	681,561	0	0	0	0	0	0	0	2,469,055
18. ANOHR (BTU/KWH)	7,909.8	7,534.6	7,758.3	7,678.9	7,494.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	7,654.7
19. NOF %	73.83	78.88	63.80	71.51	84.93	0.00	0.00	0.00	0.00	0.00	0.00	0.00	75.32
20. NPC (MW)	1,112.00	1,112.00	1,112.00	1,112.00	1,112.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1,112.00

Duke Energy

ACTUAL UNIT PERFORMANCE DATA - YEAR 2024

Citrus County Power Block 1	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-24	Nov-24	Dec-24	Jan - May Period
1. EAF	100.00	26.11	97.15	96.42	97.71	0.00	0.00	0.00	0.00	0.00	0.00	0.00	84.14
2. PH	744.0	696.0	743.0	720.0	744.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3,647.0
3. SH	744.0	185.7	721.8	701.2	744.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3,096.8
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5. UH	0.0	510.3	21.2	18.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	550.2
6. POH	0.0	484.1	12.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	496.7
7. FOH	0.0	14.1	5.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	19.5
8. MOH	0.0	12.1	3.1	18.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	34.0
9. PPOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10. LR PP (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11. PFOH	0.0	13.2	0.0	0.0	264.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	277.4
12. LR PF (MW)	0.0	90.5	0.0	0.0	52.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	53.8
13. PMOH	0.0	13.0	0.0	25.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	37.9
14. LR PM (MW)	0.0	157.0	0.0	227.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	203.1
15. NSC (MW)	807.00	807.00	807.00	807.00	807.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	807.00
16. OPER MBTU	4,009,430	916,550	3,838,340	3,530,670	3,667,310	0	0	0	0	0	0	0	15,962,300
17. NET GEN (MWH)	588,695	128,801	558,488	513,984	538,287	0	0	0	0	0	0	0	2,328,255
18. ANOHR (BTU/KWH)	6,810.7	7,116.0	6,872.7	6,869.2	6,812.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	6,855.9
19. NOF %	98.05	85.94	95.87	90.83	89.65	0.00	0.00	0.00	0.00	0.00	0.00	0.00	93.16
20. NPC (MW)	807.00	807.00	807.00	807.00	807.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	807.00

Duke Energy

ACTUAL UNIT PERFORMANCE DATA - YEAR 2024

Citrus County Power Block 2	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-24	Nov-24	Dec-24	Jan - May Period
1. EAF	99.89	92.60	93.48	99.88	100.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	97.21
2. PH	744.0	696.0	743.0	720.0	744.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3,647.0
3. SH	743.4	646.0	704.4	719.4	744.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3,557.2
4. RSH	0.0	11.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	11.3
5. UH	0.6	38.7	38.6	0.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	78.5
6. POH	0.0	38.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	38.7
7. FOH	0.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.6
8. MOH	0.0	0.0	38.6	0.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	39.2
9. PPOH	0.0	66.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	66.3
10. LR PP (MW)	0.0	155.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	155.0
11. PFOH	1.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0
12. LR PF (MW)	140.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	140.4
13. PMOH	0.0	0.0	51.2	0.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	52.0
14. LR PM (MW)	0.0	0.0	155.0	200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	155.7
15. NSC (MW)	803.00	803.00	803.00	803.00	803.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	803.00
16. OPER MBTU	4,037,200	3,347,450	3,692,860	3,692,820	3,868,660	0	0	0	0	0	0	0	18,638,990
17. NET GEN (MWH)	599,338	501,735	541,860	540,662	567,905	0	0	0	0	0	0	0	2,751,500
18. ANOHR (BTU/KWH)	6,736.1	6,671.7	6,815.2	6,830.2	6,812.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	6,774.1
19. NOF %	100.40	96.72	95.79	93.60	95.06	0.00	0.00	0.00	0.00	0.00	0.00	0.00	96.33
20. NPC (MW)	803.00	803.00	803.00	803.00	803.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	803.00

Duke Energy

ACTUAL UNIT PERFORMANCE DATA - YEAR 2024

Crystal River 4	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-24	Nov-24	Dec-24	Jan - May Period
1. EAF	68.35	0.00	52.77	87.87	81.20	0.00	0.00	0.00	0.00	0.00	0.00	0.00	58.61
2. PH	744.0	696.0	743.0	720.0	744.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3,647.0
3. SH	211.0	0.0	413.5	717.0	744.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2,085.5
4. RSH	300.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	300.0
5. UH	233.0	696.0	329.5	3.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1,261.5
6. POH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
7. FOH	119.0	0.0	0.0	3.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	122.0
8. MOH	114.0	696.0	329.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1,139.5
9. PPOH	0.0	0.0	3.2	224.6	744.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	971.8
10. LR PP (MW)	0.0	0.0	161.0	125.5	112.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	115.3
11. PFOH	5.0	0.0	128.5	53.0	145.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	331.5
12. LR PF (MW)	355.0	0.0	114.6	429.0	112.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	167.3
13. PMOH	0.0	0.0	0.0	19.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	19.0
14. LR PM (MW)	0.0	0.0	0.0	481.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	481.7
15. NSC (MW)	712.00	712.00	712.00	712.00	712.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	712.00
16. OPER MBTU	738,490	0	1,440,030	2,445,110	2,944,010	0	0	0	0	0	0	0	7,567,640
17. NET GEN (MWH)	64,473	0	127,094	209,654	269,832	0	0	0	0	0	0	0	671,053
18. ANOHR (BTU/KWH)	11,454.3	0.0	11,330.4	11,662.6	10,910.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	11,277.3
19. NOF %	42.92	0.00	43.17	41.07	50.94	0.00	0.00	0.00	0.00	0.00	0.00	0.00	45.19
20. NPC (MW)	712.00	712.00	712.00	712.00	712.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	712.00

Duke Energy

ACTUAL UNIT PERFORMANCE DATA - YEAR 2024

Crystal River 5	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-24	Nov-24	Dec-24	Jan - May Period
1. EAF	79.68	54.71	0.00	0.00	4.88	0.00	0.00	0.00	0.00	0.00	0.00	0.00	27.69
2. PH	744.0	696.0	743.0	720.0	744.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3,647.0
3. SH	598.0	363.0	0.0	0.0	36.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	997.3
4. RSH	0.0	21.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	21.0
5. UH	146.0	312.0	743.0	720.0	707.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2,628.7
6. POH	0.0	312.0	743.0	720.0	416.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2,191.9
7. FOH	0.0	0.0	0.0	0.0	186.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	186.9
8. MOH	146.0	0.0	0.0	0.0	103.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	249.9
9. PPOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10. LR PP (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11. PFOH	61.0	17.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	78.5
12. LR PF (MW)	59.1	128.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	74.5
13. PMOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
14. LR PM (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
15. NSC (MW)	698.00	698.00	698.00	698.00	698.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	698.00
16. OPER MBTU	2,675,010	1,522,600	0	0	98,080	0	0	0	0	0	0	0	4,295,690
17. NET GEN (MWH)	261,565	140,334	0	0	5,087	0	0	0	0	0	0	0	406,986
18. ANOHR (BTU/KWH)	10,226.9	10,849.8	0.0	0.0	19,280.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	10,554.9
19. NOF %	62.66	55.38	0.00	0.00	20.08	0.00	0.00	0.00	0.00	0.00	0.00	0.00	58.46
20. NPC (MW)	698.00	698.00	698.00	698.00	698.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	698.00

Duke Energy

ACTUAL UNIT PERFORMANCE DATA - YEAR 2024

Hines Power Block 1	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-24	Nov-24	Dec-24	Jan - May Period
1. EAF	96.68	73.90	96.72	90.46	99.56	0.00	0.00	0.00	0.00	0.00	0.00	0.00	91.70
2. PH	744.0	696.0	743.0	720.0	744.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3,647.0
3. SH	719.3	514.4	718.6	652.8	740.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3,345.8
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5. UH	24.7	181.6	24.4	67.2	3.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	301.2
6. POH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
7. FOH	24.7	0.0	10.0	67.2	3.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	105.1
8. MOH	0.0	181.6	14.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	196.0
9. PPOH	0.0	0.0	0.0	7.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	7.5
10. LR PP (MW)	0.0	0.0	0.0	100.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	100.2
11. PFOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12. LR PF (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
13. PMOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
14. LR PM (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
15. NSC (MW)	501.00	501.00	501.00	501.00	501.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	501.00
16. OPER MBTU	2,033,310	1,499,230	2,030,270	1,703,140	2,141,340	0	0	0	0	0	0	0	9,407,290
17. NET GEN (MWH)	276,638	207,444	273,095	224,605	290,747	0	0	0	0	0	0	0	1,272,529
18. ANOHR (BTU/KWH)	7,350.1	7,227.2	7,434.3	7,582.8	7,365.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	7,392.6
19. NOF %	76.76	80.50	75.86	68.67	78.34	0.00	0.00	0.00	0.00	0.00	0.00	0.00	75.91
20. NPC (MW)	501.00	501.00	501.00	501.00	501.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	501.00

Duke Energy

ACTUAL UNIT PERFORMANCE DATA - YEAR 2024

Hines Power Block 3	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-24	Nov-24	Dec-24	Jan - May Period
1. EAF	98.26	99.73	67.83	98.43	99.88	0.00	0.00	0.00	0.00	0.00	0.00	0.00	92.71
2. PH	744.0	696.0	743.0	720.0	744.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3,647.0
3. SH	687.1	696.0	408.0	586.0	744.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3,121.1
4. RSH	43.9	0.0	96.0	122.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	262.6
5. UH	13.0	0.0	239.0	11.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	263.3
6. POH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
7. FOH	13.0	0.0	0.0	11.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	24.3
8. MOH	0.0	0.0	239.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	239.0
9. PPOH	0.0	11.7	0.0	0.0	8.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	19.7
10. LR PP (MW)	0.0	83.8	0.0	0.0	59.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	73.8
11. PFOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12. LR PF (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
13. PMOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
14. LR PM (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
15. NSC (MW)	523.00	523.00	523.00	523.00	523.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	523.00
16. OPER MBTU	2,048,530	2,192,430	1,242,030	1,687,420	2,312,200	0	0	0	0	0	0	0	9,482,610
17. NET GEN (MWH)	285,741	305,145	174,063	232,737	322,822	0	0	0	0	0	0	0	1,320,508
18. ANOHR (BTU/KWH)	7,169.2	7,184.9	7,135.5	7,250.3	7,162.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	7,181.0
19. NOF %	79.51	83.83	81.57	75.94	82.96	0.00	0.00	0.00	0.00	0.00	0.00	0.00	80.90
20. NPC (MW)	523.00	523.00	523.00	523.00	523.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	523.00

Duke Energy

ACTUAL UNIT PERFORMANCE DATA - YEAR 2024

Hines Power Block 4	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-24	Nov-24	Dec-24	Jan - May Period
1. EAF	24.92	0.00	35.33	94.27	97.29	0.00	0.00	0.00	0.00	0.00	0.00	0.00	50.74
2. PH	744.0	696.0	743.0	720.0	744.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3,647.0
3. SH	185.4	0.0	262.2	676.6	727.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1,851.8
4. RSH	0.0	0.0	1.0	2.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3.4
5. UH	558.6	696.0	479.8	41.0	16.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1,791.8
6. POH	388.3	696.0	477.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1,562.1
7. FOH	35.5	0.0	2.0	4.6	6.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	48.1
8. MOH	134.8	0.0	0.0	36.5	10.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	181.7
9. PPOH	0.0	0.0	58.3	0.0	9.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	67.3
10. LR PP (MW)	0.0	0.0	6.7	0.0	54.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	13.1
11. PFOH	0.0	0.0	0.0	0.0	6.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	6.1
12. LR PF (MW)	0.0	0.0	0.0	0.0	85.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	85.0
13. PMOH	0.0	0.0	0.0	1.3	10.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	12.2
14. LR PM (MW)	0.0	0.0	0.0	89.6	85.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	85.5
15. NSC (MW)	525.00	525.00	525.00	525.00	525.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	525.00
16. OPER MBTU	568,280	0	660,740	2,002,050	2,282,990	0	0	0	0	0	0	0	5,514,060
17. NET GEN (MWH)	79,649	0	91,913	284,186	322,865	0	0	0	0	0	0	0	778,613
18. ANOHR (BTU/KWH)	7,134.8	0.0	7,188.8	7,044.9	7,071.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	7,081.9
19. NOF %	81.82	0.00	66.76	80.00	84.53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	80.09
20. NPC (MW)	525.00	525.00	525.00	525.00	525.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	525.00

Duke Energy

ACTUAL UNIT PERFORMANCE DATA - YEAR 2024

Osprey CC	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-24	Nov-24	Dec-24	Jan - May Period
1. EAF	52.55	95.36	93.51	0.00	80.48	0.00	0.00	0.00	0.00	0.00	0.00	0.00	64.39
2. PH	744.0	696.0	743.0	720.0	744.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3,647.0
3. SH	270.0	574.5	550.0	0.0	555.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1,950.3
4. RSH	120.9	96.6	144.8	0.0	43.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	405.4
5. UH	353.1	24.8	48.2	720.0	145.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1,291.3
6. POH	0.0	0.0	48.0	720.0	144.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	912.0
7. FOH	353.1	0.0	0.2	0.0	1.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	354.4
8. MOH	0.0	24.8	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	24.9
9. PPOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10. LR PP (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11. PFOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12. LR PF (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
13. PMOH	0.0	34.4	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	34.5
14. LR PM (MW)	0.0	131.0	0.0	0.0	169.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	131.1
15. NSC (MW)	606.00	606.00	606.00	606.00	606.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	606.00
16. OPER MBTU	700,660	1,601,950	1,388,650	0	1,631,010	0	0	0	0	0	0	0	5,322,270
17. NET GEN (MWH)	89,359	215,615	187,259	0	216,224	0	0	0	0	0	0	0	708,457
18. ANOHR (BTU/KWH)	7,841.0	7,429.7	7,415.7	0.0	7,543.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	7,512.5
19. NOF %	54.61	61.93	56.18	0.00	64.21	0.00	0.00	0.00	0.00	0.00	0.00	0.00	59.94
20. NPC (MW)	606.00	606.00	606.00	606.00	606.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	606.00

Duke Energy Florida

ACTUAL UNIT EVENT DATA - January to May 2024

Bartow CC

Unit	Date	Outage Type	Hours	MW Affected	Description
BCC 4A	12/31/2023	FMO	57.10	181.0	GAS TURBINE VIBRATION
BCC 4A	1/3/2024	FMO	23.88	181.0	GAS TURBINE VIBRATION
BCC 4A	1/9/2024	FFO	40.58	181.0	FLASHBACK INCLUDING INSTRUMENTATION
BCC 4A	1/11/2024	FFO	152.10	181.0	FLASHBACK INCLUDING INSTRUMENTATION
BCC 4A	2/4/2024	FFO	0.52	181.0	OTHER SWITCHYARD EQUIPMENT – EXTERNAL (NOT OMC)
BCC 4A	2/14/2024	FMO	1.17	181.0	FUEL PIPING AND VALVES
BCC 4A	2/21/2024	FMO	48.65	181.0	OTHER CONTROLS AND INSTRUMENTATION PROBLEMS
BCC 4A	3/15/2024	FFO	7.75	181.0	GAS FUEL SYSTEM INCLUDING CONTROLS AND INSTRUMENTATION
BCC 4A	3/17/2024	FMO	87.20	181.0	OTHER MISCELLANEOUS GAS TURBINE PROBLEMS
BCC 4A	4/4/2024	FMO	21.02	181.0	AC CIRCUIT BREAKERS
BCC 4A	4/29/2024	FMO	75.88	181.0	INLET AIR FILTERS
BCC 4A	5/4/2024	FFO	0.48	181.0	FUEL PIPING AND VALVES
BCC 4B	1/22/2024	FFO	70.23	165.0	GENERATOR VOLTAGE CONTROL
BCC 4B	3/1/2024	PO	205.32	165.0	BOROSCOPE INSPECTION
BCC 4B	3/12/2024	FFO	4.13	165.0	BLADE PATH TEMPERATURE SPREAD
BCC 4C	2/19/2024	FMO	16.40	181.0	GAS TURBINE PERFORMANCE TESTING
BCC 4C	3/1/2024	PO	1,353.15	181.0	MAJOR OVERHAUL
BCC 4C	4/28/2024	FFO	1.03	181.0	LUBE OIL PUMPS
BCC 4C	5/8/2024	FFO	7.80	181.0	LUBE OIL PUMPS
BCC 4D	2/13/2024	FMO	2.43	183.0	FUEL PIPING AND VALVES
BCC 4D	2/26/2024	FMO	56.75	183.0	NERC RELIABILITY STANDARD REQUIREMENT
BCC 4S	1/12/2024	PFO	123.37	177.0	REHEAT STOP VALVES
BCC 4S	1/22/2024	FMO	64.18	402.0	HP EXTRACTION STEAM PIPING
BCC 4S	1/25/2024	PMO	120.00	76.0	FEEDWATER PUMP
BCC 4S	3/1/2024	PPO	205.32	175.0	BOROSCOPE INSPECTION
BCC 4S	3/1/2024	PPO	1,402.55	76.0	MAJOR OVERHAUL
BCC 4S	3/12/2024	PFO	4.13	175.0	BLADE PATH TEMPERATURE SPREAD
BCC 4S	3/15/2024	PFO	7.75	76.0	GAS FUEL SYSTEM INCLUDING CONTROLS AND INSTRUMENTATION
BCC 4S	3/17/2024	PMO	87.20	175.0	OTHER MISCELLANEOUS GAS TURBINE PROBLEMS
BCC 4S	3/21/2024	PFO	4.08	175.0	400-700-VOLT TRANSFORMERS
BCC 4S	3/25/2024	PMO	41.00	175.0	CONDENSER TUBE CLEANING SYSTEM INCLUDING DEBRIS FILTER
BCC 4S	4/4/2024	PMO	20.85	175.0	AC CIRCUIT BREAKERS
BCC 4S	4/16/2024	FFO	4.27	402.0	DCS - HARDWARE PROBLEMS
BCC 4S	4/29/2024	PMO	75.88	76.0	INLET AIR FILTERS
BCC 4S	5/6/2024	PFO	42.08	76.0	FEEDWATER PUMP
BCC 4S	5/28/2024	PFO	37.47	175.0	CONDENSER TUBE LEAK

Duke Energy Florida

ACTUAL UNIT EVENT DATA - January to May 2024

Citrus County Power Block 1

Unit	Date	Outage Type	Hours	MW Affected	Description
CITR 1A	2/4/2024	PFO	20.80	91.0	OPERATOR ERROR
CITR 1A	2/5/2024	FFO	3.78	243.0	CONTROL VALVES
CITR 1A	2/8/2024	PO	505.32	243.0	GENERAL UNIT INSPECTION
CITR 1A	2/29/2024	FMO	18.35	243.0	DIFFERENTIAL EXPANSION
CITR 1B	2/3/2024	FMO	32.32	242.0	ECONOMIZER PIPING
CITR 1B	2/4/2024	PFO	23.27	90.0	OPERATOR ERROR
CITR 1B	2/9/2024	PO	522.72	242.0	GENERAL UNIT INSPECTION
CITR 1B	4/22/2024	FMO	62.57	242.0	OTHER HIGH PRESSURE PROBLEMS
CITR ST1	2/3/2024	PMO	32.52	157.0	ECONOMIZER PIPING
CITR ST1	2/4/2024	FFO	20.45	322.0	OPERATOR ERROR
CITR ST1	2/5/2024	FFO	2.17	322.0	OTHER TURBINE VALVES
CITR ST1	2/9/2024	PO	470.75	322.0	GENERAL UNIT INSPECTION
CITR ST1	2/29/2024	FFO	23.38	322.0	DIFFERENTIAL EXPANSION
CITR ST1	4/22/2024	PMO	62.57	227.0	OTHER HIGH PRESSURE PROBLEMS
CITR ST1	5/4/2024	PFO	662.00	52.0	REHEAT STEAM PIPING UP TO TURBINE STOP VALVES

Duke Energy Florida

ACTUAL UNIT EVENT DATA - January to May 2024

Citrus County Power Block 2

Unit	Date	Outage Type	Hours	MW Affected	Description
CITR 2A	1/1/2024	FFO	2.08	241.0	GAS FUEL SYSTEM INCLUDING CONTROLS AND INSTRUMENTATION
CITR 2A	3/9/2024	FMO	128.45	241.0	BLOWDOWN SYSTEM VALVES
CITR 2B	2/4/2024	PO	128.48	242.0	HRSG - REFRACTORY & INSULATION
CITR 2B	4/22/2024	FMO	2.13	242.0	OTHER MISCELLANEOUS GENERATOR PROBLEMS
CITR ST2	1/1/2024	PFO	2.43	140.4	OTHER FUEL SYSTEM PROBLEMS
CITR ST2	2/2/2024	PPO	166.48	155.0	ECONOMIZER PIPING
CITR ST2	3/9/2024	PMO	128.45	155.0	BLOWDOWN SYSTEM VALVES
CITR ST2	4/22/2024	PMO	2.13	200.0	OTHER MISCELLANEOUS GENERATOR PROBLEMS

Duke Energy Florida

ACTUAL UNIT EVENT DATA - January to May 2024

Crystal River 4

Date	Outage Type	Hours	MW Affected	Description
1/13/2024	FFO	119.00	712.0	REHEAT STOP VALVES
1/22/2024	PFO	5.00	355.0	FEEDWATER VALVES (NOT FEEDWATER REGULATING VALVE)
1/27/2024	FMO	324.00	712.0	OTHER MISCELLANEOUS BALANCE OF PLANT PROBLEMS
2/9/2024	FMO	815.50	712.0	OTHER MISCELLANEOUS BOILER AIR AND GAS SYSTEM PROBLEMS
3/16/2024	PFO	7.00	62.0	PULVERIZER EXHAUSTER FAN
3/19/2024	PPO	3.23	161.0	PRIMARY AIR DUCT AND DAMPERS
3/20/2024	PFO	2.00	453.0	OIL AND GAS FIRES
3/22/2024	PFO	119.50	112.0	PULVERIZER MILLS
4/4/2024	PMO	12.00	537.0	HEATER DRAIN PUMPS
4/19/2024	PFO	53.00	429.0	FORCED DRAFT FAN CONTROLS
4/22/2024	PPO	959.00	112.0	PULVERIZER MILLS
4/22/2024	PPO	6.55	429.0	FORCED DRAFT FAN CONTROLS
4/23/2024	PPO	3.00	429.0	BURNERS
4/23/2024	FFO	3.00	712.0	OTHER PULVERIZER PROBLEMS
4/25/2024	PMO	7.00	387.0	FORCED DRAFT FANS
5/19/2024	PFO	145.00	112.0	PULVERIZER FEEDERS

Duke Energy Florida

ACTUAL UNIT EVENT DATA - January to May 2024

Crystal River 5

Date	Outage Type	Hours	MW Affected	Description
1/1/2024	PFO	5.00	74.0	OTHER MISCELLANEOUS BOILER AIR AND GAS SYSTEM PROBLEMS
1/6/2024	FMO	146.00	698.0	SOOT BLOWERS - STEAM
1/16/2024	PFO	2.00	147.0	OTHER SLAG AND ASH REMOVAL PROBLEMS
1/22/2024	PFO	50.00	51.0	BOILER WATER CONDITION
1/29/2024	PFO	4.00	98.0	PRIMARY AIR FAN DRIVES
2/11/2024	PFO	4.00	128.0	PRIMARY AIR FAN DRIVES
2/14/2024	PFO	13.50	128.0	INDUCED DRAFT FANS
2/17/2024	PO	2,191.87	698.0	IP TURBINE - BUCKETS OR BLADES
5/18/2024	FFO	11.07	698.0	OTHER MISCELLANEOUS STEAM TURBINE PROBLEMS
5/19/2024	FFO	6.22	698.0	IP TURBINE - BUCKETS OR BLADES
5/19/2024	FFO	169.65	698.0	UNIT AUXILIARIES TRANSFORMER
5/27/2024	FMO	9.80	698.0	LP TURBINE - INNER CASING
5/28/2024	FMO	94.10	698.0	OTHER LOW PRESSURE TURBINE PROBLEMS

Duke Energy Florida

ACTUAL UNIT EVENT DATA - January to May 2024

Hines Power Block 1

Unit	Date	Outage Type	Hours	MW Affected	Description
HEP 1A	1/11/2024	FFO	74.03	167.0	EMERGENCY GENERATOR TRIP DEVICES
HEP 1A	2/22/2024	FMO	190.50	167.0	TRANSMISSION SYSTEM PROBLEM
HEP 1A	4/5/2024	PPO	7.75	87.0	CONDENSER TUBE CLEANING SYSTEM INCLUDING DEBRIS FILTER
HEP 1A	4/8/2024	FFO	20.42	167.0	CONDENSATE/HOTWELL PUMPS
HEP 1A	4/18/2024	FFO	5.17	167.0	OTHER MISCELLANEOUS STEAM TURBINE PROBLEMS
HEP 1A	4/19/2024	FFO	9.50	167.0	OTHER MISCELLANEOUS STEAM TURBINE PROBLEMS
HEP 1A	4/19/2024	FFO	14.93	167.0	OTHER MISCELLANEOUS STEAM TURBINE PROBLEMS
HEP 1A	4/20/2024	FFO	3.82	167.0	OTHER COLD REHEAT STEAM VALVES
HEP 1B	2/22/2024	FMO	202.92	167.0	HIGH PRESSURE HEATER TUBE LEAKS
HEP 1B	3/7/2024	FFO	30.00	167.0	GENERATOR CURRENT AND POTENTIAL TRANSFORMERS
HEP 1B	4/4/2024	FFO	19.82	167.0	EMERGENCY GENERATOR TRIP DEVICES
HEP 1B	4/5/2024	PPO	6.88	87.0	CONDENSER TUBE CLEANING SYSTEM INCLUDING DEBRIS FILTER
HEP 1B	4/18/2024	FFO	47.67	167.0	OTHER MISCELLANEOUS STEAM TURBINE PROBLEMS
HEP 1B	4/20/2024	FFO	38.10	167.0	OTHER COLD REHEAT STEAM VALVES
HEP 1B	5/28/2024	FFO	9.72	167.0	EMERGENCY GENERATOR TRIP DEVICES
HEP ST1	2/22/2024	FMO	194.72	167.0	TRANSMISSION SYSTEM PROBLEM
HEP ST1	4/5/2024	PPO	7.75	125.0	CONDENSER TUBE CLEANING SYSTEM INCLUDING DEBRIS FILTER
HEP ST1	4/18/2024	FFO	7.95	167.0	OTHER MISCELLANEOUS STEAM TURBINE PROBLEMS
HEP ST1	4/19/2024	FFO	28.12	167.0	OTHER MISCELLANEOUS STEAM TURBINE PROBLEMS
HEP ST1	4/20/2024	FFO	6.10	167.0	OTHER COLD REHEAT STEAM VALVES

Duke Energy Florida

ACTUAL UNIT EVENT DATA - January to May 2024

Hines Power Block 3

Unit	Date	Outage Type	Hours	MW Affected	Description
HEP 3A	1/16/2024	FFO	12.48	171.0	OTHER MISCELLANEOUS GAS TURBINE PROBLEMS
HEP 3A	2/20/2024	PPO	11.65	71.0	CONDENSER TUBE FOULING TUBE SIDE
HEP 3A	3/18/2024	FMO	239.00	171.0	TURBINE PERFORMANCE TESTING
HEP 3A	4/13/2024	FFO	16.00	171.0	OTHER TURBINE VALVES
HEP 3A	5/16/2024	PPO	8.00	66.0	CONDENSER TUBE FOULING TUBE SIDE
HEP 3B	1/7/2024	FFO	26.45	176.0	SCR NOX OTHER AMMONIA SYSTEM PROBLEMS
HEP 3B	2/20/2024	PPO	11.65	76.0	CONDENSER TUBE FOULING TUBE SIDE
HEP 3B	3/18/2024	FMO	239.00	176.0	TURBINE PERFORMANCE TESTING
HEP 3B	4/17/2024	FFO	2.00	176.0	OTHER TURBINE VALVES
HEP 3B	5/16/2024	PPO	8.00	71.0	CONDENSER TUBE FOULING TUBE SIDE
HEP ST3	2/20/2024	PPO	11.65	104.0	CONDENSER TUBE FOULING TUBE SIDE
HEP ST3	3/18/2024	FMO	239.00	176.0	TURBINE PERFORMANCE TESTING
HEP ST3	4/13/2024	FFO	16.00	176.0	OTHER TURBINE VALVES
HEP ST3	5/16/2024	PPO	8.00	41.0	CONDENSER TUBE FOULING TUBE SIDE

Duke Energy Florida

ACTUAL UNIT EVENT DATA - January to May 2024

Hines Power Block 4

Unit	Date	Outage Type	Hours	MW Affected	Description
HEP 4A	1/3/2024	FMO	128.10	171.0	GENERAL UNIT INSPECTION
HEP 4A	1/11/2024	PO	1,645.07	171.0	GENERAL UNIT INSPECTION
HEP 4A	3/21/2024	PO	38.00	171.0	GENERAL UNIT INSPECTION
HEP 4A	3/25/2024	PO	134.00	171.0	GENERAL UNIT INSPECTION
HEP 4A	4/5/2024	FMO	80.00	171.0	BALANCE OF PLANT OVERHAUL/OUTAGE
HEP 4A	4/8/2024	FMO	24.00	171.0	BALANCE OF PLANT OVERHAUL/OUTAGE
HEP 4A	4/9/2024	FFO	14.00	171.0	OTHER AUXILIARY STEAM PROBLEMS
HEP 4A	4/22/2024	FMO	8.00	171.0	OTHER VOLTAGE PROTECTION DEVICES
HEP 4A	5/13/2024	PPO	7.00	61.0	CONDENSER TUBE FOULING TUBE SIDE
HEP 4A	5/21/2024	FMO	32.00	171.0	OTHER IP STEAM SYSTEM PROBLEMS
HEP 4A	5/31/2024	PPO	2.00	61.0	INTAKE GRATING FOULING
HEP 4B	1/3/2024	FMO	144.02	176.0	GENERAL UNIT INSPECTION
HEP 4B	1/15/2024	FFO	22.55	176.0	OTHER HYDRAULIC SYSTEM PROBLEMS
HEP 4B	1/16/2024	FFO	30.00	176.0	TURNING GEAR AND MOTOR
HEP 4B	1/17/2024	PO	1,434.00	176.0	GENERAL UNIT INSPECTION
HEP 4B	3/31/2024	FFO	6.00	176.0	IP DRUM
HEP 4B	4/22/2024	PMO	2.00	68.0	SERVICE WATER PUMPS AND MOTORS
HEP 4B	5/13/2024	PPO	7.00	66.0	CONDENSER TUBE FOULING TUBE SIDE
HEP 4B	5/25/2024	FFO	18.00	176.0	LUBE OIL SYSTEM - GENERAL
HEP 4B	5/31/2024	PPO	2.00	61.6	INTAKE GRATING FOULING
HEP ST4	1/3/2024	FMO	131.98	178.0	GENERAL UNIT INSPECTION
HEP ST4	1/15/2024	FFO	22.75	178.0	OTHER HYDRAULIC SYSTEM PROBLEMS
HEP ST4	1/16/2024	FFO	30.00	178.0	TURNING GEAR AND MOTOR
HEP ST4	1/17/2024	PO	1,443.75	178.0	GENERAL UNIT INSPECTION
HEP ST4	3/21/2024	PPO	38.00	6.7	GENERAL UNIT INSPECTION
HEP ST4	3/25/2024	PPO	134.00	6.7	GENERAL UNIT INSPECTION
HEP ST4	4/22/2024	PMO	2.00	111.0	SERVICE WATER PUMPS AND MOTORS
HEP ST4	5/13/2024	PPO	7.00	38.0	CONDENSER TUBE FOULING TUBE SIDE
HEP ST4	5/21/2024	PMO	32.00	85.0	OTHER IP STEAM SYSTEM PROBLEMS
HEP ST4	5/25/2024	PFO	18.00	85.0	LUBE OIL SYSTEM - GENERAL
HEP ST4	5/31/2024	PPO	2.00	38.0	INTAKE GRATING FOULING

Duke Energy Florida

ACTUAL UNIT EVENT DATA - January to May 2024

Osprey CC

Unit	Date	Outage Type	Hours	MW Affected	Description
OSP CT1	12/31/2023	FFO	351.57	179.0	EMERGENCY GENERATOR TRIP DEVICES
OSP CT1	1/17/2024	FFO	0.40	179.0	GAS FUEL SYSTEM INCLUDING CONTROLS AND INSTRUMENTATION
OSP CT1	1/17/2024	FFO	1.00	179.0	GAS FUEL SYSTEM INCLUDING CONTROLS AND INSTRUMENTATION
OSP CT1	3/29/2024	PO	840.17	179.0	GENERAL UNIT INSPECTION
OSP CT1	5/4/2024	PO	71.98	179.0	GENERAL UNIT INSPECTION
OSP CT1	5/7/2024	FFO	0.63	179.0	OTHER MISCELLANEOUS GAS TURBINE PROBLEMS
OSP CT1	5/7/2024	FFO	0.48	179.0	OTHER CONTROLS AND INSTRUMENTATION PROBLEMS
OSP CT1	5/7/2024	FFO	2.85	179.0	OTHER MISCELLANEOUS GAS TURBINE PROBLEMS
OSP CT2	12/31/2023	FFO	351.57	179.0	EMERGENCY GENERATOR TRIP DEVICES
OSP CT2	1/18/2024	FFO	0.35	179.0	GAS FUEL SYSTEM INCLUDING CONTROLS AND INSTRUMENTATION
OSP CT2	1/18/2024	FFO	0.37	179.0	OTHER FUEL SYSTEM PROBLEMS
OSP CT2	1/24/2024	FFO	0.22	179.0	BLADE PATH TEMPERATURE SPREAD
OSP CT2	1/24/2024	FFO	0.13	179.0	BLADE PATH TEMPERATURE SPREAD
OSP CT2	2/4/2024	FMO	84.07	179.0	TURBINE OVERSPEED TRIP TEST - GAS TURBINE
OSP CT2	3/15/2024	FFO	0.33	179.0	BLADE PATH TEMPERATURE SPREAD
OSP CT2	3/17/2024	FFO	0.32	179.0	BLADE PATH TEMPERATURE SPREAD
OSP CT2	3/30/2024	PO	840.00	179.0	GENERAL UNIT INSPECTION
OSP CT2	5/4/2024	PO	71.98	179.0	GENERAL UNIT INSPECTION
OSP CT2	5/31/2024	FMO	0.17	179.0	BLOWDOWN SYSTEM PIPING
OSP ST1	12/31/2023	FFO	351.57	248.0	EMERGENCY GENERATOR TRIP DEVICES
OSP ST1	1/17/2024	FFO	0.40	248.0	GAS FUEL SYSTEM INCLUDING CONTROLS AND INSTRUMENTATION
OSP ST1	1/17/2024	FFO	1.45	248.0	GAS FUEL SYSTEM INCLUDING CONTROLS AND INSTRUMENTATION
OSP ST1	2/4/2024	PMO	84.07	131.0	TURBINE OVERSPEED TRIP TEST - GAS TURBINE
OSP ST1	3/30/2024	PO	839.95	248.0	GENERAL UNIT INSPECTION
OSP ST1	5/4/2024	PO	71.98	248.0	GENERAL UNIT INSPECTION
OSP ST1	5/31/2024	PMO	0.17	169.0	BLOWDOWN SYSTEM PIPING