

FLORIDA PUBLIC SERVICE COMMISSION

Item 2

VOTE SHEET

FILED 9/10/2024  
DOCUMENT NO. 08943-2024  
FPSC - COMMISSION CLERK

September 10, 2024

Docket No. 20240071-GU – Petition for approval of safety, access, and facility enhancement program modifications, by Florida City Gas.

**Issue 1:** Should the Commission approve FCG's proposed modifications to the Safety, Access, and Facility Enhancement program?

**Recommendation:** Yes, the Commission should approve FCG's proposed modifications to the SAFE program and its associated components to include: (i) replacing of span pipe; (ii) burying shallow and exposed pipelines; and (iii) replacing of obsolete pipe and related facilities. The proposed program modification should improve the safety of FCG's natural gas infrastructure and reduce risk to life and property, and is consistent with the Commission's prior Orders.


**APPROVED**

COMMISSIONERS ASSIGNED: All Commissioners

COMMISSIONERS' SIGNATURES

MAJORITY

DISSENTING



\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

REMARKS/DISSENTING COMMENTS:

Vote Sheet

September 10, 2024

Item 2

**Docket No. 20240071-GU** – Petition for approval of safety, access, and facility enhancement program modifications, by Florida City Gas.

(Continued from previous page)

**Issue 2:** Should this docket be closed?

**Recommendation:** Yes. If no protest is filed by a person whose substantial interests are affected within 21 days of the issuance of the Order, this docket should be closed upon the issuance of a Consummating Order.

**APPROVED**