



Stephanie A. Cuello
SENIOR COUNSEL

January 30, 2025

VIA ELECTRONIC FILING

Adam J. Teitzman, Commission Clerk
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399-0850

Re: *Fuel and Purchased Power Clause with Generating Performance Incentive
Factor; Performance Data Report for December 2024; Docket No. 20250001-EI*

Dear Mr. Teitzman:

Attached for electronic filing in the above-referenced Docket is Duke Energy Florida, LLC's Performance Data Report for December 2024.

Thank you for your assistance in this matter and if you have any questions, please feel free to contact me at (850) 521-1425.

Sincerely,

/s/ Stephanie A. Cuello

Stephanie A. Cuello

SAC/vr
Attachment

CERTIFICATE OF SERVICE

Docket No. 20250001-EI

I HEREBY CERTIFY that a true and correct copy of the foregoing has been furnished via electronic mail to the following this 30th day of January, 2025.

/s/ Stephanie A. Cuello

Stephanie A. Cuello

Ryan Sandy Office of General Counsel FL Public Service Commission 2540 Shumard Oak Blvd. Tallahassee, FL 32399-0850 rsandy@psc.state.fl.us J. Wahlen / M. Means / V. Ponder Ausley McMullen Tampa Electric Company P.O. Box 391 Tallahassee, FL 32302 jwahlen@ausley.com mmeans@ausley.com vponder@ausley.com Kenneth A. Hoffman Florida Power & Light Company 134 W. Jefferson Street Tallahassee, FL 32301-1713 ken.hoffman@fpl.com Jon C. Moyle, Jr. Moyle Law Firm, P.A. FIPUG 118 North Gadsden Street Tallahassee, FL 32301 jmoyle@moylelaw.com	W. Trierweiler / P. Christensen / C. Rehwinkel / M. Wessling / O. Ponce/ A. Watrous Office of Public Counsel 111 W. Madison St., Room 812 Tallahassee, FL 32399-1400 trierweiler.walt@leg.state.fl.us christensen.patty@leg.state.fl.us rehwinkel.charles@leg.state.fl.us wessling.mary@leg.state.fl.us ponce.octavio@leg.state.fl.us watrous.austin@leg.state.fl.us Paula K. Brown Regulatory Affairs Tampa Electric Company P.O. Box 111 Tampa, FL 33601-0111 regdept@tecoenergy.com Maria Moncada / David Lee Florida Power & Light Company 700 Universe Blvd. (LAW/JB) Juno Beach, FL 33408-0420 maria.moncada@fpl.com david.lee@fpl.com	Mike Cassel Florida Public Utilities Company 208 Wildlight Avenue Yulee, FL 32097 mcassel@fpuc.com Michelle D. Napier / Jowi Baugh Florida Public Utilities Company 1635 Meathe Drive West Palm Beach, FL 33411 mnapier@fpuc.com jbaugh@chpk.com Beth Keating Gunster, Yoakley & Stewart, P.A. Florida Public Utilities Company 215 South Monroe Street, Suite 601 Tallahassee, FL 32301 bkeating@gunster.com James W. Brew / Laura Wynn Baker / Sarah B. Newman Stone Mattheis Xenopoulos & Brew, P.C. PCS Phosphate –White Springs 1025 Thomas Jefferson Street, NW Eighth Floor, West Tower Washington, DC 20007 jbrew@smxblaw.com lwb@smxblaw.com sbn@smxblaw.com
--	---	---

Duke Energy

ACTUAL UNIT PERFORMANCE DATA - YEAR 2024

Bartow CC	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-24	Nov-24	Dec-24	Jan - Dec Period
1. EAF	88.14	97.04	72.93	81.58	98.37	99.90	99.86	98.57	92.51	49.45	56.37	69.60	83.63
2. PH	744.0	696.0	743.0	720.0	744.0	720.0	744.0	744.0	720.0	744.0	721.0	744.0	8,784.0
3. SH	577.2	572.7	518.9	557.3	721.7	719.4	740.7	734.2	656.8	405.2	444.4	507.1	7,155.5
4. RSH	88.7	102.7	60.4	49.0	14.1	0.0	3.3	0.0	17.1	0.0	4.0	18.2	357.4
5. UH	78.2	20.6	163.7	113.7	8.2	0.6	0.0	9.8	46.1	338.8	272.6	218.8	1,271.1
6. POH	0.0	0.0	147.7	103.1	0.0	0.0	0.0	0.0	35.9	213.0	216.5	35.0	751.1
7. FOH	41.8	0.1	1.9	1.7	1.3	0.0	0.0	7.4	4.7	125.8	56.1	166.7	407.5
8. MOH	36.4	20.5	14.2	8.9	6.8	0.6	0.0	2.4	5.6	0.0	0.0	17.0	112.6
9. PPOH	0.0	0.0	334.5	246.7	0.0	0.0	0.0	0.0	87.4	269.0	245.1	0.0	1,182.6
10. LR PP (MW)	0.0	0.0	98.0	76.0	0.0	0.0	0.0	0.0	91.7	152.7	175.0	0.0	121.3
11. PFOH	44.6	0.0	5.8	0.0	28.8	0.0	6.2	17.6	2.0	2.4	13.2	191.0	311.5
12. LR PF (MW)	177.0	0.0	126.9	0.0	122.6	0.0	76.0	37.0	69.7	175.0	288.0	38.0	79.9
13. PMOH	43.4	0.0	46.3	19.8	11.6	1.3	8.9	5.9	13.0	0.0	0.0	26.5	176.8
14. LR PM (MW)	76.0	0.0	175.0	113.7	76.0	76.0	76.0	37.0	37.0	0.0	0.0	37.0	96.2
15. NSC (MW)	1,112.00	1,112.00	1,112.00	1,112.00	1,112.00	1,112.00	1,112.00	1,112.00	1,112.00	1,112.00	1,112.00	1,112.00	1,112.00
16. OPER MBTU	3,747,910	3,785,240	2,856,110	3,402,820	5,107,740	5,199,120	5,336,790	5,267,360	4,519,810	2,381,840	2,555,840	3,533,060	47,693,640
17. NET GEN (MWH)	473,834	502,383	368,136	443,141	681,561	705,948	720,247	713,337	609,053	305,996	317,385	437,882	6,278,903
18. ANOHR (BTU/KWH)	7,909.8	7,534.6	7,758.3	7,678.9	7,494.2	7,364.7	7,409.7	7,384.1	7,421.0	7,783.9	8,052.8	8,068.5	7,595.9
19. NOF %	73.83	78.88	63.80	71.51	84.93	88.25	87.44	87.38	83.40	67.91	64.22	77.66	78.91
20. NPC (MW)	1,112.00	1,112.00	1,112.00	1,112.00	1,112.00	1,112.00	1,112.00	1,112.00	1,112.00	1,112.00	1,112.00	1,112.00	1,112.00

Duke Energy

ACTUAL UNIT PERFORMANCE DATA - YEAR 2024

Citrus County Power Block 1	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-24	Nov-24	Dec-24	Jan - Dec Period
1. EAF	100.00	26.11	97.15	96.42	98.75	83.86	100.00	100.00	99.97	99.90	100.00	89.95	91.32
2. PH	744.0	696.0	743.0	720.0	744.0	720.0	744.0	744.0	720.0	744.0	721.0	744.0	8,784.0
3. SH	744.0	185.7	721.8	701.2	744.0	603.8	744.0	744.0	720.0	744.0	721.0	684.6	8,058.2
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5. UH	0.0	510.3	21.2	18.8	0.0	116.2	0.0	0.0	0.0	0.0	0.0	59.4	725.8
6. POH	0.0	484.1	12.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	496.7
7. FOH	0.0	14.1	5.4	0.0	0.0	1.0	0.0	0.0	0.0	0.0	0.0	0.0	20.5
8. MOH	0.0	12.1	3.1	18.8	0.0	115.2	0.0	0.0	0.0	0.0	0.0	59.4	208.6
9. PPOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10. LR PP (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11. PFOH	0.0	13.2	0.0	0.0	144.8	0.0	0.0	0.0	7.8	22.3	0.8	0.0	188.9
12. LR PF (MW)	0.0	90.5	0.0	0.0	52.0	0.0	0.0	0.0	22.1	26.0	22.0	0.0	50.3
13. PMOH	0.0	13.0	0.0	25.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	78.9	116.8
14. LR PM (MW)	0.0	157.0	0.0	227.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	157.0	172.0
15. NSC (MW)	807.00	807.00	807.00	807.00	807.00	807.00	807.00	807.00	807.00	807.00	807.00	807.00	807.00
16. OPER MBTU	4,009,430	916,550	3,838,340	3,530,670	3,667,310	3,081,710	3,901,750	3,903,450	3,760,220	3,851,970	3,686,980	3,489,080	41,637,460
17. NET GEN (MWH)	588,695	128,801	558,488	513,984	538,287	446,775	568,640	568,434	546,975	563,476	545,709	505,712	6,073,976
18. ANOHR (BTU/KWH)	6,810.7	7,116.0	6,872.7	6,869.2	6,812.9	6,897.7	6,861.5	6,867.0	6,874.6	6,836.1	6,756.3	6,899.3	6,855.1
19. NOF %	98.05	85.94	95.87	90.83	89.65	91.69	94.71	94.67	94.14	93.85	93.79	91.54	93.40
20. NPC (MW)	807.00	807.00	807.00	807.00	807.00	807.00	807.00	807.00	807.00	807.00	807.00	807.00	807.00

Duke Energy

ACTUAL UNIT PERFORMANCE DATA - YEAR 2024

Citrus County Power Block 2	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-24	Nov-24	Dec-24	Jan - Dec Period
1. EAF	99.89	92.60	93.48	99.88	100.00	100.00	100.00	99.95	91.95	99.96	73.09	37.07	90.64
2. PH	744.0	696.0	743.0	720.0	744.0	720.0	744.0	744.0	720.0	744.0	721.0	744.0	8,784.0
3. SH	743.4	646.0	704.4	719.4	744.0	720.0	744.0	744.0	673.8	744.0	527.7	271.2	7,981.9
4. RSH	0.0	11.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	5.0	16.2
5. UH	0.6	38.7	38.6	0.6	0.0	0.0	0.0	0.0	46.2	0.0	193.3	467.8	785.8
6. POH	0.0	38.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	191.0	466.2	696.0
7. FOH	0.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2.3	1.6	4.5
8. MOH	0.0	0.0	38.6	0.6	0.0	0.0	0.0	0.0	46.2	0.0	0.0	0.0	85.4
9. PPOH	0.0	66.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	66.3
10. LR PP (MW)	0.0	155.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	155.0
11. PFOH	1.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	9.0	3.6	2.1	15.7
12. LR PF (MW)	140.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	16.5	147.3	155.0	72.7
13. PMOH	0.0	0.0	51.2	0.8	0.0	0.0	0.0	4.0	61.0	2.1	0.0	0.0	119.1
14. LR PM (MW)	0.0	0.0	155.0	200.0	0.0	0.0	0.0	68.5	155.0	55.2	0.0	0.0	150.7
15. NSC (MW)	803.00	803.00	803.00	803.00	803.00	803.00	803.00	803.00	803.00	803.00	803.00	803.00	803.00
16. OPER MBTU	4,037,200	3,347,450	3,692,860	3,692,820	3,868,660	3,817,610	3,942,360	3,930,540	3,395,500	3,913,110	2,715,260	1,417,970	41,771,340
17. NET GEN (MWH)	599,338	501,735	541,860	540,662	567,905	557,444	576,853	573,382	495,244	573,228	401,301	205,671	6,134,623
18. ANOHR (BTU/KWH)	6,736.1	6,671.7	6,815.2	6,830.2	6,812.2	6,848.4	6,834.3	6,855.0	6,856.2	6,826.4	6,766.1	6,894.4	6,809.1
19. NOF %	100.40	96.72	95.79	93.60	95.06	96.42	96.56	95.97	91.53	95.95	94.71	94.43	95.71
20. NPC (MW)	803.00	803.00	803.00	803.00	803.00	803.00	803.00	803.00	803.00	803.00	803.00	803.00	803.00

Duke Energy

ACTUAL UNIT PERFORMANCE DATA - YEAR 2024

Crystal River 4	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-24	Nov-24	Dec-24	Jan - Dec Period
1. EAF	68.35	0.00	52.77	87.87	81.20	90.42	96.28	60.48	83.85	0.00	1.64	39.17	55.35
2. PH	744.0	696.0	743.0	720.0	744.0	720.0	744.0	744.0	720.0	744.0	721.0	744.0	8,784.0
3. SH	211.0	0.0	413.5	717.0	744.0	720.0	744.0	461.9	603.8	0.0	40.8	426.8	5,082.7
4. RSH	300.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	270.0	570.0
5. UH	233.0	696.0	329.5	3.0	0.0	0.0	0.0	282.1	116.3	744.0	680.3	47.2	3,131.3
6. POH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
7. FOH	119.0	0.0	0.0	3.0	0.0	0.0	0.0	282.1	116.3	744.0	680.3	39.2	1,983.8
8. MOH	114.0	696.0	329.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	8.0	1,147.5
9. PPOH	0.0	0.0	3.2	224.6	744.0	382.4	6.0	0.0	0.0	0.0	0.0	0.0	1,360.2
10. LR PP (MW)	0.0	0.0	161.0	125.5	112.0	117.7	161.0	0.0	0.0	0.0	0.0	0.0	116.2
11. PFOH	5.0	0.0	128.5	53.0	145.0	151.0	279.3	72.3	0.0	0.0	41.0	652.0	1,527.2
12. LR PF (MW)	355.0	0.0	114.6	429.0	112.0	27.0	67.2	117.9	0.0	0.0	502.0	442.7	259.4
13. PMOH	0.0	0.0	0.0	19.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	19.0
14. LR PM (MW)	0.0	0.0	0.0	481.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	481.7
15. NSC (MW)	712.00	712.00	712.00	712.00	712.00	712.00	712.00	712.00	712.00	712.00	712.00	712.00	712.00
16. OPER MBTU	738,490	0	1,440,030	2,445,110	2,944,010	2,975,790	3,159,260	1,816,390	2,633,410	0	119,290	1,209,970	19,481,750
17. NET GEN (MWH)	64,473	0	127,094	209,654	269,832	280,468	287,744	156,026	240,140	0	7,315	105,560	1,748,306
18. ANOHR (BTU/KWH)	11,454.3	0.0	11,330.4	11,662.6	10,910.5	10,610.1	10,979.4	11,641.6	10,966.1	0.0	16,307.6	11,462.4	11,143.2
19. NOF %	42.92	0.00	43.17	41.07	50.94	54.71	54.32	47.44	55.86	0.00	25.21	34.74	48.31
20. NPC (MW)	712.00	712.00	712.00	712.00	712.00	712.00	712.00	712.00	712.00	712.00	712.00	712.00	712.00

Duke Energy

ACTUAL UNIT PERFORMANCE DATA - YEAR 2024

Crystal River 5	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-24	Nov-24	Dec-24	Jan - Dec Period
1. EAF	79.68	54.71	0.00	0.00	2.16	85.30	78.53	97.95	65.92	0.00	19.56	23.51	42.21
2. PH	744.0	696.0	743.0	720.0	744.0	720.0	744.0	744.0	720.0	744.0	721.0	744.0	8,784.0
3. SH	598.0	363.0	0.0	0.0	36.3	618.9	599.0	735.7	421.5	0.0	281.0	311.0	3,964.4
4. RSH	0.0	21.0	0.0	0.0	0.0	0.0	0.0	0.0	53.1	0.0	0.0	433.0	507.1
5. UH	146.0	312.0	743.0	720.0	707.7	101.1	145.0	8.3	245.4	744.0	440.0	0.0	4,312.5
6. POH	0.0	312.0	743.0	720.0	434.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2,209.2
7. FOH	0.0	0.0	0.0	0.0	263.8	101.1	0.0	0.0	125.4	744.0	440.0	0.0	1,674.2
8. MOH	146.0	0.0	0.0	0.0	9.8	0.0	145.0	8.3	120.0	0.0	0.0	0.0	429.1
9. PPOH	0.0	0.0	0.0	0.0	36.3	0.0	6.0	0.0	0.0	0.0	0.0	0.0	42.3
10. LR PP (MW)	0.0	0.0	0.0	0.0	389.3	0.0	70.0	0.0	0.0	0.0	0.0	0.0	344.0
11. PFOH	61.0	17.5	0.0	0.0	0.0	53.6	22.0	42.5	0.0	0.0	177.0	744.0	1,117.6
12. LR PF (MW)	59.1	128.0	0.0	0.0	0.0	57.4	448.0	114.2	0.0	0.0	551.9	533.9	464.0
13. PMOH	0.0	0.0	0.0	0.0	0.0	5.0	0.0	0.0	0.0	0.0	0.0	0.0	5.0
14. LR PM (MW)	0.0	0.0	0.0	0.0	0.0	48.0	0.0	0.0	0.0	0.0	0.0	0.0	48.0
15. NSC (MW)	698.00	698.00	698.00	698.00	698.00	698.00	698.00	698.00	698.00	698.00	698.00	698.00	698.00
16. OPER MBTU	2,675,010	1,522,600	0	0	98,080	2,721,690	2,657,060	2,827,350	1,793,750	0	803,660	1,115,100	16,214,300
17. NET GEN (MWH)	261,565	140,334	0	0	5,087	263,511	252,574	258,152	166,695	0	59,958	106,123	1,513,999
18. ANOHR (BTU/KWH)	10,226.9	10,849.8	0.0	0.0	19,280.5	10,328.6	10,519.9	10,952.3	10,760.7	0.0	13,403.7	10,507.6	10,709.6
19. NOF %	62.66	55.38	0.00	0.00	20.09	61.00	60.41	50.27	56.66	0.00	30.57	48.89	54.71
20. NPC (MW)	698.00	698.00	698.00	698.00	698.00	698.00	698.00	698.00	698.00	698.00	698.00	698.00	698.00

Duke Energy

ACTUAL UNIT PERFORMANCE DATA - YEAR 2024

Hines Power Block 1	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-24	Nov-24	Dec-24	Jan - Dec Period
1. EAF	96.68	73.90	96.72	90.46	99.56	99.81	98.59	99.93	82.65	99.16	96.70	35.08	89.15
2. PH	744.0	696.0	743.0	720.0	744.0	720.0	744.0	744.0	720.0	744.0	721.0	744.0	8,784.0
3. SH	719.3	514.4	718.6	652.8	740.8	720.0	744.0	744.0	595.1	727.9	697.3	0.0	7,574.2
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	16.1	0.0	261.0	277.1
5. UH	24.7	181.6	24.4	67.2	3.2	0.0	0.0	0.0	124.9	0.0	23.7	483.0	932.7
6. POH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
7. FOH	24.7	0.0	10.0	67.2	3.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	105.1
8. MOH	0.0	181.6	14.4	0.0	0.0	0.0	0.0	0.0	124.9	0.0	23.7	483.0	827.6
9. PPOH	0.0	0.0	0.0	7.5	0.0	7.0	8.2	2.9	0.0	32.5	0.8	0.0	58.7
10. LR PP (MW)	0.0	0.0	0.0	100.2	0.0	99.7	90.0	87.0	0.0	96.0	100.7	0.0	95.7
11. PFOH	0.0	0.0	0.0	0.0	0.0	0.0	48.8	0.0	0.0	0.0	0.0	0.0	48.8
12. LR PF (MW)	0.0	0.0	0.0	0.0	0.0	0.0	93.0	0.0	0.0	0.0	0.0	0.0	93.0
13. PMOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
14. LR PM (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
15. NSC (MW)	501.00	501.00	501.00	501.00	501.00	501.00	501.00	501.00	501.00	501.00	501.00	501.00	501.00
16. OPER MBTU	2,033,310	1,499,230	2,030,270	1,703,140	2,141,340	2,212,100	2,163,600	2,243,990	1,754,150	2,050,120	1,974,970	0	21,806,220
17. NET GEN (MWH)	276,638	207,444	273,095	224,605	290,747	301,945	288,976	307,045	234,348	272,932	265,235	0	2,943,010
18. ANOHR (BTU/KWH)	7,350.1	7,227.2	7,434.3	7,582.8	7,365.0	7,326.2	7,487.1	7,308.3	7,485.2	7,511.5	7,446.1	0.0	7,409.5
19. NOF %	76.76	80.50	75.86	68.67	78.34	83.71	77.53	82.37	78.61	74.84	75.92	0.00	77.56
20. NPC (MW)	501.00	501.00	501.00	501.00	501.00	501.00	501.00	501.00	501.00	501.00	501.00	501.00	501.00

Duke Energy

ACTUAL UNIT PERFORMANCE DATA - YEAR 2024

Hines Power Block 3	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-24	Nov-24	Dec-24	Jan - Dec Period
1. EAF	98.26	99.73	67.83	98.43	99.88	99.89	99.13	97.46	86.32	92.85	100.00	99.20	94.88
2. PH	744.0	696.0	743.0	720.0	744.0	720.0	744.0	744.0	720.0	744.0	721.0	744.0	8,784.0
3. SH	687.1	696.0	408.0	586.0	744.0	720.0	740.6	723.4	710.1	676.9	721.0	743.0	8,156.2
4. RSH	43.9	0.0	96.0	122.7	0.0	0.0	0.0	1.8	2.7	55.4	0.0	0.0	322.5
5. UH	13.0	0.0	239.0	11.3	0.0	0.0	3.4	18.8	7.2	11.8	0.0	1.0	305.3
6. POH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
7. FOH	13.0	0.0	0.0	11.3	0.0	0.0	3.4	0.0	0.0	0.0	0.0	1.0	28.6
8. MOH	0.0	0.0	239.0	0.0	0.0	0.0	0.0	18.8	7.2	11.8	0.0	0.0	276.7
9. PPOH	0.0	11.7	0.0	0.0	8.0	8.0	22.8	1.0	639.0	236.2	0.0	0.0	926.6
10. LR PP (MW)	0.0	83.8	0.0	0.0	59.3	54.0	71.8	62.6	74.7	91.6	0.0	0.0	78.8
11. PFOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	269.0	269.0
12. LR PF (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	9.6	9.6
13. PMOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
14. LR PM (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
15. NSC (MW)	523.00	523.00	523.00	523.00	523.00	523.00	523.00	523.00	523.00	523.00	523.00	523.00	523.00
16. OPER MBTU	2,048,530	2,192,430	1,242,030	1,687,420	2,312,200	2,286,240	2,323,840	2,268,960	2,269,550	2,026,160	2,244,520	2,331,850	25,233,730
17. NET GEN (MWH)	285,741	305,145	174,063	232,737	322,822	318,413	323,942	318,537	317,483	281,756	313,651	331,053	3,525,343
18. ANOHR (BTU/KWH)	7,169.2	7,184.9	7,135.5	7,250.3	7,162.5	7,180.1	7,173.6	7,123.1	7,148.6	7,191.2	7,156.1	7,043.7	7,157.8
19. NOF %	79.51	83.83	81.57	75.94	82.96	84.56	83.63	84.19	85.49	79.59	83.18	85.19	82.64
20. NPC (MW)	523.00	523.00	523.00	523.00	523.00	523.00	523.00	523.00	523.00	523.00	523.00	523.00	523.00

Duke Energy

ACTUAL UNIT PERFORMANCE DATA - YEAR 2024

Hines Power Block 4	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-24	Nov-24	Dec-24	Jan - Dec Period
1. EAF	24.92	0.00	35.33	94.27	97.29	97.21	99.91	99.92	99.93	97.07	99.67	92.21	78.36
2. PH	744.0	696.0	743.0	720.0	744.0	720.0	744.0	744.0	720.0	744.0	721.0	744.0	8,784.0
3. SH	185.4	0.0	262.2	676.6	727.5	702.9	744.0	744.0	720.0	675.4	707.4	637.0	6,782.6
4. RSH	0.0	0.0	1.0	2.3	0.0	0.0	0.0	0.0	0.0	55.1	13.6	76.4	148.5
5. UH	558.6	696.0	479.8	41.0	16.5	17.1	0.0	0.0	0.0	13.5	0.0	30.5	1,852.9
6. POH	388.3	696.0	477.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1,562.1
7. FOH	35.5	0.0	2.0	4.6	6.0	0.0	0.0	0.0	0.0	13.5	0.0	30.5	92.2
8. MOH	134.8	0.0	0.0	36.5	10.4	17.1	0.0	0.0	0.0	0.0	0.0	0.0	198.7
9. PPOH	0.0	0.0	58.3	0.0	9.0	17.0	5.8	4.8	3.6	37.0	0.0	0.0	135.5
10. LR PP (MW)	0.0	0.0	6.7	0.0	54.9	53.9	62.4	66.8	76.9	117.2	0.0	0.0	52.4
11. PFOH	0.0	0.0	0.0	0.0	6.1	0.0	0.0	0.0	0.0	0.0	14.8	176.8	197.7
12. LR PF (MW)	0.0	0.0	0.0	0.0	85.0	0.0	0.0	0.0	0.0	0.0	83.6	81.4	81.7
13. PMOH	0.0	0.0	0.0	1.3	10.8	7.8	0.0	0.0	0.0	0.0	0.0	0.0	20.0
14. LR PM (MW)	0.0	0.0	0.0	89.6	85.0	85.0	0.0	0.0	0.0	0.0	0.0	0.0	85.3
15. NSC (MW)	525.00	525.00	525.00	525.00	525.00	525.00	525.00	525.00	525.00	525.00	525.00	525.00	525.00
16. OPER MBTU	568,280	0	660,740	2,002,050	2,282,990	2,293,380	2,392,480	2,439,750	2,379,110	2,051,320	2,237,280	1,848,900	21,156,280
17. NET GEN (MWH)	79,649	0	91,913	284,186	322,865	324,013	338,738	348,321	335,579	287,185	311,619	261,083	2,985,151
18. ANOHR (BTU/KWH)	7,134.8	0.0	7,188.8	7,044.9	7,071.0	7,078.0	7,062.9	7,004.3	7,089.6	7,142.9	7,179.5	7,081.7	7,087.2
19. NOF %	81.82	0.00	66.76	80.00	84.53	87.80	86.72	89.18	88.78	80.99	83.91	78.07	83.83
20. NPC (MW)	525.00	525.00	525.00	525.00	525.00	525.00	525.00	525.00	525.00	525.00	525.00	525.00	525.00

Duke Energy

ACTUAL UNIT PERFORMANCE DATA - YEAR 2024

Osprey CC	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-24	Nov-24	Dec-24	Jan - Dec Period
1. EAF	52.55	95.36	93.51	0.00	80.48	95.41	97.94	100.00	100.00	92.95	99.60	99.73	84.01
2. PH	744.0	696.0	743.0	720.0	744.0	720.0	744.0	744.0	720.0	744.0	721.0	744.0	8,784.0
3. SH	270.0	574.5	550.0	0.0	555.7	690.9	731.2	735.6	720.0	691.6	721.0	742.5	6,983.1
4. RSH	120.9	96.6	144.8	0.0	43.1	0.0	0.0	8.4	0.0	0.0	0.0	0.0	413.8
5. UH	353.1	24.8	48.2	720.0	145.2	29.1	12.8	0.0	0.0	52.4	0.0	1.5	1,387.1
6. POH	0.0	0.0	48.0	720.0	144.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	912.0
7. FOH	353.1	0.0	0.2	0.0	1.2	2.5	0.0	0.0	0.0	52.4	0.0	1.5	410.9
8. MOH	0.0	24.8	0.0	0.0	0.1	26.5	12.8	0.0	0.0	0.0	0.0	0.0	64.2
9. PPOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	13.5	6.5	20.1
10. LR PP (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	128.0	50.1	102.6
11. PFOH	0.0	0.0	0.0	0.0	0.0	0.0	51.9	0.0	0.0	0.1	0.0	0.0	52.1
12. LR PF (MW)	0.0	0.0	0.0	0.0	0.0	0.0	29.5	0.0	0.0	53.0	0.0	0.0	29.6
13. PMOH	0.0	34.4	0.0	0.0	0.1	14.2	0.0	0.0	0.0	0.0	0.0	0.0	48.7
14. LR PM (MW)	0.0	131.0	0.0	0.0	169.0	169.0	0.0	0.0	0.0	0.0	0.0	0.0	142.1
15. NSC (MW)	606.00	606.00	606.00	606.00	606.00	606.00	606.00	606.00	606.00	606.00	606.00	606.00	606.00
16. OPER MBTU	700,660	1,601,950	1,388,650	0	1,631,010	2,129,570	2,630,820	2,665,540	2,600,650	2,362,720	2,523,810	2,652,430	22,887,810
17. NET GEN (MWH)	89,359	215,615	187,259	0	216,224	283,590	367,260	371,281	363,629	329,558	351,611	374,693	3,150,079
18. ANOHR (BTU/KWH)	7,841.0	7,429.7	7,415.7	0.0	7,543.1	7,509.3	7,163.4	7,179.3	7,151.9	7,169.4	7,177.8	7,078.9	7,265.8
19. NOF %	54.61	61.93	56.18	0.00	64.21	67.73	82.88	83.29	83.34	78.63	80.47	83.27	74.44
20. NPC (MW)	606.00	606.00	606.00	606.00	606.00	606.00	606.00	606.00	606.00	606.00	606.00	606.00	606.00

Duke Energy Florida

ACTUAL UNIT EVENT DATA - January to December 2024

Bartow CC

Unit	Date	Outage Type	Hours	MW Affected	Description
BCC 4A	12/31/2023	FMO	57.10	181.0	GAS TURBINE VIBRATION
BCC 4A	1/3/2024	FMO	23.88	181.0	GAS TURBINE VIBRATION
BCC 4A	1/9/2024	FFO	40.58	181.0	FLASHBACK INCLUDING INSTRUMENTATION
BCC 4A	1/11/2024	FFO	152.10	181.0	FLASHBACK INCLUDING INSTRUMENTATION
BCC 4A	2/4/2024	FFO	0.52	181.0	OTHER SWITCHYARD EQUIPMENT – EXTERNAL (NOT OMC)
BCC 4A	2/14/2024	FMO	1.17	181.0	FUEL PIPING AND VALVES
BCC 4A	2/21/2024	FMO	48.65	181.0	OTHER CONTROLS AND INSTRUMENTATION PROBLEMS
BCC 4A	3/15/2024	FFO	7.75	181.0	GAS FUEL SYSTEM INCLUDING CONTROLS AND INSTRUMENTATION
BCC 4A	3/17/2024	FMO	87.20	181.0	OTHER MISCELLANEOUS GAS TURBINE PROBLEMS
BCC 4A	4/4/2024	FMO	21.02	181.0	AC CIRCUIT BREAKERS
BCC 4A	4/29/2024	FMO	75.88	181.0	INLET AIR FILTERS
BCC 4A	5/4/2024	FFO	0.48	181.0	FUEL PIPING AND VALVES
BCC 4A	8/19/2024	FFO	12.25	181.0	GAS TURBINE CONTROL SYSTEM - HARDWARE PROBLEMS
BCC 4A	9/14/2024	FFO	24.62	181.0	LIGHTNING
BCC 4A	10/5/2024	FFO	6.72	181.0	GAS TURBINE CONTROL SYSTEM - HARDWARE PROBLEMS
BCC 4A	10/7/2024	FFO	11.22	181.0	GAS TURBINE CONTROL SYSTEM - HARDWARE PROBLEMS
BCC 4A	10/8/2024	FFO	126.80	181.0	HURRICANE
BCC 4A	11/15/2024	FFO	3.53	181.0	DCS - LOGIC PROBLEMS
BCC 4A	11/27/2024	FFO	50.83	181.0	GAS TURBINE CONTROL SYSTEM - HARDWARE PROBLEMS
BCC 4A	12/2/2024	FFO	5.28	181.0	FUEL PIPING AND VALVES
BCC 4A	12/6/2024	FMO	30.52	181.0	GAS TURBINE CONTROL SYSTEM - HARDWARE PROBLEMS
BCC 4B	1/22/2024	FFO	70.23	165.0	GENERATOR VOLTAGE CONTROL
BCC 4B	3/1/2024	PO	205.32	165.0	BOROSCOPE INSPECTION
BCC 4B	3/12/2024	FFO	4.13	165.0	BLADE PATH TEMPERATURE SPREAD
BCC 4B	8/7/2024	FFO	7.17	165.0	FUEL PIPING AND VALVES
BCC 4B	8/12/2024	FFO	29.37	165.0	FUEL PIPING AND VALVES
BCC 4B	8/16/2024	FMO	16.32	165.0	FUEL PIPING AND VALVES
BCC 4B	9/3/2024	FMO	17.70	165.0	GAS TURBINE PERFORMANCE TESTING
BCC 4B	9/4/2024	FFO	0.05	165.0	BLADE PATH TEMPERATURE SPREAD
BCC 4B	9/20/2024	FFO	2.77	165.0	FUEL PIPING AND VALVES
BCC 4B	9/20/2024	PO	1,594.37	165.0	MAJOR OVERHAUL
BCC 4B	11/26/2024	PO	48.18	165.0	BLADE PATH TEMPERATURE SPREAD
BCC 4B	11/28/2024	PO	2.57	165.0	BLADE PATH TEMPERATURE SPREAD
BCC 4B	12/3/2024	FFO	12.47	165.0	INLET AIR FILTERS
BCC 4B	12/8/2024	FFO	567.25	165.0	GAS TURBINE VIBRATION
BCC 4C	2/19/2024	FMO	16.40	181.0	GAS TURBINE PERFORMANCE TESTING
BCC 4C	3/1/2024	PO	1,353.15	181.0	MAJOR OVERHAUL
BCC 4C	4/28/2024	FFO	1.03	181.0	LUBE OIL PUMPS
BCC 4C	5/8/2024	FFO	7.80	181.0	LUBE OIL PUMPS
BCC 4C	10/8/2024	FFO	108.35	181.0	HURRICANE
BCC 4C	10/13/2024	FFO	19.57	181.0	MAIN TRANSFORMER

Duke Energy Florida

ACTUAL UNIT EVENT DATA - January to December 2024

Bartow CC

Unit	Date	Outage Type	Hours	MW Affected	Description
BCC 4C	11/23/2024	FFO	3.92	181.0	GAS TURBINE CONTROL SYSTEM - HARDWARE PROBLEMS
BCC 4C	12/13/2024	FFO	3.22	181.0	GAS TURBINE CONTROL SYSTEM - LOGIC PROBLEMS
BCC 4D	2/13/2024	FMO	2.43	183.0	FUEL PIPING AND VALVES
BCC 4D	2/26/2024	FMO	56.75	183.0	NERC RELIABILITY STANDARD REQUIREMENT
BCC 4D	6/26/2024	FMO	3.67	183.0	FUEL PIPING AND VALVES
BCC 4D	9/4/2024	FMO	18.30	183.0	GAS TURBINE PERFORMANCE TESTING
BCC 4D	9/17/2024	FFO	1.37	183.0	INLET AIR VANES / NOZZLES
BCC 4D	10/6/2024	PO	1,553.62	183.0	MAJOR OVERHAUL
BCC 4D	12/11/2024	PO	3.77	183.0	GAS TURBINE PERFORMANCE TESTING
BCC 4D	12/28/2024	FMO	73.35	183.0	COMBUSTOR CASING
BCC 4S	1/12/2024	PFO	123.37	177.0	REHEAT STOP VALVES
BCC 4S	1/22/2024	FMO	64.18	402.0	HP EXTRACTION STEAM PIPING
BCC 4S	1/25/2024	PMO	120.00	76.0	FEEDWATER PUMP
BCC 4S	3/1/2024	PPO	205.32	175.0	BOROSCOPE INSPECTION
BCC 4S	3/1/2024	PPO	1,402.55	76.0	MAJOR OVERHAUL
BCC 4S	3/12/2024	PFO	4.13	175.0	BLADE PATH TEMPERATURE SPREAD
BCC 4S	3/15/2024	PFO	7.75	76.0	GAS FUEL SYSTEM INCLUDING CONTROLS AND INSTRUMENTATION
BCC 4S	3/17/2024	PMO	87.20	175.0	OTHER MISCELLANEOUS GAS TURBINE PROBLEMS
BCC 4S	3/21/2024	PFO	4.08	175.0	400-700-VOLT TRANSFORMERS
BCC 4S	3/25/2024	PMO	41.00	175.0	CONDENSER TUBE CLEANING SYSTEM INCLUDING DEBRIS FILTER
BCC 4S	4/4/2024	PMO	20.85	175.0	AC CIRCUIT BREAKERS
BCC 4S	4/16/2024	FFO	4.27	402.0	DCS - HARDWARE PROBLEMS
BCC 4S	4/29/2024	PMO	75.88	76.0	INLET AIR FILTERS
BCC 4S	5/6/2024	PFO	42.08	76.0	FEEDWATER PUMP
BCC 4S	5/28/2024	PFO	37.47	175.0	CONDENSER TUBE LEAK
BCC 4S	6/26/2024	PMO	3.67	76.0	FUEL PIPING AND VALVES
BCC 4S	7/9/2024	PMO	24.68	76.0	OTHER TURBINE VALVES
BCC 4S	7/16/2024	PFO	17.08	76.0	IP DESUPERHEATER/ATTEMPERATOR PIPING
BCC 4S	8/7/2024	PFO	7.17	37.0	FUEL PIPING AND VALVES
BCC 4S	8/12/2024	PFO	29.37	37.0	FUEL PIPING AND VALVES
BCC 4S	8/16/2024	PMO	16.32	37.0	FUEL PIPING AND VALVES
BCC 4S	8/19/2024	PFO	12.25	37.0	GAS TURBINE CONTROL SYSTEM - HARDWARE PROBLEMS
BCC 4S	9/3/2024	PMO	17.70	37.0	GAS TURBINE PERFORMANCE TESTING
BCC 4S	9/4/2024	PFO	0.05	37.0	BLADE PATH TEMPERATURE SPREAD
BCC 4S	9/4/2024	PMO	18.30	37.0	GAS TURBINE PERFORMANCE TESTING
BCC 4S	9/16/2024	PFO	1.30	175.0	OTHER 4000-7000-VOLT PROBLEMS
BCC 4S	9/17/2024	PFO	1.37	37.0	INLET AIR VANES / NOZZLES
BCC 4S	9/20/2024	PFO	2.77	37.0	FUEL PIPING AND VALVES
BCC 4S	9/20/2024	PPO	24.82	37.0	MAJOR OVERHAUL
BCC 4S	9/21/2024	PPO	95.72	175.0	4000-6000 VOLT PROTECTION DEVICES
BCC 4S	9/25/2024	PPO	241.38	37.0	MAJOR OVERHAUL

Duke Energy Florida

ACTUAL UNIT EVENT DATA - January to December 2024

Bartow CC

Unit	Date	Outage Type	Hours	MW Affected	Description
BCC 4S	10/5/2024	PFO	6.72	175.0	GAS FUEL SYSTEM INCLUDING CONTROLS AND INSTRUMENTATION
BCC 4S	10/6/2024	PPO	1,301.60	175.0	MAJOR OVERHAUL
BCC 4S	10/7/2024	FFO	217.92	402.0	HURRICANE
BCC 4S	10/31/2024	FFO	92.98	402.0	GLAND SEAL SYSTEM
BCC 4S	11/15/2024	PFO	3.53	288.0	DCS - LOGIC PROBLEMS
BCC 4S	11/27/2024	PFO	32.95	288.0	GAS TURBINE CONTROL SYSTEM - HARDWARE PROBLEMS
BCC 4S	11/29/2024	FFO	262.58	402.0	OTHER EXCITER PROBLEMS
BCC 4S	12/10/2024	PFO	524.55	37.0	GAS TURBINE VIBRATION
BCC 4S	12/13/2024	PFO	3.22	175.0	GAS TURBINE CONTROL SYSTEM - LOGIC PROBLEMS
BCC 4S	12/27/2024	PFO	0.45	175.0	OTHER FEEDWATER PUMP PROBLEMS
BCC 4S	12/28/2024	PMO	73.35	37.0	COMBUSTOR CASING

Duke Energy Florida

ACTUAL UNIT EVENT DATA - January to December 2024

Citrus County Power Block 1

Unit	Date	Outage Type	Hours	MW Affected	Description
CITR 1A	2/4/2024	PFO	20.80	91.0	OPERATOR ERROR
CITR 1A	2/5/2024	FFO	3.78	243.0	CONTROL VALVES
CITR 1A	2/8/2024	PO	505.32	243.0	GENERAL UNIT INSPECTION
CITR 1A	2/29/2024	FMO	18.35	243.0	DIFFERENTIAL EXPANSION
CITR 1A	6/11/2024	FMO	134.55	243.0	IP STARTUP BYPASS SYSTEM VALVES
CITR 1A	9/14/2024	PFO	2.57	23.0	INLET AIR FILTERS
CITR 1A	10/3/2024	PFO	1.37	93.0	GAS FUEL SYSTEM INCLUDING CONTROLS AND INSTRUMENTATION
CITR 1A	10/9/2024	PFO	18.00	30.7	GROUND WATER OR OTHER WATER SUPPLY PROBLEMS (OMC)
CITR 1A	10/10/2024	PFO	7.00	15.7	GROUND WATER OR OTHER WATER SUPPLY PROBLEMS (OMC)
CITR 1A	12/1/2024	FMO	108.20	243.0	INLET AIR FILTERS
CITR 1B	2/3/2024	FMO	32.32	242.0	ECONOMIZER PIPING
CITR 1B	2/4/2024	PFO	23.27	90.0	OPERATOR ERROR
CITR 1B	2/9/2024	PO	522.72	242.0	GENERAL UNIT INSPECTION
CITR 1B	4/22/2024	FMO	62.57	242.0	OTHER HIGH PRESSURE PROBLEMS
CITR 1B	6/11/2024	FMO	105.53	242.0	IP STARTUP BYPASS SYSTEM VALVES
CITR 1B	9/13/2024	PFO	13.82	22.0	INLET AIR FILTERS
CITR 1B	9/14/2024	PFO	9.58	22.0	INLET AIR FILTERS
CITR 1B	10/1/2024	PFO	3.58	22.0	INLET AIR FILTERS
CITR 1B	10/9/2024	PFO	19.17	22.0	INLET AIR FILTERS
CITR 1B	10/9/2024	PFO	18.00	29.7	GROUND WATER OR OTHER WATER SUPPLY PROBLEMS (OMC)
CITR 1B	10/10/2024	PFO	7.00	14.7	GROUND WATER OR OTHER WATER SUPPLY PROBLEMS (OMC)
CITR 1B	11/7/2024	PFO	1.43	22.0	INLET AIR FILTERS
CITR 1B	11/8/2024	PFO	1.08	22.0	INLET AIR FILTERS
CITR 1B	12/5/2024	FMO	89.53	242.0	INLET AIR FILTERS
CITR ST1	2/3/2024	PMO	32.52	157.0	ECONOMIZER PIPING
CITR ST1	2/4/2024	FFO	20.45	322.0	OPERATOR ERROR
CITR ST1	2/5/2024	FFO	2.17	322.0	OTHER TURBINE VALVES
CITR ST1	2/9/2024	PO	470.75	322.0	GENERAL UNIT INSPECTION
CITR ST1	2/29/2024	FFO	23.38	322.0	DIFFERENTIAL EXPANSION
CITR ST1	4/22/2024	PMO	62.57	227.0	OTHER HIGH PRESSURE PROBLEMS
CITR ST1	5/4/2024	PFO	339.00	52.0	IP STARTUP BYPASS SYSTEM VALVES
CITR ST1	5/23/2024	PFO	24.00	52.0	IP STARTUP BYPASS SYSTEM VALVES
CITR ST1	6/11/2024	FMO	107.77	322.0	IP STARTUP BYPASS SYSTEM VALVES
CITR ST1	6/15/2024	FFO	2.62	322.0	OTHER LP STARTUP BYPASS SYSTEM PROBLEMS
CITR ST1	12/1/2024	PMO	108.20	157.0	INLET AIR FILTERS
CITR ST1	12/5/2024	PMO	89.53	157.0	INLET AIR FILTERS

Duke Energy Florida

ACTUAL UNIT EVENT DATA - January to December 2024

Citrus County Power Block 2

Unit	Date	Outage Type	Hours	MW Affected	Description
CITR 2A	1/1/2024	FFO	2.08	241.0	GAS FUEL SYSTEM INCLUDING CONTROLS AND INSTRUMENTATION
CITR 2A	3/9/2024	FMO	128.45	241.0	BLOWDOWN SYSTEM VALVES
CITR 2A	8/8/2024	PMO	4.00	51.2	CIRCULATING WATER PIPING
CITR 2A	10/1/2024	PMO	2.07	33.9	CIRCULATING WATER PIPING
CITR 2A	10/10/2024	PFO	14.98	13.1	GROUND WATER OR OTHER WATER SUPPLY PROBLEMS (OMC)
CITR 2A	11/16/2024	PFO	1.90	130.6	BLADE PATH TEMPERATURE SPREAD
CITR 2A	11/16/2024	FFO	7.62	241.0	BLADE PATH TEMPERATURE SPREAD
CITR 2A	11/23/2024	PO	575.45	241.0	BOROSCOPE INSPECTION
CITR 2A	12/16/2024	PO	81.00	241.0	BOROSCOPE INSPECTION
CITR 2B	2/4/2024	PO	128.48	242.0	HRSG - REFRACTORY & INSULATION
CITR 2B	4/22/2024	FMO	2.13	52.0	OTHER MISCELLANEOUS GENERATOR PROBLEMS
CITR 2B	8/8/2024	PMO	4.00	242.0	CIRCULATING WATER PIPING
CITR 2B	9/14/2024	FMO	153.17	242.0	HP EVAPORATOR TUBES
CITR 2B	10/1/2024	PMO	2.07	42.0	CIRCULATING WATER PIPING
CITR 2B	10/10/2024	PFO	14.98	17.0	GROUND WATER OR OTHER WATER SUPPLY PROBLEMS (OMC)
CITR 2B	11/23/2024	PO	574.72	242.0	BOROSCOPE INSPECTION
CITR 2B	12/16/2024	PO	78.75	242.0	BOROSCOPE INSPECTION
CITR 2B	12/20/2024	FFO	3.02	242.0	FIRE IN UNIT
CITR 2B	12/20/2024	FFO	2.23	242.0	FLASHBACK INCLUDING INSTRUMENTATION
CITR ST2	1/1/2024	PFO	2.43	140.4	OTHER FUEL SYSTEM PROBLEMS
CITR ST2	2/2/2024	PPO	166.48	155.0	ECONOMIZER PIPING
CITR ST2	3/9/2024	PMO	128.45	155.0	BLOWDOWN SYSTEM VALVES
CITR ST2	4/22/2024	PMO	2.13	200.0	OTHER MISCELLANEOUS GENERATOR PROBLEMS
CITR ST2	8/8/2024	PMO	4.00	76.0	CIRCULATING WATER PIPING
CITR ST2	9/14/2024	PMO	153.17	155.0	HP EVAPORATOR TUBES
CITR ST2	10/1/2024	PMO	2.07	76.0	CIRCULATING WATER PIPING
CITR ST2	11/16/2024	PFO	7.62	155.0	BLADE PATH TEMPERATURE SPREAD
CITR ST2	11/23/2024	PO	574.93	320.0	BOROSCOPE INSPECTION
CITR ST2	12/16/2024	PO	85.82	320.0	BOROSCOPE INSPECTION
CITR ST2	12/20/2024	PFO	3.02	155.0	FIRE IN UNIT
CITR ST2	12/20/2024	PFO	2.23	155.0	FLASHBACK INCLUDING INSTRUMENTATION

Duke Energy Florida

ACTUAL UNIT EVENT DATA - January to December 2024

Crystal River 4

Date	Outage Type	Hours	MW Affected	Description
1/13/2024	FFO	119.00	712.0	REHEAT STOP VALVES
1/22/2024	PFO	5.00	355.0	FEEDWATER VALVES (NOT FEEDWATER REGULATING VALVE)
1/27/2024	FMO	324.00	712.0	OTHER MISCELLANEOUS BALANCE OF PLANT PROBLEMS
2/9/2024	FMO	815.50	712.0	OTHER MISCELLANEOUS BOILER AIR AND GAS SYSTEM PROBLEMS
3/16/2024	PFO	7.00	62.0	PULVERIZER EXHAUSTER FAN
3/19/2024	PPO	3.23	161.0	PRIMARY AIR DUCT AND DAMPERS
3/20/2024	PFO	2.00	453.0	OIL AND GAS FIRES
3/22/2024	PFO	119.50	112.0	PULVERIZER MILLS
4/4/2024	PMO	12.00	537.0	HEATER DRAIN PUMPS
4/19/2024	PFO	53.00	429.0	FORCED DRAFT FAN CONTROLS
4/22/2024	PPO	1,166.00	112.0	PULVERIZER MILLS
4/22/2024	PPO	6.55	429.0	FORCED DRAFT FAN CONTROLS
4/23/2024	PPO	3.00	429.0	BURNERS
4/23/2024	FFO	3.00	712.0	OTHER PULVERIZER PROBLEMS
4/25/2024	PMO	7.00	387.0	FORCED DRAFT FANS
5/19/2024	PFO	145.00	112.0	PULVERIZER FEEDERS
6/11/2024	PPO	50.80	112.0	PULVERIZER MILLS
6/13/2024	PPO	45.00	112.0	PULVERIZER MILLS
6/16/2024	PPO	27.58	112.0	PULVERIZER MILLS
6/17/2024	PPO	30.42	112.0	PULVERIZER MILLS
6/19/2024	PPO	5.62	502.0	FORCED DRAFT FAN MOTORS
6/24/2024	PFO	408.33	27.0	OTHER FEEDWATER VALVES
6/25/2024	PPO	16.02	112.0	PULVERIZER MILLS
7/16/2024	PFO	22.00	537.0	CONDENSATE POLISHING AND FILTERING SYSTEMS
7/24/2024	PPO	6.00	161.0	INDUCED DRAFT FANS
8/6/2024	PFO	1.00	537.0	MAIN TRANSFORMER
8/7/2024	PFO	40.00	112.0	OTHER PULVERIZER PROBLEMS
8/14/2024	FFO	248.00	712.0	FIRST SUPERHEATER LEAK
8/24/2024	PFO	29.08	112.0	FORCED DRAFT FAN CONTROLS
8/25/2024	FFO	34.08	712.0	INDUCED DRAFT FANS
8/27/2024	PFO	2.25	112.0	INDUCED DRAFT FAN MOTORS AND DRIVES
9/26/2024	FFO	1,540.50	712.0	HURRICANE
11/29/2024	PFO	616.00	502.0	OTHER MISCELLANEOUS BALANCE OF PLANT PROBLEMS
12/2/2024	FFO	39.18	712.0	HYDRAULIC SYSTEM PIPES AND VALVES
12/4/2024	PFO	77.00	307.0	INDUCED DRAFT FANS
12/8/2024	FMO	8.00	712.0	INDUCED DRAFT FANS

Duke Energy Florida

ACTUAL UNIT EVENT DATA - January to December 2024

Crystal River 5

Date	Outage Type	Hours	MW Affected	Description
1/1/2024	PFO	5.00	74.0	OTHER MISCELLANEOUS BOILER AIR AND GAS SYSTEM PROBLEMS
1/6/2024	FMO	146.00	698.0	SOOT BLOWERS - STEAM
1/16/2024	PFO	2.00	147.0	OTHER SLAG AND ASH REMOVAL PROBLEMS
1/22/2024	PFO	50.00	51.0	BOILER WATER CONDITION
1/29/2024	PFO	4.00	98.0	PRIMARY AIR FAN DRIVES
2/11/2024	PFO	4.00	128.0	PRIMARY AIR FAN DRIVES
2/14/2024	PFO	13.50	128.0	INDUCED DRAFT FANS
2/17/2024	PO	2,191.87	698.0	IP TURBINE - BUCKETS OR BLADES
5/18/2024	PPO	2.38	638.0	TURBINE PERFORMANCE TESTING
5/18/2024	PO	11.07	698.0	IP TURBINE - BUCKETS OR BLADES
5/18/2024	PPO	5.02	548.0	TURBINE PERFORMANCE TESTING
5/19/2024	PO	6.22	698.0	IP TURBINE - BUCKETS OR BLADES
5/19/2024	PPO	4.52	463.0	TURBINE PERFORMANCE TESTING
5/19/2024	FFO	169.65	698.0	CONTRACTOR ERROR
5/26/2024	PPO	9.13	478.0	TURBINE PERFORMANCE TESTING
5/27/2024	FMO	9.80	698.0	IP TURBINE - BUCKETS OR BLADES
5/27/2024	PPO	15.23	223.0	TURBINE PERFORMANCE TESTING
5/28/2024	FFO	182.70	698.0	IP TURBINE - BUCKETS OR BLADES
6/4/2024	FFO	12.47	698.0	OTHER LOW PRESSURE TURBINE PROBLEMS
6/7/2024	PFO	9.00	48.0	SECONDARY AIR FAN/BLOWER CONTROLS
6/12/2024	PFO	2.38	98.0	PULVERIZER MILLS
6/13/2024	PMO	5.00	48.0	AIR SUPPLY DAMPERS
6/13/2024	PFO	18.00	48.0	PULVERIZER FEEDERS
6/14/2024	PFO	22.00	48.0	PULVERIZER FEEDERS
6/16/2024	PFO	1.22	98.0	PULVERIZER FEEDERS
6/22/2024	PFO	1.00	373.0	PULVERIZER MILLS
7/5/2024	PPO	6.00	70.0	CIRCULATING WATER TEMPERING SYSTEM
7/16/2024	PFO	22.00	448.0	CONDENSATE POLISHING AND FILTERING SYSTEMS
7/25/2024	FMO	153.33	698.0	TRANSMISSION SYSTEM PROBLEMS OTHER THAN CATASTROPHES
8/6/2024	PFO	2.50	373.0	STATION SERVICE POWER DISTRIBUTION SYSTEM
8/7/2024	PFO	40.00	98.0	OTHER PULVERIZER PROBLEMS
9/9/2024	FMO	120.00	698.0	PRIMARY AIR HEATER
9/21/2024	FFO	3.72	698.0	HYDRAULIC SYSTEM PUMPS
9/25/2024	FFO	1,305.67	698.0	HURRICANE
11/25/2024	PFO	696.00	488.0	OTHER MISCELLANEOUS BALANCE OF PLANT PROBLEMS
11/28/2024	PFO	800.00	690.0	FEEDWATER CONTROLS

Duke Energy Florida

ACTUAL UNIT EVENT DATA - January to December 2024

Hines Power Block 1

Unit	Date	Outage Type	Hours	MW Affected	Description
HEP 1A	1/11/2024	FFO	74.03	167.0	EMERGENCY GENERATOR TRIP DEVICES
HEP 1A	2/22/2024	FMO	190.50	167.0	TRANSMISSION SYSTEM PROBLEM
HEP 1A	4/5/2024	PPO	7.75	87.0	CONDENSER TUBE CLEANING SYSTEM INCLUDING DEBRIS FILTER
HEP 1A	4/8/2024	FFO	20.42	167.0	CONDENSATE/HOTWELL PUMPS
HEP 1A	4/18/2024	FFO	5.17	167.0	OTHER MISCELLANEOUS STEAM TURBINE PROBLEMS
HEP 1A	4/19/2024	FFO	9.50	167.0	OTHER MISCELLANEOUS STEAM TURBINE PROBLEMS
HEP 1A	4/19/2024	FFO	14.93	167.0	OTHER MISCELLANEOUS STEAM TURBINE PROBLEMS
HEP 1A	4/20/2024	FFO	3.82	167.0	OTHER COLD REHEAT STEAM VALVES
HEP 1A	6/21/2024	PPO	7.00	87.0	INTAKE GRATING FOULING
HEP 1A	7/5/2024	PFO	48.78	79.0	CIRCULATING WATER PUMP MOTORS
HEP 1A	7/20/2024	PPO	5.48	79.0	CONDENSER TUBE CLEANING SYSTEM INCLUDING DEBRIS FILTER
HEP 1A	7/26/2024	PPO	0.42	79.0	CIRCULATING WATER PUMPS
HEP 1A	7/29/2024	PPO	2.25	87.0	INTAKE GRATING FOULING
HEP 1A	8/2/2024	PPO	0.75	87.0	CONDENSER TUBE CLEANING SYSTEM INCLUDING DEBRIS FILTER
HEP 1A	8/19/2024	PPO	2.12	87.0	CONDENSER TUBE CLEANING SYSTEM INCLUDING DEBRIS FILTER
HEP 1A	9/16/2024	FMO	137.18	167.0	CONDENSATE/HOTWELL PUMPS
HEP 1A	10/26/2024	PPO	32.45	87.0	GAS FUEL SYSTEM INCLUDING CONTROLS AND INSTRUMENTATION
HEP 1A	11/11/2024	PPO	0.70	87.0	CONDENSER TUBE CLEANING SYSTEM INCLUDING DEBRIS FILTER
HEP 1A	11/30/2024	FMO	490.67	167.0	BALANCE OF PLANT OVERHAUL/OUTAGE
HEP 1B	2/22/2024	FMO	202.92	167.0	HIGH PRESSURE HEATER TUBE LEAKS
HEP 1B	3/7/2024	FFO	30.00	167.0	GENERATOR CURRENT AND POTENTIAL TRANSFORMERS
HEP 1B	4/4/2024	FFO	19.82	167.0	EMERGENCY GENERATOR TRIP DEVICES
HEP 1B	4/5/2024	PPO	6.88	87.0	CONDENSER TUBE CLEANING SYSTEM INCLUDING DEBRIS FILTER
HEP 1B	4/18/2024	FFO	47.67	167.0	OTHER MISCELLANEOUS STEAM TURBINE PROBLEMS
HEP 1B	4/20/2024	FFO	38.10	167.0	OTHER COLD REHEAT STEAM VALVES
HEP 1B	5/28/2024	FFO	9.72	167.0	EMERGENCY GENERATOR TRIP DEVICES
HEP 1B	6/21/2024	PPO	7.00	87.0	INTAKE GRATING FOULING
HEP 1B	7/5/2024	PFO	48.78	79.0	CIRCULATING WATER PUMP MOTORS
HEP 1B	7/20/2024	PPO	5.48	79.0	CONDENSER TUBE CLEANING SYSTEM INCLUDING DEBRIS FILTER
HEP 1B	7/26/2024	PPO	0.42	79.0	CIRCULATING WATER PUMPS
HEP 1B	7/29/2024	PPO	2.25	78.0	INTAKE GRATING FOULING
HEP 1B	8/2/2024	PPO	0.75	87.0	CONDENSER TUBE CLEANING SYSTEM INCLUDING DEBRIS FILTER
HEP 1B	8/19/2024	PPO	2.12	87.0	CONDENSER TUBE CLEANING SYSTEM INCLUDING DEBRIS FILTER
HEP 1B	9/16/2024	FMO	117.17	167.0	CONDENSATE/HOTWELL PUMPS
HEP 1B	10/26/2024	PPO	32.45	87.0	GAS FUEL SYSTEM INCLUDING CONTROLS AND INSTRUMENTATION
HEP 1B	11/11/2024	PPO	0.42	87.0	CONDENSER TUBE CLEANING SYSTEM INCLUDING DEBRIS FILTER
HEP 1B	11/30/2024	FMO	526.67	167.0	BALANCE OF PLANT OVERHAUL/OUTAGE
HEP ST1	2/22/2024	FMO	194.72	167.0	TRANSMISSION SYSTEM PROBLEM
HEP ST1	4/5/2024	PPO	7.75	125.0	CONDENSER TUBE CLEANING SYSTEM INCLUDING DEBRIS FILTER
HEP ST1	4/18/2024	FFO	7.95	167.0	OTHER MISCELLANEOUS STEAM TURBINE PROBLEMS
HEP ST1	4/19/2024	FFO	28.12	167.0	OTHER MISCELLANEOUS STEAM TURBINE PROBLEMS

Duke Energy Florida**ACTUAL UNIT EVENT DATA - January to December 2024****Hines Power Block 1**

Unit	Date	Outage Type	Hours	MW Affected	Description
HEP ST1	4/20/2024	FFO	6.10	167.0	OTHER COLD REHEAT STEAM VALVES
HEP ST1	6/21/2024	PPO	7.00	125.0	INTAKE GRATING FOULING
HEP ST1	7/5/2024	PFO	48.78	121.0	CIRCULATING WATER PUMP MOTORS
HEP ST1	7/20/2024	PPO	5.48	103.0	CONDENSER TUBE CLEANING SYSTEM INCLUDING DEBRIS FILTER
HEP ST1	7/26/2024	PPO	0.42	121.0	CIRCULATING WATER PUMPS
HEP ST1	7/29/2024	PPO	2.25	125.0	INTAKE GRATING FOULING
HEP ST1	8/2/2024	PPO	0.75	87.0	CONDENSER TUBE CLEANING SYSTEM INCLUDING DEBRIS FILTER
HEP ST1	8/19/2024	PPO	2.12	87.0	CONDENSER TUBE CLEANING SYSTEM INCLUDING DEBRIS FILTER
HEP ST1	9/16/2024	FMO	120.42	167.0	CONDENSATE/HOTWELL PUMPS
HEP ST1	10/26/2024	PPO	32.45	114.0	GAS FUEL SYSTEM INCLUDING CONTROLS AND INSTRUMENTATION
HEP ST1	11/11/2024	PPO	1.15	114.0	CONDENSER TUBE CLEANING SYSTEM INCLUDING DEBRIS FILTER
HEP ST1	11/30/2024	FMO	502.67	167.0	BALANCE OF PLANT OVERHAUL/OUTAGE

Duke Energy Florida

ACTUAL UNIT EVENT DATA - January to December 2024

Hines Power Block 3

Unit	Date	Outage Type	Hours	MW Affected	Description
HEP 3A	1/16/2024	FFO	12.48	171.0	OTHER MISCELLANEOUS GAS TURBINE PROBLEMS
HEP 3A	2/20/2024	PPO	11.65	71.0	CONDENSER TUBE FOULING TUBE SIDE
HEP 3A	3/18/2024	FMO	239.00	171.0	TURBINE PERFORMANCE TESTING
HEP 3A	4/13/2024	FFO	16.00	171.0	OTHER TURBINE VALVES
HEP 3A	5/16/2024	PPO	8.00	66.0	CONDENSER TUBE FOULING TUBE SIDE
HEP 3A	6/12/2024	PPO	4.00	58.0	CONDENSER TUBE FOULING TUBE SIDE
HEP 3A	6/20/2024	PPO	4.00	58.0	CONDENSER TUBE FOULING TUBE SIDE
HEP 3A	7/9/2024	PPO	13.00	71.0	CONDENSER TUBE FOULING TUBE SIDE
HEP 3A	7/12/2024	PPO	2.00	71.0	INTAKE GRATING FOULING
HEP 3A	7/26/2024	PPO	0.75	71.0	INTAKE GRATING FOULING
HEP 3A	7/30/2024	PPO	7.00	71.0	INTAKE GRATING FOULING
HEP 3A	8/9/2024	PPO	1.00	71.0	INTAKE SYSTEM PROBLEMS OTHER THAN TRAVELING SCREENS
HEP 3A	8/21/2024	FMO	4.00	171.0	OTHER LP STEAM SYSTEM PROBLEMS
HEP 3A	8/29/2024	FMO	45.13	171.0	DESUPERHEATER/ATTEMPERATOR CONTROLS
HEP 3A	9/3/2024	PPO	273.00	67.0	OTHER CO REDUCTION PROBLEMS
HEP 3A	9/13/2024	PPO	2.00	67.0	TRAVELING SCREEN FOULING
HEP 3A	9/14/2024	FMO	22.00	171.0	OTHER CO REDUCTION PROBLEMS
HEP 3A	9/15/2024	PPO	574.00	67.0	OTHER CO REDUCTION PROBLEMS
HEP 3A	9/19/2024	PPO	1.00	67.0	TRAVELING SCREEN FOULING
HEP 3A	10/17/2024	PPO	1.00	121.0	CONDENSER TUBE CLEANING SYSTEM INCLUDING DEBRIS FILTER
HEP 3A	10/26/2024	FMO	36.00	171.0	OTHER MISCELLANEOUS GAS TURBINE PROBLEMS
HEP 3A	12/2/2024	FFO	3.00	171.0	OTHER DCS PROBLEMS
HEP 3A	12/20/2024	PFO	269.00	11.0	MAIN GAS FILTER
HEP 3B	1/7/2024	FFO	26.45	176.0	SCR NOX OTHER AMMONIA SYSTEM PROBLEMS
HEP 3B	2/20/2024	PPO	11.65	76.0	CONDENSER TUBE FOULING TUBE SIDE
HEP 3B	3/18/2024	FMO	239.00	176.0	TURBINE PERFORMANCE TESTING
HEP 3B	4/17/2024	FFO	2.00	176.0	OTHER TURBINE VALVES
HEP 3B	5/16/2024	PPO	8.00	71.0	CONDENSER TUBE FOULING TUBE SIDE
HEP 3B	6/12/2024	PPO	4.00	63.0	CONDENSER TUBE FOULING TUBE SIDE
HEP 3B	6/20/2024	PPO	4.00	63.0	CONDENSER TUBE FOULING TUBE SIDE
HEP 3B	7/9/2024	PPO	13.00	76.0	CONDENSER TUBE FOULING TUBE SIDE
HEP 3B	7/12/2024	PPO	2.00	76.0	INTAKE GRATING FOULING
HEP 3B	7/25/2024	FFO	10.00	176.0	COOLING WATER SYSTEM
HEP 3B	7/26/2024	PPO	0.75	76.0	INTAKE GRATING FOULING
HEP 3B	7/30/2024	PPO	7.00	76.0	INTAKE GRATING FOULING
HEP 3B	8/9/2024	PPO	1.00	76.0	INTAKE GRATING FOULING
HEP 3B	8/21/2024	FMO	4.00	176.0	OTHER HP STEAM SYSTEM PROBLEMS
HEP 3B	9/3/2024	PPO	273.00	26.0	OTHER CO REDUCTION PROBLEMS
HEP 3B	9/13/2024	PPO	2.00	72.0	TRAVELING SCREEN FOULING
HEP 3B	9/15/2024	PPO	574.00	72.0	OTHER CO REDUCTION PROBLEMS
HEP 3B	9/19/2024	PPO	1.00	72.0	TRAVELING SCREEN FOULING

Duke Energy Florida**ACTUAL UNIT EVENT DATA - January to December 2024****Hines Power Block 3**

Unit	Date	Outage Type	Hours	MW Affected	Description
HEP 3B	10/17/2024	PPO	1.00	126.0	CONDENSER TUBE AND WATER BOX CLEANING
HEP 3B	10/26/2024	PPO	36.00	126.0	FUEL CONSERVATION
HEP 3B	12/20/2024	PFO	269.00	16.0	MAIN GAS FILTER
HEP ST3	2/20/2024	PPO	11.65	104.0	CONDENSER TUBE FOULING TUBE SIDE
HEP ST3	3/18/2024	FMO	239.00	176.0	TURBINE PERFORMANCE TESTING
HEP ST3	4/13/2024	FFO	16.00	176.0	OTHER TURBINE VALVES
HEP ST3	5/16/2024	PPO	8.00	41.0	CONDENSER TUBE FOULING TUBE SIDE
HEP ST3	6/12/2024	PPO	4.00	41.0	INTAKE GRATING FOULING
HEP ST3	6/20/2024	PPO	4.00	41.0	INTAKE GRATING FOULING
HEP ST3	7/9/2024	PPO	13.00	41.0	CONDENSER TUBE FOULING TUBE SIDE
HEP ST3	7/12/2024	PPO	2.00	41.0	INTAKE GRATING FOULING
HEP ST3	7/26/2024	PPO	0.75	41.0	INTAKE GRATING FOULING
HEP ST3	7/30/2024	PPO	7.00	41.0	INTAKE GRATING FOULING
HEP ST3	8/9/2024	PPO	1.00	41.0	INTAKE GRATING FOULING
HEP ST3	8/21/2024	FMO	4.00	176.0	OTHER HP STEAM SYSTEM PROBLEMS
HEP ST3	9/3/2024	PPO	273.00	76.0	OTHER CO REDUCTION PROBLEMS
HEP ST3	9/13/2024	PPO	2.00	124.0	TRAVELING SCREEN FOULING
HEP ST3	9/15/2024	PPO	574.00	126.0	OTHER CO REDUCTION PROBLEMS
HEP ST3	9/19/2024	PPO	1.00	124.0	TRAVELING SCREEN FOULING
HEP ST3	10/17/2024	PPO	1.00	75.0	CONDENSER TUBE CLEANING SYSTEM INCLUDING DEBRIS FILTER
HEP ST3	10/26/2024	PPO	36.00	110.0	FUEL CONSERVATION
HEP ST3	12/20/2024	PFO	269.00	1.9	MAIN GAS FILTER

Duke Energy Florida

ACTUAL UNIT EVENT DATA - January to December 2024

Hines Power Block 4

Unit	Date	Outage Type	Hours	MW Affected	Description
HEP 4A	1/3/2024	FMO	128.10	171.0	GENERAL UNIT INSPECTION
HEP 4A	1/11/2024	PO	1,645.07	171.0	GENERAL UNIT INSPECTION
HEP 4A	3/21/2024	PO	38.00	171.0	GENERAL UNIT INSPECTION
HEP 4A	3/25/2024	PO	134.00	171.0	GENERAL UNIT INSPECTION
HEP 4A	4/5/2024	FMO	80.00	171.0	BALANCE OF PLANT OVERHAUL/OUTAGE
HEP 4A	4/8/2024	FMO	24.00	171.0	BALANCE OF PLANT OVERHAUL/OUTAGE
HEP 4A	4/9/2024	FFO	14.00	171.0	OTHER AUXILIARY STEAM PROBLEMS
HEP 4A	4/22/2024	FMO	8.00	171.0	OTHER VOLTAGE PROTECTION DEVICES
HEP 4A	5/13/2024	PPO	7.00	61.0	CONDENSER TUBE FOULING TUBE SIDE
HEP 4A	5/21/2024	FMO	32.00	171.0	OTHER IP STEAM SYSTEM PROBLEMS
HEP 4A	5/31/2024	PPO	3.00	61.0	INTAKE GRATING FOULING
HEP 4A	6/13/2024	FMO	8.00	171.0	SEAL OIL SYSTEM AND SEALS
HEP 4A	6/20/2024	PPO	4.00	58.0	INTAKE GRATING FOULING
HEP 4A	6/27/2024	PPO	12.00	61.0	CONDENSER TUBE FOULING TUBE SIDE
HEP 4A	7/10/2024	PPO	1.00	67.0	INTAKE GRATING FOULING
HEP 4A	7/12/2024	PPO	2.00	71.0	INTAKE GRATING FOULING
HEP 4A	7/26/2024	PPO	0.75	71.0	INTAKE GRATING FOULING
HEP 4A	7/29/2024	PPO	1.00	71.0	INTAKE GRATING FOULING
HEP 4A	7/31/2024	PPO	1.00	93.3	INTAKE GRATING FOULING
HEP 4A	8/2/2024	PPO	0.75	54.0	INTAKE GRATING FOULING
HEP 4A	8/9/2024	PPO	4.00	56.0	INTAKE GRATING FOULING
HEP 4A	9/13/2024	PPO	4.00	63.0	TRAVELING SCREEN FOULING
HEP 4A	9/19/2024	PPO	1.00	63.0	TRAVELING SCREEN FOULING
HEP 4A	10/16/2024	PPO	1.00	70.0	CONDENSER TUBE CLEANING SYSTEM INCLUDING DEBRIS FILTER
HEP 4A	10/26/2024	PPO	36.00	121.0	FUEL CONSERVATION
HEP 4A	12/12/2024	FFO	25.00	171.0	OTHER MISCELLANEOUS GAS TURBINE PROBLEMS
HEP 4A	12/13/2024	FFO	17.00	171.0	GAS FUEL SYSTEM
HEP 4A	12/14/2024	PFO	171.00	65.0	OTHER TURBINE VALVES
HEP 4B	1/3/2024	FMO	144.02	176.0	GENERAL UNIT INSPECTION
HEP 4B	1/15/2024	FFO	22.55	176.0	OTHER HYDRAULIC SYSTEM PROBLEMS
HEP 4B	1/16/2024	FFO	30.00	176.0	TURNING GEAR AND MOTOR
HEP 4B	1/17/2024	PO	1,434.00	176.0	GENERAL UNIT INSPECTION
HEP 4B	3/31/2024	FFO	6.00	176.0	IP DRUM
HEP 4B	4/22/2024	PMO	2.00	68.0	SERVICE WATER PUMPS AND MOTORS
HEP 4B	5/13/2024	PPO	7.00	66.0	CONDENSER TUBE FOULING TUBE SIDE
HEP 4B	5/25/2024	FFO	18.00	176.0	LUBE OIL SYSTEM - GENERAL
HEP 4B	5/31/2024	PPO	3.00	66.0	INTAKE GRATING FOULING
HEP 4B	6/13/2024	FMO	11.00	176.0	SEAL OIL SYSTEM AND SEALS
HEP 4B	6/16/2024	FMO	23.00	176.0	MAIN TRANSFORMER
HEP 4B	6/20/2024	PPO	4.00	66.0	INTAKE GRATING FOULING
HEP 4B	6/27/2024	PPO	12.00	63.0	CONDENSER TUBE FOULING TUBE SIDE

Duke Energy Florida

ACTUAL UNIT EVENT DATA - January to December 2024

Hines Power Block 4

Unit	Date	Outage Type	Hours	MW Affected	Description
HEP 4B	7/10/2024	PPO	1.00	72.0	INTAKE GRATING FOULING
HEP 4B	7/12/2024	PPO	2.00	76.0	INTAKE GRATING FOULING
HEP 4B	7/26/2024	PPO	0.75	76.0	INTAKE GRATING FOULING
HEP 4B	7/29/2024	PPO	1.00	76.0	INTAKE GRATING FOULING
HEP 4B	7/31/2024	PPO	1.00	100.0	INTAKE GRATING FOULING
HEP 4B	8/2/2024	PPO	0.75	61.0	INTAKE GRATING FOULING
HEP 4B	8/9/2024	PPO	4.00	61.0	INTAKE GRATING FOULING
HEP 4B	9/13/2024	PPO	3.00	68.0	TRAVELING SCREEN FOULING
HEP 4B	9/19/2024	PPO	1.00	68.0	TRAVELING SCREEN FOULING
HEP 4B	10/16/2024	PPO	1.00	126.0	CONDENSER TUBE CLEANING SYSTEM INCLUDING DEBRIS FILTER
HEP 4B	10/21/2024	FFO	14.00	176.0	4000-7000-VOLT CIRCUIT BREAKERS
HEP 4B	10/26/2024	PPO	36.00	126.0	FUEL CONSERVATION
HEP 4B	11/21/2024	PFO	22.00	64.0	HOT WELL
HEP 4B	12/12/2024	FFO	25.00	176.0	OTHER MISCELLANEOUS GAS TURBINE PROBLEMS
HEP 4B	12/14/2024	PFO	171.00	70.0	OTHER TURBINE VALVES
HEP ST4	1/3/2024	FMO	131.98	178.0	GENERAL UNIT INSPECTION
HEP ST4	1/15/2024	FFO	22.75	178.0	OTHER HYDRAULIC SYSTEM PROBLEMS
HEP ST4	1/16/2024	FFO	30.00	178.0	TURNING GEAR AND MOTOR
HEP ST4	1/17/2024	PO	1,443.75	178.0	GENERAL UNIT INSPECTION
HEP ST4	3/21/2024	PPO	38.00	6.7	GENERAL UNIT INSPECTION
HEP ST4	3/25/2024	PPO	134.00	6.7	GENERAL UNIT INSPECTION
HEP ST4	4/22/2024	PMO	2.00	111.0	SERVICE WATER PUMPS AND MOTORS
HEP ST4	5/13/2024	PPO	7.00	38.0	CONDENSER TUBE FOULING TUBE SIDE
HEP ST4	5/21/2024	PMO	32.00	85.0	OTHER IP STEAM SYSTEM PROBLEMS
HEP ST4	5/25/2024	PFO	18.00	85.0	LUBE OIL SYSTEM - GENERAL
HEP ST4	5/31/2024	PPO	3.00	38.0	INTAKE GRATING FOULING
HEP ST4	6/13/2024	FMO	9.00	178.0	SEAL OIL SYSTEM AND SEALS
HEP ST4	6/16/2024	PMO	23.00	85.0	MAIN TRANSFORMER
HEP ST4	6/20/2024	PPO	4.00	38.0	CONDENSER TUBE FOULING TUBE SIDE
HEP ST4	6/27/2024	PPO	12.00	38.0	INTAKE GRATING FOULING
HEP ST4	7/10/2024	PPO	1.00	38.0	INTAKE GRATING FOULING
HEP ST4	7/12/2024	PPO	2.00	38.0	INTAKE GRATING FOULING
HEP ST4	7/26/2024	PPO	0.75	43.0	INTAKE GRATING FOULING
HEP ST4	7/29/2024	PPO	1.00	43.0	INTAKE GRATING FOULING
HEP ST4	7/31/2024	PPO	1.00	6.0	INTAKE GRATING FOULING
HEP ST4	8/2/2024	PPO	0.75	83.0	INTAKE GRATING FOULING
HEP ST4	8/9/2024	PPO	4.00	83.0	INTAKE GRATING FOULING
HEP ST4	9/13/2024	PPO	1.00	128.0	TRAVELING SCREEN FOULING
HEP ST4	9/19/2024	PPO	1.00	128.0	TRAVELING SCREEN FOULING
HEP ST4	10/16/2024	PPO	1.00	6.0	CONDENSER TUBE CLEANING SYSTEM INCLUDING DEBRIS FILTER
HEP ST4	10/21/2024	FFO	26.00	178.0	4000-7000-VOLT CIRCUIT BREAKERS

Duke Energy Florida

ACTUAL UNIT EVENT DATA - January to December 2024

Hines Power Block 4

Unit	Date	Outage Type	Hours	MW Affected	Description
HEP ST4	10/26/2024	PPO	36.00	109.0	FUEL CONSERVATION
HEP ST4	11/21/2024	PFO	22.00	103.0	HOT WELL
HEP ST4	12/12/2024	FFO	25.00	178.0	OTHER MISCELLANEOUS GAS TURBINE PROBLEMS
HEP ST4	12/13/2024	PFO	17.00	85.0	GAS FUEL SYSTEM
HEP ST4	12/14/2024	PFO	171.00	108.0	OTHER TURBINE VALVES

Duke Energy Florida

ACTUAL UNIT EVENT DATA - January to December 2024

Osprey CC

Unit	Date	Outage Type	Hours	MW Affected	Description
OSP CT1	12/31/2023	FFO	351.57	179.0	EMERGENCY GENERATOR TRIP DEVICES
OSP CT1	1/17/2024	FFO	0.40	179.0	GAS FUEL SYSTEM INCLUDING CONTROLS AND INSTRUMENTATION
OSP CT1	1/17/2024	FFO	1.00	179.0	GAS FUEL SYSTEM INCLUDING CONTROLS AND INSTRUMENTATION
OSP CT1	3/29/2024	PO	840.17	179.0	GENERAL UNIT INSPECTION
OSP CT1	5/4/2024	PO	71.98	179.0	GENERAL UNIT INSPECTION
OSP CT1	5/7/2024	FFO	0.63	179.0	OTHER MISCELLANEOUS GAS TURBINE PROBLEMS
OSP CT1	5/7/2024	FFO	0.48	179.0	OTHER CONTROLS AND INSTRUMENTATION PROBLEMS
OSP CT1	5/7/2024	FFO	2.85	179.0	OTHER MISCELLANEOUS GAS TURBINE PROBLEMS
OSP CT1	6/25/2024	FMO	18.03	179.0	TRANSMISSION SYSTEM PROBLEM
OSP CT1	7/1/2024	FMO	12.35	179.0	SWITCHYARD SYSTEM PROTECTION DEVICES – EXTERNAL (OMC)
OSP CT1	7/7/2024	PFO	51.93	10.0	SWITCHYARD TRANSFORMERS AND ASSOCIATED COOLING SYSTEMS
OSP CT1	8/6/2024	FFO	0.08	179.0	STARTING SYSTEM (INCLUDING MOTOR)
OSP CT1	10/9/2024	FFO	46.23	179.0	HURRICANE
OSP CT1	12/11/2024	FFO	4.65	179.0	FLASHBACK INCLUDING INSTRUMENTATION
OSP CT1	12/11/2024	FFO	0.30	179.0	FUEL PIPING AND VALVES
OSP CT1	12/17/2024	PPO	4.67	60.0	MAIN STEAM RELIEF/SAFETY VALVES OFF SUPERHEATER
OSP CT2	12/31/2023	FFO	351.57	179.0	EMERGENCY GENERATOR TRIP DEVICES
OSP CT2	1/18/2024	FFO	0.35	179.0	GAS FUEL SYSTEM INCLUDING CONTROLS AND INSTRUMENTATION
OSP CT2	1/18/2024	FFO	0.37	179.0	OTHER FUEL SYSTEM PROBLEMS
OSP CT2	1/24/2024	FFO	0.22	179.0	BLADE PATH TEMPERATURE SPREAD
OSP CT2	1/24/2024	FFO	0.13	179.0	BLADE PATH TEMPERATURE SPREAD
OSP CT2	2/4/2024	FMO	84.07	179.0	TURBINE OVERSPEED TRIP TEST - GAS TURBINE
OSP CT2	3/15/2024	FFO	0.33	179.0	BLADE PATH TEMPERATURE SPREAD
OSP CT2	3/17/2024	FFO	0.32	179.0	BLADE PATH TEMPERATURE SPREAD
OSP CT2	3/30/2024	PO	840.00	179.0	GENERAL UNIT INSPECTION
OSP CT2	5/4/2024	PO	71.98	179.0	GENERAL UNIT INSPECTION
OSP CT2	5/31/2024	FMO	34.83	179.0	BLOWDOWN SYSTEM PIPING
OSP CT2	6/14/2024	FFO	8.63	179.0	GAS TURBINE VIBRATION
OSP CT2	6/25/2024	FMO	16.63	179.0	TRANSMISSION SYSTEM PROBLEM
OSP CT2	7/1/2024	FMO	12.98	179.0	SWITCHYARD SYSTEM PROTECTION DEVICES – EXTERNAL (OMC)
OSP CT2	7/7/2024	PFO	51.93	9.6	SWITCHYARD TRANSFORMERS AND ASSOCIATED COOLING SYSTEMS
OSP CT2	10/9/2024	FFO	67.67	179.0	HURRICANE
OSP CT2	12/18/2024	PPO	4.62	60.0	MAIN STEAM RELIEF/SAFETY VALVES OFF SUPERHEATER
OSP ST1	12/31/2023	FFO	351.57	248.0	EMERGENCY GENERATOR TRIP DEVICES
OSP ST1	1/17/2024	FFO	0.40	248.0	GAS FUEL SYSTEM INCLUDING CONTROLS AND INSTRUMENTATION
OSP ST1	1/17/2024	FFO	1.45	248.0	GAS FUEL SYSTEM INCLUDING CONTROLS AND INSTRUMENTATION
OSP ST1	2/4/2024	PMO	84.07	131.0	TURBINE OVERSPEED TRIP TEST - GAS TURBINE
OSP ST1	3/30/2024	PO	839.95	248.0	GENERAL UNIT INSPECTION
OSP ST1	5/4/2024	PO	71.98	248.0	GENERAL UNIT INSPECTION
OSP ST1	5/31/2024	PMO	34.83	169.0	BLOWDOWN SYSTEM PIPING
OSP ST1	6/25/2024	FMO	14.80	248.0	TRANSMISSION SYSTEM PROBLEM

Duke Energy Florida

ACTUAL UNIT EVENT DATA - January to December 2024

Osprey CC

Unit	Date	Outage Type	Hours	MW Affected	Description
OSP ST1	7/1/2024	FMO	13.00	248.0	SWITCHYARD SYSTEM PROTECTION DEVICES – EXTERNAL (OMC)
OSP ST1	7/7/2024	PFO	51.93	58.0	SWITCHYARD TRANSFORMERS AND ASSOCIATED COOLING SYSTEMS
OSP ST1	10/9/2024	FFO	45.85	248.0	HURRICANE
OSP ST1	10/11/2024	PFO	0.32	53.0	BURNER INSTRUMENTS AND CONTROLS (EXCEPT LIGHT OFF)
OSP ST1	11/19/2024	PPO	33.00	128.0	FEEDWATER PUMP COUPLING AND DRIVE SHAFT
OSP ST1	12/17/2024	PPO	4.67	43.0	MAIN STEAM RELIEF/SAFETY VALVES OFF SUPERHEATER
OSP ST1	12/18/2024	PPO	4.62	43.0	MAIN STEAM RELIEF/SAFETY VALVES OFF SUPERHEATER