

1                   **BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION**  
2                   **FLORIDA POWER & LIGHT COMPANY**  
3                   **DIRECT TESTIMONY OF FRANCISCO PRIETO**  
4                   **DOCKET NO. 20220045-EI**  
5                   **APRIL 1, 2022**  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23

**Table of Contents**

**I. INTRODUCTION AND SUMMARY..... 3**

**II. OVERVIEW OF FPL’S TRANSMISSION SYSTEM..... 6**

**III. DESCRIPTION OF THE SWP ..... 8**

**IV. FPL PLANNING PROCESS ..... 9**

**V. NEED FOR THE PROJECT ..... 11**

**VI. DISCUSSION OF TRANSMISSION ALTERNATIVES ..... 14**

**VII. ADVERSE CONSEQUENCES OF DELAY OR DENIAL OF THE SWP 15**

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 0
- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 0
- 1
- 2
- 3

A. My name is Francisco Prieto. My business address is 4200 W. Flagler Street, Miami, Florida 33134.

A. I am employed by Florida Power & Light Company (“FPL” or the “Company”) as Senior Manager, System Planning.

A. My responsibilities include the direct supervision of engineers in the development of transmission plans for interconnection and integration of generation, transmission service for wholesale customers, and inter-utility ties ensuring compliance with North American Electric Reliability Corporation (“NERC”) standards associated with transmission planning functions. I have held this position and performed these responsibilities since April of 2012.

A. I graduated from Florida International University with a Bachelor of Science degree in Electrical Engineering in May of 1990. From 2008 through April 2012, I worked as a Senior Manager of System Operations in charge of supervising the FPL Transmission System Operation personnel to ensure safe, reliable operation of the FPL Bulk Electric System (“BES”) in compliance with NERC Reliability Standards. During this time, my primary duties and

1 responsibilities included the operation and coordination of the FPL  
2 Generation, Transmission, and Substation system in order to provide reliable  
3 service to FPL's customers in an efficient manner. In this role, I ensured on-  
4 going personnel training needs were met on all processes and procedures  
5 necessary to maintain situational awareness during normal and emergency  
6 conditions.

7 **Q. Are you sponsoring any exhibits in this case?**

8 A. Yes. I am sponsoring Exhibits FP-1 through FP-4, which are attached to my  
9 direct testimony.

- 10 • Exhibit FP-1 FPL Electric Facilities Map (FPL general map)
- 11 • Exhibit FP-2 Map of Study Area with Existing Facilities and SWP
- 12 • Exhibit FP-3 Sweatt-Whidden Expected Construction Schedule
- 13 • Exhibit FP-4 List of Contingencies

14 **Q. What is the purpose of your testimony?**

15 A. The purpose of my testimony is to sponsor and support FPL's request for a  
16 determination of need for the Sweatt-Whidden 230kV Transmission Project  
17 ("SWP" or "Project"). Specifically, my testimony presents the following  
18 information in support of the SWP:

- 19 • General overview of the FPL transmission system
- 20 • A general description of the SWP including the design and operating  
21 voltage of the proposed transmission line, the starting and ending  
22 points of the line, the approximate cost of the SWP, and the projected  
23 in-service date

- 1           • The specific conditions, contingencies, and factors which demonstrate
- 2           the need for the SWP, including a discussion of FPL's transmission
- 3           planning process and the reliability benefits of the SWP
- 4           • The alternatives to the SWP that were evaluated and rejected by FPL
- 5           in favor of the SWP
- 6           • The adverse consequences to FPL's electric system and customers if
- 7           the SWP is delayed or denied.

8   **Q.   Please summarize your testimony.**

9   A.   FPL is proposing to build a new 230kV transmission line extending from

10       FPL's Sweatt Substation in Okeechobee County to FPL's Whidden Substation

11       in DeSoto County. This transmission line would convert portions of FPL's

12       existing Okeechobee-Whidden 69kV line to address the anticipated reliability

13       limitations beginning in 2025, which were identified in FPL's transmission

14       planning process. An analysis of transmission alternatives resulted in FPL's

15       selection of the project as the most cost-effective and efficient means to: (a)

16       improve reliability for FPL customers served from the existing 69kV circuit

17       between Okeechobee and Whidden Substations; (b) increase east to west

18       power transfer capabilities of the transmission network by providing a

19       resilient, hardened 230kV circuit between the east and west areas of FPL's

20       territory north of Lake Okeechobee; (c) relieve potential overloads and low

21       voltage conditions under contingency events; and (d) reduce line loading on

22       existing transmission circuits. The project is the most cost-effective

23       alternative, taking into account the demand for electricity, enhancing electric

1 system reliability and integrity, and addressing the need for abundant, low-  
2 cost electrical energy to assure the economic well-being of the citizens of this  
3 state. Furthermore, the project meets area load requirements by serving  
4 existing customers and allowing for future industrial, commercial, and  
5 residential load growth. The estimated construction cost for the project is  
6 \$213.5 million. The final cost of the project is subject to the ultimate line  
7 routing, length, and conditions of certification required by the Transmission  
8 Line Siting Board. FPL asserts that the estimated cost of the project is  
9 reasonable, and the transmission line will assure the economic well-being of  
10 the citizens of the state by providing electric service to projected new load in  
11 the region and improving the region's electric reliability by minimizing the  
12 region's exposure to double contingency events.

## 14 II. OVERVIEW OF FPL'S TRANSMISSION SYSTEM

16 **Q. Please describe FPL's transmission system.**

17 A. The FPL transmission system is comprised of approximately 9,174 circuit  
18 miles of transmission lines and 828 substations which integrate FPL's  
19 generation and distribution system. FPL transmission system interconnects  
20 with a larger transmission network that includes other utilities in Florida and  
21 the Eastern Interconnection ("EI") transmission network. The EI is a  
22 transmission network which provides electrical energy to a large area of the  
23 United States from the Great Plains to the Atlantic Ocean and also includes  
24 four Canadian provinces. The EI has multiple points of interconnection with

1 other utilities that enable power to be exchanged during planned and  
2 unplanned scenarios.

3 **Q. How does FPL design its transmission system?**

4 A. The FPL transmission system is designed to integrate all of FPL's generation  
5 resources to serve FPL's customers and to meet FPL's firm long-term  
6 transmission service obligations in a reliable and cost-effective manner. FPL  
7 plans, designs, and operates its transmission system to comply with NERC  
8 Reliability Standards. The Transmission System Planning Performance  
9 Requirements Reliability Standard (TPL-001-4) defines scenarios and  
10 expected levels of system performance that the BES should comply with in  
11 the long-term planning horizon.

12 **Q. Please provide a brief description of the existing load and electric**  
13 **characteristics.**

14 A. FPL's load characteristics consist primarily of residential and commercial  
15 load with limited industrial load. FPL's summer peak demand in recent years  
16 has been as high as 24,499 MW and the winter peak demand has been as high  
17 as 19,718 MW, serving approximately 5.7 million customers. An overview of  
18 FPL's existing electrical transmission network indicating the general location  
19 of generating plants, substations, and transmission lines is shown in Exhibit  
20 FP-1.





1 potential overloads and low voltage conditions under contingency events; and  
2 (d) reduce line loading on existing transmission circuits.

3

4 Exhibit FP-2 is a map showing the SWP corridor route, along with the  
5 existing electrical facilities in the area. The corridor route is conceptual and  
6 for illustrative purposes only. The ultimate route will be selected through the  
7 TLSA process.

8 **Q. What is FPL's timetable for licensing, design, and construction of the**  
9 **SWP?**

10 A. For an indicative schedule of licensing, design, and construction, please see  
11 Exhibit FP-3.

12 **Q. What is FPL's estimated construction cost of the SWP?**

13 A. The estimated construction cost of the SWP is \$213.5 million (\$226.4 million  
14 CPVRR).

15 **Q. What is the proposed in-service date for the SWP?**

16 A. The projected in-service date is December 2025.

17

#### 18 **IV. FPL PLANNING PROCESS**

19

20 **Q. How does FPL determine the need for new transmission lines?**

21 A. FPL identifies and analyzes the need for new transmission lines through its  
22 transmission planning process. The transmission planning process consists of  
23 five major steps: (1) the preparation of system models, (2) the assessment of the  
24 transmission system performance to comply with NERC Reliability Standards,

1 (3) the development and evaluation of transmission expansion alternatives, (4)  
2 the selection and approval of the preferred alternatives, and (5) the  
3 incorporation of the expansion plan into the Florida Reliability Coordinating  
4 Council (“FRCC”) Regional Planning Process.

5  
6 FPL plans, designs, and operates its transmission system to comply with  
7 NERC Reliability Standards. The TPL-001-4 defines scenarios and expected  
8 levels of system performance that the BES must comply with in the long-term  
9 planning horizon. In general, the system will remain stable and both thermal  
10 and voltage limits will be within applicable facility ratings for each of the  
11 contingency categories listed on Table 1 of TPL-001-4. In addition to the  
12 NERC reliability standards, FPL proposes projects in the short-term planning  
13 horizon to address additional changes across the BES. These include changes  
14 of power transfers across areas associated with transmission service, generator  
15 interconnection requests or generation retirements, potential generation-to-  
16 load area imbalance, and improvements to the overall reliability of the BES,  
17 such as providing loop service to customers and the addition of relay points on  
18 transmission lines with several distribution stations. The planned transmission  
19 system, with its expected loads and transfers, must be stable and within  
20 applicable ratings for all categories of contingency scenarios.

21

1           The design of new transmission connections should consider and minimize, to  
2           the extent practical, the adverse consequences of all contingency categories  
3           and improve system reliability.

4   **Q.    Did FPL perform any studies to determine the need for the SWP?**

5   A.    Yes. Transmission assessment studies were conducted by FPL in 2021. These  
6           studies identified potential system limitations that will require reliability  
7           improvements for Okeechobee, Highlands, DeSoto, Collier, Lee, Sarasota,  
8           and Manatee Counties. The studies also identified that by 2025, customer  
9           demand is increasing generation imbalance in the West Region of FPL's  
10          territory which can be alleviated by increasing the transfer capability into the  
11          area. Currently, the east to west power transfer capability under several  
12          contingency scenarios, such as generation unavailability and loss of the  
13          existing cross state 500kV transmission line, is limited and the existing 69kV  
14          line is operating normally open to avoid potential thermal overloads and  
15          unacceptable voltage levels.

16   **Q.    Please describe the contingencies that support the need for reliability**  
17          **improvements and increased transfer capacity.**

18   A.    FPL transmission assessment studies identified the contingency events shown  
19          in Exhibit FP-4 as the most critical scenarios for the Project Service Area.

20

## 21                                   **V.    NEED FOR THE PROJECT**

22

23   **Q.    Please explain the need for the SWP.**

24   A.    The need for the SWP is based on the following considerations:

- 1           • The need to improve reliability for FPL customers served from the
- 2           existing 69kV circuit between Okeechobee and Whidden substations;
- 3           • The need to provide an additional transmission path to increase east to
- 4           west power transfer capabilities; and
- 5           • The need to mitigate potential overloads and low voltage conditions
- 6           under contingency events.

7           The existing Okeechobee-Whidden 69kV line is operated in a radial  
8           configuration due to contingency loading limitations, with a normal open  
9           switch at Childs 69kV substation. As a result of the radial configuration,  
10          customers along this line have experienced service interruptions for single  
11          contingency scenarios in the transmission system. As discussed previously,  
12          transmission assessment studies conducted by FPL in 2021 have identified  
13          potential system limitations that will require reliability improvements for  
14          Okeechobee, Highlands, DeSoto, Collier, Lee, Sarasota, and Manatee  
15          Counties. These studies have also identified that by 2025, customer demand is  
16          increasing generation imbalance in the West Region. The east to west power  
17          transfer capability under several contingency scenarios is limited, supporting  
18          the need for an additional transmission path.

19   **Q.    Please explain the benefits of the SWP.**

20   A.    The construction of the SWP provides the following benefits to the Project  
21   Service Area:

- 22          • Provides a more reliable delivery of power to FPL customers now and
- 23          into the future while addressing future customer load growth.

- 1                   • Substantially mitigates customer impacts during contingency events.
- 2                   • Provides resilient, hardened transmission service to the area.
- 3                   • Improves voltage support in the area to efficiently and effectively
- 4                   serve existing and future customers in FPL distribution substations
- 5                   along the route of the project.
- 6                   • Increases east to west power transfer capabilities of the transmission
- 7                   network by providing an additional circuit between the east and west
- 8                   areas of FPL's territory north of Lake Okeechobee. The increase in
- 9                   east to west transfer capability helps support customers in the
- 10                  populated areas of the southwest portion of the FPL service territory
- 11                  under several contingency situations that could occur during high
- 12                  customer demand periods and/or storm situations.
- 13                  • Reduces line loading on existing transmission circuits.
- 14                  • Reduces transmission losses by approximately 3 MW at peak load
- 15                  levels and approximately 2 MW at off peak load levels.
- 16                  • Meets the Project Service Area's long-term reliability requirements.

17   **Q.    Is the SWP the most cost-effective alternative to meet the identified need**  
18   **based on the criteria in the applicable transmission line need**  
19   **determination statute, Section 403.537, Florida Statutes?**

20   A.    Yes. For the reasons discussed in my testimony, the SWP is the most cost-  
21   effective alternative, taking into account the demand for electricity, enhancing  
22   electric system reliability and integrity, and addressing the need for abundant,

1 low-cost electrical energy to assure the economic well-being of the citizens of  
2 this state.

3

4 **VI. DISCUSSION OF TRANSMISSION ALTERNATIVES**

5

6 **Q. Did FPL consider transmission alternatives to the SWP?**

7 A. Yes, FPL considered transmission alternatives to the SWP to meet the  
8 identified need.

9 **Q. Please describe the transmission alternatives that were considered and**  
10 **explain the reasons why they were rejected.**

11 A. FPL evaluated two transmission alternatives to the proposed SWP Project.

12 **Alternative I:** The Ft. Drum-Whidden Project consists of a new 230kV  
13 transmission line extending from FPL's Ft. Drum substation in Indian River  
14 County to FPL's Whidden substation in DeSoto County. The estimated  
15 construction cost of this alternative is \$283.9 million (\$300.3 million  
16 CPVRR). This alternative was rejected for the following reasons: 1) it does  
17 not provide the needed reliability improvements for all customers served from  
18 the existing 69kV circuit between Okeechobee and Whidden substations, 2)  
19 the cost of the alternative is approximately \$70 million higher than the SWP,  
20 and 3) this alternative does not provide for future transmission network  
21 flexibility, nor does it substantially improve reliability in the Project Service  
22 Area because it only allows for reconfiguration of existing infrastructure on  
23 the 69kV network.

24

1        **Alternative II:** The Martin-Whidden Project consists of a new 230kV  
2        transmission line extending from FPL’s Martin substation in Martin County,  
3        to FPL’s Whidden substation in DeSoto County. The estimated construction  
4        cost of this alternative is \$223.3 million (236.5 million CPVRR). This  
5        alternative was rejected for the following reasons: 1) does not provide the  
6        needed reliability improvements for all customers served from the existing  
7        69kV circuit between Okeechobee and Whidden substations, 2) the cost of the  
8        alternative is approximately \$10 million higher than the SWP, and 3) this  
9        alternative does not substantially improve reliability in the Project Service  
10       Area because it only allows for reconfiguration of existing infrastructure on  
11       the 69kV network.

12  
13       **VII.    ADVERSE CONSEQUENCES OF DELAY OR DENIAL OF THE SWP**

14  
15       **Q.        Would there be adverse consequences to FPL’s customers in the SWP**  
16       **Service Area if the SWP is not timely approved?**

17       A.        Yes. If the SWP is not built by December 2025, then sufficient transmission  
18       capacity would not be available to serve the existing and future industrial,  
19       commercial, and residential customers in the Project Service Area and, by  
20       virtue of the current radial transmission service configuration, system  
21       reliability and integrity would not be at the same level delivered to other FPL  
22       customers, which have normal looped transmission service.

1   **Q.     Should the Florida Public Service Commission (“Commission”) approve**  
2       **the need for the SWP?**


3   A.     Yes. For all the reasons described above, the Commission should determine  
4       that there is a need for the Sweatt-Whidden 230kV transmission line to  
5       preserve electric system reliability and integrity in the area and to maintain  
6       low-cost electrical energy for the economic well-being of the residents of  
7       Florida.

8   **Q.     Does this conclude your direct testimony?**

9   A.     Yes.



# FPL Substation and Transmission System Configuration



**Exhibit FP-2 is Confidential in Its Entirety**  
**(Bates No. 000018)**

**Sweatt-Whidden Expected Construction Schedule**

<b>Milestone</b>	<b>Begin</b>	<b>End</b>
TLSA/Need Determination Process (DEP must receive FPSC Need Determination approval by 8/1/22)	Apr, 2022	Apr, 2023
Transmission Line and ROW Design & Material Orders	Jan, 2022	Oct, 2023
Substation Design & Material Orders	Jan, 2022	Oct, 2023
Permitting (station & line)	Apr, 2022	May, 2024
Whidden Site Preparation	N/A	N/A
Sweatt Site Preparation	Oct, 2023	Apr, 2024
ROW Engineering/Surveying	Aug, 2022	Apr, 2023
ROW Acquisition	May, 2023	Dec, 2024
Transmission Line ROW Preparation	Jun, 2024	Mar, 2025
Substation Construction (Sweatt, Whidden)	Jan, 2024	Nov, 2025
Transmission Line Construction	Sept, 2024	Nov, 2025
In-service/Commissioning	-	Dec, 2025

**Exhibit FP-4 is Confidential in Its Entirety**  
**(Bates No. 000019)**