

Zone	Op Center	County	Project	Sub Category	Project Status	Project #	Costs	Number of Units
North Coastal	Inverness	Citrus	Storm Hardening Dixie Shores Subdivision, Crystal River.	Submersible UG Transformers	Completed 2021	MX0128072	\$ 213,294	24
South Coastal	WALSM		GIP_LFSG_PMH-9_J229_J265	Submersible Switchgear	2020	29065515	\$ 34,731	1
North Coastal	MONTI		SWITHGEAR RUSTED AND UNSAFE REPLACE IN NEW LOCATION	Submersible Switchgear	2021	29520384	\$ 46	1
North Coastal	MONTI		Replace VFI switchgear RUSTED NOT SAFE TO WORK REPLACE IN PLACE	Submersible Switchgear	2021	29522801	\$ 33,565	1
South Coastal	CLWTR		REPLACE ESCO WITH G&W for RA 240	Submersible Switchgear	2020	30091770	\$ 4,991	1
South Coastal	SPETE		(HOLD) GSR: SWG PME-9 L for Submersible REPLACEMENT SWG X2964 and X2965	Submersible Switchgear	2021	35002887	\$ 10,768	1
North Coastal	SEVSP		3/16 GIS*Replace VFI C5944 switchgear leaking oil	Submersible Switchgear	2020	35123111	\$ 652	1
North Coastal	SEVSP		3/8 GIS*Replace VFI C5928 seeping oil.	Submersible Switchgear	2020	35123560	\$ 15,316	1