

T

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION
PREPARED DIRECT TESTIMONY OF
JOHN E. ODOM, JR.
ON BEHALF OF FLORIDA POWER CORPORATION
DOCKET NO. 910578-EI
June 19, 1991

**ORIGINAL
FILE COPY**

Introduction and Qualifications

Q. Please state your name, business address and occupation.

A. My name is John E. Odom, Jr. and my business address is 3201 34th St. South, St. Petersburg, Florida 33711. I am a Senior Transmission & Distribution Planning Engineer in the System Planning Department at Florida Power Corporation.

Q. What are your duties and responsibilities in that position?

A. As a planning engineer, I am responsible for identifying the future transmission needs of FPC with adequate lead time to allow for the licensing, engineering and construction of new transmission or substation projects. I am currently the area planner responsible for evaluating the transmission system within FPC's

1 **Mid-Florida Division, including interconnections**
2 **with other divisions and utilities. In addition,**
3 **I am involved in special projects on an as-needed**
4 **basis.**

5
6 **Q. Please summarize your educational background.**

7 **A. I graduated from Lake-Sumter Community College**
8 **with an Associate of Arts Degree in 1975, and from**
9 **University of Central Florida with a Bachelor of**
10 **Science in Engineering Degree in 1979.**

11

12 **Q. Please summarize your professional experience.**

13 **A. I have approximately five years of Design**
14 **Engineering experience and seven and one-half**
15 **years of System Planning experience, all with**
16 **Florida Power Corporation.**

17

18 **Q. Are you a member of any professional organizations**
19 **or industry groups?**

20 **A. Yes, I am a registered Professional Engineer in**
21 **the State of Florida. In addition, I am a member**
22 **of the Power Engineering Society of the IEEE. I**
23 **am also a member of the Application of Probability**
24 **Methods Subcommittee of that Society's Power**
25 **System Engineering Committee.**

1 Q. Have you previously testified before this
2 Commission?

3 A. Yes. In August, 1987, I testified on substation
4 and transmission issues in a territorial dispute
5 between FPC and Suwannee Valley Electric
6 Cooperative, Inc. (Docket No. 870096-EU).

7

8 **Purpose of Testimony**

9 Q. What is the purpose of your testimony?

10 A. The purpose of my testimony is to describe the
11 technical aspects of the DeBary-Winter Springs
12 230 kV transmission line (the "Project") and to
13 demonstrate FPC's need for the Project. I will
14 explain FPC's transmission planning process,
15 including our transmission reliability criteria.
16 I will describe why additional 230 kV transmission
17 is needed by the end of 1995 to maintain
18 acceptable transmission reliability in the Greater
19 Orlando Area and to enable FPC to reliably
20 disperse power from future CTs that may be added
21 at the DeBary Generating site. I will explain how
22 FPC determined that the Project is the best
23 alternative to meet these needs, and will describe
24 other benefits that the Project provides. I will
25 also explain the adverse consequences to FPC and

1 its customers if approval of the Project is
2 delayed or denied.

3

4 **Q. Are you sponsoring any exhibits as part of your**
5 **testimony?**

6 **A. Yes. Exhibit ____ (JEO-1) is the report titled**
7 **"Determination of Need for DeBary-Winter Springs**
8 **230 kV Transmission Project" that was filed in**
9 **this docket on June 3, 1991. I have also prepared**
10 **Exhibits ____ (JEO-2) to ____ (JEO-4), which are**
11 **attached to this testimony.**

12

13 **Planning Process**

14 **Q. Please describe FPC's transmission planning**
15 **process.**

16 **A. FPC conducts a comprehensive transmission study**
17 **each year to identify future transmission**
18 **improvements needed to maintain acceptable**
19 **transmission reliability. In addition, we conduct**
20 **special studies on an as-needed basis when**
21 **significant changes occur that could impact the**
22 **current plan. FPC uses the Multiple Contingency**
23 **Load Flow (MCLF) program to identify areas of**
24 **concern. This program models the outage of**
25 **individual transmission lines or transformers at**

1 various load levels to identify areas that need
2 further review. Once an area of concern has been
3 identified, a planning engineer conducts an in-
4 depth analysis of the area. This analysis
5 determines the extent of the problem, identifies
6 and evaluates possible solutions, and selects a
7 recommended alternative for inclusion in FPC's
8 capital facilities plan.

9
10 Q. Please explain the reliability criteria used as
11 the basis for planning FPC's transmission system.

12 A. FPC has developed various criteria, consistent
13 with Florida Electric Power Coordinating Group
14 (FPCG) Planning Criteria, to ensure that the
15 transmission system will perform in a reliable
16 manner. FPC designs its transmission system so
17 that, under normal conditions (i.e., with no
18 transmission or transformer outages), the flow on
19 any line or transformer will be below its normal
20 rating. This criteria must be met for any
21 reasonable generation dispatch, including
22 situations where any single generating unit is out
23 of service for scheduled maintenance. Therefore,
24 a single generating unit outage is considered to
25 be a normal condition.

1 In addition, the system is designed so that no
2 lines or transformers will exceed their emergency
3 ratings in the event of the loss of any single
4 transmission line or transformer (a "single
5 contingency"). FPC's criteria also provide that
6 the voltages at any bus that serves residential or
7 commercial customers should not drop below 95% of
8 its nominal voltage under single contingency
9 conditions.

10

11 **Q. What other factors are used in assessing**
12 **transmission reliability?**

13 **A. When FPC conducts a study of an area, the planner**
14 **considers other factors that may be important to**
15 **the specific area. These factors may include the**
16 **likely duration of an outage, the remedial action**
17 **that could be taken to react to an outage, the**
18 **possibility that multiple contingencies could**
19 **result from a single event, and the need to**
20 **withstand events that could separate large load**
21 **centers from the sources of generation.**

22

23 **Q. What analyses did you perform in investigating the**
24 **need for the Project?**

1 A. The analysis included an in-depth study of all
2 single 230 kV line outages and any double circuit
3 line outages in the study area as shown on the map
4 attached as Exhibit ____ (JEO-2). This analysis
5 was performed using the FCG and FPC 1990/1991
6 transmission data bases and our computerized load
7 flow program.

8
9 The analysis concentrated on line outages that
10 would cause other lines in the area to overload.
11 The voltage at each bus was also examined;
12 however, this was not a significant factor in the
13 study, since low voltages were not identified as a
14 problem under any single contingency. The study
15 included an examination of how the generation
16 dispatch affected power flows on the transmission
17 system in the study area.

18
19 Need for Project

20 Q. What specific factors show a need for additional
21 transmission in the study area by 1995?

22 A. The study identified two items of concern that
23 indicate a need for transmission improvements by
24 1995. The first is a violation of single
25 contingency criteria that occurs in 1995 when the

1 outage of the Sanford-North Longwood 230 kV line
2 causes the Sanford-Sylvan-North Longwood line to
3 overload and exceed its emergency rating (the
4 "1995 single contingency"). Service to
5 approximately 95,000 customers could be affected
6 by this single contingency. This is the type of
7 single contingency that FPC ordinarily designs its
8 transmission system to withstand.

9
10 The second item of concern is that an outage of
11 the Sanford-Altamonte and Sanford-North Longwood
12 lines, which share common structures for
13 approximately 12 miles, causes a severe
14 overloading of the Sanford-Sylvan-North Longwood
15 line. This double contingency could totally
16 separate the generation at DeBary and at FPL's
17 Sanford Plant from the Greater Orlando Area, and
18 has the potential to impact service to
19 approximately 500,000 customers as the result of a
20 single event (i.e., the loss of a single
21 transmission structure). This particular double
22 circuit outage is a problem that FPC believes
23 should be addressed from a reliability viewpoint,
24 even though our criteria do not require the
25 transmission system to be able to withstand every

1 double contingency. The double-circuit outage
2 problem and the 1995 single contingency are
3 referred to together as the "DeBary-North Longwood
4 corridor violations."
5

6 Q. Are there any other reliability problems in the
7 area that must be addressed?

8 A. Yes. By December, 1997, the outage of the North
9 Longwood-Winter Springs line causes the Stanton-
10 Rio Pinar line to reach its emergency rating (the
11 "1997 single contingency" or the "Stanton-Rio
12 Pinar violation"). Service to approximately
13 16,000 customers could be affected by this single
14 contingency. Again, this is the type of single
15 contingency that FPC's system is typically
16 designed to withstand.
17

18 Finally, by December, 1997, the single contingency
19 loss of the Rio Pinar-Stanton line will cause the
20 North Longwood-Winter Springs line to exceed its
21 normal rating, requiring corrective action that
22 could affect service to approximately 8,000
23 customers.
24

- 1 **Q. How does the Project address these reliability**
2 **problems?**
- 3 **A. The Project strengthens the 230 kV system so that**
4 **it can withstand either the 1995 or 1997 single**
5 **contingency without causing any transmission line**
6 **in the area to exceed its normal rating. The**
7 **Project also addresses the double circuit outage**
8 **situation by significantly reducing the overload**
9 **on the Sanford-Sylvan-North Longwood line. While**
10 **the overloading is not eliminated, the improvement**
11 **will give FPC's system dispatchers more time to**
12 **respond to such an outage in a controlled manner.**
13 **The results of these studies, showing line**
14 **loadings with and without the Project, are**
15 **presented in the table attached as Exhibit ____**
16 **(JEO-3). Detailed load flow plots are contained**
17 **in Appendices H and I of Exhibit ____ (JEO-1).**
18
- 19 **Q. How was the possible need to add CT capacity at**
20 **the DeBary Generating site included in your**
21 **analysis?**
- 22 **A. As Mr. Foley has testified, FPC needs the ability**
23 **to add combustion turbine (CT) capacity to its**
24 **system on short notice. The study therefore**
25 **included an analysis of the impact of additional**

1 generation at DeBary, beyond the 340 MW being
2 added at the site in 1992. The analysis showed
3 that by 1992 the DeBary site will be transmission-
4 limited, such that the addition of as little as
5 150 MW of new generation at the site without
6 transmission improvements would cause the system
7 to violate single contingency criteria. By adding
8 a third circuit from the site to the load area in
9 the south, the Project enables up to 450 MW of
10 generation to be added at the DeBary site without
11 adverse transmission system consequences.

12

13 Mr. Foley discusses the various planning
14 contingencies that could result in the need to
15 locate additional combustion turbines at the
16 DeBary site on short notice.

17

18 Q. Does the Project provide any other benefits?

19 A. Yes, in addition to (1) solving the 1995 single
20 contingency, (2) addressing the double circuit
21 outage problem, (3) preventing the 1997 single
22 contingency violation, and (4) supporting 450 MW
23 of additional CT capacity at the DeBary site, the
24 Project provides two other benefits. First, the
25 Project provides the ability to reliably transfer

1 more power from the electrical sources at DeBary
2 and FPL's Sanford Plant into the Greater Orlando
3 Area. Second, the Project makes the Winter
4 Springs Substation a strong source that will
5 support a 230 kV extension to the south and east
6 to provide a new source for the underlying 69 kV
7 network in the future.

8

9 Alternatives

10 Q. Did FPC examine any alternatives to the Project?

11 A. Yes.

12

13 Q. Please summarize those alternatives.

14 A. FPC identified transmission improvements that,
15 singly or in combination, could meet all of the
16 needs that are addressed by the Project. The
17 alternatives fell into three groups:

18 Group A: Alternatives that address the DeBary-
19 North Longwood corridor violations, the Stanton-
20 Rio Pinar violation, and support additional
21 generation at the DeBary site.

22 Group B: Alternatives that address the DeBary-
23 North Longwood Corridor violations and support
24 additional capacity at DeBary.

1 **Group C:** Alternatives that correct the Stanton-
2 Rio Pinar violation.
3 Each alternative is shown on the table attached as
4 Exhibit ____ (JEO-4). The alternatives in Group B
5 and Group C do not address all of the needs the
6 line is designed to address. The only options
7 that address all of the needs are the Project and
8 the DeBary-Winter Park East line (Group A), and
9 combinations of one project from Group B and one
10 project from Group C.

11

12 **Q.** How did you conclude that the Project is the best
13 of the available alternatives?

14 **A.** Each alternative (or combination of alternatives)
15 that meets all of the needs was evaluated based on
16 cost and technical factors. The only single-line
17 alternative that provided the same benefits is the
18 DeBary-Winter Park East line. This alternative is
19 essentially a longer and more expensive version of
20 the Project. This alternative was rejected
21 because the added cost did not provide any
22 additional benefits. Each of the two-line
23 alternatives was more expensive than the Project,
24 and none of them were as desirable from a
25 technical viewpoint. The Project was therefore

1 **selected as the best solution from both a**
2 **technical and cost perspective.**

3

4 **Project Details**

5 **Q. What is the FPC's timetable for licensing, design**
6 **and construction of the Project?**

7 **A. FPC is presently evaluating corridors in**
8 **anticipation of submitting an application under**
9 **the Transmission Line Siting Act (TLSA) by**
10 **December, 1991. The final action by the Siting**
11 **Board is expected by October, 1992. Detailed**
12 **design of the Project will begin as soon as a**
13 **final corridor is approved. Construction is**
14 **expected to begin in June, 1994 and to be**
15 **completed by December, 1995. A licensing and**
16 **construction timetable for the Project is**
17 **contained in Appendix B of Exhibit ____ (JEO-1).**

18

19 **Q. What is the current status of corridor selection**
20 **for the Project?**

21 **A. FPC's permitting team, in conjunction with its**
22 **consultants, has examined a large number of**
23 **possible corridors using a series of**
24 **environmental, land use, cost, reliability, and**
25 **other criteria. Although no final decision on the**

1 preferred corridor or corridors has been made, the
2 most promising candidate corridors make extensive
3 use of existing transmission line rights-of-way.
4

5 **Q. Please provide FPC's capital cost estimate for the**
6 **Project and describe the assumptions on which the**
7 **estimate is based.**

8 **A. The Project is estimated to cost approximately**
9 **\$14 million in 1995 dollars, although the cost**
10 **could range from approximately \$12 million to**
11 **approximately \$16 million depending on the final**
12 **corridor approved under the TLSA. This estimate**
13 **incorporates all costs, including transmission**
14 **design and construction, right-of-way acquisition,**
15 **terminations at DeBary Substation and the Winter**
16 **Springs Substation, and the cost to convert the**
17 **Lake Emma Substation from a 115/13 kV substation**
18 **to a 230/13 kV substation. This conversion cost**
19 **is included because several of the possible siting**
20 **options use an existing 115 kV transmission line**
21 **right-of-way for a portion of the Project. If one**
22 **of these corridors is selected, the existing line**
23 **would be removed and the Lake Emma Substation**
24 **would need to be converted. Many of the options**
25 **that do not include routing through the Lake Emma**

1 Substation have other offsetting costs, and the
2 estimated costs for the top ten routes are all
3 within the \$12 to \$16 million range. This
4 compares with an estimated cost of \$17 million to
5 \$31 million for the alternatives discussed above
6 and shown on Exhibit ____ (JEO-4).

7

8 **Q.** What assurance can FPC give that the actual cost
9 of the Project will not exceed the current
10 estimate?

11 **A.** FPC cannot give any absolute assurance as to the
12 final installed cost of the line. While the
13 estimate is the most accurate one possible at this
14 time, the final route has not been selected and a
15 number of factors beyond FPC's control can affect
16 the final cost of the line. These include: the
17 determination of the final length and routing of
18 the line in further proceedings under the TLSA;
19 any costs required to comply with unexpected
20 conditions that may be imposed through the TLSA
21 process; and unexpected changes in materials or
22 labor costs.

1 **Consequences of Delay or Denial**

2 **Q. What would be the consequences to FPC and its**
3 **customers if the approval of the Project was**
4 **delayed?**

5 **A. The consequences would depend in part on the**
6 **length of the delay. Any delay of more than a few**
7 **months in obtaining final approval by the Siting**
8 **Board could delay the in-service date of the**
9 **Project on a month-for-month basis. Any in-**
10 **service delay would expose FPC's customers to the**
11 **possibility of losing service in the event of the**
12 **single contingency outage of the Sanford-North**
13 **Longwood line beginning in winter 1995. In**
14 **addition, such a delay would extend the period**
15 **during which the double circuit outage could cause**
16 **severe outages in the Greater Orlando Area, and**
17 **would delay the date that CTs could be added at**
18 **the DeBary site without violating single**
19 **contingency criteria.**

20

21 **An in-service delay of two years or more would**
22 **expose FPC's customers to the possibility of**
23 **losing service in the event of the outage of the**
24 **Stanton-Rio Pinar 230 kV line, in addition to all**
25 **of the consequences of a shorter delay.**

1 Q. What would be the impact if certification of the
2 line was denied?

3 A. Because FPC will violate single contingency
4 criteria by 1995 without the Project, doing
5 nothing is not an alternative. If certification
6 was denied, FPC would be required to address its
7 customers' needs with a longer, more costly, less
8 desirable alternative or combination of
9 alternatives.

10

11 **SUMMARY**

12 Q. Please summarize your testimony.

13 A. The DeBary-Winter Springs transmission line is
14 needed for a variety of reasons. By December
15 1995, a single transmission line outage would
16 cause a transmission line to overload. In
17 addition, by December 1997, a different single
18 transmission line outage would result in a second
19 transmission line overload. The Project corrects
20 both of these problems, as well as minimizing the
21 effect of a double-circuit outage that would cause
22 widespread outages. In addition, the Project will
23 allow FPC a great deal of flexibility in how it
24 meets the energy needs of its customers. This
25 line provides that flexibility in two ways. The

1 first way is by eliminating the transmission
2 limitation at the DeBary Generating Plant. This
3 provides FPC with the option of installation of
4 generation at DeBary on short notice if that is
5 the most prudent, cost-effective thing to do.
6 This Project also provides flexibility by
7 providing a starting point for an extension of the
8 230 kV transmission system to the south and east
9 that will provide needed support for the existing
10 and future 69 kV system.


11

12 Q. Does that conclude your testimony?

13 A. Yes.

14

DEBARY-WINTER SPRINGS PROJECT STUDY AREA



Florida Power Corporation
Docket No. 910578-EI
Witness: Odom
Exhibit ___ (JEO-3)

**LOAD FLOWS BEFORE AND AFTER
DEBARY-WINTER SPRINGS PROJECT**

CASE	OUTAGE	ADVERSELY AFFECTED LINE	% OF EMERGENCY RATING		% OF NORMAL RATING	
			WITHOUT PROJECT	WITH PROJECT	WITHOUT PROJECT	WITH PROJECT
1995 WINTER	Sanford-No. Longwood	Sanford-Sylvan- No. Longwood	109%	80%	134%	98%
	Sanford-Altamonte & Sanford-No. Longwood (Double-Circuit)	Sanford-Sylvan- No. Longwood	169%	117%	207%	144%
1995 WINTER PLUS 150 MW	Sanford-No. Longwood	Sanford-Sylvan- No. Longwood	115%	83%	140%	102%
	DeBary-Sanford Circuit #1	DeBary-Sanford Circuit #2	107%	56%	123%	65%
	Sanford-Altamonte & Sanford-No. Longwood (Double-Circuit)	Sanford-Sylvan- No. Longwood	177%	123%	217%	150%
1997 WINTER	No. Longwood-Winter Springs	Rio Pinar-OUC Stanton	100%	59%	120%	70%
	Rio Pinar-OUC Stanton	No. Longwood-Winter Springs	93%	44%	107%	51%

Florida Power Corporation
Docket No. 910578-EI
Witness: Odom
Exhibit ___ (JEO-4)

COMPARISON OF ALTERNATIVES

Name Length (Miles±)	Cost (000,000)	DeBary-North Longwood Corridor Violations		Support DeBary CTs	Rio Pinar- Stanton	Other Factors
		Correct 1995 Single Contingency	Address Double Contingency		Correct 1997 Single Contingency	
GROUP A						
THE PROJECT: DeBary-Winter Springs (20)	\$ 14	Yes	Yes	Yes	Yes	Option Selected
DeBary-Winter Park E. (24)	\$ 17	Yes	Yes	Yes	Yes	Longer version of DeBary-Winter Springs
GROUP B						
DeBary-North Longwood (15)	\$ 12	Yes	Yes	Partly	No	A segment of the Project; adds third source to N. Longwood
DeBary-Piedmont (24)	\$ 21	Yes	Yes	Partly	No	Site limited by adjacent development
DeBary-Sorrento (20)	\$ 12	Yes	Yes	Partly	No	
GROUP C						
North Longwood-Winter Springs (5)	\$ 5	No	No	No	Yes	A segment of the Project
Altamonte-Winter Park East (8)	\$ 7	No	No	No	Yes	
OUC Stanton-Rio Pinar (11)	\$ 10	No	No	No	Yes	Does not enhance North to South flow of power