

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26

**ORIGINAL  
FILE COPY**

**PREFILED REBUTTAL TESTIMONY  
OF  
GERALD C. HARTMAN, P.E.  
BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION  
ON BEHALF OF SOUTHERN STATES UTILITIES, INC.  
DOCKET NO. 920199-WS**

1 Q. PLEASE STATE YOUR NAME AND BUSINESS ADDRESS.

2 A. My name is Gerald C. Hartman. My business address  
3 is Hartman & Associates, Inc., 201 East Pine Street,  
4 Suite 1000, Orlando, Florida 32801.

5 Q. ARE YOU THE SAME GERALD C. HARTMAN WHO SUBMITTED  
6 PREFILED DIRECT TESTIMONY IN THIS PROCEEDING?

7 A. Yes, I am.

8 Q. WHAT IS THE PURPOSE OF YOUR REBUTTAL TESTIMONY IN  
9 THE PROCEEDING?

10 A. The purpose of my rebuttal testimony is to rebut  
11 certain points of the prefiled direct testimonies  
12 of Kimberly H. Dismukes, Legislative Analyst III  
13 with the Office of the Public Counsel, Jerrold E.  
14 Chapdelaine, a Utilities Systems/Communications  
15 Engineer with the Staff of the Florida Public  
16 Service Commission, Gregory L. Shafer, Bureau Chief  
17 in the Special Assistance Bureau of the Staff of the  
18 Florida Public Service Commission and Harry C.  
19 Jones, President of the Cypress and Oak Villages  
20 Association in Sugar Mill Woods. In addition, I  
21 will be addressing several other issues that have  
22 been raised via the interrogatories, request for  
23 production of documents and the depositions that  
24 have taken place thus far in this proceeding.

25 Q. WHAT DO YOU WISH TO REBUT CONCERNING MS. DISMUKES'

1           **PREFILED DIRECT TESTIMONY?**

2           A.    I wish to discuss Ms. Dismukes' comments concerning  
3                   SSU's method of calculating margin reserve and her  
4                   proposed alternative methods.   SSU calculated the  
5                   margin reserve based upon the historical average  
6                   annual growth in ERC's generally over the last 5  
7                   years.  This growth projection methodology has been  
8                   the generally accepted method that the Florida  
9                   Public Service Commission has been utilizing for a  
10                  number of years.  Only recently have they applied  
11                  an alternative methodology in certain circumstances.  
12                  I will be discussing this alternative methodology  
13                  further in my rebuttal to the testimony of  
14                  Gregory L. Shafer.

15                        Ms. Dismukes states in her prefiled direct  
16                        testimony on pages 27 and 28, starting with lines  
17                        23 and continuing through line 2 of the following  
18                        page, that "in reviewing the information supplied  
19                        by the Company in the MFRs, it appeared that in  
20                        several instances, the historical growth in ERC's  
21                        may not be reflective of the growth that would occur  
22                        during the next year and a half.  Under these  
23                        circumstances, the Company's requested margin  
24                        reserve would be excessive."  First, I would like  
25                        to state that the MFRs were prepared using the

1 standard methodology historically utilized by the  
2 Florida Public Service Commission.

3 Second, there are numerous industry-wide  
4 accepted methodologies for projecting growth, both  
5 in the long term and in the short term. Short term  
6 growth is investigated for purposes of determining  
7 the margin reserve. Certainly, if you will review  
8 some of the percentages of growth in ERC's indicated  
9 on the F-9 and F-10 schedules of the Engineering  
10 MFRs, it appears that growth has decreased over the  
11 last couple of years in some systems and increased  
12 in others. One factor driving a declining growth  
13 is the current state of the economy -- while in  
14 other systems, the availability of desirous housing  
15 may increase growth. Certain systems that SSU  
16 provides service to are seasonal in nature and with  
17 the current condition of the economy, people may  
18 defer the purchase of a second home or the rental  
19 of vacation dwelling units, thus possibly creating  
20 higher levels of growth when economic conditions do  
21 improve.

22 Third, most of the systems in this proceeding  
23 are relatively small systems, and due to that fact  
24 growth can vary dramatically from year to year,  
25 based upon the development trends in the service

1 area. Most of the systems have a current customer  
2 base of less than 1,000 ERC's. Thus, a system may  
3 appear to be at build-out currently, however, if a  
4 new development appears within the service area, for  
5 example, a 100 unit single family residential home  
6 development, growth can quickly increase. The  
7 purpose of the margin reserve is to assist the  
8 utility in being able to provide service to  
9 customers in a timely manner as required by both  
10 the Florida Public Service Commission and DER.  
11 Therefore, historical trends in growth for small  
12 systems do not necessarily indicate what the near  
13 future will bring. Certainly, a very large system,  
14 say 100,000 customers, would have a very steady  
15 growth rate which would not fluctuate as  
16 dramatically as growth may occur on small systems.  
17 For example, most large county and municipal systems  
18 in the State of Florida have growth in the range of  
19 2-3% per year and generally budget based upon those  
20 growth rates. For a large system, the hypothetical  
21 100 unit single family residential development would  
22 have a very small impact upon the growth of the  
23 system as a whole. Typically, the driving factor  
24 behind a declining growth rate, whether it be a  
25 large or small system, is the build-out condition

1 of the service area where no opportunities to expand  
2 that service area are available. With the exception  
3 of just a few systems, this condition does not apply  
4 to most of the SSU systems. Therefore, an average  
5 of the past five (5) year period statewide is the  
6 most reasonable method in my opinion.

7 **Q. WHAT IS THE METHOD THAT MS. DISMUKES HAS PROPOSED**  
8 **FOR DETERMINING MARGIN RESERVE?**

9 **A.** Ms. Dismukes has reviewed the information provided  
10 by Southern States in response to OPC Interrogatory  
11 No. 210. In that response, the Company provided a  
12 summary of projected growth for the years 1992,  
13 1993, and 1994 for all of the water and wastewater  
14 systems in this application. The source of this  
15 data was a report prepared by the Engineering  
16 Department at SSU in March of 1992 to plan for  
17 capital improvements in the next 5 years. This  
18 report was intended for internal Company use only  
19 in preparation for the annual meeting of the Board  
20 of Directors of the parent company. As indicated  
21 in the assumptions section of the report, it states:  
22 "This report takes a macro view of the SSU system  
23 and makes general assumptions for the overall growth  
24 projections." The primary purpose of the  
25 projections was to provide a very conservative

1 estimate of revenues for the purposes of obtaining  
2 capital financing. As described in Mr. Scott W.  
3 Vierima's prefiled direct testimony, the Company had  
4 a difficult time obtaining financing in 1991 due to  
5 the outcome of the 1990 rate application in Docket  
6 No. 900329-WS. Thus, in the Company's current  
7 ongoing efforts to obtain long term capital  
8 financing, it wanted to be very conservative in its  
9 revenue projections in order to not overestimate its  
10 ability to make the debt payments. That is the  
11 source of the information to which Ms. Dismukes is  
12 referring on page 28, lines 5 through 9 of her  
13 testimony. Schedule 5 of Ms. Dismukes Exhibit KHD-  
14 1, page 1 of 1, provides a comparison of 30 selected  
15 water systems and 22 selected wastewater systems of  
16 the 127 systems included in Southern States'  
17 application. She has compared the projected number  
18 of ERC's through the margin reserve period as filed  
19 in the Company's rate application as compared to the  
20 projected number of ERC's based upon the growth  
21 projections indicated in Interrogatory response No.  
22 210R.

23 Ms. Dismukes has selected only 30 of the 90  
24 water systems that are contained in this rate  
25 application. It appears that Ms. Dismukes' criteria

1 for determining which systems to include on her  
2 summary Schedule 5 was that if the margin reserve  
3 projection in the MFRs was greater than the  
4 projection made for the capital improvements report,  
5 it was included in her summary. This is true with  
6 the exception of 3 systems listed in her schedule  
7 5 for which the projected ERC's of the capital  
8 improvement plan are greater than the projected  
9 ERC's in the margin reserve request. Likewise for  
10 the wastewater systems, Ms. Dismukes selected 22 of  
11 the 37 wastewater systems contained in this  
12 application and the same criteria appears to have  
13 been used for selecting those systems. Thus, it  
14 appears that Ms. Dismukes is one-sided in her  
15 approach to calculating margin reserves.

16 Ms. Dismukes provides a detailed discussion  
17 utilizing the Beacon Hill's water system as an  
18 example. The average of the 5 years of historical  
19 growth for the Beacon Hills water system is 12.25%  
20 with the highest growth rate being in 1988 of 22.8%  
21 and declining in 1989 to 13.01%, in 1990 to 6.72%  
22 and in 1991 to 6.48%. I believe that the dramatic  
23 decline between 1989 and 1990 just proves my point  
24 that the economy is certainly a factor in the  
25 decline of growth of systems such as Beacon Hills.



1           The recessionary nature of the economy certainly  
2           began to appear in 1990 and has continued through  
3           to 1992. For the first 9 months of 1992, the  
4           Company's records indicate that there were an  
5           additional 96 ERC's added to the Beacon Hills water  
6           system which equates to 3.5% growth, indicating that  
7           growth is still off. It should be noted that there  
8           is still substantial vacant land within the Beacon  
9           Hills water system service area in which to grow,  
10          thus, the system has not approached build-out at  
11          this time. The capital improvements projection of  
12          growth in 1992 was only 4.7% for the Beacon Hills  
13          water system. Based upon this information, Ms.  
14          Dismukes states that the used and useful percentage  
15          of the supply wells would decline from 69% to 64%  
16          with the use of the lower growth factor. She states  
17          that a similar analysis of the wastewater treatment  
18          used and useful capacity equates to a 5% decline  
19          from 64% to 59%. Of course, I do not agree with  
20          either of these adjustments for the reasons  
21          previously given.

22                 Ms. Dismukes pursues a similar analysis for the  
23          Spring Hill water and wastewater systems. In  
24          summary, she proposes that the margin reserve for  
25          19 of the 90 water systems and 9 of the 37

1 wastewater systems included in this proceeding  
2 should be based upon the Company's capital  
3 improvements projections and not the 5 year  
4 historical average growth rates. As I indicated  
5 previously, this is not correct in light of the size  
6 of the systems and also the current conditions of  
7 the economy which should hopefully improve in the  
8 near future. The whole purpose of margin reserve  
9 is to assure that capacity is available so when  
10 customers request service, service can be provided  
11 immediately. Certainly, if a conservative growth  
12 projection is utilized for the margin reserve and  
13 then growth substantially increases, the Company  
14 will not be able to meet its responsibility to  
15 provide this immediate service and thus will be  
16 providing a reduced level of service to all of its  
17 customers, including existing customers.

18 **Q. MR. HARTMAN, HAVE YOU REVIEWED THE PREFILED DIRECT**  
19 **TESTIMONY OF MR. JERROLD E. CHAPDELAIN FROM THE**  
20 **STAFF OF THE FLORIDA PUBLIC SERVICE COMMISSION AND**  
21 **DO YOU HAVE ANY PRELIMINARY COMMENTS?**

22 **A. Yes, I have reviewed Mr. Chapdelaine's testimony**  
23 **and yes I do have comments concerning it. First,**  
24 **I do not agree with Mr. Chapdelaine's rationale for**  
25 **used and useful adjustments as discussed on the top**

1 of page 3 of his prefiled direct testimony. I  
2 believe that if the condition discussed in Mr.  
3 Chapdelaine's statement is of a no growth,  
4 moratorium, build-out or aberrational service  
5 condition, then there should be no used and useful  
6 adjustment. In the general circumstances cited, he  
7 alleges that even though the service area may be  
8 built-out (or in any of the above stated conditions)  
9 and even where the design capacity of the system has  
10 not been reached, the Company should be penalized  
11 even though the capacity of the system and  
12 facilities constructed were based upon sound  
13 engineering estimates of design loads and spatial  
14 configurations prior to actual connections  
15 occurring. I am aware that in at least one of the  
16 prior cases in which Mr. Chapdelaine testified as  
17 an expert witness (Docket No. 870981-WS, Miles Grant  
18 Water and Sewer Company), the Commission found that  
19 the utility facilities were 100% used and useful  
20 because the service area was at or near build-out  
21 and there was no room for expansion (due to the  
22 system being surrounded by other systems). Thus,  
23 in that case, the "connected load" was less than  
24 the expected build-out or "design load" yet the  
25 Commission found that the facilities were 100% used

1 and useful. I have been informed that there are  
2 numerous instances of similar findings by the  
3 Commission.

4 A utility must stand ready to provide service  
5 and to make prudent decisions regarding investment  
6 in plant necessary to serve its territory in the  
7 context of effective long-range planning as well as  
8 least cost design and construction. I agree that  
9 the used and useful analysis must consider the  
10 factors of least cost design, economies of scale,  
11 long range planning, etc. and these factors should  
12 be reflected in a proper determination.

13 **Q. HAVE YOU REVIEWED FS 367.081(2)(a) REGARDING USED**  
14 **AND USEFUL CALCULATIONS AND THE REQUIREMENT FOR THE**  
15 **COMMISSION TO CONSIDER A REASONABLE TIME FROM THE**  
16 **END OF THE HISTORICAL TEST PERIOD FOR USE OF**  
17 **FACILITIES OR LAND?**

18 **A. Yes, I have. The end of the second sentence in**  
19 **section 367.081(2)(a) merely reflects "property used**  
20 **and useful in the public service." This statute**  
21 **does not prescribe a methodology for the used and**  
22 **useful determination. The final sentence of this**  
23 **statute states: "The Commission shall also consider**  
24 **the investment of the utility in land acquired or**  
25 **facilities constructed or to be constructed in the**

1 public interest within a reasonable time in the  
2 future, not to exceed, unless extended by the  
3 Commission, 24 months from the end of the historical  
4 test period used to set final rates" (emphasis  
5 added).

6 **Q. WHY WAS THE MARGIN OF RESERVE REQUESTED IN THIS CASE**  
7 **LIMITED TO 18 MONTHS FOR WATER AND WASTEWATER PLANTS**  
8 **AND 12 MONTHS FOR UTILITY LINES?**

9 A. I limited the margin of reserve to these time  
10 periods due to the Company's direction not to create  
11 an issue on this point as a result of the  
12 combination of the Commission's adverse ruling in  
13 Docket 900329-WS and the critical need for rate  
14 relief. It should be noted that (1) the 24 month  
15 convention indicated in section 367.081(2)(a) was  
16 not used, (2) no extensions of that period were  
17 requested despite the existence of DER Rule  
18 17-600.405, F.A.C., which confirms that for  
19 wastewater plants, a period in excess of 48 months  
20 would be appropriate, and (3) the period for  
21 designing, permitting, constructing, and placing  
22 water and wastewater plant facilities into service  
23 far exceed the 18 month period commonly used to  
24 establish the margin reserve for water and  
25 wastewater treatment plants.

1 Q. HAVE YOU REVIEWED THE COMMISSION'S RULES REGARDING  
2 USED AND USEFUL METHODOLOGY AND MARGIN RESERVE?

3 A. Yes, I have. To my knowledge, there are no  
4 prescribed methodologies for used and useful or  
5 margin reserve determinations stated in the  
6 Commission's rules. However, Rule 25-30.255,  
7 F.A.C., entitled "Plant and Facilities," sections  
8 (1) and (2) state, respectively, that the utility  
9 "shall design, construct and install its plant in  
10 accordance with accepted engineering practices to  
11 ensure reasonably adequate and safe service to its  
12 customers" (emphasis added) and "shall maintain and  
13 operate its plant and facilities . . . in accordance  
14 with the rules of the Department of Environmental  
15 Regulation" (emphasis added). It is accepted  
16 engineering practice to design and construct water  
17 facilities utilizing the average flow on the maximum  
18 day when sufficient storage is incorporated or the  
19 peaking needs of the water system when sufficient  
20 storage is not incorporated in the system.

21 Q. ON PAGE 4 OF MR. CHAPDELAIN'S PREFILED DIRECT  
22 TESTIMONY, HE SPEAKS BRIEFLY OF "ECONOMIES OF SCALE"  
23 AND THEIR EFFECT ON THE USED AND USEFUL ANALYSIS.  
24 WOULD YOU PLEASE COMMENT ON THESE EFFECTS?

25 A. Economies of scale are an important criteria in the

1 design of water and wastewater facilities. In April  
2 of this year, Hartman and Associates performed a  
3 brief industry-wide evaluation of capital planning  
4 costs and their effects on economies of scale.

5 Q. I SHOW YOU EXHIBIT \_\_\_ (GCH-3) UNDER THE COVER PAGE  
6 ENTITLED "CAPITAL COST CURVES." WAS THIS EXHIBIT  
7 PREPARED BY YOU OR UNDER YOUR DIRECTION?

8 A. Yes, it was.

9 Q. COULD YOU BRIEFLY DESCRIBE THIS EXHIBIT?

10 A. Yes, Exhibit \_\_\_ (GCH-3) indicates the results of  
11 this brief industry-wide evaluation of capital  
12 planning costs. As can be seen, there are large  
13 economies of scale to be achieved in the  
14 construction of water and wastewater facilities.  
15 As a result of dealings with Southern States, I can  
16 attest to the fact that Southern States capitalizes  
17 on these economies of scale whenever possible.  
18 However, it also should be noted that the Commission  
19 Staff's apparently preferred methodology for  
20 computing the used and useful portion of utility  
21 facilities (as advocated in Mr. Chapdelaine's  
22 testimony) adversely effects Southern States'  
23 ability to capture the benefits of such economies  
24 for its customers in some circumstances.

25 Q. HOW DOES MR. CHAPDELAIN PROPOSE THAT THE USED AND

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

**USEFUL FACILITIES BE DETERMINED?**

A. Mr. Chapdelaine proposes the use of the "hydraulic share of the plant used and useful in service to the customers in test year for the rate application." He goes on to say that other considerations should be taken into account over and above the hydraulic share. He cites Chapter 17-555, F.A.C., and Chapter 17-600, F.A.C., along with "sound engineering, standard industrial practices and regulatory requirements." In fact, on lines 1 and 2 of page 5 of Mr. Chapdelaine's direct testimony, it appears that he is agreeing with the Company's approach to used and useful in reviewing and analyzing the water and wastewater systems on a major component basis. Yet, the methodology that he discusses does not review these major components independently in relation to their standard engineering design criteria. As Mr. Chapdelaine states on lines 5 and 6 of page 5 of his prefiled direct testimony, "various maximum flows may be taken into account based on peak month, peak day, and peak hour demands to determine the highest level of capacity which is indicated for the system based on the test year data which may be adjusted for natural occurrences, line breaks and fire



1 fighting." This is certainly true. Yet, in his  
2 testimony he uses the average of the five maximum  
3 days to determine the used and useful capacity of  
4 all of the various water supply, treatment, storage,  
5 and pumping facilities when, in actuality, standard  
6 engineering design criteria requires that different  
7 components use different flow or demand  
8 considerations.

9 Q. DO YOU AGREE WITH MR. CHAPDELAIN'S APPROACH USING  
10 A 5-DAY MAXIMUM DAILY PRODUCTION OF WATER TO  
11 DETERMINE THE USED AND USEFUL PERCENTAGE?

12 A. No. I have reviewed the references cited in 17-  
13 555.330, F.A.C., entitled "Engineering References  
14 for Public Water Systems" along with several  
15 standard engineering design text books for water  
16 facilities and I have not been able to find any cite  
17 to substantiate Mr. Chapdelaine's statement that  
18 "maximum daily production water flow based upon the  
19 average of the 5 highest pumping rate days in the  
20 highest pumping rate month should be utilized." For  
21 example, Part 3 entitled "Source Development" of the  
22 "Recommended Standards for Water Works" - 1987,  
23 states under Section 3.2 - Groundwater, subsection  
24 3.2.1 - Quantity, sub-subsection 3.2.1.1 - Source  
25 Capacity that "[t]he total developed groundwater

1 source capacity shall equal or exceed the design  
2 maximum day demand."

3 In addition, as discussed in Chapter 2 of  
4 "Water Treatment Plant Design", Second Edition, by  
5 the AWWA (page 17) under "Plant Capacity":

6 We then plot water use trends for average 24  
7 hour, maximum 24 hour and peak hour demands.  
8 The peak hourly demands are met from  
9 distribution storage and therefore do not have  
10 to pass through the treatment facility. The  
11 treatment facility is normally designed for  
12 maximum 24 hour demand, so that an adequate  
13 amount of water will be treated and  
14 transmitted to distribution storage system  
15 throughout the year including days when usage  
16 is maximum (emphasis added).

17 Thus, as clearly stated by these two standard  
18 references which are cited in Rule 17-555.330,  
19 F.A.C., the maximum day must be considered in the  
20 design of the treatment facility and supply  
21 sources. Moreover, it is my professional  
22 engineering opinion that the above is true (I have  
23 been qualified as a technical expert in water  
24 treatment design in numerous Florida DOAH cases).  
25 Further, as is discussed in the AWWA "Water

1 Treatment Plant Design" manual, different  
2 components of the water system facilities are  
3 utilized for different purposes and thus have  
4 different demands, i.e., storage and pumping needed  
5 to meet peak hour demands while treatment and  
6 supply sources must meet only maximum day demands.

7 At this point, I would like to state that even  
8 though in this rate application our used and useful  
9 analysis utilized only the data from the historical  
10 test year period, standard engineering design would  
11 require you to review as much of the record  
12 available, and no less than 5 years of historical  
13 data, to determine maximum day demands due to  
14 variations in climactic conditions, economic  
15 conditions, and seasonal population fluctuations.  
16 I would agree with Mr. Chapdelaine's statement that  
17 these maximum day demands should be adjusted for  
18 "natural occurrences, line breaks and fire  
19 fighting" only to the point that the source of  
20 supply or treatment facilities should not have to  
21 meet these requirements but that storage should.

22 It should be noted that these are "natural  
23 occurrences" and that they do occur and they are  
24 real world operational requirements that a utility  
25 must consider and thus must be considered in plant

1 design. Typically, occurrences such as line breaks  
2 and fire flows are absorbed by the storage  
3 requirements or peaking facilities of the system as  
4 I will discuss later. I would like to emphasize  
5 that what is being discussed is standard  
6 engineering design criteria. Certainly, if a  
7 system has little or no storage, the source of  
8 supply must be able to meet the peak hour demands  
9 of the system as was utilized in our used and  
10 useful analysis in this rate application. It  
11 should also be noted that the distribution system  
12 for very small systems generally consists of small  
13 pipes and is not very extensive in size. In  
14 addition, there generally is no storage, so that  
15 the source of supply must meet the instantaneous  
16 demands of the customers (i.e., there is little  
17 buffering volume within the distribution system to  
18 attenuate those instantaneous demands). In  
19 summary, I cannot agree with Mr. Chapdelaine's  
20 suggestion that the use of the 5 day average  
21 maximum day demand is appropriate. I believe the  
22 methodology, as explained in the Introduction  
23 section of Volume 2, Book 11 of 11 of the MFRs,  
24 details the appropriate used and useful  
25 methodology, which is substantiated by sound

1           engineering practice. It should be noted that the  
2           same methodology was used in the 1990 rate  
3           application and Staff did not propose the  
4           adjustment now advocated by Mr. Chapdelaine.

5           In addition, in the last SSU rate case, FPSC  
6           Docket No. 900329-WS, the Staff utilized the  
7           maximum day in its used and useful analysis for the  
8           Staff Recommendation. For this rate application,  
9           the major components selected for the water  
10          systems, if they applied, were the source of  
11          supply, water treatment equipment, finished water  
12          storage, high service pumping and hydropneumatic  
13          tanks. As explained in the introduction section of  
14          Volume 2, Book 11 of 11, source of supply  
15          facilities must meet maximum day or peak hour  
16          conditions depending on the quantities of storage  
17          available. In most instances, water treatment  
18          equipment is designed around the maximum day  
19          demand. Finished water storage capacity is made up  
20          of three criteria: equalization storage, fire flow  
21          requirements and emergency storage. High service  
22          pumping capacity is typically based upon peak hour  
23          demand conditions and hydropneumatic tanks are  
24          based upon the size of the pumping units pumping  
25          through them and the chlorine contact time

1           necessary for adequate disinfection.

2           **Q. DO YOU AGREE WITH MR. CHAPDELAIN'S COMMENTS**  
3           **CONCERNING THE USE OF AVERAGE DAILY FLOW FROM THE**  
4           **PEAK FLOW MONTH FOR DETERMINATION OF THE USED AND**  
5           **USEFUL PORTION OF WASTEWATER FACILITIES?**

6           **A. Yes. It should be noted that all wastewater**  
7           **capacity determinations discussed have been based**  
8           **on a hydraulic flow basis. However, solids loading**  
9           **in the form of organic matter, i.e., BOD, total**  
10           **suspended solids and other factors, must be**  
11           **considered when designing the treatment facility**  
12           **and these solids loading have an impact on the**  
13           **capacity of the facility. With many utilities**  
14           **going to alternative reclaimed water disposal**  
15           **techniques, the effluent limitations leaving the**  
16           **treatment facilities have become more strict, and**  
17           **hence, more difficult to attain than the previous**  
18           **standard secondary treatment requirements. Thus,**  
19           **today engineers must be more conservative when**  
20           **determining appropriate hydraulic and solids**  
21           **loading rates when designing facilities. As a**  
22           **result of these phenomena, even though a facility**  
23           **has had capital improvements, the permitted**  
24           **capacity of the system actually could be reduced**  
25           **after such improvements due to the required**

1 decreased loading rates to attain a more stringent  
2 effluent quality.

3 Q. DO YOU AGREE WITH MR. CHAPDELAIN'S COMMENTS  
4 CONCERNING THE TIME PERIOD FOR MARGIN RESERVE?

5 A. No. Although we did use 12 and 18 months for  
6 determining margin reserve with respect to this  
7 rate application, these periods are not adequate to  
8 plan, design, permit and construct additional  
9 facilities to meet customer demands. Thus, if the  
10 Commission intends to deviate at all from the  
11 heretofore preferred method of determining margin  
12 reserve (as advocated by Staff witness Shafer), the  
13 Commission should modify the margin reserve period  
14 to reflect this reality.

15 In most instances today, if a utility must  
16 construct additional capacity to keep ahead of  
17 customer demands, it needs more than eighteen  
18 months to complete the process. For a relatively  
19 "clean" process in which there are no permitting,  
20 financing or construction delays (which indeed  
21 would constitute an aberration from reality), two  
22 years is about the minimum time period in which  
23 additional capacity can be provided. Below, I have  
24 briefly outlined a step by step process for the  
25 addition of water treatment capacity:

- 1           1.    In house review of records, capacity, customer  
2                    commitments, etc. and the determination of the  
3                    abilities and manpower needed to complete the  
4                    work.
- 5           2.    Request for a proposal, review of  
6                    qualifications and selection of an outside  
7                    consultant to perform the work.
- 8           3.    Determination of the needed capacity increase  
9                    to meet the demands of the current and future  
10                   customers via a planning document.
- 11          4.    Study of the various raw water supply  
12                    alternatives and the required treatment  
13                    facilities necessary to produce potable water.
- 14          5.    Selection of the raw water supply and  
15                    treatment alternative that provides the  
16                    highest quality product for the lowest  
17                    customer price.
- 18          6.    Determination of the source of supply and the  
19                    sizing of treatment facilities taking into  
20                    account economies of scale and used and useful  
21                    analysis.
- 22          7.    Preliminary planning level engineering  
23                    estimate of planning, financing, design,  
24                    permit, construction and startup costs  
25                    including overhead expenses, capitalized



- 1 interest, etc.
- 2 8. Study of complete financing alternatives and  
3 determination of lowest cost financing  
4 alternative considering all aspects.
- 5 9. Preliminary approval of selected financing  
6 alternative by financial institution, local  
7 government, etc.
- 8 10. Water Use Permit (WUP) application preparation  
9 with supporting documentation.
- 10 11. Water Management District (WMD) review and  
11 request for additional information.
- 12 12. Complete request for additional information.
- 13 13. WMD review and staff report.
- 14 14. WMD Board approval, noticing and WUP issuance.
- 15 15. Design wells and local government approval.
- 16 16. Bidding evaluation and award well drilling  
17 contract.
- 18 17. Finalization of financing for the well  
19 drilling contract.
- 20 18. Well construction and testing.
- 21 19. Water sampling and analysis.
- 22 20. Determination of water quality and its  
23 applicability to the treatment process. At  
24 this point, project redesign may be necessary  
25 causing significant delays.

- 1           21. Water treatment facilities design completion.
- 2           22. Application for FDER construction permit.
- 3           23. FDER review and request of additional
- 4           information.
- 5           24. Complete request for additional information.
- 6           25. FDER review and notice of intent.
- 7           26. FDER construction permit noticing and permit
- 8           issuance if no objections.
- 9           27. Local government review and permitting.
- 10          28. Final design completion and preparation of
- 11          bidding documents.
- 12          29. Bidding, evaluation and award of construction
- 13          contract.
- 14          30. Finalization of financing for the water plant
- 15          construction contract.
- 16          31. Water treatment plant construction and
- 17          disinfection.
- 18          32. Substantial completion inspection and
- 19          certification.
- 20          33. Punch list determination and completion of
- 21          items.
- 22          34. Start up, operator training and operation and
- 23          maintenance manual review.
- 24          35. Final walk through and inspection and
- 25          completion of final punch list items.

1           36. Final payment to contractor and project close-  
2           out.  
3           37. Final FDER certification and preparation of as  
4           built drawings.  
5           38. Begin preparing rate application to include  
6           costs of new facilities.

7           It should be noted that the above 38 steps for  
8           constructing new facilities are not all inclusive  
9           and constitute only the major activities required  
10          to add water system capacity. Also, the 38 steps  
11          assume construction of a relatively simple water  
12          treatment facility with no major delays in the  
13          permitting, design or construction processes. If  
14          this were a more complex facility, for example an  
15          R.O. facility with an injection well, the  
16          permitting and construction time would more than  
17          likely be extended by at least one additional year.  
18          Hartman & Associates recently completed an R.O.  
19          facility which utilized an existing injection well  
20          and which was on an extremely fast track, and the  
21          permitting and construction alone took more than  
22          two years. A similar result also is occurring in  
23          the wastewater industry. A fast tracked wastewater  
24          treatment facility expansion currently in progress  
25          is expected to take over two years to design,

1 permit and construct. Both of these projects were  
2 relatively straightforward since there were no  
3 treatment alternatives available, which eliminated  
4 the first five steps previously outlined.

5 Recent DER rule revisions concerning planning  
6 for wastewater facilities expansion also now  
7 require the extension of the margin reserve period  
8 beyond eighteen months for wastewater treatment  
9 facilities. DER Rule 17-600.405, F.A.C., requires  
10 a utility to provide timely planning, design and  
11 construction of plant expansions based on a  
12 schedule delineated by DER. This rule requires a  
13 utility providing wastewater service to submit  
14 annual capacity analysis reports to the DER. These  
15 reports must analyze existing facilities and their  
16 capacity to provide service. Basically, the rule  
17 has established four triggers to determine when  
18 certain activities need to be commenced concerning  
19 the design, permitting and construction of  
20 additional wastewater treatment facilities. If the  
21 projected flows of the facility exceed the  
22 permitted capacity of the facility within 5 years  
23 of the date of the report, then the report must  
24 include a statement by a registered engineer that  
25 planning and preliminary design of a plant

1 expansion has been initiated. When the projected  
2 flows are expected to exceed the capacity within 4  
3 years, the report must include a statement from the  
4 registered engineer that plans and specifications  
5 for the expansion are being prepared. If the  
6 engineer determines that projected flows are going  
7 to exceed the capacity within 3 years, then a  
8 construction permit application must be submitted  
9 to the DER within 30 days of such a determination.  
10 The final trigger is that if the capacity analysis  
11 report indicates that the projected flows are going  
12 to exceed the permitted capacity of the treatment  
13 facilities within 6 months, an operating permit  
14 application must be submitted by the utility along  
15 with the capacity analysis report.

16 The clear intent of the DER's rule is that  
17 capacity must be maintained for a minimum 4 year  
18 window if the utility does not wish to perpetually  
19 be in a permitting and expansion mode for every  
20 wastewater treatment plant it operates. Hence,  
21 pursuant to this rule, a minimum 4 year margin  
22 reserve time period is required for wastewater  
23 treatment facilities.

24 This DER rule has been acknowledged by the  
25 Florida Public Service Commission in a recently

1           adopted Memorandum of Understanding between the DER  
2           and the Commission.     Page 5 of the proposed  
3           Memorandum of Understanding, under the heading,  
4           "PSC Responsibilities - Wastewater Management",  
5           states as follows:

6                     The DER has adopted rules requiring utilities  
7                     to perform timely planning, design and  
8                     construction of expanded facilities to ensure  
9                     that sufficient wastewater treatment, disposal  
10                    and reuse capacity is available. In light of  
11                    DER rules, the PSC agrees to evaluate capacity  
12                    constraints imposed by statutes and rules on  
13                    private utilities within PSC jurisdiction by  
14                    PSC's application of the used and useful  
15                    concept. If justified, this evaluation shall  
16                    include the assessment of the possible need  
17                    for statutory rule or revisions.

18                    Thus, based upon DER's new rule requirements and  
19                    this Memorandum of Understanding, a four year  
20                    margin reserve requirement is necessary and  
21                    justified for all of the Company's wastewater  
22                    treatment facilities in order to be in compliance  
23                    with current rules and regulations.

24           **Q. I SHOW YOU EXHIBIT \_\_\_\_ (GCH-4) UNDER COVER PAGE**  
25           **ENTITLED, "MEMORANDUM OF UNDERSTANDING BETWEEN THE**

1 FLORIDA DEPARTMENT OF ENVIRONMENTAL REGULATION AND  
2 THE FLORIDA PUBLIC SERVICE COMMISSION". ARE YOU  
3 FAMILIAR WITH THIS EXHIBIT?

4 A. Yes.

5 Q. COULD YOU BRIEFLY DESCRIBE THIS EXHIBIT?

6 A. This exhibit contains a copy of the Memorandum of  
7 Understanding between the Commission and the DER  
8 which I just referred to.

9 Q. DO YOU HAVE ANY FURTHER COMMENTS REGARDING MR.  
10 CHAPDELAINES PROPOSAL?

11 A. Yes. Mr. Chapdelaine refers to the Commission  
12 "policy" of capping the margin reserve at 20%, even  
13 where the historical growth rate is higher than  
14 20%. I do not believe this cap is justified. If  
15 the customer base of a water or wastewater system  
16 is increasing at a growth rate higher than 20% per  
17 year, the utility must be able to provide service  
18 to those customers no matter how rapidly the  
19 requests for service are coming. This is  
20 particularly true of Southern States' small systems  
21 which are experiencing growth at a rate in excess  
22 of 20%, including Grand Terrace (117.1%), Lake Ajay  
23 (37.3%), Pine Ridge Estates (25.3%), Pine Ridge  
24 (20.5%) and Rolling Green (34.0%). Also, new  
25 systems such as Palisades, Quail Ridge, and

1           Fountains can be expected to exceed an annual  
2           growth rate of 20%. Land developers often project  
3           a 5 year build-out for their projects which  
4           translates into an average of 20% growth per year.  
5           However, typically a development starts out slow  
6           and finishes slow in reaching build-out, but the  
7           years in between, which say would be years 2, 3,  
8           and 4, would greatly exceed 20% and reach levels of  
9           perhaps 30% or even higher. The Commission should  
10          not limit the margin reserve to 20% for these SSU  
11          systems, but rather should establish the margin  
12          reserves based on the actual average rates of  
13          growth.

14        **Q. DO YOU AGREE WITH MR. CHAPDELAINES COMMENTS**  
15        **CONCERNING REDUNDANCY?**

16        **A. Yes. As Mr. Chapdelaine discusses on page 5, lines**  
17        **21 through 23, there are specific regulatory**  
18        **requirements for redundancy of the facilities.**  
19        **Typically, any mechanical component must have a**  
20        **back-up in order to adequately provide service if**  
21        **the primary unit should be out of service. The**  
22        **redundancy requirements are based upon a**  
23        **probability that a particular component of a system**  
24        **is going to be out of service and the reliability**  
25        **of that component. The theory of reliability for**



1 water systems is described in Chapter 18 of AWWA's  
2 "Water Treatment Plant Design" manual, pages 537  
3 through 539. In addition, the USEPA has  
4 established specific criteria concerning redundancy  
5 and reliability of wastewater treatment facilities.  
6 This is discussed in "Design Criteria for  
7 Mechanical, Electric, and Fluid System and  
8 Component Reliability" - MCD-05, published by the  
9 USEPA. In that manual, it discusses three levels  
10 of reliability for wastewater treatment facilities,  
11 Class I, Class II and Class III. The DER requires  
12 facilities providing reclaimed water to sites  
13 accessible to the general public to maintain Class  
14 I reliability. This is an important concept to  
15 understand when evaluating the capacity of existing  
16 wastewater treatment facilities that must now be in  
17 compliance with Class I reliability.

18 Typically, the minimum standard for  
19 reliability assumes the largest unit out of service  
20 for maintenance or due to a mechanical failure. As  
21 I explained earlier, reliability is a function of  
22 the probability that a particular piece of  
23 equipment is going to be out of service.  
24 Certainly, the greater the number of pieces of the  
25 same type of equipment that are necessary to

1           operate a system, the greater the likelihood that  
2           more than one unit could be out of service at the  
3           same time. For example, in multiple well systems  
4           such as Deltona Lakes (23), Spring Hill (21) or  
5           Sugar Mill Woods (9), it is not uncommon to assume  
6           that at least the two largest units will be out of  
7           service. Certainly one well could be down for  
8           routine maintenance, such as bearing replacement,  
9           impeller replacement, thrust bearing replacement or  
10          numerous other things. While maintenance is  
11          occurring on that particular unit, another unit  
12          could fail due to a mechanical problem (i.e., motor  
13          burning up, being struck by lightning, shaft  
14          breaking), thus redundancy requirements are not  
15          strictly a function of a single unit being out of  
16          service, but in some instances, multiple units must  
17          be considered out of service. It must be  
18          remembered that we are not dealing with  
19          hypotheticals here but rather the realistic  
20          assumptions which must be made to insure the  
21          utility's ability to meet its obligation to provide  
22          water to its customers.

23        **Q. DO YOU AGREE WITH MR. CHAPDELAIN'S COMMENTS**  
24        **CONCERNING FIRE FLOW REQUIREMENTS?**

25        **A. Yes, with the following qualifications:**

1 Fire flow requirements typically come from the  
2 storage units within the system. Of course, if no  
3 storage or inadequate capacity is available, the  
4 source of supply must be able to meet the average  
5 demand conditions during the maximum day plus the  
6 fire flow requirement. Thus, for example, if a  
7 utility had a maximum day demand of 1 million  
8 gallons, the average demand condition during that  
9 day would be approximately 700 gallons per minute,  
10 if that system had a 500 gallon per minute fire  
11 flow requirement, the source of supply would need  
12 to have a capacity of approximately 1,200 gallons  
13 per minute to meet the conditions of the fire flow  
14 plus the maximum average day demand condition.

15 Q. ARE YOU AWARE OF ANY PROPOSED RULES REGARDING USED  
16 AND USEFUL METHODOLOGY AND MARGIN RESERVE  
17 DETERMINATION?

18 A. Yes, I participated in discussions with FPSC staff,  
19 Mr. Charles Hill, and the Florida Waterworks  
20 Association and provided information regarding the  
21 need to develop appropriate rules. The work  
22 product from these efforts were incorporated in the  
23 Commission staff's latest rulemaking proceeding.  
24 I have included this information as Exhibit \_\_\_\_  
25 (GCH - 5). These proposed rules reflect the

1 methodology used by me in this proceeding.

2 Q. IS THE HISTORICAL TEST YEAR PERIOD ADEQUATE TO  
3 ASSESS THE EXTENT OF USED AND USEFUL FACILITIES IN  
4 WATER AND WASTEWATER SYSTEMS?

5 A. No. Even though for the purposes of this rate case  
6 we constrained these analyses to the historical  
7 test year, professional engineers are bound by  
8 Florida Statutes Chapter 471 to, in part, protect  
9 the "public health, safety and welfare." It is not  
10 generally accepted engineering practice or proper  
11 utility planning to consider only one year of  
12 historical data. For example, the Sugar Mill Woods  
13 water system in 1989 had five maximum days ranging  
14 from 2.788 MGD to 4.581 MGD and averaged 3.335 MGD.  
15 In 1991, the water system ranged from 1.833 MGD to  
16 1.869 MGD averaging 1.854 MGD. Facilities were  
17 constructed to meet the needs in 1989 and the  
18 associated investments were prudently made at that  
19 time. Yet, in 1991, those same facilities were  
20 used less and the utility is penalized with a lower  
21 used and useful percentage. The Company cannot  
22 just arbitrarily reduce its investment simply due  
23 to a low usage year and thereafter increase the  
24 investment again when demands increase later.  
25 Rather, the Company has the obligation of having

1           adequate facilities for service. Therefore, the  
2           used and useful percentages calculated are below  
3           the appropriate level due to the restriction of a  
4           single historic test year convention. Absent plant  
5           additions, I can think of no situation which would  
6           justify a reduction in used and useful levels  
7           associated with the same plant assets from one year  
8           to the next. For example, if the investment in  
9           Plant A was prudent when made, the construction  
10          costs were reasonable and Plant A's used and useful  
11          character is determined in Year 1, the Company  
12          should not be penalized subsequently when events  
13          occur, particularly those beyond the Company's  
14          control such as inordinate rainfall levels or a  
15          devastating economic slowdown, which reduce water  
16          consumption and thus the usefulness of Plant A.

17        **Q.   WHAT IS AN APPROPRIATE AMOUNT OF UNACCOUNTED FOR**  
18        **WATER?**

19        **A.**   Unaccounted for water is an ambiguous term and a  
20          precise determination of what are excessive  
21          unaccounted for water levels is no less difficult  
22          to decipher. Mr. Chapdelaine states that the  
23          Commission "policy" is that anything greater than  
24          10% is considered to possibly be excessive and  
25          should be investigated for possible adjustment. If

1 the system is having a problem with leaking  
2 transmission and distribution pipes, which is  
3 typically considered unaccounted for water, the  
4 true test of whether the amount of lost water is  
5 excessive should be determined by a cost/benefit  
6 analysis (examining the cost of repairing the lines  
7 versus paying the additional costs of pumping and  
8 treating the lost water). In some situations, it  
9 is more cost effective to improve the leakage  
10 situation, and in other situations, it is better to  
11 continue to pump water. Replacement of  
12 transmission and distribution lines and the follow-  
13 up restoration of pavements, landscaping, etc., is  
14 capital intensive and in many situations it is not  
15 practical to correct the problem. In these  
16 situations, the Company should not be penalized for  
17 unaccounted for water levels above 10%.

18 Q. DO YOU AGREE THAT AN ACCEPTABLE LEVEL OF  
19 UNACCOUNTED FOR WATER IS 10% OF THE WATER PUMPED?

20 A. No. This may be an acceptable level of unaccounted  
21 for water but to determine that anything above 10%  
22 is to be considered excessive is incorrect. As I  
23 previously mentioned in this testimony, a  
24 cost/benefit analysis must be done to determine  
25 whether it is worth the cost of resolving the

1 unaccounted for water problems. Replacement and  
2 restoration of water distribution lines can be very  
3 expensive.

4 **Q. DO YOU BELIEVE ANY OF THE WATER SYSTEMS IN THIS**  
5 **RATE CASE APPLICATION HAVE EXCESSIVE UNACCOUNTED**  
6 **FOR WATER?**

7 **A. No.** In Staff's Prehearing Statement, Staff raised  
8 the issue whether the Beechers Point, Interlachen  
9 Lakes Estates, Keystone Heights, River Grove,  
10 Saratoga Harbor-Weelacha, Kingswood, Oakwood,  
11 Palisades, and Stone Mountain systems have  
12 excessive unaccounted for water levels. As I have  
13 stated previously, excessive unaccounted for water  
14 levels cannot be determined solely on the fact that  
15 such levels may exceed 10% of the water pumped and  
16 sold to customers. Cost/benefit analyses must be  
17 performed to determine whether quantities of  
18 unaccounted for water are excessive to the point  
19 where extensive capital projects are necessary to  
20 correct the problem. It should be noted that each  
21 of the systems identified by Staff are very small  
22 and more than likely it would not even be prudent  
23 to cause customers served by these systems to pay  
24 for a cost/benefit analysis.

25 **Q. WHAT IS INFILTRATION AND IN-FLOW?**

1       A.    Infiltration is typically considered the passing of  
2            groundwater into the gravity sewer system due to  
3            gaps in joints, cracks in pipes, etc. This occurs  
4            most in areas which have high groundwater levels  
5            (which is quite common in the State of Florida).  
6            Typically, in-flow is considered the passing of  
7            surface water into the collection system via  
8            manhole lids, illegal connections, stormwater  
9            connections into the collection system, etc. In-  
10           flow problems are more easily identified and  
11           resolved than infiltration problems. Infiltration  
12           can be difficult to both identify and locate within  
13           the system. The correction of the problem, which  
14           typically either calls for replacement of the pipe  
15           or lining the pipe with a suitable material, can be  
16           very costly, sometimes up to 3 times the cost of  
17           the original installation. As Mr. Chapdelaine  
18           states, the Commission policy is to allow 10%  
19           inflow and infiltration and anything beyond that is  
20           considered excessive and may affect the  
21           determination of used and useful plant absent  
22           justification. Again, as with unaccounted for  
23           water, the true test of whether the level of  
24           infiltration and in-flow is excessive should be  
25           determined by a cost/benefit analysis which



1 determines whether it is less costly to correct the  
2 problem or to continue to treat the existing  
3 amounts of wastewater. Therefore, I would not  
4 agree with Mr. Chapdelaine's comments that  
5 unaccounted for water and infiltration and in-flow  
6 should be limited to 10%.

7 **Q. DO YOU BELIEVE INFILTRATION AT THE JUNGLE DEN**  
8 **WASTEWATER SYSTEM IS EXCESSIVE?**

9 A. No. The Company provided Staff with an  
10 interrogatory response which included facts that  
11 confirm that based on the design of the collection  
12 system at Jungle Den, the amount of infiltration is  
13 not excessive. Moreover, based on the small size  
14 of the system, it is probably not even prudent to  
15 perform an analysis to determine where the  
16 infiltration may be occurring much less invest in  
17 capital improvements to correct problems which may  
18 exist.

19 **Q. DO YOU BELIEVE THE PALM PORT SYSTEM HAS EXCESSIVE**  
20 **INFILTRATION?**

21 A. No. We have compared the amount of wastewater  
22 treated in this system to the amount of water  
23 pumped and do not believe that there is excessive  
24 infiltration.

25 **Q. DO YOU AGREE WITH MR. CHAPDELAINES ALLEGATION THAT**

1           SSU'S USED AND USEFUL ADJUSTMENTS WERE "NOT BASED  
2           UPON STANDARD COMMISSION PRACTICE"?

3           A.   First, I'm not sure that the Commission has a  
4           "standard practice" concerning used and useful  
5           adjustments. To the best of my knowledge, Chapter  
6           367, Florida Statutes, and Chapter 25-30, F.A.C. do  
7           not address any "standard practices" for used and  
8           useful adjustment. Second, Mr. Chapdelaine states  
9           that "no explanation or justification was found as  
10          to why deviations occurred." I strongly disagree  
11          with this statement. As I discussed previously,  
12          the F schedules in the MFRs contain an introduction  
13          that describes the used and useful methodologies we  
14          used. Volume 2, Book 11 of 11, in the Introduction  
15          to Water Engineering Schedules under Schedules F-  
16          5 "Used and Useful Determination for Water  
17          Systems", contains a detailed explanation of the  
18          methodologies used to determine the used and  
19          usefulness of water supply wells, water treatment  
20          equipment, finished water storage, high service  
21          pumps, auxiliary power, chlorination equipment,  
22          hydropneumatic tanks, water transmission and  
23          distribution systems and fire flow requirements.  
24          I believe this introduction provides a more than  
25          adequate explanation and justification of the used

1 and useful methodologies we utilized. According to  
2 Mr. Chapdelaine, one of the Company's alleged  
3 deviations from alleged "standard practices" was  
4 our use of the single peak day rather than the  
5 average of the peak 5 days to determine used and  
6 useful plant levels. Our analysis is explained in  
7 the introduction section of the MFRs and I also  
8 thoroughly discussed this point previously in this  
9 rebuttal testimony.

10 Mr. Chapdelaine cites a second alleged  
11 deviation regarding our "calculation of  
12 hydropneumatic tank used and usefulness based upon  
13 a factor of 15 rather than a factor of 10 relative  
14 to well capacity as called for in the Ten State  
15 Standards (Recommended Standards for Water Works)."  
16 First, the standards indicated in the Ten State  
17 Standards manual are minimum standards only. The  
18 standard that Mr. Chapdelaine is referring to is in  
19 Part 7 of the Ten State Standards and it is  
20 entitled "Finished Water Storage". In Section 7.2  
21 - Hydropneumatic Tanks, under subsection 7.2.2 -  
22 Sizing, it states:

23 The capacity of the wells and pumps in a  
24 hydropneumatic system should be at least 10  
25 times the average daily consumption rate. The

1           gross volume of the hydropneumatic tank, in  
2           gallons, should be least ten times the  
3           capacity of the largest pump, rated in gallons  
4           per minute. For example, a 250 gallon per  
5           minute pump should have a 2,500 gallon  
6           pressure tank.

7           The Company's use of 15 times the capacity of the  
8           largest pump is done for two reasons. First and  
9           foremost, for most of these water systems, the only  
10          storage that is available is the hydropneumatic  
11          tank and it is the only place that chlorine has  
12          adequate time to contact the water and properly  
13          disinfect it. It should be noted that in Part b of  
14          subsection 7.2.2, of the Ten State Standards, it  
15          states: "Sizing of hydropneumatic storage tanks  
16          must consider the need for chlorine detention time,  
17          as applicable, independent of the requirements in  
18          7.2.2.a above." Industry standards require a  
19          minimum of 15 minutes chlorine contact time at peak  
20          flow rates. Moreover, section 4.3.1.2, page 56 of  
21          the Ten State Standards states "free chlorine  
22          residual . . . maintained in the water after  
23          contact time of at least 30 minutes when maximum  
24          flow rate coincides with anticipated maximum  
25          chlorine demand." Thus, with a simple well and

1           hydropneumatic tank system, which exist on the  
2           majority of the SSU systems, the hydropneumatic  
3           tank must have a capacity of at least 15 times the  
4           well pump capacity so that there is approximately  
5           15 minutes of detention (at peak hour versus  
6           maximum day) within the hydropneumatic tank prior  
7           to delivery to the distribution system.

8                     Another reason for using 15 times the largest  
9           pump capacity is that you want to minimize the  
10          number of starts that an electrical motor has in a  
11          one hour period. Typically, the number of starts  
12          varies with the size of the motor, but a maximum of  
13          4 to 5 starts per hour would require the  
14          hydropneumatic tank to have a capacity of at least  
15          15 times the largest pump capacity.

16                    To conclude, based on my foregoing responses  
17          to these two apparent "deviations", the Company's  
18          used and useful methodology certainly did not  
19          deviate from standard engineering practice. I know  
20          that in many instances the Commission practice  
21          would not even have considered the capacity of the  
22          hydropneumatic tanks in a separate analysis. It  
23          would have been included in the overall used and  
24          useful percentage of all the water treatment  
25          facilities.

1           Another "deviation" alleged by Mr. Chapdelaine  
2           is that Southern States "included fill-in lots in  
3           the distribution and collection systems used and  
4           useful adjustment rather than only the lots which  
5           were or would be developed as is the basis pursuant  
6           to Commission practice."    It is true that we  
7           believe that some of the water distribution and  
8           wastewater collection systems included in this  
9           proceeding are 100% used and useful despite lower  
10          results when the total lots occupied are divided by  
11          the total number of lots where service is  
12          available.    I know that in Docket No. 900329-WS,  
13          the Staff recommended 100% used and useful levels  
14          on numerous SSU water distribution and wastewater  
15          collection systems that still had lots that were  
16          vacant and thus were without active connections.  
17          I am also aware of several other dockets in which  
18          the Commission has determined the water  
19          distribution or wastewater collection system to be  
20          either 100% used and useful or used and useful in  
21          amounts greater than the result achieved by  
22          dividing the total active lots by the total number  
23          of lots with service available.    If the application  
24          of this calculation is standard Commission practice  
25          (and I do not believe it is), the Commission

1 deviates quite often from this "practice" and  
2 should do so in this proceeding.

3 In addition, the Commission's own rules  
4 provide for the inclusion of "fill-in" lots. Rule  
5 25-30.231 - Extent of System which Utility shall  
6 Maintain (emphasis added), requires "delivery of  
7 water service to the customer up to and including  
8 the point of delivery into the piping." Also, Rule  
9 25-30.225 - Plant and Facilities, states in  
10 paragraph (7) that "each utility which provides  
11 both water and sewer service shall operate and  
12 maintain in safe, efficient, and proper condition,  
13 all of its facilities to the point of delivery"  
14 (emphasis added).

15 The utility strongly believes that fill-in  
16 lots are used and useful purely from a required  
17 service and an economy of scale approach. If the  
18 utility were to only install lines to one customer  
19 at a time, the cost would be exorbitant.

20 Q. DO YOU HAVE ANY COMMENTS REGARDING MR.  
21 CHAPDELAIN'S STATEMENTS CONCERNING THE USED AND  
22 USEFUL CHARACTER OF WATER DISTRIBUTION AND SEWER  
23 COLLECTION LINES?

24 A. On page 6, line 25 and continuing on through lines  
25 1 and 2 of page 7, Mr. Chapdelaine states that

1 "Commission policy with regard to contributions in  
2 aid of construction (CIAC) calls for 100% of the  
3 distribution and collection system to be  
4 contributed." He continues by stating, "compliance  
5 with CIAC policy obviates used and useful  
6 determinations involving distribution and  
7 collection systems." I do not agree with Mr.  
8 Chapdelaine that Commission policy is that water  
9 distribution and wastewater collection systems are  
10 to be considered 100% contributed. Mr. Chapdelaine  
11 does not identify where this alleged "Commission  
12 policy" is established. To my knowledge, no such  
13 policy exists. Perhaps Mr. Chapdelaine is thinking  
14 that at the time the service availability charges  
15 are developed it is assumed that a minimum level of  
16 CIAC to be collected will cover the cost of at  
17 least the installation of the distribution and  
18 collection systems. However, in reality, it is  
19 more than likely that construction costs will have  
20 increased or some other factor would have occurred  
21 such that 100% recovery is not received from the  
22 service availability charges established at some  
23 prior time by the Commission. In addition, it  
24 should be noted that since SSU acquires most of its  
25 utilities long after the service availability



1 charges have been established and CIAC has been  
2 collected, it takes the system "as is" and has no  
3 control over the of CIAC levels. In addition, in  
4 each rate case that I have participated in before  
5 the Commission, the Commission has made a  
6 determination of the used and usefulness of the  
7 water distribution and wastewater collection lines  
8 independent of the level of CIAC associated with  
9 them.

10 Also, if Mr. Chapdelaine's statements were  
11 truly "Commission policy," why did Staff raise  
12 Issue 38 in their pre-hearing statement, which  
13 states, "What are the used and useful percentages  
14 for the water distribution systems?" and Issue 40,  
15 which states, "What are the used and useful  
16 percentages for the wastewater collection systems?"  
17 To conclude, I believe Mr. Chapdelaine's assertion  
18 regarding "Commission policy" is not accurate and  
19 the portion of his testimony concerning such  
20 alleged policy should be disregarded. The used and  
21 usefulness of the water and wastewater lines should  
22 be established at the levels indicated in the MFRs.

23 Q. DO YOU HAVE ANY COMMENTS CONCERNING MR.  
24 CHAPDELAINES STATEMENT THAT NON-USED AND USEFUL  
25 PLANT SHOULD BE ACCOMMODATED THROUGH RECOGNITION OF

1           **AN ALLOWANCE FOR FUNDS PRUDENTLY INVESTED (AFPI)?**

2           A.   The Company does not disagree with this statement,  
3           and the MFRs confirm that the Company has applied  
4           for AFPI charges for all non-used and useful  
5           facilities. However, it should be noted that AFPI  
6           charges do not accrue to the Company's benefit  
7           until (and if) they are actually collected and  
8           these charges are only accrued up to a 5 year  
9           period. Thus, the Company's ability to recover a  
10          return on its prudent investments in utility plant  
11          is tied to growth projections over which the  
12          Company has no control and which may or may not be  
13          achieved.

14                   Mr. Chapdelaine further indicates that "the  
15          used and useful determination should be made based  
16          upon Commission practice and MFR requirements all  
17          of which are known to utilities such as Southern  
18          States." First, I do not believe (as I have  
19          stated previously) that the Commission has an  
20          established practice for making used and useful  
21          determinations. Indeed, Commission Staff is only  
22          now working on a rule that will spell out used and  
23          useful methodologies and even this rule is to be  
24          used only in situations where the utility does not  
25          present an alternative method of determining the

1 used and usefulness of utility plant. Second, the  
2 MFRs do not specify a methodology for making used  
3 and useful determinations.

4 Q. DO YOU AGREE WITH MR. CHAPDELAINES STATEMENT THAT  
5 "IT IS INCUMBENT UPON THE UTILITY TO JUSTIFY ITS  
6 FILING, PROVE ITS CASE AND INDICATE WHY IT CHOSE TO  
7 DEVIATE FROM COMMISSION PRACTICE"?

8 A. Yes. But I believe Mr. Chapdelaine has ignored,  
9 perhaps inadvertently, the introductory sections to  
10 the F Schedules in both volumes of the Company's  
11 MFRs in which our used and useful methodologies are  
12 identified and explained. In addition, it must be  
13 noted that the Company responded to numerous Staff  
14 interrogatories concerning certain aspects of our  
15 methods for determining the used and useful levels.  
16 Therefore, Mr. Chapdelaine's expressed lack of  
17 knowledge of our methods is surprising to the  
18 Company.

19 Finally, if the Company has deviated from  
20 "Commission practice" (which practice either does  
21 not exist or is routinely deviated from), it is  
22 solely because the Company wanted to provide a  
23 methodology that appropriately tracked the  
24 engineering design criteria utilized in building  
25 these facilities.

1 Q. HAVE YOU REVIEWED THE TESTIMONY OF STAFF WITNESS  
2 GREGORY L. SHAFER?  
3 A. Yes, I have.  
4 Q. WHAT COMMENTS DO YOU WISH TO MAKE CONCERNING MR.  
5 SHAFER'S TESTIMONY?  
6 A. Mr. Shafer discusses the methodology for  
7 determining margin reserve. He believes the margin  
8 reserve should be calculated using a linear  
9 regression model analysis.  
10 Q. DO YOU AGREE WITH MR. SHAFER'S UNDERSTANDING OF THE  
11 CONCEPT OF MARGIN RESERVE IN THE REGULATION OF  
12 WATER AND WASTEWATER UTILITIES?  
13 A. Yes I do. Mr. Shafer states that "a margin reserve  
14 allowance is recognition in rate base of that  
15 portion of plant needed to serve short term  
16 growth." As I stated earlier, a utility must have  
17 the next increment of capacity ready to serve  
18 customers at a moments notice. If the utility did  
19 not have this margin reserve capacity available, it  
20 would either have to continuously be constructing  
21 small increments of plant capacity, which would be  
22 very uneconomical to construct, or the utility  
23 would more than likely not be able to complete the  
24 facilities in a timely manner to be able to serve  
25 such customers. In addition, without a margin

1           reserve, the utility more than likely would be  
2           unable to comply with DER rules and regulations  
3           perhaps at some point in the not too distant future  
4           for certain systems.

5           **Q.   DO YOU AGREE WITH MR. SHAFER'S STATEMENTS**  
6           **CONCERNING THE COMMISSION'S CURRENT METHOD OF**  
7           **CALCULATING THE MARGIN RESERVE?**

8           **A.**   Not entirely. I do not agree with his statement  
9           that "the construction time factors represent the  
10          average amount of time needed for construction of  
11          additional treatment plant or distribution or  
12          collection facilities."       As I have stated  
13          previously in this testimony, I do not believe the  
14          margin reserve time factor of 18 months is adequate  
15          time to design, permit and construct additional  
16          water or wastewater treatment facilities.

17                 Mr. Shafer states that he does not have any  
18          particular problem with the simple average method  
19          other than that it is the most basic approach  
20          possible and there are perhaps other methods, i.e.,  
21          the linear regression method, that may more  
22          accurately relate to the actual historical data in  
23          certain situations. This is true -- but if you are  
24          going to use linear regression, why stop there.  
25          You could project growth based on a second, third,

1 fourth or fifth order equation or even a more  
2 elaborate equation that would probably match the  
3 historical data exactly. But the pertinent  
4 question is, does this reflect an accurate  
5 projection of growth in the future? Mr. Shafer  
6 states that "as a strictly mathematical  
7 extrapolation, [the simple average method] totally  
8 ignores the fact that there may be a relationship  
9 between the two pertinent factors, time and rate of  
10 growth." It is true that there certainly is always  
11 some sort of relationship between time and rate of  
12 growth, but as I discussed earlier in this  
13 testimony, for small systems such as many of the  
14 systems included in this rate proceeding, any  
15 historical relationship between time and rate of  
16 growth could be greatly modified in the near future  
17 due to a new residential or commercial development  
18 or some other condition that may occur within the  
19 service area. Mr. Shafer believes the statistical  
20 linear regression is a relatively easy and superior  
21 method upon which to base growth projections. With  
22 the advent of PC computer based statistical  
23 methods, any other multiple regression analysis  
24 technique could also be easily used. Models  
25 require only that you input the data and the

1 computer determines which type of equation best  
2 fits the data.

3 Another problem I see with any statistical  
4 approach to growth projections is that we are  
5 looking at only 5 observations, which typically is  
6 not sufficient to provide accurate results. In  
7 addition, you must be able to interpret the  
8 accuracy of these results to determine whether the  
9 statistical methodology is appropriate. In  
10 reviewing two of the three examples provided in  
11 Exhibit \_\_\_\_\_ (GLS-1), Sanlando Utilities  
12 Corporation's Wastewater Treatment - Wekiva  
13 facility and SSU's Marco Island - Wastewater  
14 facility, there appears to be a poor correlation  
15 between the growth and ERCs in any historical  
16 trend. This poor correlation is confirmed by the  
17 R squared value of 0.29 for Sanlando and 0 for the  
18 Marco Island facility and can be observed in the  
19 graphs presenting both of these results. I believe  
20 these results also confirm that Mr. Shafer's linear  
21 regression approach is not appropriate for this  
22 rate case. While I believe the linear regression  
23 method is one possibility for projecting growth,  
24 when it appears that it accurately depicts the  
25 historical data, I believe that ten (10) years of

1 historical data would better suit future  
2 projections. This is supported by DER's  
3 requirement to provide 10-years of historical data  
4 as part of all capacity analysis reports conducted  
5 for wastewater facility planning. Given the data,  
6 systems and circumstances in this proceeding, I  
7 believe that the average of the past 5-years of  
8 data is the most appropriate method for determining  
9 margin reserve in this case.

10 Q. MR. HARTMAN HAVE YOU REVIEWED THE TESTIMONY OF MR.  
11 HARRY C. JONES?

12 A. Yes I have, and I wish to rebut several points  
13 raised by Mr. Jones.

14 First, I would like to address Mr. Jones'  
15 statements that Southern States needs to "change  
16 their usage from meter sizes to residential units  
17 to determine ERC's" and that "previous Public  
18 Service Commission decisions used residential  
19 units." Mr. Jones is referring to the fact that  
20 the single family residential customer in Sugar  
21 Mill Woods utilizes a 1 inch water meter, which  
22 based on American Water Works Association meter  
23 equivalency standards is equivalent to 2.5 ERC's.  
24 In Docket No. 900329-WS, the Company agreed with  
25 the Cypress Village Homeowners Association (COVA)



1           that the potential of the water distribution and  
2           wastewater collection system was 9,054 ERC's based  
3           on an exhibit provided by COVA's witness in that  
4           case, Mr. Bud L. Hanson. In order to compare  
5           apples to apples, we converted the number of  
6           connections based upon meter size and AWWA meter  
7           equivalents into ERC's. This calculation results  
8           in 4,291 ERC's for the historic test year. This  
9           equates to approximately 47% used and useful. With  
10          the inclusion of the margin reserve, the used and  
11          useful capacity for the water distribution system  
12          increased to 50%. Now Mr. Jones argues that the  
13          9,054 is not ERC's but lots and that we should  
14          either multiply the 9,054 lots by 2.5 to come up  
15          with the denominator in ERC's or convert the  
16          numerator back to lots. If we were to multiply the  
17          9,054 ERC's by 2.5, it would require us to assume  
18          that all residential connections in the future  
19          would contain a 1 inch meter. This may not be true  
20          as time goes on in the Sugar Mill Woods  
21          development.

22                 To analyze the water distribution and  
23                 wastewater collection system strictly on a lot by  
24                 lot approach provides no credit for fill-in lots.  
25                 As discussed previously in this testimony, from an

1 analysis of the distribution and collection system  
2 maps provided with the rate application, it appears  
3 that there are two discrete areas within Sugar Mill  
4 Woods -- an area that has a relatively high density  
5 of customers and an area that has a very low  
6 density of active connections. In analyzing this  
7 situation, we were able to draw a line on these  
8 maps indicating a delineation between these high  
9 and low density areas. If an assumption is made  
10 that all the lots within the high density area  
11 (whether they were occupied by an active connection  
12 or not) are 100% used and useful, and all vacant  
13 lots in the low density area are 0% used and  
14 useful, the used and usefulness of the water  
15 distribution and wastewater collection systems,  
16 including the margin reserve, would be  
17 approximately 40%. This analysis assumes that no  
18 less of a water distribution and wastewater  
19 collection system could have been installed in the  
20 high density area to serve the existing number of  
21 customers. This appears to be a reasonable  
22 assumption based on the type of distribution and  
23 collection system in service in Sugar Mill Woods  
24 and the above average water usage of the Sugar Mill  
25 Woods customers. It could conceivably be argued

1           that even the people in the remote areas of the  
2           water distribution system are required to have fire  
3           protection service and hence the main sizes  
4           provided to serve them are required to provide that  
5           fire protection service. In any event, we think  
6           that the "two area" approach represents a  
7           reasonable check confirming the validity of our  
8           analysis.

9           **Q. DO YOU AGREE WITH MR. JONES' DETERMINATION OF THE**  
10           **USED AND USEFUL PERCENTAGES FOR SUGAR MILL WOODS?**

11           **A.** No. Mr. Jones has incorrectly calculated the used  
12           and useful percentage of the water plant. He  
13           states that it is 73% used and useful. The Sugar  
14           Mill Woods water system consists of simple well and  
15           hydropneumatic tank arrays in which each water  
16           treatment facility has two or more wells pumping  
17           water through hydropneumatic tanks, which water is  
18           chlorinated and pumped directly into the  
19           distribution system utilizing the energy of the  
20           well pump only. As I previously indicated, a  
21           system such as Sugar Mill Woods must be able to  
22           meet the maximum hour demands plus the fire flow  
23           requirements. In the case of Sugar Mill Woods, it  
24           is believed that the reliable capacity of the water  
25           system should be considered with the two largest

1 wells out of service. As I also discussed  
2 previously, mechanical equipment can be out of  
3 service for many different reasons, but they  
4 primarily fall into two categories, either  
5 maintenance or mechanical failure. For instance,  
6 if one of Sugar Mill Woods' nine wells is down for  
7 bearing replacement, impeller replacement, thrust  
8 bearing wear or any other routine maintenance item,  
9 it is conceivable that a second well could be out  
10 of service due to a mechanical failure (i.e.,  
11 struck by lightning, broken shaft, motor failure,  
12 starter failure or any other problem). The total  
13 capacity of Sugar Mill Woods' 9 wells is 4,800  
14 gallons per minute. The 2 largest wells have  
15 capacities of 600 gallons per minute each, thus the  
16 total reliable well capacity for Sugar Mill Woods  
17 would be 3,600 gallons per minute. The average  
18 daily demand during the maximum day equates to  
19 1,298 gallons per minute. If you multiply 1,298  
20 gpm by two to approximate the peak hour demands  
21 (which probably exceed that figure on the Sugar  
22 Mill Woods system), you arrive at a peak hour  
23 demand rate of 2,596 gallons per minute. Adding  
24 the 2,500 gallon per minute fire flow requirement  
25 based on Citrus County Ordinance 86-10, brings the

1 required well capacity to 5,096 gallons per minute.  
2 With a reliable well capacity of only 3,600 gallons  
3 per minute, the facilities are considered 100% used  
4 and useful.

5 Mr. Jones does not identify how he arrived at  
6 his 73% percent used and useful determination, but  
7 I believe it was based upon the average daily flow  
8 during the maximum day (1,298 gallons per minute)  
9 plus a fire flow requirement of 1,500 gallons per  
10 minute. Summing these two factors provides a  
11 required well capacity of 2,798 gallons per minute.  
12 I believe Mr. Jones assumed the source of supply  
13 with the single largest well out of service or a  
14 reliable capacity of 4,200 gallons per minute.  
15 Thus, dividing the 2,798 gallons per minute by the  
16 4,200 gallons per minute, you arrive at a 67% used  
17 and useful. With the inclusion of a margin  
18 reserve, this would increase to approximately 73%  
19 as Mr. Jones indicates.

20 Mr. Jones' methodology is in error in that he  
21 has only allowed well capacity to meet the average  
22 daily demand conditions during the maximum day, yet  
23 a system of this type must meet peak hour demand.  
24 Thus, even if we stipulate to Mr. Jones' 1,500  
25 gallons per minute fire flow requirement and only

1 one well out of service, total required capacity is  
2 still  $1,298 \times 2 + 1,500 = 4,096$ . Utilizing Mr.  
3 Jones' criteria of only one well out of service,  
4 the reliable well capacity is 4,200 gallons per  
5 minute and the facilities are 97.5% used and useful  
6 or, for all intents and purposes, 100% used and  
7 useful.

8 Q. DO YOU AGREE WITH MR. JONES' CONTENTION THAT THE  
9 "FIRE PROTECTION RESERVE" SHOULD BE ONLY 1,500  
10 GALLONS PER MINUTE AND NOT 2,500 GALLONS PER  
11 MINUTE?

12 A. No. Citrus County Ordinance 86-10 requires a  
13 utility to provide 2,500 gallons per minute of fire  
14 flow based on the criteria established in the  
15 Ordinance. The letter dated October 28, 1991 from  
16 John Reeves, Citrus County Deputy Fire Marshall to  
17 Andy Woodcock of my firm, Hartman & Associates,  
18 Inc., states that "for Sugar Mill Woods as per  
19 Citrus County Ordinance 86-10 and NFPA 1231, the  
20 required fire flow for this project is 1,500  
21 gallons per minute." A letter from the Deputy Fire  
22 Marshall does not relieve the Company of its  
23 obligation to comply with Citrus County Ordinance  
24 86-10 which requires 2,500 gallons per minute.  
25 Moreover, even if Southern States were to be

1 notified today that the Citrus County Board of  
2 County Commissioners has amended the ordinance to  
3 reduce Sugar Mill Woods' fire flow requirement to  
4 1,500 gallons per minute, the Company still would  
5 have been required in the past to have built  
6 facilities meeting the then-existing requirements  
7 of the ordinance. Therefore, the reduction of the  
8 fire flow requirement to 1,500 gallons per minute  
9 has no affect upon the used and useful percentage  
10 of the water source of supply facility. I still  
11 believe that the reliable capacity of the source of  
12 supply should be evaluated with the two largest  
13 wells out of service based upon my previous  
14 discussion concerning maintenance requirements and  
15 mechanical failures. But, even assuming only the  
16 largest well out of service, the source of supply  
17 facilities are still considered 100% used and  
18 useful, so the outcome is the same with or without  
19 Mr. Jones' proposed changes in applicable criteria.

20 **Q. DO YOU AGREE WITH MR. JONES' STATEMENT THAT THE**  
21 **THREE NEW WELLS DID NOT BECOME ACTIVE UNTIL APRIL**  
22 **OF 1992 YET THE COSTS WERE INCLUDED IN THE**  
23 **HISTORICAL 1991 TEST YEAR?**

24 **A. Based upon Company records, the water treatment**  
25 **facility was placed into service in December 1991.**

1           At that time, they had reached substantial  
2           completion on all phases of the project except the  
3           3 wells and the chlorination system. Thus, all the  
4           improvements located at the existing water  
5           treatment plant no. 2 site were in service and  
6           being utilized. The construction of the wells had  
7           been completed, however, there were difficulties  
8           acquiring the necessary bacteriological clearance  
9           prior to placing the wells into service. After  
10          several rounds of sampling, the wells were cleared  
11          for service in 1992. Even though the wells were  
12          not cleared, the construction had been completed  
13          and Southern States had booked all of the plant in  
14          service.

15          **Q. MR. HARTMAN, DO YOU HAVE ANY ADDITIONAL ISSUES YOU**  
16          **WISH TO DISCUSS?**

17          **A.** Yes. I do not believe that, from an engineering  
18          standpoint, CIAC should be imputed on any of the  
19          margin reserve capacity. The Company has a duty to  
20          provide service to the customers when they apply.  
21          The imputation of CIAC is inappropriate because  
22          whether customers will actually hook onto the  
23          system is beyond the Company's control and they may  
24          never do so. Also, there is no guarantee that the  
25          CIAC levels which exist today, and thus would be



1 utilized to compute the imputation, will not be  
2 decreased by the Commission in the future. Under  
3 either scenario, Southern States would never be  
4 able to recover a portion of its prudently invested  
5 funds. Therefore, the imputation would be premised  
6 on two totally speculative events whereas the  
7 Company's duty to stand ready to serve is real and  
8 remains a regulatory requirement imposed on the  
9 Company under Chapter 367, Florida Statutes, and  
10 DER Rules and Regulations. Second, I have reviewed  
11 the fire flow requirements for the Deltona Lakes  
12 system and they appear to have been overstated in  
13 the original application. The original application  
14 stated fire flow requirements to be 2,500 gallons  
15 per minute for 4 hours. The appropriate fire flow  
16 requirement is 2,500 gallons per minute for 2  
17 hours, not 4 hours.

18 Q. DO YOU AGREE WITH THE CONTENTION THAT NO MARGIN  
19 RESERVE SHOULD BE ALLOWED FOR THE SALT SPRINGS  
20 WASTEWATER SYSTEM SINCE IT HAS EXPERIENCED NO  
21 GROWTH IN THE PAST 3 YEARS AND IS ESSENTIALLY  
22 BUILT-OUT?

23 A. No. The Salt Springs system is not built-out and  
24 although it may not have experienced any growth in  
25 the past 3 years, there are still vacant lots to be

1 occupied and Adventure Resorts of America is  
2 considering an expansion of their RV park at this  
3 time which would provide a substantial increase in  
4 the number of connected ERC's for both the water  
5 and wastewater systems.

6 **Q. DO YOU AGREE THAT THE WOODMERE WATER AND WASTEWATER**  
7 **SYSTEMS SHOULD RECEIVE NO MARGIN RESERVE DUE TO LOW**  
8 **GROWTH RATE?**

9 **A.** No. The SSU commitment report indicates that there  
10 are four current developments that either are in  
11 process or are beginning to connect to the Woodmere  
12 system. Thus, the service area does not appear to  
13 be built-out and as soon as the economy picks up,  
14 it is expected that growth will once again occur  
15 for the Woodmere system and it more than likely  
16 would exceed the 3.9% historical 5 year average  
17 indicated in the MFRs.

18 **Q. DO YOU HAVE ANY USED AND USEFUL PERCENTAGES WHICH**  
19 **YOU WISH TO REVISE AT THIS TIME?**

20 **A.** Yes. Through the discovery process, it became  
21 apparent that on the maximum day utilized in the  
22 determination of the used and usefulness of the  
23 Marion Oaks water system, there was a main break  
24 occurrence, and this unusual event should have been  
25 ignored. However, it is certainly a fact that

1           these things do occur and the utility must have  
2           sufficient capacity in order to continue to provide  
3           sufficient service and also manage these  
4           situations. If the May 14, 1991 maximum day is  
5           ignored, the next highest maximum day was June 16,  
6           1991 in which 1,032,000 gallons of water were  
7           pumped to the Marion Oaks customers. For systems  
8           such as Marion Oaks, which have adequate storage,  
9           the source of supply must be able to meet the  
10          average daily demand during the maximum day. Thus,  
11          the average daily demand using the June 16, 1991  
12          maximum day is 717 gallons per minute. The  
13          reliable well capacity with the largest well out of  
14          service is 1,000 gallons per minute, thus the  
15          revised used and useful capacity of the historical  
16          test year is 72% for the supply wells without the  
17          margin reserve. The finished water storage and  
18          high service pumps remain 100% used and useful, the  
19          hydropneumatic tanks' used and useful percentages  
20          remain the same, and the distribution system  
21          remains 31% used and useful excluding the margin  
22          reserve.

23        **Q. DO YOU AGREE THAT THE DELTONA LAKES, SUGAR MILL,**  
24        **JUNGLE DEN, FOX RUN, PALMS MOBILE HOME PARK,**  
25        **SUNSHINE PARKWAY AND VENETIAN VILLAGE WATER**

1           **DISTRIBUTION SYSTEMS ARE LESS THAN 100% USED AND**  
2           **USEFUL?**

3           A.   No.   These systems, like most of the other water  
4           systems in this rate application, could not provide  
5           service to existing customers with any less of a  
6           water transmission and distribution system.  There  
7           may remain some vacant lots within these systems  
8           but they must be considered fill-in lots.  Many  
9           developments never reach 100% occupancy and if the  
10          methodology that is being proposed by Staff is  
11          utilized, the utility would never receive a return  
12          on its prudent investment.  In addition, I do not  
13          understand why these systems have been singled out  
14          as being something less than 100% used and useful  
15          when they have similar characteristics as many  
16          other systems that are included in this rate  
17          application and that have been considered by Staff  
18          in previous cases to be 100% used and useful.  For  
19          example, in the 1990 rate case (Docket No. 900329-  
20          WS), the Staff recommendation indicated that the  
21          Fox Run system was 100% used and useful.  I also  
22          question whether electric or telephone utilities  
23          are subjected to the disallowance for used and  
24          useful purposes of "fill-in lots."  I do not  
25          believe they are and I do not see how such an

1 adjustment could be considered proper.

2 Q. DO YOU AGREE THAT THE SOUTH FORTY WASTEWATER  
3 TREATMENT FACILITY USED AND USEFUL DETERMINATION IS  
4 OVERSTATED SINCE THE CAPACITY OF THE SOUTH FORTY  
5 PLANT AND NOT THE SPRAY FIELD SHOULD BE USED TO  
6 CALCULATE THE CAPACITY?

7 A. No. The permitted condition of the South Forty  
8 treatment facility is limited to the capacity of  
9 the spray field site and hence that should be used  
10 as the denominator in the determination of the used  
11 and useful facilities. In addition, it should be  
12 noted that at one time this system had  
13 substantially higher flows due to one single  
14 customer that was lost in 1990, namely, Gold Bond  
15 Ice Cream. A refurbished treatment facility was  
16 brought in (the 75,000 gallon per day treatment  
17 plant), when the old facility was being overloaded  
18 due to the Gold Bond Ice Cream customer. However,  
19 not long after the refurbished 75,000 gallon per  
20 day plant was brought in, Gold Bond Ice Cream  
21 closed its doors, resulting in a dramatic decrease  
22 in flows. It should also be noted that this  
23 refurbished 75,000 gallon per day plant was  
24 probably acquired at a cost much less than it would  
25 have cost to construct say a 30,000 gallon per day

1 plant which otherwise would have been required to  
2 serve the existing customers besides Gold Bond Ice  
3 Cream. For these reasons, and as I indicated  
4 previously, the Company should not be penalized by  
5 a reduction to the prior use of its plant due to  
6 circumstances beyond its control.

7 Q. DO YOU AGREE THAT THE DELTONA LAKES, SUGAR MILL,  
8 JUNGLE DEN, FOX RUN, SUNSHINE PARKWAY, AND VENETIAN  
9 VILLAGE WASTEWATER COLLECTION SYSTEMS ARE LESS THAN  
10 100% USED AND USEFUL?

11 A. No. As stated previously, these systems may have  
12 some vacant lots spread throughout their service  
13 area but essentially no less of a system could  
14 provide service to the existing customers, hence  
15 they should be considered 100% used and useful.

16 Q. DOES THAT CONCLUDE YOUR PREFILED REBUTTAL  
17 TESTIMONY?

18 A. Yes, it does at this time.

Exhibit \_\_\_\_ (GCH-3)  
Cover Page

CAPITAL COST CURVES

---

# HARTMAN & ASSOCIATES, INC.

---

engineers, hydrogeologists, surveyors & management consultants

April 30, 1992

HAI #91-230.00

Hand Delivered

Lowell W. Hendricks  
Construction Project Manager  
Southern States Utilities, Inc.  
1000 Color Place  
Apopka, Florida 32703

**Subject: Industry Standard Capital Planning Costs**

Dear Mr. Hendricks:

Enclosed are five draft figures indicating Hartman & Associates, Inc.'s best effort in compiling water and wastewater industry standard capital planning costs. The information presented in these four figures represents the knowledge of HAI employees with over \$500 million in constructed facilities experience. These facilities represent an appropriate mixture of public and private utility project costs. Since every capital project is unique, it should be understood that these costs represent an industry average and should be used for early planning stage cost estimates only. As the specific project becomes more definitive, a planning or preliminary construction cost estimate should be determined.

The cost per gallon axis should be interpreted as 1992 costs. I would recommend using the Engineering News Record (ENR) Construction Cost Index to trend these costs. Attached is the ENR summary for 1971 through 1992. The four figures for water represent the four most common water systems utilized by the industry today. The cost per gallon is indicated on a function of both the system size in annual average daily flow (AADF) and peaking factor. The peaking factor is the ratio of the peak hour demand during the year or an instantaneous demand for small systems, divided by the annual average daily flow. Typically, the larger the system, the less the peaking factor. It should be noted that these costs do not include the transmission and distribution system. The range indicated by the band width is the result of various appurtenances being included or not included in the project.

The wastewater figure does not include the costs of effluent disposal or collection systems. Effluent disposal costs were not included due to the great range of variability of the costs associated with the various disposal alternatives. The width of the band indicates the differences in cost from a simple activated sludge process to a EPA Class I reliable or advanced level treatment facilities.



Lowell W. Hendricks  
April 30, 1992  
Page Two

If you desire any additional information or further refinement of these figures, please do not hesitate to call.

Very truly yours,


**Hartman & Associates, Inc.**

  
Charles M. Bliss, E.I.  
Project Engineer

CMB/11/C-7/hend.cmb  
Enclosures - 5 Figures and 1 Table

cc: Charles E. Wood, V.P.-Planning and Engineering, SSU  
Charles K. Lewis, Rate Director, SSU  
Gary S. Morse, Senior Rate Engineer, SSU  
Gerald C. Hartman, President, HAI

PEAK FACTOR



FIGURE



**HARTMAN & ASSOCIATES, INC.**

engineers, hydrogeologists, surveyors & management consultants

201 EAST PINE STREET - SUITE 1000 - ORLANDO, FL 32801  
TELEPHONE (407) 839-3655 - FAX (407) 839-3790

**WATER CAPITAL PLANNING COSTS  
WELLS, CHLORINATION AND HYDROPNEUMATIC TANKS**




Exhibit (CH-3)  
Page 4 of 8

FIGURE




**HARTMAN & ASSOCIATES, INC.**

engineers, hydrogeologists, surveyors & management consultants

201 EAST PINE STREET - SUITE 1000 - ORLANDO, FL 32801  
TELEPHONE (407) 839-3955 - FAX (407) 839-3790

**WATER CAPITAL PLANNING COSTS**  
**WELLS, AERATION, GROUND STORAGE, CHLORINATION AND PUMPING**



FIGURE




**HARTMAN & ASSOCIATES, INC.**

engineers, hydrogeologists, surveyors & management consultants

201 EAST PINE STREET - SUITE 1000 - ORLANDO, FL 32801  
TELEPHONE (407) 839-3955 - FAX (407) 839-3790

**WATER CAPITAL PLANNING COSTS  
WELLS, AERATION, LIME SOFTENING, GROUND WATER,  
CHLORINATION AND PUMPING**

PEAK FACTOR



NOTE: COSTS DO NOT INCLUDE BRINE DISPOSAL.

FIGURE




**HARTMAN & ASSOCIATES, INC.**

engineers, hydrogeologists, surveyors & management consultants

201 EAST PINE STREET - SUITE 1000 - ORLANDO, FL 32801  
 TELEPHONE (407) 838-3833 -- FAX (407) 838-3780

**WATER CAPITAL PLANNING COSTS  
 WELLS, REVERSE OSMOSIS, DEGASIFICATION,  
 GROUND STORAGE, CHLORINATION AND PUMPING**



NOTE: COST DOES NOT INCLUDE EFFLUENT DISPOSAL OR THE COLLECTION SYSTEM.

FIGURE



**HARTMAN & ASSOCIATES, INC.**  
 engineers, hydrogeologists, surveyors & management consultants  
 201 EAST PINE STREET - SUITE 1000 - ORLANDO, FL 32801  
 TELEPHONE (407) 839-3955 - FAX (407) 839-3790

**WASTEWATER CAPITAL PLANNING COSTS  
 ACTIVATED SLUDGE TREATMENT**

Year	Month												Annual Average
	Jan.	Feb.	Mar.	Apr.	May	June	July	Aug.	Sept.	Oct.	Nov.	Dec.	
1971	1465	1467	1496	1513	1551	1589	1618	1629	1654	1657	1665	1672	1581
1972	1686	1691	1697	1707	1735	1761	1772	1777	1786	1794	1808	1816	1753
1973	1838	1850	1859	1874	1880	1896	1901	1902	1929	1933	1935	1939	1895
1974	1940	1940	1940	1961	1961	1993	2040	2076	2089	2100	2094	2101	2020
1975	2103	2128	2128	2135	2164	2205	2248	2274	2275	2293	2292	2297	2212
1976	2305	2314	2322	2327	2357	2410	2414	2445	2465	2478	2486	2490	2401
1977	2494	2505	2513	2514	2515	2541	2579	2611	2644	2675	2659	2660	2576
1978	2672	2681	2693	2698	2733	2753	2821	2829	2851	2851	2861	2869	2776
1979	2872	2877	2886	2886	2889	2984	3052	3071	3120	3122	3131	3140	3003
1980	3132	3134	3159	3143	3139	3198	3260	3304	3319	3327	3355	3376	3237
1981	3372	3373	3384	3450	3471	3496	3548	3616	3657	3660	3697	3695	3535
1982	3704	3728	3721	3731	3734	3815	3899	3899	3902	3901	3917	3950	3825
1983	3960	4001	4006	4001	4003	4073	4108	4132	4142	4127	4133	4110	4066
1984	4109	4113	4118	4132	4142	4161	4166	4169	4176	4161	4158	4144	4146
1985	4145	4153	4151	4150	4171	4201	4220	4230	4229	4228	4231	4228	4195
1986	4218	4230	4231	4242	4275	4303	4332	4334	4335	4344	4342	4351	4295
1987	4354	4352	4359	4363	4369	4387	4404	4443	4456	4459	4453	4478	4406
1988	4470	4473	4484	4489	4493	4525	4532	4542	4535	4555	4567	4568	4519
1989	4574	4567	4568	4571	4572	4593	4598	4606	4647	4646	4655	4679	4606
1990	4673	4674	4701	4702	4696	4734	4734	4751	4755	4758	4780	4769	4727
1991	4770	4773	4772	4766	4801	4818	4854	4892	4891	4892	4896	4889	4835
1992	4885	4884											

FIGURE



**HARTMAN & ASSOCIATES, INC.**

engineers, hydrogeologists, surveyors & management consultants

201 EAST PINE STREET - SUITE 1000 - ORLANDO, FL 32801  
TELEPHONE (407) 839-3955 - FAX (407) 839-3790

**ENGINEERING NEWS RECORD  
CONSTRUCTION COST INDEX HISTORY 1971-1992  
MONTHLY INDEX**

Exhibit \_\_\_\_ (GCH-4)  
Cover Page

MEMORANDUM OF UNDERSTANDING  
BETWEEN  
FLORIDA DEPARTMENT OF ENVIRONMENTAL REGULATION  
AND  
FLORIDA PUBLIC SERVICE COMMISSION





# Public Service Commission

-M-E-M-O-R-A-N-D-U-M-

DATE: August 25, 1992  
TO: David Swafford, Executive Director  
FROM: Charles Hill, Division of Water and Wastewater *CH*  
Noreen Davis, Division of Legal Services *nd*  
RE: Memorandum of Understanding with the Department of Environmental  
Regulation and Proposed Legislation on Water Conservation

PLEASE PLACE ON THE NEXT INTERNAL AFFAIRS

Attached to this recommendation is the final draft Memorandum of Understanding (MOU) with the Department of Environmental Regulation. The MOU spells out each of our agency's roles in developing a statewide water conservation plan. A similar MOU with the Water Management Districts was completed and signed on June 27, 1991.

Commission staff has been working informally with both DER and the WMDs over the last several years in various certification and rate cases. DER provides testimony in rate cases where quality of service is a controversial issue. DER has recently updated its internal procedures to officially recognize the Commission staff's interpretation of Section 367.031, Florida Statutes. That section requires that a utility must obtain a certificate of authorization from the Commission prior to being issued a permit by the DER for the construction of a new water or wastewater facility or prior to being issued a consumptive use or drilling permit by a water management district. The section also requires each jurisdictional utility to obtain a certificate of authorization or an exemption order from the Commission. The Commission staff believes that these provisions must be read together to accomplish the legislative intent. DER's General Counsel concurs in this interpretation. The result is that DER now requires an applicant to submit documentation as to its exempt status with the PSC. This change in DER's procedures will help to close a gap by prohibiting proposed new water and wastewater utilities which are subject to the Commission's jurisdiction from being constructed without the appropriate Commission action.

The Commission staff has provided assistance to DER by reviewing the financial portion of feasibility studies submitted by utilities related to the projected cost of providing reclaimed water for reuse. Our staff is also participating in the monthly meetings of the Reuse Coordinating Committee. This committee is one of eighteen committees formed to develop and coordinate the statewide water conservation program. DER, the WMDs and the PSC staff hope to have a jointly supported package of legislation designed to implement conservation and reuse. A copy of two proposed additions to Chapter 367, F. S. are attached. The first addition would give the Commission statewide rate structure and territorial dispute jurisdiction over water, wastewater, and reuse systems owned by governmental authorities and cooperatives. The second addition would eliminate master metering on new construction of mobile home parks, apartments, condominiums, etc. These two proposals are preliminary drafts.

The MOU outlines the respective objectives and responsibilities of DER and the PSC and provides for coordination of our agencies through project managers who will meet on a regular basis. In particular, the PSC will continue to review rate structures for the utilities

within the Commission's jurisdiction to determine whether the structure encourages conservation. DER has expressed some concern over its acceptance of our interpretation of Section 367.031, F. S., as discussed above. The MOU states that the PSC agrees to provide legal and technical support to DER in any related administrative hearings or legal proceedings. The PSC agrees to consider DER rules related to capacity requirements for wastewater systems in our application of the "used and useful" concept. In addition, when a utility regulated by the PSC files a reuse feasibility study with DER, the DER will provide a copy of the study to the PSC. The PSC staff will review the study for completeness and advise DER as to whether or not the staff will be able to conduct a complete review and provide comments.

Staff recommends that the Commission adopt the attached Memorandum of Understanding. The attached draft of proposed legislation is for your review. It will be presented to you formally at a later date.

MEMORANDUM OF UNDERSTANDING

FLORIDA DEPARTMENT OF ENVIRONMENTAL REGULATION  
AND  
FLORIDA PUBLIC SERVICE COMMISSION

The Florida Department of Environmental Regulation (DER) and the Florida Public Service Commission (PSC) recognize that water conservation and reuse of reclaimed water are key elements of Florida's long-term water management strategy. It is our joint goal and high priority to ensure that Florida water and wastewater utilities provide safe and efficient treatment and use of water and wastewater. This memorandum of understanding (MOU) formally establishes the policies and procedures to be followed by the DER and PSC to promote and encourage water conservation and reuse, and safe and efficient water supply and wastewater management services.

BACKGROUND

Water Supply

The Federal Safe Drinking Water Act requires certain monitoring, testing, treatment, and reporting to ensure the quality of potable waters. The Florida Safe Drinking Water Act, contained in Chapter 403, Florida Statute (F.S.), outlines the basic requirements for Florida's water supply program. Chapters 17-550, 17-551, 17-555, and 17-560, Florida Administrative Code (F.A.C.), contain specific requirements governing water supply in Florida. The PSC's responsibilities for regulation of private water supply utilities are outlined in Chapter 367, F.S.

Wastewater Management

The Federal Clean Water Act requires effective treatment and management of wastewater in order to protect the nation's ground water and surface water resources. Florida's wastewater management and environmental control programs are contained in Chapter 403, F.S. Specific regulations governing domestic wastewater management are contained in Chapters 17-600, 17-601, 17-602, 17-604, 17-610, 17-611, 17-640, and 17-650, F.A.C. The PSC's responsibilities for regulation of private wastewater utilities are outlined in Chapter 367, F.S.

Reuse of Reclaimed Water

The encouragement and promotion of water conservation and reuse of reclaimed water are established as state objectives in Section 403.064(1), F.S.

The DER has developed and implemented a comprehensive reuse program designed to meet those objectives. This reuse program includes:

1. Comprehensive rules governing the reuse of reclaimed water (Chapter 17-610, F.A.C);
2. A mandatory reuse program;
3. An Antidegradation Policy;
4. The Indian River Lagoon System and Basin Act; and
5. Requirements for evaluation of reuse feasibility.

Section 403.064, F.S., requires that after January 1, 1992, all applicants for permits to construct or operate a domestic wastewater treatment facility in a critical water supply problem area evaluate the cost and benefits of reusing reclaimed water as part of their application for the permit.

The Antidegradation Policy is contained in Chapter 17-4, F.A.C., "Permits," and Chapter 17-302, F.A.C., "Surface Water Quality Standards." These rules require an applicant for a new or expanded discharge to surface waters to demonstrate that the discharge is clearly in the public interest. As part of this public interest test, the applicant must evaluate the feasibility of reuse of reclaimed water. If reuse is economically and technologically reasonable, it will be preferred over the surface water discharge.

The Indian River Lagoon System and Basin Act, which is contained in Chapter 90-262, Laws of Florida, provides increased protection to the Indian River Lagoon System. Section 3 of the Act requires the owner of an existing sewage treatment facility within the Indian River Lagoon Basin to investigate the feasibility of using reclaimed water for beneficial purposes. These reuse feasibility studies were to be completed before July 1, 1992.

## OBJECTIVES

The common objectives, as they relate to domestic water supply and wastewater management facilities subject to regulation by the DER and the PSC, are as follows:

1. To monitor water supply systems to ensure that safe and reliable water is produced and delivered in accordance with applicable rules and drinking water standards;
2. To monitor domestic wastewater systems to ensure the safe and efficient collection, treatment, and reuse or disposal of wastewater and residuals;
3. To encourage and promote water conservation and reuse of reclaimed water;
4. To foster conservation and to reduce the withdrawal of ground and surface water through employment of conservation-promoting rate structures, reuse of reclaimed water, and consumer education programs.

## PSC RESPONSIBILITIES

The following presents the general description of the roles and responsibilities of the PSC related to water supply, water conservation, wastewater management, and reuse of reclaimed water. The PSC's jurisdiction is limited to economic regulation of investor-owned utilities and is effective in only some of the counties in Florida. The PSC will offer assistance to the extent provided by law and agency priority and workload. The PSC agrees to adopt and implement policies and procedures necessary to administer these duties.

### Water Supply

1. When appropriate, arrange for joint public meetings with customers to ensure that customers are aware of the need for water supply system improvement projects, and the potential impacts the projects will have on service rates.
2. Inform the DER of the PSC public meetings with customers and hearings in which water supply projects will be discussed.
3. Review proposed rate structures for private utilities within PSC jurisdiction.

4. Provide assistance in review of water conservation rate structures within PSC jurisdiction.
5. Monitor abandonment and bankruptcy proceedings for private water utilities within PSC jurisdiction. Inform the DER of pending abandonment and bankruptcy cases.
6. If an applicant for a DER permit challenges the interpretation of Section 367.031, F.S., the PSC agrees to provide legal and technical support to the DER in any related administrative hearings or legal proceedings.

#### Wastewater Management

1. When appropriate, arrange for joint public meetings with customers to ensure that customers are aware of the need for wastewater management system improvement projects, and the potential impacts the projects will have on service rates.
2. Inform the DER of the PSC public meetings with customers and hearings in which wastewater management projects will be discussed.
3. Review proposed rate structures for private wastewater management utilities within PSC jurisdiction.
4. Monitor abandonment and bankruptcy proceedings for private wastewater utilities within PSC jurisdiction. Inform the DER of pending abandonment and bankruptcy cases.
5. If an applicant for a DER permit challenges the interpretation of Section 367.031, F.S., the PSC agrees to provide legal and technical support to the DER in any related administrative hearings or legal proceedings.
6. The DER has adopted rules requiring utilities to perform timely planning, design, and construction of expanded facilities to ensure that sufficient wastewater treatment, disposal, and reuse capacity is available. In light of DER rules, the PSC agrees to evaluate capacity constraints imposed by statute and rules on private utilities within PSC jurisdiction, by PSC's application of the "used and useful" concept. If justified, this evaluation shall include assessment of possible need for statutory or rule revisions.

#### Reuse

1. When appropriate, arrange for joint public meetings with customers to ensure that customers are made aware of the need for reuse system improvement projects, and the potential impacts the projects will have on service rates.

2. Inform the DER of the PSC public meetings with customers and hearings in which reuse of reclaimed water will be discussed.
3. Provide feasibility analyses of the financial impacts, if any, of reuse system projects on both the customers and the wastewater utilities within PSC jurisdiction.
4. Within 10 days of receipt of a reuse feasibility study, the PSC staff shall review the document for completeness of the financial aspects and shall notify the DER whether or not the document is complete and whether or not the PSC will be able to conduct a complete review. If the PSC staff determines that it will be able to review the document, the PSC staff shall provide comments and recommendations to the DER within 30 days of receipt of the complete document.
5. Participate in appropriate DER hearings in which the feasibility of reuse will be discussed.
6. Review proposed rate structures for reuse projects for private utilities within PSC jurisdiction. As noted in Section 403.064(6), F.S., and pursuant to Chapter 367, F.S., the PSC shall allow utilities which implement reuse projects to recover the full cost of such facilities through their rate structures.
7. Assist the water management districts in review of reuse feasibility studies associated with the mandatory reuse program in Chapter 17-40, F.A.C., and other reuse-related activities of the water management districts in the counties within PSC jurisdiction. A separate MOU between the water management districts and the PSC governs these activities.

#### DER RESPONSIBILITIES

The following is a general description of the roles and responsibilities of the DER related to potable water supply, water conservation, wastewater management, and reuse of reclaimed water. The DER agrees to adopt and implement policies and procedures necessary to administer these duties.

##### Water Supply

1. Review applications for construction of potable water supply systems.
2. Monitor compliance of potable water supply systems with applicable rules and drinking water standards.

3. Notify the PSC of impending abandonment or bankruptcy cases involving water utilities and assist the PSC in such cases, as needed.
4. For utilities subject to Chapter 367, F.S., the DER shall verify the existence of a certificate of authorization or order indicating exempt status from the PSC before issuance of a construction permit for a new water system.

#### Wastewater Management

1. Review applications for construction and operation of domestic wastewater facilities.
2. Monitor compliance of domestic wastewater management facilities with applicable rules and effluent discharge limitations.
3. Monitor water quality in the State's ground waters and surface waters.
4. Notify the PSC of impending abandonment or bankruptcy cases involving wastewater utilities and assist the PSC in such cases, as needed.
5. For utilities subject to Chapter 367, F.S., the DER shall verify the existence of a certificate of authorization or order indicating exempt status from the PSC before issuance of a construction permit for a new wastewater facility.

#### Reuse

1. Administer the State's reuse program.
2. Review reuse feasibility studies required by Section 403.064, F.S., the Antidegradation Policy, or the Indian River Lagoon System and Basin Act.
3. Within five working days after receipt of a reuse feasibility study required by Section 403.064, F.S., the Antidegradation Policy, or the Indian River Lagoon System and Basin Act, the DER shall provide a copy of the reuse feasibility study to the PSC. This applies only to feasibility studies produced by private utilities located within counties regulated by the PSC.
4. Final determinations on the adequacy of reuse feasibility studies will be made by the DER. Comments and recommendations made by the PSC on the financial aspects of these reuse feasibility studies will be considered by the DER.



5. Participate in appropriate PSC public meetings with customers and hearings in which reuse issues raised by the DER are to be discussed. This may include, but is not limited to, expert witness testimony.

#### PROJECT COORDINATION

##### Water Supply

1. The PSC will designate a Water Supply Project Manager.
2. The DER's Drinking Water Section Administrator will serve as the DER's Water Supply Project Manager.
3. Exchange of information between the DER and the PSC shall be through the designated Water Supply Project Managers. Copies of pertinent correspondence related to water supply and water conservation issues shall be sent to the appropriate agency's Water Supply Project Manager.

##### Wastewater Management

1. The PSC will designate a Wastewater Management Project Manager.
2. The DER's Domestic Wastewater Section Administrator will serve as the DER's Wastewater Management Project Manager.
3. Exchange of information between the DER and the PSC shall be through the designated Wastewater Management Project Managers. Copies of pertinent correspondence related to wastewater management issues shall be sent to the appropriate agency's Wastewater Management Project Manager.

##### Reuse

1. The PSC will designate a Reuse Project Manager. All reuse feasibility studies provided to the PSC by the DER will be directed to this Project Manager.
2. The DER's Reuse Coordinator will serve as the DER's Reuse Project Manager for purposes of this agreement.
3. Reuse feasibility studies to be submitted to the PSC will be submitted over the signature of the DER Reuse Coordinator or over the signature of one of the six Water Facilities Administrators located in the DER district offices.

4. The DER Reuse Coordinator shall be copied on any correspondence between the PSC's Project Manager and the DER's Water Facilities Administrators regarding reuse feasibility studies.
5. Whenever a potential conflict regarding a specific project is identified, each agency will examine the alternative solutions available and then meet to discuss the issues involved and attempt to reach an agreement before announcing a position. If an agreement cannot be reached after due deliberations, several positions may be advocated. Such disagreements, if any, will not obviate this MOU.
6. Exchange of information between the DER and the PSC shall be through the designated Reuse Project Managers. Copies of pertinent correspondence between an agency and other parties concerning a reuse project shall be sent to the Reuse Project Manager of each agency until project completion.

#### Overall Coordination

The designated Water Supply, Wastewater Management, and Reuse Project Managers from the DER and the PSC shall meet as necessary, but at least annually, with the Director of the Water and Wastewater Division of the PSC and the Director of the Division of Water Facilities of the DER. The meetings will address and review progress on the water supply, wastewater management, and reuse programs in Florida and attempt to resolve any issues which may be identified by the staffs.

#### AMENDMENTS

This MOU may be amended by mutual agreement of the DER and PSC. It shall remain in effect until it is dissolved by mutual agreement among the agencies or terminated by an agency after giving written notice 30 days in advance to the other agency.

EFFECTIVE DATE AND SIGNATURES

This MOU will become effective after being signed by both parties.

\_\_\_\_\_  
Thomas M. Beard, Chairman  
Florida Public Service  
Commission

\_\_\_\_\_  
Carol M. Browner, Secretary  
Department of Environmental  
Regulation

\_\_\_\_\_  
Date

\_\_\_\_\_  
Date

Exhibit \_\_\_\_ (GCH-5)  
Cover Page

COMMISSION STAFF CURRENT DRAFT  
OF USED AND USEFUL RULES

WATER AND WASTEWATERCHAPTER 25-3025-30.432 Used and Useful in rate case proceedings.

(1) The Commission shall allow a utility to recover, through authorized rates, charges and fees, the costs incurred in meeting its statutory obligations to provide safe, efficient and sufficient service. The utility's investment, prudently incurred, in meeting its statutory obligations shall be considered used and useful.

(2) It is the policy of this Commission to encourage utility planning that recognizes conservation, environmental protection, economies of scale, and which is economically beneficial to its customers over the long term.

(3) In determining those portions of water and wastewater systems that are used and useful in serving the public, the Commission shall consider:

(a) the design and construction requirements set forth in Chapter 17-555, F.A.C., Permitting and Construction of Public Water Systems and Chapter 17-600, F.A.C., Domestic Wastewater Facilities;

(b) the investment in land acquired or facilities constructed or to be constructed in the public interest within a reasonable time in the future;

(c) the prudence of the investment, taking into consideration such factors as (i) the treatment process, (ii) water storage capacity, (iii) economies of scale, (iv) the historical and projected rate of growth in customers and demand, (v) seasonal demand characteristics, (vi) residential and commercial mix, and (vii) the configuration of the service area.

CODING: Words underlined are additions; words in ~~struck through~~ type are deletions from existing law.

WATER AND WASTEWATERCHAPTER 25-30

1' (4) In order to encourage long-term planning and least cost  
2 system design, the Commission, at a minimum, shall consider as used  
3 and useful the level of investment that would have been required  
4 had the utility designed and constructed the system to serve only  
5 its existing customer base.

6 (5) For the purpose of calculating used and useful, the following  
7 specific factors shall apply. When applying these factors,  
8 references to customer demand shall mean the demand per ERC used  
9 for design or permitting and/or the actual historical demand per  
10 ERC, whichever is greater.

11 (a) Margin Reserve

12 1. The Commission recognizes, that in order for a utility  
13 to be able to meet its statutory responsibility, it must  
14 have sufficient capacity and investment to meet the  
15 existing and changing demands of present customers, and the  
16 demands of potential customers within a reasonable time.  
17 The investment needed to meet the demands of potential  
18 customers and the changing demands of existing customers,  
19 is defined as margin reserve. As a matter of policy, the  
20 Commission recognizes margin reserve as a component of used  
21 and useful rate base.

22 2. In determining the allowable investment in margin  
23 reserve, the Commission shall consider, but not be limited  
24 to (i) the functions of each component of plant (treatment,  
25 transmission, distribution, etc.), (ii) the treatment

CODING: Words underlined are additions; words in  
~~struck through~~ type are deletions from existing law.

WATER AND WASTEWATERCHAPTER 25-30

1 process, (iii) regulatory requirements, including those  
2 requiring plant redundancies, (iv) regulatory lag, (v) the  
3 rate of growth in customers and demand, (vi) seasonal  
4 demand characteristics, (vii) the economies of scale, and  
5 (viii) the construction time frame.

6 3. As a part of its rate filing, the utility shall submit  
7 historical data for a minimum of five years preceding the  
8 test year for (i) the number of customers by class and  
9 meter size, (ii) annual sales by class, (iii) annual  
10 treated or pumped flows for the system, (iv) and monthly  
11 system peak day flows.

12 4. Unless otherwise justified, the following margin reserve  
13 allowances shall be used:

14 i. Water source and treatment facilities and wastewater  
15 treatment and disposal facilities: 20% of the permitted  
16 or actual ERC capacity, whichever is greater;

17 ii. Prudently constructed water transmission mains and  
18 off-site wastewater force and gravity collector mains  
19 and pumping stations shall be considered 100% used and  
20 useful, and margin reserve shall therefore not be a  
21 factor.

22 iii. Non-contributed on-site water distribution mains  
23 and services and on-site wastewater collection mains,  
24 pumping stations and laterals: 20% of the ERCs capable  
25 of being served. However, where the utility

CODING: Words underlined are additions; words in  
~~struck through~~ type are deletions from existing law.

WATER AND WASTEWATERCHAPTER 25-30

1 demonstrates that such portions of the system will  
2 likely reach build-out within 36 months after the test  
3 year, such portions of the system shall be considered  
4 100% used and useful, and margin reserve shall therefore  
5 not be a factor.

6 (b) Fire Flow

7 1. Fire flow shall be considered in used and useful  
8 calculations for any utility that requests that fire flow  
9 be a consideration in its system requirements.

10 2. Insufficient capacity to provide adequate fire flows  
11 shall not be grounds to exclude fire flows as a factor in  
12 determining used and useful; however the Commission may  
13 require the utility to take the steps necessary to provide  
14 adequate fire flow capacity. In so doing, the Commission  
15 shall set a reasonable time table for compliance and may  
16 withhold that portion of the rates associated with the  
17 required additions and fire flow capacity allowed, until  
18 the requirements set by the Commission are met.

19 3. When fire flow requirements are set by a governmental  
20 authority, those requirements shall be the basis for  
21 determining the fire flow component of used and useful. in  
22 such cases, as part of its rate filing, the utility shall  
23 identify and file with the Commission a copy of the  
24 applicable governmental fire flow requirements. In all  
25 other cases, unless specific support is provided, the

CODING: Words underlined are additions; words in  
~~struck through~~ type are deletions from existing law.



WATER AND WASTEWATERCHAPTER 25-30

1 Commission shall consider a minimum fire flow demand to be  
2 500 gpm for single family and 1,500 gpm for multiple family  
3 and commercial areas for a duration of two (2) hours for  
4 needed fire flows up to 2500 gpm, and three (3) hours for  
5 needed fire flows of 3000 and 3500 gpm. Such requirements  
6 shall be satisfied without causing deterioration of water  
7 pressure below 20 psi.

8 (c) Unaccounted for Water

9 1. It is the policy of this Commission to recognize  
10 conservation of water as a fundamental and proper concern  
11 of water system operation. The Commission encourages water  
12 utilities to exercise good operational and economic  
13 management toward preventing depletion and wasteful use of  
14 this important natural resource. Good modern water utility  
15 practice dictates that, wherever possible, all customer  
16 services and plant output and plant uses be metered and  
17 reasonable records be kept.

18 2. Unaccounted for water is all water produced or purchased  
19 by a water utility that is neither sold, metered nor  
20 accounted for in the records of the utility. Water, other  
21 than that sold, which can and should be accounted for  
22 includes, but is not limited to, water for plant  
23 operations, line flushing, hydrant testing, hydrant use,  
24 sewer cleaning, street cleaning, line breaks, leakage,  
25 theft, unauthorized use, malfunctions and meter errors.

CODING: Words underlined are additions; words in  
~~struck-through~~ type are deletions from existing law.

WATER AND WASTEWATERCHAPTER 25-30

1 3. The Commission recognizes that some uses of water are  
2 readily measurable and others are not. The Commission  
3 encourages each utility to establish procedures to measure  
4 or estimate the quantity of water used but not sold, by  
5 cause, and to maintain documentation for those measurements  
6 and estimates.

7 4. The Commission shall consider the amount of unaccounted-  
8 for water in determining used an useful expenses and shall  
9 allow the AWWA Standards' design level of leakage (2-3%  
10 plus the standard 10% for a maximum of 12.5%) without  
11 further explanation. Imputation of revenues or reductions  
12 to purchased power and chemical expenses may be made where  
13 inadequate explanation is given for unaccounted for water  
14 in excess of this amount.

15 (d) Infiltration and Inflow

16 1. It is the policy of the Commission to consider the  
17 impact of infiltration and inflow on wastewater treatment  
18 and collection systems in determining the appropriate level  
19 of operation and maintenance expenses. Infiltration refers  
20 to those extraneous flows (usually from groundwater  
21 sources) that enter the wastewater system through openings  
22 in pipes that may be caused by normal deterioration,  
23 corrosion, or damage from ground movement or structural  
24 overload. Inflow refers to extraneous flows from sources  
25 other than infiltration, such as surface water run-off into

WATER AND WASTEWATERCHAPTER 25-30

1 manholes or from unauthorized connections to surface water  
2 sources. Although a utility has little control over the  
3 amount of inflow, it should provide an estimate, with  
4 support, of the annual flows in its system due to inflow.  
5 Without specific support allowable inflow will be 10% of  
6 treated flows. Infiltration should be kept at an  
7 economically acceptable level.

8 2. The Commission recognizes as reasonable the Infiltration  
9 Specification Allowances set forth in Water Environment  
10 Federation Manual of Practice No. 9. Absent sufficient  
11 justification to the contrary, excess infiltration is  
12 defined as flows in excess of 500 gpd/in. diam/mile. for  
13 all lines, including service laterals.

14 (e) Cost/benefit Analysis - The Commission may order a utility  
15 to perform a cost/benefit analysis to determine the amount of water  
16 losses or wastewater infiltration that may be economically  
17 eliminated. The actual or estimated prudent cost of any  
18 cost/benefit analysis ordered by the Commission shall be  
19 recoverable through rates in the rate proceeding pending at the  
20 time of such order. If the analysis is ordered by the Commission  
21 in the course of evaluating a rate application, the cost shall be  
22 recovered through the revenues authorized in that rate proceeding,  
23 and the cost shall be amortized over three years. If the analysis  
24 is ordered outside of a formal rate proceeding, the utility may  
25 request the cost be recovered through a limited proceeding.

CODING: Words underlined are additions; words in  
~~struck-through~~ type are deletions from existing law.

WATER AND WASTEWATERCHAPTER 25-30

1 pursuant to Section 367.0822, Florida Statutes.

2 (f) Used and useful Analysis -

3 1. As a part of its rate filing, each utility shall provide  
4 a determination of the used and useful percentage for each  
5 primary plant account along with the supporting formulas  
6 and documentation.

7 2. In lieu of presenting evidence in support of used and  
8 useful percentages, the utility may elect to use the  
9 default formulas in Rule 25-30.432(6), F.A.C. for  
10 calculating used and useful percentages for water supply,  
11 treatment, pumping and storage equipment, water  
12 transmission and distribution systems, wastewater treatment  
13 and effluent disposal equipment and wastewater pumping and  
14 collection systems. The terms used in the default formulas  
15 are defined in Rule 25-30.432(7).

16 (6) Used and useful default formulas

17 (a) Small water systems (less than 1 MGD capacity)

18 1. Small water systems (less than 1 MGD capacity) with  
19 adequate reliable finished water storage capacity to meet  
20 the local fire flow ordinances and to meet the peak hour  
21 demand of its customers:

22 i. Water source of supply:

23 (Maximum Day Demand + Margin Reserve) / Firm  
24 Reliable Capacity

25 ii. Water treatment equipment:

CODING: Words underlined are additions; words in  
~~struck-through~~ type are deletions from existing law.

WATER AND WASTEWATER

CHAPTER 25-30

1 (Maximum Day Demand + Margin Reserve) / Firm  
2 Reliable Capacity

3 iii. Finished water storage:

4 (Equalization Volume + Fire Flow + Emergency  
5 Storage + Margin Reserve) / Firm Reliable Capacity

6 iv. Water high service pumping:

7 (Instantaneous Demand + Margin Reserve) / Firm  
8 Reliable Capacity

9 or

10 (Peak Hour Demand + Fire Flow + Margin Reserve) /  
11 Firm Reliable Capacity

12 v. Other water facilities:100% used and useful

13 vi. Water transmission system:100% used and useful

14 vii. Water distribution system - non-developer  
15 related:100% used and useful

16 viii. Water distribution system - developer related,  
17 single family developments:

18 ((Lots Served + Fill-in Lots + Margin Reserve) /  
19 Lots with Service Available) + Fire Flow Allowance

20 ix. Water distribution system - developer related,  
21 mixed developments (e.g., single family, multi-  
22 family and commercial):

23 ((Connected ERCs + Fill-in ERCs + Margin Reserve) /  
24 ERC Capacity) + Fire Flow Allowance

25 2. Small water systems (less than 1 MGD capacity) with no

CODING: Words underlined are additions; words in  
~~struck-through~~ type are deletions from existing law.

WATER AND WASTEWATERCHAPTER 25-30

1 | storage facilities other than hydropneumatic tanks or with  
2 | insufficient storage to buffer the instantaneous demands of  
3 | its customers:

4 | i. Water source of supply:

5 | (Instantaneous Demand + Margin Reserve) / Firm  
6 | Reliable Capacity

7 | or

8 | (Maximum Day Demand + Fire Flow + Margin Reserve) /  
9 | Firm Reliable Capacity

10 | ii. Water treatment equipment:

11 | (Instantaneous Demand + Margin Reserve) / Firm  
12 | Reliable Capacity

13 | or

14 | (Maximum Day Demand + Fire Flow + Margin Reserve) /  
15 | Firm Reliable Capacity

16 | iii. Finished water storage:100% used and useful

17 | iv. Water high service pumping:

18 | (Instantaneous Demand + Margin Reserve) / Firm  
19 | Reliable Capacity

20 | or

21 | (Peak Hour Demand + Fire Flow + Margin Reserve) /  
22 | Firm Reliable Capacity

23 | v. Other water facilities:100% used and useful

24 | vi. Water transmission system:100% used and useful

25 | vii. Water distribution system - non-developer

CODING: Words underlined are additions; words in  
~~struck through~~ type are deletions from existing law.

WATER AND WASTEWATERCHAPTER 25-30

1 related:100% used and useful

2 viii. Water distribution system - developer related,  
 3 single family developments:

4 ((Lots Served + Fill-in Lots + Margin Reserve) /  
 5 Lots with Service Available) + Fire Flow Allowance

6 ix. Water distribution system - developer related,  
 7 mixed developments (e.g., single family, multi-  
 8 family and commercial):

9 ((Connected ERCs + Fill-in ERCs + Margin Reserve) /  
 10 ERC Capacity) + Fire Flow Allowance

11 (b) Medium water systems (1 MGD to 5 MGD Capacity):

12 1. Medium water systems (1 MGD to 5 MGD capacity) with  
 13 adequate reliable finished water storage capacity to meet  
 14 the local fire flow ordinances and to meet the peak hour  
 15 demand of its customers:

16 i. Water source of supply:

17 (Maximum Day Demand + Margin Reserve) / Firm  
 18 Reliable Capacity

19 ii. Water Treatment Equipment:

20 (Maximum Day Demand + Margin Reserve) / Firm  
 21 Reliable Capacity

22 iii. Finished water storage:

23 (Equalization Volume + Fire Flow + Emergency  
 24 Storage + Margin Reserve) / Firm Reliable Capacity

25 iv. Water high service pumping:

CODING: Words underlined are additions; words in  
~~struck through~~ type are deletions from existing law.

WATER AND WASTEWATERCHAPTER 25-30

1 (Peak Hour Demand + Margin Reserve) / Firm Reliable  
 2 Capacity

3 or

4 (Maximum Day Demand + Fire Flow + Margin Reserve) /  
 5 Firm Reliable Capacity

6 v. Other water facilities:100% used and useful

7 vi. Water transmission system:100% used and useful

8 vii. Water distribution system - non-developer  
 9 related:100% used and useful

10 viii. Water distribution system - developer related,  
 11 single family developments:

12 ((Lots Served + Fill-in Lots + Margin Reserve) /  
 13 Lots with Service Available) + Fire Flow Allowance

14 ix. Water distribution system - developer related,  
 15 mixed developments (e.g., single family, multi-  
 16 family and commercial):

17 ((Connected ERCs + Fill-in ERCs + Margin Reserve) /  
 18 ERC Capacity) + Fire Flow Allowance

19 2. Medium water systems (1 MGD to 5 MGD capacity) with no  
 20 storage facilities other than hydropneumatic tanks or with  
 21 insufficient storage to buffer the instantaneous demands of  
 22 its customers:

23 i. Water source of supply:

24 (Peak Hour Demand + Margin Reserve) / Firm Reliable  
 25 Capacity

CODING: Words underlined are additions; words in  
~~struck-through~~ type are deletions from existing law.



WATER AND WASTEWATER

CHAPTER 25-30

- 1                    or
- 2                    (Maximum Day Demand + Fire Flow + Margin Reserve) /
- 3                    Firm Reliable Capacity
- 4                    ii. Water treatment equipment:
- 5                    (Peak Hour Demand + Margin Reserve) / Firm Reliable
- 6                    Capacity
- 7                    or
- 8                    (Maximum Day Demand + Fire Flow + Margin Reserve) /
- 9                    Firm Reliable Capacity
- 10                   iii. Finished water storage:100% used and useful
- 11                   iv. Water high service pumping:
- 12                   (Peak Hour Demand + Margin Reserve) / Firm Reliable
- 13                   Capacity
- 14                   or
- 15                   (Maximum Day Demand + Fire Flow + Margin Reserve) /
- 16                   Firm Reliable Capacity
- 17                   v. Other water facilities:100% used and useful
- 18                   vi. Water transmission system:100% used and useful
- 19                   vii. Water distribution system - non-developer
- 20                   related:100% used and useful
- 21                   viii. Water distribution system - developer related,
- 22                   single family developments:
- 23                   ((Lots Served + Fill-in Lots + Margin Reserve) /
- 24                   Lots with Service Available) + Fire Flow Allowance
- 25                   ix. Water distribution system - developer related,

CODING: Words underlined are additions; words in  
~~struck-through~~ type are deletions from existing law.

WATER AND WASTEWATERCHAPTER 25-30

1 | mixed developments (e.g., single family, multi-  
2 | family and commercial):

3 | ((Connected ERCs + Fill-in ERCs + Margin Reserve) /  
4 | ERC Capacity) + Fire Flow Allowance

5 | (c) Large water systems (over 5 MGD Capacity):

6 | 1. Large water systems (over 5 MGD capacity) with adequate  
7 | reliable finished water storage capacity to meet the local  
8 | fire flow ordinances and to meet the peak hour demand of  
9 | its customers:

10 | i. Water source of supply:

11 | (Average 5 Maximum Days Demand + Margin Reserve) /  
12 | Firm Reliable Capacity

13 | ii. Water treatment equipment:

14 | (Average 5 Maximum Days Demand + Margin Reserve) /  
15 | Firm Reliable Capacity

16 | iii. Finished water storage:

17 | (Equalization Volume + Fire Flow + Emergency  
18 | Storage + Margin Reserve) / Firm Reliable Capacity

19 | iv. Water high service pumping:

20 | (Peak Hour Demand + Margin Reserve) / Firm Reliable  
21 | Capacity

22 | or

23 | (Maximum Day Demand + Fire Flow + Margin Reserve) /  
24 | Firm Reliable Capacity

25 | v. Other water facilities:100% used and useful

CODING: Words underlined are additions; words in  
~~struck through~~ type are deletions from existing law.

WATER AND WASTEWATERCHAPTER 25-30

1 vi. Water transmission system:100% used and useful

2 vii. Water distribution system - non-developer  
3 related:100% used and useful

4 viii. Water distribution system - developer related,  
5 single family developments:

6 ((Lots Served + Fill-in Lots + Margin Reserve) /  
7 Lots with Service Available) + Fire Flow Allowance

8 ix. Water distribution system - developer related,  
9 mixed developments (e.g., single family, multi-  
10 family and commercial):

11 ((Connected ERCs + Fill-in ERCs + Margin Reserve) /  
12 ERC Capacity) + Fire Flow Allowance

13 2. Large water systems (over 5 MGD capacity) with no  
14 storage facilities other than hydropneumatic tanks or with  
15 insufficient storage to buffer the instantaneous demands of  
16 its customers:

17 i. Water source of supply:

18 (Maximum Day Demand + Fire Flow + Margin Reserve) /  
19 Firm Reliable Capacity

20 ii. Water treatment equipment:

21 (Maximum Day Demand + Fire Flow + Margin Reserve) /  
22 Firm Reliable Capacity

23 iii. Finished water storage:100% used and useful

24 iv. Water high service pumping:

25 (Peak Hour Demand + Fire Flow + Margin Reserve) /

CODING: Words underlined are additions; words in  
~~struck-through~~ type are deletions from existing law.

WATER AND WASTEWATERCHAPTER 25-30Firm Reliable Capacity

- 1  
2  
3 v. Other water facilities:100% used and useful
- 4 vi. Water transmission system:100% used and useful
- 5 vii. Water distribution system - non-developer  
6 related:100% used and useful
- 7 viii. Water distribution system - developer related,  
8 single family developments:  
9 ((Lots Served + Fill-in Lots + Margin Reserve) /  
10 Lots with Service Available) + Fire Flow Allowance
- 11 ix. Water distribution system - developer related,  
12 mixed developments (e.g., single family, multi-  
13 family and commercial):  
14 ((Connected ERCs + Fill-in ERCs + Margin Reserve) /  
15 ERC Capacity) + Fire Flow Allowance

(d) Wastewater systems:

- 16
- 17 1. Wastewater collection system and pumping stations - non-  
18 developer related:100% used and useful
- 19 2. Wastewater collection system and pumping stations -  
20 developer related, single family developments:  
21 (Lots Served + Fill-in Lots + Margin Reserve) / Lots with  
22 Service Available
- 23 3. Wastewater collection system and pumping stations -  
24 developer related, mixed developments (e.g., single family,  
25 multi-family and commercial):

CODING: Words underlined are additions; words in  
~~struck-through~~ type are deletions from existing law.

WATER AND WASTEWATERCHAPTER 25-30

1 (Connected ERCs + Fill-in ERCs + Margin Reserve) / ERC  
2 Capacity

3 4. Wastewater force mains:100% used and useful

4 5. Wastewater treatment equipment:

5 (Maximum Month Flow + Margin Reserve) / Firm Reliable  
6 Capacity

7 6. Effluent disposal facilities:

8 (Maximum Month Flow + Margin Reserve) / Firm Reliable  
9 Capacity

10 7. Other wastewater facilities:100% used and useful

11 (7) Definitions - the following definitions apply to the  
12 default formulas in Rule 25-30.432(6), F.A.C., for purposes of  
13 determination of used and useful water and wastewater facilities.

14 (a) Average 5 Maximum Days Demand - the average of the five  
15 greatest days demand attained by a water system during the past  
16 five years, exclusive of emergency or fire flow events.

17 (b) Effluent Disposal Facilities - this includes the  
18 transmission lines, percolation and evaporation ponds, sprayfields,  
19 irrigation systems, deep wells, etc., utilized in the disposal of  
20 effluent or reclaimed water.

21 (c) Emergency Storage - that storage required by a water system  
22 to meet the emergency-like demands of the customers. Typically,  
23 Emergency Storage is made available when it is more cost effective  
24 to provide the storage and pumping facilities than to add  
25 redundancy to the system for emergency conditions. The quantity of

CODING: Words underlined are additions; words in  
~~struck through~~ type are deletions from existing law.

WATER AND WASTEWATER

CHAPTER 25-30

1 Emergency Storage need is a function of the duration of the  
2 emergency condition and is typically assumed to be approximately  
3 one half of the average annual daily demand.

4 (d) Equalization Volume - the quantity of storage in a water  
5 system necessary to meet the customers' greatest demands which are  
6 beyond the throughput capacity of the source of supply and/or water  
7 treatment equipment. Typical design criteria allows for four hours  
8 storage at the 16 hour demand.

9 (e) Fill-in Lots - The total number of unoccupied residential  
10 lots on isolatable sections of the distribution system in which no  
11 less than 25% of the lots are currently, or in the past have been  
12 provided active water or wastewater service, as applicable.

13 (f) Fire Flow Allowance - an allowance for the capacity of a  
14 water distribution system, calculated using the following formula:

15 Fire Flow Allowance = (Fire Flow Requirement / (Fire Flow  
16 Requirement + Maximum Day Demand)) X (1 - ((Average number  
17 of ERCs connected to the distribution system + Margin  
18 Reserve in ERCs) / Capacity of the distribution system in  
19 ERCs))

20 (g) Fire Flow Requirement - as defined in 25-30.432(5)(b),  
21 F.A.C.

22 (h) Firm Reliable Capacity - the capacity of a particular  
23 component of a water or wastewater facility in which at least the  
24 largest unit is assumed to be out of service. If the used and  
25 useful category contains several components, the Firm Reliable

CODING: Words underlined are additions; words in  
~~struck through~~ type are deletions from existing law.

WATER AND WASTEWATER

CHAPTER 25-30

1 Capacity is assumed to be the limiting component in that category  
2 with the largest unit out of service. For finished water storage,  
3 the Firm Reliable Capacity excludes any unusable or dead storage.

4 (i) Instantaneous Demand - the greatest demand that a water  
5 system attains. It is typically used only as a design criteria on  
6 small water systems with no storage and a small distribution system  
7 that does not have the ability to absorb these instantaneous  
8 demands through depressurization of the distributions system. Rule  
9 25-30.432(8), F.A.C., should be used to determine the instantaneous  
10 demand unless specific quantitative information indicates greater  
11 demands.

12 (j) Large Water System - a system that has a reliable capacity  
13 of more than five millions gallons per day. Based upon Rule 17-  
14 602.370(4), F.A.C., operation requirements, a Large Water System  
15 would require at least on shift per day of operations for a  
16 Category IV or V system (aeration or chlorination) and at least a  
17 double shift of operations for Category I, II, or III (filtration,  
18 softening or reverse osmosis).

19 (k) Lots Served - the total number of residential lots that are  
20 currently, or in the past have been, provided active water or  
21 wastewater service, as applicable, plus lots occupied but never  
22 connected to the system that are capable of being provided service  
23 by the existing distribution or collection system.

24 (l) Lots with Service Available - the total number of  
25 residential lots that currently have the water distribution or

CODING: Words underlined are additions; words in  
~~struck-through~~ type are deletions from existing law.

WATER AND WASTEWATERCHAPTER 25-30

1 wastewater collection system, as applicable, immediately available.

2 (m) Margin Reserve - as defined in 25-30.432(5)(a), F.A.C.

3 (n) Maximum Day Demand - the maximum daily demand that a water  
4 system attained during the past five years of time, exclusive of  
5 emergency or fire flow events. Typical design criteria allow .55  
6 gpm per ERC.

7 (o) Maximum Month Flow - the average daily flow through a  
8 wastewater treatment facility for the month with the highest total  
9 flow during the past five years.

10 (p) Medium Water System - a system that has a reliable capacity  
11 of between one million gallons per day and five million gallons per  
12 day. Based upon Rule 17-602.370(4), F.A.C., operation  
13 requirements, a Medium Water System would require less than 24  
14 hours per day operation but greater operational requirements than  
15 a small system.

16 (q) Other Wastewater Facilities - this includes disinfection  
17 units, emergency generators, auxiliary engines, customer service  
18 laterals, laboratory equipment, utility office and other general  
19 plant and equipment used in the operation of a wastewater system.

20 (r) Other Water Facilities - this includes disinfection  
21 facilities, emergency generators, auxiliary engines, customer  
22 service lines and meters, laboratory equipment, utility office and  
23 other general plant used in the operation of a water system.

24 (s) Peak Hour Demand - the greatest demand attained by a water  
25 system over a sustained period of sixty minutes. Typical design

CODING: Words underlined are additions; words in  
~~struck through~~ type are deletions from existing law.



WATER AND WASTEWATERCHAPTER 25-30

1 criteria allows for a Peak Hour Demand of two times the maximum day  
2 demand or 1.1 gpm per ERC.

3 (t) Small Water System - a system that has a reliable capacity  
4 of less than one million gallons per day. Based upon Rule 17-  
5 603.370(4), F.A.C., operation requirements, a Small Water System  
6 would require less than one hour per day visit for a Category IV or  
7 V system (aeration and chlorination) and less than eight hours of  
8 operation for a Category I, II or III system (filtration, softening  
9 or reverse osmosis).

10 (u) Wastewater Collection System and Pumping Stations - this  
11 includes all the gravity collection lines form the customer sewer  
12 lateral to and including the wastewater pumping stations.

13 (v) Wastewater Force Mains - this includes the force mains from  
14 the discharge of the pumping stations to the influent structure at  
15 the wastewater treatment facilities.

16 (w) Wastewater Treatment Equipment - this includes the influent  
17 structure, pretreatment facilities, pumping, aeration,  
18 clarification, filtration, chlorine contact and effluent pumping  
19 equipment.

20 (8) Unless specific quantitative information indicates greater  
21 demands, a water system's Instantaneous Demand, for purposes of  
22 determining used and useful, will be calculated from the following  
23 table:

24  
25  
CODING: Words underlined are additions; words in  
~~struck through~~ type are deletions from existing law.

WATER AND WASTEWATER

CHAPTER 25-30

INSTANTANEOUS DEMANDS PER ERC(1)

No. of ERCs	Instantaneous Demand (GPM)	No. of ERCs	Instantaneous Demand (GPM)	No. of ERCs	Instantaneous Demand (GPM)	No. of ERCs	Instantaneous Demand (GPM)
1	15	26	124	51	203	76	279
2	20	27	128	52	206	77	282
3	25	28	132	53	209	78	285
4	30	29	136	54	212	79	288
5	35	30	140	55	215	80	291
6	40	31	143	56	218	81	294
7	45	32	146	57	221	82	297
8	50	33	149	58	224	83	300
9	55	34	152	59	227	84	303
10	60	35	155	60	230	85	306
11	64	36	158	61	233	86	309
12	68	37	161	62	237	87	312
13	72	38	164	63	240	88	315
14	76	39	167	64	243	89	318
15	80	40	170	65	246	90	321
16	84	41	173	66	249	91	324
17	88	42	176	67	252	92	327
18	92	43	179	68	255	93	330
19	96	44	182	69	258	94	333
20	100	45	185	70	261	95	336
21	104	46	188	71	264	96	339
22	108	47	191	72	267	97	342
23	112	48	194	73	270	98	345
24	116	49	197	74	273	98	348
25	120	50	200	75	276	100(2)	351

Notes:

(1) Source: Community Water Systems Source Book, 5th Edition, 1971, by Joseph S. Ameen, Page 62.

(2) For Systems greater than 100 ERCs, ID =  $351 \times \frac{\text{ERCs}}{100}$  in GPM

CODING: Words underlined are additions; words in ~~struck-through~~ type are deletions from existing law.

WATER AND WASTEWATER

CHAPTER 25-30

1 Specific Authority: 367.121, F.S.

2 Law Implemented: 367.081, F.S.

3 History: New.

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

CODING: Words underlined are additions; words in  
~~struck-through~~ type are deletions from existing law.