

930455-WS

**A·E**  
ANGLES  
ESTEBAN  
ASSOC., INC.  
ARCHITECTURE  
AND PLANNING  
CCA NO. 1457

ORIGINAL  
FILE COPY

July 15, 1993

Mr. Jock McCartney  
Royal Utility Company  
8900 N. W. 44 Court  
Coral Springs, Florida 33065

Re: Royal Land, Coventry  
Meter Size Requirements

Dear Mr. McCartney:


This letter is to inform you that due to the amount of fixture units on Models A, B & C, which are as follows:

- Model A - 22 F.U.
- Model B - 26 F.U.
- Model C - 31 F.U.

The minimum required meter size shall be 1" meter as per Section 4614.12, table 46Q of the South Florida Building Code, Broward County Edition, which states that any copper line having between 19-55 F.U. shall have a 1" line and a 1" meter.

Sincerely,

ANGLES ESTEBAN ASSOC., INC.



Jorge L. Esteban, AIA

JLE/c

DOCUMENT NUMBER - DATE  
07796 JUL 20 93



BUILDING DEPARTMENT

CITY OF *CORAL SPRINGS* FLORIDA

9530 WEST SAMPLE ROAD  
P.O. BOX 754501  
CORAL SPRINGS, FL 33075-4501  
TELEPHONE (305) 344-1025

July 15, 1993

Mr. Jock McCartney  
Royal Utility Company  
8900 NW 44 Court  
Coral Springs, FL 33065

Re: Royal Land, Coventry  
Meter Size Requirements

Dear Mr. McCartney:

This letter is to inform you that I agree with all the facts presented by Angles Esteban Assoc., Inc., in their letter of July 15, 1993 relative to meter sizes in Royal Land Amended.

The code is very specific with the term "shall", it is a mandatory term.

Therefore, as the Chief Plumbing Inspector I have no choice but to enforce the requirements of the code.

Sincerely,

William Burns  
Chief Plumbing Inspector