

ORIGINAL
FILE COPY

ST. GEORGE ISLAND UTILITY COMPANY, LTD.

**BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION
REGARDING THE APPLICATION FOR INCREASED RATES FOR
ST. GEORGE ISLAND UTILITY COMPANY, LTD.**

IN FRANKLIN COUNTY

DOCKET NO. ~~940100-111~~

**REBUTTAL TESTIMONY OF
TED L. BIDDY, P.E., P.L.S.**

RECEIVED
06778 JUL -7 8
FPC-REGISTRATION REPORTING

- 1 Q. Please state your name, profession and address.
- 2 A. Ted L. Bidby, P.E., P.L.S., Tallahassee Regional Manager,
3 Baskerville-Donovan, Inc., consulting engineers, 2878
4 Remington Green Circle, Tallahassee, FL 32308.
- 5 Q. Please give us a brief outline of your educational and
6 professional background.
- 7 A. (See attached detailed resume).
- 8 Q. Please outline your professional relationship with St.
9 George Island Utility Company, Ltd.?
- 10 A. In late 1970's and early 1980's, I provided design and
11 permitting services for water system extensions to
12 various sub-divisions on St. George Island through former
13 firm of Ted L. Bidby & Associates, Inc. During 1991,
14 1992, 1993 and to date in 1994, the Tallahassee office of
15 Baskerville-Donovan, Inc. has served as consulting
16 engineer to the Utility for various projects including
17 system capacity analysis, design, permitting and
18 construction administration for Well No. 3; preparation
19 of distribution system maps; preparation of aerator
20 report; design and permitting for treatment plant
21 improvements and miscellaneous services.
- 22 Q. Have you previously filed direct testimony in this
23 proceeding?
- 24 A. No, I have not.
- 25 Q. What is the purpose of your rebuttal testimony.
- 26 A. The purpose of my rebuttal testimony is to respond to the
27 direct testimony of PSC staff witnesses Kintz and
28

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28

McKeown.

Q. Have you reviewed and analyzed the testimony of John Kintz and Cliff McKeown?

A. Yes.

Q. Would you please give us your response to the testimony of PSC staff witness John Kintz?

A. Yes. My response will basically follow the issues as set forth by Mr. Kintz. Firstly, in answer to the question of what immediate, near-term or long-range actions the Utility needs to accomplish in order to accommodate current and future customers, Mr. Kintz states, "that the Utility would need to construct an additional raw water line from the mainland in order to supply potable water for additional development of St. George Island in excess of the allowable total of 1346 customer connections".

I do not agree that the allowable total customer connections is 1346 but is 1541 based on the detailed system capacity analyses performed under my direction by the Tallahassee office of Baskerville-Donovan, Inc. (See attached report dated May 27, 1992 and addendum report dated May 5, 1994.)

We have demonstrated in an addendum to the utility's hydraulic analysis, assuming the treatment plant modifications are on line, that the system has the capacity to serve 1541 ERU's under peak hourly flow.

In the course of providing model computations to support a construction permit application for Sunset Beach, we

1 have demonstrated the capability of the Utility to serve
2 its existing service commitments; i.e. 1500 ERU;s, with
3 resultant pressures of 30 psi +/- at Bob Sikes Cut and 35
4 psi +/- near the East end (State Park gate). This
5 analysis would indicate that the system has the capacity
6 to serve additional customers beyond 1500 before
7 resultant pressures reach the 20 psi minimum.

8 These system analysis reports were very detailed and
9 rigorous computer modeling of the distribution system
10 based on best available engineering data and the report
11 of May 27, 1992 was described by Mr. Kintz in his letter
12 to the Utility of June 5, 1992 as "an excellent and
13 thorough evaluation of the water system's status".

14 Mr. Kintz's conclusion that an additional raw water line
15 is required is apparently based on the limitation that
16 Northwest Florida Water Management District has set forth
17 in its consumptive use permit; i.e. 700,000 gpd is as
18 much as can be pumped through the existing raw water
19 main. However, the capability of the Utility to provide
20 additional raw water supply may be increased by other
21 means, a determination of which should be economically
22 feasible as much as any other factor:

23 For Example:

- 24 1. Increase withdrawal rates specified in Consumptive
25 Use Permits (Utility is pursuing).
- 26 2. Construct additional raw water supply wells.
- 27 3. Install pumping appurtenances to boost higher flows

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28

thru existing main, taking into consideration design limitations of the existing pipe and practical constraints.

- 4. Increase finished storage on the island to accommodate future demand.

Mr. Kintz statement that an additional raw water line needs to be constructed is puzzling and is not related to system capacity. The existing 8 inch raw water line will supply water to St. George Island at a rate of 500 gpm with Well No. 1 and Well No. pumping in tandem for 12 hours and at a rate of 620 gpm with Well No. 3 pumping alone for 12 hours for a total of 806,400 gallons per day. This 806,400 gallons per day is more than the maximum daily demand of 801,320 gallons for 1541 connections, at maximum daily demand of 520 gpd/ERU, not considering the 375,000-400,000 gallons of water storage which exists on the island. We contend that the water storage on the island should be considered along with raw water supply from the mainland when computing system capacity. A detailed analysis of finished water storage required would be dependent upon an analysis of average daily flow requirements as it relates to Department criteria and regulations. An evaluation of this scope has not been completed or reviewed by our office to date.

Calculations by our firm demonstrated that raw water supply simply is not a problem related to allowable

1 number of equivalent residential connections. Rather,
2 the distribution system pressure reaching the lowest
3 allowable value of 20 pounds per square inch in the water
4 main at the worst case as set forth in Section 17-555,
5 F.A.C. should be the limiting factor for maximum
6 allowable equivalent residential connections. The
7 computer model capacity analyses which our firm performed
8 computed the maximum number of connections which could be
9 served while maintaining the minimum legal pressure of 20
10 psi.

11 Mr. Kintz's calculation of system capacity by considering
12 only the 700,000 gallons per day allowable withdrawal
13 rate based on the Northwest Florida Water Management
14 District's consumptive use permit is also puzzling.
15 Adding this maximum daily raw water pumping rate of
16 700,000 gpd to the total storage of 400,000 gallons gives
17 a total of 1,100,000 gallons of water available per day
18 compared to the maximum daily demand of 801,320
19 gallons for 1541 connections. One must also keep in mind
20 that these periods of maximum demand occur only for a 1
21 to 2 day period at the three holiday periods of Memorial
22 Day, Fourth of July and Labor Day with demand for all
23 other times at much lower rates. Adequacy of supply is
24 further documented in our firms' Technical Memorandum
25 dated May 25, 1994 for Sunset Beach Subdivision attached
26 hereto. Updating the ERU's in the memorandum to 1541
27 instead of the 1500 as presented would only increase the

1 usage from the elevated tank to 101,320 gallons for
2 maximum day. Mr. Kintz determination of capacity is
3 apparently based on the single limiting factor of maximum
4 withdrawal set forth in the standard water use permit.
5 Mr. Kintz is apparently confusing system capacity with
6 system reliability. His concerns as previously expressed
7 to me center on catastrophic events such as hurricanes
8 interrupting the raw water supply by causing broken lines
9 at the bridge crossing areas.

10 If the Utility is to be held to the test that raw water
11 delivery to the island must equal maximum daily demand,
12 then it is obvious that the consumptive use permit
13 withdrawal rate would need to be increased from the
14 present maximum day of 700,000 gallons to 801,320.
15 Reportedly the Utility has such a permit modification
16 request before the Northwest Florida Water Management
17 District.

18 The third well effectively added one hundred percent
19 backup supply well capacity for greater system
20 reliability. Perhaps, adding parallel lines for the
21 bridge crossing areas could be added in the future for
22 greater system reliability. It is noted that during
23 storm periods, there would be very few people on St.
24 George Island and next to no water demand.

25 Mr. Kintz's comments on required system improvements for
26 fire flow requirements are correct as far as additional
27 storage on the island and increased size of distribution
28

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28

system mains.

However, a fire flow system analysis would require a great deal of study to determine precise requirements which would not necessarily include increasing the capacity of the raw water transport to the island. For instance, adequately sized storage and pumping with separate dedicated fire flow water mains would not require additional raw water transport to the island.

Mr. Kintz's opinion is formulated without benefit of any fire flow analysis directed specifically at the St. George system. Criteria required to be developed in such an analysis include but are not limited to minimum pressure, flow and duration of fire flow.

With the necessary criteria developed, not all or any of the items deemed necessary may be required. AWWA Standards suggest that the development of fire protection in private utilities include consideration of economic feasibility in providing the system.

Finally, I note with exception that Mr. Kintz in his February 17, 1994 memo to Allan W. Johnson (EXH JAK-3) states that the Baskerville-Donovan capacity analysis report used theoretical assumptions rather than measured flows. The basis for all computer simulations of the SGIU System has been well documented in our firm's May 1992 report (attached) and is further discussed in the May 25, 1994 Technical Memorandum

1 (attached). We believe that our method of analysis has
2 been an objective, reasonable and documented approach to
3 evaluating system capacity in keeping with sound
4 engineering principles.

5 Q. Would you please proceed now with your response to the
6 testimony of PSC staff witness Cliff McKeown?

7 A. Yes. My response will follow the issues in the same
8 order set forth by Mr. McKeown.

9 On Page 3 of his testimony, Mr. McKeown states that the
10 Utility has experienced pressure related problems at the
11 East end State Park entrance with 16 psi recorded by the
12 Florida Rural Water Association (FRWA) on May 24, 1992
13 and 11 psi recorded on July 4, 1992.

14 Taking the FRWA report as a complete document, the
15 following data is derived.

16 1. State Park employees reportedly tampered with
17 pressure recording equipment placed at this
18 location during the May 24 weekend. This makes
19 this data suspect and may explain the observed drop
20 in pressure.

21 2. The recorded pressure of 11 psi on July 4 spanned
22 over about a two hour period. This low pressure
23 may have been coincident with the State Park
24 personnel replenishing their water storage tanks.
25 It is common knowledge that the Utility and the
26 State Park have coordinated the filling of the
27 Park's storage tanks to minimize disruption or
28

1 degradation of service to the rest of the island,
2 primarily being accomplished by filling these tanks
3 at off peak hours. A more striking illustration of
4 the pressure recording chart included with Mr.
5 McKeown's testimony is that pressures of 35-40± psi
6 were maintained at this location throughout the
7 remainder of the two day recording period. Other
8 pressure recordings submitted with both the May 24,
9 1992 and July 4, 1992 reports illustrate the system
10 maintaining pressures above the 20 psi minimum.

11 Attached hereto are both FRWA reports.

12 On Page 6 of his testimony, Mr. McKeown discusses his
13 concerns for the presence of a light gray to white clay
14 like material often found in the system's aerator and
15 states that this material is lime rock breakup within the
16 Florida Aquifer and being pumped to the aerator from Well
17 No. 2.

18 This statement by Mr. McKeown is sheer conjecture and
19 guesswork with no basis for such an opinion. The more
20 likely source of the light gray to white clay like
21 material found in the aerator is the residue of granular
22 chlorination of the ground storage tank which is
23 sometimes performed by the Utility for disinfection of
24 the raw water before it is treated and pumped.

25 Concerning Mr. McKeown's discussion of the requirement
26 for the Utility to develop current and accurate water
27 distribution system maps which were required by the

1 Partial Final Judgement, the following history of
2 submittals of such maps to the best of my knowledge and
3 belief is as follows:

- 4 1. August 31, 1992 - Two sets of maps submitted to
5 FDEP for review with regard to requirements of PFJ.
- 6 2. Per telephone conversation with Cliff McKeown on
7 September 2, 1992 confirmed in writing by letter
8 dated September 10, 1992, our firm received FDEP
9 review comments on the subject maps.
- 10 3. On August 24, 1993 two copies of the subject map
11 were transmitted to FDEP with the remaining copies
12 required by the PFJ being submitted to the Utility
13 for distribution. During the period of time
14 between September 10, 1992 and August 24, 1993,
15 Baskerville-Donovan, Inc. coordinated collection of
16 the additional information required for the maps
17 and was also involved in negotiations with the
18 Utility to secure payment for professional services
19 associated with completing the maps.
- 20 4. On October 27, 1993 FDEP issued correspondence
21 indicating a number of corrections that needed to
22 be performed on the maps.
- 23 5. This firm has recently reached an agreement for
24 payment of professional fees owed by the Utility to
25 the firm and is proceeding with the completion of
26 the maps, current and up to date according to the
27 Utility's CIAC list dated May 18, 1994. We

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28

estimate completion no later than July 31, 1994.

On Page 8 of his testimony, Mr. McKeown states that Well No. 3 exceeded the MCL for color. While Well No. 3 did initially fail the MCL for color, subsequent testing yielded results within the range of Department secondary standards.

Concerning Mr. McKeown's discussion on Page 9 of H₂S removal and this firm's report on the matter, I offer the following:

The Department, as illustrated by the exhibits to the aerator analysis does not have a specific MCL for hydrogen sulfide in its drinking water standards. The subject analysis does discuss several sets of H₂S data, a portion of which was supplied by the Utility, and a portion collected independently.

Concerning Mr. McKeown's discussion on Page 11 of request for an operating scheme for the three wells, I offer the following:

An operating scheme for the three supply wells was documented in the original construction permit application submitted to the Department, as well as by separate letter dated February 11, 1994. The proposed pumping scheme had been communicated to the Department in May, 1992, during the construction permitting phase.

1 Concerning Mr. McKeown's discussion on Page 12 of the
2 aerator report, I offer the following:

3 The aerator report was submitted to the Department
4 for review on August 24, 1993. Delay in its
5 delivery was a direct result in prioritizing of
6 Baskerville-Donovan, Inc.'s work effort by the
7 Utility, and on-going negotiations by Baskerville-
8 Donovan, Inc. with the Utility to secure payment
9 for professional services rendered.

10 The Department provided review comments on the
11 aerator report by letter dated November 18, 1993.
12 For reasons previously cited with regard to
13 contract negotiations with the Utility,
14 Baskerville-Donovan, Inc. has not responded to
15 those comments.

16 Since the recent agreement has been reached between
17 the Utility and Baskerville-Donovan, Inc., a
18 response to the Department's letter will be
19 submitted no later than July 31, 1994.

20 With regard to the validity of the data submitted
21 by the Utility's contract lab, we are not in a
22 position to comment on the technique, accuracy or
23 format of the lab results.

24 Q. After having reviewed all of the direct testimony filed
25 by PSC staff witnesses Kintz and McKeown, have you
26 changed any of the opinions or conclusions set forth in
27 your engineering analysis, including the various
28

1 amendments?

2 A. No.

3 Q. Mr. McKeown indicated that the system map was filed late.
4 When was it actually filed?

5 A. First submittal was August 31, 1992.

6 Q. Was this map based upon the best engineering information
7 available at the time?

8 A. Yes.

9 Q. Is this normal, for a map to be filed and then updated
10 and revised at later dates?

11 A. Yes for large systems.

12 Q. Regarding the aerator analysis, do you believe that it
13 was deficient or defective?

14 A. No.

15 Q. Why not?

16 A. I have fully commented on the aerator analysis in my
17 response above to Mr. McKeown's testimony.

18 Q. Has Baskerville-Donovan, Inc. updated and revised the
19 map?

20 A. Yes, and it will be delivered to the Utility no later
21 than July 31, 1994.

22 Q. Have you updated and revised the aerator analysis as
23 requested by DEP?

24 A. It is being done now and will be delivered to the company
25 by July 31, 1994.

26 Q. What is the total amount of all professional fees charged
27 to St. George Island Utility Company between January 1,

28

1 1992 and the current date?

2 A. Approximately \$141,140

3 Q. Have these fees been paid, or have satisfactory

4 arrangements been made for payment.

5 A. Approximately \$59,542 has been paid with an agreement

6 reached for payment over a period of time for the balance

7 of \$81,462.80.

8 Q. What would Baskerville-Donovan charge St. George Island

9 Utility Company to revise and update its engineering

10 analysis?

11 A. \$24,400.00.

12 Q. What would this cover?

13 A. Update of the 1992 Capacity Analysis report extended

14 through the year 2020.

15 Q. Was the St. George Island Utility system designed as a

16 fire protection system?

17 A. No.

18 Q. On what do you base this conclusion?

19 A. Familiar with system since initial installation.

20 Q. What would Baskerville-Donovan charge the utility company

21 for a complete fire protection analysis?

22 A. \$30,000.

23 Q. What would this cover?

24 A. Complete study of alternative fire protection systems and

25 costs estimates therefor.

26 Q. Based upon all that you know about the St. George Island

27 Utility system, do you have an opinion as to whether it

28

1 is in compliance with all of the state statutes, rules
2 and regulations administered by the Department of
3 Environmental Protection?

4 A. Yes.

5 Q. What is that opinion?

6 A. Utility is in compliance except for completion of some
7 minor items of consent order.

8 Q. Is there anything about the St. George Island Utility
9 Company system that makes it unique from other systems?

10 A. Very unique system, long distance from supply wells,
11 sparse widely separated connections in some areas,
12 private wells allowed in some areas, long narrow island
13 does not lend itself to economical looped systems, loose
14 sand conditions predominate with high water table making
15 construction and maintenance difficult. Beach homes are
16 typically 3 or more stories above ground.

17 Q. Base on all that you know about St. George Island Utility
18 Company, does it seem to be well managed?

19 A. Yes, reasonably so and much better in recent years.

20 Q. If the utility company is in compliance, how do you
21 explain all of the problems that the utility company
22 seems to be having with DEP?

23 A. The utility company is a growing highly visible utility
24 serving a resort type community where complaints from
25 customers seem to be very vocal, although mostly
26 unfounded. Such complaints have regularly been made to
27 the FDEP who are sensitive to public comments. Over the
28

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28

years, it seems that the utility owner, Mr. Gene Brown has been viewed as in an adversarial role to FDEP to the point where he is personally disliked by the agency. During the last three years as the utility has attempted to make substantial improvements, our firm, as consulting engineer for the improvements, has experienced unusual resistance from the agency in obtaining approvals and permits, seemingly related to the agency's dislike for Gene Brown.

tlb190

TED L. BIDDY, P.E. / P.L.S.
CIVIL ENGINEER

BASKERVILLE-DONOVAN, INC.

- EDUCATION:** Bachelor of Science, Civil Engineering
Georgia Institute of Technology, 1963
- REGISTRATION:** Professional Engineer, Florida No. 17656
Registered Engineer, Georgia 12609
Registered Engineer, Mississippi 3984
Registered Engineer, Louisiana 18431
Registered Land Surveyor, Florida No. 2658
Registered Land Surveyor, Mississippi No. 1429
Registered Land Surveyor, Georgia No. 1421

EXPERIENCE:

Mr. Biddy joined Baskerville-Donovan, Inc. (BDI) in 1991. He presently serves as the Tallahassee Regional Manager. Prior to joining BDI, Mr. Biddy operated his own civil engineering firm for 21 years, where he served as chief designer and project manager for over 1300 projects. Mr. Biddy's areas of expertise include civil engineering, structural engineering (including bridge design), sanitary engineering, soils and foundation engineering, and precise surveying.

Experience includes, but is not limited to:

- Site survey of hazardous waste site at Mt. Pleasant, FL - U.S. Environmental Protection Agency, Atlanta, GA.
- Design of containment facilities at hazardous waste storage site - FL Department of Environmental Regulation, Tallahassee, FL.
- Design of replacements for underground storage tanks including underground concrete vaults, piping, leak detection, etc. - U.S. West, DesMoins, IA.
- Complete design of 320 lot subdivision including water, sewer, streets, drainage, platting and surveying - Better Housing, Ltd., Tallahassee, FL.
- Complete design and platting of 9 subdivisions. - Leisure Properties, Tallahassee, FL



- 3-Year contract for tide gauge maintenance and surveying throughout Florida coastline - U.S. National Ocean Survey, Rockville, MD.
- Boundary maps for parcels in Taylor, Franklin, Dixie, Jefferson & Wakulla Counties, FL. - Florida Department of Natural Resources, Tallahassee, FL.
- 5-Miles of County road - Liberty County Board of County Commissioners, Bristol, FL.
- Surveys & structural design of 100-ft. calibration tower at St. George Island - General Dynamics, Pomona, CA.
- Complete design, construction, contract administration & inspection for marina in Carrabelle, FL - Anneewakee Foundation, Douglasville, GA.
- Pile cap designs for Apalachicola Bay Bridge, Apalachicola, FL - L&A General Contractors, Hattiesburg, MS.
- Cofferdams for sheet pile dolphins at Sunshine Skyway Bridge, Tampa, FL - H.G. Harders & Son, Inc. Panama City, FL.
- Pier 17, Cochrane Bridge, Mobile, AL - J.J. Grove & Son Company, Mobile, AL.
- Two 1-year survey contracts throughout Mobile District - Mobile District Corps of Engineers.
- Detailed drainage study, reports, & court appearances for 1,000 acres area west of Madison, FL - William Burnett.
- Detailed overall drainage study and report for City of Madison, FL and surrounding areas - City of Madison, FL.
- Drainage & flooding study for property near Madison, FL - William Kinner.
- Drainage and flooding study for shopping center complex in Live Oak, FL - Levis & Walter Lawson.
- Drainage, runoff & flooding studies, reports & permitting for commercial, industrial & residential facilities in Leon County - Numerous Clients.
- Drainage, runoff & flooding studies, reports, & permitting for recreational, commercial & residential projects on the Gulf Coast and at St. George Island, FL - Numerous Clients.



- Design & construction supervision of river barge terminal & support facilities - Jackson County Port Authority, Sneeds, FL.
- Design & construction supervision of bulk fertilizer unloading, conveying & storage facility & reclaim facility - MS Chemical Corporation.
- Complete design & construction supervision of 2.5 million dollar barge terminal port facility. - Jackson County Port Authority, Sneeds, FL.
- Master plan for complete development of 1500 acres property - Creare Corporation, Ocean Springs, MS.
- Master plan & scale model of 2000 acres planned unit development. Design & construction supervision of 150 acres first phase - Holiday Lakes, Inc., Eustis, FL.
- Planning, design & construction supervision of 220 lot mobile home park - Belle Aire Village, Tallahassee, FL.
- Preliminary engineering report for 420 acres industrial park - Apalachee Industries, Ltd., Tallahassee, FL.
- Planning & design of 130 acres subdivision. Planning & design of 35 acres subdivision. Property & topographic survey of 500 acres project. Planning & design of marina facilities. Planning for shopping center - Equity Resources, Inc., Tallahassee, FL.
- Property & topographic surveys and planning for 120 acres subdivision - Twin Lakes Development, Tallahassee, FL.
- Planning for 150 acres industrial park - Jackson County Port Authority, Marianna, FL.
- Property & topographic surveys, planning, & design of 110 acres subdivision - Panhandle Waterways, Ltd., Tallahassee, FL.
- Preliminary engineering report, topographic survey & feasibility report for sand mine and subdivision development on 200 acres tract - Gulf Land & Minerals, Ltd., Tallahassee, FL.
- Planning, design & receiving of construction bids for 13,200,000 tons per year coal unloading, conveying, storage, reclaim & shipping facility.



- One year long surveying contract for all types of surveying for 4-6 crews - U.S. Army Corps of Engineers Mobile, AL & Memphis, TN Districts.
- Cadastral & boundary surveys for numerous full sections throughout North Florida - St. Joe Paper Company, Port St. Joe, FL.
- Survey, plat, & designs for 1400 acre property in Franklin Co., FL - U.S. Home Corporation, Clearwater, FL.
- Civil engineering projects at 20 school locations - Leon County School Board, Tallahassee, FL.
- Planning & design of 4 mile water distribution system, Leon County, FL - Talquin Electric Coop, Inc., Tallahassee, FL.
- Design of over 100 steel buildings for this steel building manufacturer - Space Steel, Inc., Jackson, MS.
- Design of approximately 50 steel buildings for this prefabricated steel building manufacturer - Baywood Corporation, Hattiesburg, MS.
- Geometric analysis of 17 tainter gates at Robert S. Kerr Lock & Dam - Perini Corporation, Framingham, MA.
- Design & construction supervision of sewage collection system & sewage treatment plant. Preliminary designs & layouts for major shopping center mall in Leon County, FL - Culpepper Construction Company, Panama City, FL.
- Land planning for subdivision development. Construction engineering consisting of quantity computations, and estimating for bidding purposes. Structural engineering for construction equipment - Harders Construction Company, Panama City, FL.
- Preliminary engineering report & investigations for repairs to major industrial building - Process Engineering Company, Jackson, MS.
- Preliminary engineering report & feasibility study for cement plant. Preliminary engineering report & feasibility study for 500,000 bushel grain terminal. Feasibility study for barge towing company.
- Preparation of oil spill protection and counter-measure plan - Escambia Treating Company, Pensacola, FL.



AFFILIATIONS:

Florida Engineering Society, Florida Society of Professional Land Surveyors, and National Society of Professional Engineers.



FLORIDA RURAL WATER ASSOCIATION

1391 TIMBERLANE ROAD • SUITE 104 • TALLAHASSEE, FL 32312
(904) 668-2746

Rec'd 5/28/92
Jaw



St. George Island Hydraulic Analysis

The flow test performed at the utility consisted of monitoring the output of the high service pump and master meter by utilizing a Polysonics Tyme Flight strap-on meter. Signal strength and accuracy were checked and good. The test was conducted from 18:03 on May 23, 1992 until 12:03 on May 25, 1992 to cover the heavy use period on Memorial Day weekend. The amount of people visiting the island was very high. The stores ran out of ice, the hotels were booked and the state park recorded its largest number of people ever to the knowledge of the park manager (4,187 people on Sunday, May 24.)

Pressure recorders were placed at the far ends of the distribution at Mr. Cozy's home near the cut at St. George Plantation (7.8 miles from the water tank), and at the state park on the east end of the island (4.5 Miles from the water tank.) The pressure charts and strip charts for the flow meter are attached as part this report.

A separate test on flow to the aerator from the wells was performed on the bridge coming onto the island 1 mile from the water tank. The well pumps were tested running together and independently. Both well pumps running together were averaging 410 gallons per minute. The number 2 well pump averaged 310 gpm. The number 1 well pump averaged 265 gpm.

The flow test at the high service pump/meter site ran from 18:03 on May 23, 1992 until 12:03 on May 25, 1992. The maximum amount pumped over a 24 hour period during this time was 435,200 gallons. This occurred from 18:03 on May 24 until 18:03 on May 25. The minimum amount pumped in 24 hours was 337,400 from 18:03 on May 22 to 18:03 on May 23. Because flows were logged every hour during the test, 43 time periods of 24 hours can be calculated. The



average 24 hour flow is 401,211 gallons or 279 gallons per minute. During each hour of the flow test the high service pump on/off status was recorded. The pump was on 26 times and off 41 times when checked hourly. Of the 26 "instantaneous" recordings of the high service pump, the maximum output was 719 gallons per minute. The minimum output was 633 gpm. The average was 680 gpm. The St. George Island Utility meter was reading 6% high. The pressure test was conducted at both ends of the utilities distribution and observed at the tank between the sampling points. There was approximately 12.3 miles from the sampling point at St. George Plantation (Mr. Cozy's house) to the sampling site at the state park. For time and pressure analysis, please observe the chart recordings.

Hank Garrett of SGI utilities helped Florida Rural Water during the testing of the Memorial Day holiday.


Sincerely,

A handwritten signature in cursive script that reads "Rick Herndon". The signature is written in black ink and is positioned to the right of the word "Sincerely,".


Rick Herndon

DATE	TIME	FLOW FOR PREVIOUS 24 HOURS	DATE	TIME	FLOW FOR PREVIOUS 24 HOURS
5/23	18:03	337,400	5/24	16:03	429,200
	19:03	375,800		17:03	403,700
	20:03	362,300		18:03	435,200
	21:03	394,700		19:03	406,100
	22:03	377,800		20:03	430,200
	24:03	406,500		21:03	400,200
5/24	00:03	383,900		22:03	420,400
	01:03	386,500	5/25	23:03	391,700
	02:03	407,900		00:03	417,100
	03:03	400,300		01:03	414,500
	04:03	385,700		02:03	393,100
	05:03	409,200		03:03	393,100
	06:03	409,200		04:03	415,600
	07:03	383,600		05:03	392,100
	08:03	415,400		06:03	392,100
	09:03	387,000		07:03	412,800
	10:03	420,500		08:03	389,600
	11:03	388,100		09:03	418,500
	12:03	422,600		10:03	399,800
	13:03	390,000		11:03	423,700
	14:03	424,700		12:03	409,200
	15:03	395,100			


Mr. Cozys
"The Cut"




Mr. Cozys
"The Cut"



Mr. Cozys
"The Cut"



State Park



122 METER

03:03+008.432E 06PM 00R
ON +00024 *100 G 00R
-00000 *100 G 00R
+000.00% AI1 00R
+002.50% AI2 00R

03:03+ 0.000E 06PM 00R
OFF +00046 *100 G 00R
-00000 *100 G 00R
+000.00% AI1 00R
+002.50% AI2 00R

03:03+ 0.000E 06PM 00R
OFF +00344 *100 G 00R
-00000 *100 G 00R
+000.00% AI1 00R
+002.50% AI2 00R

03:03+ 0.000E 06PM 00R
OFF +00344 *100 G 00R
-00000 *100 G 00R
+000.00% AI1 00R
+002.50% AI2 00R

03:03+ 0.000E 06PM 00R
OFF +00669 *100 G 00R
-00000 *100 G 00R
+000.00% AI1 00R
+002.50% AI2 00R

03:03+ 0.000E 06PM 00R
OFF +00669 *100 G 00R
-00000 *100 G 00R
+000.00% AI1 00R
+002.50% AI2 00R

03:03+ 0.000E 06PM 00R
OFF +00938 *100 G 00R
-00000 *100 G 00R
+000.00% AI1 00R
+002.50% AI2 00R

03:03+ 0.000E 06PM 00R
OFF +00938 *100 G 00R
-00000 *100 G 00R
+000.00% AI1 00R
+002.50% AI2 00R

03:03+ 0.000E 06PM 00R
OFF +00938 *100 G 00R
-00000 *100 G 00R
+000.00% AI1 00R
+002.50% AI2 00R

03:03+660.694E 06PM 00R
ON +01014 *100 G 00R
-00000 *100 G 00R
+000.00% AI1 00R
+002.50% AI2 00R

03:03+ 0.000E 06PM 00R
OFF +01160 *100 G 00R
-00000 *100 G 00R
+000.00% AI1 00R
+002.50% AI2 00R

03:03+ 0.000E 06PM 00R
OFF +01160 *100 G 00R
-00000 *100 G 00R
+000.00% AI1 00R
+002.50% AI2 00R

03:03+ 0.000E 06PM 00R
OFF +01160 *100 G 00R
-00000 *100 G 00R
+000.00% AI1 00R
+002.50% AI2 00R

0N +01416 *100 G 00R
-00000 *100 G 00R
+000.00% AI1 00R
+002.50% AI2 00R

03:03+ 0.000E 06PM 00R
OFF +01421 *100 G 00R
-00000 *100 G 00R
+000.00% AI1 00R
+002.50% AI2 00R

03:03+651.712E 06PM 00R
ON +01751 *100 G 00R
-00000 *100 G 00R
+000.00% AI1 00R
+002.50% AI2 00R

10:03+ 0.000E 06PM 00R
OFF +01829 *100 G 00R
-00000 *100 G 00R
+000.00% AI1 00R
+002.50% AI2 00R

11:03+666.242E 06PM 00R
ON +02193 *100 G 00R
-00000 *100 G 00R
+000.00% AI1 00R
+002.50% AI2 00R

12:03+ 0.000E 06PM 00R
OFF +02239 *100 G 00R
-00000 *100 G 00R
+000.00% AI1 00R
+002.50% AI2 00R

13:03+695.036E 06PM 00R
ON +02565 *100 G 00R
-00000 *100 G 00R
+000.00% AI1 00R
+002.50% AI2 00R

14:03+ 0.000E 06PM 00R
OFF +02591 *100 G 00R
-00000 *100 G 00R
+000.00% AI1 00R
+002.50% AI2 00R

15:03+671.789E 06PM 00R
ON +02894 *100 G 00R
-00000 *100 G 00R
+000.00% AI1 00R
+002.50% AI2 00R

16:03+ 0.000E 06PM 00R
OFF +02932 *100 G 00R
-00000 *100 G 00R
+000.00% AI1 00R
+002.50% AI2 00R

17:03+690.545E 06PM 00R
ON +03307 *100 G 00R
-00000 *100 G 00R
+000.00% AI1 00R
+002.50% AI2 00R

18:03+712.736E 06PM 00R
ON +03398 *100 G 00R
-00000 *100 G 00R
+000.00% AI1 00R
+002.50% AI2 00R

19:03+681.823E 06PM 00R
ON +03604 *100 G 00R
-00000 *100 G 00R
+000.00% AI1 00R
+002.50% AI2 00R

20:03+ 0.000E 06PM 00R
OFF +03967 *100 G 00R
-00000 *100 G 00R
+000.00% AI1 00R
+002.50% AI2 00R

21:03+678.393E 06PM 00R
ON +04291 *100 G 00R
-00000 *100 G 00R
+000.00% AI1 00R
+002.50% AI2 00R

22:03+ 0.000E 06PM 00R
OFF +04447 *100 G 00R
-00000 *100 G 00R
+000.00% AI1 00R
+002.50% AI2 00R

23:03+692.923E 06PM 00R
ON +04734 *100 G 00R
-00000 *100 G 00R
+000.00% AI1 00R
+002.50% AI2 00R

00:03+ 0.000E 06PM 00R
OFF +04777 *100 G 00R
-00000 *100 G 00R
+000.00% AI1 00R
+002.50% AI2 00R

01:03+719.340E 06PM 00R
ON +04803 *100 G 00R
-00000 *100 G 00R
+000.00% AI1 00R
+002.50% AI2 00R

02:03+ 0.000E 06PM 00R
OFF +05017 *100 G 00R
-00000 *100 G 00R
+000.00% AI1 00R
+002.50% AI2 00R

03:03+ 0.000E 06PM 00R
OFF +05017 *100 G 00R
-00000 *100 G 00R
+000.00% AI1 00R
+002.50% AI2 00R

04:03+ 0.000E 06PM 00R
OFF +05017 *100 G 00R
-00000 *100 G 00R
+000.00% AI1 00R
+002.50% AI2 00R

05:03+ 0.000E 06PM 00R
OFF +05252 *100 G 00R
-00000 *100 G 00R
+000.00% AI1 00R
+002.50% AI2 00R

06:03+ 0.000E 06PM 00R
OFF +05252 *100 G 00R
-00000 *100 G 00R
+000.00% AI1 00R
+002.50% AI2 00R

07:03+ 0.000E 06PM 00R
OFF +05252 *100 G 00R
-00000 *100 G 00R
+000.00% AI1 00R
+002.50% AI2 00R

08:03+683.941E 06PM 00R
ON +05575 *100 G 00R
-00000 *100 G 00R
+000.00% AI1 00R
+002.50% AI2 00R

08:03+683.941E 06PM 00R
ON +05575 *100 G 00R
-00000 *100 G 00R
+000.00% AI1 00R
+002.50% AI2 00R

S24

07:03+687.375E 06PM 00R
ON +05621 *100 G 00R
-00000 *100 G 00R
+000.00% A11 00R
+002.50% A12 00R

10:03+686.054E 06PM 00R
ON +06025 *100 G 00R
-00000 *100 G 00R
+000.00% A11 00R
+002.50% A12 00R

11:03+ 0.000E 06PM 00R
OFF +06074 *100 G 00R
-00000 *100 G 00R
+000.00% A11 00R
+002.50% A12 00R

12:03+ 0.000E 06PM 00R
OFF +06465 *100 G 00R
-00000 *100 G 00R
+000.00% A11 00R
+002.50% A12 00R

13:03+ 0.000E 06PM 00R
OFF +06465 *100 G 00R
-00000 *100 G 00R
+000.00% A11 00R
+002.50% A12 00R

14:03+679.450E 06PM 00R
ON +06838 *100 G 00R
-00000 *100 G 00R
+000.00% A11 00R
+002.50% A12 00R

15:03+ 0.000E 06PM 00R
OFF +06845 *100 G 00R
-00000 *100 G 00R
+000.00% A11 00R
+002.50% A12 00R

16:03+636.390E 06PM 00R
ON +07224 *100 G 00R
-00000 *100 G 00R
+000.00% A11 00R
+002.50% A12 00R

17:03+667.298E 06PM 00R
ON +07344 *100 G 00R
-00000 *100 G 00R
+000.00% A11 00R
+002.50% A12 00R

18:03+671.789E 06PM 00R
ON +07750 *100 G 00R
-00000 *100 G 00R
+000.00% A11 00R
+002.50% A12 00R

19:03+673.903E 06PM 00R
ON +07865 *100 G 00R
-00000 *100 G 00R
+000.00% A11 00R
+002.50% A12 00R

20:03+712.736E 06PM 00R
ON +08269 *100 G 00R
-00000 *100 G 00R
+000.00% A11 00R
+002.50% A12 00R

21:03+698.471E 06PM 00R
ON +08293 *100 G 00R
-00000 *100 G 00R
+000.00% A11 00R
+002.50% A12 00R

07:03+ 0.000E 06PM 00R
OFF +08651 *100 G 00R
-00000 *100 G 00R
+000.00% A11 00R
+002.50% A12 00R

23:03+ 0.000E 06PM 00R
OFF +08651 *100 G 00R
-00000 *100 G 00R
+000.00% A11 00R
+002.50% A12 00R

sbs

00:03+ 0.000E 06PM 00R
OFF +08948 *100 G 00R
-00000 *100 G 00R
+000.00% A11 00R
+002.50% A12 00R

01:03+ 0.000E 06PM 00R
OFF +08948 *100 G 00R
-00000 *100 G 00R
+000.00% A11 00R
+002.50% A12 00R

02:03+ 0.000E 06PM 00R
OFF +08948 *100 G 00R
-00000 *100 G 00R
+000.00% A11 00R
+002.50% A12 00R

03:03+ 0.000E 06PM 00R
OFF +08948 *100 G 00R
-00000 *100 G 00R
+000.00% A11 00R
+002.50% A12 00R

04:03+ 0.000E 06PM 00R
OFF +09173 *100 G 00R
-00000 *100 G 00R
+000.00% A11 00R
+002.50% A12 00R

05:03+ 0.000E 06PM 00R
OFF +09173 *100 G 00R
-00000 *100 G 00R
+000.00% A11 00R
+002.50% A12 00R

06:03+ 0.000E 06PM 00R
OFF +09173 *100 G 00R
-00000 *100 G 00R
+000.00% A11 00R
+002.50% A12 00R

07:03+680.507E 06PM 00R
ON +09380 *100 G 00R
-00000 *100 G 00R
+000.00% A11 00R
+002.50% A12 00R

08:03+ 0.000E 06PM 00R
OFF +09471 *100 G 00R
-00000 *100 G 00R
+000.00% A11 00R
+002.50% A12 00R

09:03+677.337E 06PM 00R
ON +09806 *100 G 00R
-00000 *100 G 00R
+000.00% A11 00R
+002.50% A12 00R

10:03+ 0.000E 06PM 00R
OFF +00023 *100 G 00R
-00000 *100 G 00R
+000.00% A11 00R
+002.50% A12 00R

11:03+672.846E 06PM 00R
ON +00311 *100 G 00R
-00000 *100 G 00R
+000.00% A11 00R
+002.50% A12 00R

12:03+ 0.000E 06PM 00R
OFF +00557 *100 G 00R
-00000 *100 G 00R
+000.00% A11 00R
+002.50% A12 00R

11:11-416.335E 06PM 00R
 +00000 *10 G 00R
 -00000 *10 G 00R
 +000.00% AI1 00R
 +002.40% AI2 00R

14:12-408.410E 06PM 00R
 +00000 *10 G 00R
 -00000 *10 G 00R
 +000.00% AI1 00R
 +002.40% AI2 00R

14:13-405.240E 06PM 00R
 +00000 *10 G 00R
 -00000 *10 G 00R
 +000.00% AI1 00R
 +002.40% AI2 00R

14:14-428.222E 06PM 00R
 +00000 *10 G 00R
 -00030 *10 G 00R
 +000.00% AI1 00R
 +002.40% AI2 00R

14:15-416.335E 06PM 00R
 +00000 *10 G 00R
 -00070 *10 G 00R
 +000.00% AI1 00R
 +002.40% AI2 00R

14:16-431.393E 06PM 00R
 +00000 *10 G 00R
 -00112 *10 G 00R
 +000.00% AI1 00R
 +002.40% AI2 00R

14:17-389.389E 06PM 00R
 +00000 *10 G 00R
 -00152 *10 G 00R
 +000.00% AI1 00R
 +002.50% AI2 00R

14:18-406.296E 06PM 00R
 +00000 *10 G 00R
 -00194 *10 G 00R
 +000.00% AI1 00R
 +002.40% AI2 00R

14:19-408.410E 06PM 00R
 +00000 *10 G 00R
 -00235 *10 G 00R
 +000.00% AI1 00R
 +002.50% AI2 00R

14:20-395.729E 06PM 00R
 +00000 *10 G 00R
 -00276 *10 G 00R
 +000.00% AI1 00R
 +002.50% AI2 00R

14:21-416.335E 06PM 00R
 +00000 *10 G 00R
 -00317 *10 G 00R
 +000.00% AI1 00R
 +002.50% AI2 00R

14:22-158.767E 06PM 00R
 +00000 *10 G 00R
 -00348 *10 G 00R
 +000.00% AI1 00R
 +002.50% AI2 00R

14:23- 70.005E 06PM 00R
 +00000 *10 G 00R
 -00358 *10 G 00R
 +000.00% AI1 00R
 +002.50% AI2 00R

14:24- 41.210E 06PM 00R

21.397E 06PM 00R
 +00000 *10 G 00R
 -00366 *10 G 00R
 +000.00% AI1 00R
 +002.50% AI2 00R

14:26- 13.472E 06PM 00R
 +00000 *10 G 00R
 -00368 *10 G 00R
 +000.00% AI1 00R
 +002.50% AI2 00R

14:27- 23.511E 06PM 00R
 +00000 *10 G 00R
 -00369 *10 G 00R
 +000.00% AI1 00R
 +002.50% AI2 00R

14:28- 13.472E 06PM 00R
 +00000 *10 G 00R
 -00371 *10 G 00R
 +000.00% AI1 00R
 +002.50% AI2 00R

4:30- 17.699E 06PM 00R
 +00000 *10 G 00R
 -00373 *10 G 00R
 +000.00% AI1 00R
 +002.50% AI2 00R

4:31- 18.756E 06PM 00R
 +00000 *10 G 00R
 -00374 *10 G 00R
 +000.00% AI1 00R
 +002.50% AI2 00R

4:32- 19.812E 06PM 00R
 +00000 *10 G 00R
 -00376 *10 G 00R
 +000.00% AI1 00R
 +002.50% AI2 00R

14:33-331.271E 06PM 00R
 +00000 *10 G 00R
 -00400 *10 G 00R
 +000.00% AI1 00R
 +002.50% AI2 00R

14:34-300.363E 06PM 00R
 +00000 *10 G 00R
 -00432 *10 G 00R
 +000.00% AI1 00R
 +002.50% AI2 00R

14:35-301.420E 06PM 00R
 +00000 *10 G 00R
 -00463 *10 G 00R
 +000.00% AI1 00R
 +002.50% AI2 00R

14:36-305.647E 06PM 00R
 +00000 *10 G 00R
 -00494 *10 G 00R
 +000.00% AI1 00R
 +002.50% AI2 00R

14:37-299.306E 06PM 00R
 +00000 *10 G 00R
 -00525 *10 G 00R
 +000.00% AI1 00R
 +002.50% AI2 00R

14:38-299.306E 06PM 00R
 +00000 *10 G 00R
 -00556 *10 G 00R
 +000.00% AI1 00R
 +002.50% AI2 00R

14:39-145.030E 06PM 00R
 +00000 *10 G 00R

14:41- 47.550E 06PM 00R
 +00000 *10 G 00R
 -00598 *10 G 00R
 +000.00% AI1 00R
 +002.50% AI2 00R

14:42- 35.399E 06PM 00R
 +00000 *10 G 00R
 -00602 *10 G 00R
 +000.00% AI1 00R
 +002.50% AI2 00R

14:43-279.494E 06PM 00R
 +00000 *10 G 00R
 -00623 *10 G 00R
 +000.00% AI1 00R
 +002.50% AI2 00R

14:44-269.455E 06PM 00R
 +00000 *10 G 00R
 -00650 *10 G 00R
 +000.00% AI1 00R
 +002.50% AI2 00R

14:45-252.548E 06PM 00R
 +00000 *10 G 00R
 -00677 *10 G 00R
 +000.00% AI1 00R
 +002.50% AI2 00R

14:46-278.437E 06PM 00R
 +00000 *10 G 00R
 -00702 *10 G 00R
 +000.00% AI1 00R
 +002.50% AI2 00R

14:47-260.473E 06PM 00R
 +00000 *10 G 00R
 -00729 *10 G 00R
 +000.00% AI1 00R
 +002.50% AI2 00R

14:48-244.623E 06PM 00R
 +00000 *10 G 00R
 -00755 *10 G 00R
 +000.00% AI1 00R
 +002.50% AI2 00R

14:49-133.142E 06PM 00R
 +00000 *10 G 00R
 -00777 *10 G 00R
 +000.00% AI1 00R
 +002.50% AI2 00R

14:50- 73.175E 06PM 00R
 +00000 *10 G 00R
 -00787 *10 G 00R
 +000.00% AI1 00R
 +002.50% AI2 00R

14:51- 49.664E 06PM 00R
 +00000 *10 G 00R
 -00793 *10 G 00R
 +000.00% AI1 00R
 +002.50% AI2 00R

14:52- 35.399E 06PM 00R
 +00000 *10 G 00R
 -00797 *10 G 00R
 +000.00% AI1 00R
 +002.50% AI2 00R

14:53- 26.681E 06PM 00R
 +00000 *10 G 00R

BOTH ON

Wells

#1 ON

OFF

#2

OFF

OFF

St. George Island Water Utility Review

On July 3,4,5, 1992 the Florida Rural Water Association completed flow and pressure testing activities for St. George Island Water Utility. These tests include the flow on the raw water line just prior to aerator and flow on the finish water line next to high service pumps. Chart records were placed at both ends of the utility distribution system and on a house located on a 2" main to record system pressure. An activity recorder was hooked into the high service pump circuits to record on a chart when pumps were on and when they were off.

The following is the results of these tests and supporting material.

1) The 8" PVC - C900 line was exposed to provide access for the FRWA Polysonics TF-P Ultrasonic flow tester. (In our last trip to the island, we hooked the unit to a dead 8" line in the same excavation, and couldn't get a flow or signal.) This application provided an excellent location, signal strength, accuracy, and consistent flow. The unit needs a signal strength over 2.0 (we had 2.8) and full pipe of constant flow (which we had) and an accuracy between 98% and 102% (we had 99.14%). We ran the test twice between 4:30 p.m. and 6:00 p.m., July 3, 1992. The integrator function on the flow meter was set to get total gallons. This number then allows us to divide the number of minutes test ran to get on average gallon per minute flow.

7/3/92	<u>Gallons</u>	<u>GPM</u>
16:55	980	
16:56	1480	500
16:57	1980	500
16:58	2480	500
16:59	2970	490
17:00	3470	500
17:01	3980	510
17:02	4480	500
17:03	4980	500
17:04	5480	500
17:05	5980	500
17:06	Well Off	
17:35	Well On (0)	
17:36	490	490
17:37	1000	510
17:38	1500	500
17:39	2000	500
17:40	2500	500
17:41	3000	500
17:42	3500	500
17:43	4010	510
17:44	4500	490
17:45	5000	500
17:46	5510	510
17:47	6010	500
17:48	6500	490
17:49	7010	510

Average = 500 gpm

done by JFW

See charts #1 and #2

2) A measurement of flow was taken at the high service pump location on the 12" line. At this location we had good flow, good signal strength (2.40%), just under 98% (97.5%) accuracy. We were unable to get a higher accuracy figure. (We suspect encrustation, or perhaps an obstruction in a valve or tee.) Therefore, these figures may not be perfectly accurate, so use as best estimate. The unit printed out flows every 10 minutes starting at 6:37 p.m., 7/3/92 until 4:37 a.m., 7/4/92.

The following is an understanding of the printout:

18:47	-	26.417	GPM	OOR
	+	00015	*10G	OOR
	-	00024	*10G	OOR
	+	002.40%	A12	OOR

18:47 Military time

- 26.417 Gallon per minute flow instantaneous
a 18:47
(-) negative number means reverse flow
(check valve on high service pump is not closing totally off)

+ 00015 *10G Integrated flow since unit started printing out, Positive flow, 15 gallons x 10= 150 gallons

- 00024 *10G Integrated flow since unit started printing out, Negative flow, 24 gallons x 10= 240 gallons

+ 002.40% A12 Signal strength

OOR Acceptable flow - non-aerated

See chart #3

3) A measurement of flow at the same high service pump location was done each hour from 9:00 a.m. to 7:06 p.m. on 7/4/92.

The same parameter and data were recorded except the addition of feet per second was added:

+ 2.057E OFPS (feet per second) OOR

Again, the accuracy was only 97.58%

See chart #4

4) An activi... Recorder was set-up and r...orded high service pump activity from 7/3/92 to 7/5/92.

The line closest to the outside of the chart shows when the pump are off. The inside line shows when the pumps are running. The uneven, blotched lines are results of loading and unloading the charts.

See charts #5 and #6

5) The following is a chart of pressure recording data location close to the entrance of the state park. (It should be noted that Bruce Tyce of St. George Island State Park told Hank Garrett, SCI Utility and Gary Williams, FRWA, that the pressure recorder setting on Memorial Day weekend was tampered with by state park employees.) Therefore, we moved recorder location to area not accessible by people wanting to tamper with the equipment.

See chart #7

6) The following are charts that show pressure at 573 W. Gorrie Drive, from 7/3 to 7/4 (Chart #8) and 7/4 to 7/5 (Chart #9).

7) The following are charts that show pressure at location in the Plantation towards the end of distribution system.

See chart #10 7/3/92 to 7/4/92

(This chart stopped advancing by only dropped to 44psi in that time.)

See chart #11 7/4/92 to 7/5/92

It should be noted that the Utility had its Peak Day for water usage on Saturday, July 4, 1992, at 449,000 gallons used.

If any additional information is needed or questions arise upon review of this data, please do not hesitate to contact Gary Williams at (800) 872-8207.

OUTER DIAMETER L1
8.6248 IN

PIPE MATERIAL L1
PVC

WALL THICKNESS L1
0.4059 IN

INNER LINING L1
NO LING.

LING. THICKNESS L1
0.0000 IN

KIND OF FLUID L1
WATER

SENSOR MOUNTIN L1
U

TYPE OF SENSOR L1
SMALL

SPACING L1
6.272 IN U

*8" PVC Line - into the Plant
Unit Accuracy - 99.14%*

(#1)

16:55+498.492E 0GPM 00R
+00098 *10 G 00R
-00000 *10 G 00R
+002.80% AI2 00R

16:56+507.210E 0GPM 00R
+00148 *10 G 00R
-00000 *10 G 00R
+002.80% AI2 00R

16:57+495.058E 0GPM 00R
+00198 *10 G 00R
-00000 *10 G 00R
+002.80% AI2 00R

16:58+485.548E 0GPM 00R
+00248 *10 G 00R
-00000 *10 G 00R
+002.80% AI2 00R

16:59+496.379E 0GPM 00R
+00297 *10 G 00R
-00000 *10 G 00R
+002.80% AI2 00R

17:00+500.341E 0GPM 00R
+00347 *10 G 00R
-00000 *10 G 00R
+002.80% AI2 00R

17:01+492.152E 0GPM 00R
+00398 *10 G 00R
-00000 *10 G 00R
+002.80% AI2 00R

17:02+511.701E 0GPM 00R
+00448 *10 G 00R
-00000 *10 G 00R
+002.80% AI2 00R

17:03+488.932E 0GPM 00R
+00498 *10 G 00R
-00000 *10 G 00R
+002.80% AI2 00R

17:04+499.021E 0GPM 00R
+00548 *10 G 00R
-00000 *10 G 00R
+002.80% AI2 00R

17:05+496.379E 0GPM 00R
+00598 *10 G 00R
-00000 *10 G 00R
+002.80% AI2 00R

17:06+326.252E 0GPM 00R
+00632 *10 G 00R
-00000 *10 G 00R
+002.80% AI2 00R

17:07+312.251E 0GPM 00R
+00664 *10 G 00R
-00000 *10 G 00R
+002.80% AI2 00R

17:08+160.616E 0GPM 00R
+00690 *10 G 00R
-00000 *10 G 00R
+002.80% AI2 00R

17:09+ 63.137E 0GPM 00R
+00700 *10 G 00R
-00000 *10 G 00R
+002.80% AI2 00R

17:10+ 25.360E 0GPM 00R
+00704 *10 G 00R
-00000 *10 G 00R
+002.80% AI2 00R

17:11+ 6.340E 0GPM 00R
+00706 *10 G 00R
-00000 *10 G 00R
+002.80% AI2 00R

17:12+ 0.000E 0GPM 00R
+00706 *10 G 00R
-00000 *10 G 00R
+002.80% AI2 00R

17:13+ 0.000E 0GPM 00R
+00706 *10 G 00R
-00000 *10 G 00R
+002.80% AI2 00R

17:14+ 0.000E 0GPM 00R
+00706 *10 G 00R
-00000 *10 G 00R
+002.80% AI2 00R

17:15+ 0.000E 0GPM 00R
+00706 *10 G 00R
-00000 *10 G 00R
+002.80% AI2 00R

17:16+ 0.000E 0GPM 00R
+00706 *10 G 00R
-00000 *10 G 00R
+002.80% AI2 00R

OUTER DIAMETER L1
8.6248 IN

PIPE MATERIAL L1
PUC

WALL THICKNESS L1
0.4859 IN

INNER LINING L1
NO LING.

LING. THICKNESS L1
0.0000 IN

KIND OF FLUID L1
WATER

SENSOR MOUNTIN L1
U

TYPE OF SENSOR L1
SMALL

SPACING L1
6.272 IN U

97.14 90 Accurate

#2

17:35+512.229E 0GPM 00R
+00000 *10 G 00R
-00000 *10 G 00R
+002.80% AI2 00R

17:36+521.475E 0GPM 00R
+00049 *10 G 00R
-00000 *10 G 00R
+002.80% AI2 00R

17:37+519.098E 0GPM 00R
+00100 *10 G 00R
-00000 *10 G 00R
+002.80% AI2 00R

17:38+513.022E 0GPM 00R
+00150 *10 G 00R
-00000 *10 G 00R
+002.80% AI2 00R

17:39+473.924E 0GPM 00R
+00200 *10 G 00R
-00000 *10 G 00R
+002.80% AI2 00R

17:40+500.870E 0GPM 00R
+00250 *10 G 00R
-00000 *10 G 00R
+002.80% AI2 00R

17:41+514.078E 0GPM 00R
+00300 *10 G 00R
-00000 *10 G 00R
+002.80% AI2 00R

17:42+490.567E 0GPM 00R
+00350 *10 G 00R
-00000 *10 G 00R
+002.80% AI2 00R

17:43+512.229E 0GPM 00R
+00401 *10 G 00R
-00000 *10 G 00R
+002.80% AI2 00R

17:44+494.530E 0GPM 00R
+00450 *10 G 00R
-00000 *10 G 00R
+002.80% AI2 00R

17:45+485.284E 0GPM 00R
+00500 *10 G 00R
-00000 *10 G 00R
+002.80% AI2 00R

17:46+498.492E 0GPM 00R
+00551 *10 G 00R
-00000 *10 G 00R
+002.80% AI2 00R

17:47+502.719E 0GPM 00R
+00601 *10 G 00R
-00000 *10 G 00R
+002.80% AI2 00R

17:48+493.473E 0GPM 00R
+00650 *10 G 00R
-00000 *10 G 00R
+002.80% AI2 00R

17:49+504.832E 0GPM 00R
+00701 *10 G 00R
-00000 *10 G 00R
+002.80% AI2 00R

18:37+679.978E 0GPM 00R
+00000 *10 G 00R
-00000 *10 G 00R
+002.40% AI2 00R

OUTER DIAMETER L1
13.000 IN

PIPE MATERIAL L1
AL,DI

WALL THICKNESS L1
0.5000 IN

INNER LINING L1
MORTAR

LINING THICKNESS L1
0.1000 IN

KIND OF FLUID L1
WATER

SENSOR MOUNTING L1
U

TYPE OF SENSOR L1
SMALL

SPACING L1
10.677 IN U

18:47- 26.417E 0GPM 00R
+00015 *10 G 00R
-00024 *10 G 00R
+002.40% AI2 00R

18:57- 19.548E 0GPM 00R
+00015 *10 G 00R
-00048 *10 G 00R
+002.40% AI2 00R

19:07- 19.548E 0GPM 00R
+00015 *10 G 00R
-00072 *10 G 00R
+002.40% AI2 00R

19:17- 29.851E 0GPM 00R
+00015 *10 G 00R
-00096 *10 G 00R
+002.40% AI2 00R

19:27- 22.982E 0GPM 00R
+00015 *10 G 00R
-00119 *10 G 00R
+002.40% AI2 00R

19:37+713.264E 0GPM 00R
+00381 *10 G 00R
-00131 *10 G 00R
+002.40% AI2 00R

19:47+690.281E 0GPM 00R
+01099 *10 G 00R
-00131 *10 G 00R
+002.40% AI2 00R

19:57+724.888E 0GPM 00R
+01819 *10 G 00R
-00131 *10 G 00R
+002.40% AI2 00R

20:07+713.264E 0GPM 00R
+02536 *10 G 00R
-00131 *10 G 00R
+002.40% AI2 00R

20:17+707.717E 0GPM 00R
+03239 *10 G 00R
-00131 *10 G 00R
+002.40% AI2 00R

20:37- 24.039E 0GPM 00R
+04118 *10 G 00R
-00150 *10 G 00R
+002.40% AI2 00R

20:47- 21.926E 0GPM 00R
+04118 *10 G 00R
-00174 *10 G 00R
+002.40% AI2 00R

20:57- 24.039E 0GPM 00R
+04118 *10 G 00R
-00197 *10 G 00R
+002.40% AI2 00R

21:07- 27.738E 0GPM 00R
+04118 *10 G 00R
-00221 *10 G 00R
+002.40% AI2 00R

21:17+ 22.982E 0GPM 00R
+04118 *10 G 00R
-00245 *10 G 00R
+002.40% AI2 00R

21:27- 25.360E 0GPM 00R
+04118 *10 G 00R
-00268 *10 G 00R
+002.40% AI2 00R

21:37+722.774E 0GPM 00R
+04766 *10 G 00R
-00270 *10 G 00R
+002.40% AI2 00R

21:47+698.471E 0GPM 00R
+05483 *10 G 00R
-00270 *10 G 00R
+002.40% AI2 00R

21:57+704.018E 0GPM 00R
+06194 *10 G 00R
-00270 *10 G 00R
+002.40% AI2 00R

22:07+690.281E 0GPM 00R
+06904 *10 G 00R
-00270 *10 G 00R
+002.40% AI2 00R

22:17+698.471E 0GPM 00R
+07610 *10 G 00R
-00270 *10 G 00R
+002.40% AI2 00R

22:27- 18.492E 0GPM 00R
+08103 *10 G 00R
-00278 *10 G 00R
+002.40% AI2 00R

22:37- 21.926E 0GPM 00R
+08103 *10 G 00R
-00303 *10 G 00R
+002.40% AI2 00R

22:47- 26.417E 0GPM 00R
+08103 *10 G 00R
-00326 *10 G 00R
+002.40% AI2 00R

22:57- 31.172E 0GPM 00R
+08103 *10 G 00R
-00349 *10 G 00R
+002.40% AI2 00R

23:07- 28.794E 0GPM 00R
+08103 *10 G 00R
-00373 *10 G 00R
+002.40% AI2 00R

23:17- 21.926E 0GPM 00R
+08103 *10 G 00R
-00397 *10 G 00R
+002.40% AI2 00R

23:27- 21.926E 0GPM 00R
+08103 *10 G 00R
-00420 *10 G 00R
+002.40% AI2 00R

23:37+693.715E 0GPM 00R
+08388 *10 G 00R
-00434 *10 G 00R
+002.40% AI2 00R

23:47+721.454E 0GPM 00R
+09102 *10 G 00R
-00434 *10 G 00R
+002.40% AI2 00R

23:57+693.715E 0GPM 00R
+09915 *10 G 00R
-00434 *10 G 00R
+002.40% AI2 00R

00:07+696.093E 0GPM 00R
+00523 *10 G 00R
-00434 *10 G 00R
+002.40% AI2 00R

00:17- 22.982E 0GPM 00R
+01045 *10 G 00R
-00441 *10 G 00R
+002.40% AI2 00R

00:27- 29.851E 0GPM 00R
+01045 *10 G 00R
-00466 *10 G 00R
+002.40% AI2 00R

00:37- 20.605E 0GPM 00R
+01045 *10 G 00R
-00490 *10 G 00R
+002.40% AI2 00R

00:47- 20.605E 0GPM 00R
+01045 *10 G 00R
-00514 *10 G 00R
+002.40% AI2 00R

00:57- 28.794E 0GPM 00R
+01045 *10 G 00R
-00537 *10 G 00R
+002.40% AI2 00R

01:07- 19.548E 0GPM 00R
+01045 *10 G 00R
-00561 *10 G 00R
+002.40% AI2 00R

01:17- 24.039E 0GPM 00R
+01045 *10 G 00R
-00584 *10 G 00R
+002.40% AI2 00R

01:27- 19.548E 0GPM 00R
+01045 *10 G 00R
-00608 *10 G 00R
+002.40% AI2 00R

01:37- 27.738E 0GPM 00R
+01045 *10 G 00R
-00631 *10 G 00R
+002.40% AI2 00R

01:47- 18.492E 0GPM 00R
+01045 *10 G 00R
-00679 *10 G 00R
+002.40% AI2 00R

02:07- 27.738E 0GPM 00R
+01045 *10 G 00R
-00704 *10 G 00R
+002.40% AI2 00R

02:17- 27.738E 0GPM 00R
+01045 *10 G 00R
-00729 *10 G 00R
+002.40% AI2 00R

02:27- 29.851E 0GPM 00R
+01045 *10 G 00R
-00755 *10 G 00R
+002.40% AI2 00R

02:37- 33.285E 0GPM 00R
+01045 *10 G 00R
-00781 *10 G 00R
+002.40% AI2 00R

02:47+719.078E 0GPM 00R
+01570 *10 G 00R
-00787 *10 G 00R
+002.40% AI2 00R

02:57+705.339E 0GPM 00R
+02282 *10 G 00R
-00787 *10 G 00R
+002.40% AI2 00R

03:07+702.961E 0GPM 00R
+02992 *10 G 00R
-00787 *10 G 00R
+002.40% AI2 00R

03:17- 32.288E 0GPM 00R
+03476 *10 G 00R
-00794 *10 G 00R
+002.40% AI2 00R

03:27- 20.605E 0GPM 00R
+03476 *10 G 00R
-00819 *10 G 00R
+002.40% AI2 00R

03:37- 25.360E 0GPM 00R
+03476 *10 G 00R
-00844 *10 G 00R
+002.40% AI2 00R

03:47- 20.605E 0GPM 00R
+03476 *10 G 00R
-00868 *10 G 00R
+002.40% AI2 00R

03:57- 26.417E 0GPM 00R
+03476 *10 G 00R
-00891 *10 G 00R
+002.40% AI2 00R

04:07- 26.417E 0GPM 00R
+03476 *10 G 00R
-00915 *10 G 00R
+002.40% AI2 00R

04:17- 26.417E 0GPM 00R
+03476 *10 G 00R
-00938 *10 G 00R
+002.40% AI2 00R

04:27- 19.548E 0GPM 00R
+03476 *10 G 00R
-00962 *10 G 00R
+002.40% AI2 00R

04:37- 26.417E 0GPM 00R
+03476 *10 G 00R
-00985 *10 G 00R
+002.40% AI2 00R

9750-46

#3

7/4-7/5 '92

OUTER DIAMETER L1
13.2000 IN

PIPE MATERIAL L1
AL, DI

WALL THICKNESS L1
0.5000 IN

INNER LINING L1
MORTAR

LINING THICKNESS L1
0.1000 IN

KIND OF FLUID L1
WATER

SENSOR MOUNTING L1
U

TYPE OF SENSOR L1
SMALL

SPACING L1
10.677 IN U

09:06+724.888E OGPM 00R
+ 2.057E OFPS 00R
+00000 *10 G 00R
-00000 *10 G 00R
+002.40% AI2 00R

10:06+715.642E OGPM 00R
+ 2.030E OFPS 00R
+01158 *10 G 00R
-00000 *10 G 00R
+002.40% AI2 00R

11:06+729.643E OGPM 00R
+ 2.070E OFPS 00R
+05596 *10 G 00R
-00000 *10 G 00R
+002.40% AI2 00R

12:06+ 0.000E OGPM 00R
+ 0.000E OFPS 00R
+06347 *10 G 00R
-00000 *10 G 00R
+002.40% AI2 00R

13:06+734.134E OGPM 00R
+ 2.083E OFPS 00R
+00646 *10 G 00R
-00000 *10 G 00R
+002.40% AI2 00R

14:06+ 0.000E OGPM 00R
+ 0.000E OFPS 00R
+01172 *10 G 00R
-00000 *10 G 00R
+002.40% AI2 00R

Under 98% accurate

##


15:06+721.454E OGPM 00R
+ 2.047E OFPS 00R
+05252 *10 G 00R
-00000 *10 G 00R
+002.40% AI2 00R

16:06+736.060E OGPM 00R
+ 2.145E OFPS 00R
+06061 *10 G 00R
-00000 *10 G 00R
+002.40% AI2 00R


17:06+729.643E OGPM 00R
+ 2.070E OFPS 00R
+00499 *10 G 00R
-00000 *10 G 00R
+002.40% AI2 00R

18:06+ 0.000E OGPM 00R
+ 0.000E OFPS 00R
+02016 *10 G 00R
-00001 *10 G 00R
+002.40% AI2 00R


19:06+724.888E OGPM 00R
+ 2.057E OFPS 00R
+06107 *10 G 00R
-00001 *10 G 00R
+002.40% AI2 00R




ACTIVITY RECORDER ON HIGH SERVICE PUMP CIRCUITRY FROM 7/3 to 7/4 1992.




ACTIVITY RECORDER 7/4 to 7/5 1992.



CLOSE TO ENTRANCE OF STATE PARK




573 WEST GORRIE DRIVE, 2" MAIN, 7/3 to 7/4 1992




573 WEST GORRIE DRIVE, 2" MAIN, 7/4 to 7/5 1991

LOCATION TOWARDS THE END OF PLANTATION

UNIT QUIT ADVANCING AT 8:00 p.m. BUT DROPPED ONLY TO 44psi
BEFORE THE CHART WAS CHANGED OUT AT 12:30 p.m. on 7/4/92.





LOCATION TOWARDS THE END OF THE PLANTATION

7/4 to 7/5 1992



2878 REMINGTON GREEN CIRCLE
TALLAHASSEE, FL 32308
(904) 385-6788 • FAX: 385-5401

LETTER OF TRANSMITTAL

DATE MAY 25, 1994	JOB NO. 25701.06
ATTENTION RICE CREEKMORE, P.E.	
RE: SUNSET BEACH	

TO JOHNSON, CREEKMORE & FABRE
119 E. GREGORY
PENSACOLA, FLORIDA 32501

GENTLEMEN:

WE ARE SENDING YOU Attached Under separate cover via _____ the following items

Shop drawings Prints Plans Samples Specifications

Copy of letter Change order _____

COPIES	DATE	NO.	DESCRIPTION
3	5/25/94		TECHNICAL MEMORANDUM

THESE ARE TRANSMITTED as checked below:

- For approval
- For your use
- As requested
- For review and comment
- FOR BIDS DUE _____ 19 _____
- Approved as submitted
- Approved as noted
- Returned for corrections
- _____
- Resubmit _____ copies for approval
- Submit _____ copies for distribution
- Return _____ corrected prints
- PRINTS RETURNED AFTER LOAN TO US

REMARKS _____

file

CLIFF McKEOWEN - FDEP
SHAY DIVSALAR - JRA ARCHITECTS
COPY TO HELEN SPOHRER - RESORT REALTY

SIGNED *James Waddell*

TECHNICAL MEMORANDUM

May 25, 1994

25701.06

TO: Rice Creekmore, P.E.
Johnson, Creekmore, Fabre

FROM: James Waddell, P.E.
Baskerville-Donovan, Inc.

SUBJECT: Sunset Beach Subdivision

James Waddell
5-25-94

Mr. Creekmore,

Baskerville-Donovan, Inc. has completed its analysis of the St. George Island Utility (SGIU) water system as it relates to supplying water to the above-referenced project.

Our calculations and analysis may be summarized as follows:

- A. Total # of ERU's added based on the type of development at Sunset Beach -
- | | | |
|---|----------|----------------|
| 30 Phase I residential lots | = | 30 ERU's |
| 13 Phase II (future) residential lots | = | 13 ERU's |
| Club House and Pool | | |
| 43 Household members x 3 pers/household | = | 129 persons |
| 129 persons x 10 gal/day/person (Dept. of H.R.S Rule 10D-6) | = | 1,290 gal/day |
| (1,290 gal/day)/(300 gal/ERU) | = | 4.3, Say 5 ERU |
| TOTAL NO. OF ERU'S | = | 48 |
- B. Update of SGIU engineers report dated May 1992 to reflect additional commitments by utility to provide service.

The most recent CIAC list (date May 17, 1994) was made available by the Utility, which lists all commitments made by the Utility since May 1992. Through discussions with representatives of Sunset Beach, FDEP, and the Utility, we have summarized those commitments as follows.

In order to evaluate the impact of those commitments on the capacity of the system, the commitments were input into the Waterworks computer model, developed in the original engineers report, at the node(s) indicated.

1. Nicks Hole: Including St. George Island Resort Village ERU's = 25, loaded at node 132
2. The Bluffs: ERU's = 10, loaded at node 132

3. Pebble Beach: ERU's = 21, loaded at node 133
4. Sunset Beach: ERU's = 48, loaded at node 30
5. Sea Palm Village: ERU's = 14, loaded at node 129
6. St. George Plantation (Various Locations): ERU's = 55, loaded at nodes 125-150
7. West Side of Island: ERU's = 15, loaded at node 114 (7th St./Gulf Beach Drive)
8. East Side of Island: ERU's = 52, loaded at node 14 (8th St. East/Gulf Beach Drive)
9. Case Del Mar: 25 ERU's + 67 ERU's purchased from Andrew Jackson = 92, loaded at nodes 151-154

The results of the computer model (attached), simulating the proposed treatment plant modifications, indicate a total peak hourly demand of 1,035 gpm and a minimum pressure of 29.59 psi, occurring at Bob Sikes Cut.

This analysis indicates that the system has the capacity to serve Sunset Beach subdivision at a pressure of 35 psi +/- under a peak hourly flow condition.

With regard to the additional questions raised by the Department in their letter dated May 11, 1994, we offer the following comments.

The basis for all computer simulations of the SGIU system has been well documented in BDI's May 1992 Engineer's Report. The simulation submitted with this Technical Memorandum models peak hourly flow of all commitments claimed by the Utility and appearing on the May 17, 1994 CIAC list. Peak hourly flow is derived by increasing average daily flow (300 gpd/ERU) by an appropriate peaking factor. The peaking factor in this simulation, derived in a manner consistent with the May 1992 report, is approximately 3.3.

Peak hourly flow is loaded into the model, assuming each and every ERU is using water (0.69 gpm) at the same time.

It has been suggested by the Department that the values reported in the model for individual ERU'S is low and does not account for a peak hourly flow condition. It is our opinion that the method of analysis employed is an objective, reasonable, documented approach to evaluating the system under a peak flow condition. An arbitrary assignment of some fractional distribution of active ERU'S to simulate a peak flow condition would be purely subjective.

With regard to comparing the results of this analysis and the capacity of the system to meet the historical Maximum Day Demand (520 gpd/ERU), the following comments are offered.

The Utility's Standard Water Use Permit allows for a maximum combined withdrawal of 700,000 gpd from the raw water supply wells. Separate finished water storage of 150,000 gallons is provided by the elevated tank, given that the tank is full at the beginning of the day. Therefore, during any one twenty four hour period 850,000 gallons is available for delivery to the Utility's ERU commitments. In the case of this simulation the Utility could deliver approximately 567 gpd/ERU.

Given the conditions of flow described in the May 1992 report, the burden on finished water storage would be as follows:

	6 hr total peak X 0.69 gpm/ERU X 1500 ERU =	372,600 gal
	18 hr X 0.21 gpm/ERU X 1500 ERU =	340,200 gal
TOTAL	24 hr	712,800 gal

Net storage utilized would equal 12,800 gal (712,800-700,000)
Average ERU demand would be 475 gpd (712,800/1500).

Similarly, if ERU demand is taken to be 520 gpd/ERU (maximum daily flow), total flow would equal 780,000. Thus, only 80,000 gal of finished water storage would be depleted.

The Utility, based on these calculations, would be capable of adequately supplying service in the range of the historical ERU maximum day demand.

7

ST. GEORGE ISLAND WATER DISTRIBUTION SYSTEM
 COMMITMENTS PER CIAC LIST DATED MAY 17, 1994
 BOTH PUMPS ON
 PEAK HOURLY FLOW WITH EXISTING ELEVATED TANK OFF LINE

PIPE TABLE

			Input			Output			Input
Pipe	UpNode	DnNode	Length	Diameter	Roughness	Flow Velocity	HeadLoss	Status	
			NA	NA	ERR	NA	NA	NA	
								Open	
1	101	1	140.00	12.00	120.00	1035.00	2.94	0.45	
2	1	2	500.00	8.00	120.00	476.74	3.04	2.73	
3	2	3	330.00	4.00	120.00	17.94	0.46	0.12	
4	3	4	185.00	4.00	120.00	11.04	0.28	0.03	
5	2	5	180.00	8.00	120.00	453.97	2.90	0.90	
6	5	6	200.00	8.00	120.00	373.29	2.38	0.69	
7	6	7	500.00	8.00	120.00	367.77	2.35	1.69	
8	7	8	450.00	8.00	120.00	364.32	2.33	1.49	
9	8	9	440.00	8.00	120.00	357.42	2.28	1.41	
10	9	10	595.00	8.00	120.00	351.21	2.24	1.84	
11	10	11	1180.00	8.00	120.00	346.38	2.21	3.57	
12	11	12	1070.00	8.00	120.00	318.68	2.03	2.77	
13	12	13	1185.00	8.00	120.00	304.19	1.94	2.82	
14	13	14	1200.00	8.00	120.00	293.84	1.88	2.67	
15	14	15	1220.00	8.00	120.00	230.55	1.47	1.73	
16	15	16	330.00	6.00	120.00	32.46	0.37	0.05	
17	16	17	430.00	4.00	120.00	32.46	0.83	0.47	
18	17	18	770.00	4.00	120.00	29.01	0.74	0.69	
19	18	19	330.00	6.00	120.00	13.88	0.16	0.01	
20	19	20	1210.00	8.00	120.00	199.55	1.27	1.32	
21	20	21	550.00	2.00	120.00	-7.54	-0.77	1.16	
22	20	22	2000.00	6.00	120.00	195.27	2.22	8.49	
23	22	23	1400.00	6.00	120.00	184.92	2.10	5.37	
24	23	24	850.00	6.00	120.00	180.09	2.04	3.11	
25	24	25	1150.00	6.00	120.00	173.19	1.97	3.91	
26	25	26	1150.00	6.00	120.00	162.15	1.84	3.46	
27	26	27	2000.00	6.00	120.00	158.70	1.80	5.78	
28	27	28	1300.00	6.00	120.00	152.49	1.73	3.49	
29	28	29	500.00	6.00	120.00	145.59	1.65	1.23	
30	29	30	2600.00	6.00	120.00	65.55	0.74	1.46	
31	5	31	500.00	6.00	120.00	11.04	0.13	0.01	
32	31	32	450.00	6.00	120.00	11.04	0.13	0.01	
33	32	33	440.00	6.00	120.00	10.35	0.12	0.01	
34	11	34	400.00	6.00	120.00	13.90	0.16	0.01	
35	34	35	1070.00	2.00	120.00	13.90	1.42	7.17	
36	35	36	1185.00	2.00	120.00	5.62	0.57	1.48	
37	36	37	1200.00	2.00	120.00	-2.66	-0.27	0.38	
38	37	38	1220.00	2.00	120.00	9.57	0.98	4.09	
39	38	39	1210.00	2.00	120.00	3.36	0.34	0.58	
40	39	40	1210.00	2.00	120.00	-2.85	-0.29	0.43	
41	5	41	150.00	6.00	120.00	69.64	0.79	0.09	
101	0	101	10.00	12.00	120.00	1035.00	2.94	0.03	
102	101	102	300.00	8.00	120.00	0.00	0.00	0.00	
103	1	103	600.00	8.00	120.00	558.26	3.56	4.39	

ST. GEORGE ISLAND WATER DISTRIBUTION SYSTEM
 COMMITMENTS PER CIAC LIST DATED MAY 17, 1994
 BOTH PUMPS ON
 PEAK HOURLY FLOW WITH EXISTING ELEVATED TANK OFF LINE

PIPE TABLE

			Input			Output			Input
Pipe	UpNode	DnNode	Length	Diameter	Roughness	Flow	Velocity	HeadLoss	Status
			NA	NA	ERR	NA	NA	NA	Open
104	103	104	400.00	6.00	120.00	-38.59	-0.44	0.08	
105	103	105	510.00	8.00	120.00	594.78	3.80	4.19	
106	105	106	900.00	6.00	120.00	198.38	2.25	3.93	
107	106	107	630.00	8.00	120.00	197.69	1.26	0.67	
108	107	108	570.00	2.00	120.00	14.49	1.48	4.13	
109	105	109	1174.00	8.00	120.00	375.70	2.40	4.12	
110	109	110	1174.00	8.00	120.00	362.59	2.31	3.86	
111	110	111	900.00	6.00	120.00	-130.76	-1.48	1.82	
112	111	112	360.00	8.00	120.00	-172.16	-1.10	0.30	
113	111	113	860.00	8.00	120.00	21.39	0.14	0.01	
114	110	114	983.00	8.00	120.00	478.17	3.05	5.40	
115	114	115	1154.00	8.00	120.00	454.02	2.90	5.76	
116	115	116	790.00	6.00	120.00	15.18	0.17	0.03	
117	116	117	350.00	6.00	120.00	15.18	0.17	0.01	
118	115	118	1177.00	8.00	120.00	419.52	2.68	5.07	
119	118	119	1222.00	8.00	120.00	401.58	2.56	4.86	
120	119	120	800.00	6.00	120.00	19.32	0.22	0.05	
121	120	121	840.00	6.00	120.00	12.42	0.14	0.02	
122	121	122	600.00	6.00	120.00	10.35	0.12	0.01	
123	119	123	1250.00	8.00	120.00	368.46	2.35	4.23	
124	123	124	1170.00	8.00	120.00	332.58	2.12	3.28	
125	124	125	1150.00	8.00	120.00	320.16	2.04	3.00	
126	125	126	920.00	8.00	120.00	307.74	1.96	2.23	
127	126	127	978.00	8.00	120.00	298.08	1.90	2.24	
128	127	128	1323.00	8.00	120.00	289.11	1.85	2.86	
129	128	129	1150.00	8.00	120.00	271.86	1.74	2.22	
130	129	130	805.00	8.00	120.00	255.30	1.63	1.38	
131	130	131	3450.00	8.00	120.00	253.92	1.62	5.87	
132	131	132	1035.00	8.00	120.00	249.78	1.59	1.71	
133	132	133	1150.00	8.00	120.00	218.73	1.40	1.48	
134	133	134	690.00	8.00	120.00	197.34	1.26	0.74	
135	134	135	690.00	8.00	120.00	195.96	1.25	0.73	
136	135	136	1322.00	8.00	120.00	187.68	1.20	1.28	
137	136	137	1265.00	8.00	120.00	178.02	1.14	1.11	
138	137	138	863.00	8.00	120.00	166.98	1.07	0.68	
139	138	139	920.00	8.00	120.00	153.18	0.98	0.61	
140	139	140	1150.00	8.00	120.00	138.69	0.89	0.64	
141	140	141	690.00	8.00	120.00	128.34	0.82	0.33	
142	141	142	690.00	8.00	120.00	117.30	0.75	0.28	
143	142	143	402.00	8.00	120.00	115.92	0.74	0.16	
144	143	144	460.00	8.00	120.00	114.54	0.73	0.18	
145	144	145	460.00	8.00	120.00	93.15	0.59	0.12	
146	145	146	633.00	8.00	120.00	91.77	0.59	0.16	
147	146	147	288.00	8.00	120.00	90.39	0.58	0.07	

ST. GEORGE ISLAND WATER DISTRIBUTION SYSTEM
 COMMITMENTS PER CIAC LIST DATED MAY 17, 1994
 BOTH PUMPS ON
 PEAK HOURLY FLOW WITH EXISTING ELEVATED TANK OFF LINE

PIPE TABLE

Pipe	UpNode	DnNode	Input			Output			Status
			Length	Diameter	Roughness	Flow	Velocity	HeadLoss	
			NA	NA	ERR	NA	NA	NA	Open
148	147	148	460.00	8.00	120.00	77.28	0.49	0.09	
149	148	149	633.00	8.00	120.00	75.90	0.48	0.12	
150	149	150	1150.00	8.00	120.00	66.24	0.42	0.16	
151	150	151	748.00	8.00	120.00	64.86	0.41	0.10	
152	151	152	288.00	8.00	120.00	48.30	0.31	0.02	
153	152	153	690.00	8.00	120.00	32.43	0.21	0.03	
154	153	154	403.00	8.00	120.00	16.56	0.11	0.00	
155	154	155	403.00	8.00	120.00	0.69	0.00	0.00	
156	155	156	690.00	8.00	120.00	0.00	0.00	0.00	
157	156	157	460.00	8.00	120.00	0.00	0.00	0.00	
158	123	158	320.00	6.00	120.00	15.87	0.18	0.01	
159	158	159	1220.00	6.00	120.00	4.83	0.05	0.01	
401	15	19	1210.00	8.00	120.00	191.88	1.22	1.22	
402	18	21	990.00	4.00	120.00	11.68	0.30	0.16	
403	14	37	400.00	6.00	120.00	21.89	0.25	0.03	
404	20	40	400.00	6.00	120.00	2.85	0.03	0.00	
405	41	104	960.00	6.00	120.00	68.26	0.77	0.58	
406	107	112	1358.00	8.00	120.00	183.20	1.17	1.26	
500	500	0	2.00	12.00	120.00	263.79	0.75	0.00	
501	501	0	2.00	12.00	120.00	771.21	2.19	0.00	

DEMAND

0.69 gpm/ERU

NODE TABLE

<----- Input ----->		<----- Output ----->		<----- Optional ----->		<----- Input ----->	
Node	Elevation	Demand	Pressure	HGL	XCoord	YCoord	Status
	NA	NA	NA	NA			ON
0	6.00	0.00	62.59	150.59			
1	6.00	0.00	62.39	150.12			
2	6.00	4.83	61.21	147.39			
3	6.00	6.90	61.15	147.26			
4	6.00	11.04	61.14	147.24			
5	6.00	0.00	60.82	146.49			
6	6.00	5.52	60.52	145.79			
7	6.00	3.45	59.79	144.11			
8	6.00	6.90	59.14	142.61			
9	6.00	6.21	58.53	141.20			
10	6.00	4.83	57.73	139.36			
11	6.00	13.80	56.19	135.79			
12	6.00	14.49	54.99	133.02			
13	6.00	10.35	53.77	130.21			
14	6.00	41.40	52.61	127.53			
15	6.00	6.21	51.86	125.80			
16	6.00	0.00	51.84	125.75			
17	6.00	3.45	51.63	125.28			
18	6.00	3.45	51.34	124.59			
19	6.00	6.21	51.33	124.58			
20	6.00	8.97	50.76	123.26			
21	6.00	4.14	51.26	124.42			
22	6.00	10.35	47.09	114.77			
23	6.00	4.83	44.76	109.40			
24	6.00	6.90	43.42	106.29			
25	6.00	11.04	41.73	102.39			
26	6.00	3.45	40.23	98.93			
27	6.00	6.21	37.73	93.15			
28	6.00	6.90	36.21	89.66			
29	6.00	80.04	35.68	88.42			
30	6.00	65.55	35.05	86.96			
31	6.00	0.00	60.81	146.48			
32	6.00	0.69	60.81	146.47			
33	6.00	10.35	60.81	146.46			
34	6.00	0.00	56.18	135.78			
35	6.00	8.28	53.08	128.61			
36	6.00	8.28	52.44	127.13			
37	6.00	9.66	52.60	127.50			
38	6.00	6.21	50.83	123.41			
39	6.00	6.21	50.57	122.83			
40	6.00	0.00	50.76	123.26			
41	6.00	1.38	60.78	146.39			
101	6.00	0.00	62.58	150.56			
102	7.00	0.00	62.15	150.56			

DEMAND

0.69 gpm/ERU

NODE TABLE

←----- Input -----		----- Output -----		----- Optional -----		←-Input->	
Node	Elevation	Demand	Pressure	HGL	XCoord	YCoord	Status
	NA	NA	NA	NA			ON
103	6.00	2.07	60.49	145.73			
104	6.00	29.67	60.52	145.81			
105	6.00	20.70	58.67	141.53			
106	6.00	0.69	56.97	137.60			
107	6.00	0.00	56.68	136.93			
108	6.00	14.49	54.89	132.80			
109	6.00	13.11	56.89	137.41			
110	6.00	15.18	55.22	133.55			
111	6.00	20.01	56.00	135.37			
112	6.00	11.04	56.13	135.67			
113	6.00	21.39	56.00	135.35			
114	6.00	24.15	52.88	128.15			
115	6.00	19.32	50.39	122.40			
116	6.00	0.00	50.38	122.37			
117	6.00	15.18	50.37	122.36			
118	6.00	17.94	48.19	117.33			
119	6.00	13.80	46.09	112.47			
120	6.00	6.90	46.07	112.43			
121	6.00	2.07	46.06	112.40			
122	6.00	10.35	46.06	112.39			
123	6.00	20.01	44.26	108.24			
124	6.00	12.42	42.84	104.96			
125	6.00	12.42	41.54	101.96			
126	6.00	9.66	40.57	99.72			
127	6.00	8.97	39.60	97.48			
128	6.00	17.25	38.37	94.62			
129	6.00	16.56	37.41	92.41			
130	6.00	1.38	36.81	91.02			
131	6.00	4.14	34.27	85.16			
132	6.00	31.05	33.53	83.45			
133	6.00	21.39	32.89	81.97			
134	6.00	1.38	32.57	81.23			
135	6.00	8.28	32.25	80.51			
136	6.00	9.66	31.70	79.22			
137	6.00	11.04	31.22	78.11			
138	6.00	13.80	30.92	77.43			
139	6.00	14.49	30.66	76.82			
140	6.00	10.35	30.38	76.18			
141	6.00	11.04	30.24	75.85			
142	6.00	1.38	30.12	75.57			
143	6.00	1.38	30.05	75.41			
144	6.00	21.39	29.97	75.23			
145	6.00	1.38	29.92	75.11			
146	6.00	1.38	29.85	74.94			

DEMAND

0.69 gpm/ERU

NODE TABLE

←----- Input -----		----->----- Output -----		----->----- Optional -----		----->----- Input ----->	
Node	Elevation	Demand	Pressure	HGL	XCoord	YCoord	Status
	NA	NA	NA	NA			ON
147	6.00	13.11	29.81	74.87			
148	6.00	1.38	29.78	74.79			
149	6.00	9.66	29.73	74.67			
150	6.00	1.38	29.66	74.51			
151	6.00	16.56	29.61	74.41			
152	6.00	15.87	29.60	74.38			
153	6.00	15.87	29.59	74.36			
154	6.00	15.87	29.59	74.35			
155	6.00	0.69	29.59	74.35			
156	6.00	0.00	29.59	74.35			
157	6.00	0.00	29.59	74.35			
158	6.00	11.04	44.25	108.22			
159	6.00	4.83	44.25	108.22			
500	6.00		62.59	150.59			
501	6.00		62.60	150.60			
		1035.00	29.59				

INFLOW TABLE

←----- Input -----		----->----- Output -----		----->----- Input ----->	
Node	Pumps OpCurve	%Estimate	%Actual	Inflow	Status
				NA	ON
102	1 PUMP1	1	0.00	0.00	C
501	1 PUMP2		0.75	-771.21	
500	1 PUMP3		0.25	-263.79	

PUMP1		PUMP2		PUMP3	
←----- Input ----->		←----- Input ----->		←----- Input ----->	
Flow	Head	Flow	Head	Flow	Head
NA	NA	NA	NA	NA	NA
0.00	105.00	0.00	250.00	0.00	190.00
500.00	105.00	100.00	250.00	80.00	185.00
1000.00	105.00	300.00	240.00	160.00	180.00
1500.00	105.00	500.00	215.00	240.00	155.00
		650.00	185.00	320.00	120.00
		800.00	135.00	400.00	70.00
		900.00	80.00	480.00	20.00
		1000.00	0.00	490.00	0.00

FILENAME: SUNSET2.WK1

CUSTOMERS

(ERU'S)

RUN1 RUN1
NODE NO. EX. CUST. +DAGMT

0	0	
1	0	
2	7	
3	10	
4	16	
5	0	
6	8	
7	5	
8	10	
9	9	
10	7	
11	20	
12	21	
13	15	
14	8	52
15	9	
16	0	
17	5	
18	5	
19	9	
20	13	
21	6	
22	15	
23	7	
24	10	
25	16	
26	5	
27	9	
28	10	
29	116	
30	47	48
31	0	
32	1	
33	15	
34	0	
35	12	
36	12	
37	14	
38	9	
39	9	
40	0	
41	2	
101	0	
102	0	

FILENAME: SUNSET2.WK1

CUSTOMERS
(ERU'S)

RUN1 RUN1
NODE NO. EX. CUST. +DAGMT

103	3	
104	43	
105	30	
106	1	
107	0	
108	21	
109	19	
110	22	
111	29	
112	16	
113	31	
114	20	15
115	28	
116	0	
117	22	
118	26	
119	20	
120	10	
121	3	
122	15	
123	29	
124	18	
125	15	3
126	11	3
127	10	3
128	23	2
129	8	16
130	0	2
131	4	2
132	8	37
133	8	23
134	0	2
135	10	2
136	12	2
137	14	2
138	18	2
139	19	2
140	13	2
141	14	2
142	0	2
143	0	2
144	29	2
145	0	2
146	0	2

FILENAME: SUNSET2.WK1

CUSTOMERS
(ERU'S)

RUN1 RUN1
NODE NO. EX. CUST. +DAGMT

147	17	2
148	0	2
149	12	2
150	0	2
151	1	23
152	0	23
153	0	23
154	0	23
155	1	
156	0	
157	0	
158	16	
159	7	

TOTAL 1168 332

ALL COMMITMENTS 1500

ADDENDUM NUMBER 2

MAY 5, 1994

ENGINEER'S REPORT
SYSTEM CAPACITY ANALYSIS OF THE

ST. GEORGE ISLAND UTILITY CO., LTD WATER DISTRIBUTION SYSTEM

PREPARED FOR

ST. GEORGE ISLAND UTILITY CO., LTD.

PREPARED BY

BASKERVILLE-DONOVAN, INC.
316 SOUTH BAYLEN STREET
SUITE 300
P.O. BOX 13370
PENSACOLA, FLORIDA 32591

MAY, 1992

Yed Huddy
5-6-94

The following text is hereby incorporated into the subject report, certified by Baskerville-Donovan, Inc. on May 27, 1992. Information in this addendum relates to the capacity of St. George Island Utility Co., Ltd. to serve additional customers.

Parameters established for the data presented in this model assume that year 2 improvements are on line. The improvements include:

1. Altitude valve with pressure sustaining feature to isolate the existing elevated tank during periods of high demand.
2. Modification of electrical controls to allow parallel operation of the larger and smaller booster pumps located at the treatment plant.
3. Reconditioning of existing pumps to ensure performance similar to their published curves.
4. Provision of a second 50 hp pump, with operating characteristics similar to that of the existing 50 hp pump.

The purpose of this analysis is to determine the limiting capacity of the system. The limiting capacity of the system is assumed to be the point at which under a peak hourly flow condition, the system cannot maintain pressures above the minimum level of 20 psi, as set forth in Section 17-555, F.A.C.

VI. Analysis Results

A. Existing Customers

5. Peak hourly flow demand for existing ERU's (1264), plus additional ERU's totalling 277 were distributed throughout the distribution node network (as shown on the attached printout) in the waterworks model. This simulation was executed with the 50 hp and 20 hp booster pumps operating in parallel and the existing elevated tank off line. The results, attached as Exhibit 10-G, indicate a total instantaneous system demand of approximately 1048 gpm. The flow contribution by the large and small booster pump is 779 gpm and 269 gpm, respectively. Minimum system pressure, occurring at node 157, is approximately 20 psi.

To clarify the location of additional connections input for this simulation, the assignment of ERU's is as follows:

- A. One (1) ERU per node throughout the system, excluding St. George Plantation.

- B. 5 or 6 ERU's per node within St. George Plantation, except node 130 (Nick's Hole) where 35 ERU's were input into the model.

jw00113

ST. GEORGE ISLAND WATER DISTRIBUTION SYSTEM
 EXISTING FLOWS
 BOTH PUMPS ON, PEAK HOURLY FLOW WITH EXIST. ELEVATED TANK
 OFF LINE AND PLANT MODIFICATIONS IN PLACE

PIPE TABLE

Pipe	Input		Length	Diameter			Roughness	Output			Status
	UpNode	DnNode		NA	NA	ERR		Flow	Velocity	HeadLoss	
			NA	NA	ERR	NA	NA	NA	Open		
1	101	1	140.00	12.00	120.00	1045.84	2.97	0.45			
2	1	2	500.00	8.00	120.00	457.19	2.92	2.53			
3	2	3	330.00	4.00	120.00	19.04	0.49	0.14			
4	3	4	185.00	4.00	120.00	11.56	0.30	0.03			
5	2	5	180.00	8.00	120.00	432.71	2.76	0.82			
6	5	6	200.00	8.00	120.00	321.64	2.05	0.53			
7	6	7	500.00	8.00	120.00	315.52	2.01	1.27			
8	7	8	450.00	8.00	120.00	311.44	1.99	1.12			
9	8	9	440.00	8.00	120.00	303.96	1.94	1.04			
10	9	10	595.00	8.00	120.00	297.16	1.90	1.35			
11	10	11	1180.00	8.00	120.00	291.72	1.86	2.59			
12	11	12	1070.00	8.00	120.00	263.98	1.69	1.95			
13	12	13	1185.00	8.00	120.00	249.02	1.59	1.94			
14	13	14	1200.00	8.00	120.00	238.14	1.52	1.81			
15	14	15	1220.00	8.00	120.00	207.55	1.32	1.43			
16	15	16	330.00	6.00	120.00	30.15	0.34	0.04			
17	16	17	430.00	4.00	120.00	29.47	0.75	0.40			
18	17	18	770.00	4.00	120.00	25.39	0.65	0.54			
19	18	19	330.00	6.00	120.00	10.12	0.11	0.01			
20	19	20	1210.00	8.00	120.00	173.92	1.11	1.02			
21	20	21	550.00	2.00	120.00	-6.43	-0.66	0.87			
22	20	22	2000.00	6.00	120.00	165.92	1.88	6.28			
23	22	23	1400.00	6.00	120.00	155.04	1.76	3.88			
24	23	24	850.00	6.00	120.00	149.60	1.70	2.20			
25	24	25	1150.00	6.00	120.00	142.12	1.61	2.71			
26	25	26	1150.00	6.00	120.00	130.56	1.48	2.32			
27	26	27	2000.00	6.00	120.00	126.48	1.44	3.80			
28	27	28	1300.00	6.00	120.00	119.68	1.36	2.23			
29	28	29	500.00	6.00	120.00	112.20	1.27	0.76			
30	29	30	2600.00	6.00	120.00	32.64	0.37	0.40			
31	5	31	500.00	6.00	120.00	12.92	0.15	0.01			
32	31	32	450.00	6.00	120.00	12.24	0.14	0.01			
33	32	33	440.00	6.00	120.00	10.88	0.12	0.01			
34	11	34	400.00	6.00	120.00	13.46	0.15	0.01			
35	34	35	1070.00	2.00	120.00	12.78	1.30	6.14			
36	35	36	1185.00	2.00	120.00	3.94	0.40	0.77			
37	36	37	1200.00	2.00	120.00	-4.90	-0.50	1.17			
38	37	38	1220.00	2.00	120.00	9.37	0.96	3.94			
39	38	39	1210.00	2.00	120.00	2.57	0.26	0.36			
40	39	40	1210.00	2.00	120.00	-4.23	-0.43	0.90			
41	5	41	150.00	6.00	120.00	97.47	1.11	0.18			
101	0	101	10.00	12.00	120.00	1047.20	2.97	0.03			
102	101	102	300.00	8.00	120.00	0.68	0.00	0.00			
103	1	103	600.00	8.00	120.00	587.97	3.75	4.83			

ST. GEORGE ISLAND WATER DISTRIBUTION SYSTEM
 EXISTING FLOWS
 BOTH PUMPS ON, PEAK HOURLY FLOW WITH EXIST. ELEVATED TANK
 OFF LINE AND PLANT MODIFICATIONS IN PLACE

PIPE TABLE

Pipe	UpNode	DnNode	Input			Output			Status
			Length	Diameter	Roughness	Flow	Velocity	HeadLoss	
			NA	NA	ERR	NA	NA	NA	Open
104	103	104	400.00	6.00	120.00	-65.51	-0.74	0.22	
105	103	105	510.00	8.00	120.00	650.76	4.15	4.95	
106	105	106	900.00	6.00	120.00	217.06	2.46	4.65	
107	106	107	630.00	8.00	120.00	215.70	1.38	0.79	
108	107	108	570.00	2.00	120.00	14.96	1.53	4.38	
109	105	109	1174.00	8.00	120.00	412.62	2.63	4.90	
110	109	110	1174.00	8.00	120.00	399.02	2.55	4.61	
111	110	111	900.00	6.00	120.00	-146.34	-1.66	2.24	
112	111	112	360.00	8.00	120.00	-188.50	-1.20	0.35	
113	111	113	860.00	8.00	120.00	21.76	0.14	0.02	
114	110	114	983.00	8.00	120.00	529.72	3.38	6.52	
115	114	115	1154.00	8.00	120.00	515.44	3.29	7.28	
116	115	116	790.00	6.00	120.00	16.32	0.19	0.03	
117	116	117	350.00	6.00	120.00	15.64	0.18	0.01	
118	115	118	1177.00	8.00	120.00	479.40	3.06	6.49	
119	118	119	1222.00	8.00	120.00	461.04	2.94	6.27	
120	119	120	800.00	6.00	120.00	21.08	0.24	0.06	
121	120	121	840.00	6.00	120.00	13.60	0.15	0.03	
122	121	122	600.00	6.00	120.00	10.88	0.12	0.01	
123	119	123	1250.00	8.00	120.00	425.68	2.72	5.53	
124	123	124	1170.00	8.00	120.00	389.64	2.49	4.40	
125	124	125	1150.00	8.00	120.00	376.72	2.40	4.06	
126	125	126	920.00	8.00	120.00	361.76	2.31	3.01	
127	126	127	978.00	8.00	120.00	349.52	2.23	3.00	
128	127	128	1323.00	8.00	120.00	337.96	2.16	3.82	
129	128	129	1150.00	8.00	120.00	316.88	2.02	2.95	
130	129	130	805.00	8.00	120.00	306.00	1.95	1.93	
131	130	131	3450.00	8.00	120.00	280.84	1.79	7.07	
132	131	132	1035.00	8.00	120.00	263.16	1.68	1.88	
133	132	133	1150.00	8.00	120.00	252.28	1.61	1.93	
134	133	134	690.00	8.00	120.00	241.40	1.54	1.07	
135	134	135	690.00	8.00	120.00	235.96	1.51	1.02	
136	135	136	1322.00	8.00	120.00	223.72	1.43	1.78	
137	136	137	1265.00	8.00	120.00	210.12	1.34	1.51	
138	137	138	863.00	8.00	120.00	195.16	1.25	0.90	
139	138	139	920.00	8.00	120.00	177.48	1.13	0.81	
140	139	140	1150.00	8.00	120.00	159.12	1.02	0.82	
141	140	141	690.00	8.00	120.00	144.84	0.92	0.41	
142	141	142	690.00	8.00	120.00	129.88	0.83	0.34	
143	142	143	402.00	8.00	120.00	125.12	0.80	0.18	
144	143	144	460.00	8.00	120.00	120.36	0.77	0.20	
145	144	145	460.00	8.00	120.00	95.88	0.61	0.13	
146	145	146	633.00	8.00	120.00	91.12	0.58	0.16	
147	146	147	288.00	8.00	120.00	86.36	0.55	0.07	

ST. GEORGE ISLAND WATER DISTRIBUTION SYSTEM
 EXISTING FLOWS
 BOTH PUMPS ON, PEAK HOURLY FLOW WITH EXIST. ELEVATED TANK
 OFF LINE AND PLANT MODIFICATIONS IN PLACE

PIPE TABLE

Pipe	Input			Output			Input		
	UpNode	DnNode	Length	Diameter	Roughness	Flow	Velocity	HeadLoss	Status
			NA	NA	ERR	NA	NA	NA	Open
148	147	148	460.00	8.00	120.00	70.04	0.45	0.07	
149	148	149	633.00	8.00	120.00	65.28	0.42	0.09	
150	149	150	1150.00	8.00	120.00	52.36	0.33	0.11	
151	150	151	748.00	8.00	120.00	47.60	0.30	0.06	
152	151	152	288.00	8.00	120.00	42.16	0.27	0.02	
153	152	153	690.00	8.00	120.00	37.40	0.24	0.03	
154	153	154	403.00	8.00	120.00	33.32	0.21	0.02	
155	154	155	403.00	8.00	120.00	29.24	0.19	0.01	
156	155	156	690.00	8.00	120.00	24.48	0.16	0.02	
157	156	157	460.00	8.00	120.00	20.40	0.13	0.01	
158	123	158	320.00	6.00	120.00	15.64	0.18	0.01	
159	158	159	1220.00	6.00	120.00	4.76	0.05	0.01	
401	15	19	1210.00	8.00	120.00	170.60	1.09	0.98	
402	18	21	990.00	4.00	120.00	11.19	0.29	0.15	
403	14	37	400.00	6.00	120.00	24.47	0.28	0.04	
404	20	40	400.00	6.00	120.00	4.91	0.06	0.00	
405	41	104	960.00	6.00	120.00	95.43	1.08	1.08	
406	107	112	1358.00	8.00	120.00	200.06	1.28	1.48	
500	500	0	2.00	12.00	120.00	269.36	0.76	0.00	
501	501	0	2.00	12.00	120.00	778.52	2.21	0.00	

DEMAND

0.68 gpm/ERU

NODE TABLE

Node	Elevation	Demand	Pressure	HGL	XCoord	YCoord	Status
Input	NA	NA	NA	NA			ON
0	6.00	0.68	61.54	148.16			
1	6.00	0.68	61.33	147.67			
2	6.00	5.44	60.24	145.14			
3	6.00	7.48	60.18	145.01			
4	6.00	11.56	60.16	144.98			
5	6.00	0.68	59.88	144.32			
6	6.00	6.12	59.65	143.79			
7	6.00	4.08	59.10	142.52			
8	6.00	7.48	58.62	141.41			
9	6.00	6.80	58.17	140.36			
10	6.00	5.44	57.58	139.01			
11	6.00	14.28	56.46	136.42			
12	6.00	14.96	55.61	134.46			
13	6.00	10.88	54.77	132.52			
14	6.00	6.12	53.99	130.71			
15	6.00	6.80	53.37	129.28			
16	6.00	0.68	53.35	129.23			
17	6.00	4.08	53.18	128.84			
18	6.00	4.08	52.94	128.30			
19	6.00	6.80	52.94	128.29			
20	6.00	9.52	52.50	127.27			
21	6.00	4.76	52.88	128.15			
22	6.00	10.88	49.78	120.99			
23	6.00	5.44	48.10	117.12			
24	6.00	7.48	47.15	114.92			
25	6.00	11.56	45.98	112.21			
26	6.00	4.08	44.97	109.89			
27	6.00	6.80	43.33	106.09			
28	6.00	7.48	42.37	103.86			
29	6.00	79.56	42.04	103.10			
30	6.00	32.64	41.86	102.70			
31	6.00	0.68	59.87	144.31			
32	6.00	1.36	59.87	144.30			
33	6.00	10.88	59.86	144.29			
34	6.00	0.68	56.45	136.40			
35	6.00	8.84	53.80	130.27			
36	6.00	8.84	53.46	129.50			
37	6.00	10.20	53.97	130.67			
38	6.00	6.80	52.26	126.73			
39	6.00	6.80	52.11	126.37			
40	6.00	0.68	52.50	127.27			
41	6.00	2.04	59.80	144.15			
101	6.00	0.68	61.53	148.12			
102	7.00	0.68	61.09	148.12			

DEMAND

0.68 gpm/ERU

NODE TABLE

Node	Elevation	Demand	Pressure	HGL	XCoord	YCoord	Status
Input	Output	Optional	Input				
NA	NA	NA	NA	NA			ON
103	6.00	2.72	59.24	142.84			
104	6.00	29.92	59.34	143.06			
105	6.00	21.08	57.09	137.89			
106	6.00	1.36	55.08	133.24			
107	6.00	0.68	54.74	132.45			
108	6.00	14.96	52.84	128.07			
109	6.00	13.60	54.97	132.98			
110	6.00	15.64	52.97	128.37			
111	6.00	20.40	53.94	130.61			
112	6.00	11.56	54.10	130.96			
113	6.00	21.76	53.94	130.59			
114	6.00	14.28	50.15	121.85			
115	6.00	19.72	47.00	114.57			
116	6.00	0.68	46.98	114.54			
117	6.00	15.64	46.98	114.52			
118	6.00	18.36	44.19	108.08			
119	6.00	14.28	41.48	101.81			
120	6.00	7.48	41.45	101.75			
121	6.00	2.72	41.44	101.73			
122	6.00	10.88	41.43	101.71			
123	6.00	20.40	39.08	96.27			
124	6.00	12.92	37.18	91.88			
125	6.00	14.96	35.42	87.82			
126	6.00	12.24	34.12	84.81			
127	6.00	11.56	32.81	81.80			
128	6.00	21.08	31.16	77.98			
129	6.00	10.88	29.89	75.04			
130	6.00	25.16	29.05	73.10			
131	6.00	17.68	25.99	66.03			
132	6.00	10.88	25.17	64.15			
133	6.00	10.88	24.34	62.22			
134	6.00	5.44	23.88	61.15			
135	6.00	12.24	23.43	60.13			
136	6.00	13.60	22.66	58.35			
137	6.00	14.96	22.01	56.84			
138	6.00	17.68	21.62	55.94			
139	6.00	18.36	21.27	55.13			
140	6.00	14.28	20.91	54.31			
141	6.00	14.96	20.73	53.89			
142	6.00	4.76	20.59	53.55			
143	6.00	4.76	20.51	53.37			
144	6.00	24.48	20.42	53.17			
145	6.00	4.76	20.37	53.04			
146	6.00	4.76	20.30	52.88			

DEMAND

0.68 gpm/ERU

NODE TABLE

Node	Input	Output	Optional	Input		
Elevation	Demand	Pressure	HGL	XCoord	YCoord	Status
NA	NA	NA	NA			ON
147	6.00	16.32	20.27	52.82		
148	6.00	4.76	20.24	52.74		
149	6.00	12.92	20.20	52.66		
150	6.00	4.76	20.15	52.55		
151	6.00	5.44	20.13	52.49		
152	6.00	4.76	20.12	52.48		
153	6.00	4.08	20.11	52.44		
154	6.00	4.08	20.10	52.43		
155	6.00	4.76	20.09	52.41		
156	6.00	4.08	20.09	52.40		
157	6.00	20.40	20.08	52.39		
158	6.00	10.88	39.07	96.26		
159	6.00	4.76	39.07	96.26		
500	6.00		61.54	148.16		
501	6.00		61.54	148.16		
		1047.88	20.08			

INFLOW TABLE

←----- Input ----->		----->----- Output -----<		----->----- Input ----->	
Node	Pumps OpCurve	%Estimate	%Actual	Inflow	Status
				NA	ON
				NA	ON
102	1 PUMP1	1	0.00	0.00	C
501	1 PUMP2		0.74	-778.52	
500	1 PUMP3		0.26	-269.36	

PUMP1		PUMP2		PUMP3	
Input		Input		Input	
Flow	Head	Flow	Head	Flow	Head
NA	NA	NA	NA	NA	NA
0.00	105.00	0.00	250.00	0.00	190.00
500.00	105.00	100.00	250.00	80.00	185.00
1000.00	105.00	300.00	240.00	160.00	180.00
1500.00	105.00	500.00	215.00	240.00	155.00
		650.00	185.00	320.00	120.00
		800.00	135.00	400.00	70.00
		900.00	80.00	480.00	20.00
		1000.00	0.00	490.00	0.00

CUSTOMERS

(ERU'S)

RUN1 RUN1

MODE NO. EX. CUST. +DAGMT ADDL.

0	0		1
1	0		1
2	7		1
3	10		1
4	16		1
5	0		1
6	8		1
7	5		1
8	10		1
9	9		1
10	7		1
11	20		1
12	21		1
13	15		1
14	8		1
15	9		1
16	0		1
17	5		1
18	5		1
19	9		1
20	13		1
21	6		1
22	15		1
23	7		1
24	10		1
25	16		1
26	5		1
27	9		1
28	10		1
29	116		1
30	47		1
31	0		1
32	1		1
33	15		1
34	0		1
35	12		1
36	12		1
37	14		1

CUSTOMERS

(ERU'S)

RUN1 RUN1

CODE NO. EX. CUST. +DAGMT ADDL.

38	9		1
39	9		1
40	0		1
41	2		1
101	0		1
102	0		1
103	3		1
104	43		1
105	30		1
106	1		1
107	0		1
108	21		1
109	19		1
110	22		1
111	29		1
112	16		1
113	31		1
114	20		1
115	28		1
116	0		1
117	22		1
118	26		1
119	20		1
120	10		1
121	3		1
122	15		1
123	29		1
124	18		1
125	15	1	6
126	11	1	6
127	10	1	6
128	23	2	6
129	8	2	6
130	0	2	35
131	4	16	6
132	8	2	6
133	8	2	6
134	0	2	6
135	10	2	6
136	12	2	6
137	14	2	6
138	18	2	6
139	19	2	6
140	13	2	6

CUSTOMERS

(ERU'S)

RUN1 RUN1

NODE NO. EX. CUST. +DAGMT ADDL.

141	14	2	6
142	0	2	5
143	0	2	5
144	29	2	5
145	0	2	5
146	0	2	5
147	17	2	5
148	0	2	5
149	12	2	5
150	0	2	5
151	1	2	5
152	0	2	5
153	0	1	5
154	0	1	5
155	1	1	5
156	0	1	5
157	0	25	5
158	16		
159	7		

TOTAL 1168 96 277

1541

ADDENDUM NO. 1

June 8, 1992

ENGINEER'S REPORT

SYSTEM CAPACITY ANALYSIS
OF THE
ST. GEORGE ISLAND UTILITY CO. LTD.
WATER DISTRIBUTION SYSTEM

Prepared For:

St. George Island Utility Co. Ltd.

Prepared By:

Baskerville-Donovan, Inc.
316 South Baylen Street, Suite 300
P.O. Box 13370
Pensacola, Florida 32591

May 1992

The following text is hereby incorporated into the subject report, certified by Baskerville-Donovan, Inc. on May 27, 1992. Information presented in this Addendum relates to the capacity of St. George Island Utility Co., Ltd. to accept additional ERU's. The limiting capacity of the system is assumed to be the point at which under a peak hourly flow condition, the system cannot maintain pressures above the minimum level of 20 psi, as set forth in Section 17-555, FAC.

VI. ANALYSIS RESULTS

A. Existing Customers

4. Peak hourly flow demand for existing ERU's (1264), plus additional ERU's (totalling 130) evenly distributed throughout the distribution node network was input into the Waterworks model with the elevated tank and large booster pump at the treatment plant on line. The results of this simulation, included as Exhibit 10-E, indicate a total instantaneous system demand of approximately 962 gpm. The flow contribution by the large booster pump and elevated tank is 853 gpm and 109 gpm, respectively. Minimum system pressure, occurring at node 157 is approximately 20 psi.

Similarly, existing ERU's (1264), plus additional ERU's (totalling 50) evenly distributed in the St. George Plantation area was input into the Waterworks model with the elevated tank and large booster pump at the treatment plant on line. The results of this simulation, included as Exhibit 10-F, indicate a total instantaneous system demand of 920 gpm. The flow contribution by the large booster pump and elevated tank is 853 gpm and 67 gpm respectively. Minimum system pressure, occurring at node 157 is approximately 20 psi.

The results of these simulations indicate that the Utility system, in its current configuration, can adequately serve up to 130 additional ERU's, depending on their location within the system, and maintain pressures under peak flow conditions of at least 20 psi, as required by Section 17-555, FAC.

ST. GEORGE ISLAND WATER DISTRIBUTION SYSTEM
 EXISTING FLOWS
 ONLY LARGE PUMP ON
 PEAK HOURLY FLOW WITH EXISTING ELEVATED TANK ON LINE

PIPE TABLE

q#	Input			Output				
	Pipe	UpNode	DnNode	Length ft	Diameter in	Roughness	Flow US gpm	Velocity ft/sec
1	1	101	1	140.00	12.00	120.00	961.17	2.73
2	2	1	2	500.00	8.00	120.00	443.99	2.83
3	3	2	3	330.00	4.00	120.00	20.70	0.53
4	4	3	4	185.00	4.00	120.00	12.42	0.32
5	5	2	5	180.00	8.00	120.00	417.08	2.66
6	6	5	6	200.00	8.00	120.00	337.41	2.15
7	7	6	7	500.00	8.00	120.00	330.51	2.11
8	8	7	8	450.00	8.00	120.00	325.68	2.08
9	9	8	9	440.00	8.00	120.00	317.40	2.03
10	10	9	10	595.00	8.00	120.00	309.81	1.98
11	11	10	11	1180.00	8.00	120.00	303.60	1.94
12	12	11	12	1070.00	8.00	120.00	274.61	1.75
13	13	12	13	1185.00	8.00	120.00	258.74	1.65
14	14	13	14	1200.00	8.00	120.00	247.01	1.58
15	15	14	15	1220.00	8.00	120.00	215.37	1.37
16	16	15	16	330.00	6.00	120.00	32.12	0.36
17	17	16	17	430.00	4.00	120.00	30.74	0.79
18	18	17	18	770.00	4.00	120.00	25.91	0.66
19	19	18	19	330.00	6.00	120.00	8.43	0.10
20	20	19	20	1210.00	8.00	120.00	176.49	1.13
21	21	20	21	550.00	2.00	120.00	-7.14	-0.73
22	22	20	22	2000.00	6.00	120.00	168.36	1.91
23	23	22	23	1400.00	6.00	120.00	157.32	1.79
24	24	23	24	850.00	6.00	120.00	151.80	1.72
25	25	24	25	1150.00	6.00	120.00	144.21	1.64
26	26	25	26	1150.00	6.00	120.00	132.48	1.50
27	27	26	27	2000.00	6.00	120.00	128.34	1.46
28	28	27	28	1300.00	6.00	120.00	121.44	1.38
29	29	28	29	500.00	6.00	120.00	113.85	1.29
30	30	29	30	2600.00	6.00	120.00	33.12	0.38
31	31	5	31	500.00	6.00	120.00	13.11	0.15
32	32	31	32	450.00	6.00	120.00	12.42	0.14
33	33	32	33	440.00	6.00	120.00	11.04	0.13
34	34	11	34	400.00	6.00	120.00	13.81	0.16
35	35	34	35	1070.00	2.00	120.00	13.12	1.34
36	36	35	36	1185.00	2.00	120.00	4.15	0.42
37	37	36	37	1200.00	2.00	120.00	-4.82	-0.49
38	38	37	38	1220.00	2.00	120.00	9.57	0.98
39	39	38	39	1210.00	2.00	120.00	2.67	0.27
40	40	39	40	1210.00	2.00	120.00	-4.23	-0.43
41	41	5	41	150.00	6.00	120.00	65.18	0.74
42	101	0	101	10.00	12.00	120.00	852.87	2.42
43	102	101	102	300.00	8.00	120.00	-108.99	-0.70
44	103	1	103	600.00	8.00	120.00	517.18	3.30
45	104	103	104	400.00	6.00	120.00	-32.75	-0.37
46	105	103	105	510.00	8.00	120.00	547.17	3.49
47	106	105	106	900.00	6.00	120.00	183.90	2.09

ST. GEORGE ISLAND WATER DISTRIBUTION SYSTEM
 EXISTING FLOWS
 ONLY LARGE PUMP ON
 PEAK HOURLY FLOW WITH EXISTING ELEVATED TANK ON LINE

PIPE TABLE

q#	Input			Output			
	Pipe	UpNode	DnNode	Length ft	Diameter in	Roughness	Flow Velocity US gpm ft/sec
48	107	106	107	630.00	8.00	120.00	182.52 1.17
49	108	107	108	570.00	2.00	120.00	15.18 1.55
50	109	105	109	1174.00	8.00	120.00	341.88 2.18
51	110	109	110	1174.00	8.00	120.00	328.08 2.09
52	111	110	111	900.00	6.00	120.00	-112.14 -1.27
53	112	111	112	360.00	8.00	120.00	-154.92 -0.99
54	113	111	113	860.00	8.00	120.00	22.08 0.14
55	114	110	114	983.00	8.00	120.00	424.35 2.71
56	115	114	115	1154.00	8.00	120.00	409.86 2.62
57	116	115	116	790.00	6.00	120.00	16.56 0.19
58	117	116	117	350.00	6.00	120.00	15.87 0.18
59	118	115	118	1177.00	8.00	120.00	373.29 2.38
60	119	118	119	1222.00	8.00	120.00	354.66 2.26
61	120	119	120	800.00	6.00	120.00	21.39 0.24
62	121	120	121	840.00	6.00	120.00	13.80 0.16
63	122	121	122	600.00	6.00	120.00	11.04 0.13
64	123	119	123	1250.00	8.00	120.00	318.78 2.03
65	124	123	124	1170.00	8.00	120.00	279.45 1.78
66	125	124	125	1150.00	8.00	120.00	266.34 1.70
67	126	125	126	920.00	8.00	120.00	254.61 1.63
68	127	126	127	978.00	8.00	120.00	245.64 1.57
69	128	127	128	1323.00	8.00	120.00	237.36 1.52
70	129	128	129	1150.00	8.00	120.00	219.42 1.40
71	130	129	130	805.00	8.00	120.00	211.83 1.35
72	131	130	131	3450.00	8.00	120.00	209.76 1.34
73	132	131	132	1035.00	8.00	120.00	195.27 1.25
74	133	132	133	1150.00	8.00	120.00	187.68 1.20
75	134	133	134	690.00	8.00	120.00	180.09 1.15
76	135	134	135	690.00	8.00	120.00	178.02 1.14
77	136	135	136	1322.00	8.00	120.00	169.05 1.08
78	137	136	137	1265.00	8.00	120.00	158.70 1.01
79	138	137	138	863.00	8.00	120.00	146.97 0.94
80	139	138	139	920.00	8.00	120.00	132.48 0.85
81	140	139	140	1150.00	8.00	120.00	117.30 0.75
82	141	140	141	690.00	8.00	120.00	106.26 0.68
83	142	141	142	690.00	8.00	120.00	94.53 0.60
84	143	142	143	402.00	8.00	120.00	92.46 0.59
85	144	143	144	460.00	8.00	120.00	90.39 0.58
86	145	144	145	460.00	8.00	120.00	68.31 0.44
87	146	145	146	633.00	8.00	120.00	66.24 0.42
88	147	146	147	288.00	8.00	120.00	64.17 0.41
89	148	147	148	460.00	8.00	120.00	50.37 0.32
90	149	148	149	633.00	8.00	120.00	47.61 0.30
91	150	149	150	1150.00	8.00	120.00	36.57 0.23
92	151	150	151	748.00	8.00	120.00	33.81 0.22
93	152	151	152	288.00	8.00	120.00	30.36 0.19
94	153	152	153	690.00	8.00	120.00	27.60 0.18

ST. GEORGE ISLAND WATER DISTRIBUTION SYSTEM
 EXISTING FLOWS
 ONLY LARGE PUMP ON
 PEAK HOURLY FLOW WITH EXISTING ELEVATED TANK ON LINE

PIPE TABLE

Pipe #	Input			Output				
	Pipe	UpNode	DnNode	Length ft	Diameter in	Roughness	Flow US gpm	Velocity ft/sec
95	154	153	154	403.00	8.00	120.00	25.53	0.16
96	155	154	155	403.00	8.00	120.00	23.46	0.15
97	156	155	156	690.00	8.00	120.00	20.70	0.13
98	157	156	157	460.00	8.00	120.00	18.63	0.12
99	158	123	158	320.00	6.00	120.00	18.63	0.21
100	159	158	159	1220.00	6.00	120.00	6.21	0.07
101	401	15	19	1210.00	8.00	120.00	175.66	1.12
102	402	18	21	990.00	4.00	120.00	12.66	0.32
103	403	14	37	400.00	6.00	120.00	24.74	0.28
104	404	20	40	400.00	6.00	120.00	4.92	0.06
105	405	41	104	960.00	6.00	120.00	63.11	0.72
106	406	107	112	1358.00	8.00	120.00	166.65	1.06
107	500	500	0	2.00	12.00	120.00	0.00	0.00
108	501	501	0	2.00	12.00	120.00	852.87	2.42

DEMAND

0.69 gpm/ERU

-----><--Input-->		NODE TABLE				-----><--- Opti	
adLoss	Status	Node	Elevation	Demand	Pressure	HGL	XCoord
ft	Open		ft	US gpm	psi	ft	
0.39		0	6.00	0.00	45.85	111.92	
2.39		1	6.00	0.00	45.67	111.50	
0.16		2	6.00	6.21	44.64	109.11	
0.03		3	6.00	8.28	44.57	108.95	
0.77		4	6.00	12.42	44.55	108.92	
0.58		5	6.00	1.38	44.31	108.35	
1.39		6	6.00	6.90	44.06	107.77	
1.21		7	6.00	4.83	43.46	106.38	
1.13		8	6.00	8.28	42.93	105.17	
1.46		9	6.00	7.59	42.44	104.04	
2.79		10	6.00	6.21	41.81	102.58	
2.10		11	6.00	15.18	40.60	99.79	
2.09		12	6.00	15.87	39.69	97.68	
1.94		13	6.00	11.73	38.79	95.60	
1.53		14	6.00	6.90	37.95	93.66	
0.05		15	6.00	7.59	37.28	92.13	
0.43		16	6.00	1.38	37.26	92.08	
0.56		17	6.00	4.83	37.08	91.65	
0.00		18	6.00	4.83	36.84	91.09	
1.05		19	6.00	7.59	36.83	91.09	
0.86		20	6.00	10.35	36.38	90.04	
6.45		21	6.00	5.52	36.75	90.90	
3.98		22	6.00	11.04	33.59	83.59	
2.26		23	6.00	5.52	31.86	79.61	
2.78		24	6.00	7.59	30.89	77.34	
2.38		25	6.00	11.73	29.68	74.56	
3.90		26	6.00	4.14	28.65	72.18	
2.29		27	6.00	6.90	26.96	68.28	
0.78		28	6.00	7.59	25.97	65.99	
0.41		29	6.00	80.73	25.63	65.21	
0.01		30	6.00	33.12	25.45	64.80	
0.01		31	6.00	0.69	44.30	108.33	
0.01		32	6.00	1.38	44.29	108.32	
0.01		33	6.00	11.04	44.29	108.31	
6.44		34	6.00	0.69	40.59	99.77	
0.85		35	6.00	8.97	37.81	93.33	
1.13		36	6.00	8.97	37.44	92.49	
4.10		37	6.00	10.35	37.93	93.62	
0.38		38	6.00	6.90	36.16	89.52	
0.90		39	6.00	6.90	35.99	89.14	
0.08		40	6.00	0.69	36.38	90.04	
0.02		41	6.00	2.07	44.27	108.26	
0.11		101	6.00	0.69	45.84	111.89	
3.81		102	7.00	0.00	45.45	112.00	
0.06		103	6.00	2.76	44.02	107.70	
3.59		104	6.00	30.36	44.05	107.76	
3.42		105	6.00	21.39	42.47	104.10	

DEMAND

0.69 gpm/ERU

NODE TABLE

HeadLoss	<-Input-> Status Open	Node	Elevation ft	Demand US gpm	Pressure psi	HGL ft	<--- Opti XCoord
0.58		106	6.00	1.38	40.99	100.69	
4.50		107	6.00	0.69	40.74	100.10	
3.46		108	6.00	15.18	38.79	95.61	
3.21		109	6.00	13.80	40.97	100.64	
1.37		110	6.00	15.87	39.58	97.43	
0.25		111	6.00	20.70	40.17	98.80	
0.02		112	6.00	11.73	40.28	99.05	
4.33		113	6.00	22.08	40.17	98.78	
4.76		114	6.00	14.49	37.71	93.11	
0.03		115	6.00	20.01	35.65	88.35	
0.01		116	6.00	0.69	35.63	88.31	
4.08		117	6.00	15.87	35.63	88.30	
3.86		118	6.00	18.63	33.88	84.26	
0.06		119	6.00	14.49	32.21	80.40	
0.03		120	6.00	7.59	32.18	80.35	
0.01		121	6.00	2.76	32.17	80.32	
3.24		122	6.00	11.04	32.17	80.31	
2.38		123	6.00	20.70	30.81	77.16	
2.14		124	6.00	13.11	29.78	74.79	
1.57		125	6.00	11.73	28.85	72.65	
1.56		126	6.00	8.97	28.17	71.08	
1.99		127	6.00	8.28	27.50	69.52	
1.49		128	6.00	17.94	26.64	67.53	
0.98		129	6.00	7.59	25.99	66.04	
4.12		130	6.00	2.07	25.57	65.06	
1.08		131	6.00	14.49	23.79	60.94	
1.12		132	6.00	7.59	23.32	59.86	
0.62		133	6.00	7.59	22.83	58.74	
0.61		134	6.00	2.07	22.56	58.12	
1.06		135	6.00	8.97	22.30	57.52	
0.90		136	6.00	10.35	21.84	56.46	
0.53		137	6.00	11.73	21.45	55.56	
0.47		138	6.00	14.49	21.22	55.02	
0.47		139	6.00	15.18	21.02	54.56	
0.23		140	6.00	11.04	20.82	54.09	
0.19		141	6.00	11.73	20.72	53.85	
0.11		142	6.00	2.07	20.63	53.67	
0.12		143	6.00	2.07	20.59	53.56	
0.07		144	6.00	22.08	20.54	53.44	
0.09		145	6.00	2.07	20.51	53.38	
0.04		146	6.00	2.07	20.47	53.29	
0.04		147	6.00	13.80	20.45	53.25	
0.05		148	6.00	2.76	20.44	53.21	
0.05		149	6.00	11.04	20.42	53.16	
0.03		150	6.00	2.76	20.39	53.11	
0.01		151	6.00	3.45	20.38	53.08	
0.02		152	6.00	2.76	20.38	53.07	

DEMAND

0.69 gpm/ERU

NODE TABLE

<-Input->		Input		Output			Opti
adLoss	Status	Node	Elevation	Demand	Pressure	HGL	XCoord
ft	Open		ft	US gpm	psi	ft	
0.01		153	6.00	2.07	20.37	53.05	
0.01		154	6.00	2.07	20.36	53.04	
0.01		155	6.00	2.76	20.36	53.03	
0.01		156	6.00	2.07	20.35	53.02	
0.02		157	6.00	18.63	20.35	53.01	
0.01		158	6.00	12.42	30.80	77.15	
1.04		159	6.00	6.21	30.80	77.14	
0.19		500	6.00		45.85	111.92	
0.04		501	6.00		45.85	111.92	
0.00							
0.50				961.86	20.35		
1.06							
0.00							
0.00							

INFLOW TABLE

Input		Output		Input	
Node	Pumps OpCurve	%Estimate	%Actual	Inflow US gpm	Status
102	1 PUMP1	1	0.11	-108.99	ON
501	1 PUMP2		0.89	-852.87	
500	1 PUMP3		0.00	0.00 C	

PUMP1		PUMP2		PUMP3	
<----- Input ----->		<----- Input ----->		<----- Input ----->	
Flow	Head	Flow	Head	Flow	Head
US gpm	ft	US gpm	ft	US gpm	ft
0.00	105.00	0.00	250.00	0.00	190.00
500.00	105.00	100.00	250.00	80.00	185.00
1000.00	105.00	300.00	240.00	160.00	180.00
1500.00	105.00	500.00	215.00	240.00	155.00
		650.00	185.00	320.00	120.00
		800.00	135.00	400.00	70.00
		900.00	80.00	480.00	20.00
		1000.00	0.00	490.00	0.00

CUSTOMERS
(ERU'S)

NODE NO. EX. CUST. RUN1 +DAGMT ADDL.

0	0		
1	0		
2	7		2
3	10		2
4	16		2
5	0		2
6	8		2
7	5		2
8	10		2
9	9		2
10	7		2
11	20		2
12	21		2
13	15		2
14	8		2
15	9		2
16	0		2
17	5		2
18	5		2
19	9		2
20	13		2
21	6		2
22	15		1
23	7		1
24	10		1
25	16		1
26	5		1
27	9		1
28	10		1
29	116		1
30	47		1
31	0		1
32	1		1
33	15		1
34	0		1
35	12		1
36	12		1
37	14		1
38	9		1
39	9		1
40	0		1
41	2		1
101	0		1
102	0		0
103	3		1
104	43		1
105	30		1

CUSTOMERS
(ERU'S)

NODE NO. RUN1 EX. CUST. RUN1 +DAGMT ADDL.

106	1			1
107	0			1
108	21			1
109	19			1
110	22			1
111	29			1
112	16			1
113	31			1
114	20			1
115	28			1
116	0			1
117	22			1
118	26			1
119	20			1
120	10			1
121	3			1
122	15			1
123	29			1
124	18			1
125	15	1		1
126	11	1		1
127	10	1		1
128	23	2		1
129	8	2		1
130	0	2		1
131	4	16		1
132	8	2		1
133	8	2		1
134	0	2		1
135	10	2		1
136	12	2		1
137	14	2		1
138	18	2		1
139	19	2		1
140	13	2		1
141	14	2		1
142	0	2		1
143	0	2		1
144	29	2		1
145	0	2		1
146	0	2		1
147	17	2		1
148	0	2		2
149	12	2		2
150	0	2		2
151	1	2		2
152	0	2		2

ST. GEORGE ISLAND WATER DISTRIBUTION SYSTEM
 EXISTING FLOWS
 ONLY LARGE PUMP ON
 PEAK HOURLY FLOW WITH EXISTING ELEVATED TANK ON LINE

g#	PIPE TABLE						Output	
	Pipe	UpNode	DnNode	Input Length ft	Diameter in	Roughness	Flow US gpm	Velocity ft/sec
1	1	101	1	140.00	12.00	120.00	919.80	2.61
2	2	1	2	500.00	8.00	120.00	415.71	2.65
3	3	2	3	330.00	4.00	120.00	18.20	0.46
4	4	3	4	185.00	4.00	120.00	11.20	0.29
5	5	2	5	180.00	8.00	120.00	392.61	2.51
6	6	5	6	200.00	8.00	120.00	308.70	1.97
7	7	6	7	500.00	8.00	120.00	303.10	1.93
8	8	7	8	450.00	8.00	120.00	299.60	1.91
9	9	8	9	440.00	8.00	120.00	292.60	1.87
10	10	9	10	595.00	8.00	120.00	286.30	1.83
11	11	10	11	1180.00	8.00	120.00	281.40	1.80
12	12	11	12	1070.00	8.00	120.00	255.16	1.63
13	13	12	13	1185.00	8.00	120.00	240.46	1.54
14	14	13	14	1200.00	8.00	120.00	229.96	1.47
15	15	14	15	1220.00	8.00	120.00	201.11	1.28
16	16	15	16	330.00	6.00	120.00	28.51	0.32
17	17	16	17	430.00	4.00	120.00	28.51	0.73
18	18	17	18	770.00	4.00	120.00	25.01	0.64
19	19	18	19	330.00	6.00	120.00	10.07	0.11
20	20	19	20	1210.00	8.00	120.00	170.06	1.09
21	21	20	21	550.00	2.00	120.00	-7.25	-0.74
22	22	20	22	2000.00	6.00	120.00	164.50	1.87
23	23	22	23	1400.00	6.00	120.00	154.00	1.75
24	24	23	24	850.00	6.00	120.00	149.10	1.69
25	25	24	25	1150.00	6.00	120.00	142.10	1.61
26	26	25	26	1150.00	6.00	120.00	130.90	1.49
27	27	26	27	2000.00	6.00	120.00	127.40	1.45
28	28	27	28	1300.00	6.00	120.00	121.10	1.37
29	29	28	29	500.00	6.00	120.00	114.10	1.29
30	30	29	30	2600.00	6.00	120.00	32.90	0.37
31	31	5	31	500.00	6.00	120.00	11.20	0.13
32	32	31	32	450.00	6.00	120.00	11.20	0.13
33	33	32	33	440.00	6.00	120.00	10.50	0.12
34	34	11	34	400.00	6.00	120.00	12.24	0.14
35	35	34	35	1070.00	2.00	120.00	12.24	1.25
36	36	35	36	1185.00	2.00	120.00	3.84	0.39
37	37	36	37	1200.00	2.00	120.00	-4.56	-0.47
38	38	37	38	1220.00	2.00	120.00	8.89	0.91
39	39	38	39	1210.00	2.00	120.00	2.59	0.26
40	40	39	40	1210.00	2.00	120.00	-3.71	-0.38
41	41	5	41	150.00	6.00	120.00	72.71	0.83
42	101	0	101	10.00	12.00	120.00	852.76	2.42
43	102	101	102	300.00	8.00	120.00	-67.04	-0.43
44	103	1	103	600.00	8.00	120.00	504.09	3.22
45	104	103	104	400.00	6.00	120.00	-41.21	-0.47
46	105	103	105	510.00	8.00	120.00	543.20	3.47

ST. GEORGE ISLAND WATER DISTRIBUTION SYSTEM
 EXISTING FLOWS
 ONLY LARGE PUMP ON
 PEAK HOURLY FLOW WITH EXISTING ELEVATED TANK ON LINE

PIPE TABLE

#	Input						Output	
	Pipe	UpNode	DnNode	Length ft	Diameter in	Roughness	Flow US gpm	Velocity ft/sec
7	106	105	106	900.00	6.00	120.00	181.91	2.06
8	107	106	107	630.00	8.00	120.00	181.21	1.16
9	108	107	108	570.00	2.00	120.00	14.70	1.50
0	109	105	109	1174.00	8.00	120.00	340.29	2.17
1	110	109	110	1174.00	8.00	120.00	326.99	2.09
2	111	110	111	900.00	6.00	120.00	-113.31	-1.29
3	112	111	112	360.00	8.00	120.00	-155.31	-0.99
4	113	111	113	860.00	8.00	120.00	21.70	0.14
5	114	110	114	983.00	8.00	120.00	424.90	2.71
6	115	114	115	1154.00	8.00	120.00	410.90	2.62
7	116	115	116	790.00	6.00	120.00	15.40	0.17
8	117	116	117	350.00	6.00	120.00	15.40	0.17
9	118	115	118	1177.00	8.00	120.00	375.90	2.40
0	119	118	119	1222.00	8.00	120.00	357.70	2.28
1	120	119	120	800.00	6.00	120.00	19.60	0.22
2	121	120	121	840.00	6.00	120.00	12.60	0.14
3	122	121	122	600.00	6.00	120.00	10.50	0.12
4	123	119	123	1250.00	8.00	120.00	324.10	2.07
5	124	123	124	1170.00	8.00	120.00	287.70	1.84
6	125	124	125	1150.00	8.00	120.00	275.10	1.76
7	126	125	126	920.00	8.00	120.00	262.50	1.68
8	127	126	127	978.00	8.00	120.00	252.70	1.61
9	128	127	128	1323.00	8.00	120.00	243.60	1.56
0	129	128	129	1150.00	8.00	120.00	224.70	1.43
1	130	129	130	805.00	8.00	120.00	217.00	1.39
2	131	130	131	3450.00	8.00	120.00	214.20	1.37
3	132	131	132	1035.00	8.00	120.00	199.50	1.27
4	133	132	133	1150.00	8.00	120.00	191.10	1.22
5	134	133	134	690.00	8.00	120.00	183.40	1.17
6	135	134	135	690.00	8.00	120.00	180.60	1.15
7	136	135	136	1322.00	8.00	120.00	171.50	1.09
8	137	136	137	1265.00	8.00	120.00	160.30	1.02
9	138	137	138	863.00	8.00	120.00	148.40	0.95
0	139	138	139	920.00	8.00	120.00	133.00	0.85
1	140	139	140	1150.00	8.00	120.00	117.60	0.75
2	141	140	141	690.00	8.00	120.00	105.70	0.67
3	142	141	142	690.00	8.00	120.00	93.80	0.60
4	143	142	143	402.00	8.00	120.00	91.00	0.58
5	144	143	144	460.00	8.00	120.00	88.90	0.57
6	145	144	145	460.00	8.00	120.00	65.80	0.42
7	146	145	146	633.00	8.00	120.00	63.70	0.41
8	147	146	147	288.00	8.00	120.00	60.90	0.39
9	148	147	148	460.00	8.00	120.00	46.90	0.30
0	149	148	149	633.00	8.00	120.00	44.10	0.28
1	150	149	150	1150.00	8.00	120.00	33.60	0.21
2	151	150	151	748.00	8.00	120.00	30.80	0.20

ST. GEORGE ISLAND WATER DISTRIBUTION SYSTEM
 EXISTING FLOWS
 ONLY LARGE PUMP ON
 PEAK HOURLY FLOW WITH EXISTING ELEVATED TANK ON LINE

PIPE TABLE

Pipe #	Input			Output				
	Pipe	UpNode	DnNode	Length	Diameter	Roughness	Flow	Velocity
				ft	in		US gpm	ft/sec
93	152	151	152	288.00	8.00	120.00	28.00	0.18
94	153	152	153	690.00	8.00	120.00	25.20	0.16
95	154	153	154	403.00	8.00	120.00	23.80	0.15
96	155	154	155	403.00	8.00	120.00	21.70	0.14
97	156	155	156	690.00	8.00	120.00	19.60	0.13
98	157	156	157	460.00	8.00	120.00	18.20	0.12
99	158	123	158	320.00	6.00	120.00	16.10	0.18
00	159	158	159	1220.00	6.00	120.00	4.90	0.06
01	401	15	19	1210.00	8.00	120.00	166.29	1.06
02	402	18	21	990.00	4.00	120.00	11.45	0.29
03	403	14	37	400.00	6.00	120.00	23.25	0.26
04	404	20	40	400.00	6.00	120.00	3.71	0.04
05	405	41	104	960.00	6.00	120.00	71.31	0.81
06	406	107	112	1358.00	8.00	120.00	166.51	1.06
07	500	500	0	2.00	12.00	120.00	0.00	0.00
08	501	501	0	2.00	12.00	120.00	852.76	2.42

DEMAND

0.7 gpm/ERU

NODE TABLE

<--Input-->		Input					Output		Optional	
dLoss	Status	Node	Elevation	Demand	Pressure	HGL	XCoord	YCoord		
ft	Open		ft	US gpm	psi	ft				
0.36		0	6.00	0.00	45.88	111.98				
2.12		1	6.00	0.00	45.71	111.60				
0.12		2	6.00	4.90	44.80	109.48				
0.03		3	6.00	7.00	44.74	109.36				
0.69		4	6.00	11.20	44.73	109.33				
0.49		5	6.00	0.00	44.50	108.79				
1.18		6	6.00	5.60	44.29	108.31				
1.04		7	6.00	3.50	43.78	107.13				
0.97		8	6.00	7.00	43.33	106.09				
1.26		9	6.00	6.30	42.91	105.11				
2.43		10	6.00	4.90	42.36	103.85				
1.84		11	6.00	14.00	41.31	101.42				
1.82		12	6.00	14.70	40.51	99.59				
1.70		13	6.00	10.50	39.73	97.77				
1.35		14	6.00	5.60	38.99	96.07				
0.04		15	6.00	6.30	38.41	94.72				
0.37		16	6.00	0.00	38.39	94.68				
0.52		17	6.00	3.50	38.23	94.31				
0.01		18	6.00	3.50	38.00	93.79				
0.98		19	6.00	6.30	38.00	93.78				
0.83		20	6.00	9.10	37.58	92.80				
6.18		21	6.00	4.20	37.94	93.63				
3.83		22	6.00	10.50	34.90	86.62				
2.19		23	6.00	4.90	33.25	82.80				
2.71		24	6.00	7.00	32.30	80.61				
2.33		25	6.00	11.20	31.13	77.90				
3.85		26	6.00	3.50	30.12	75.57				
2.28		27	6.00	6.30	28.45	71.72				
0.78		28	6.00	7.00	27.47	69.45				
0.41		29	6.00	81.20	27.13	68.66				
0.01		30	6.00	32.90	26.95	68.25				
0.01		31	6.00	0.00	44.50	108.78				
0.01		32	6.00	0.70	44.49	108.77				
0.01		33	6.00	10.50	44.49	108.77				
5.67		34	6.00	0.00	41.30	101.41				
0.73		35	6.00	8.40	38.85	95.75				
1.02		36	6.00	8.40	38.53	95.01				
3.57		37	6.00	9.80	38.98	96.04				
0.36		38	6.00	6.30	37.43	92.46				
0.70		39	6.00	6.30	37.27	92.10				
0.10		40	6.00	0.00	37.58	92.80				
0.02		41	6.00	1.40	44.46	108.69				
0.04		101	6.00	0.00	45.87	111.96				
3.63		102	7.00	0.00	45.45	112.00				
0.10		103	6.00	2.10	44.14	107.97				
3.55		104	6.00	30.10	44.18	108.06				

DEMAND

0.7 gpm/ERU

NODE TABLE

<-Input->		Input		Output			Optional	
adLoss	Status	Node	Elevation	Demand	Pressure	HGL	XCoord	YCoord
ft	Open		ft	US gpm	psi	ft		
3.35		105	6.00	21.00	42.61	104.42		
0.57		106	6.00	0.70	41.16	101.07		
4.24		107	6.00	0.00	40.91	100.50		
3.43		108	6.00	14.70	39.07	96.26		
3.19		109	6.00	13.30	41.12	100.99		
1.39		110	6.00	15.40	39.74	97.80		
0.25		111	6.00	20.30	40.34	99.19		
0.02		112	6.00	11.20	40.45	99.44		
4.34		113	6.00	21.70	40.34	99.18		
4.78		114	6.00	14.00	37.86	93.46		
0.03		115	6.00	19.60	35.79	88.68		
0.01		116	6.00	0.00	35.78	88.65		
4.14		117	6.00	15.40	35.77	88.64		
3.92		118	6.00	18.20	34.00	84.54		
0.05		119	6.00	14.00	32.30	80.62		
0.02		120	6.00	7.00	32.28	80.58		
0.01		121	6.00	2.10	32.27	80.55		
3.34		122	6.00	10.50	32.27	80.54		
2.51		123	6.00	20.30	30.86	77.28		
2.27		124	6.00	12.60	29.77	74.78		
1.66		125	6.00	12.60	28.79	72.51		
1.65		126	6.00	9.80	28.07	70.85		
2.08		127	6.00	9.10	27.36	69.20		
1.56		128	6.00	18.90	26.46	67.11		
1.02		129	6.00	7.70	25.78	65.56		
4.28		130	6.00	2.80	25.34	64.53		
1.13		131	6.00	14.70	23.49	60.25		
1.16		132	6.00	8.40	23.00	59.13		
0.64		133	6.00	7.70	22.50	57.97		
0.62		134	6.00	2.80	22.22	57.33		
1.09		135	6.00	9.10	21.95	56.70		
0.92		136	6.00	11.20	21.48	55.62		
0.54		137	6.00	11.90	21.08	54.70		
0.47		138	6.00	15.40	20.85	54.16		
0.47		139	6.00	15.40	20.64	53.69		
0.23		140	6.00	11.90	20.44	53.22		
0.19		141	6.00	11.90	20.34	52.98		
0.10		142	6.00	2.80	20.26	52.80		
0.11		143	6.00	2.10	20.21	52.70		
0.06		144	6.00	23.10	20.17	52.58		
0.08		145	6.00	2.10	20.14	52.52		
0.03		146	6.00	2.80	20.10	52.44		
0.03		147	6.00	14.00	20.09	52.40		
0.04		148	6.00	2.80	20.07	52.37		
0.05		149	6.00	10.50	20.05	52.33		
0.03		150	6.00	2.80	20.03	52.28		

INFLOW TABLE

Input		Output		Input	
Node	Pumps OpCurve	%Estimate	%Actual	Inflow	Status
102	1 PUMP1	1	0.07	US gpm	ON
501	1 PUMP2		0.93	-67.04	
500	1 PUMP3		0.00	-852.76	
				0.00 c	

PUMP1		PUMP2		PUMP3	
Flow	Head	Flow	Head	Flow	Head
US gpm	ft	US gpm	ft	US gpm	ft
0.00	105.00	0.00	250.00	0.00	190.00
500.00	105.00	100.00	250.00	80.00	185.00
1000.00	105.00	300.00	240.00	160.00	180.00
1500.00	105.00	500.00	215.00	240.00	155.00
		650.00	185.00	320.00	120.00
		800.00	135.00	400.00	70.00
		900.00	80.00	480.00	20.00
		1000.00	0.00	490.00	0.00

CUSTOMERS
(ERU'S)

RUN1 RUN1
NODE NO. EX. CUST. +DAGMT ADDL.

0	0
1	0
2	7
3	10
4	16
5	0
6	8
7	5
8	10
9	9
10	7
11	20
12	21
13	15
14	8
15	9
16	0
17	5
18	5
19	9
20	13
21	6
22	15
23	7
24	10
25	16
26	5
27	9
28	10
29	116
30	47
31	0
32	1
33	15
34	0
35	12
36	12
37	14
38	9
39	9
40	0
41	2
101	0
102	0
103	3
104	43

CUSTOMERS
(ERU'S)

NODE NO. EX. CUST. RUN1 +DAGMT ADDL.

105	30		
106	1		
107	0		
108	21		
109	19		
110	22		
111	29		
112	16		
113	31		
114	20		
115	28		
116	0		
117	22		
118	26		
119	20		
120	10		
121	3		
122	15		
123	29		
124	18		
125	15	1	2
126	11	1	2
127	10	1	2
128	23	2	2
129	8	2	1
130	0	2	2
131	4	16	1
132	8	2	2
133	8	2	1
134	0	2	2
135	10	2	1
136	12	2	2
137	14	2	1
138	18	2	2
139	19	2	1
140	13	2	2
141	14	2	1
142	0	2	2
143	0	2	1
144	29	2	2
145	0	2	1
146	0	2	2
147	17	2	1
148	0	2	2
149	12	2	1
150	0	2	2

CUSTOMERS
(ERU'S)

NODE NO.	EX. CUST.	RUN1 +DAGMT	RUN1 ADDL.
151	1	2	1
152	0	2	2
153	0	1	1
154	0	1	2
155	1	1	1
156	0	1	1
157	0	25	1
158	16		
159	7		
TOTAL	1168	96	50

1314

ENGINEER'S REPORT
SYSTEM CAPACITY ANALYSIS
OF THE
ST. GEORGE ISLAND UTILITY CO. LTD.
WATER DISTRIBUTION SYSTEM

Prepared For:
St. George Island Utility Co. Ltd.

Prepared By:
Baskerville-Donovan, Inc.
316 South Baylen Street, Suite 300
P.O. Box 13370
Pensacola, Florida 32591

May 1992

Kiran Killian
5/27/92

TABLE OF CONTENTS

Letter of Transmittal

- I. Introduction
- II. Existing System Overview
 - A. Supply
 - B. Treatment
 - C. Distribution
- III. Purpose and Scope
- IV. System Demand Characteristics
 - A. General
 - B. Customer Usage/History
 - C. Current Use
- V. Hydraulic Capacity Analysis
 - A. Software
 - B. Program Settings
 - C. Distribution System Node Map
 - D. Customer Demand Input
 - E. Peak Flow Period
 - F. Case Studies
- VI. Analysis Results
 - A. Existing Customers
 - B. Future Customers
 - C. Impact on Supply and Storage
- VII. Conclusions and Recommendations

EXHIBITS:

NO.	DESCRIPTION
1.	FDER Consent Order Partial Final Judgement
2.	Existing Treatment Plant Schematic
3.	May 12 Memorandum - St. George Island Utility Co., Ltd. Customer Data
4.	Flow History - Maximum Demand Months
5.	Customers By Account No.
6 A	Distribution System Key Map
6 B	Distribution System Node Map
7.	ERU Demand Calculations
8.	ERU Calculations - Commercial Accounts
9.	ERU Calculations - Covington Properties
10 - 13.	Waterworks Printouts

May 28, 1992

Mr. John Kintz
Potable Water Section Supervisor
Florida Department of Environmental Regulation
160 Governmental Center
Pensacola, Florida 32501-5794


Re: St. George Island Utility Co., Ltd.
Capacity Analysis Report
Project No. 12801.00

Dear Mr. Kintz:

Transmitted herewith for review is the above referenced report. If you have any questions regarding its contents, please do not hesitate to call.

Sincerely,

BASKERVILLE-DONOVAN, INC.



James Waddell
Project Engineer


JW/pja

I. INTRODUCTION

St. George Island Utility Company, Ltd. (Utility) is a privately owned company which provides potable water service to customers on St. George Island, Florida (SGI). The Utility is presently under consent orders with the Florida Public Service Commission (PSC) and Florida Department of Environmental Regulation (FDER) to correct cited deficiencies in the Utility Supply, Treatment, and Distribution System.

Subsequent to the FDER Consent Order, a Partial Final Judgement was rendered in the Circuit Court, Second Judicial Circuit, Franklin County, Florida, whereby the Utility was ordered to accomplish required improvements to the Utility System, and provided a schedule for their completion.

The FDER Consent Order and Partial Final Judgement are included as Exhibit 1. Baskerville-Donovan, Inc. (BDI) has been retained by the Utility to provide engineering services to accomplish a portion of the work required by the Judgement. Our scope of services presently includes design and permitting of a third raw water well and a hydraulic analysis of the Utility Distribution System to determine existing capacity and recommend improvements to increase system capacity. These items will be discussed in more detail in a later section.



VICINITY MAP

BASKERVILLE-DONOVAN, INC.

Project ST. GEORGE ISLAND WATER SYS.
 Job No. 12801.00 Index
 Date MAY 26, 1992 By JFW

Sheet 1
 of 1

II. EXISTING SYSTEM OVERVIEW

A. Supply

Raw water supply for the system is currently provided by two wells, each rated at a design capacity of 250 gpm. These wells are located on the mainland in Eastpoint, Florida and are manifolded into a transmission main along in the right-of-way of the Bryant Patton Bridge/Causeway. The transmission main discharges raw water into a ground storage tank on St. George Island (SGI) at the Utility Water Treatment Plant.

A construction permit application for a third raw water well (Well No. 3) has been submitted by BDI on behalf of the Utility to FDER and is currently under review.

From a review of the project files, it is our understanding that the capacity proposed for Well No. 3 in the Northwest Florida Water Management District (NFWMD) permits is the same as Well Nos. 1 and 2, (i.e., 250 gpm or 0.360 MGD maximum daily withdrawal, based on 24-hour flows). Well No. 3, operating in conjunction with Well Nos. 1 or 2 would yield approximately 250 gpm based on hydraulic calculations and modeling of the utility transmission main system. Calculations further show that should Well No. 3 be placed into operation alone, its pumping rate would be approximately 400 gpm. This flow rate should be permissible under the existing NFWMD permits, provided that the maximum daily withdrawal is not exceeded. Thus, the mode of operation proposed for Well No. 3

is to serve as a back-up source of supply and pump separately at a rate of 400 gpm. It will provide alternate service with Well Nos. 1 and 2 pumping together (500 gpm). Subsequently, the maximum capacity of the raw water supply system, over a 24 hour period, is approximately 0.720 MGD.

B. Treatment

Treatment facilities provided by the Utility are located on Gulf Beach Drive and consists of gravity fed tray aeration and chlorination. Storage facilities located at the plant consist of a 300,000 gal. ground storage tank and a 150,000 gal. elevated storage tank. The capacity of the primary ground storage tank will be addressed in a later section.

Finished water is supplied by a 50 hp 650 gpm primary booster pump which operates on a pressure range of 43-47 psi as determined by the static water level in the elevated tank. The elevated tank has a height of 115' (ground to overflow). smaller 20 hp 250 gpm pump is provided as back-up. A standby generator is provided as backup in case of a loss of electrical power. A schematic layout of the treatment plant is included as Exhibit 2.

The sequence of treatment is as follows.

1. Raw water pumped from the mainland is discharged into a tray aerator system located above the ground storage tank.

2. Aerated water drains into the ground storage tank.
3. Water stored in the ground storage tank is pumped by the 50 hp primary pump into the elevated tank and distribution system.
4. Disinfection occurs at two points within the system, gaseous chlorination as the supply is pumped into the Distribution System, and by a satellite chlorinator located in St. George Plantation, near the west extreme of the Distribution System.

C. Distribution

The existing Distribution System consists of a watermain ranging in diameter from 2" to 12" and extends from the Julian G. Bruce State Park West to the Bob Sikes Cut. Areas served include the original unit subdivisions of SGI, the State Park, St. George Plantation, and commercial establishments in the vicinity of Franklin Boulevard.

Installation of the Distribution System was accomplished by phased construction, primarily during 1974 - 1978. System extensions via residential subdivision construction and minor improvements by Utility forces has also occurred.

III. PURPOSE AND SCOPE

The purpose of this report is to satisfy that portion of the

Partial Final Judgement relating to the hydraulic capacity of the Utility. More specifically:

"the engineer shall develop a Certified Engineering Report along with supporting documentation in the form of system maps, calculations, records of conversations with consumers and operator, computer generated reports and other normal documentation describing the condition of this water system and its ability to properly and adequately serve additional customers. Information submitted shall include a system wide hydraulic analysis using methodology commonly accepted by the engineering community. It shall include flow conditions when the St. George Island State Park at the eastern end of the water system is at maximum occupancy and is refilling the park's water storage tanks. Also, flows shall be estimated for future growth at the Bob Sikes Cut using the maximum allowable population density based on the most dense zoning criteria available for Franklin County. This hydraulic analysis of the water system shall consider the extreme flow conditions above resulting from a peak flow period..."

It was originally ordered that the report be finalized after Well No. 3 has been operational for at least six months. However, the purpose of Well No. 3 is to serve as a backup and an alternate source of supply to Well Nos. 1 and 2. Well No. 3, while increasing the reliability of the raw water supply system, will not increase the overall capacity of the system to meet existing demand or future demands, assuming Well Nos. 1 and 2 remain in service. Therefore, it has been requested by the Utility that this Engineer's Report be submitted in advance of the timetable established by the Partial Final Judgement.

IV. SYSTEM DEMAND CHARACTERISTICS

A. General

For the purposes of this report and at the request of FDER

personnel prior to this writing, the historical information reviewed in determining the hydraulic capacity of the Utility dates back to 1988. It is our understanding that during 1988, specifically on the 4th of July holiday, total flow was approximately .517 MGD, and the system was not capable of meeting that demand.

Further, since recorded flows on SGI vary seasonally, the months of primary interest are May, July, and September. These months are coincident with the major holiday weekends of Memorial Day, 4th of July, and Labor Day, respectively, when the resident and transient population on SGI is the highest and maximum water usage is expected.

B. Customer/Usage History

From Water Usage/Customer Records provided by the Utility (See Exhibit 3), the number of customers has increased as follows:

<u>YEAR</u>	<u>NO. OF CUSTOMERS (3 MONTHS AVG.)</u>	<u>% INCREASE</u>
1988	588	--
1989	691	18%
1990	729	5%
1991	855	17%

Thus far in 1992 the number of active connection totals 896, representing a 5% increase. The subject of current Utility commitments in terms of connections will be discussed in a

later section.

Historical flow trends for the primary months compiled from monthly operating reports (See Exhibit 4) and information provided by the Utility indicate that since 1988 the following flows have occurred:

3 MONTHS AVERAGE (MAY, JULY, SEPTEMBER)			
<u>YEAR</u>	<u>ADF (MGD)</u>	<u>MDF (MGD)</u>	<u>ACTUAL PEAKING FACTOR (MDF/ADF)</u>
1988	.292	.517	1.77
1989	.263	.399	1.52
*1991	.243	.424	1.74

* 1990 Data not used due to missing and/or unreliable data, as per conversations with Utility personnel.

The above information illustrates that water usage on SGI is highly variable. These figures represent the maximum range of flows as the resident and transient population is higher. Winter flows are typically less as the resident and transient population is lower.

C. Current Use

Referring to Exhibit 5, as of April 30, 1992 there are 896 connections being served by the Utility. Additionally, there are approximately 130 presold connections in which customers

pay a minimum monthly charge, but do not receive water service. Also included in the customer count are 96 presold taps owned by Andrew Jackson Savings Bank 80 are for a private developer and 16 are for Nick's Hole Phase I Subdivision). This comprises a total customer count of 1122. It has been ordered that all customers, active as well as presold taps, be considered in the determination of the hydraulic capacity of the system.

V. HYDRAULIC CAPACITY ANALYSIS

A. Software

The software employed to perform calculations relating to the hydraulic capacity of the Utility System is Water Works- All In One PC Software, by Synex Systems Corporation. It is a Lotus 1-2-3 add-in program for the design and analysis of water pipe networks. BDI is licensed to use this software.

B. Program Settings

The following parameters have been used in the network analysis of the Utility system:

<u>Parameter</u>	<u>Units/Method</u>
Flow	GPM
Headloss coefficient	C=120 (Hazem-Williams)*
Pipe Length/Size	U.S. Units (LF/Inches dia.)

* A conservative value of the Hazem-Williams coefficient was

selected in consideration of the age of the distribution system pipe network and account for minor losses.

C. Distribution System Node Map

Following the protocol required by Waterworks, the Utility Distribution System has been reduced to a system of nodes and pipe numbers to evaluate the results of the analysis. The distribution system map, compiled from record drawings and information provided by Utility personnel, generally include pipe ~~sizes~~^{sizes} 4" dia. and larger. Some 2" in dia. line has been included where such pipes form a system loop. Dead-end pipes (all sizes) which branch from the distribution mains were not included in the analysis. Demands actually served by those dead-end pipes have been loaded on the system at nodes on the distribution main closest to their location. A distribution system node map is included as Exhibit 6 A and 6 B. 6B.

D. Customer Demand Input

Customer demand placed on the system has been input in the form of equivalent residential units (ERU). Average daily demand assumed in this report is 300 gpd/ERU. This ERU consumption is less than the normally published value of 350 gpd/ERU. However, recent flow records (See Exhibit 7) indicate a lower demand.

Commercial accounts served by the Utility have been converted to a representative number of ERU's based on average monthly flows from April through October in 1988 and 1991 (See Exhibit

8). This time period was selected to account for higher summer flows.

As referenced in section IV.C the report, the approximate number of residential connections served by the Utility (active and presold) is 1122. The number of commercial ERU's calculated is 140. Thus the total number of existing ERU's is 1,264.

E. Peak Flow Period

In the analysis of water distribution systems, the ability of the system to meet peak hourly demand is of primary importance. Peak hourly demands usually occur about three times a day.

1. Morning Peak - 6:00 - 8:00 AM.
2. Noon Peak - 11:00 - 2:00 PM.
3. Evening Peak - 5:00 - 7:00 PM.

Though actual times may vary, this peak flow period may be expected to have a normal duration of about two to three hours.

The peak hourly flow rate is obtained by multiplying average daily flow by an appropriate peaking factor. For the purposes of this report, the method of calculating the appropriate peaking factor is taken from GLUMRB, Recommended Standards For Sewage Works, 1978 edition (Ten States Standards):

$$\text{Peaking Factor PF} = \frac{18 + \sqrt{P}}{4 + \sqrt{P}}$$

where P is population in 1000's

The calculation of the peak hourly flow rate for the existing customer count (1264) is illustrated as follows:

ERU demand = 300 gpd/ERU, assuming 100 gpd.

(No. of ERU's = 1,264)

1264 ERU x 3 persons/ERU = 3,792 or 3.8 thousand persons

$$PF = \frac{18 + \sqrt{73.8}}{4 + \sqrt{73.8}} = 3.4$$

$$\text{Peak Hourly Demand} = \frac{1,264 \text{ ERU} \times 300 \text{ gpd/ERU} \times 3.4}{1440}$$

$$= 895 \text{ gpm}$$

F. Case Studies

To comply with the conditions of the Partial Final Judgement, the following flow conditions have been evaluated.

1. Existing Customers, equivalent to 1264 ERU's
 - A. Average Daily Flow Demand
 - B. Peak Hourly Flow Demand
2. Future Customers
 - A. Average daily flow demand at the end of 10 years
 - B. Peak hourly flow demand at the end of year 2, 6, and 10.

With regard to Case 2, the following growth/expansion of the system was anticipated:

1. Application of a 1.5 growth factor system wide (5% growth per year for 10 years, or 1.5 x 1122 ERU's = 560 ERU's).

2. Anticipated Development at Bob Sikes Cut -
 - * Sunny Day Development - 84 Lot Subdivision, owner George Mahr (Amended DRI and Franklin County Development Order).
 - * Covington Properties - 289 ERU's (Proposed Amendment to DRI and Franklin County Development Order (See Exhibit 9)).

VI. ANALYSIS RESULTS

A. Existing Customers

1. Average daily flow demand for existing ERU's (1264) was input into the Waterworks model with the existing elevated tank on line. The results of this simulation, included as Exhibit 10-A, indicate a total instantaneous system demand of approximately 265 gpm. Minimum system pressure, occurring at node 157 (Bob Sikes Cut) is 43 psi. Minimum system pressure on existing system is deemed acceptable to accommodate existing average daily flow demand.

2. Peak hourly flow demand for existing ERU's (1264) was input into the Waterworks model with the elevated tank and large booster pump at the treatment plant on line. The results of this simulation, included as Exhibit 10-B, indicate a total instantaneous system demand of approximately 885 gpm. The flow contribution by the large booster pump and elevated tank is 853 gpm and 32 gpm, respectively. Minimum system pressure, occurring at node 157 (Bob Sikes Cut) is approximately 25 psi.

3. This simulation was extended to evaluate the systems performance at peak hourly demand with both booster pumps and the elevated tank on line. The results of that simulation, included as Exhibit 10-C, indicate a flow contribution of 851 gpm and 341 gpm from the large and small booster pump respectively. With system demand remaining at 885 gpm, the existing elevated tank is filling at a rate of 307 gpm. Minimum system pressure remains the same.

4. The existing system was then modeled with the existing elevated tank off line, through the use of an altitude valve, and both booster pumps on. Flow contributions are 694 gpm and 191 gpm for the larger and smaller pumps, respectively. Minimum system pressures range from 55 psi at the State Park property line to 53 psi at Bob Sikes Cut. Maximum system pressure increased from 46 psi to 74 psi.

B. Future Customers

The analysis presented thus far has not evaluated the capacity of the system to handle additional ERU's. As previously mentioned, future flows must account for development at Bob Sikes Cut. A natural growth rate of 5% per year (56 ERU's) has also been added to the system over a period of 10 years (560 ERU's). This 10 year period is initiated with year one (1) being the Utility servicing its existing commitment of 1264 ERU's. The following simulations analyze growth of the system and identify the need for improvements.

1. Year two (2) peak hourly demand, which consists of existing ERU's, Sunny Day Development (84), Covington and Properties - year 1 (17), and 5% island wide growth for a total of 1,421 ERU's, was input into the Waterworks model with the existing elevated tank off line, and both pumps on. The results of this simulation, included as Exhibit 11, indicate a total instantaneous demand of approximately 980 gpm. Flow contribution by the larger and smaller pump is 740 gpm and 240 gpm, respectively. Minimum pressures at the east and west ends of the system are 48 psi and 31 psi, respectively.

2. Year three (3) through year six (6) peak hourly demand, which consists of the above ERU's plus 4 year island wide growths at 5% and Covington Properties through year 6 comprises a total of 1917 ERU's. This demand was input into the Waterworks model with the existing elevated tank off line, both pumps on-line, and a 50,000 gal. ground storage tank (new facility) located at node 155 (Bob Sikes Cut). The results of this simulation, included as Exhibit 12, indicate a total instantaneous demand of approximately 1,265 gpm. Minimum pressures at the east and west ends of the system are 40 psi and 24 psi, respectively. The ground storage tank will serve those ERU's (289) west of node 155.

3. Year seven (7) through ten (10) average daily demand, which includes the above ERU's, plus 5% growth island wide (280) for a total of 2,197 ERU's was input into the Waterworks

model with the existing elevated tank on-line, both pumps off, a new elevated storage tank at node 137 (Windjammer Village), off line for average daily flow conditions, and the ground storage tank at node 155 omitted. The results of this simulation, included as Exhibit 13 - A, indicate a total instantaneous demand of 461 gpm. Minimum system pressures at the east and west ends are 42 psi and 31 psi, respectively.

4. Year seven (7) through ten (10) peak hourly demand of 2,197 ERU's was input into the Waterworks mode with the existing elevated tank off line, both pumps on, new elevated tank at node 137 on-line, and the ground storage tank at node 155 omitted. The results of this simulation, included as Exhibit 13 B, indicate a total instantaneous demand of 1428 gpm. Minimum system pressures at the east and west ends are 38 psi and 28 psi, respectively.

C. Impact on Supply and Storage

1. Supply: The existing supply wells No. 1 and 2 in conjunction with the proposed well No. 3 are capable of pumping 500 gallons per minute for 24 hours per day. This provides a supply capacity of 720,000 gal. per day. This capacity is in excess of the average daily demand of the system of 660, 000 gal. per day in year 2002. Therefore, it is obvious that the system supply capacity is adequate.

This supply capacity in conjunction with the storage capacity discussed in the next section will be adequate to satisfy the maximum day demands in the system.

2. Storage: The existing water system storage consists of a 300,000 gal. ground storage tank with an assumed effective capacity of 250,000 gal. and a 150,000 gal. elevated tank, giving a combined storage capacity of 400,000 gal. Therefore, 300,000 gallons of additional storage will be required to satisfy the requirements of F.A.C. Rule 17-555.320 (6). This rule states that storage equal to one half maximum daily demand should be provided. This requirement disregards the effect of the pumping capacity of both the supply pumps and the distribution pumps on the storage requirement.

For a more rational determination of storage volume a study involving accurate estimation of average daily demand and maximum daily demand per ERU is necessary. Such a study is not within the scope of this report. After demands per ERU are determined more accurately, storage requirements may be estimated.

VII. CONCLUSIONS AND RECOMMENDATIONS

1. The existing water distribution system should function satisfactorily without modifications through year 1992, for all existing and committed ERU's. The system should maintain adequate pressures throughout the system under peak hourly

flow.

2. By 1994, if assumed development at Bob Sikes Cut (Sunny Day Development (MAHR) and Covington Properties - year 1) occurs along with 5% ERU growth throughout the system, system modifications will be required. These modifications include, but are not necessarily limited to installation of an altitude valve to isolate the existing elevated tank during peak flows and modification of existing pump controls to allow parallel operation of the larger and smaller booster pumps at the treatment plant. The distribution system would then have the capacity to serve 1421 ERU's

3. For years three (3) through six (6) (1995-1998) of the analysis period, it is assumed that growth at Bob Sikes Cut and island wide growth will continue. From these projections, it is concluded that 50,000 gal. ground storage tank (GST) and booster pumps should be constructed in 1995 to accommodate this demand. The location of the GST in the Waterworks model is at node 155, near Bob Sikes Cut. The distribution system would then have the capacity to serve a total of 1917 ERU's.

4. For years seven (7) through (10) of the analysis period (1999-2002), the GST at Bob Sikes Cut would be omitted from the system and a new elevated storage tank constructed near node 137 (Windjammer Village). With these improvements, the system should have the capacity to serve 2,197 ERU's.

5. In the modeling and analysis of the distribution system, the booster pumps at the treatment plant in some cases operate at points beyond their published performance curves. It is recommended that their capacity be evaluated through field flow tests. Should the pumps not adequately perform at the assumed ranges, modifications and/or replacement of the pumps may be necessary.

6. Though not specifically addressed in this report, all of the analyses presented have been based on the existing distribution pipe network. Line improvements to provide a looped system where possible would increase the reliability and performance of the system. Hydraulic capacity would not be increased by line improvements alone, but would also require some of the system modifications discussed herein.

692



Florida Department of Environmental Regulation

Northwest District • 160 Governmental Center • Pensacola, Florida 32501-5794 • 904-436-8300

Bob Martinez, Governor

Dale Twachtmann, Secretary

John Shearer, Assistant Secretary
Robert Kriegel, Deputy Assistant Secretary

NOV 20 1989

CERTIFIED, RETURN
RECEIPT REQUESTED

Mr. Gene D. Brown
St. George Island Utility Company, LTD
Post Office Box 1109
Tallahassee, Florida 32308

Dear Mr. Brown:

Enclosed is a copy of the executed Consent Order concerning the potable water facility at the St. George Island Utility Company, LTD.

Please review the document for the agreed upon actions and dates by which they are to be completed.

If you have any questions regarding this matter, please contact John Kintz at (904) 436-8380. Your continued cooperation is appreciated.

Sincerely,

Robert V. Kriegel
Deputy Assistant Secretary

RVK/jkm
Attach: Executed Consent Order
cc: Cliff McKeown
Bob Crouch
Richard Tuten

EXHIBIT 1

Received

NOV 28 1989

DER, Tallahassee
Branch Office

BEFORE THE STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL REGULATION

STATE OF FLORIDA DEPARTMENT
OF ENVIRONMENTAL REGULATION

In the Office of the
Northwest District

Complainant

vs.

OGC FILE NO: 88-1100

SAINT GEORGE ISLAND UTILITIES
COMPANY, LTD. A FLORIDA
PARTNERSHIP

Respondent.

CONSENT ORDER

This Consent Order is entered into between the State of Florida Department of Environmental Regulation (hereinafter "the Department") and Saint George Island Utilities Company Ltd. (hereinafter "Respondent").

The Department finds and Respondent admits the following:

1. The Department is the administrative agency of the State of Florida with the authority to administer and enforce the Florida Safe Drinking Water Act, Sections 403.850-403.864, Florida Statutes, and the rules promulgated thereunder in Florida Administrative Code Chapters 17-16, 17-550 and 17-555.

2. Respondent is a business in the State of Florida and a person within the meaning of Section 403.852(5), Florida Statutes.

Received

NOV 22 1989

DER, Tallahassee
Branch Office

3. Respondent owns and operates a potable water supply system (hereinafter "the system") and is the supplier of water to the residents of St. George Island. The system consists of two wells, ground storage reservoir, aerator, water distribution system and associated appurtenances. The water treatment plant is located on Gulf Beach Drive at West 2nd Street, Latitude 29°39'45"N, Longitude 84°52'05"W.

4. Respondent's system supplies drinking water for human consumption to residents of Saint George Island. The system has approximately 711 service connections used by a year-round resident population of approximately 2,488 persons.

5. On March 10, 1987, a Department inspector conducted an inspection of the Saint George Island Utilities Company Ltd. water system. Results of the inspection were forwarded to the Respondent in a Department letter dated March 20, 1987. The survey revealed numerous deficiencies including:

- A. No cross connection control program.
- B. No back up chlorinator.
- C. Operation and maintenance logs were incomplete.
- D. Insufficient chlorine residual at remote locations in the distribution system.
- E. Insufficient finished water storage.

6. On March 15, 1988, a follow up inspection was made. Results of the inspection were forwarded to Respondent in a Department letter dated March 28, 1988. The inspection revealed the following deficiencies.

ENCLOSURE

NOV 22 1989

DER. Telephone
Branch Office

- A. No cross connection control program.
- B. The back up chlorinator was not installed on line in a parallel mode with the primary chlorinator.
- C. Operation and maintenance logs were incomplete.
- D. Insufficient chlorine residual at remote locations in the distribution system.
- E. Insufficient finished water storage.

7. On October 13, 1988 a sanitary survey inspection was made. Results of the inspection were forwarded to the Respondent in a Department letter dated October 21, 1988. The survey revealed numerous deficiencies including:

- A. No cross connection control program.
- B. The back up chlorinator was inoperable.
- C. There were no operation and maintenance logs.
- D. Insufficient chlorine residual at remote locations in the distribution system.
- E. Insufficient finished water storage.
- F. The auxiliary generator did not operate in the automatic mode.
- G. Well #1 is operating at approximately 30 per cent of its normal capacity.
- H. The raw water tap at Well #1 is in poor condition.
- I. The aerator does not remove sufficient hydrogen sulfide.

8. On February 15, 1989, Department representatives met with Respondent to discuss the violations and a possible

Received

NOV 22 1989

DER, Tallahassee
Branch Office

resolution. A schedule of actions to resolve the violations was discussed and an agreeable resolution was reached.

Therefore, having reached a resolution of the matter pursuant to Florida Administrative Code Rule 17-103.110(3), the Respondent and the Department mutually agree and it is

ORDERED:

9. Within 90 days of the effective date of this Consent Order, Respondent shall establish and implement a formal cross-connection program. Respondent shall complete an audit of the system to identify the degree of hazard from potential cross-connections at such places as the wastewater treatment plants, seafood processing plants, marinas, private wells, etc. The program shall also include adequate training through an American Water Works Association (AWWA) affiliated course which shall be provided to the manager of the cross-connection control program. The manager shall inform the Department of the progress of this program by forwarding a copy of system audit and also forwarding copies of the monthly inspections made to Cliff McKeown.

10. Respondent has replaced the back up chlorinator and agrees to maintain both chlorinators in an operable condition at all times in the future.

11. Respondent has established an operation and maintenance log and updates it on a daily basis. The log shall include the following information:

Plant name, signature and certification number of the operator and maintenance person(s) attending the plant, the

Received

NOV 22 1989

DER, Tallahassee
Branch Office

specific operation and maintenance performed, test results, samples collected and major repairs made. Respondent shall insure that a copy of the operation and maintenance log is mailed along with the daily operation summary to the Department's Tallahassee Branch Office so that both are received on or before the 15th of the month following the month for which the report is made. These reports shall be continued on a monthly basis until the requirement is cancelled by the Department.

12. Respondent has obtained the services of a registered professional engineer to design and supervise construction of an elevated water storage tank and chlorine booster station. The Phase I elevated tank shall be at least 150,000 gallons capacity and of such a height as to adequately supply sufficient pressure and volume to all parts of the system's service area to support both the existing system's maximum daily demand and the maximum daily demand resulting from the additional residential connections agreed to in Paragraph 17. The Respondent further agrees to timely provide additional elevated storage (Phase II) to support the increased demand beyond that agreed to in paragraph 17.

A. Construction shall begin on the elevated storage tank on or before January 1, 1990. Construction shall be completed and the tank placed in use, by April 30, 1990.

B. Respondent has constructed a chlorine booster station. If the existing chlorine booster station is inadequate, Respondent agrees to update it so that

Received
NOV 22 1989

DER, Tallahassee
Branch Office

acceptable free chlorine residual exists throughout the system at all times.

13. Within 60 days of the effective date of this Consent Order Respondent shall repair the auxiliary generator so that when a power failure occurs, the generator will start automatically and operate the water system in order to provide at least one half of the system maximum daily demand. Respondent also agrees to exercise the generator 1 hour per week every week under full load.

✓14. On or before December 1, 1989, Respondent shall submit an application for a permit for a new potable water supply well (Well #3).

15. Respondent has replaced the raw water tap at Well #1.

IN PROCESS ✓16. On or before December 1, 1989, Respondent shall obtain the services of a registered professional engineer to evaluate the existing aerator or other treatment methodology. The aerator must be designed to remove 90% of the hydrogen sulfide present in the raw water. Construction or repair must begin and be completed within 180 days of the effective date of this Consent Order.

17. Respondent may make up to 200 equivalent residential connections until Well #3 and the Phase I elevated water storage tank (150,000 gallons) are in use. After the 200 new connections are made to the system, a certified engineering report reviewing the system's capability to handle additional connections above this number shall be provided to the Department for review. Any of the pre-paid connections that

Received

NOV 22 1989

DER, Tallahassee

are placed into service must be counted as part of the 200 connections.

18. Within 30 days after the effective date of this Consent Order, Respondent shall reimburse the Department for costs and expenses incurred in resolving this matter in the sum of \$1,220.00. The effective date of this Consent Order shall be that date of the Certification of Service which will be affixed to the signature page after execution by Respondent and the Department. Payment shall be made by cashiers' check, certified check or money order payable to the Department of Environmental Regulation and shall be sent to the Northwest District, 160 Governmental Center, Pensacola, Florida 32501-5794.

19. Within 30 days of the effective date of this Consent Order, Respondent shall make payment to the Department for settlement of the matters alleged in this Consent Order in the sum of \$3,205. Payment shall be made by cashiers' check, certified check or money order payable to the Department of Environmental Regulation and shall be sent to the Northwest District, 160 Governmental Center, Pensacola, Florida 32501-5794.

20. If any event occurs which causes delay or the reasonable likelihood of delay in the implementation of the requirements of this Consent Order. Respondent shall have the burden of proving that the delay was or will be caused by circumstances beyond the reasonable control of Respondent, and could not have been or cannot be overcome by due diligence. Upon occurrence of such event, Respondent shall promptly notify the Department orally and shall within seven (7) calendar days

Received

NOV 22 1989

DE [illegible]

notify the Department, in writing, of the anticipated length and cause of delay, the measures taken or to be taken to prevent or minimize the delay and the time table by which Respondent intends to implement these measures. If the parties can agree that the delay or anticipated delay has been or will be caused by circumstances beyond the reasonable control of Respondent, the time for performance hereunder shall be extended for a period equal to the delay resulting from such circumstances. Such agreement shall be confirmed by letter from the Department accepting or if necessary, modifying the extension request. Respondent shall adopt all reasonable measures necessary to avoid or minimize delay. Failure of Respondent to comply with the notice requirements of this paragraph shall constitute a waiver of Respondent's right to request an extension of time to complete the requirements of this Consent Order. Increased cost of performance of any of the activities set forth in this Consent Order or changed economic circumstances shall not be considered circumstances beyond the control of Respondent. A determination by the Department that the delay has been or will be caused by circumstances within the control of Respondent shall be deemed an agency action subject to the provisions of paragraph 22 of this Consent Order.

21. In the event Respondent experiences a delay which results in a waiver of Respondent's right to request an extension or in the event the Department determines that the delay has been or will be caused by circumstances within the control of Respondent or in the event Respondent fails to meet

Received

NOV 22 1989

DNR Telephone

any compliance provisions of this Consent Order, Respondent shall pay a stipulated penalty of \$100.00 for each day that the delay or non-compliance occurs.

22. In the event that Respondent disagrees with any determination made by the Department regarding Respondent's responses, duties and obligations made pursuant to this Consent Order, Respondent may file a Petition for Formal or Informal Administrative Hearing Proceeding, if Respondent objects to the Department's determination, pursuant to Section 120.57, Florida Statutes, and Chapters 17-103 and 28-5, Florida Administrative Code. The petition must conform with the requirements of Florida Administrative Code Rule 28-201, and must be received by the Department's Office of General Counsel, 2600 Blair Stone Road, Tallahassee, Florida 32301, within 21 days after receipt of notice from the Department of any determination Respondent wishes to challenge. Failure to file a petition within this time period shall constitute a waiver by Respondent of its right to request an administrative proceeding under Section 120.57, Florida Statutes. The Department's determination, upon expiration of the 21 day time period if no petition is filed, or the Department's Final Order as a result of the filing of a petition, shall be incorporated by reference into this Consent Order and made a part of it. All other aspects of the Consent Order shall remain in full force and effect at all times.

In the event Respondent seeks an administrative proceeding pursuant to this paragraph, the Department in lieu of or in addition to holding the administrative hearing may file suit to

Received
NOV 22 1989

DER, Tallahassee
Public Office

obtain judicial resolution of the issues. In the event the Department files suit pursuant to this paragraph, both parties retain their rights as set forth in this paragraph.

23. Respondent shall be publish the following notice in a newspaper of general circulation in Franklin County, Florida. The notice shall be published one time only within 14 days after execution of the Consent Order by the Department.

State of Florida Department of Environmental Regulation
Notice of Proposed Agency Action

The Department of Environmental Regulation gives notice of agency action of entering into a Consent Order with the Saint George Island Utilities Company, Ltd. pursuant to Florida Administrative Code Rule 17-103.110. The Consent Order requires the upgrading of the Saint George Island Utilities Company Ltd. potable water system; and payment of Department expenses.

The Consent Order is available for public inspection during normal business hours, 8:00 a.m. to 5:00 p.m., Monday through Friday, except legal holidays, at the Department of Environmental Regulation, 160 Governmental Center, Pensacola, Florida.

Persons whose substantial interests are affected by the above proposed agency action have a right pursuant to Section 120.57, F.S., to petition for an administrative determination (hearing) on the proposed action. The Petition must conform to the requirement of FAC Chapters 17-103 and 28-5, and must be filed (received) with the Department's Office of General Counsel, 2600 Blair Stone Road, Tallahassee, Florida 32399-2400, within 21 days of publication of this notice. Failure to file a petition within the 21 days constitutes a waiver of any right such person has to an administrative determination (hearing) pursuant to Section 120.57, F.S.

If a petition is filed, the administrative hearing process is designed to formulate agency action. Accordingly, the Department's final

Received

NOV 22 1970

DER, Tallahassee
Branch Office

action may be different from the proposed agency action. Persons whose substantial interests will be affected by a decision of the Department have the right to intervene in the proceeding. A petition for intervention must be filed pursuant to Model Rule FAC 28-5.207, at least five days before the final hearing and be filed with the Hearing Officer if one has been assigned at the Division of Administrative Hearings, Department of Administration, 2009 Apalachee Parkway, Tallahassee, Florida 32301. If no Hearing Officer has been assigned, the petition is to be filed with the Department's Office of General Counsel, 2600 Blair Stone Road, Tallahassee, Florida 32399-2400. Failure to petition to intervene within the allowed time frame constitutes a waiver of any right such person has to an administrative determination (hearing) under Section 120.57, F.S.

Respondent shall provide proof of publication to the Department within seven (7) days of publication.

24. Respondent shall allow all authorized representatives of the Department access to the property at reasonable times for the purpose of determining compliance with this Consent Order and the rules and regulations of the Department.

25. Entry of this Consent Order does not relieve Respondent of the need to comply with all applicable Federal, State and local laws, regulations, or ordinances.

26. The Department, for and in consideration of complete and timely performance by Respondent of the obligations agreed to in this Consent Order, hereby agrees to waive its right to seek judicial imposition of damages, or civil or criminal penalties for the violations outlined in this Consent Order. Respondent waives its right to a hearing or judicial review of the terms of this Consent Order.

Received

NOV 22 1989

DER, Tallahassee

27. The terms and conditions set forth in the Consent Order may be enforced in a court of competent jurisdiction pursuant to Sections 120.69 and 403.121, Florida Statutes. Failure to comply with terms of this Consent Order shall constitute a violation of Section 403.161(1)(b), Florida Statutes.

28. Respondent is fully aware that a violation of the terms of this Consent Order may subject Respondent to judicial imposition of damages, civil penalties of up to \$5,000 per offense, and criminal penalties.

29. The Department hereby expressly reserves the right to initiate appropriate legal action to prevent or prohibit the future violation of applicable statutes or the rules promulgated thereunder.

30. All plans, applications and information required by this Consent Order to be submitted to the Department shall be sent to the Water Facilities Program Administrator Northwest District Department of Environmental Regulation 160 Governmental Center, Pensacola, Florida 32501-5794.

31. No modification of the terms of this Consent Order shall be effective until reduced to writing and executed by both Respondent and the Department.

32. This Consent Order is the final action of the Department pursuant to Section 120.69, Florida Statutes, and Florida Administrative Code Rule 17-103.110(3), and it is final and effective on the date filed with the clerk of the Department unless a petition is filed in accordance with the preceding

Received

NOV 22 1990

DER, Tallahassee
Regional Office

paragraphs. Upon the timely filing of a petition this Consent Order will not be effective until further order of the Department.

FOR RESPONDENT:

Nov. 8, '89
Date

Gene D. Brown
GENE D. BROWN, General Partner of
Saint George Island Utilities
Company, Ltd.

DONE AND ENTERED this 17th day of Nov, 1989, in
Pensacola, Florida.

STATE OF FLORIDA DEPARTMENT
OF ENVIRONMENTAL REGULATION

Robert V. Kriegel
ROBERT V. KRIEGEL
Deputy Assistant Secretary

160 Governmental Center
Pensacola, Florida 32501-5794
(904) 436-8300

CERTIFICATE OF SERVICE

This is to certify that this CONSENT ORDER and all copies were mailed before the close of business on November 20, 1989 to the listed person.

FILING AND ACKNOWLEDGEMENT FILED, on this date, pursuant to § 120.52(10), Florida Statutes, with the designated Department Clerk, receipt of which is hereby acknowledged.

Alanna Caldwell
Clerk

Nov. 20 1989
Date

Received

NOV 22 1989

IN THE CIRCUIT COURT
SECOND JUDICIAL CIRCUIT
FRANKLIN COUNTY, FLORIDA

STATE OF FLORIDA DEPARTMENT
OF ENVIRONMENTAL REGULATION,

Plaintiff,

v.

Case No: 90-335

GENE D. BROWN, d/b/a SAINT
GEORGE ISLAND UTILITIES
COMPANY, and SAINT GEORGE
ISLAND UTILITIES COMPANY, LTD.,
a Florida Corporation,
Defendants.

PARTIAL FINAL JUDGMENT


THIS MATTER having come on to be heard upon the Stipulation for Entry of Partial Judgment of the parties hereto, and the Court having reviewed the pleadings, the Stipulation, and being otherwise advised in the premises, it is HEREBY ORDERED, ADJUDGED AND DECREED that:

1. The aforesaid stipulation, a copy of which is attached hereto, is APPROVED and made a part of this Partial Final Judgment, and the parties are ordered to comply therewith.
2. The Plaintiff, STATE OF FLORIDA DEPARTMENT OF ENVIRONMENTAL REGULATION, shall have and recover of the

Defendants, Gene D. Brown and SAINT GEORGE ISLAND UTILITIES COMPANY, LTD., the sum of \$4,425.00 (four thousand four hundred and twenty-five dollars), together with interest at the statutory rate until paid, as reimbursement for the Department's costs and expenses incurred to date in this case, for which let execution issue forthwith.

3. The Court retains jurisdiction to enforce the terms of this Partial Final Judgment upon petition of any of the parties, and to rule on any issues not resolved herein.

DONE AND ORDERED this 30th day of April, 1992 in Chambers, Galachicola, Franklin County, Florida.



Circuit Judge

Copies furnished to:

Richard L. Windsor, Esq.

Thomas Pelham, Esq.

Gene D. Brown, Esq.

IN THE CIRCUIT COURT
SECOND JUDICIAL CIRCUIT
FRANKLIN COUNTY, FLORIDA.

STATE OF FLORIDA DEPARTMENT
OF ENVIRONMENTAL REGULATION

Plaintiff,

vs.

Case No. 90-335

GENE D. BROWN, d/b/a SAINT
GEORGE ISLAND UTILITIES
COMPANY, and SAINT GEORGE
ISLAND UTILITIES COMPANY, LTD.,
a Florida Corporation

Defendants.

STIPULATION FOR ENTRY OF PARTIAL FINAL JUDGMENT

IT IS HEREBY stipulated and agreed by Plaintiff and Defendants that for purposes of trial the issues relating to imposition of civil penalties may be bifurcated and determined at a subsequent hearing, and that a partial judgment may be entered granting other relief sought in the complaint of the State of Florida Department of Environmental Regulation (DER), and particularly the following factual findings and injunctive relief:

FACTS

1. During the pendency of the Consent Order, OGC No. 88-1100 (hereinafter "C. O."), some progress has been made

by Defendants toward resolving the issue of an adequate cross connection control program; completion of the work already begun and certain improvements to the program will benefit the public and users of the potable water system.

2. Defendants have done some work on the water system's aerator during the pendency of the C. O.; the required goal of removal of 90% of hydrogen sulfide from the water has not yet been met.

3. Proper operation of the water system requires that a third well (not yet in existence) be completed and put into service. A second permit application for the new well was submitted to the Department in early 1992. Until the new well is completed and properly placed into service, no new connections to the system beyond the number previously agreed upon by the Defendants and the Department would be appropriate.

4. Improvements to the design and operation of the chlorination system must be made in order that the Department is assured of 100% reliability of the chlorination system and that chlorination levels are maintained at safe and adequate levels throughout the community public water system at all times.

INJUNCTIVE RELIEF

5. The Defendants shall review and improve the cross connection control program . Items required are:

a. A data sheet shall be completed by Defendants; it shall include in each instance the customer billing name, street address, control device type, serial number, installation date, and initial and subsequent test dates, service meter number, meter book page number and customer telephone number. This data compilation shall be provided to the Department and a copy provided to the court on or before June 1, 1992.

b. All presently untested control devices shall be tested on or before July 1, 1992 and the test results provided to the Department and this court.

c. All devices shall be re-tested 12 months following installation.

d. All data sheets, correspondence, test results, shut off orders and any other materials pertaining to the cross connection control program shall be submitted to the Department within 5 working days of the date such materials are generated, and filed individually. This requirement shall begin on the date of the partial judgment.

e. Each service connection with a device installed and with an initial satisfactory test shall be tested again 12 months after installation. These customers shall be notified 30 days before the end of 12 months by mail by Defendants using a format acceptable to DER. Any customer that does not provide a passing test to the water system and to DER shall be allowed 5 days to repair or replace the device and provide a passing test to the water system and to DER or service shall be discontinued until a passing test is received.

f. The Defendants shall comply fully with the water system's cross connection control program according to the policy statement previously submitted to and accepted by the Department. The court shall retain jurisdiction to make such modifications or further orders as may become necessary in this matter concerning important public health issues.

6. The Defendants shall cause the system's backup chlorinator to be connected to the water system at all times and operable in all regards. The regular and the backup chlorinator shall be interchangeable, and both shall have automatic cylinder switching devices and two chlorine gas cylinders connected to each chlorinator at all times.

Each chlorine cylinder shall be mounted on an accurate weighing scale, weighed daily, and the weight recorded on an Operation and Maintenance Log. Both chlorinators shall additionally be equipped with a loss of chlorine alarm that is both visual and audible. A chlorine leak detector shall be installed in the chlorine room. All equipment shall at all times be kept in good working order. In the event of downtime exceeding 30 days Defendants shall immediately obtain a backup device. Defendants shall adequately secure the chlorination room.

7. The Operation and Maintenance Log for the water system shall be modified to include each information heading area contained in paragraph 11 of the C.O. A Maintenance Log shall be kept up to date on each major water plant component including but not limited to each well, each water storage area, each chlorinator, each high service pump and the auxiliary generator. Copies of these logs shall be submitted to the Department on the 5th of each month following the month for which the report is made.

8. Defendants shall assure that the chlorine booster station is locked at all times. This station shall be

)

inspected daily and a separate Operation and Maintenance Log maintained on it. A loss of electrical power warning light shall be placed at the booster station and at the main water plant along with a clearly legible sign stating "POWER OFF-LOSS OF DISINFECTION CAPABILITY-PLEASE CONTACT OPERATOR AT 927-2648". These signs must have letters at least 3" high in colors contrasting the sign's background color. This station shall be continuously operated so that an adequate chlorine residual is maintained at the west end of the water distribution system.

9. Defendants shall cause the auxiliary power unit to be repaired so that the automatic startup switch and generator has 100% reliability. The automatic startup switches' electrical components shall be installed in a NEMA weather proof housing. Bars, screens or louvers shall be placed on the generator shed so that unauthorized entry will not occur. The generator will be operated under load for a least one hour each week. The operating sequence shall be started when main power to the water plant is shut off. The generator shall then start and operate the largest high service pump and one chlorinator. Any downtime exceeding 30 days shall result in purchase of and stocking of spares.

10. By July 1, 1992, Defendants shall retain an engineer registered in Florida to evaluate the existing aerator and raw water quality with respect to Hydrogen Sulfide Content. The existing aerator will be evaluated using accepted engineering practices. By August 1, 1992 a recommendation regarding repair, replacement, modification or additional treatment shall be developed and submitted to DER in the form of a complete construction permit application. Within 60 days following issuance of the permit Defendants shall complete construction and return the completed aerator to service. Beginning June 1, 1992, Defendants shall cause to be tested (at a Department of Health and Rehabilitative Services Certified Drinking Water Laboratory) samples for Hydrogen Sulfide collected from the following locations:

- 1) Each well - from the raw water tap after the well has been operated for 15 minutes;
- 2) The water treatment plant prior to aeration (may not be sampled in the aerator);
- 3) The water plant after aeration, but before chlorination;
- 4) The water plant after chlorination;
- 5) Entrance to the plantation;
- 6) West end of the distribution system;

- 7) Last tap before the chlorine booster station
- 8) First tap after the chlorine booster station
- 9) Mid point between the water plant and State Park entrance.

The sampling and testing for Hydrogen Sulfide shall be done every 2 weeks year round. Chain of Custody Sheets shall be completed on each sample point. Sample points shall not be changed without written permission from the Department. Defendant may apply for a modification to the sampling protocol, from biweekly to monthly upon a showing of a good cause.

11. By September 1, 1992, Defendants shall complete Well Number three.

12. Defendants shall retain an engineer registered in Florida to evaluate the water system. The engineer shall develop a Certified Engineering Report along with supporting documentation in the form of system maps, calculations, records of conversations with consumers and operator, computer generated reports and other normal documentation describing the condition of this water system and its ability to properly and adequately serve additional customers. Information submitted shall include a system wide hydraulic analysis using methodology commonly accepted

by the engineering community. It shall include flow conditions when the St. George Island State Park at the eastern end of the water system is at maximum occupancy and is refilling the park's water storage tanks. Also flows shall be estimated for future growth at the Bob Sikes Cut using the maximum allowable population density based on the most dense zoning criteria available for Franklin County. This hydraulic analysis of the water system shall consider the extreme flow conditions above resulting from a peak flow period. This report shall be finalized after Well Number 3 has been operational for at least 6 months. Data collection may begin before this period.

13. A Monthly Report shall hereafter be generated by Defendants and submitted to DER showing the total number of connections, number of connections with meters installed and number of connections that used water during the previous billing cycle. This report shall be submitted so as to be received by DER on the 5th of every month beginning in May 1, 1992. Defendants shall deliver meter books to DER for examination upon request, within 3 calendar days of a request for same.

14. Defendants shall remit \$4,425 to the DER by cashier's check immediately in payment of costs and

expenses incurred in investigation and resolution of this matter.

15. Defendants shall establish an escrow account for construction of Well Number 3 and improvements to the water system. Among the authorized signatures essential to the withdrawal of funds from said account shall be the Department's Northwest District Director of District Management or his designee. The amount of the account shall be no less than \$75,000. This account shall be opened in a bank within the city limits of Tallahassee, Florida and shall be titled St. George Island Utilities Co. Ltd. Water System Improvement Account. This account will be in place by May 1, 1992.

16. Defendants shall retain an engineer registered in Florida to develop a current and up to date water distribution system map. This map shall include main sizes, materials, locations, locations of services, fire hydrants, flush stands and other appurtenances. Valves and hydrants shall be numbered. Water main sections shall have a separate identification system, so as to clearly identify each section of main from a valve or hydrant. This map will be complete and submitted to DER by September 1, 1992.

By October 1, 1992, each system valve shall be marked in the field by a clearly identifiable manner. Copies of the system plans shall be delivered to; DER (2 copies), PSC, local building officials, local utilities including but not limited to cable TV, electrical and telephone companies, fire department and Plantation Homeowners Association.

17. Defendants shall develop and implement a written sampling plan establishing a procedure for all samples required by DER. The plan shall identify each water quality parameter separately, its sampling frequency, person to collect the sample, laboratory to test the sample and date the next sample is due. This sampling plan is to be submitted to DER before May 15, 1992.

18. Defendants shall construct a chain link fence with a locked gate around the water treatment plant. The fence shall be 6 feet high with an angled barbed wire top. Construction shall be complete by July 1, 1992.

19. Defendants shall increase elevated storage capacity as follows:

a. Within 60 days of the need being identified by the Department preliminary design will be finished and submitted to DER;

b. Within the 90 days following such notification funding will be available and obtained;

c. Within the following 30 days design will be finalized and a permit application submitted to the Department. Should the application be incomplete, the applicant will furnish the requested information within 30 days of the request. If the additional information is deemed by the Department to be insufficient, inadequate or not submitted, then no more connections shall be made to the water system. This includes connections that do not have a service meter installed at the time. Defendant will then within 30 days submit a statement to the Department regarding completing the application and providing a date certain when the requested information will be submitted;

d. Within 90 days following issuance of a construction permit, construction will be completed. The second elevated water storage tank will be placed in operation only after the Department receives the engineer of record certification of completion of construction and the Department has issued approval to Defendants to place the second elevated water storage tank into service.

e. Failure to comply with the above provisions will result in the number of service connections remaining at a total of 911 equivalent residential connections.

20. The court shall retain jurisdiction to grant such further relief, or to modify this partial judgment, as may be necessitated by environmental or public health exigencies.

21. This stipulation shall not be deemed an admission by any party regarding the determination of penalties, the amount and necessity of which shall be determined at a subsequent hearing.

FOR DEFENDANTS:

STATE OF FLORIDA DEPARTMENT
OF ENVIRONMENTAL REGULATION,
Plaintiff

Gene D. Brown, subject By: *Richard L. Windsor*

GENE D. BROWN
3836 Killlearn Court
Tallahassee, FL 32308

RICHARD L. WINDSOR
Assistant General Counsel
2600 Blair Stone Road
Tallahassee, FL
32399-2400

*to stipulation on it,
second regarding
personal liability
of Gene D. Brown*




EXHIBIT 2

EXISTING SUPPLY/TREATMENT SYSTEM
 ST. GEORGE ISLAND WATER SYSTEM
 FRANKLIN COUNTY, FLORIDA




EXHIBIT 2

EXISTING SUPPLY/TREATMENT SYSTEM

ST GEORGE ISLAND WATER SYSTEM
FRANKLIN COUNTY, FLORIDA

May 12, 1992

TO: Gene Brown

FROM: A. Hillis *A. Hillis*

The following is the information that James Wydell requested on Commercial Accounts from 1988 to 1991. I've included the water usage for the first four months of 1992. The Commercial Accounts are as follows:

Acct. 476 Villas of St. George
Acct. 861 Townhomes of St. George
Acct. 479 Buccaneer Inn II
Acct. 536 Buccaneer Inn I
Acct. 495 St. George Inn
Acct. 466 Happy Pelican
Acct. 474 Islander Restaurant
Acct. 468 Mini Convenience Store
Acct. 471 Sunshine Food Stores

The documentation over the past years isn't very good for determining how many customers were capable of using water. The following information should be close:

	1988	1989	* 1990	1991
May	569	691	708	850
July	617	n/a	740	854
Sept	578	n/a	739	860
AVG.	588	691	729	855

cc: James Wydell - Backsville Demos

Harv Garrett

EXHIBIT 3

VILLAS OF ST. GEORGE - ACCT. 476

OLD ACCT. 298

Water Usage ->	1988	1989	1990	1991	1992	AVERAGE
Jan	133900	145900	122200	165300	100900	133640
Feb	126600	168300	149400	49000	81000	114860
March	256200	256200	201300	141500	125200	196080
April	258700	261700	397000	182900	51400	230340
May	324100	356500	184700	114300		244900
June	401000	292700	374600	272200		335125
July	323400		333700	247000		301367
Aug	332300		299500	362800		331533
Sept	119700		149000	157400		142033
Oct	204800		110200	78000		131000
Nov	179500	100000	169800	85300		133650
Dec	105000		139500	72500		105667
Year	2765200	1581300	2630900	1928200	358500	2400195
Average	230433	225900	219242	160683	89625	200016

TOWNHOMES OF ST. GEORGE - ACCT. 861 OLD ACCT. 592

Water Usage ->	1988	1989	1990	1991	1992	AVERAGE
Jan	103000	200	188700	232700	247500	154420
Feb	120300	16500	215600	154200	51500	111620
March	0	6100	186700	43700	262800	99860
April	76700	8000	173500	97400	211600	113440
May	79100	10000	221200	172500		120700
June	59200	96000	234800	168600		139650
July	24200		141000	131190		98797
Aug	24200		165200	205600		131667
Sept	0		194700	245600		146767
Oct	0		197100	198000		131700
Nov	33200	142800	233900	259000		167225
Dec	0		195300	70200		88700
Year	519900	279600	2348300	1978690	773400	1504545
Average	43325	39943	195692	164891	193350	125379

BUCCANEER INN II - ACCT. 479

OLD ACCT. 301

Water Usage ->	1988	1989	1990	1991	1992	AVERAGE
Jan	28200	10700	48800	9200	5600	20500
Feb	80200	19200	30300	7400	7300	28880
March	47800	22400	76400	35300	26000	41580
April	30300	29400	73200	67900	25900	45340
May	72700	118200	17200	70300		69600
June	111700	52100	244300	139800		136975
July	70400		114400	113500		99433
Aug	86400		114400	11300		70700
Sept	7700		59500	50700		39300
Oct	22000		111300	37700		57000
Nov	3500	53200	82700	81900		55325
Dec	2500		21500	23600		15867
Year	563400	305200	994000	648600	64800	680500
Average	46950	43600	82833	54050	16200	56708

BUCCANEER INN I - ACCT. 536 & 10000536
(OLD ACCT. # LARGE SIDELARGE SIDESMALL SIDESMALL SIDE
Water Usage -> 1991 1992 1991 1992

	1991	1992	1991	1992	AVERAGE
Jan		2200		71700	36950
Feb		500		49400	24950
March		3600		102600	53100
April		5800		102300	54050
May					ERR
June					ERR
July					ERR
Aug					ERR
Sept					ERR
Oct					ERR
Nov	2000		1100		1550
Dec	800		45000		22900
Year	2800	12100	46100	326000	ERR
Average	1400	3025	23050	81500	ERR

ST. GEORGE INN - ACCT. 495

OLD ACCT. 315

Water Usage ->	1988	1989	1990	1991	1992	AVERAGE
Jan	32400	61900	0	33700	41400	33890
Feb	35900	39300	200	20800	32800	25800
March	46700	32000	13700	35400	53300	36220
April	54900	27400	11800	26900	69800	38160
May	90900	28400	10900	48600		44700
June	81200	19000	22100	66620		47230
July	58200		18000	39170		38457
Aug	59400		53400	49300		54033
Sept	30600		39000	63800		44467
Oct	58800		35900	44700		46467
Nov	55600	0	48000	44600		37050
Dec	39200		49200	27300		38567
Year	643800	208000	302200	500890	197300	485030
Average	53650	29714	25183	41741	49325	40419

HAPPY PELICAN - ACCT. 466

OLD ACCT. 286

Water Usage ->	1988	1989	1990	1991	1992	AVERAGE
Jan	13030	18260	14400	11700	14100	14298
Feb	19710	26690	13900	11200	14200	15719
March	32620	0	195900	22900	14300	35142
April	37840	11200	24700	23360	14000	37682
May	34070	25100	13200	18060		22392
June	46850	15200	18400	22970		25855
July	20370		12100	15860		16110
Aug	53030		279000	15800		115943
Sept	27760		10300	16600		18220
Oct	11270		9300	12600		11057
Nov	19820	17500	10700	12500		15130
Dec	17070		5700	12700		11823
Year	333440	113950	607600	196250	56600	339372
Average	27787	16279	50633	16354	14150	28281

ISLANDER RESTAURANT - ACCT. 474

OLD ACCT. 295

Water Usage ->	1988	1989	1990	1991	1992	AVERAGE
Jan	63100	29000	4700	1100	43200	28220
Feb	50500	35900	4410	15400	36300	28502
March	45500	29300	6790	51860	36000	33890
April	34600	36900	6100	46030	35000	31726
May	46900	48800	4500	49490		37423
June	45500	51900	4500	55600		39375
July	38900		3200	57290		33130
Aug	52400		3100	49800		35100
Sept	19900		1500	50700		24033
Oct	28200		1400	34600		21400
Nov	25100	151900	1400	40200		54650
Dec	17300		500	24400		14067
Year	467900	383700	42100	476470	150500	381516
Average	38992	54814	3508	39706	37625	31793

MINI CONVENIENCE STORE - ACCT. 468

OLD ACCT. 289

(OLD ACCT. #

Water Usage ->	1988	1989	1990	1991	1992	AVERAGE
Jan	37500	28000	53900	38800	65000	44640
Feb	35000	31200	47300	28000	31700	34640
March	33700	30600	41900	39000	46100	38260
April	33400	34900	43300	44820	19900	35264
May	50600	36700	37600	26040		37735
June	85200	41600	62100	34800		55925
July	44400		54300	42530		47077
Aug	45500		55100	53300		51300
Sept	17600		46500	81800		48633
Oct	23800		73200	35000		44000
Nov	21400	22400	74100	35600		38375
Dec	20600		96600	19900		45700
Year	448700	225400	685900	479590	162700	521549
Average	37392	32200	57158	39966	40675	43462

SUNSHINE FOOD STORES - ACCT. 471
 (OLD ACCT. #

OLD ACCT. 292

Water Usage ->	1988	1989	1990	1991	1992	AVERAGE
Jan	3140	13940	6400	23500	11000	11596
Feb	4540	6440	6530	36400	12000	13182
March	6130	10490	1940	32500	11800	12572
April	7620	6190	5270	18110	15400	10518
May	6530	7410	16530	24950		13855
June	10430	21030	20080	39930		22868
July	6010		3540	62750		24100
Aug	8400		0	47900		18767
Sept	13360		0	68000		27120
Oct	4120		10	53300		19143
Nov	18770	10590	9390	7000		11438
Dec	21260		9260	6400		12307
Year	110310	76090	78950	420740	50200	197465
Average	9193	10870	6579	35062	12550	16455

State Park - Account #593

AVG. VS.
1991 REVENUE

Water Usage ->	1988	1989	1990	1991	AVERAGE	DIFFERENCE	LOST
Jan	2027400	618100	226700	126400	749650	623250	\$1,040.83
Feb	294500	654800	308500	54800	326150	273350	\$456.49
March	654600	341300	435000	107600	384625	277025	\$462.63
April	79200	439900	572200	183000	318575	135575	\$226.41
May	0	843400	762200	242100	461925	219825	\$367.11
June	697300	939200	933400	295700	716400	420700	\$702.57
July	826400	553300	504700	206300	522675	316375	\$528.35
Aug	54800	606800		360000	340533		\$0.00
Sept	54800	461800		200000	238867		\$0.00
Oct	368800	588600	206500	60000	305975	245975	\$410.78
Nov	569200	728600	161000	70000	382200	221200	\$369.40
Dec	543300	442300	20900	50000	264125	243225	\$406.19
Year	6170300	7218100	4131100	1955900	5013700	2976500	\$4,970.75
Average	514192	601508	413110	162992	417808		

417808

4 yr. AVG -

EXHIBIT 4

FLOW HISTORY
MAXIMUM DEMAND MONTHS

<u>YEAR</u>	<u>MONTH</u>	<u>NO. OF CUSTOMERS</u>	<u>ADF (MGD)</u>	<u>MDF (MGD)</u>
1988	MAY	569	.265	
	JULY	617	.345	.517
	SEPT	578	.267	
1989	MAY	691	.228	
	JULY	691	.312	.399
	SEPT	691	.249	
*1991	MAY	850	.235	
	JULY	854	.289	.424
	SEPT	860	.207	

* 1990 Data not used due to missing and/or unreliable data,
as per conversations with Utility personnel.

5-6-92
JFW

RESIDENT ACCOUNT NUMBER	NAME	SERVICE ADDRESS	BOOK /SEQ	FIELD #1 DEPOSIT	FIELD #1 RATE CODE
0000001	ST. GEORGE PLANTATION OWNERS	NORTH ENTRANCE PLANTATION	1.001	0.00	R2
0000002	ST. GEORGE PLANTATION OWNERS	SOUTH ENTRANCE PLANTATION	1.003	0.00	R2
0000003	ST. GEORGE PLANTATION OWNERS	GUARD HOUSE	1.005	0.00	R1 *
0000004	JIM DUNKIN	1 OSPREY VILLAGE	1.007	0.00	R1
0000005	ROLF G. SCHERMAN	3 OSPREY VILLAGE	1.009	40.00	R1
0000006	MFG. VENTURES	4 OSPREY	1.011	40.00	R1
0000007	MFG. VENTURES	5 OSPREY	1.013	40.00	R1
0000008	RON BROWER	6 OSPREY VILLAGE	1.015	25.00	R1
0000009	CHARLES TITSHAW	11 OSPREY VILLAGE	1.017	25.00	R1
0000010	APALACHICOLA STATE BANK	14 OSPREY	1.019	40.00	R1
0000011	MFG. VENTURES	20 OSPREY	1.021	40.00	R1
0000012	STEPHEN DAY % RESORT REALTY	23 SEA DUNE VILLAGE	1.023	0.00	R1
0000013	JACK BUFORD	11B SEA DUNE VILLAGE	1.025	25.00	R1
0000014	PETER V. AMATO	21A SEA DUNE VILLAGE	1.027	0.00	R1
0000015	DARRELL FROCTOR	19A SEA DUNE VILLAGE	1.029	25.00	R1
0000016	W. E. VANCE	18A SEA DUNE VILLAGE	1.031	0.00	R1
0000017	ALICE D. COLLINS REALTY	16A SEA DUNE VILLAGE	1.033	40.00	R1
0000018	G. R. CROFTON	13A SEA DUNE VILLAGE	1.035	0.00	R1
0000019	TOM TIFFIN	10A SEA DUNE VILLAGE	1.037	0.00	R1
0000020	DAVID V. KERNIS	9A SEA DUNE VILLAGE	1.039	0.00	R1
0000021	TOM W. HOFFER	7A SEA DUNE VILLAGE	1.041	0.00	R1
0000022	ERNE BOWERS	6B SEA DUNE VILLAGE	1.043	25.00	R1
0000023	BOB WILGUS	5B SEA DUNE VILLAGE	1.045	0.00	R1
0000024	GERALD A. BUTTERFIELD	5A SEA DUNE VILLAGE	1.047	0.00	R1
0000025	WILLIAM DODD	1B SEA DUNE VILLAGE	1.049	0.00	R1
0000026	DIANE CHASTAIN	11 BAY PINE VILLAGE	1.051	25.00	R1
0000027	ED MINGLEDORFF	10 BAY PINE VILLAGE	1.054	0.00	R1
0000028	NORMAN FEETS	20 SEA PINE VILLAGE	1.056	0.00	R1
0000029	DOROTHY PONDY	21 SEA PINE VILLAGE	1.057	25.00	R1
0000030	WILLIAM R. ELLINGTON	33 SEA PINE VILLAGE	1.059	0.00	R1
0000031	DON BOYD	25 SEA PINE VILLAGE	1.061	0.00	R1
0000032	TILLET/WRIGHT	27 SEA PINE VILLAGE	1.063	25.00	R1
0000033	LARRY JOHNSTON	28 SEA PINE VILLAGE	1.065	0.00	R1
0000034	RICHARD FELHAM	29 SEA PINE VILLAGE	1.067	0.00	R1
0000035	THOMAS COLLINS	16 SEA PIN VILLAGE	1.069	0.00	R1
0000036	WILLIAM SOLEBURG	10 BAY PALM VILLAGE	1.071	0.00	R1
0000037	GEORGE F. BAILEY	5 BAY PALM	1.073	0.00	R1
0000038	JULIA CRAWFORD	6 BAY PALM VILLAGE	1.075	0.00	R1*
0000039	JOHN E. BENTE	2 SEA PALM VILLAGE	1.077	25.00	R1
0000040	NICK LASLAVIC	6 SEA PALM VILLAGE	1.079	0.00	R1
0000041	LEE KNOWLES	15 SEA PALM VILLAGE	1.081	0.00	R1
0000042	GUY MARSH	20 SEA PALM VILLAGE	1.083	25.00	R1
0000043	WILLIAM R. CLARK, JR.	33 SEA PALM VILLAGE	1.085	0.00	R1
0000044	DENNIS HOWE	27 SEA PALM VILLAGE	1.087	0.00	R1
0000045	JOHN P. DOODS	29 SEA PALM VILLAGE	1.089	0.00	R1
0000046	CINDY STOCK	30 SEA PALM VILLAGE	1.091	25.00	R1
0000047	HAMPTON DEWS	70 SEA PALM VILLAGE	1.093	0.00	R1
0000048	HARRY A BUZZETT	40 SEA PALM VILLAGE	1.095	25.00	R1
0000049	T. A. FIELD	44 SEA PALM VILLAGE	1.097	0.00	R1
0000050	SUNCOAST REALTY	45 SEA PALM VILLAGE	1.099	0.00	R1

RESIDENT ACCOUNT NUMBER	NAME	SERVICE ADDRESS	BOOK /SEQ	FIELD #1 DEPOSIT	FIELD #1 RATE CODE
000051	WILLIAM M. SHORT	54 SEA PALM VILLAGE	1.101	0.00	R1
000052	PHILIP H. WELLS	54 SEA PALM VILLAGE	1.103	0.00	R1
000053	CHARLES RITTER	56 SEA PALM VILLAGE	1.105	0.00	R1
000054	TOM ADAMS	58 SEA PALM VILLAGE	1.107	25.00	R1
000055	BILL DEYD, JR.	60 SEA PALM VILLAGE	1.109	25.00	R1
000056	DR. K. S. SERAI	20 BAY PALM VILLAGE	1.111	0.00	R1
000057	MARTIN J. WILLIAMS	19 BAY PALM VILLAGE	1.113	25.00	R1 X
000058	FELICAN POINT HOMEOWNERS	FELICAN POINT TENNIS CT.	1.115	0.00	R1
000059	WALTER ARMISTEAD	14 FELICAN POINT	1.117	47.78	R1
000060	TIDAL INVESTMENTS	17 FELICAN POINT	1.119	0.00	R1
000061	WILDER PROPERTIES, INC.	NICK'S HOLE ENTRANCE	1.121	0.00	R2 X
000062	PHIL B. WHITAKER	3 & 4 NICK'S HOLE	1.123	0.00	R2 X
000063	T. E. ALLEN III	LOT 3 NICK'S HOLE	1.125	0.00	R1 X
000064	DR. WINSTON BALL	19 SANDPIPER VILLAGE	1.127	0.00	R1
000065	WILLIAM POLORONIS	5 PEBBLE BEACH VILLAGE	1.129	0.00	R1
000066	AMALIA F. READ	8 PEBBLE BEACH VILLAGE	1.131	0.00	R1
000067	JOSIE DAVIS	9 PEBBLE BEACH VILLAGE	1.135	25.00	R1
000068	MARK BALDINO	11 PEBBLE BEACH VILLAGE	1.137	0.00	R1
000069	LEONARD PEPPER	12 PEBBLE BEACH VILLAGE	1.139	0.00	R1
000070	PHILLIP M. FAYNE III	21 SANDPIPER VILLAGE	1.142	0.00	R1
000071	R. FUNK 1202 KILDONAN DR.	24 SANDPIPER VILLAGE	1.143	25.00	R1
000072	TOM TIFFIN	28 SANDPIPER VILLAGE	1.145	0.00	R1
000073	THOMAS DAY	30 SANDPIPER VILLAGE	1.147	0.00	R1
000074	LEONARD J. GRUBBS	34 SANDPIPER VILLAGE	1.149	0.00	R1
000075	DAHLEN RITCHEY	50 PEBBLE BEACH VILLAGE	1.151	0.00	R1
000076	DOROTHY SLASHT	51 PEBBLE BEACH VILLAGE	1.153	0.00	R1
000077	TERRA INC.	52 PEBBLE BEACH VILLAGE	1.155	0.00	R1
000078	WILLIAM KRUEGER	55 PEBBLE BEACH VILLAGE	1.157	25.00	R1
000079	VERA ANN RECHSTEINER	11 WINDJAMMER VILLAGE	1.159	0.00	R1
000080	WOODY MILEY	3 WINDJAMMER VILLAGE	1.161	25.00	R1
000081	WILLIAM F. LANGDALE, JR.	7 WINDJAMMER VILLAGE	1.163	0.00	R1
000082	GEORGE KLEINE	6 WINDJAMMER VILLAGE	1.165	0.00	R1
000083	JOHN SPOHRER	74 PEBBLE BEACH VILLAGE	1.167	0.00	R1
000084	GWEN HENKEL	65 PEBBLE BEACH VILLAGE	1.169	25.00	R1
000085	J. B. RODDENBERY, JR.	68 PEBBLE BEACH VILLAGE	1.171	25.00	R1
000086	MATTHEW MORGAN	67 PEBBLE BEACH VILLAGE	1.173	0.00	R1
000087	FAM MILLER	71 PEBBLE BEACH VILLAGE	1.175	0.00	R1 X
000088	GIL TROUTMAN	4 TURTLE BEACH VILLAGE	1.177	25.00	R1
000089	MATTHEW MORGAN	5 TURTLE BEACH VILLAGE	1.179	0.00	R1
000090	JON CAMINEZ	8 TURTLE BEACH VILLAGE	1.181	0.00	R1
000091	KIM CHMYUNG-HI	9 TURTLE BEACH VILLAGE	1.183	0.00	R1
000092	JOANNE SOBERAY	10 TURTLE BEACH VILLAGE	1.185	0.00	R1 X
000093	JERRY HENDERSON	25 WINDJAMMER VILLAGE	1.187	0.00	R1
000094	MASON BEAN	17 WINDJAMMER VILLAGE	1.189	0.00	R1
000095	ERIC LOEVINGER	19 TURTLE BEACH VILLAGE	1.191	25.00	R1
000096	SIVASAILAM THIAGARAJAN	32 TURTLE BEACH VILLAGE	1.193	0.00	R1
000097	EVE MORRIS	42 TURTLE BEACH VILLAGE	1.195	0.00	R1
000098	RAY SOLOMON	35 TURTLE BEACH VILLAGE	1.197	25.00	R1
000099	JERRY HOLMES	37 TURTLE BEACH VILLAGE	1.199	0.00	R1
00100	R. M. SILER	33 TURTLE BEACH VILLAGE	1.201	25.00	R1

RESIDENT ACCOUNT NUMBER	NAME	SERVICE ADDRESS	BOOK /SEQ	FIELD #1 DEPOSIT	FIELD #1 RATE CODE
000101	ANCHOR REALTY & MTG.	39 TURTLE BEACH VILLAGE	1.203	0.00	R1
0102	GARY ULRICH	40 WINDJAMMER VILLAGE	1.205	0.00	R1
0103	LES BLOOM	38 WINDJAMMER VILLAGE	1.207	0.00	R1
000104	DELAND/NOELL	36 TURTLE BEACH VILLAGE	1.209	0.00	R1
0105	LARRY HALE	35 WINDJAMMER VILLAGE	1.211	0.00	R1
0106	CHARLES M. DORN	57 TURTLE BEACH VILLAGE	1.213	0.00	R1
000107	ZEK BARDHI	47 TURTLE BEACH VILLAGE	1.215	25.00	R1
000108	ST. GEORGE PLANTATION OWNERS	48 TURTLE BEACH/RONDESIC	1.217	0.00	R1
0109	ST. GEORGE PLANTATION OWNERS	48 TURTLE CLUBHOUSE/POOL	1.219	0.00	R4 X
0110	JACK BUFORD (JULIUS)	49 TURTLE BEACH VILLAGE	1.221	0.00	R1
000111	J. J. GLEATON	50 TURTLE BEACH VILLAGE	1.223	0.00	R1
0112	AARON TAYLOR	51 TURTLE BEACH VILLAGE	1.225	25.00	R1
0113	RICHARD PLESSINGER	53 TURTLE BEACH VILLAGE	1.227	0.00	R1
000114	HELDO CO. C/O ROBERT LINK	4 BAY VIEW VILLAGE	1.229	0.00	R1
0115	CLARK BLOODWORTH	5 BAY VIEW VILLAGE	1.231	25.00	R1
0116	MFG. VENTURES	65 PLANTATION BEACH VILL.	1.233	40.00	R1
000117	KATHY FROELICH	38 PLANTATION BEACH VILL.	1.235	0.00	R1 X
000118	GEORGE LEWIS	32 PLANTATION BEACH VILL.	1.237	0.00	R1 X
0119	DAVID JASIN	34 PLANTATION BEACH VILL.	1.239	0.00	R1 X
0120	ROY PLAUT, JR.	1 PLANTATION BEACH VILL.	1.241	25.00	R1
000121	MIKE & GEENA FIRST	2 PLANTATION BEACH VILL.	1.243	0.00	R1
0122	JOHN WIGHT	4 PLANTATION BEACH VILL.	1.245	0.00	R1
0123	JAMES TUNNELL	6 PLANTATION BEACH VILL.	1.247	0.00	R1
000124	CHARLES L. BOND	5 PLANTATION BEACH VILL.	1.249	0.00	R1
000125	JOHN CADDELL	8 PLANTATION BEACH VILL.	1.251	0.00	R2
0126	ELLIS C. SMITH	27 PLANTATION BEACH VILL.	1.253	0.00	R1
000127	SUSAN BOYD	28 PLANTATION BEACH VILL.	1.255	0.00	R1
000128	JAMES MCCONNAUGHAY	29 PLANTATION BEACH VILL.	1.257	25.00	R1
0129	AUGUST FONTAINE	42 PLANTATION BEACH VILL.	1.259	0.00	R1
0130	MFG. VENTURES	58 PLANTATION BEACH VILL.	1.261	40.00	R1
000131	VIVIAN KADIS	23 PLANTATION BEACH VILL.	1.263	0.00	R1
0132	VAN REED	26 PLANTATION BEACH VILL.	1.265	0.00	R1
0133	GREGORY SULLIVAN	12 PLANTATION BEACH VILL.	1.267	0.00	R1
000134	DAWN G. MURPHY	14 PLANTATION BEACH VILL.	1.269	0.00	R1
0135	HARRY L. TUCKER	15 PLANTATION BEACH VILL.	1.271	0.00	
0136	HARRY TUCKER	16 PLANTATION BEACH VILL.	1.273	25.00	R1
000137	OLIVIER MONOD	19 PLANTATION BEACH VILL.	1.275	0.00	R1
000138	ROBERT WILKINSON	20 PLANTATION BEACH VILL.	1.277	25.00	R1
0139	LYNN WILSON	22 PLANTATION BEACH VILL.	1.279	25.00	R1
0140	ROBERT WILKINSON	47 PLANTATION BEACH VILL.	1.281	0.00	R1
000141	MFG. VENTURES	52 PLANTATION BEACH VILL.	1.283	40.00	R1
0142	MICHAEL A. BELL	54 PLANTATION BEACH VILL.	1.285	25.00	R1
0143	JOSEPH A. D'ATELLO	55 PLANTATION BEACH VILL.	1.287	0.00	R1
000144	ST. GEORGE ISLAND INVESTORS	25 BAY VIEW VILLAGE	1.289	0.00	R1
000145	CAIRO INGRAM	24 BAY VIEW VILLAGE	1.291	0.00	R1
0146	JOANNE SOBERAY	23 BAY VIEW VILLAGE	1.293	0.00	R1
000147	JOSEPH LUENSCHLOSS	21 BAY VIEW VILLAGE	1.295	25.00	R1
000148	RUSSELL D. HUNTER	19 BAY VIEW VILLAGE	1.297	40.00	R1
0149	JAMES TUNNELL	4 INDIAN BAY VILLAGE	1.299	0.00	R1
0150	SONNY MARSHALL	9 INDIAN BAY VILLAGE	1.302	25.00	R1

RESIDENT ACCOUNT NUMBER	NAME	SERVICE ADDRESS	BOOK /SEQ	FIELD #1 DEPOSIT	FIELD #1 RATE CODE
000151	PATRICK ROFFEY	32 TREASURE BEACH VILLAGE	1 304	25.00	R1
000152	GERHARD SOMMER	33 TREASURE BEACH VILLAGE	1 305	0.00	R1
000153	ROBERT WILKINSON	1 TREASURE BEACH VILLAGE	1 307	0.00	R1
000154	R. C. BALFOUR III	4 TREASURE BEACH VILLAGE	1 309	0.00	R1
000155	JAMES R. SULLIVAN	5 TREASURE BEACH VILLAGE	1 311	25.00	R1
000156	TOM FITZGERLAD	6 TREASURE BEACH VILLAGE	1 313	0.00	R1
000157	ANDREW RALPH HARWOOD	8 TREASURE BEACH VILLAGE	1 315	0.00	R1
000158	WILLIAM KESSLER	17 INDIAN BAY VILLAGE	1 317	0.00	R1
000159	ALEX MEYER	13 INDIAN BAY VILLAGE	1 319	0.00	R1
000160	LEO A. SMITH	19 INDIAN BAY VILLAGE	1 321	0.00	R1
000161	RAY STANYARD	46 TREASURE BEACH VILLAGE	1 323	25.00	R1
000162	MFG. VENTURES	48 TREASURE BEACH VILLAGE	1 325	40.00	R1
000163	WICKHAM R. CARTER III	24 TREASURE BEACH VILLAGE	1 327	40.00	R1x
000164	JERRY DEMERY	25 TREASURE BEACH VILLAGE	1 329	25.00	R1x
000165	GARY GUELZOW C/O ANCHOR REALTY	26 TREASURE BEACH VILLAGE	1 331	40.00	R1x
000166	E&S PARISH C/O ANCHOR REALTY	12 TREASURE BEACH VILLAGE	1 334	40.00	R1
000167	JOSEPHINE B. MOORE	13 TREASURE BEACH VILLAGE	1 335	0.00	R1
000168	SEA GULL ASS C/O ANCHOR REALTY	14 TREASURE BEACH VILLAGE	1 337	40.00	R1
000169	MILTON H. BEVIS	15 TREASURE BEACH VILLAGE	1 339	0.00	R1
000170	EUGENE HUNTER	17 TREASURE BEACH VILLAGE	1 341	0.00	R1
000171	RICHARD KOWALSKI	18 TREASURE BEACH VILLAGE	1 343	0.00	R1
000172	GEROME W. KOWALSKI	28 INDIAN BAY VILLAGE	1 345	25.00	R1
000173	JOHN STRICKLAND	24 INDIAN BAY VILLAGE	1 347	0.00	R1
000174	REGINAL EYE	27 INDIAN BAY VILLAGE	1 349	0.00	R1
000175	JAMES H. GREEN	58 PELICAN BEACH VILLAGE	1 351	25.00	R1
000176	GUSTKE, BLUSIEWICZ, DONLEY	57 PELICAN BEACH VILLAGE	1 353	40.00	R1
000177	MICHAEL R. BRITTON	55 PELICAN BEACH VILLAGE	1 355	0.00	R1
000178	DONALD PFAENDER	1 PELICAN BEACH VILLAGE	1 357	25.00	R1
000179	ROBERT WILKINSON	37 PELICAN BEACH VILLAGE	1 359	0.00	R1
000180	CHARLES E. HAWKINS	31 PELICAN BEACH VILLAGE	1 361	25.00	R1x
000181	JOHN HANES	2 PELICAN BEACH VILLAGE	1 363	0.00	R1
000182	DAVID MOORE	5 PELICAN BEACH VILLAGE	1 365	0.00	R1
000183	RICHARD A. BURMAN	29 PELICAN BEACH VILLAGE	1 368	0.00	R1
000184	RUTH O'DONNELL	10/1/2	5 126	40.00	R1
000185	MFG. VENTURES	3 BAY COVE VILLAGE	1 371	40.00	R1
000186	JAMES KENT, JR.	4 BAY COVE VILLAGE	1 373	0.00	R1
000187	R. O. PERSONS, JR.	7 BAY COVE VILLAGE	1 375	0.00	R1
000188	BRUCE KRUEGER	31 BAY COVE VILLAGE	1 377	0.00	R1
000189	BILLY G. BLACKBURN, JR.	53 PELICAN BEACH VILLAGE	1 379	25.00	R1x
000190	JOSEPH B. BURGESS	48 PELICAN BEACH VILLAGE	1 381	0.00	R1
000191	ISHMAEL H. JOHNSON, JR.	50 PELICAN BEACH VILLAGE	1 383	0.00	R1
000192	ROBERT WILKINSON	43 PELICAN BEACH VILLAGE	1 385	0.00	R1
000193	GENE BELANGER	23 PELICAN BEACH VILLAGE	1 387	0.00	R1
000194	RODERICK & KATHERINE DAVIS, III	13 PELICAN BEACH VILLAGE	1 389	40.00	R1
000195	RICHARD BURMAN	14 PELICAN BEACH VILLAGE	1 391	0.00	R1
000196	WILLIAM G. THAMES	15 PELICAN BEACH VILLAGE	1 393	0.00	R1
000197	TERRELL C. TEMPLIN	16 PELICAN BEACH VILLAGE	1 395	25.00	R1
000198	GEORGE HORNEL	20 PELICAN BEACH VILLAGE	1 397	0.00	R1x
000199	SHIRLEY HUGHES	22 PELICAN BEACH VILLAGE	1 399	40.00	R1x
000200	THOMAS L. OUTLAW	26 BAY COVE VILLAGE	1 401	0.00	R1

CUSTOMERS BY ACCOUNT NUMBER

04/30/92

ACCOUNT NUMBER	ESTDENT NAME	SERVICE ADDRESS	BOOK /SEQ	FIELD #1 DEPOSIT	FIELD #1 RATE CODE
000201	LARRY C. STRONGOSKI	19 BAY COVE VILLAGE	1.403	0.00	R1
000202	GENE BELANGER	29 DOLPHIN BEACH VILLAGE	1.405	0.00	R1
000203	CARMEN FIGUEROA	41 DOLPHIN BEACH VILLAGE	1.407	0.00	R1
000204	HERMAN W. LAYFIELD	40 DOLPHIN BEACH VILLAGE	1.409	0.00	R1
000205	WILLIAM E. SWAB	39 DOLPHIN BEACH VILLAGE	1.411	0.00	R1
000206	JIM EGGERS	8 DOLPHIN BEACH VILLAGE	1.413	0.00	R1 X
000207	ROBERT W. MCILLAN	29 DOLPHIN BEACH VILLAGE	1.415	25.00	R1
000208	RICK LUDWIG	30 DOLPHIN BEACH VILLAGE	1.417	25.00	R1 X
000209	HOWARD BERLINER C/O ANCHOR REA	31 DOLPHIN BEACH VILLAGE	1.419	40.00	R1 X
000210	CLARENCE KNIGHT	7 DOLPHIN BEACH VILLAGE	1.421	0.00	R1
000211	PHILLIP R. LUBBERS	8 DOLPHIN BEACH VILLAGE	1.423	0.00	R1
000212	JAMES MOORE	25 DOLPHIN BEACH VILLAGE	1.425	0.00	R1
000213	DANIEL Y. SUMNER	26 DOLPHIN BEACH VILLAGE	1.427	0.00	R1
000214	GLEN WOODSUM	27 DOLPHIN BEACH VILLAGE	1.429	0.00	R1
000215	STEVEN D. WARREN	21 BAY COVE VILLAGE	1.431	0.00	R1
000216	ROGER BERNOT	13 DOLPHIN BEACH VILLAGE	1.433	0.00	R1
000217	RONALD F. VALENTINE	10 DOLPHIN BEACH VILLAGE	1.435	0.00	R1
000218	JERRY OSTERYOUNG	20 DOLPHIN BEACH VILLAGE	1.437	25.00	R1
000219	ROBERT E. HAILS	12 DOLPHIN BEACH VILLAGE	1.439	0.00	R1
000220	FLOYD LEWELLYN	14 DOLPHIN BEACH VILLAGE	1.441	0.00	R1 X
000221	C. DON SIMMONS	23 DOLPHIN BEACH VILLAGE	1.443	0.00	R1
000222	FRANK SANCHEZ	19 DOLPHIN BEACH VILLAGE	1.445	0.00	R1
000223	CHUCK ELVER	20 HERON BAY VILLAGE	1.447	0.00	R1
000224	MARY FLOWERS	17 DOLPHIN BEACH VILLAGE	1.449	25.00	R1
000225	THOMAS H. TOWNSON	21 DOLPHIN BEACH VILLAGE	1.451	40.00	R1
000226	B. L. COSEY	10 OYSTER BAY VILLAGE	1.453	0.00	R1 X
000227	JOSEPHINE MOORE	74 SEA PALM VILLAGE	1.455	0.00	R1
000228	7 FLAGS DEVELOPMENT CORP.	45 PELICAN BEACH VILLAGE	1.380	40.00	R1
000229	ELDEN W. BUTZBAUGH, JR.	11 DOLPHIN BEACH VILLAGE	1.434	25.00	R1
000230	JAMES TARRER	16/83/5	2.001	55.84	R1 X
000231	KENNETH COLLINS	1/83/5	2.004	25.00	R1
000232	WILLIAM SANDERS	4/83/5	2.005	0.00	R1
000233	JOSEPH FOGST	1/90/5	2.007	0.00	R1 X
000234	EDNA G. ROLLINS	2/90/5	2.009	0.00	R1
000235	CLEVE RANDOLPH	18/83/5	2.011	0.00	R1
000236	BUDDY FREDERICK	19/83/5	2.013	23.94	R1
000237	RALLS JENNINGS	20/83/5	2.015	25.00	R1
000238	FRED LAWHON	22/83/5	2.017	25.00	R1
000239	MARCUS WAGER	29/87/5	2.019	53.10	R1
000240	DEBORAH DAVIS	24/87/5	2.021	0.00	R1
000241	MARILYN WALKER	19/83/5	2.023	0.00	R1 X
000242	GLENN FRICKETT	9/90/5	2.025	25.00	R1
000243	ROBERT C. ABBEY	13/87/5	2.027	25.00	R1 X
000244	TINA SHIVER	24/86/5	2.029	0.00	R1
000245	LEE EDMISTON	7/87/5	2.031	0.00	R1
000246	DON HAMMOCK	30/86/5	2.033	0.00	R1
000247	LARRY TROY	32/86/5	2.035	25.00	R1
000248	RAYMOND BANKS	1/87/5	2.037	0.00	R1
000249	JAMES ABBOTT	1/81/5	2.039	0.00	R1
000250	JEANNE WRAY	2/81/5	2.041	46.58	R1

RESIDENT ACCOUNT NUMBER	NAME	SERVICE ADDRESS	BOOK /SEQ	FIELD #1 DEPOSIT	FIELD #1 RATE CODE
0000251	JOHN ANDREWS	2/86/5	2.043	59.42	R1
0000252	THOMAS GROGS	3/86/5	2.045	0.00	R1
0000253	HERBERT M JENKINS	21/85/5	2.046	0.00	R1
0000254	WILLIAM F. MITCHELL	4/83/5	2.049	25.00	R1
0000255	GARY L. PONTIUS	14/85/5	2.051	0.00	R1
0000256	ANCHOR REALTY	1/82/5	2.053	0.00	R1
0000257	JOHN RAFNEL	13/85/5	2.055	0.00	R1
0000258	BILLY J. HICKS	27/78/5	2.057	25.00	R1
0000259	GAIL HERZICH	10/85/5	2.059	40.00	R1
0000260	WILLIAM BENDA	3/85/5	2.061	0.00	R1
0000261	PRIMARY CARE, INC.	6/81/5	2.063	0.00	R1
0000262	GEORGE CRUM	3/81/5	2.065	25.00	R1
0000263	SKIP SHIVER	3/78/5	2.067	0.00	R1
0000264	ALMA GARRETT	1/76/5	2.069	25.00	R1
0000265	E. W. TEAGUE	2/76/5	2.071	25.00	R1
0000266	THOMAS H. BLAYDEE	4/76/5	2.073	0.00	R1
0000267	KENNETH W. ENDICOTT	5/76/5	2.075	0.00	R1
0000268	WILLIAM ROGERS	6/76/5	2.077	0.00	R1
0000269	VIRGINIA C. HOLMES	4/77/5	2.079	25.00	R1
0000270	ROBERT HOUD	9/76/5	2.081	40.00	R1
0000271	DONALD HARTSFIELD	12/76/5	2.083	0.00	R1
0000272	NELLE LANDRUM	13/76/5	2.085	25.00	R1
0000273	HARRY LANDRUM	14/76/5	2.088	0.00	R1
0000274	INGA JENSEN	15/76/5	2.089	0.00	R1
0000275	MARTY BLAINE	12/78/5	2.091	0.00	R1
0000276	ROBERT CARTER	11/78/5	2.093	0.00	R1
0000277	SANDRA WALKER	7/77/5	2.095	0.00	R1
0000278	HAROLD HAGHENBECK	13/78/5	2.100	40.00	R1
0000279	GERRIT MULDEERS	16/76/5	2.099	25.00	R1
0000280	CHRIS CROZIER	13/76/5	2.101	34.04	R1
0000281	JAMES E. SELLERS	14/78/5	2.103	0.00	R1
0000282	NEIL LAWS	5/79/5	2.105	0.00	R1
0000283	H. W. MCCALL	20/78/5	2.107	25.00	R1
0000284	CLYDE LAW	22/78/5	2.109	0.00	R1
0000285	JOYCE BECK	25/79/5	2.111	40.00	R1
0000286	MICHAEL HUMPHREY	26/78/5	2.113	25.00	R1
0000287	GEORGE SURRETT	26/79/5	2.115	0.00	R1
0000288	JEFF VONIER	11/79/5	2.117	0.00	R1
0000289	ROBERT CROZIER	20/76/5	2.119	0.00	R1
0000290	AL FAULKNER	2/71/5	2.121	0.00	R1
0000291	DON D. REEDER	2/73/5	2.123	0.00	R1 X
0000292	VIVIAN SHERLOCK	5/71/5	2.125	0.00	R1
0000293	ALAN D. MCALLISTER	6/71/5	2.127	25.00	R1
0000294	LOUIE HICKS	7/71/5	2.129	0.00	R1
0000295	WAYNE J. FOSTER	3/73/5	2.131	25.00	R1
0000296	RAY TAYLOR	9/71/5	2.133	25.00	R1
0000297	ROBERT FUNDERBURN	1/72/5	2.135	40.60	R1
0000298	JIM BENNETT	10/71/5	2.137	38.32	R1
0000299	C. E. MARKLEY	11/71/5	2.139	0.00	R1
0000300	TONY COLVIN	2/72/5	2.141	25.00	R1 X

ACCOUNT NUMBER	RESIDENT NAME	SERVICE ADDRESS	BOOK /SEQ	FIELD #1 DEPOSIT	FIELD #1 RATE CODE
000301	JOHN E. LINEHAN	12/71/5	2.143	25.00	R1
000302	JOHN M. WHIDDON	13/71/5	2.145	25.00	R1
000303	ROSEMARY EVANS	14/71/5	2.147	0.00	R1
000304	BILLY SCHULTZ	15/71/5	2.149	0.00	R1
000305	BILL JONES	16/71/5	2.151	0.00	R1
000306	WILLIAM HOWELL	17/71/5	2.153	0.00	R1
000307	PHILLIP SPRATT	18/71/5	2.155	30.40	R1
000308	W. C. WALLACE	4/72/5	2.157	25.00	R1
000309	JOHN P. DOODS	21/71/5	2.159	0.00	R1
000310	MICHAEL -BARBARA ROEULOCK	9/73/5	2.161	25.00	R1
000311	MARY STOUT	11/73/5	2.163	0.00	R1
000312	MACK HARBUCK	9/74/5	2.165	42.66	R1 X
000313	ROBERT AMMONS	1-2/69/5	2.167	25.00	R1
000314	DENISE (MOGONIA) ROUX	24/69/5	2.169	0.00	R1
000315	JEANNETTE PETERSON	1/70/5	2.171	25.00	R1
000316	TOMMY HICKS	23/69/5	2.173	0.00	R1
000317	ELIZABETH POSEY	22/69/5	2.175	0.00	R1
000318	THOMAS WOODWARD	21/69/5	2.177	0.00	R1
000319	C. H. BENEFIELD	20/69/5	2.179	0.00	R1
000320	LEAH NEEDER	18/69/5	2.181	25.00	R1
000321	M. (SUMMERWIND) BROWN	7/70/5	2.183	0.00	R1
000322	JOHN A. JOHNSON	11/69/5	2.185	73.30	R1
000323	BILLY THOMAS	5/66/5	2.187	0.00	R1
000324	BILL HINKLEY	9/69/5	2.189	0.00	R1
000325	MARION HOLMES	6/69/5	2.191	0.00	R1
000326	T. M. WHITNEY	4/69/5	2.193	0.00	R1
000327	PAUL HARRELL	4/67/5	2.195	0.00	R1
000328	DON THOMPSON	4/68/5	2.197	0.00	R1
000329	GEORGE GROSE	3/68/5	2.199	0.00	R1
000330	CHARLES N. SMITH	3/67/5	2.201	0.00	R1
000331	LLOYD V. WARNKEN	2/67/5	2.203	0.00	R1
000332	GEORGE D. PLYMEL, SR.	2/68/5	2.205	0.00	R1
000333	JAMES HEALY	1/68/5	2.207	0.00	R1
000334	DONALD PITROWSKI	1/65/5	2.209	25.00	R1
000335	CHARLES HURST	3/65/5	2.211	0.00	R1 X
000336	LEWIS WARD	6/65/5	2.213	0.00	R1 X
000337	BILLY J. THOMAS	3/66/5	2.215	55.18	R1
000338	AARON LOVETT	10/65/5	2.217	0.00	R1
000339	RONALD & SHARON WALLACE	4/62/5	2.219	40.00	R1
000340	J. V. GANDER	2/62/5	2.221	25.00	R1
000341	FRED BOND	9/64/5	2.223	0.00	R1
000342	JAMES STEELE	1/62/5	2.225	0.00	R1
000343	CLARK PORTER	6/63/5	2.227	0.00	R1
000344	CLIFTON HOPKINS	6/64/5	2.229	0.00	R1
000345	R. H. KILPATRICK	5/64/5	2.231	25.00	R1
000346	JEANNE WRAY	5/63/5	2.233	0.00	R1
000347	JOHNNIE FLETCHER	4/64/5	2.235	0.00	R1
000348	ROBERT GROZIER	3/64/5	2.237	0.00	R1
000349	VICTOR LAMAR JOHNSON	3/63/5	2.239	40.00	R1 X
000350	DONALD R. STALLINGS	2/63/5	2.241	32.88	R1

ACCOUNT NUMBER	NAME	SERVICE ADDRESS	BOOK /SEQ	FIELD #1 DEPOSIT	FIELD #1 RATE CODE
000351	SOUTHERN SEA FOOD	1/64/5	2.243	40.00	R1
0352	RICHARD STEPHENSON	7/62/5	2.245	25.00	R1
0353	ANDY DURHAM	9/62/5	2.247	0.00	R1
000354	R. W. STEPHENSON	6/23/1W	2.249	0.00	R1
0355	CLAUDE WILDER	10/66/5	2.251	25.00	R1 X
0356	WAYNE COLLIER	11/23/1W	2.253	40.00	R1
000357	JACKEL PINKI	4/23/1W	2.255	0.00	R1
000358	THERESA SPOHRER	3/23/1W	2.257	25.00	R1
0359	W. F. BLANKS	16/61/5	2.259	0.00	R1X
0360	MICHAEL & DOROTHY LONG	12/60/5	2.261	40.00	R1
000361	HAROLD RUDD	15/61/5	2.263	0.00	R1
0362	E. W. CARRELL	14/61/5	2.265	0.00	R1
0363	BOB HERREN	13/61/5	2.267	0.00	R1
000364	CONNIE CRUSOE	9/60/5	2.269	0.00	R1
0365	WILLIAM TULLY	8/60/5	2.271	0.00	R1
0366	JEAN McMILLAN (SCOTT FAIN)	11/61/5	2.273	40.50	R1
000367	GEORGE AVANT	5/60/5	2.275	0.00	R1
000368	STANLEY M. WEBER	7/61/5	2.277	40.00	R1
0369	CLARENCE COOK	5/61/5	2.279	25.00	R1
0370	C. W. ANSLEY	2/60/5	2.281	0.00	R1
0371	TONY LITTLE	1/60/5	2.283	0.00	R1
0372	W. ANDERSON	3/61/5	2.285	0.00	R1
0373	LESTER SHEETS	2/61/5	2.287	40.00	R1
000374	EDWARD M. HARRELL	1/61/5	2.289	25.00	R1
0375	MARY WALDORFF	1/59/5	2.291	0.00	R1
0376	JEAN LARRAMORE-EDWARDS	2/59/5	2.293	0.00	R1
000377	JAMES MORTON	3/59/5	2.295	40.00	R1
0378	JOHN WARD	4/59/5	2.297	25.00	R1
0379	JACK BULLOCH	26/60/5	2.299	25.00	R1
0380	LEONARD GRUBBS	3/58/5	2.301	0.00	R1
000381	WILLIE GUS CHANCY	25/60/5	2.303	0.00	R1
0382	PAUL W. LOMBUM	22/60/5	2.305	40.00	R1
0383	DAVID B. CROY	18/60/5	2.307	0.00	R1
000384	FRED C. MILLENDER	9/58/5	2.309	0.00	R1
0385	BILL LEE	10/58/5	2.311	0.00	R1X
0386	DONNA FLOYD	15/60/5	2.313	25.00	R1
0387	JOHN LUTTRELL	10/22/1W	2.315	0.00	R1
000388	CARLTON ETHRIDGE	14/57/5	2.317	25.00	R1
0389	BETTE R. BOLAND	13/57/5	2.319	0.00	R1
0390	DOC W. PORTERFIELD	15/58/5	2.321	46.20	R1
000391	THOMAS MOLONY	17/58/5	2.323	0.00	R1
0392	ARIGENA VONIER	18/58/5	2.325	0.00	R1
0393	MARTHA BRADY	9/57/5	2.327	0.00	R1
000394	ANDREW PITTS	7/57/5	2.329	0.00	R1
0395	JAMES ROZAR	20/58/5	2.331	53.10	R1
0396	HUBERT KADEL	6/57/5	2.333	0.00	R1
0397	HUBERT KADEL	5/57/5	2.335	25.00	R1
000398	JAMES DUFFES	4/57/5	2.337	0.00	R1
0399	CHESTER CLARK	3/57/5	2.339	0.00	R1
0400	ANDREW PITTS	28/58/5	2.341	25.00	R1

RESIDENT ACCOUNT NUMBER	NAME	SERVICE ADDRESS	BOOK /SEQ	FIELD #1 DEPOSIT	FIELD #1 RATE CODE
0000401	W. L. MILAM	5/55/5	2.343	25.00	R1
0000402	J. H. SPRATT	4/55/5	2.345	0.00	R1
0000403	BRUFORD FLOWERS	9/56/5	2.347	25.00	R1
0000404	ANDREW A. PITTS	5/56/5	2.349	0.00	R1
0000405	JAMES HANKINS	4/56/5	2.351	25.00	R1
0000406	SCOTT ANDERSON	1/54/5	2.353	25.00	R1
0000407	JOANIE BALES	2/54/5	2.355	45.10	R1
0000408	GORDON WALDO	5/54/5	2.357	0.00	R1
0000409	BOBBY J. ROBINSON	10/53/5	2.359	25.00	R1
0000410	JANICE JACKSON	6/54/5	2.361	40.00	R1
0000411	JOSEPH HALL	1/52/5	2.363	0.00	R1
0000412	LEGETTE BARRETT	3/52/5	2.365	0.00	R1
0000413	DAVID JOHNSON	10/52/5	2.367	78.80	R1
0000414	DONALD WATSON	12/54/5	2.369	0.00	R1
0000415	JACK TAYLOR	1/51/5	2.371	0.00	R1
0000416	MONTE W. PHILLIPS	2/51/5	2.373	25.00	R1
0000417		3/51/5	2.375	0.00	R1
0000418	A. WILLIAM IRVINE	9/52/5	2.377	0.00	R1
0000419	DOMINIC BARAGONA	7/52/5	2.379	25.00	R1
0000420	DIANA PRICKETT	5/52/5	2.381	25.00	R1
0000421	GRETCHEN SCHMID	4/15/1W	2.383	82.68	R1
0000422	JANE BAHEURG	5/15/1W	2.385	0.00	R1
0000423	MIKE HUMHREY	6/55/5	2.387	25.00	R1
0000424	TOM CHRISTENSON	12/15/1W	2.389	40.56	R1
0000425	DAVID WALKER	22/22/1W	2.391	40.00	R1
0000426	BOBBY JAMES	20-21/3/1W	2.393	65.94	R1x
0000427	JOHN BONN	5/14/1W	2.395	0.00	R1
0000428	HELEN SPOHRER--PHENIX HARBOUR	OLD MARINA/TRACT A	2.399	0.00	R1
0000429	PAUL BYRD	7/51/5	2.400	53.10	R1
0000430	WILLIAM CHALECKE	1/15/1W	2.401	0.00	R1
0000431	ROBERT W. CLARK	10/14/1W	2.403	0.00	R1
0000432	ROBERT K. LIGHT	8/13/1W	2.405	0.00	R1
0000433	DAVID TUPLIN	6/13/1W	2.407	25.00	R1
0000434	CARLA ETHERIDGE	20/15/1W	2.409	25.00	R1
0000435	SUNCOAST REALTY	20/16/1W	2.411	25.00	R1
0000436	MIKE BURTON	18/15/1W	2.413	0.00	R1
0000437	CYNTHIA RHEW	15/15/1W	2.415	40.00	R1
0000438	CURTIS CAQUETTE	17/15/1W	2.417	25.00	R1
0000439	PAM PRINCE	15/15/1W	2.419	25.00	R1
0000440	ROBERT GAVIGAN	17/22/1W	2.421	0.00	R1
0000441	FRED MILLS	17/21/1W	2.423	0.00	R1
0000442	A. J. JERNIGAN	15/22/1W	2.425	25.00	R1
0000443	BRUCE DRYE	14/21/1W	2.427	25.00	R1x
0000444	CLARENCE HOOKS	13/22/1W	2.429	0.00	R1x
0000445	DIANE HUNT	16/24/1W	2.431	40.00	R1
0000446	BOB CLARK	11/21/1W	2.433	25.00	R1
0000447	JOANN WINGLER	1/24/1W	2.435	25.00	R1
0000448	R. L. BRYAN	15/24/1W	2.437	25.00	R1
0000449	STANLEY RAINWATER	10/75/5	2.439	55.80	R1
0000450	H. E. FELT	9/75/5	2.441	25.00	R1

IDENT	ACCOUNT	SER	NAME	SERVICE ADDRESS	BOOK /SER	FIELD #1 DEPOSIT	RATE	FIELD #1 CODE
00451			TONY A. SHIVER	21/74/5	2.443	40.00	R1	
452			R. E. ASHMORE	6/75/5	2.445	0.00	R1	
453			RICHARD MOOREFIELD	11/80/5	2.447	25.00	R1	
00454			THOMAS HARE	16/79/5	2.449	0.00	R1	
455			ROBERT POWELL	20/79/5	2.451	0.00	R1	
456			ROCKDALE SAND & STONE	5/80/5	2.453	25.00	R1	
00457			FLETCHER HERNDON	22/79/5	2.455	0.00	R1	
00458			JOHN LAW	4/80/5	2.457	66.72	R1X	
459			PAUL J. LILLIS	23/79/5	2.459	0.00	R1	
460			KALUKO P. MATHESON	10/83/5	2.461	25.00	R1	
00461			DANNY BROWN	9/82/5	2.463	0.00	R1	
462			GAIL FLORES	16/86/5	2.465	0.00	R1	
463			JUDY THOMPSON	6/90/5	2.467	0.00	R1	
00464			JUANITA WHIDDON	5/90/5	2.469	25.00	R1	
465			GUS PITTS	1-2/1/1W	3.002	0.00	R1	
466			HAPPY PELICAN	28-29/1/1W	3.003	0.00	R1	
00467			HARRY A'S TAVERN & PACKAGE	4-5/1/1W	3.005	0.00	R1	
00468			MINI CONVENIENCE STORE	10/1/1W	3.007	0.00	R1	
469			SUNCOAST REALTY	15-18/1/1W	3.009	59.04	R1	
470			AFALACHICOLA STATE BANK	19-21/1/1W	3.011	0.00	R1	
00471			SUNSHINE FOOD STORES	16/6/1W	3.013	0.00	R1	
472			SURVIVORS	22-23/6/1W	3.015	0.00	R1X	
473			GULF STATE BANCORP.	1-3/6/1W	3.017	0.00	R1	
00474			ISLANDER RESTAURANT	1-2/7/1W	3.019	0.00	R1	
00475			HELEN SPORHRER	11-12/5/1W	3.022	0.00	R1X	
476			VILLAS OF ST. GEORGE	7-8/10/1W	3.023	0.00	R8	
00477			ISLAND UTILITIES	15-16/9/1W	3.025	322.02	R1	
00478			WALTER ARMISTEAD	7/8/1W	3.027	25.00	R1	
479			BUCCANEER INN II	13-20/10/1W	3.029	0.00	R5	
480			RICK RUCKER	11-12/10/1W	3.031	25.00	R1	
00481			ROSEHILL LAND COMPANY	REALETY SALES OFFICE	3.033	0.00	R1X	
482			ISLAND OASIS	9/6/1E	3.035	0.00	R1X	
483			ANCHOR REALTY & MTG.	12-15/6/1E	3.037	25.00	R1	
00484			GULF COAST REALTY OF SGI	10-11/8/1E	3.039	0.00	R1Y	
00485			BUBBA'S BEACH CLUB	4-5/8/1E	3.041	0.00	R1	
486			**NEW-ACCOUNT**	5-6/5/1E	3.043	0.00	R1X	
00487			HAROLD E. FREDERICK	25-29/5/1E	3.045	0.00	R2X	
00488			FIRST UNITED METHODIST CHURCH	11-12/4/1E	3.048	0.00	R1X	
489			ISLAND EMPORIUM	31-32/5/1E	3.049	40.00	R1	
490			JAMES HOLZHAUSEN	21/5/1E	3.051	58.38	R1X	
00491			JOHN COLLINS/ADC WAREHOUSE	17/2/1E	3.053	0.00	R1	
492			ST. JOSEPH TELEPHONE COMPANY	17-18/5/1E	3.055	25.00	R1X	
493			GUN HEAT & AIR CONDITIONING	26/1/1E	3.057	25.00	R1X	
00494			JANIS DRAKE	24-25/1/1E	3.059	0.00	R1	
495			ST. GEORGE INN	16-24/6/1E	3.061	0.00	R1	
496			OYSTER COVE RESTAURANT	14-17/3/1E	3.064	0.00	R1	
00497			SGI VOLUNTEER FIRE DEPT.	8/14/1E	3.065	0.00	R1	
00498			HARRY D. MCGHIN	20/16/1E	3.067	0.00	R1	
499			FIRST BAPTIST CHURCH	17/29/4	3.069	0.00	R1	
500			DALE HERNDON	1/22/1E	3.071	0.00	R1	

RESIDENT ACCOUNT NUMBER	NAME	SERVICE ADDRESS	BOOK /SEQ	FIELD #1 DEPOSIT	FIELD #1 RATE CODE
000501	FIRST BAPTIST CHURCH	14/29/4	3.073	0.00	R1
000502	SANDRA J. NAPIER	15/22/1E	3.075	40.00	R1
000503	RICK RUCKER	15/21/1E	3.077	0.00	R1
000504	CARL HOFFMAN	9/22/1E	3.079	0.00	R1
000505	HAROLD HARDEN	2/36/4	3.081	25.00	R1
000506	DALE BODZIONY	3/36/4	3.083	0.00	R1
000507	JOHN STRICKLAND	5/36/4	3.085	25.00	R1
000508	PEGGY POWERS	6/36/4	3.087	25.00	R1
000509	JOHN SCULLY	26/35/4	3.090	0.00	R1
000510	CHARLOTTE I. JENSEN C/O DOWNEY	25/35/4	3.091	25.00	R1
000511	ROBERT O. SHEPHARD, JR.	4/39/4	3.093	40.00	R1
000512	LARRY KIENZLE	10/37/4	3.095	25.00	R1
000513	NICK YONCLAS	7/39/4	3.097	0.00	R1
000514	OLLIE GUNN	1/48/4	3.099	93.68	R1 X
000515	DOUGLAS J. WINGATE	22/42/4	3.101	0.00	R1
000516	ROBERT RAY	7/43/4	3.103	0.00	R1
000517	VICTOR COBB	5/44/4	3.105	0.00	R1
000518	K. L. CARR	1/45/4	3.107	25.00	R1
000519	BARBARA KESTER	2/45/4	3.109	0.00	R1
000520	T. B. HOWARD	3/45/4	3.111	25.00	R1
000521	ROBERT C. BOCK	4/45/4	3.113	0.00	R1
000522	CHRIS FLOYD	11/48/4	3.115	25.00	R1
000523	WENDELL LACY	10/45/4	3.117	28.10	R1
000524	E. R. THOMPSON	11/45/4	3.119	25.00	R1
000525	W. C. CHAMBERS	1/49/4	3.121	25.00	R1
000526	BILLY CHARLES HORTON	14/48/4	3.123	0.00	R1
000527	WILLIAM BURNS	17/48/4	3.125	25.00	R1
000528	MARVIN R. MCINTOSH	9/49/4	3.127	25.00	R1
000529	JOHN MCEACHERN	8/49/4	3.129	0.00	R1
000530	JAMES C. BYRD	23/48/4	3.131	0.00	R1
000531	JOHN W. BIGGERS	14/45/4	3.133	25.00	R1
000532	SAM LIPSCOMB	6/50/4	3.135	40.00	R1
000533	RICHARD F. FIORENTINO	11/49/4	3.137	0.00	R1
000534	JIMMIE COOPER	1/TRACT 33	3.139	0.00	R1
000535	SGI BEAUTIFICATION COMM.	MEDIAN LANDSCAPING	7.001	25.00	R1
000536	EUCANEER INN I	19-20/10/1W	3.143	40.00	C3
000537	MARION GUESS	1/12/1W	4.001	0.00	R1
000538	JAMES K. HESTER	2/11/1W	4.003	25.00	R1
000539	TYLER PROSKINE	4/11/1W	4.005	25.00	R1
000540	JAMES HOWARD	5/11/1W	4.007	0.00	R1
000541	RICHARD COLLINS	1/17/1W	4.009	0.00	R1
000542	GEORGE H. KIRKLAND III	1/18/1W	4.011	40.00	R1
000543	G. ADKINS C/O ALICE COLLINS R.	2/18/1W	4.013	0.00	R1
000544	BEN LAWSON	3/18/1W	4.015	0.00	R1
000545	BILL JONES	4/17/1W	4.017	0.00	R1
000546	JEFF MCGEE	5/17/1W	4.019	25.00	R1
000547	PEARCE L. BARRETT	5/17/1W	4.021	0.00	R1
000548	ROBERT D. SNYDER	8/18/1W	4.023	0.00	R1 X
000549	DAVIS TEMP	10/18/1W	4.025	0.00	R1
000550	HAL GLAZE	3/19/1W	4.027	0.00	R1

RESIDENT	ACCOUNT NUMBER	NAME	SERVICE ADDRESS	BOOK /SEQ	FIELD #1 DEPOSIT	FIELD #1 RATE CODE
	000551	BARBARA RIDDLE	4/19/1W	4.029	25.00	R1
	000552	R.H. KILPATRICK	6/19/1W	4.031	40.00	R1
	000553	W.E. MIDDLETON	7/19/1W	4.033	0.00	R1X
	000554	J.K. DUFFES	8/19/1W	4.035	25.00	R1X
	000555	VICKIE CUMMINGS	8/20/1W	4.038	0.00	R1
	000556	MONA ERIKSON	9/20/1W	4.039	25.00	R1X
	000557	JANE MIKLOS	9/19/1W	4.041	0.00	R1X
	000558	CONRAD GLEBER	10/20/1W	4.043	25.00	R1X
	000559	STEVE BAIRD	2/25/1W	4.045	25.00	R1
	000560	MARK BANE, BETTY CHURCH	1/26/1W	4.047	0.00	R1
	000561	DOROTHY JOHNSTON	2/26/1W	4.049	0.00	R1
	000562	J.M. JORDAN JR.	4/26/1W	4.051	0.00	R1
	000563	JAMES GARRETT	5/26/1W	4.053	0.00	R1X
	000564	DON MAY	7/26/1W	4.055	0.00	R1
	000565	BOBBY COOK	7/25/1W	4.057	0.00	R1
	000566	J. SLAPPEY C/O GULF COAST REAL	1/A/3	4.059	55.46	R1
	000567	W.D. BELL	2/A/3	4.061	25.00	R1
	000568	DR. OH (PRIMA VILLA)	4/A/3	4.063	25.00	R1
	000569	DAVID E. FINDLEY	13/F/3	4.065	25.00	R1
	000570	H. DAVID STORY	5/A/3	4.067	40.00	R1
	000571	A.C. CHURCH	7/A/3	4.072	0.00	R1
	000572	FRED SUBER	16/F/3	4.071	0.00	R1
	000573	KENNETH MICK	15/F/3	4.073	25.00	R1
	000574	HARVEY HILL	8/A/3	4.075	0.00	R1
	000575	REGINALD CASH	10/A/3	4.077	0.00	R1
	000576	MAMIE S. HURST	13/F/3	4.079	40.00	R1
	000577	C.E. HELMS	19/G/3	4.081	0.00	R1
	000578	RONALD HOCK	4/B/3	4.083	0.00	R1X
	000579	JAMES WALT C/O GULF COAST REAL	16/G/3	4.085	0.00	R1
	000580	BRIAN KRONTZ	16/G/3	4.087	0.00	R1
	000581	JACK HARMON	7/B/3	4.089	0.00	R1
	000582	JAMES SMITH C/O ANCHOR REALTY	8/B/3	4.091	0.00	R1
	000583	HAROLD E. HODGE	9/B/3	4.093	25.00	R1
	000584	DOROTHY ROLESTAD	14/G/3	4.095	0.00	R1
	000585	HARRIETT SMITH	1/C/3	4.097	0.00	R1
	000586	WILLIAM S. NEWTON	3/C/3	4.099	0.00	R1X
	000587	WILLIAM E. BALL III	5/C/3	4.101	25.00	R1
	000588	HUGH M. AUSTIN	7/C/3	4.103	40.00	R1
	000589	DWIGHT MARSHALL	8/C/3	4.105	0.00	R1X
	000590	NANCY EDWARDS	22/1/3	4.107	25.00	R1
	000591	VIVIAN M. SHERLOCK	2/D/3	4.109	0.00	R1
	000592	COLIN M. GALLANT D.D.S.	21/1/3	4.111	40.00	R1
	000593	LEONARD F. HOWARD	3/D/3	4.113	0.00	R1
	000594	DAVID LADD C/O SUNCOAST REALTY	5/D/3	4.115	25.00	R1
	000595	HATTIE BOSTICK	6/D/3	4.117	0.00	R1
	000596	E.L. SUBER	15/1/3	4.119	25.00	R1
	000597	M. GREENE	7/D/3	4.121	0.00	R1
	000598	HARRY MIXSON	9/D/3	4.123	25.00	R1
	000599	FRANCINE B. ALDRIDGE	10/D/3	4.125	0.00	R1
	000600	STEVEN RASH	12/1/3	4.127	40.00	R1

RESIDENT ACCOUNT NUMBER	NAME	SERVICE ADDRESS	BOOK /SEQ	FIELD #1 DEPOSIT	FIELD #1 RATE CODE
0000601	LEE SIMMONS	1/E/3	4.129	0.00	R1
0000602	RONALD BRASWELL	22/J/3	4.131	25.00	R1
0000603	THOMAS B. WEBB	20/J/3	4.135	25.00	R1
0000604	HENRY SMITH III	2/E/3	4.137	25.00	R1
0000605	DONALD KIRKSEY	3/E/3	4.139	25.00	R1
0000606	JOHN WIGHT	4/E/3	4.141	0.00	R1
0000607	WALT COWARD C/O GULF COAST REA	5/E/3	4.143	40.00	R1
0000608	SUNCOAST REALTY (BEMAN)	5/E/3	4.145	0.00	R1 X
0000609	MARTHA G. DIMON	15/J/3	4.147	40.00	R1
0000610	SANFORD LISS	8/E/3	4.149	0.00	R1
0000611	CHARLES WAKEN	9/E/3	4.151	25.00	R1
0000612	CLAUDIA BURTON	10/E/3	4.153	40.50	R1
0000613	W.L. HARTSFIELD	12/J/3	4.155	25.00	R1
0000614	GREGORY PARKER	9/J/3	4.157	25.00	R1
0000615	HUGH REICHERT	8/O/3	4.159	25.00	R1
0000616	SCHIEBER GORDON	7/O/3	4.161	25.00	R1
0000617	LIPPINCOTT/MACKENZIE	5/O/3	4.163	0.00	R1
0000618	CHARLES W. MOBLEY JR	3/O/3	4.165	0.00	R1
0000619	TWENTY NORTH REALTY	4/J/3	4.167	57.00	R1
0000620	THOMAS CLINE	1/J/2	4.169	0.00	R1
0000621	JOANNA DOLLOFF	10/N/3	4.171	0.00	R1
0000622	ROBERT DAVIS	10/I/3	4.173	0.00	R1
0000623	CHARLES W. SHIERLING	9/I/3	4.175	25.00	R1
0000624	P.G. MORRISON	7/N/3	4.177	0.00	R1
0000625	LINDA PROTSMAN	6/N/3	4.179	0.00	R1
0000626	BOBBY STRICKLAND	3/I/3	4.181	25.00	R1
0000627	C.R. MCKEMIE	11/M/3	4.183	25.00	R1
0000628	EUNICE MIRABELLA	11/H/3	4.185	0.00	R1
0000629	ROBERT BOUY	9/M/3	4.187	0.00	R1
0000630	LAMAR HARTSFIELD	8/H/3	4.189	25.00	R1
0000631	RICHARD O'MARA	7/H/3	4.191	0.00	R1
0000632	JERRY MARTIN	6/H/3	4.193	0.00	R1 X
0000633	DR. RICHARD A. LAFLEUR	5/M/3	4.195	40.00	R1
0000634	KENNETH R. HOFFMAN	4/M/3	4.197	40.00	R1
0000635	ROSE CLARK	2/M/3	4.199	25.00	R1
0000636	FLORENE MCCOMB	3/H/3	4.201	25.00	R1
0000637	JAMES B. DAVIS	3/M/3	4.203	0.00	R1
0000638	SANDRA MARKS	1/M/3	4.205	0.00	R1
0000639	JOHN D. SPEISER	3/G/3	4.207	0.00	R1
0000640	MARION HARRIS C/O SUNCOAST REA	9/L/3	4.209	0.00	R1
0000641	ROBERT GILL C/O SUNCOAST REALT	7/G/3	4.211	40.00	R1
0000642	WAYNE MURPHY	6/B/3	4.213	0.00	R1
0000643	LUCRETIA MIHALICH	2/G/3	4.215	92.02	R1
0000644	DAN CHASE	1/G/3	4.217	0.00	R1
0000645	WARREN CADWALLADER	10/K/3	4.219	41.86	R1
0000646	WILLIAM WILGUS	11/F/3	4.221	25.00	R1
0000647	JOHN FICKLEN	22/G/3	4.223	0.00	R1
0000648	DONALD E. WATERS SR.	7/K/3	4.225	0.00	R1
0000649	PEPPER GHAZVINI (WINDWALKER)	5/K/3	4.227	40.00	R1
0000650	HARRELL & KARLENE REVELL	5/F/3	4.229	40.00	R1

RESIDENT	ACCOUNT NUMBER	NAME	SERVICE ADDRESS	BOOK /SEQ	FIELD #1 DEPOSIT	FIELD #1 RATE CODE
	000651	WILLIAM H. HICKS	3/L/3	4.231	0.00	R1
	000652	KATHLEEN FORREST	1/F/3	4.233	40.00	R1
	000653	LUCY KIZIRIAN	6/24/1W	4.235	0.00	R1
	000654	JAN E. POWELL	6/21/1W	4.237	25.00	R1
	000655	GEORGE BRIGGS	5/21/1W	4.239	0.00	R1
	000656	CINDY JOHNSON	2/21/1W	4.241	40.00	R1
	000657	RODNEY ALLEN, WAVERLY HILLS	11/17/1W	4.243	0.00	R1
	000658	E.M. ANDERSON	1/20/1W	4.245	0.00	R1
	000659	HARRY ARNOLD	9/16/1W	4.247	86.34	R1
	000660	THOMAS MILLER	8/16/1W	4.250	0.00	R1
	000661	ROGER W. BUTLER	5/16/1W	4.251	0.00	R1
	000662	HAROLD SHADBURN	2/16/1W	4.253	38.92	R1
	000663	W.Y. BRACKIN	3/13/1W	4.255	0.00	R1
	000664	ANTHONY BIGSICA	2/13/1W	4.257	25.00	R1
	000665	VAN PONDER	3/K/3	4.230	40.00	R1
	000666	ADELE CASH	3/13/1E	5.001	0.00	R1
	000667	RICHARD HODGKINS	1/16/1E	5.003	25.00	R1
	000668	UNITED METHODIST CHURCH	4/16/1E	5.005	25.00	R1
	000669	NANCI TRIPPITELLI C/O SUNCOAST	3/16/1E	5.007	40.00	R1
	000670	ONEZ O'NEAL	6/16/1E	5.009	25.00	R1
	000671	R. B. EGGART	10/16/1E	5.011	0.00	R1
	000672	PHILIP BRACHMAN	11/16/1E	5.013	25.00	R1
	000673	DAVID WALKER	3/21/1E	5.015	40.00	R1
	000674	A. P. FLOYD	4/21/1E	5.017	0.00	R1
	000675	A. E. MIDDLEBROOKS	5/21/1E	5.019	25.00	R1
	000676	A.C. YOUNG, JR.	6/21/1E	5.021	40.00	R1
	000677	KENNY KNOX	8/21/1E	5.023	25.00	R1
	000678	GRADY UNDERWOOD	9/21/1E	5.025	40.00	R1 X
	000679	WILBUR HOLLIS	1/K/2	5.027	0.00	R1
	000680	KIM FISH	2/K/2	5.030	25.00	R1
	000681	EARL CASH	3/F/2	5.033	25.00	R1
	000682	REX A. WHITEMAN	4/F/2	5.037	40.00	R1
	000683	LLOYD SUMMER, III	6/F/2	5.041	0.00	R1
	000684	JAMES B. LACKEY	6/K/2	5.043	40.00	R1
	000685	PHYLIS VITALI C/O ALICE COLLIN	7/F/2	5.045	0.00	R1
	000686	ZSUZSANNA PASZTOR	8/F/2	5.047	0.00	R1
	000687	H. G. LEAVINS	10/K/2	5.049	0.00	R1 X
	000688	SANDRA PRINCE	1/G/2	5.051	0.00	R1
	000689	J. A. CRUMLEY	2/L/2	5.055	0.00	R1
	000690	KRISTINE POWELL	3/L/2	5.059	25.00	R1
	000691	JAMES LEE GUERNSEY	9/L/2	5.063	0.00	R1
	000692	GARY BROOKS	11/G/2	5.065	25.00	R1
	000693	QUENTON HERNDON	5/H/2	5.067	0.00	R1
	000694	CLAY SCHNITKER	6/H/2	5.071	0.00	R1
	000695	ESTATE OF IKE WILLIAMS, JR.	8/M/2	5.073	25.00	R1
	000696	RAY A. WESTER, JR.	9/H/2	5.075	25.00	R1 X
	000697	JAMES F. KEMP	10/M/2	5.079	0.00	R1
	000698	THOMAS G. MALOOF	1/I/2	5.081	25.00	R1
	000699	RALPH REDDICK	2/I/2	5.085	25.00	R1
	000700	TIM QUICK	3/N/2	5.089	40.00	R1

RESIDENT ACCOUNT NUMBER	MEMBER NAME	SERVICE ADDRESS	BOOK /SEQ	FIELD #1 DEPOSIT	FIELD #1 RATE CODE
000701	GUY MARSH	5/1/2	5.093	0.00	R1
0702	GARY CATES	6/N/2	5.095	25.00	R1
0703	OLLIE GUNN JR.	11/N/2	5.097	40.00	R1
000704	CHARLES BRANNON	1/0/2	5.099	0.00	R1
0705	DORIS Y. BRAY	8/1/2	5.103	40.00	R1
0706	MYERS SHULER	1/1/2	5.105	0.00	R1
000707	MARGARET GARVUE	2/J/2	5.107	0.00	R1
000708	ROBERT GARDNER	2/0/2	5.111	0.00	R1
0709	PAUL LONBOM	3/J/2	5.113	0.00	R1
000710	ALBERT F. DUNCAN	5/0/2	5.115	25.00	R1
000711	JIMMY MEEKS	6/J/2	5.119	0.00	R1
0712	JIM HOLZHAUSEN	7/0/2	5.123	61.54	R1
0713	KELLY	6/15/1W	2.386	0.00	R1
000714	WILLIAM NICHOLS	11/J/2	5.127	25.00	R1
000715	SUZANNE LATHAM	12/J/2	5.129	0.00	R1 X
0716	R. J. MATHEWS, JR.	TRACT 1E	5.133	25.00	R1
000717	MALCOLM BURTON	2/TRACT 1E	5.135	0.00	R1
000718	JEAN WEBB	9/E/2	5.139	0.00	R1
0719	ANCHOR REALTY	15/J/2	5.141	0.00	R1 X
0720	ROBERT DUBAY	5/E/2	5.143	0.00	R1
000721	DAN RUHL, JR.	4/E/2	5.145	0.00	R1
0722	MICHAEL SIMMONS	19/J/2	5.147	0.00	R1
0723	ALEXANDER HINSON	21/J/2	5.149	0.00	R1
000724	J. W. LAMBERT	22/J/2	5.153	0.00	R1
000725	CLEM HALLMAN	1/E/2	5.157	65.82	R1
0726	ROBERT CRUZIER	12/1/2	5.161	0.00	R1
000727	WILLIAM KIRKSEY	10/0/2	5.165	0.00	R1
000728	JOHN HORTON	9/0/2	5.171	0.00	R1
0729	RICK JOHNSON	14/1/2	5.173	25.00	R1
000730	COLUMBUS COLONIES/FRANK JON	8/0/2	5.177	0.00	R1
000731	MONTE PHILLIPS	6/0/2	5.181	0.00	R1
0732	C. W. HARBIN	5/0/2	5.183	0.00	R1
0733	CECIL BUTLER	3/0/2	5.185	0.00	R1
000734	CAROL MCCORMICK	22/1/2	5.187	0.00	R1
000735	ROBERT DUBAY	13/H/2	5.189	0.00	R1
0736	JOHN LIVELY	10/0/2	5.195	0.00	R1
000737	VIRGINIA GLASS	14/H/2	5.200	0.00	R1
000738	JAMES R. TODD	15/H/2	5.203	25.00	R1
0739	ROBERT ROBUCK	8/0/2	5.205	0.00	R1
000740	ANN J. ROBUCK	16/H/2	5.207	0.00	R1
000741	JOSEPH S. STRAKA, III	8/L/3	4.249	40.00	R1 X
0742	AMN CHOPPIN	17/H/2	5.211	0.00	R1
0743	CLIFF MADSEN	5/0/2	5.215	0.00	R1
000744	H. L. JEFFORDS	3/0/2	5.217	0.00	R1
000745	ARTHUR LITTLE	20/H/2	5.219	0.00	R1
0746	MARILYN HELMS	22/H/2	5.223	40.00	R1
000747	LOWRY BLACKBURN	1/0/2	5.225	0.00	R1 X
000748	ORPHA RUSSELL	10/B/2	5.229	0.00	R1
0749	LARRY CLIETT	8/8/2	5.233	73.84	R1
000750	G. WHITE C/O GULF COAST REALTY	15/6/2	5.235	0.00	R1

RESIDENT ACCOUNT NUMBER	NAME	SERVICE ADDRESS	BOOK /SEQ	FIELD #1 DEPOSIT	FIELD #1 RATE CODE
0000751	JAMES N. ROUKOSKI	9/B/2	5.237	40.00	R1
0000752	LINDA K. DEBRUYNE	15/G/2	5.239	0.00	R1
0000753	JIM RUDNIK	5/B/2	5.241	0.00	R1
0000754	A. F. HARDEE	4/B/2	5.245	0.00	R1
0000755	PEYTON MCQUARY	18/G/2	5.247	25.00	R1
0000756	FRANK FLYNN	3/B/2	5.249	0.00	R1
0000757	JERRY CARNES	20/G/2	5.251	0.00	R1
0000758	RUTH C. REGISTER	2/B/2	5.255	0.00	R1
0000759	LAWRENCE R. MALONE	1/B/2	5.259	0.00	R1
0000760	DENNIS BOYLE	10/A/2	5.263	0.00	R1
0000761	WALTER AUTREY	9/A/2	5.265	0.00	R1
0000762	W. E. BURKE	8/A/2	5.267	0.00	R1
0000763	JOHN W. OWEN	14/F/2	5.269	0.00	R1
0000764	DOYLE R. PRATT	15/F/2	5.271	0.00	R1
0000765	JOHN DOODS	17/F/2	5.273	0.00	R1
0000766	JOAN SWANSON	18/F/2	5.275	25.00	R1
0000767	T. W. LINDSEY	5/A/2	5.279	0.00	R1
0000768	ROBERT BALDWIN	4/A/2	5.283	25.00	R1
0000769	JOAN SWANSON	18/F/2	5.285	0.00	R1
0000770	TONY ANDERSON	19/F/2	5.289	25.00	R1
0000771	M. E. PITTMAN	2/A/2	5.291	25.00	R1
0000772	HARVEY NEISLER	22/F/2	5.293	0.00	R1
0000773	GARY MAHONEY	8/20/1E	5.295	25.00	R1
0000774	WALTER HOCH	7/20/1E	5.297	36.78	R1
0000775	W. D. LINES /BLUCHER B. LINES	6/19/1E	5.299	25.00	R1X
0000776	ELIZABETH ATKINSON	5/19/1E	5.301	0.00	R1X
0000777	LEONARD MCCROAN	6/20/1E	5.303	25.00	R1
0000778	JAMES B. SAXON	5/20/1E	5.305	0.00	R1
0000779	CHUCK STAFFORD	4/19/1E	5.307	0.00	R1
0000780	JOHN F. OESHGER	3/19/1E	5.309	0.00	R1
0000781	LOWRY BLACKBURN	4/20/1E	5.311	61.38	R1
0000782	LUCILLE CAGLE	2/19/1E	5.313	0.00	R1
0000783	SMITH BEACH HOUSE	9/17/1E	5.315	0.00	R1
0000784	E. HOWARD CARSON, SR.	8/18/1E	5.317	43.40	R1
0000785	SUNCOAST REALTY	7/18/1E	5.319	0.00	R1
0000786	TOM TYRONE	6/18/1E	5.321	25.00	R1
0000787	DAN RUHL	5/18/1E	5.325	25.00	R1
0000788	JANE HARRELL	2/18/1E	5.327	0.00	R1X
0000789	GEORGE KIRVIN	5/11/1E	5.329	0.00	R1
0000790	JAMES C. HALL	2/12/1E	5.335	0.00	R1
0000791	ROBLEY J. LIGHT	1/12/1E	5.339	0.00	R1
0000792	ELLERBEE C/O LIGHTHOUSE PT. FR	7/1/2	5.336	40.00	R1X
0000793	LEE NOEL C/O SUNCOAST REALTY	15/10/1E	5.365	0.00	R1
0000794	LEE NOEL C/O SUNCOAST REALTY	16/10/1E	5.367	0.00	R1
0000795	ROBERT PILCHER	1/TRACT 3	6.001	25.00	R1
0000796	ROBERT S. LEGG	2/TRACT 3	6.003	25.00	R1
0000797	DENNIS SMITH	3/TRACT 3	6.005	0.00	R1
0000798	DENNIS SMITH	4/TRACT 3	6.007	0.00	R1
0000799	MIKE ROEHR	4/TRACT 5	6.009	0.00	R1
0000800	TERRY LEWIS C/O RESORT REALTY	5/TRACT 5	6.011	0.00	R1

RESIDENT ACCOUNT NUMBER	NAME	SERVICE ADDRESS	BOOK /SER	FIELD #1 DEPOSIT	FIELD #1 RATE CODE
00801	CONNIE CROWLEY	4/TRACT 39E	6.013	25.00	R1
0802	PHILLIP SWARTZ	3/TRACT 7	6.015	0.00	R1
00803	CHIDORA PROPERTIES/DLSEN	9 DUNES ST. GEORGE	6.017	75.44	R1
00804	FORD THOMPSON	4 DUNES ST. GEORGE	6.019	0.00	R1
0805	BENJAMIN MASSEY	TRACT 6E	6.023	0.00	R1
0806	SUSAN SPEARS C/O GULF COAST RE	5/TRACT 6	6.025	0.00	R1
00807	FRANK GOMEZ	5/TRACT 6	6.029	0.00	R1
0808	PETER RIPLEY	1/TRACT 6	6.031	0.00	R1
0809	DENNIS SMITH C/O SUNCOAST REAL	1/TRACT 9	6.035	40.00	R1
00810	W. H. HARWELL	TRACT 9	6.039	0.00	R1
00811	JOHN K. FOLGER	TRACT 10	6.043	0.00	R1
0812	RON J. BROWN	3/TRACT 42E	6.045	0.00	R1
00813	JOHN ALDERMAN	8/TRACT 42	6.047	0.00	R1
00814	DAVID E. BESS	7/TRACT 42	6.049	0.00	R1
0815	HERB JUFFE	1/TRACT 44	6.051	0.00	R1
0816	HEATHER HILTON	8/TRACT 44	6.055	0.00	R1
00817	LARRY MOHANNUS	8/TRACT 44	6.059	0.00	R1
0818	ELECE HARRISON	2 SANDS ST GEORGE	6.063	25.00	R1
0819	ROBERT HEIDE	DUNES ST. GEORGE	6.065	0.00	R1
00820	JOE DOWNEY C/O SUNCOAST REALTY	7/TRACT 13-14	6.067	0.00	R1
00821	SUNCOAST REALTY #553	6/TRACT 14	6.069	0.00	R1
0822	DOUG NARSIZ	5/TRACT 14	6.071	25.00	R1
00823	DEAN SCHEER	TRACT 12	6.073	0.00	R1
00824	SHIRLEY REDD	1/TRACT 48	6.075	0.00	R1
0825	**NEW-ACCOUNT (4.11)**	2/TRACT 48	6.077	0.00	R1
0826	KATHY GILBERT	8/TRACT 48	6.079	25.00	R1
00827	C. J. HESTER, JR.	3/TRACT 15	6.081	0.00	R1X
0828	JOHN COLLINS	6 EAST BAY ESTATES	6.085	0.00	R1
0829	MRS. T. C. METZNER	9/TRACT 49	6.089	0.00	R1
00830	EAST BAY ESTATES	EAST BAY EST. POOL	6.091	0.00	R1X
00831	JAMES G. DAVISON	2/EAST BAY ESTATES	6.093	25.00	R1
0832	EAST BAY ESTATES	3/EAST BAY ESTATES	6.095	0.00	R1
00833	WILLIAM H. BRADLEY	1/GULF PEARL ESTATE	6.099	0.00	R1
00834	ROYCE HODGE	3/TRACT 17E	6.101	0.00	R1
0835	ROYCE HODGE	4/GULF PEARL ESTATE	6.105	0.00	R1
0836	ROYCE HODGE	5/TRACT 17	6.107	0.00	R1
00837	JOHN MEAGH	6/TRACT 50E	6.109	0.00	R1
0838	LEWIS JAMES	1/TRACT 18	6.111	25.00	R1
0839	JOHN TOUCHTON	2/TRACT 51	6.113	0.00	R1
00840	OTIS HORTON	4/TRACT 51	6.115	0.00	R1
00841	STEVE REILLY	TRACT 20	6.117	0.00	R1
0842	JIMMIE CROWDER	TRACT 19	6.119	25.00	R1
00843	R. RYAN MAXWELL	1/TRACT 21E	6.121	0.00	R1
00844	R. H. KILPATRICK	2/TRACT 22	6.123	25.00	R1
0845	J. GAULT ALLEE	TRACT 22	6.125	0.00	R1
0846	GULF COAST REALTY	2 SHELL HARBOUR	6.128	0.00	R1
00847	BEN BARRS	TRACT 23	6.130	0.00	R1
00848	JOHN BALL	1/TRACT 24	6.133	0.00	R1X
00849	MARTHA MCPHERSON	4 SHELL HARBOUR	6.135	0.00	R1X
00850	JEFF MCMILLAN	5/TRACT 25	6.137	25.00	R1

RESIDENT ACCOUNT NUMBER	NAME	SERVICE ADDRESS	BOOK /SEQ	FIELD #1 DEPOSIT	FIELD #1 RATE CODE
000851	CECIL MABE C/O ANCHOR REALTY	1/TRACT 25	6.139	40.00	R1X
000852	JAMES H. COBB	8 SHELL HARBOUR	6.141	0.00	R1
000853	E. M. POWELL	10 SHELL HARBOUR	6.143	0.00	R1
000854	CLIFF HANSON	5/TRACT 27E	6.145	0.00	R1
000855	CHARLES HURT	9 SHELL HARBOUR	6.147	0.00	R1
000856	CLARENCE GISSENDANNER	15 SHELL HARBOUR	6.149	0.00	R1
000857	LARRY BURKE	17 SHELL HARBOUR	6.151	25.00	R1
000858	CHARLES WALL	23 SHELL HARBOUR	6.153	25.00	R1
000859	ALBERS C/O LIGHTHOUSE REALTY	24 SHELL HARBOUR	6.155	0.00	R1
000860	RICHARD HOLZHAUSEN	28 SHELL HARBOUR	6.157	0.00	R1
000861	TOWNHOMES OF ST. GEORGE	SEWAGE PLANT	6.159	0.00	R1
000862	STATE OF FLORIDA - STATE PARK	STATE PARK	6.161	0.00	10
000863	MARVIN W. CARLSON	B-1 300 OCEAN MILE	6.163	25.00	R1
000864	HOMER A. OOTEN	B-2 300 OCEAN MILE	6.165	25.00	R1
000865	EVELYN STRIPLING	B-3 300 OCEAN MILE	6.169	25.00	R1
000866	LESLIE EMHOFF	B-4 300 OCEAN MILE	6.175	0.00	R1
000867	LESLIE EMHOFF	B-5 300 OCEAN MILE	6.177	0.00	R1
000868	DAVID COOK	B-6 300 OCEAN MILE	6.179	25.00	R1
000869	HELEN WILLIAMS	C-1 300 OCEAN MILE	6.181	0.00	R1
000870	WILLIAM P. SIMMONS	C-2 300 OCEAN MILE	6.183	0.00	R1
000871	RICHARD B. SMITH	C-3 300 OCEAN MILE	6.185	0.00	R1
000872	J. F. RAHEL	C-4 300 OCEAN MILE	6.187	25.00	R1
000873	WILLIAM BALDOCK	C-5 300 OCEAN MILE	6.189	0.00	R1
000874	HARRY ARNOLD	C-6 300 OCEAN MILE	6.191	0.00	R1
000875	FRED VROOM	F-1 300 OCEAN MILE	6.193	0.00	R1
000876	E & G INVESTMENTS	F-2 300 OCEAN MILE	6.195	0.00	R1
000877	J.D. GREEN C/O ANCHOR REALTY	F-3 300 OCEAN MILE	6.197	25.00	R1
000878	GULF COAST REALTY	F-4 300 OCEAN MILE	6.199	0.00	R1
000879	DEWEY STONE/GULF COAST REALTY	F-5 300 OCEAN MILE	6.201	0.00	R1
000880	JOHN J. HALAHAN	F-6 300 OCEAN MILE	6.203	25.00	R1
000881	NICK EPPS, JR.	A-1 300 OCEAN MILE	6.205	25.00	R1
000882	STUART WOLCOTT	A-2 300 OCEAN MILE	6.207	25.00	R1
000883	RONALD CUMMINGS	A-3 300 OCEAN MILE	6.209	0.00	R1
000884	PATRICIA M. POHL	A-4 300 OCEAN MILE	6.211	0.00	R1
000885	W. R. HORNE	A-5 300 OCEAN MILE	6.215	0.00	R1
000886	DR. CHARLES BIANCO	A-6 300 OCEAN MILE	6.219	0.00	R1
000887	BRUCE PETTIBONE	E-1 300 OCEAN MILE	6.221	0.00	R1
000888	JAN HEVIER	E-2 300 OCEAN MILE	6.225	0.00	R1
000889	JAMES KIDD	E-3 300 OCEAN MILE	6.229	41.92	R1
000890	JUDY WILSON	E-4 300 OCEAN MILE	6.231	25.00	R1
000891	C. EVERETT BOYD	E-5 300 OCEAN MILE	6.233	0.00	R1
000892	ROBERT SCHNEIDER	E-6 300 OCEAN MILE	6.235	0.00	R1
000893	BRUCE A. MINNICK	D-1 300 OCEAN MILE	6.237	25.00	R1
000894	LAWRENCE V. SAGER	D-2 300 OCEAN MILE	6.239	0.00	R1
000895	WILLIAM R. STANTON, JR.	D-3 300 OCEAN MILE	6.241	0.00	R1
000896	**NEW-ACCOUNT (4.11)**	D-4 300 OCEAN MILE	6.243	0.00	R1
000897	PAUL ELLIOTT	D-5 300 OCEAN MILE	6.245	25.00	R1
000898	ORRIN SKOLNICK	D-6 300 OCEAN MILE	6.247	0.00	R1
000899	DONALD A. RHETT	G-6 300 OCEAN MILE	6.249	0.00	R1
000900	ANTHONY J. TARANTO	G-5 300 OCEAN MILE	6.251	0.00	R1

STUDENT NUMBER	AGENT NAME	SERVICE ADDRESS	BOOK /SER	FIELD #1 DEPOSIT	FIELD #1 RATE CODE
0901	STONE D ATT: MRS. JAMES	G-4 300 OCEAN MILE	6.255	0.00	R1
0902	MOLENA SAND COMPANY	G-3 300 OCEAN MILE	6.259	0.00	R1
00903	ORRIN SKOLNICK	G-2 300 OCEAN MILE	6.261	0.00	R1
00904	GRACE DANBY	G-1 300 OCEAN MILE	6.263	0.00	R1
0905	TOWNHOMES OF ST. GEORGE	300 OCEAN MILE POOL	6.265	0.00	R1
00906	PAUL BARRINGER	H-1 PHASE II 300 OCEAN	7.002	25.00	R1
00907	MIKE PISCITELLI	H-2 PHASE II 300 OCEAN	7.003	40.00	R1
0908	RONALD W. ROE	H-3 PHASE II 300 OCEAN	7.005	40.00	R1
0909	MILTON BURNETT	H-4 PHASE II 300 OCEAN	7.010	25.00	R1
00910	JOANNE SOBERAY	H-5 PHASE II 300 OCEAN	7.015	0.00	R1
0911	MACK ROOKS	H-6 PHASE II 300 OCEAN	7.017	25.00	R1
0912	JEAN COLLIS	H-7 PHASE II 300 OCEAN	7.019	25.00	R1
00913	JANE R COOPER C/O ANCHOR REALT	H-8 PHASE II 300 OCEAN	7.021	40.00	R1
0914	MYRTLE KOZICH	H-9 PHASE II 300 OCEAN	7.025	25.00	R1
0915	TOWNHOMES OF ST. GEORGE	PHASE II POOL METER	7.027	0.00	R1
00916	KEN GORDON	I-1 PHASE II 300 OCEAN	7.029	76.34	R1
00917	RONALD MITCHELL	I-2 PHASE II 300 OCEAN	7.031	25.00	R1
0918	JIM BACHRACH (ANCHOR REALTY)	I-3 PHASE II 300 OCEAN	7.033	40.00	R1
0919	FRANK MIRABELLA	I-4 PHASE II 300 OCEAN	7.035	25.00	R1
00920	WILLIAM F. KRUEGER	I-5 PHASE II 300 OCEAN	7.039	40.00	R1
0921	WILLIAM WILLIFORD	I-6 PHASE II 300 OCEAN	7.041	25.00	R1
0922	JACKIE WILKES	I-7 PHASE II 300 OCEAN	7.043	25.00	R1
00923	JERRY GLEATON	I-8 PHASE II 300 OCEAN	7.045	25.00	R1
00924	CHARLES SLOMKA	I-9 PHASE II 300 OCEAN	7.047	25.00	R1
0925	LENWOOD HARRELL	J-13 PHASE II 300 OCEAN	7.049	0.00	R1
00926	LENWOOD HARRELL	J-12 PHASE II 300 OCEAN	7.051	0.00	R1
00927	STEVEN HORVATH	J-11 PHASE II 300 OCEAN	7.055	40.00	R1
0928	R. WHELAND C/O ALICE COLLINS R	J-10 PHASE II 300 OCEAN	7.059	25.00	R1
0929	FRANK A. MIRABELLA	J-9 PHASE II 300 OCEAN	7.061	0.00	R1
00930	ROBERT G. MCPHERSON, SR.	J-8 PHASE II 300 OCEAN	7.063	25.00	R1
0931	ROBERT W. CROZIER	J-7 PHASE II 300 OCEAN	7.065	0.00	R1
0932	LOULA M. FULLER	J-6 PHASE II 300 OCEAN	7.067	0.00	R1
00933	ANNA J. MATTSOIN	J-5 PHASE II 300 OCEAN	7.069	0.00	R1
0934	KEENER LYNN	J-4 PHASE II 300 OCEAN	7.073	25.00	R1
0935	DAVID VOLK	J-3 PHASE II 300 OCEAN	7.075	41.50	R1
00936	JEROME A. COOK	J-2 PHASE II 300 OCEAN	7.077	25.00	R1
00937	TERRENCE STINSON	J-1 PHASE II 300 OCEAN	7.079	0.00	R1
0938	RAY B. MURROE	K-1 PHASE II 300 OCEAN	7.081	0.00	R1
0939	RICHARD L. PUCKETT	K-2 PHASE II 300 OCEAN	7.085	0.00	R1
0940	WILLIAM E. WILLIFORD	K-3 PHASE II 300 OCEAN	7.089	0.00	R1
0941	KEVIN BELL	K-4 PHASE II 300 OCEAN	7.091	25.00	R1
0942	JEREMY GLEATON, JR.	K-5 PHASE II 300 OCEAN	7.093	25.00	R1
00943	DOUGLAS BALLARD	K-6 PHASE II 300 OCEAN	7.095	0.00	R1
0944	NANCY KRALOWETZ	K-7 PHASE II 300 OCEAN	7.097	25.00	R1
0945	JERRY GLEATON	K-8 PHASE II 300 OCEAN	7.099	0.00	R1
0946	FRED GLEATON	K-9 PHASE II 300 OCEAN	7.103	0.00	R1
00947	SAMUEL & WILDA MATHEWS	K-10 PHASE II 300 OCEAN	7.105	25.00	R1
0948	SUSAN LEE	K-11 PHASE II 300 OCEAN	7.107	25.00	R1
0949	TOWNHOMES OF ST. GEORGE	K-12 PHASE II 300 OCEAN	7.109	25.00	R1
0950	TOWNHOMES OF ST. GEORGE	K-13 PHASE II 300 OCEAN	7.111	25.00	R1

ACCOUNT NUMBER	IDENT NAME	SERVICE ADDRESS	BOOK /SEQ	FIELD #1 DEPOSIT	FIELD #1 RATE CODE
000951	WAYNE KOZICK	L-1 PHASE II 300 OCEAN	7.115	25.00	R1
000952	DEAN DANIELS	L-2 PHASE II 300 OCEAN	7.120	25.00	R1
000953	KENNETH K. KENT	L-3 PHASE II 300 OCEAN	7.125	25.00	R1
000954	GUY MOORE	L-4 PHASE II 300 OCEAN	7.127	0.00	R1
000955	CALVIN MELTON	L-5 PHASE II 300 OCEAN	7.129	0.00	R1
000956	LARRY SCHUEREN	L-6 PHASE II 300 OCEAN	7.131	25.00	R1
000957	TOM CHRISTENSON	L-7 PHASE II 300 OCEAN	7.135	36.58	R1
000958	GLENN L. BLOCKER	L-8 PHASE II 300 OCEAN	7.137	0.00	R1
000959	D. WEINER C/O ANCHOR REALTY	L-9 300 OCEAN MILE	7.139	0.00	R1
000960	DAVID PARKER	L-10 PHASE II 300 OCEAN	7.141	0.00	R1
000961	LAURENCE L. BENSON	L-11 PHASE II 300 OCEAN	7.145	0.00	R1
000962	SCOTT MCGILL	L-12 PHASE II 300 OCEAN	7.149	0.00	R1
000963	JUDY MITCHELL	L-13 PHASE II 300 OCEAN	7.153	40.00	R1
000965	KARIN J. WYATT	18779/5	2.116	40.00	R1
000966	HARRY ARNOLD	10/16/1W	4.248	40.00	R1
000967	JUDY SULLIVAN	31 TREASURE BEACH VILLAGE	1.303	40.00	R1
000968	JAMES SIBLEY C/O ANCHOR REALTY	18 DOLPHIN BEACH	1.450	25.00	R1
000969	HARRY FALK, JR.	9/J/2	5.124	25.00	R1
000970	ROY HOFFMAN, JR.	12 SEA PINE VILLAGE	1.055	40.00	R1 X
000971	JAMES E. EDENFIELD	7/M/2	5.072	40.00	R1 X
000972	KAREN HARTMANN C/O ANCHOR REAL	2/TRACT 25	6.138	40.00	R1 X
000973	R. PAUL MCBEE	19/86/5	2.028	40.00	R1 X
000974	WALTER ARMISTEAD	7/10/1E	5.370	0.00	R1 X
000975	BRADLEY D. SUBER	8 SEA PALM VILLAGE	1.082	40.00	R1 X
000976	RICHARD W. KNIGHT	1/TRACT 37E	6.012	40.00	R1 X
000977	DAVID & MARTHA FULMER	15/16/1E	3.066	40.00	R1 X
000978	DALE HERNDON	2/22/1E	3.072	40.00	R1 X
000979	WILLIE GUS CHANCY	10/61/95	2.274	40.00	
000980	E.N. REEDER C/O ANCHOR REALTY	LOT 6 NICK'S HOLE	1.124	40.00	R1 X
000981	JOHN C. BROADBUSH	33 PLANTATION BEACH VILLA	1.236	40.00	R1 X
000982	LEE NOEL	2/TRACT 5	6.008	25.00	R1
000983	O. A. FAIRCLOTH	25 SEA PALM VILLAGE	1.084	40.00	R1 X
000984	LEIGH N. CHAPMAN	1/10/1E	5.355	40.00	R1 X
000985	MARTIN J. WILLIAMS	6/TRACT 48	6.078	40.00	R1 X
000986	BEACH BUILDERS	9 DOLPHIN BEACH VILLAGE	1.424	40.00	R1 X
000987	MICHAEL & LORI RODRIGUE	11 SEA PALM VILLAGE	1.050	40.00	R1
000988	ROBERT D. HENKER	5/TRACT 42E	6.046	40.00	R1
000989	ANDY JOHNSON	4/TRACT 23	6.131	40.00	R1
000990	HAROLD E. FREDERICK	1/17/1E	5.314	40.00	R1 X
000991	KEITH & LINDA LOOMIS	30 TREASURE BEACH VILLAGE	1.301	40.00	R1 X
000992	DAVID FINDLEY	7 TREASURE BEACH VILLAGE	1.314	40.00	R1 X
000993	DANIEL E. MYERS	3/TRACT 11E	6.074	40.00	R1 X
000994	AL SPARKS	7/65/5	2.214	40.00	R1
000995	WALTER ARMISTEAD	3/10/1E	5.364	0.00	R1 X
000996	ANCHOR REALTY (SUSAN GIN)	4/10/1E	5.366	40.00	R1 X
000997	WALTER ARMISTEAD	5/10/1E	5.368	0.00	R1 X
000998	WALTER ARMISTEAD	6/10/1E	5.369	0.00	R1 X
000999	J. RITTENDOUR C/O WM. BRACKIN	4/24/1W	4.236	40.00	R1
1000	KAREN MYERS	31 SEA PINE VILLAGE	1.058	40.00	R1
1001	DENNIS BARNELL	17/86/5	2.026	40.00	R1

ACCOUNT NUMBER	RESIDENT NAME	SERVICE ADDRESS	BOOK /SEQ	FIELD #1 DEPOSIT	RATE CODE	FIELD #1
001002	LEE KNOWLES	• 2 TREASURE BEACH	1.308	40.00	R1X	
001003	DOUGLAS P. SHERMAN	• 28 SEA PALM VILLAGE	1.088	40.00	R1X	
001004	JOHN & BONNIE KELLER	• 8 PELICAN BEACH VILLAGE	1.366	40.00	R1X	
001005	NELSON KRAEFT	• 3/TRACT 23	6.129	40.00	R1X	
001006	HENRY L. KOZLOWSKY	• 15 BAY COVE VILLAGE	1.376	40.00	R1X	
001007	WILLIAM H. & DOROTHY C. WILSON	• 3/18/1E	5.326	0.00	R1X	
001008	WILLIAM H. & DOROTHY C. WILSON	• 10/C/3	4.106	0.00	R1X	
001009	WILLIAM H. & DOROTHY C. WILSON	• 1/11/1E	5.330	0.00	R1X	
001010	WILLIAM H. & DOROTHY C. WILSON	• 6/14/1W	2.396	0.00	R1X	
001011	WILLIAM H. & DOROTHY C. WILSON	• 7/14/1W	2.397	0.00	R1X	
001012	WILLIAM H. & DOROTHY C. WILSON	• 8/14/1W	2.398	0.00	R1X	
001013	WILLIAM H. & DOROTHY C. WILSON	• 26/6/1E	3.062	0.00	R1X	
001014	WILLIAM H. & DOROTHY C. WILSON	• 29/6/1E	3.063	0.00	R1X	
001015	WILLIAM H. & DOROTHY C. WILSON	• 1/4/1E	3.047	0.00	R1X	
001016	WILLIAM H. & DOROTHY C. WILSON	• 6/7/1W	3.020	0.00	R1X	
001017	WILLIAM H. & DOROTHY C. WILSON	• 7/7/1W	3.021	0.00	R1X	
001018	PHOENIX-HARBOUR	• 21 PEBBLE BEACH	1.140	0.00	R1X	
001019	PHOENIX-HARBOUR	• 22 PEBBLE BEACH	1.141	0.00	R1X	
001020	WALTER ARMISTEAD	• 2/10/1E	5.356	0.00	R1X	
001021	WALTER ARMISTEAD	• 8/10/1E	5.357	0.00	R1X	
001022	WALTER ARMISTEAD	• 9/10/1E	5.358	0.00	R1X	
001023	WALTER ARMISTEAD	• 10/10/1E	5.359	0.00	R1X	
001024	WALTER ARMISTEAD	• 11/10/1E	5.360	0.00	R1X	
001025	WALTER ARMISTEAD	• 12/10/1E	5.361	0.00	R1X	
001026	WALTER ARMISTEAD	• 13/10/1E	5.362	0.00	R1X	
001027	WALTER ARMISTEAD	• 14/10/1E	5.363	0.00	R1X	

14146.50

Number of accounts printed is 1027

04/30/92 ¹⁰²⁶

CUSTOMERS WITH NO METERS

04/30/92

11-00
5/1/92
15...

IDENT NUMBER	OWNER ACCOUNT NUMBER	NAME	SERVICE ADDRESS	BOOK /SEQ	CURRENT USAGE
000006	NO METER	MFG. VENTURES	4 OSPREY	1.011	0
000007	NO METER	MFG. VENTURES	5 OSPREY	1.013	0
000011	NO METER	MFG. VENTURES	20 OSPREY	1.021	0
000013	NO METER	JACK BUFORD	11B SEA DUNE VILLAGE	1.025	0
000036	NO METER	WILLIAM SOLBURG	10 BAY PALM VILLAGE	1.071	0
000049	NO METER	T. A. FIELD	44 SEA PALM VILLAGE	1.097	0
000055	NO METER	BILL DEVO, JR.	60 SEA PALM VILLAGE	1.109	0
000065	NO METER	WILLIAM POLDRONIS	5 PEBBLE BEACH VILLAGE	1.129	0
000070	NO METER	PHILLIP M. PAYNE III	21 SANDPIPER VILLAGE	1.142	0
000071	NO METER	R. FUNK 1202 KILDONAN DR.	24 SANDPIPER VILLAGE	1.143	0
000072	NO METER	TOM TIFFIN	28 SANDPIPER VILLAGE	1.145	0
000076	NO METER	DOROTHY SLAGHT	51 PEBBLE BEACH VILLAGE	1.153	0
000077	NO METER	TERRA INC.	52 PEBBLE BEACH VILLAGE	1.155	0
000082	NO METER	GEORGE KLEINE	6 WINDJAMMER VILLAGE	1.165	0
000086	NO METER	MATTHEW MORGAN	67 PEBBLE BEACH VILLAGE	1.173	0
000089	NO METER	MATTHEW MORGAN	5 TURTLE BEACH VILLAGE	1.179	0
000099	NO METER	JERRY HOLMES	37 TURTLE BEACH VILLAGE	1.199	0
000102	NO METER	GARY ULRICH	40 WINDJAMMER VILLAGE	1.205	0
000104	NO METER	DELAND/NGELL	36 TURTLE BEACH VILLAGE	1.209	0
000110	NO METER	JACK BUFORD (JULIUS)	49 TURTLE BEACH VILLAGE	1.221	0
000111	NO METER	J. J. GLEATON	50 TURTLE BEACH VILLAGE	1.223	0
000116	NO METER	MFG. VENTURES	65 PLANTATION BEACH VILL.	1.233	0
000121	NO METER	MIKE & GEENA FIRST	2 PLANTATION BEACH VILL.	1.243	0
000123	NO METER	JAMES TUNNELL	6 PLANTATION BEACH VILL.	1.247	0
000130	NO METER	MFG. VENTURES	58 PLANTATION BEACH VILL.	1.261	0
000135	NO METER	HARRY L. TUCKER	15 PLANTATION BEACH VILL.	1.271	0
000140	NO METER	ROBERT WILKINSON	47 PLANTATION BEACH VILL.	1.281	0
000141	NO METER	MFG. VENTURES	52 PLANTATION BEACH VILL.	1.283	0
000142	NO METER	MICHAEL A. BELL	54 PLANTATION BEACH VILL.	1.285	0
000143	NO METER	JOSEPH A. D'AIELLO	55 PLANTATION BEACH VILL.	1.287	0
000149	NO METER	JAMES TUNNELL	4 INDIAN BAY VILLAGE	1.299	0
000157	NO METER	ANDREW RALPH HARWOOD	8 TREASURE BEACH VILLAGE	1.315	0
000158	NO METER	WILLIAM KESSLER	17 INDIAN BAY VILLAGE	1.317	0
000161	NO METER	RAY STANARD	46 TREASURE BEACH VILLAGE	1.323	0
000162	NO METER	MFG. VENTURES	49 TREASURE BEACH VILLAGE	1.325	0
000172	NO METER	JEROME W. KOWALSKI	23 INDIAN BAY VILLAGE	1.345	0
000173	NO METER	JOHN STRICKLAND	24 INDIAN BAY VILLAGE	1.347	0
000175	NO METER	JAMES H. GREEN	58 PELICAN BEACH VILLAGE	1.351	0
000177	NO METER	MICHAEL R. BRITTON	55 PELICAN BEACH VILLAGE	1.355	0
000178	NO METER	DONALD PFAENDER	1 PELICAN BEACH VILLAGE	1.357	0
000179	NO METER	ROBERT WILKINSON	37 PELICAN BEACH VILLAGE	1.359	0
000184	NO METER	RUTH O'DONNELL	10/J/2	5.126	0
000185	NO METER	MFG. VENTURES	3 BAY COVE VILLAGE	1.371	0
000186	NO METER	JAMES KENT, JR.	4 BAY COVE VILLAGE	1.373	0
000188	NO METER	BRUCE KRUEGER	31 BAY COVE VILLAGE	1.377	0
000190	NO METER	JOSEPH B. BURGESS	48 PELICAN BEACH VILLAGE	1.381	0
000191	NO METER	ISHMAEL H. JOHNSON, JR.	50 PELICAN BEACH VILLAGE	1.383	0
000192	NO METER	ROBERT WILKINSON	43 PELICAN BEACH VILLAGE	1.385	0
000193	NO METER	GENE BELANGER	23 PELICAN BEACH VILLAGE	1.387	0
000194	NO METER	RODERICK & KATHERINE DAVIS, III	13 PELICAN BEACH VILLAGE	1.389	0

04/30/92

PAGE 1

EXHIBIT 5

CUSTOMERS WITH NO METERS

04/30/92

STUDENT COUNCIL NUMBER	OWNER ACCOUNT NUMBER	NAME	SERVICE ADDRESS	BOOK /SEQ	CURRENT USAGE

0195	NO METER	RICHARD BURMAN	14 PELICAN BEACH VILLAGE	1.391	0
0196	NO METER	WILLIAM G. THAMES	15 PELICAN BEACH VILLAGE	1.393	0
000197	NO METER	TERRELL C. TEMPLIN	16 PELICAN BEACH VILLAGE	1.395	0
0200	NO METER	THOMAS L. OUTLAW	26 BAY COVE VILLAGE	1.401	0
0201	NO METER	LARRY C. STRONGOSKI	19 BAY COVE VILLAGE	1.403	0
000202	NO METER	GENE BELANGER	28 DOLPHIN BEACH VILLAGE	1.405	0
000203	NO METER	CARMEN FIGUEROA	41 DOLPHIN BEACH VILLAGE	1.407	0
0204	NO METER	HERMAN W. LAYFIELD	40 DOLPHIN BEACH VILLAGE	1.409	0
0205	NO METER	WILLIAM E. SWAB	39 DOLPHIN BEACH VILLAGE	1.411	0
000207	NO METER	ROBERT W. McMILLAN	29 DOLPHIN BEACH VILLAGE	1.415	0
0211	NO METER	PHILLIP R. LUBBERS	8 DOLPHIN BEACH VILLAGE	1.423	0
0212	NO METER	JAMES MOORE	25 DOLPHIN BEACH VILLAGE	1.425	0
000213	NO METER	DANIEL Y. SUMNER	26 DOLPHIN BEACH VILLAGE	1.427	0
0214	NO METER	GLEN WOODSUM	27 DOLPHIN BEACH VILLAGE	1.429	0
0216	NO METER	ROGER BERNOT	13 DOLPHIN BEACH VILLAGE	1.433	0
000218	NO METER	JERRY OSTERYOUNG	20 DOLPHIN BEACH VILLAGE	1.437	0
000222	NO METER	FRANK SANCHEZ	19 DOLPHIN BEACH VILLAGE	1.445	0
0227	NO METER	JOSEPHINE MOORE	74 SEA PALM VILLAGE	1.455	0
0229	NO METER	ELDEN W. BUTZBAUGH, JR.	11 DOLPHIN BEACH VILLAGE	1.434	0
000272	NO METER	NELLE LANDRUM	13/76/5	2.085	0
0361	NO METER	HAROLD RUDD	15/61/5	2.263	0
0397	NO METER	HUBERT KADEL	5/57/5	2.335	0
000417	NO METER		3/51/5	2.375	0
000428	NO METER	HELEN SPOHRER--PHEONIX HARBOUR	OLD MARINA/TRACT A	2.399	0
0431	NO METER	ROBERT W. CLARK	10/14/1W	2.403	0
000436		MIKE BURTON	18/15/1W	2.413	0
000447	NO METER	JOANN WINGLER	1/24/1W	2.435	0
0461	NO METER	DANNY BROWN	9/82/5	2.463	0
000481	NO METER	ROSEHILL LAND COMPANY	REALTY SALES OFFICE	3.033	0
000485	NO METER	BURBA'S BEACH CLUB	4-5/8/1E	3.041	0
0490	NO METER	JAMES HOLZHAUSEN	21/5/1E	3.051	0
0523	NO METER	WENDELL LACY	10/45/4	3.117	0
000535	NO METER	SGI BEAUTIFICATION COMM.	MEDIAN LANSCAPING	7.001	0
000567	NO METER	W.D. BELL	2/A/3	4.061	0
000618	NO METER	CHARLES W. NOBLEY JR	3/0/3	4.165	0
000621	NO METER	JOANNA DOLLOFF	10/N/3	4.171	0
000648	NO METER	DONALD E. WATERS SR.	7/K/3	4.225	0
000651	NO METER	WILLIAM H. HICKS	3/L/3	4.231	0
000678	NO METER	GRADY UNDERWOOD	9/21/1E	5.025	0
000713	NO METER	KELLY	6/15/1W	2.386	0
000735	NO METER	ROBERT FILCHER	1/TRACT 3	6.001	0
000736	NO METER	ROBERT S. LEGG	2/TRACT 3	6.003	0
000797	NO METER	DENNIS SMITH	3/TRACT 3	6.005	0
000798	NO METER	DENNIS SMITH	4/TRACT 3	6.007	0
000812	NO METER	RON J. BROWN	3/TRACT 42E	6.045	0
000834	NO METER	ROYCE HODGE	3/TRACT 17E	6.101	0
000837	NO METER	JOHN MEAGH	6/TRACT 50E	6.109	0
000865	NO METER	KARIN J. WYATT	13/73/5	2.116	0
000979	NO METER	WILLIE GUS CHANCY	10/61/9	2.274	0
000987	NO METER	MICHAEL & LORI RODRIGUE	11 SEA PALM VILLAGE	1.080	0

04/30/92

PAGE 2


CUSTOMERS WITH NO METERS

04/30/92

IDENT	OWNER	ACCOUNT	ACCOUNT	BOOK	CURRENT
NUMBER	NUMBER	NAME	SERVICE ADDRESS	/SEQ	USAGE
000988	NO METER	ROBERT D. HENNER	5/TRACT 42E	6.046	0
0989	NO METER	ANDY JOHNSON	4/TRACT 23	6.131	0
0999	NO METER	J. RITTENDOUR C/O WM. BRACKIN	4/24/1W	4.236	0
001000	NO METER	KAREN MYERS	31 SEA PINE VILLAGE	1.058	0
1002	NO METER	LEE KNOWLES	2 TREASURE BEACH	1.308	0
1003	NO METER	DOUGLAS P. SHERMAN	28 SEA PALM VILLAGE	1.088	0
001004	NO METER	JOHN & BONNIE KELLER	8 PELICAN BEACH VILLAGE	1.366	0
001005	NO METER	NELSON KRAEFT	3/TRACT 23	6.129	0
1006	NO METER	HENRY L. KOZLOWSKY	15 BAY COVE VILLAGE	1.376	0
001007	NO METER	WILLIAM H. & DOROTHY C. WILSON	3/18/1E	5.326	0
001008	NO METER	WILLIAM H. & DOROTHY C. WILSON	10/C/3	4.106	0
1009	NO METER	WILLIAM H. & DOROTHY C. WILSON	1/11/1E	5.330	0
1010	NO METER	WILLIAM H. & DOROTHY C. WILSON	6/14/1W	2.396	0
001011	NO METER	WILLIAM H. & DOROTHY C. WILSON	7/14/1W	2.397	0
001012	NO METER	WILLIAM H. & DOROTHY C. WILSON	8/14/1W	2.398	0
1013	NO METER	WILLIAM H. & DOROTHY C. WILSON	26/6/1E	3.062	0
001014	NO METER	WILLIAM H. & DOROTHY C. WILSON	29/6/1E	3.063	0
001015	NO METER	WILLIAM H. & DOROTHY C. WILSON	1/4/1E	3.047	0
1016	NO METER	WILLIAM H. & DOROTHY C. WILSON	6/7/1W	3.020	0
001017	NO METER	WILLIAM H. & DOROTHY C. WILSON	7/7/1W	3.021	0
001018	NO METER	PHOENIX-HARBOUR	21 PEBBLE BEACH	1.140	0
1019	NO METER	PHOENIX-HARBOUR	22 PEBBLE BEACH	1.141	0
1020	NO METER	WALTER ARMISTEAD	2/10/1E	5.356	0
001021	NO METER	WALTER ARMISTEAD	8/10/1E	5.357	0
001022	NO METER	WALTER ARMISTEAD	9/10/1E	5.358	0
1023	NO METER	WALTER ARMISTEAD	10/10/1E	5.359	0
001024	NO METER	WALTER ARMISTEAD	11/10/1E	5.360	0
001025	NO METER	WALTER ARMISTEAD	12/10/1E	5.361	0
1026	NO METER	WALTER ARMISTEAD	13/10/1E	5.362	0
001027	NO METER	WALTER ARMISTEAD	14/10/1E	5.363	0

0

Number of accounts printed is 130



LEGEND

- 105 NODE NUMBER
- GST EXIST. 300,000 GAL. GROUND STORAGE TANK
- ET EXIST. 150,000 GAL. ELEVATED TANK
- P EXIST. PUMP

EXHIBIT 6A

DISTRIBUTION SYSTEM KEY MAP
 ST. GEORGE ISLAND WATER SYSTEM
 FRANKLIN COUNTY, FLORIDA

EXHIBIT 7

ERU DEMAND CALCULATIONS
SELECTED MONTHS - 1991

<u>MONTH</u>	<u>ADF (MGD)</u>	<u>MDF (MGD)</u>	<u>ADF/CONN gpd</u>	<u>MDF/CONN gpd</u>
JANUARY	.155	.335	180	390
JULY	.289	.424	336	493
SEPTEMBER	.207	.361	240	419
NOVEMBER	<u>.160</u>	<u>.239</u>	<u>187</u>	<u>277</u>
AVERAGE	.203	.340	235	350

SOURCE: Flows FDER Monthly Operating Reports

Approximate Number of Connections = 860 (See EXHIBIT 3).

ERU Demand Average (ADF + MDF) = $235 + 350/2 = 292$ gpd.

ERU Demand shall be 300 gpd to account for variable seasonal flows.

DRINKING WATER TREATMENT PLANT DAILY OPERATION SUMMARY

10/29/91

Copy John Pope & File on

5/2/91

PHS ID No. 1190781 Name of Drinking Water System Saint George Island Utilities

Location City or S/V St George Island, Florida County Franklin

Owned by St. George Island Utilities Company, Inc Reporting Month September 1991

Plant Effluent pH 7.5 (Avg) No. of Services at End of Month 929

Design Flow 750 gpm Remarks (Use reverse side) Plant No. 6278884

I certify this report is correct Wayne Com. Q B 2713
(Lead Operator's Signature) (Dist. Level) (Dist. No.)

Days of Month	Total Water Treated in Thousands of Gallons	GAS Chlorine		In. H ₂ O	mg/l	In. H ₂ O	mg/l	Residual Chlorine mg/l		Number of Samples Taken	Bacteriological MCL Violations
		gals. nr (lb.) Used	mg/l					Plant Effluent	Residual Tap		
Monthly Total	6219.0	219.0	114.1					71.8	12.9	4	NONE
Average	207.3	7.3	3.8					100.0	0.4		
Maximum	361.0	13.0	7.5					100.0	0.5		
Minimum	130.0	5.0	2.29					100.0	0.4		
1	307.0	7.0	4.31					100.0	0.5		
2	367.0	13.0	4.31					100.0	0.4		
3	285.0	10.0	4.20					100.0	0.5		
4	151.0	5.0	3.97					100.0	0.4		
5	165.0	6.0	4.36					100.0	0.5		
6	162.0	6.0	4.44					100.0	0.5		
7	211.0	7.0	3.98					100.0	0.5		
8	182.0	6.0	3.85					100.0	0.5		
9	130.0	5.0	4.61					100.0	0.4		
10	178.0	6.0	4.04					100.0	0.4		
11	309.0	11.0	4.27					100.0	0.5		
12	188.0	7.0	4.46					100.0	0.4		
13	175.0	6.0	4.11					100.0	0.4		
14	251.0	9.0	4.30					100.0	0.5		
15	227.0	8.0	4.22					100.0	0.5		
16	201.0	7.0	4.17					100.0	0.4		
17	188.0	7.0	4.44					100.0	0.4		
18	173.0	6.0	4.15					100.0	0.4		
19	175.0	6.0	4.11					100.0	0.4		
20	176.0	6.0	4.08					100.0	0.4		
21	219.0	8.0	4.38					100.0	0.4		
22	239.0	8.0	4.01					100.0	0.5		
23	236.0	8.0	4.06					100.0	0.4		
24	173.0	6.0	4.15					100.0	0.4		
25	174.0	6.0	4.13					100.0	0.4		
26	175.0	6.0	4.17					100.0	0.3		
27	161.0	6.0	4.46					100.0	0.3		
28	196.0	7.0	4.28					100.0	0.4		
29	251.0	9.0	4.30					100.0	0.4		
30	200.0	7.0	4.19					100.0	0.4		
31											

This form must be completed in full and submitted to the appropriate DER or County Health Department office within 15 days after the month of record. Notes: fold top flap down, fold this flap up over it, then staple or tape.

Received

OCT 21 1991

DER, Tallahassee
Branch Office

DRINKING WATER TREATMENT PLANT DAILY OPERATION SUMMARY

MS ID No. 1190781 Name of Drinking Water System Saint George Island Utilities
 Location: City or S/O St George Island, Florida County FRANKLIN
 Owned by St. George Island Utilities Company, Ltd Reporting Month JANUARY 1991
 Plant Effluent pH 7.3 (Avg) No. of Services at End of Month 929
 Leaking Flow 750gpm Remarks (Use reverse side) Phone No.: 6278884
 I certify this report is correct Wayne Conrad B 2
 (Lead Operator's Signature) (Cert. Level) (Cert. No.)

Days of Month	Total Water Treated in Thousands of Gallons	GAS Chlorine		In line	mg/l	In line	mg/l	Residual Chlorine mg/l		Number of Samples taken	Bacteriological MCL Violations
		gals. or (Tm) Used	mg/l					Plant Effluent	Residual Tap		
Monthly Total	4793.0	93.0	10.8					106.9	15.6	4	none
Average	157.6	3.0	2.5					3.7	0.5		
Maximum	335.0	3.0	3.8					3.5	0.5		
Minimum	98.0	3.0	1.1					3.1	0.5		
1	98.0	3.0	3.8					3.5	0.5		
2	98.0	3.0	3.8					3.5	0.5		
3	93.0	3.0	3.8					3.5	0.5		
4	163.0	3.0	2.1					3.5	0.5		
5	158.0	3.0	2.3					3.5	0.5		
6	160.0	3.0	2.3					3.5	0.5		
7	146.0	3.0	2.5					3.5	0.5		
8	148.0	3.0	2.5					3.5	0.5		
9	153.0	3.0	2.3					3.5	0.2		
10	153.0	3.0	2.3					3.5	0.3		
11	151.0	3.0	2.3					3.1	0.3		
12	151.0	3.0	2.3					3.1	0.3		
13	138.0	3.0	2.3					3.1	0.3		
14	156.0	3.0	2.3					3.1	0.3		
15	156.0	3.0	2.3					3.5	0.5		
16	277.0	3.0	1.2					3.5	0.5		
17	166.0	3.0	3.8					3.5	0.6		
18	191.0	3.0	3.3					3.5	0.7		
19	177.0	3.0	2.0					3.5	0.7		
20	116.0	3.0	3.0					3.5	0.7		
21	117.0	3.0	2.1					3.5	0.6		
22	141.0	3.0	2.1					3.5	0.5		
23	211.0	3.0	1.7					3.5	0.6		
24	335.0	3.0	1.1					3.5	0.5		
25	151.0	3.0	2.3					3.5	0.4		
26	154.0	3.0	2.3					3.5	0.7		
27	124.0	3.0	3.0					3.5	0.7		
28	121.0	3.0	3.0					3.5	0.6		
29	132.0	3.0	2.7					3.5	0.5		
30	142.0	3.0	2.5					3.5	0.5		
31	142.0	3.0	2.5					3.5	0.5		

This form must be completed in full and submitted to the appropriate DER or County Health Department office within 15 days after the month of record. Note: fold top flap down, fold this flap up over it, then staple or tape.

FEB 27 1991

DER, Tallahassee
 Branch Office

DRINKING WATER TREATMENT PLANT DAILY OPERATION SUMMARY

file

DWS ID No. 11901891 Name of Drinking Water System Saint George Island Utilities

Location City or S/D St George Island, Florida County FRANKLIN

Owned by St. George Island Utilities Company, LLC Reporting Month July 1991

Plant Effluent pH 7.4 (Avg) No. of Services at End of Month 929

Design Flow 750gpm Remarks (Use reverse side) Plant No. 6278884

I certify this report is correct Wayne Conrad B 2713
(Plant Operator's Signature) (Cert. Level) (Cert. No.)

Days of Month	Total Water Treated in Thousands of Gallons	GAS Chlorine		ftm ftm	mg/l	ftm ftm	mg/l	Residual Chlorine mg/l		Number of Samples taken	Bacteriological MCL Violations
		gals. or (lbs) Used	mg/l					Plant Effluent	Remote Tap		
Monthly Total	8961.0	373.0	129.7					77.7	18.0	4	none
Average	271.1	11.4	4.0					2.5	0.3		
Maximum	424.0	15.0	4.7					3.5	0.6		
Minimum	178.0	6.0	4.0					2.0	0.2		
1	288.0	10.0	4.16					3.5	0.2		
2	311.0	11.0	4.24					3.5	0.2		
3	344.0	12.0	4.18					2.0	0.2		
4	264.0	9.0	4.08					2.5	0.3		
5	424.0	15.0	4.24					2.5	0.3		
6	411.0	14.0	4.06					3.5	0.2		
7	411.0	14.0	4.06					2.0	0.4		
8	271.0	10.0	4.42					2.5	0.4		
9	287.0	10.0	4.17					2.0	0.3		
10	265.0	9.0	4.07					2.5	0.4		
11	256.0	9.0	4.21					2.5	0.4		
12	282.0	10.0	4.25					2.5	0.3		
13	309.0	11.0	4.26					2.7	0.4		
14	320.0	11.0	4.12					2.7	0.3		
15	279.0	10.0	4.19					2.7	0.3		
16	237.0	8.0	4.11					2.4	0.3		
17	335.0	12.0	4.29					2.9	0.3		
18	179.0	6.0	4.01					2.9	0.3		
19	293.0	10.0	4.09					2.5	0.3		
20	289.0	10.0	4.14					2.4	0.3		
21	378.0	13.0	4.12					2.5	0.3		
22	232.0	8.0	4.13					2.6	0.2		
23	279.0	10.0	4.29					2.5	0.2		
24	277.0	10.0	4.42					2.5	0.3		
25	291.0	10.0	4.12					2.4	0.2		
26	265.0	9.0	4.07					2.0	0.3		
27	295.0	10.0	4.06					2.3	0.5		
28	347.0	12.0	4.14					2.1	0.4		
29	258.0	9.0	4.15					2.0	0.4		
30	281.0	10.0	4.26					2.0	0.5		
31	308.0	11.0	4.28					2.1	0.6		

This form must be completed in full and submitted to the appropriate UER or County Health Department office within 15 days after the month of record. Note: Fold top flap down, fold this flap up over it, then staple or tape.

UER Form 17-1.208(5)
Effective November 30, 1982

Received
SEP 4 1991
UER, Tallahassee
Branch Office

DRINKING WATER TREATMENT PLANT DAILY OPERATION SUMMARY

JAN 7 - 1991

PMS ID No. 1190781 Name of Drinking Water System Saint George Island Utilities

Location City or S/O St George Island, Florida County FRANKLIN

Owned by St. George Island Utilities Company, Ltd Reporting Month November 1991

Plant Effluent pH 7.3 (Avg) No. of Services at End of Month 929

Design Flow 750 gpm Remarks (Use reverse side) Plant No. 6278884

I certify this report is correct Greg Hamney (Cert. Level) C (Cert. No.) 5955

Days of Month	Total Water Treated in Thousands of Gallons	GAS Chlorine		lin	mg/l	lin	mg/l	Residual Chlorine		Number of Samples taken	Bacteriological MCL Violations
		gal. or (lb) Used	mg/l					Plant Effluent	Residual Tap		
Monthly Total	4,798.0	167.0	125.0					72.50	9.30	4	none
Average	160.0	5.60	4.20					2.42	0.31		
Maximum	239.0	8.0	4.60					2.60	0.40		
Minimum	119.0	4.0	3.9					2.30	0.30		
1	169.0	6.0	4.3					2.4	0.3		
2	180.0	6.0	4.0					2.3	0.3		
3	200.0	7.0	4.2					2.4	0.3		
4	200.0	7.0	4.2					2.4	0.3		
5	170.0	6.0	4.2					2.4	0.3		
6	180.0	6.0	4.0					2.3	0.3		
7	129.0	5.0	4.6					2.4	0.3		
8	150.0	5.0	4.0					2.4	0.3		
9	187.0	7.0	4.5					2.5	0.3		
10	170.0	6.0	4.2					2.4	0.3		
11	170.0	6.0	4.2					2.4	0.3		
12	122.0	4.0	3.9					2.3	0.3		
13	143.0	5.0	4.2					2.4	0.3		
14	143.0	5.0	4.2					2.4	0.3		
15	165.0	6.0	4.4					2.4	0.3		
16	157.0	6.0	4.6					2.5	0.3		
17	175.0	6.0	4.1					2.5	0.3		
18	122.0	4.0	3.9					2.6	0.4		
19	124.0	4.0	3.9					2.5	0.3		
20	124.0	4.0	3.9					2.5	0.3		
21	124.0	4.0	3.9					2.5	0.3		
22	123.0	4.0	3.9					2.4	0.3		
23	119.0	4.0	4.0					2.4	0.3		
24	133.0	5.0	4.5					2.5	0.3		
25	139.0	5.0	4.3					2.4	0.3		
26	155.0	6.0	4.6					2.3	0.3		
27	154.0	5.0	3.9					2.4	0.3		
28	209.0	7.0	4.0					2.4	0.3		
29	223.0	8.0	4.3					2.4	0.4		
30	239.0	8.0	4.0					2.4	0.3		
31											

This form must be completed in full and submitted to the appropriate UCR or County Health Department office within 15 days after the month of record. Note: Fold top flap down; fold this flap up over it, then staple or tape.

Received
DEC 31 1991
DEB, Tallahassee
Water Office

EXHIBIT 8

COMMERCIAL ACCOUNT ERU CALCULATIONS

CUSTOMER: CITY OF ST. GEORGE

MONTH	TOTAL MONTHLY FLOWS (THOUS. GAL.)	
	1989	1991
APR	258.7	182.9
MAY	324.1	114.2
JUN	401.0	272.2
JUL	323.4	247.0
AUG	382.0	362.8
SEP	119.7	157.4
OCT	204.8	78.0
AVERAGE	280.6	207.1

ERU'S = ((AVERAGE)/30 DAYS)/300 GAL PER ERU PER DAY

NO. OF EQUIVALENT RESIDENTIAL UNITS (ERU'S) = 27

EXHIBIT 2

COMMERCIAL ACCOUNT ERU CALCULATIONS

CUSTOMER: JULIAN G. BRUCE STATE PARK

MONTH	TOTAL MONTHLY FLOWS (THOUS. GAL.)		
	1988	1989	1991
APR	79.2	439.9	182
MAY	697.7	841.4	242.1
JUN	826.4	939.2	295.7
JUL	54.8	553.3	200.3
AUG	54.8	606.8	360.0
SEP	368.8	461.8	200.0
OCT		588.6	60.0
AVERAGE	346.9	633.3	221.0

ERU'S = ((AVERAGE)/30 DAYS)/300 GAL PER ERU PER DAY

NO. OF EQUIVALENT RESIDENTIAL UNITS (ERU'S) = 45.0

EXHIBIT 8

COMMERCIAL ACCOUNT ERU CALCULATIONS

BUCCANEER 1 (BUCCABEET) INP 11

MONTH	TOTAL SEWER FLOWS (THOUS. GALL.)	
	1988	1989
APR	30.3	67.9
MAY	27.7	70.8
JUN	111.7	139.8
JUL	70.4	113.5
AUG	86.4	11.3
SEP	7.7	50.7
OCT	22.0	37.7
AVERAGE	57.2	70.2

ERU'S = ((AVERAGE)/30 DAYS)/300 GAL PER ERU PER DAY

NO. OF EQUIVALENT RESIDENTIAL UNITS (ERU'S) = 7

ASSUME ERU'S FOR BUCCANEER 1 = 7 ALSO. TOTAL = 14

EXHIBIT 8

COMMERCIAL ACCOUNT ERU CALCULATIONS

CUSTOMER: H. L. FOOD STORE

MONTH	TOTAL MONTHLY FLOWS (THOUS. GALS.) 1991
APR	18.11
MAY	24.95
JUN	39.93
JUL	62.75
AUG	47.9
SEP	68.0
OCT	53.3
AVERAGE	45.0

ERU'S = ((AVERAGE/30 DAYS))/300 GAL PER ERU PER DAY

NO. OF EQUIVALENT RESIDENTIAL UNITS (ERU'S) = 5

USE 5 ERU'S FOR ALL CONVENIENCE STORES

EXHIBIT 2

COMMERCIAL ACCOUNT ERU CALCULATIONS

CUSTOMER: ISLANDER RESTAURANT

MONTH	DAILY MONTHLY FLOW (GPM) (GAL/D)	
	1989	1991
APR	24.6	46.0
MAY	46.0	49.5
JUN	45.5	55.6
JUL	28.0	57.2
AUG	52.4	49.8
SEP	19.9	50.7
OCT	28.2	24.7
AVERAGE	38.1	49.1

(GPM) (AVERAGE) (30 DAYS) / 300 GAL PER ERU PER DAY

NO. OF EQUIVALENT RESIDENTIAL UNITS (ERU'S) = 5.0

EXHIBIT 9

COMMERCIAL ACCOUNT ERU CALCULATIONS

CUSTOMER: TOWNHOMES OF ST. GEORGE (WWT)

MONTH	TOTAL MONTHLY FLOWS (THOUS. GAL.)	
	1988	1991
APR	76.7	97.4
MAY	79.1	172.5
JUN	59.2	168.6
JUL	74.7	141.2
AUG	24.2	205.6
SEP	0.0	245.6
OCT	0.0	199.0
AVERAGE	52.7	174.1

ERU'S = ((AVERAGE/30 DAYS))/300 GAL PER ERU PER DAY

NO. OF EQUIVALENT RESIDENTIAL UNITS (ERU'S) = 13

EXHIBIT 8

COMMERCIAL ACCOUNT ERU CALCULATIONS

CUSTOMER: ST. GEORGE INN

MONTH	TOTAL MONTHLY FLOWS (THOUS. GALL.)	
	1988	1991
APR	54.0	26.9
MAY	90.9	48.6
JUN	81.2	66.6
JUL	58.2	39.2
AUG	59.4	49.1
SEP	20.6	63.8
OCT	58.8	44.7
AVERAGE	62.0	48.4

ERU'S = ((AVERAGE/30 DAYS))/300 GAL PER ERU PER DAY

NO. OF EQUIVALENT RESIDENTIAL UNITS (ERU'S) = 6

EXHIBIT 8

COMMERCIAL ACCOUNT ERU CALCULATIONS

CUSTOMER: HAPPY PELICAN

MONTH	TOTAL MONTHLY FLOW (THOUS. GAL.)	
	1988	1991
APR	37.8	23.4
MAY	34.1	19.1
JUN	46.9	23.0
JUL	20.4	15.9
AUG	53.0	15.8
SEP	27.8	16.6
OCT	11.2	12.6
AVERAGE	33.0	17.9

$ERU'S = ((AVERAGE/30 DAYS))/300 \text{ GAL PER ERU PER DAY}$

NO. OF EQUIVALENT RESIDENTIAL UNITS (ERU'S) = 3

EXHIBIT 9
COVINGTON PROPERTIES DEVELOPMENT

ERU CALCULATION

1ST YEAR

A. Dry Storage Building -

$$2 @ 400 \text{ gpd} = 800 \text{ gpd}$$

B. 14 Resident Units -

$$14 @ 300 \text{ gpd} = 4,200 \text{ gpd}$$

2ND YEAR

A. 12 Unit Resident (Herron Property) -

$$12 @ 300 \text{ gpd} = 3,600 \text{ gpd}$$

B. 36 Units on Beach (Condos.) -

$$36 @ 300 \text{ gpd} = 10,800 \text{ gpd}$$

3RD YEAR

A. Marina: 75 Slips @ 40 gpd = 3,000 gpd

B. 60 Resident Units: 60 @ 300 gpd = 18,000 gpd

4TH/5TH YEAR

A. Shops, Rest., Oyster Bar -

$$22,000 \text{ S.F.} @ 0.5 \text{ gal/day/S.F.} = 11,000 \text{ gpd}$$

B. 36 Boatel Units -

$$36 @ 150 \text{ gal/rm/day} = 5,400 \text{ gpd}$$

5TH/6TH YEAR

A. 100 Resid. Units (Condos.) -

$$100 @ 300 = \underline{30,000} \text{ gpd}$$

$$86,800 \text{ gpd}$$

$$\text{Divided By: } \underline{300}$$

$$\text{Total No. of ERU's} = 289 \text{ ERU}$$

EXHIBIT 10A

ST. GEORGE ISLAND WATER DISTRIBUTION SYSTEM
 EXISTING FLOWS
 BOTH PUMPS OFF
 AVERAGE DAILY FLOW WITH EXISTING ELEVATED TANK ON LINE

DEMAND
 0.21 gpm/ERU

1 OF 3

Seq#	PIPE TABLE										NODE TABLE				
	Input			Output			Input				Output				
	Pipe	UpNode	DownNode	Length	Diameter	Roughness	Flow	Velocity	HeadLoss	Status	Node	Elevation	Demand	Pressure	HGL
			ft	in		US gpm	ft/sec	ft	Open		ft	US gpm	psi	ft	
1	1	101	1	140.00	12.00	120.00	265.44	0.75	0.04		0	6.00	0.00	45.65	111.45
2	2	1	2	500.00	8.00	120.00	121.82	0.78	0.22		1	6.00	0.00	45.63	111.41
3	3	2	3	330.00	4.00	120.00	5.46	0.14	0.01		2	6.00	1.47	45.54	111.19
4	4	3	4	185.00	4.00	120.00	3.36	0.09	0.00		3	6.00	2.10	45.53	111.18
5	5	2	5	180.00	8.00	120.00	114.89	0.73	0.07		4	6.00	3.36	45.53	111.18
6	6	5	6	200.00	8.00	120.00	92.61	0.59	0.05		5	6.00	0.00	45.51	111.12
7	7	6	7	500.00	8.00	120.00	90.93	0.58	0.13		6	6.00	1.68	45.48	111.07
8	8	7	8	450.00	8.00	120.00	89.88	0.57	0.11		7	6.00	1.05	45.43	110.94
9	9	8	9	440.00	8.00	120.00	87.78	0.56	0.10		8	6.00	2.10	45.38	110.83
10	10	9	10	595.00	8.00	120.00	85.89	0.55	0.14		9	6.00	1.89	45.34	110.73
11	11	10	11	1180.00	8.00	120.00	84.42	0.54	0.26		10	6.00	1.47	45.28	110.59
12	12	11	12	1070.00	8.00	120.00	76.55	0.49	0.20		11	6.00	4.20	45.16	110.33
13	13	12	13	1185.00	8.00	120.00	72.14	0.46	0.20		12	6.00	4.41	45.08	110.13
14	14	13	14	1200.00	8.00	120.00	68.99	0.44	0.18		13	6.00	3.15	44.99	109.94
15	15	14	15	1220.00	8.00	120.00	60.35	0.39	0.14		14	6.00	1.68	44.91	109.75
16	16	15	16	330.00	6.00	120.00	9.02	0.10	0.00		15	6.00	1.89	44.85	109.61
17	17	16	17	430.00	4.00	120.00	9.02	0.23	0.04		16	6.00	0.00	44.85	109.60
18	18	17	18	770.00	4.00	120.00	7.97	0.20	0.05		17	6.00	1.05	44.83	109.56
19	19	18	19	330.00	6.00	120.00	2.26	0.03	0.00		18	6.00	1.05	44.81	109.51
20	20	19	20	1210.00	8.00	120.00	49.81	0.32	0.10		19	6.00	1.89	44.81	109.51
21	21	20	21	550.00	2.00	120.00	-3.39	-0.35	0.07		20	6.00	2.73	44.77	109.41
22	22	20	22	2000.00	6.00	120.00	49.35	0.56	0.66		21	6.00	1.26	44.80	109.48
23	23	22	23	1400.00	6.00	120.00	46.20	0.52	0.41		22	6.00	3.15	44.48	108.74
24	24	23	24	850.00	6.00	120.00	44.73	0.51	0.24		23	6.00	1.47	44.30	108.33
25	25	24	25	1150.00	6.00	120.00	42.63	0.48	0.29		24	6.00	2.10	44.20	108.10
26	26	25	26	1150.00	6.00	120.00	39.27	0.45	0.25		25	6.00	3.36	44.07	107.80
27	27	26	27	2000.00	6.00	120.00	38.22	0.43	0.41		26	6.00	1.05	43.96	107.55
28	28	27	28	1300.00	6.00	120.00	36.33	0.41	0.25		27	6.00	1.89	43.78	107.14
29	29	28	29	500.00	6.00	120.00	34.23	0.39	0.08		28	6.00	2.10	43.68	106.89
30	30	29	30	2600.00	6.00	120.00	9.87	0.11	0.04		29	6.00	24.36	43.64	106.81
31	31	5	31	500.00	6.00	120.00	3.36	0.04	0.00		30	6.00	9.87	43.62	106.77
32	32	31	32	450.00	6.00	120.00	3.36	0.04	0.00		31	6.00	0.00	45.51	111.12
33	33	32	33	440.00	6.00	120.00	3.15	0.04	0.00		32	6.00	0.21	45.51	111.12
34	34	11	34	400.00	6.00	120.00	3.67	0.04	0.00		33	6.00	3.15	45.51	111.12
35	35	34	35	1070.00	2.00	120.00	3.67	0.38	0.61		34	6.00	0.00	45.16	110.33
36	36	35	36	1185.00	2.00	120.00	1.15	0.12	0.08		35	6.00	2.52	44.90	109.72
37	37	36	37	1200.00	2.00	120.00	-1.37	-0.14	0.11		36	6.00	2.52	44.87	109.64
38	38	37	38	1220.00	2.00	120.00	2.65	0.27	0.38		37	6.00	2.94	44.91	109.75
39	39	38	39	1210.00	2.00	120.00	0.76	0.08	0.04		38	6.00	1.89	44.75	109.37
40	40	39	40	1210.00	2.00	120.00	-1.13	-0.12	0.08		39	6.00	1.89	44.73	109.33
41	41	5	41	150.00	6.00	120.00	18.92	0.21	0.01		40	6.00	0.00	44.77	109.41
42	101	0	101	10.00	12.00	120.00	0.00	0.00	0.00		41	6.00	0.42	45.50	111.11
43	102	101	102	300.00	8.00	120.00	-265.44	-1.69	0.55		101	6.00	0.00	45.65	111.45
44	103	1	103	600.00	8.00	120.00	143.62	0.92	0.36		102	7.00	0.00	45.45	112.00
45	104	103	104	400.00	6.00	120.00	-9.47	-0.11	0.01		103	6.00	0.63	45.48	111.06
46	105	103	105	510.00	8.00	120.00	152.46	0.97	0.34		104	6.00	9.03	45.48	111.06

ST. GEORGE ISLAND WATER DISTRIBUTION SYSTEM
 EXISTING FLOWS
 BOTH PUMPS OFF
 AVERAGE DAILY FLOW WITH EXISTING ELEVATED TANK ON LINE

2 OF 3

DEMAND 0.21 gpm/ERU

Seq#	PIPE TABLE										NODE TABLE				
	Pipe	UpNode	DnNode	Length	Diameter	Roughness	Flow	Velocity	HeadLoss	Status	Node	Elevation	Demand	Pressure	HGL
				ft	in		US gpm	ft/sec	ft	Open		ft	US gpm	psi	ft
47	106	105	106	900.00	6.00	120.00	51.19	0.58	0.32		105	6.00	6.30	45.33	110.72
48	107	106	107	630.00	8.00	120.00	50.98	0.33	0.05		106	6.00	0.21	45.19	110.40
49	108	107	108	570.00	2.00	120.00	4.41	0.45	0.46		107	6.00	0.00	45.17	110.34
50	109	105	109	1174.00	8.00	120.00	94.97	0.61	0.32		108	6.00	4.41	44.97	109.89
51	110	109	110	1174.00	8.00	120.00	90.98	0.58	0.30		109	6.00	3.99	45.19	110.40
52	111	110	111	900.00	6.00	120.00	-30.61	-0.35	0.12		110	6.00	4.62	45.06	110.10
53	112	111	112	360.00	8.00	120.00	-43.21	-0.28	0.02		111	6.00	6.09	45.12	110.22
54	113	111	113	860.00	8.00	120.00	6.51	0.04	0.00		112	6.00	3.36	45.13	110.24
55	114	110	114	983.00	8.00	120.00	116.97	0.75	0.40		113	6.00	6.51	45.12	110.22
56	115	114	115	1154.00	8.00	120.00	112.77	0.72	0.44		114	6.00	4.20	44.89	109.70
57	116	115	116	790.00	6.00	120.00	4.62	0.05	0.00		115	6.00	5.88	44.70	109.26
58	117	116	117	350.00	6.00	120.00	4.62	0.05	0.00		116	6.00	0.00	44.70	109.26
59	118	115	118	1177.00	8.00	120.00	102.27	0.65	0.37		117	6.00	4.62	44.70	109.26
60	119	118	119	1222.00	8.00	120.00	96.81	0.62	0.35		118	6.00	5.46	44.54	108.89
61	120	119	120	800.00	6.00	120.00	5.88	0.07	0.01		119	6.00	4.20	44.39	108.54
62	121	120	121	840.00	6.00	120.00	3.78	0.04	0.00		120	6.00	2.10	44.39	108.54
63	122	121	122	600.00	6.00	120.00	3.15	0.04	0.00		121	6.00	0.63	44.39	108.54
64	123	119	123	1250.00	8.00	120.00	86.73	0.55	0.29		122	6.00	3.15	44.39	108.53
65	124	123	124	1170.00	8.00	120.00	75.81	0.48	0.21		123	6.00	6.09	44.26	108.25
66	125	124	125	1150.00	8.00	120.00	72.03	0.46	0.19		124	6.00	3.78	44.17	108.04
67	126	125	126	920.00	8.00	120.00	68.67	0.44	0.14		125	6.00	3.36	44.09	107.85
68	127	126	127	978.00	8.00	120.00	66.15	0.42	0.14		126	6.00	2.52	44.03	107.71
69	128	127	128	1323.00	8.00	120.00	63.84	0.41	0.17		127	6.00	2.31	43.97	107.57
70	129	128	129	1150.00	8.00	120.00	58.59	0.37	0.13		128	6.00	5.25	43.90	107.40
71	130	129	130	805.00	8.00	120.00	56.49	0.36	0.08		129	6.00	2.10	43.84	107.27
72	131	130	131	3450.00	8.00	120.00	56.07	0.36	0.36		130	6.00	0.42	43.80	107.19
73	132	131	132	1035.00	8.00	120.00	51.87	0.33	0.09		131	6.00	4.20	43.65	106.83
74	133	132	133	1150.00	8.00	120.00	49.77	0.32	0.10		132	6.00	2.10	43.61	106.73
75	134	133	134	690.00	8.00	120.00	47.67	0.30	0.05		133	6.00	2.10	43.57	106.64
76	135	134	135	690.00	8.00	120.00	47.25	0.30	0.05		134	6.00	0.42	43.54	106.59
77	136	135	136	1322.00	8.00	120.00	44.73	0.29	0.09		135	6.00	2.52	43.52	106.53
78	137	136	137	1265.00	8.00	120.00	41.79	0.27	0.08		136	6.00	2.94	43.48	106.44
79	138	137	138	863.00	8.00	120.00	38.43	0.25	0.04		137	6.00	3.36	43.45	106.37
80	139	138	139	920.00	8.00	120.00	34.23	0.22	0.04		138	6.00	4.20	43.43	106.32
81	140	139	140	1150.00	8.00	120.00	29.82	0.19	0.04		139	6.00	4.41	43.41	106.28
82	141	140	141	690.00	8.00	120.00	26.67	0.17	0.02		140	6.00	3.15	43.40	106.25
83	142	141	142	690.00	8.00	120.00	23.31	0.15	0.01		141	6.00	3.36	43.39	106.23
84	143	142	143	402.00	8.00	120.00	22.89	0.15	0.01		142	6.00	0.42	43.38	106.22
85	144	143	144	460.00	8.00	120.00	22.47	0.14	0.01		143	6.00	0.42	43.38	106.21
86	145	144	145	460.00	8.00	120.00	15.96	0.10	0.00		144	6.00	6.51	43.38	106.20
87	146	145	146	633.00	8.00	120.00	15.54	0.10	0.01		145	6.00	0.42	43.37	106.19
88	147	146	147	288.00	8.00	120.00	15.12	0.10	0.00		146	6.00	0.42	43.37	106.19
89	148	147	148	460.00	8.00	120.00	11.13	0.07	0.00		147	6.00	3.99	43.37	106.19
90	149	148	149	633.00	8.00	120.00	10.71	0.07	0.00		148	6.00	0.42	43.37	106.18
91	150	149	150	1150.00	8.00	120.00	7.77	0.05	0.00		149	6.00	2.94	43.37	106.18
92	151	150	151	748.00	8.00	120.00	7.35	0.05	0.00		150	6.00	0.42	43.37	106.18

ST. GEORGE ISLAND WATER DISTRIBUTION SYSTEM
 EXISTING FLOWS
 BOTH PUMPS OFF
 AVERAGE DAILY FLOW WITH EXISTING ELEVATED TANK ON LINE

DEMAND

3 OF 3

0.21 gpm/ERU

Seq#	PIPE TABLE										NODE TABLE				
	Pipe	UpNode	OnNode	Input			Output			Status	Node	Elevation	Demand	Pressure	HGL
				Length	Diameter	Roughness	Flow	Velocity	HeadLoss			US gpm	psi	ft	
				ft	in		US gpm	ft/sec	ft	Open	ft				
93	152	151	152	288.00	8.00	120.00	6.72	0.04	0.00		151	6.00	0.63	43.37	106.18
94	153	152	153	690.00	8.00	120.00	6.30	0.04	0.00		152	6.00	0.42	43.37	106.17
95	154	153	154	403.00	8.00	120.00	6.09	0.04	0.00		153	6.00	0.21	43.37	106.17
96	155	154	155	403.00	8.00	120.00	5.88	0.04	0.00		154	6.00	0.21	43.36	106.17
97	156	155	156	690.00	8.00	120.00	5.46	0.03	0.00		155	6.00	0.42	43.36	106.17
98	157	156	157	460.00	8.00	120.00	5.25	0.03	0.00		156	6.00	0.21	43.36	106.17
99	158	123	158	320.00	6.00	120.00	4.83	0.05	0.00		157	6.00	5.25	43.36	106.17
100	159	158	159	1220.00	6.00	120.00	1.47	0.02	0.00		158	6.00	3.36	44.26	108.25
101	401	15	19	1210.00	8.00	120.00	49.44	0.32	0.10		159	6.00	1.47	44.26	108.25
102	402	18	21	990.00	4.00	120.00	4.65	0.12	0.03		500	6.00		45.65	111.45
103	403	14	37	400.00	6.00	120.00	6.96	0.08	0.00		501	6.00		45.65	111.45
104	404	20	40	400.00	6.00	120.00	1.13	0.01	0.00						
105	405	41	104	960.00	6.00	120.00	18.50	0.21	0.05				265.44	43.36	
106	406	107	112	1358.00	8.00	120.00	46.57	0.30	0.10						
107	500	500	0	2.00	12.00	120.00	0.00	0.00	0.00						
108	501	501	0	2.00	12.00	120.00	0.00	0.00	0.00						

EXHIBIT 10C

1 OF 3

ST. GEORGE ISLAND WATER DISTRIBUTION SYSTEM

EXISTING FLOWS

BOTH PUMPS ON

PEAK HOURLY FLOW WITH EXISTING ELEVATED TANK ON LINE

DEMAND

0.7 gpm/ERT

Seq#	PIPE TABLE										NODE TABLE			
	Input			Output			(-Input-)	Input		Output		HGL		
	Pipe	UpMode	DnMode	Length	Diameter	Roughness	Flow	Velocity	HeadLoss	Status	Node		Elevation	Demand
ft	in		US gpm	ft/sec	ft	Open	ft	US gpm	psi	ft				
1	1	101	1	140.00	12.00	120.00	884.80	2.51	0.33	0	6.00	0.00	46.22	112.77
2	2	1	2	500.00	8.00	120.00	406.05	2.59	2.03	1	6.00	0.00	46.06	112.39
3	3	2	3	330.00	4.00	120.00	18.20	0.46	0.12	2	6.00	4.90	45.18	110.37
4	4	3	4	185.00	4.00	120.00	11.20	0.29	0.03	3	6.00	7.00	45.13	110.24
5	5	2	5	180.00	8.00	120.00	382.95	2.44	0.65	4	6.00	11.20	45.11	110.21
6	6	5	6	200.00	8.00	120.00	308.70	1.97	0.49	5	6.00	0.00	44.90	109.71
7	7	6	7	500.00	8.00	120.00	303.10	1.93	1.18	6	6.00	5.60	44.69	109.22
8	8	7	8	450.00	8.00	120.00	299.60	1.91	1.04	7	6.00	3.50	44.17	108.04
9	9	8	9	440.00	8.00	120.00	292.60	1.87	0.97	8	6.00	7.00	43.72	107.00
10	10	9	10	595.00	8.00	120.00	286.30	1.83	1.26	9	6.00	6.30	43.30	106.03
11	11	10	11	1180.00	8.00	120.00	281.40	1.80	2.43	10	6.00	4.90	42.76	104.77
12	12	11	12	1070.00	8.00	120.00	255.16	1.63	1.84	11	6.00	14.00	41.71	102.34
13	13	12	13	1185.00	8.00	120.00	240.46	1.54	1.82	12	6.00	14.70	40.91	100.51
14	14	13	14	1200.00	8.00	120.00	229.96	1.47	1.70	13	6.00	10.50	40.12	98.68
15	15	14	15	1220.00	8.00	120.00	201.10	1.28	1.35	14	6.00	5.60	39.39	96.99
16	16	15	16	330.00	6.00	120.00	28.47	0.32	0.04	15	6.00	6.30	38.80	95.64
17	17	16	17	430.00	4.00	120.00	28.47	0.73	0.37	16	6.00	0.00	38.79	95.60
18	18	17	18	770.00	4.00	120.00	24.97	0.64	0.52	17	6.00	3.50	38.63	95.23
19	19	18	19	330.00	6.00	120.00	10.93	0.12	0.01	18	6.00	3.50	38.40	94.71
20	20	19	20	1210.00	8.00	120.00	170.97	1.09	0.99	19	6.00	6.30	38.40	94.70
21	21	20	21	550.00	2.00	120.00	-6.33	-0.65	0.86	20	6.00	9.10	37.97	93.71
22	22	20	22	2000.00	6.00	120.00	164.50	1.87	6.18	21	6.00	4.20	38.34	94.57
23	23	22	23	1400.00	6.00	120.00	154.00	1.75	3.83	22	6.00	10.50	35.30	87.53
24	24	23	24	850.00	6.00	120.00	149.10	1.69	2.19	23	6.00	4.90	33.64	83.70
25	25	24	25	1150.00	6.00	120.00	142.10	1.61	2.71	24	6.00	7.00	32.69	81.52
26	26	25	26	1150.00	6.00	120.00	130.90	1.49	2.33	25	6.00	11.20	31.52	78.81
27	27	26	27	2000.00	6.00	120.00	127.40	1.45	3.85	26	6.00	3.50	30.51	76.48
28	28	27	28	1300.00	6.00	120.00	121.10	1.37	2.28	27	6.00	6.30	28.84	72.63
29	29	28	29	500.00	6.00	120.00	114.10	1.29	0.78	28	6.00	7.00	27.86	70.35
30	30	29	30	2600.00	6.00	120.00	32.90	0.37	0.41	29	6.00	81.20	27.52	69.57
31	31	5	31	500.00	6.00	120.00	11.20	0.13	0.01	30	6.00	32.90	27.34	69.16
32	32	31	32	450.00	6.00	120.00	11.20	0.13	0.01	31	6.00	0.00	44.89	109.70
33	33	32	33	440.00	6.00	120.00	10.50	0.12	0.01	32	6.00	0.70	44.89	109.69
34	34	11	34	400.00	6.00	120.00	12.24	0.14	0.01	33	6.00	10.50	44.88	109.68
35	35	34	35	1070.00	2.00	120.00	12.24	1.25	5.67	34	6.00	0.00	41.70	102.33
36	36	35	36	1185.00	2.00	120.00	3.84	0.39	0.73	35	6.00	8.40	39.25	96.66
37	37	36	37	1200.00	2.00	120.00	-4.56	-0.47	1.02	36	6.00	8.40	38.93	95.93
38	38	37	38	1220.00	2.00	120.00	8.90	0.91	3.58	37	6.00	9.80	39.37	96.95
39	39	38	39	1210.00	2.00	120.00	2.60	0.27	0.36	38	6.00	6.30	37.82	93.37
40	40	39	40	1210.00	2.00	120.00	-3.70	-0.38	0.70	39	6.00	6.30	37.67	93.01
41	41	5	41	150.00	6.00	120.00	63.05	0.72	0.08	40	6.00	0.00	37.97	93.71
42	101	0	101	10.00	12.00	120.00	1192.49	3.38	0.04	41	6.00	1.40	44.86	109.63
43	102	101	102	300.00	8.00	120.00	307.69	1.96	0.73	101	6.00	0.00	46.20	112.73
44	103	1	103	600.00	8.00	120.00	478.75	3.06	3.30	102	7.00	0.60	45.45	112.00
45	104	103	104	400.00	6.00	120.00	-31.55	-0.36	0.06	103	6.00	2.10	44.63	109.09
46	105	103	105	510.00	8.00	120.00	508.20	3.24	3.13	104	6.00	30.10	44.65	109.15

ST. GEORGE ISLAND WATER DISTRIBUTION SYSTEM
 EXISTING FLOWS
 BOTH PUMPS ON
 PEAK HOURLY FLOW WITH EXISTING ELEVATED TANK ON LINE

DENAND

3 OF 3

0.7 gpm/ERU

Seq#	PIPE TABLE										NODE TABLE			
	Input			Output			Input	Output			Input	Output		
	Pipe	UpNode	DownNode	Length	Diameter	Roughness	Flow	Velocity	HeadLoss	Status	Node	Elevation	Demand	Pressure
			ft	in		US gpm	ft/sec	ft	Open		ft	US gpm	psi	ft
93	152	151	152	288.00	8.00	120.00	22.40	0.14	0.01	151	6.00	2.10	24.99	63.73
94	153	152	153	690.00	8.00	120.00	21.00	0.13	0.01	152	6.00	1.40	24.99	63.72
95	154	153	154	403.00	8.00	120.00	20.30	0.13	0.01	153	6.00	0.70	24.98	63.71
96	155	154	155	403.00	8.00	120.00	19.60	0.13	0.01	154	6.00	0.70	24.98	63.71
97	156	155	156	690.00	8.00	120.00	18.20	0.12	0.01	155	6.00	1.40	24.98	63.70
98	157	156	157	460.00	8.00	120.00	17.50	0.11	0.01	156	6.00	0.70	24.97	63.69
99	158	123	158	320.00	6.00	120.00	16.10	0.18	0.01	157	6.00	17.50	24.97	63.69
100	159	158	159	1220.00	6.00	120.00	4.90	0.06	0.01	158	6.00	11.20	33.34	83.02
101	401	15	19	1210.00	8.00	120.00	166.34	1.06	0.94	159	6.00	4.90	33.34	83.02
102	402	18	21	990.00	4.00	120.00	10.53	0.27	0.14	500	6.00		46.22	112.77
103	403	14	37	400.00	6.00	120.00	23.26	0.26	0.03	501	6.00		46.22	112.77
104	404	20	40	400.00	6.00	120.00	3.70	0.04	0.00					
105	405	41	104	960.00	6.00	120.00	61.65	0.70	0.48			884.80	24.97	
106	406	107	112	1358.00	8.00	120.00	155.24	0.99	0.93					
107	500	500	0	2.00	12.00	120.00	341.17	0.97	0.00					
108	501	501	0	2.00	12.00	120.00	851.32	2.42	0.00					

EXHIBIT 100

1 OF 3

ST. GEORGE ISLAND WATER DISTRIBUTION SYSTEM

EXISTING FLOWS

BOTH PUMPS ON

PEAK HOURLY FLOW WITH EXISTING ELEVATED TANK OFF LINE

DEMAND

0.7 gpm/EFU

Seq#	PIPE TABLE										NODE TABLE				
	Pipe	UpNode	DnNode	Input			Output			Status	Input			Output	
				Length	Diameter	Roughness	Flow	Velocity	HeadLoss		Node	Elevation	Demand	Pressure	Hbl
ft	in		US gpm	ft/sec	ft	ft	ft	ft	ft	US gpm	psi	ft			
1	1	101	1	140.00	12.00	120.00	884.80	2.51	0.33	Open	0	6.00	0.00	73.75	176.35
2	2	1	2	500.00	8.00	120.00	406.05	2.09	1.05		1	6.00	0.00	73.59	176.00
3	3	2	3	330.00	4.00	120.00	18.20	0.46	0.12		2	6.00	4.90	72.71	173.97
4	4	3	4	185.00	4.00	120.00	11.20	0.29	0.08		3	6.00	7.00	72.66	173.84
5	5	4	5	130.00	8.00	120.00	362.95	2.44	0.65		4	6.00	11.20	72.65	173.82
6	6	5	6	200.00	8.00	120.00	308.70	1.97	0.49		5	6.00	0.00	72.43	173.31
7	7	6	7	500.00	8.00	120.00	305.10	1.93	1.18		6	6.00	5.60	72.22	172.82
8	8	7	8	450.00	8.00	120.00	299.60	1.91	1.04		7	6.00	3.50	71.71	171.65
9	9	8	9	440.00	8.00	120.00	292.60	1.87	0.97		8	6.00	7.00	71.26	170.61
10	10	9	10	595.00	8.00	120.00	286.30	1.83	1.26		9	6.00	6.30	70.84	169.63
11	11	10	11	1150.00	8.00	120.00	281.40	1.80	1.43		10	6.00	4.90	70.29	168.27
12	12	11	12	1070.00	8.00	120.00	255.16	1.63	1.84		11	6.00	14.00	69.24	165.94
13	13	12	13	1185.00	8.00	120.00	240.46	1.54	1.82		12	6.00	14.70	68.44	164.11
14	14	13	14	1290.00	8.00	120.00	229.96	1.47	1.70		13	6.00	10.50	67.66	162.29
15	15	14	15	1220.00	8.00	120.00	201.16	1.28	1.25		14	6.00	5.60	66.92	160.59
16	16	15	16	530.00	6.00	120.00	30.06	0.34	0.04		15	6.00	6.30	66.24	159.24
17	17	16	17	430.00	4.00	120.00	30.06	0.77	0.41		16	6.00	0.00	66.22	159.20
18	18	17	18	770.00	4.00	120.00	26.56	0.68	0.47		17	6.00	3.50	66.14	158.79
19	19	18	19	320.00	6.00	120.00	7.54	0.09	0.00		18	6.00	3.50	65.94	158.32
20	20	19	20	1210.00	8.00	120.00	166.04	1.06	0.94		19	6.00	6.30	65.94	158.32
21	21	20	21	550.00	2.00	120.00	-11.32	-1.16	0.66		20	6.00	9.10	65.53	157.38
22	22	20	22	270.00	6.00	120.00	164.50	1.87	0.16		21	6.00	4.20	65.62	158.04
23	23	22	23	1400.00	6.00	120.00	154.60	1.75	3.83		22	6.00	10.50	62.66	151.20
24	24	23	24	650.00	6.00	120.00	149.10	1.69	2.19		23	6.00	4.90	61.20	147.37
25	25	24	25	1150.00	6.00	120.00	142.11	1.61	2.14		24	6.00	7.00	60.25	145.18
26	26	25	26	1150.00	6.00	120.00	130.30	1.49	2.03		25	6.00	11.20	59.08	142.48
27	27	26	27	2000.00	6.00	120.00	127.40	1.45	3.85		26	6.00	3.50	58.07	140.15
28	28	27	28	1300.00	6.00	120.00	121.10	1.37	2.28		27	6.00	6.30	56.41	136.30
29	29	28	29	500.00	6.00	120.00	114.10	1.29	0.78		28	6.00	7.00	55.42	134.02
30	30	29	30	2600.00	6.00	120.00	32.30	0.37	0.41		29	6.00	61.20	55.68	133.24
31	31	30	31	500.00	6.00	120.00	11.20	0.13	0.01		30	6.00	32.30	54.20	132.23
32	32	31	32	450.00	6.00	120.00	11.20	0.11	0.01		31	6.00	0.00	72.43	173.31
33	33	32	33	440.00	6.00	120.00	10.50	0.11	0.01		32	6.00	0.70	72.42	173.23
34	34	33	34	500.00	6.00	120.00	12.24	0.14	0.01		33	6.00	10.50	72.42	173.28
35	35	34	35	1070.00	2.00	120.00	12.24	1.25	3.67		34	6.00	0.00	69.22	165.92
36	36	35	36	1185.00	2.00	120.00	0.64	0.09	0.01		35	6.00	6.30	68.76	160.27
37	37	36	37	1290.00	2.00	120.00	14.75	0.47	1.92		36	6.00	6.30	68.46	159.32
38	38	37	38	1220.00	2.00	120.00	0.64	0.30	0.54		37	6.00	6.30	68.51	160.55
39	39	38	39	1210.00	2.00	120.00	1.54	0.18	0.25		38	6.00	6.30	65.97	157.01
40	40	39	40	1210.00	2.00	120.00	0.78	0.08	0.11		39	6.00	6.30	65.22	156.67
41	41	40	41	1300.00	6.00	120.00	0.00	0.02	0.08		40	6.00	0.00	65.53	157.38
42	42	41	42	19.00	12.00	120.00	684.00	2.54	0.12		41	6.00	1.40	72.43	173.31
43	102	101	102	120.00	8.00	120.00	0.00	0.00	0.00		101	6.00	0.00	72.44	176.33
44	103	102	103	600.00	6.00	120.00	478.75	2.05	0.20		102	6.00	0.00	0.00	176.33
45	104	103	104	400.00	6.00	120.00	701.50	2.36	0.06		103	6.00	0.00	0.00	176.33
46	105	104	105	110.00	6.00	120.00	308.20	2.24	0.12		104	6.00	30.10	0.00	176.33

of. SOURCE: GRAND WATER DISTRIBUTION SYSTEM
 EXISTING FLOW
 BOTH PUMPS ON
 PEAK HOURLY FLOW WITH EXISTING ELEVATED TANK OFF LINE

SCHEMATIC 0.7 gpm/ft/cu

PIPE TABLE										NODE TABLE						
Seq#	Pipe	UpNode	DnNode	Input			Output			Status	Input			Output		
				Length	Diameter	Roughness	Flow	Velocity	Headloss		Node	Elevation	Demand	Pressure	Hgt	
				ft	in		US gpm	ft/sec	ft		ft	US gpm	psi	ft		
47	106	105	106	300.00	8.00	120.00	173.65	1.34	2.36	1	105	6.00	21.00	70.81	163.56	
48	107	106	107	630.00	8.00	120.00	169.95	1.36	0.51	1	106	6.00	0.70	69.52	166.59	
49	108	107	108	570.00	8.00	120.00	14.70	1.50	4.24	1	107	6.00	0.00	63.30	166.08	
50	109	108	109	1174.00	8.00	120.00	316.55	2.02	3.00	1	108	6.00	14.70	67.46	161.64	
51	110	109	110	1174.00	8.00	120.00	303.25	1.94	2.77	1	109	6.00	13.30	69.51	166.56	
52	111	110	111	300.00	8.00	120.00	-102.05	-1.16	1.15	1	110	6.00	15.40	68.31	163.79	
52	112	111	112	360.00	8.00	120.00	-144.05	-1.52	0.21	1	111	6.00	20.30	63.80	164.93	
54	113	111	113	560.00	8.00	120.00	-11.70	-0.14	0.02	1	112	6.00	11.20	68.90	165.15	
55	114	110	114	983.00	8.00	120.00	359.30	2.49	6.70	1	113	6.00	21.70	68.20	164.92	
56	115	114	115	1154.00	8.00	120.00	370.30	2.40	4.06	1	114	6.00	14.00	66.70	160.09	
57	116	115	116	730.00	8.00	120.00	15.40	0.17	0.01	1	115	6.00	19.60	64.95	156.03	
58	117	116	117	550.00	8.00	120.00	12.40	0.17	0.01	1	116	6.00	0.00	64.94	156.00	
59	118	115	118	1177.00	8.00	120.00	340.10	2.15	3.45	1	117	6.00	15.40	64.93	155.99	
60	119	118	119	1222.00	8.00	120.00	322.70	1.96	3.24	1	118	6.00	18.20	63.45	152.58	
61	120	119	120	800.00	8.00	120.00	19.60	0.22	0.03	1	119	6.00	14.00	62.05	149.34	
62	121	120	121	840.00	8.00	120.00	12.60	0.14	0.02	1	120	6.00	7.00	62.03	149.29	
63	122	121	122	600.00	8.00	120.00	19.60	0.14	0.01	1	121	6.00	2.00	62.02	149.27	
64	123	119	123	1230.00	8.00	120.00	259.10	1.95	1.30	1	122	6.00	19.20	62.02	149.26	
65	124	123	124	1170.00	8.00	120.00	252.70	1.61	1.97	1	123	6.00	20.30	60.86	146.64	
66	125	124	125	1150.00	8.00	120.00	140.10	1.53	1.76	1	124	6.00	12.60	60.03	144.67	
67	126	125	126	920.00	8.00	120.00	223.30	1.46	1.29	1	125	6.00	11.20	59.27	142.90	
68	127	126	127	378.00	8.00	120.00	220.50	1.41	1.10	1	126	6.00	8.40	58.71	141.61	
69	128	127	128	1323.00	8.00	120.00	222.90	1.36	1.62	1	127	6.00	7.70	58.15	140.33	
70	129	128	129	1150.00	8.00	120.00	135.30	1.25	1.20	1	128	6.00	17.50	57.45	138.71	
71	130	129	130	805.00	8.00	120.00	166.30	1.22	0.99	1	129	6.00	7.00	56.93	137.51	
72	131	130	131	2450.00	8.00	120.00	196.30	1.19	0.65	1	130	6.00	1.40	56.59	136.72	
73	132	131	132	1935.00	8.00	120.00	171.30	1.10	0.65	1	131	6.00	14.00	55.15	133.39	
74	133	132	133	1150.00	8.00	120.00	165.30	1.06	0.65	1	132	6.00	7.00	54.78	132.53	
75	134	133	134	630.00	8.00	120.00	156.30	1.01	1.49	1	133	6.00	7.00	54.39	131.64	
76	135	134	135	690.00	8.00	120.00	151.50	1.01	0.99	1	134	6.00	1.40	54.18	131.15	
77	136	135	136	1221.00	8.00	120.00	143.10	0.95	0.94	1	135	6.00	8.40	53.97	130.67	
78	137	136	137	1265.00	8.00	120.00	159.30	0.99	0.71	1	136	6.00	3.00	53.60	129.83	
79	138	137	138	863.00	8.00	120.00	133.10	0.92	0.41	1	137	6.00	11.20	53.30	129.12	
80	139	138	139	321.00	8.00	120.00	114.10	0.73	1.06	1	138	6.00	14.00	53.10	128.71	
81	140	139	140	1150.00	8.00	120.00	99.40	0.63	0.64	1	139	6.00	14.70	52.97	128.20	
82	141	140	141	630.00	8.00	120.00	66.30	0.57	0.17	1	140	6.00	19.20	52.82	128.00	
83	142	141	142	630.00	8.00	120.00	77.70	0.56	0.12	1	141	6.00	11.20	52.74	127.64	
84	143	142	143	420.00	8.00	120.00	76.50	0.49	0.17	1	142	6.00	1.40	52.59	127.71	
85	144	143	144	860.00	8.00	120.00	74.70	0.46	0.02	1	143	6.00	1.40	52.66	127.64	
86	145	144	145	460.00	8.00	120.00	50.20	0.34	0.04	1	144	6.00	21.70	52.62	127.55	
87	146	145	146	620.00	8.00	120.00	51.60	0.33	0.06	1	145	6.00	1.40	52.60	127.51	
88	147	146	147	250.00	8.00	120.00	50.40	0.31	0.12	1	146	6.00	1.40	52.56	127.45	
89	148	147	148	860.00	8.00	120.00	27.10	0.24	0.12	1	147	6.00	13.20	52.51	127.43	
90	149	148	149	630.00	8.00	120.00	23.70	0.22	0.03	1	148	6.00	1.40	52.46	127.40	
91	150	149	150	1250.00	8.00	120.00	25.30	0.27	0.03	1	149	6.00	1.40	52.34	127.36	
92	151	150	151	740.00	8.00	120.00	24.50	0.18	0.02	1	150	6.00	1.40	52.30	127.33	

ST. GEORGE ISLAND WATER DISTRIBUTION SYSTEM
 EXISTING FLOWS
 BOTH PUMPS ON
 PEAK HOURLY FLOW WITH EXISTING ELEVATED TANK OFF LINE

3 OF 3
 DEMAND 0.7 gpa/ERU

Seq#	PIPE TABLE										NODE TABLE				
	Pipe	UpNode	DownNode	Length	Diameter	Roughness	Flow	Velocity	HeadLoss	Status	Node	Elevation	Demand	Pressure	HGL
				ft	in		US gpm	ft/sec	ft	Open		ft	US gpm	psi	ft
93	152	151	152	288.00	8.00	120.00	22.40	0.14	0.01		151	6.00	2.10	52.52	127.33
94	153	152	153	690.00	8.00	120.00	21.00	0.13	0.01		152	6.00	1.40	52.52	127.33
95	154	153	154	403.00	8.00	120.00	20.30	0.13	0.01		153	6.00	0.70	52.52	127.31
96	155	154	155	403.00	8.00	120.00	19.60	0.13	0.01		154	6.00	0.70	52.51	127.31
97	156	155	156	690.00	8.00	120.00	18.20	0.12	0.01		155	6.00	1.40	52.51	127.30
98	157	156	157	460.00	8.00	120.00	17.50	0.11	0.01		156	6.00	0.70	52.51	127.29
99	158	123	158	320.00	6.00	120.00	16.10	0.18	0.01		157	6.00	17.50	52.51	127.29
100	159	158	159	1220.00	6.00	120.00	4.90	0.06	0.01		158	6.00	11.20	60.88	146.62
101	401	15	19	1210.00	8.00	120.00	164.80	1.05	0.92		159	6.00	4.90	60.87	146.62
102	402	18	21	990.00	4.00	120.00	15.52	0.40	0.28		500	6.00		73.75	176.35
103	403	14	37	400.00	6.00	120.00	23.20	0.26	0.03		501	6.00		73.75	176.36
104	404	20	40	400.00	6.00	120.00	3.76	0.04	0.00						
105	405	41	104	960.00	6.00	120.00	61.65	0.70	0.48				884.80	52.51	
106	406	107	112	1358.00	8.00	120.00	155.25	0.99	0.93						
107	500	500	0	2.00	12.00	120.00	190.87	0.54	0.00						
108	501	501	0	2.00	12.00	120.00	693.93	1.97	0.00						

ST. GEORGE ISLAND WATER DISTRIBUTION SYSTEM

EXISTING FLOWS + MAJOR DEVELOPMENT + OTHER GENERAL DEVELOPMENT @ END OF ALL SYSTEM YEAR 2

3 OF 3

DEMAND 0.69 gpm/ft²

PEAK HOURLY FLOW WITH EXISTING ELEVATED TANK OFF LINE

98	157	156	157	460.00	8.00	120.00	28.98	0.18	0.01	156	0.00	1.08	31.72	79.26
99	158	123	158	520.00	6.00	120.00	17.25	0.20	0.02	157	0.00	26.98	31.71	79.25
100	159	158	159	1220.00	6.00	120.00	5.52	0.06	0.01	158	0.00	11.73	48.76	118.63
101	401	15	19	1210.00	8.00	120.00	167.38	1.07	0.35	159	0.00	5.52	48.75	118.62
102	402	18	21	590.00	4.00	120.00	15.75	0.40	0.19	500	0.00	0.00	67.06	160.91
103	403	14	37	400.00	6.00	120.00	23.62	0.27	0.03	501	0.00	0.00	67.06	160.91
104	404	20	40	400.00	6.00	120.00	4.64	0.03	0.00					
105	405	41	104	960.00	6.00	120.00	62.52	0.34	0.03					
106	406	107	112	1258.00	8.00	120.00	182.26	1.16	1.15			500.49	31.71	
107	500	500	0	0.00	12.00	120.00	240.22	0.68	0.00					
	501	501	0	2.00	12.00	120.00	740.27	2.10	0.00					

EXHIBIT 12

1 OF 3

ST. GEORGE ISLAND WATER DISTRIBUTION SYSTEM
 EXISTING FLOWS + MARK'S DEVELOPMENT + OTHER GENERAL DEVELOPMENT
 YEAR 3 THROUGH THE END OF YEAR 6
 PEAK HOURLY FLOW WITH EXISTING ELEVATED TANK OFF LINE AND BOTH PUMPS ON
 GROUND STORAGE TANK AT NODE 155

DEMAND 0.66 gpm/ERU

Seq#	PIPE TABLE										NODE TABLE			
	Input		Pipe			Output			Status	Input		Output		
	Pipe UpNode	DnNode	Length	Diameter	Roughness	Flow	Velocity	HeadLoss		Node Elevation	Demand	Pressure	HGL	
		ft	in		US gpm	ft/sec	ft	ft	ft	US gpm	psi	ft		
1	1	101	1	140.00	12.00	120.00	1047.42	2.97	0.48	0	6.00	3.30	61.04	146.99
2	2	1	2	500.00	8.00	120.00	471.31	3.02	1.68	1	6.00	6.00	60.82	146.51
3	3	2	3	330.00	4.00	120.00	20.46	0.52	0.15	2	6.00	7.92	59.66	143.82
4	4	3	4	185.00	4.00	120.00	13.86	0.55	0.04	3	6.00	6.60	59.60	143.67
5	5	2	5	180.00	8.00	120.00	443.33	2.83	0.86	4	6.00	13.86	59.58	143.63
6	6	5	6	200.00	8.00	120.00	347.16	2.22	0.61	5	6.00	6.00	59.29	142.36
7	7	6	7	500.00	8.00	120.00	356.58	2.16	1.45	6	6.00	6.58	59.03	142.35
8	8	7	8	450.00	8.00	120.00	335.23	2.14	1.26	7	6.00	3.30	58.40	140.91
9	9	8	9	440.00	8.00	120.00	325.53	2.08	1.18	8	6.00	3.30	57.85	139.63
10	10	9	10	595.00	8.00	120.00	313.44	2.04	1.55	9	6.00	3.30	57.23	138.44
11	11	10	11	1180.00	8.00	120.00	311.52	1.99	2.23	10	6.00	7.32	56.66	136.89
12	12	11	12	1070.00	8.00	120.00	281.68	1.80	2.10	11	6.00	13.20	55.40	133.97
13	13	12	13	1185.00	8.00	120.00	264.51	1.69	2.17	12	6.00	17.16	54.44	131.76
14	14	13	14	1280.00	8.00	120.00	254.62	1.63	2.05	13	6.00	3.30	53.50	129.59
15	15	14	15	1220.00	8.00	120.00	220.62	1.41	1.60	14	6.00	6.58	52.61	127.54
16	16	15	16	330.00	6.00	120.00	25.63	0.40	0.06	15	6.00	5.94	51.32	125.94
17	17	16	17	430.00	4.00	120.00	32.33	0.63	0.47	16	6.00	3.30	51.30	125.88
18	18	17	18	770.00	4.00	120.00	29.03	0.74	0.54	17	6.00	3.30	51.69	125.41
19	19	18	19	350.00	6.00	120.00	5.62	0.06	0.00	18	6.00	6.60	51.46	124.86
20	20	19	20	1210.00	8.00	120.00	178.73	1.14	1.07	19	6.00	5.94	51.45	124.86
21	21	20	21	550.00	2.00	120.00	-12.84	-1.31	0.75	20	6.00	11.88	50.99	123.79
22	22	20	22	2000.00	6.00	120.00	171.60	1.93	0.63	21	6.00	3.30	51.32	124.54
23	23	22	23	1400.00	6.00	120.00	138.40	1.80	4.03	22	6.00	13.20	48.10	117.11
24	24	23	24	850.00	6.00	120.00	153.78	1.75	2.32	23	6.00	4.62	46.35	113.07
25	25	24	25	1150.00	6.00	120.00	143.88	1.63	2.77	24	6.00	9.90	45.35	110.76
26	26	25	26	1150.00	6.00	120.00	133.32	1.51	2.41	25	6.00	10.56	44.15	107.98
27	27	26	27	2000.00	6.00	120.00	126.72	1.44	3.01	26	6.00	6.60	43.11	105.58
28	28	27	28	1300.00	6.00	120.00	120.76	1.37	2.27	27	6.00	5.94	41.46	101.76
29	29	28	29	300.00	6.00	120.00	110.88	1.26	0.74	28	6.00	3.30	40.48	99.50
30	30	29	30	2600.00	6.00	120.00	34.22	0.33	0.44	29	6.00	76.56	40.15	98.75
31	31	5	31	500.00	6.00	120.00	131.66	0.16	0.02	30	6.00	34.32	39.36	98.31
32	32	31	32	450.00	6.00	120.00	131.86	0.16	0.01	31	6.00	9.00	39.26	142.95
33	33	32	33	440.00	6.00	120.00	3.90	0.11	0.01	32	6.00	3.30	39.23	142.93
34	34	11	34	400.00	6.00	120.00	16.64	0.13	0.02	33	6.00	3.30	39.27	142.92
35	35	34	35	1070.00	2.00	120.00	131.84	1.36	6.63	34	6.00	0.30	35.33	103.95
36	36	35	36	1135.00	2.00	120.00	3.32	0.35	1.39	35	6.00	7.92	32.51	127.30
37	37	36	37	1200.00	2.00	120.00	-0.60	-0.39	1.39	36	6.00	11.22	31.91	125.21
38	38	37	38	1220.00	2.00	120.00	19.26	1.06	4.76	37	6.00	3.24	32.60	127.50
39	39	38	39	2210.00	2.00	120.00	1.14	0.12	0.08	38	6.00	9.24	30.53	122.73
40	40	39	40	1210.00	2.00	120.00	-4.07	-1.47	3.11	39	6.00	5.34	30.50	122.65
41	41	3	41	150.00	6.00	120.00	82.91	0.94	0.23	40	6.00	3.30	30.59	122.78
42	101	0	101	10.00	12.00	120.00	1000.72	2.20	0.00	41	6.00	1.22	32.23	142.83
43	102	101	102	300.00	6.00	120.00	0.08	0.00	0.00	101	6.00	0.30	61.02	146.36
44	101	1	101	300.00	6.00	120.00	370.11	2.67	4.04	102	7.00	0.00	60.53	146.36
45	104	103	104	400.00	6.00	120.00	-0.21	-0.20	0.15	103	6.00	5.28	58.82	141.87
46	105	103	105	510.00	8.00	120.00	623.04	3.98	4.57	104	6.00	28.38	58.66	142.02

ST. JACOB ISLAND WATER DISTRIBUTION SYSTEM
 EXISTING FLOWS + MAH'S DEVELOPMENT + OTHER GENERAL DEVELOPMENT
 YEAR 3 THROUGH THE END OF YEAR 6
 PEAK HOURLY FLOW WITH EXISTING ELEVATED TANK OFF LINE AND MAIN PUMPS ON
 GROUND STORAGE TANK AT NODE 155

DEMAND 0.66 gpm/ERU

Seq#	PIPE TABLE										NODE TABLE			
	Input			Output			Input			Output				
	Pipe	UpNode	DnNode	Length	Diameter	Roughness	Flow velocity	headloss	Status	Node	Elevation	Demand	Pressure	HSL
			ft	in		US gpm	ft/sec	ft	Open		ft	US gpm	psi	ft
47	106	105	106	900.00	8.00	120.00	208.01	2.56	4.29	105	6.00	20.70	56.04	137.30
48	107	106	107	630.00	8.00	120.00	207.35	1.52	0.74	106	6.00	9.66	54.38	133.01
49	108	107	108	570.00	2.00	120.00	13.86	1.42	3.80	107	6.00	3.20	54.66	132.27
50	109	105	109	1174.00	8.00	120.00	391.35	2.50	4.46	108	6.00	13.66	53.02	128.47
51	110	109	110	1174.00	8.00	120.00	376.09	2.49	4.22	109	6.00	13.64	54.31	132.34
52	111	110	111	900.00	6.00	120.00	-133.43	-1.51	1.39	110	6.00	14.32	53.12	128.71
53	112	111	112	360.00	6.00	120.00	-179.63	-1.15	0.32	111	6.00	22.44	53.34	130.60
54	113	111	113	860.00	8.00	120.00	23.76	0.13	0.02	112	6.00	19.36	54.06	130.32
55	114	110	114	983.00	8.00	120.00	495.60	3.16	5.75	113	6.00	23.76	53.33	130.58
56	115	114	115	1154.00	8.00	120.00	481.30	3.00	6.42	114	6.00	19.20	50.63	122.36
57	116	115	116	790.00	6.00	120.00	17.82	0.20	0.04	115	6.00	21.78	47.65	116.53
58	117	116	117	350.00	6.00	120.00	17.62	0.20	0.04	116	6.00	9.00	47.63	116.49
59	118	115	118	1177.00	8.00	120.00	442.20	2.82	5.59	117	6.00	7.62	47.82	116.47
60	119	118	119	1222.00	8.00	120.00	425.04	2.71	5.39	118	6.00	17.16	45.43	110.34
61	120	119	120	800.00	6.00	120.00	21.78	0.25	0.06	119	6.00	16.50	43.09	105.55
62	121	120	121	840.00	6.00	120.00	15.16	0.17	0.03	120	6.00	6.60	43.07	105.49
63	122	121	122	600.00	6.00	120.00	9.39	0.11	0.01	121	6.00	5.28	43.06	105.46
64	123	119	123	1250.00	8.00	120.00	386.76	2.47	4.63	122	6.00	3.30	43.05	105.45
65	124	123	124	1176.00	8.00	120.00	342.34	2.19	3.46	123	6.00	22.44	41.09	100.32
66	125	124	125	1150.00	8.00	120.00	330.66	2.11	3.19	124	6.00	21.66	39.59	97.45
67	126	125	126	320.00	8.00	120.00	316.80	2.02	2.36	125	6.00	19.36	38.21	94.26
68	127	126	127	978.00	8.00	120.00	308.68	1.97	2.39	126	6.00	7.32	37.19	91.31
69	128	127	128	1323.00	8.00	120.00	298.32	1.90	2.93	127	6.00	10.36	36.16	89.52
70	129	128	129	1150.00	8.00	120.00	281.62	1.80	2.37	128	6.00	16.50	34.84	86.49
71	130	129	130	805.00	8.00	120.00	271.32	1.73	1.93	129	6.00	3.30	33.82	84.11
72	131	130	131	3450.00	8.00	120.00	270.60	1.73	6.60	130	6.00	1.32	33.14	82.56
73	132	131	132	1035.00	8.00	120.00	254.10	1.62	1.76	131	6.00	16.50	30.29	75.36
74	133	132	133	1150.00	8.00	120.00	247.50	1.58	1.66	132	6.00	6.60	29.52	74.20
75	134	133	134	690.00	8.00	120.00	237.60	1.52	1.94	133	6.00	3.30	28.72	72.34
76	135	134	135	690.00	8.00	120.00	236.25	1.51	1.93	134	6.00	1.32	28.27	71.30
77	136	135	136	1322.00	8.00	120.00	225.36	1.44	1.80	135	6.00	17.22	27.62	70.27
78	137	136	137	1265.00	8.00	120.00	213.62	1.38	1.39	136	6.00	3.24	27.04	68.47
79	138	137	138	683.00	8.00	120.00	201.36	1.33	0.36	137	6.00	19.36	26.33	66.88
80	139	138	139	320.00	8.00	120.00	188.76	1.29	0.39	138	6.00	13.20	25.34	65.92
81	140	139	140	1430.00	8.00	120.00	171.60	1.20	0.35	139	6.00	17.16	25.05	65.02
82	141	140	141	690.00	8.00	120.00	161.70	1.13	1.31	140	6.00	3.30	23.14	64.07
83	142	141	142	650.00	8.00	120.00	147.64	0.94	0.43	141	6.00	13.66	24.32	63.36
84	143	142	143	402.00	8.00	120.00	136.52	0.84	0.23	142	6.00	1.32	24.73	62.10
85	144	143	144	460.00	8.00	120.00	141.30	0.91	0.27	143	6.00	3.66	24.65	62.69
86	145	144	145	460.00	8.00	120.00	121.44	0.78	0.20	144	6.00	20.36	24.31	62.62
87	146	145	146	633.00	8.00	120.00	116.62	0.75	0.26	145	6.00	3.62	24.42	62.42
88	147	146	147	280.00	8.00	120.00	103.30	0.64	0.11	146	6.00	1.32	24.31	62.16
89	148	147	148	330.00	8.00	120.00	93.60	0.64	0.14	147	6.00	13.34	24.26	62.05
90	149	148	149	330.00	8.00	120.00	81.30	0.61	0.17	148	6.00	1.32	24.22	61.91
91	150	149	150	1200.00	8.00	120.00	69.30	0.58	0.22	149	6.00	2.34	24.14	61.74
92	151	150	151	240.00	8.00	120.00	57.60	0.55	0.14	150	6.00	3.30	24.02	61.49

ST. GEORGE ISLAND WATER DISTRIBUTION SYSTEM
 EXISTING FLOWS + MAHR'S DEVELOPMENT + OTHER GENERAL DEVELOPMENT
 YEAR 1 THROUGH THE END OF YEAR 6
 YEAR HOURLY FLOW WITH EXISTING ELEVATED TANK OFF LINE AND BOTH PUMPS ON
 GROUND STORAGE TANK AT NODE 155

DEMAND

3 OF 3

0.66 gpm/ERU

PIPE TABLE

Pipe	Input			Output			Status	Node					
	UpNode	DownNode	Length	Diameter	Roughness	Flow velocity		HeadLoss	Elevation	Demand	Pressure	HGL	
			ft	in		US gpm	ft/sec	ft	ft	psi	ft		
33	152	151	208.00	8.00	120.00	72.60	0.46	0.03	151	6.00	5.28	23.96	61.35
34	153	152	699.00	8.00	120.00	36.96	0.24	0.02	152	6.00	25.64	23.94	61.30
35	154	153	403.00	8.00	120.00	33.00	0.21	0.02	153	6.00	3.96	23.93	61.27
36	155	154	403.00	8.00	120.00	4.62	0.03	0.00	154	6.00	26.38	23.92	61.25
37	156	155	690.00	8.00	120.00	0.00	0.00	0.00	155	6.00	4.62	23.92	61.25
38	157	156	460.00	8.00	120.00	207.24	1.32	0.54	156	6.00	3.96	79.31	189.22
39	158	157	320.00	6.00	120.00	21.78	0.25	0.02	157	6.00	207.24	79.08	188.68
40	159	158	1220.00	6.00	120.00	7.92	0.03	0.01	158	6.00	13.86	41.08	100.89
41	401	15	1210.00	8.00	120.00	179.05	1.14	1.06	159	6.00	7.92	41.07	100.88
42	402	18	390.00	4.00	120.00	16.50	0.42	0.22	500	6.00	0.00	61.04	146.99
43	403	14	400.00	6.00	120.00	25.42	0.29	0.04	501	6.00	0.00	61.04	147.00
44	404	29	400.00	6.00	120.00	8.10	0.09	0.00	600	6.00	0.00	8.66	26.00
45	405	41	960.00	6.00	120.00	61.59	0.95	0.61	601	6.00	79.63	189.94	
46	406	107	1358.00	8.00	120.00	190.19	1.21	1.03	602	6.00	0.00	0.00	0.00
47	500	500	0.00	12.00	120.00	272.01	0.77	0.00					
48	501	501	0.00	12.00	120.00	782.01	2.22	0.00					
49	603	155	10.00	8.00	120.00	0.00	0.00	0.00			1265.22	23.92	
110	600	603	30.00	8.00	120.00	0.00	0.00	0.00					
111	601	600	48.00	8.00	120.00	0.00	0.00	0.00					
112	602	601	48.00	8.00	120.00	211.20	1.35	0.54					
113	607	602	600.00	8.00	120.00	211.20	1.35	0.54					

EXHIBIT 13A

1 OF 3

ST. GEORGE ISLAND WATER DISTRIBUTION SYSTEM

EXISTING FLOWS + MAHAK'S DEVELOPMENT + OTHER GENERAL DEVELOPMENT @ 5% OF EXISTING CUSTOMERS

DEMAND

0.21 gpm/ERU

YEAR 7 THROUGH THE END OF YEAR 10

AVERAGE DAILY FLOW WITH EXISTING ELEVATED TANK ON LINE AND BOTH PUMPS OFF

NEW ELEVATED TANK AT NODE 137 OFF LINE ---- GROUND STORAGE TANK AT NODE 155 OMITTED

PIPE TABLE

Seq#	Input			Output			Status	NODE TABLE						
	Pipe	UpNode	GrNode	Length	Diameter	Roughness		Flow	Velocity	HeadLoss	Node	Elevation	Demand	Pressure
				ft	in		US gpm	ft/sec	ft		ft	US gpm	psi	ft
1	1	101	1	140.00	12.00	120.00	457.17	1.30	0.10	0	6.00	2.10	45.22	110.46
2	2	1	2	500.00	8.00	120.00	192.71	1.23	0.51	1	6.00	0.00	45.18	110.36
3	3	2	3	320.00	4.00	120.00	7.56	0.19	0.02	2	6.00	3.57	44.96	109.85
4	4	3	4	185.00	4.00	120.00	5.46	0.14	0.01	3	6.00	2.10	44.95	109.83
5	5	2	5	180.00	8.00	120.00	121.58	1.16	0.16	4	6.00	5.46	44.94	109.82
6	6	5	6	200.00	8.00	120.00	128.31	0.82	0.10	5	6.00	0.00	44.89	109.69
7	7	6	7	500.00	8.00	120.00	124.55	0.79	0.22	6	6.00	3.78	44.84	109.59
8	8	7	8	450.00	8.00	120.00	123.48	0.79	0.20	7	6.00	1.05	44.75	109.36
9	9	8	9	440.00	8.00	120.00	119.28	0.76	0.18	8	6.00	4.20	44.66	109.16
10	10	9	10	535.00	8.00	120.00	117.39	0.75	0.24	9	6.00	1.89	44.58	108.98
11	11	10	11	1180.00	8.00	120.00	113.62	0.72	0.45	10	6.00	3.57	44.47	108.73
12	12	11	12	1070.00	8.00	120.00	102.71	0.66	0.54	11	6.00	4.20	44.28	108.28
13	13	12	13	1165.00	8.00	120.00	96.29	0.61	0.33	12	6.00	6.51	44.13	107.94
14	14	13	14	1200.00	8.00	120.00	93.05	0.59	0.32	13	6.00	3.15	43.99	107.61
15	15	14	15	1220.00	8.00	120.00	89.09	0.51	0.24	14	6.00	3.78	43.85	107.29
16	16	15	16	320.00	8.00	120.00	13.66	0.16	0.01	15	6.00	1.89	43.74	107.04
17	17	16	17	430.00	4.00	120.00	11.56	0.20	0.07	16	6.00	2.10	43.74	107.03
18	18	17	18	770.00	4.00	120.00	10.51	0.27	0.08	17	6.00	1.05	43.71	106.96
19	19	18	19	320.00	6.00	120.00	1.20	0.01	0.09	18	6.00	3.15	43.67	106.88
20	20	19	20	1210.00	8.00	120.00	63.96	0.41	0.16	19	6.00	1.89	43.67	106.88
21	21	20	21	550.00	2.00	120.00	-4.79	-0.49	0.11	20	6.00	4.83	43.60	106.72
22	22	20	22	2000.00	6.00	120.00	59.35	0.68	0.95	21	6.00	1.26	43.65	106.83
23	23	22	23	1400.00	6.00	120.00	54.60	0.62	0.56	22	6.00	5.25	43.19	105.77
24	24	23	24	850.00	6.00	120.00	23.12	0.60	0.32	23	6.00	1.47	42.95	105.21
25	25	24	25	1150.00	6.00	120.00	48.75	0.56	0.38	24	6.00	4.20	42.81	104.89
26	26	25	26	1150.00	6.00	120.00	45.97	0.52	0.35	25	6.00	3.36	42.64	104.51
27	27	26	27	2000.00	6.00	120.00	42.42	0.48	0.50	26	6.00	3.15	42.50	104.18
28	28	27	28	1300.00	6.00	120.00	40.53	0.46	0.30	27	6.00	1.89	42.28	103.68
29	29	28	29	500.00	6.00	120.00	36.33	0.41	0.09	28	6.00	4.20	42.15	103.38
30	30	29	30	2600.00	6.00	120.00	11.39	0.14	0.06	29	6.00	24.36	42.11	103.28
31	31	31	31	500.00	6.00	120.00	3.46	0.06	0.00	30	6.00	11.97	42.09	103.22
32	32	31	32	430.00	6.00	120.00	5.46	0.06	0.00	31	6.00	0.00	44.88	109.68
33	33	32	33	440.00	6.00	120.00	6.15	0.04	0.00	32	6.00	2.31	44.68	109.68
34	34	33	34	400.00	6.00	120.00	6.31	0.08	0.00	33	6.00	3.15	44.68	109.68
35	35	34	35	1000.00	2.00	120.00	4.61	0.49	1.01	34	6.00	2.10	44.28	108.28
36	36	35	36	1165.00	2.00	120.00	11.29	0.25	0.26	35	6.00	2.52	43.84	107.27
37	37	36	37	1200.00	2.00	120.00	10.85	0.24	0.29	36	6.00	4.62	43.72	106.99
38	38	37	38	1200.00	2.00	120.00	10.31	0.26	0.28	37	6.00	2.34	43.85	107.28
39	39	38	39	1200.00	2.00	120.00	10.96	0.01	0.00	38	6.00	3.99	43.51	106.50
40	40	39	40	1200.00	2.00	120.00	11.37	0.02	0.02	39	6.00	1.89	43.51	106.50
41	41	40	41	150.00	6.00	120.00	47.61	0.54	0.05	40	6.00	2.10	43.60	106.72
42	101	0	101	100.00	12.00	120.00	72.16	-0.01	0.00	41	6.00	0.42	44.07	109.64
43	102	101	102	500.00	6.00	120.00	-461.37	-1.35	1.54	101	6.00	2.10	45.22	110.46
44	103	1	103	600.00	6.00	120.00	264.46	1.07	1.16	102	6.00	0.00	45.45	112.00
45	104	103	104	100.00	6.00	120.00	100.15	0.44	0.03	103	6.00	2.70	44.70	109.26
46	105	104	105	500.00	6.00	120.00	200.15	1.32	1.16	104	6.00	3.00	44.74	109.34

ST. GEORGE ISLAND WATER DISTRIBUTION SYSTEM
 EXISTING FLOWS + MAHR'S DEVELOPMENT + OTHER GENERAL DEVELOPMENT @ 5% OF EXISTING CUSTOMERS
 YEAR 7 THROUGH THE END OF YEAR 10
 AVERAGE DAILY FLOW WITH EXISTING ELEVATED TANK ON LINE AND BOTH PUMPS OFF
 NEW ELEVATED TANK AT NODE 137 OFF LINE ---- GROUND STORAGE TANK AT NODE 155 OMITTED

2 OF 3

DEMAND 0.21 gpm/ERU

Seq#	PIPE TABLE										NODE TABLE				
	Input			Output			Input				Output				
	Pipe	UpNode	DnNode	Length	Diameter	Roughness	Flow	Velocity	HeadLoss	Status	Node	Elevation	Demand	Pressure	HGL
			ft	in		US gpm	ft/sec	ft	Open		ft	US gpm	psi	ft	
47	106	105	106	900.00	6.00	120.00	99.12	1.12	1.09		105	6.00	8.40	44.19	108.08
48	107	106	107	630.00	8.00	120.00	98.91	0.63	0.19		106	6.00	0.21	43.72	106.39
49	108	107	108	570.00	2.00	120.00	4.41	0.45	0.46		107	6.00	2.10	43.64	106.80
50	109	105	109	1174.00	8.00	120.00	192.57	1.23	1.20		108	6.00	4.41	43.44	106.25
51	110	109	110	1174.00	8.00	120.00	186.48	1.19	1.13		109	6.00	6.09	43.67	106.88
52	111	110	111	900.00	6.00	120.00	-72.24	-0.82	0.61		110	6.00	4.62	43.18	105.76
53	112	111	112	360.00	8.00	120.00	-89.04	-0.57	0.09		111	6.00	8.19	43.45	106.36
54	113	111	113	860.00	8.00	120.00	8.61	0.05	0.00		112	6.00	3.36	43.48	106.45
55	114	110	114	983.00	8.00	120.00	254.10	1.62	1.67		113	6.00	8.61	43.45	106.36
56	115	114	115	1154.00	8.00	120.00	249.90	1.60	1.30		114	6.00	4.20	42.46	104.08
57	116	115	116	790.00	6.00	120.00	6.72	0.08	0.01		115	6.00	7.98	41.64	102.18
58	117	116	117	350.00	6.00	120.00	6.72	0.08	0.00		116	6.00	0.00	41.63	102.17
59	118	115	118	1177.00	8.00	120.00	235.20	1.50	1.74		117	6.00	6.72	41.63	102.17
60	119	118	119	1222.00	8.00	120.00	229.74	1.47	1.73		118	6.00	5.46	40.88	100.44
61	120	119	120	800.00	6.00	120.00	7.98	0.09	0.01		119	6.00	6.30	40.14	98.72
62	121	120	121	840.00	6.00	120.00	5.88	0.07	0.01		120	6.00	2.10	40.13	98.71
63	122	121	122	600.00	6.00	120.00	3.15	0.04	0.00		121	6.00	2.73	40.13	98.70
64	123	119	123	1250.00	8.00	120.00	215.46	1.38	1.57		122	6.00	3.15	40.13	98.70
65	124	123	124	1170.00	8.00	120.00	198.24	1.27	1.26		123	6.00	8.19	39.46	97.15
66	125	124	125	1150.00	8.00	120.00	194.46	1.24	1.19		124	6.00	3.78	38.91	95.89
67	126	125	126	920.00	8.00	120.00	189.00	1.21	0.91		125	6.00	5.46	38.40	94.70
68	127	126	127	978.00	8.00	120.00	186.48	1.19	0.94		126	6.00	2.52	38.00	93.79
69	128	127	128	1323.00	8.00	120.00	182.07	1.16	1.21		127	6.00	4.41	37.60	92.85
70	129	128	129	1150.00	8.00	120.00	176.82	1.13	1.00		128	6.00	5.25	37.07	91.64
71	130	129	130	805.00	8.00	120.00	172.62	1.10	0.67		129	6.00	4.20	36.64	90.64
72	131	130	131	3450.00	8.00	120.00	172.20	1.10	2.86		130	6.00	0.42	36.35	89.97
73	132	131	132	1035.00	8.00	120.00	165.90	1.06	0.80		131	6.00	6.30	35.11	87.11
74	133	132	133	1150.00	8.00	120.00	163.80	1.05	0.87		132	6.00	2.10	34.77	86.31
75	134	133	134	690.00	8.00	120.00	159.60	1.02	0.50		133	6.00	4.20	34.39	85.44
76	135	134	135	690.00	8.00	120.00	159.18	1.02	0.49		134	6.00	0.42	34.18	84.94
77	136	135	136	1322.00	8.00	120.00	154.56	0.99	0.90		135	6.00	4.62	33.96	84.45
78	137	136	137	1265.00	8.00	120.00	151.62	0.97	0.83		136	6.00	2.94	33.57	83.55
79	138	137	138	863.00	8.00	120.00	146.16	0.93	0.53		137	6.00	5.46	33.22	82.73
80	139	138	139	920.00	8.00	120.00	141.96	0.91	0.53		138	6.00	4.20	32.99	82.20
81	140	139	140	1150.00	8.00	120.00	135.45	0.86	0.61		139	6.00	6.51	32.76	81.67
82	141	140	141	690.00	8.00	120.00	132.30	0.84	0.35		140	6.00	5.15	32.49	81.06
83	142	141	142	690.00	8.00	120.00	126.84	0.81	0.32		141	6.00	5.46	32.34	80.70
84	143	142	143	402.00	8.00	120.00	126.42	0.81	0.19		142	6.00	0.42	32.20	80.38
85	144	143	144	460.00	8.00	120.00	123.90	0.79	0.21		143	6.00	2.52	32.12	80.19
86	145	144	145	460.00	8.00	120.00	117.39	0.75	0.19		144	6.00	6.51	32.03	79.99
87	146	145	146	633.00	8.00	120.00	114.87	0.73	0.25		145	6.00	2.52	31.95	79.80
88	147	146	147	288.00	8.00	120.00	114.45	0.73	0.11		146	6.00	0.42	31.84	79.55
89	148	147	148	460.00	8.00	120.00	108.36	0.69	0.16		147	6.00	6.09	31.79	79.44
90	149	148	149	633.00	8.00	120.00	105.84	0.68	0.21		148	6.00	2.52	31.72	79.28
91	150	149	150	1150.00	8.00	120.00	100.80	0.64	0.25		149	6.00	3.04	31.63	79.06
92	151	150	151	740.00	8.00	120.00	98.28	0.63	0.22		150	6.00	2.52	31.48	78.71

EXHIBIT 13B

1 OF 3

ST. GEORGE ISLAND WATER DISTRIBUTION SYSTEM

EXISTING FLOWS + MAINT'S DEVELOPMENT + OTHER GENERAL DEVELOPMENT PLUS OF EXISTING CUSTOMERS

DEMAND

0.65 gpm/ERU

YEAR 7 THROUGH THE END OF YEAR 10

PEAK HOURLY FLOW WITH EXISTING ELEVATED TANK OFF LINE AND BORN PUMPS ON

NEW ELEVATED TANK AT NODE 157 ON LINE ---- GROUND STORAGE TANK AT NODE 155 OMITTED

Seq#	PIPE TABLE										NODE TABLE				
	Input			Output			Input			Output					
	Pipe	UpNode	OnNode	Length ft	Diameter in	Roughness	Flow US gpm	Velocity ft/sec	HeadLoss ft	Status open	Node	Elevation ft	Demand US gpm	Pressure psi	HdL ft
1	1	101	1	140.00	12.00	120.00	1017.13	2.62	0.43	1	0	0.00	6.50	62.98	151.48
2	2	1	2	500.00	8.00	120.00	467.76	0.71	1.85	2	1	0.00	0.00	62.78	151.02
3	3	2	3	330.00	4.00	120.00	23.40	0.69	0.29	3	2	0.00	11.05	61.55	148.17
4	4	3	4	185.00	4.00	120.00	16.90	0.43	0.06	4	3	0.00	6.50	61.46	147.98
5	5	4	5	180.00	8.00	120.00	153.01	1.63	0.30	5	4	0.00	16.30	61.43	147.91
6	6	5	6	200.00	8.00	120.00	397.15	1.54	0.76	6	5	0.00	0.00	61.16	147.38
7	7	6	7	500.00	8.00	120.00	365.45	1.46	1.64	7	6	0.00	11.70	60.82	146.50
8	8	7	8	450.00	8.00	120.00	362.23	1.44	1.60	8	7	0.00	3.25	60.03	144.66
9	9	8	9	440.00	8.00	120.00	363.20	1.46	1.50	9	8	0.00	13.00	59.32	143.03
10	10	9	10	595.00	8.00	120.00	363.05	1.45	1.35	10	9	0.00	5.85	58.67	141.53
11	11	10	11	1180.00	5.00	120.00	351.09	1.15	0.63	11	10	0.00	11.05	57.82	139.57
12	12	11	12	1070.00	8.00	120.00	317.36	1.23	1.76	12	11	0.00	15.00	56.23	135.85
13	13	12	13	1185.00	8.00	120.00	317.75	1.20	1.71	13	12	0.00	20.15	55.03	133.13
14	14	13	14	1200.00	8.00	120.00	263.00	1.61	1.58	14	13	0.00	4.75	53.86	130.42
15	15	14	15	1220.00	6.00	120.00	247.64	1.38	1.33	15	14	0.00	11.70	52.75	127.85
16	16	15	16	330.00	6.00	120.00	43.23	0.76	0.06	16	15	0.00	5.85	51.63	125.86
17	17	16	17	430.00	4.00	120.00	39.73	1.06	0.01	17	16	0.00	6.50	51.66	125.79
18	18	17	18	770.00	4.00	120.00	39.54	0.78	0.75	18	17	0.00	3.25	51.64	125.28
19	19	18	19	330.00	6.00	120.00	7.76	0.99	0.09	19	18	0.00	9.75	51.31	124.53
20	20	19	20	1210.00	8.00	120.00	263.61	1.30	1.67	20	19	0.00	5.85	51.31	124.52
21	21	20	21	550.00	2.00	120.00	9.12	0.33	1.17	21	20	0.00	14.95	50.72	123.16
22	22	21	22	4000.00	6.00	120.00	183.23	1.16	7.70	22	21	0.00	3.90	51.22	124.32
23	23	22	23	1400.00	6.00	120.00	189.00	1.12	4.33	23	22	0.00	16.25	47.38	115.46
24	24	23	24	850.00	6.00	120.00	164.43	1.67	1.62	24	23	0.00	4.55	45.42	110.91
25	25	24	25	1150.00	6.00	120.00	151.45	1.72	0.95	25	24	0.00	13.00	44.28	108.29
26	26	25	26	1150.00	6.00	120.00	141.05	1.60	0.67	26	25	0.00	16.40	42.96	105.24
27	27	26	27	2000.00	6.00	120.00	131.30	1.49	4.07	27	26	0.00	3.75	41.30	102.56
28	28	27	28	1300.00	6.00	120.00	123.43	1.72	1.93	28	27	0.00	5.85	40.04	98.49
29	29	28	29	500.00	6.00	120.00	112.45	1.23	0.76	29	28	0.00	13.00	38.99	96.06
30	30	29	30	2600.00	6.00	120.00	37.03	0.42	0.01	30	29	0.00	75.40	38.66	95.30
31	31	30	31	500.00	6.00	120.00	16.33	0.49	0.02	31	30	0.00	27.03	38.44	94.73
32	32	31	32	450.00	6.00	120.00	16.39	0.19	0.02	32	31	0.00	0.00	38.15	93.26
33	33	32	33	450.00	6.00	120.00	3.13	0.11	0.01	33	32	0.00	7.25	38.14	93.24
34	34	33	34	400.00	6.00	120.00	21.49	0.24	0.03	34	33	0.00	3.75	38.14	93.23
35	35	34	35	1200.00	2.00	120.00	14.30	1.02	0.15	35	34	0.00	6.50	38.22	93.06
36	36	35	36	1300.00	2.00	120.00	7.10	0.72	0.23	36	35	0.00	7.60	38.69	92.71
37	37	36	37	1200.00	2.00	120.00	3.22	0.34	0.03	37	36	0.00	19.00	38.00	92.42
38	38	37	38	1200.00	2.00	120.00	12.16	1.24	0.03	38	37	0.00	3.10	38.73	92.80
39	39	38	39	2210.00	2.00	120.00	39.16	0.62	0.00	39	38	0.00	12.05	49.96	121.41
40	40	39	40	1200.00	2.00	120.00	39.04	0.62	1.72	40	39	0.00	5.85	49.96	121.42
41	41	40	41	1200.00	2.00	120.00	39.26	0.43	0.00	41	40	0.00	6.50	50.71	123.14
42	42	41	42	1500.00	2.00	120.00	39.07	0.30	0.00	42	41	0.00	1.00	61.00	147.23
43	43	42	43	2000.00	6.00	120.00	39.00	0.00	0.00	43	42	0.00	0.00	62.97	151.45
44	44	43	44	600.00	6.00	120.00	39.00	0.00	0.00	44	43	0.00	0.00	62.95	151.45
45	45	44	45	400.00	6.00	120.00	17.01	0.11	0.21	45	44	0.00	0.45	61.00	147.04
46	46	45	46	510.00	6.00	120.00	331.06	0.03	3.40	46	45	0.00	27.90	61.00	147.03