

# MACFARLANE AUSLEY FERGUSON & McMULLEN

ATTORNEYS AND COUNSELORS AT LAW

227 SOUTH CALHOUN STREET  
P.O. BOX 391 (ZIP 32302)  
TALLAHASSEE, FLORIDA 32301  
19041 224-9115 FAX 19041 222-7560

111 MADISON STREET, SUITE 2300  
P.O. BOX 1531 (ZIP 33601)  
TAMPA, FLORIDA 33602  
(813) 273-4200 FAX (813) 273-4396

ORIGINAL FILE COPY  
400 CLEVELAND STREET  
P.O. BOX 1569 (ZIP 34617)  
CLEARWATER, FLORIDA 34615  
(813) 441-8966 FAX (813) 442-8470

May 19, 1995

HAND DELIVERED

IN REPLY REFER TO

Tallahassee

Ms. Blanca S. Bayo, Director  
Division of Records and Reporting  
Florida Public Service Commission  
101 East Gaines Street  
Tallahassee, Florida 32399-0850

RECEIVED  
K  
FPSC DIVISION OF RECORDS

Re: Fuel and Purchased Power Cost Recovery Clause  
with Generating Performance Incentive Factor;  
FPSC Docket No. 950001-EI

Dear Ms. Bayo:


Enclosed for filing in the above docket, on behalf of Tampa Electric Company, are fifteen (15) copies of each of the following:

- 04397 95 1. Prepared Direct Testimony and Exhibit (MJP-1) of Mary Pennino regarding Tampa Electric Company's fuel adjustment and capacity cost recovery final true-up amounts for the period October 1994 through March 1995. 2
- 04398 95 2. Prepared Direct Testimony and Exhibit (GAK-1) of Mr. George A. Keselowsky regarding Tampa Electric Company's Generating Performance Incentive Factor for the period October 1994 through March 1995. 1
- 04399 95 3. Exhibit (WNC/EAT-1) entitled Oil Backout Cost Recovery, Actual, October 1994 - March 1995. orig x 3

Please acknowledge receipt and filing of the above by stamping the duplicate copy of this letter and returning same to this writer.

Thank you for your assistance in connection with this matter.

Sincerely,

  
James D. Beasley

JDB/pp  
Enclosures

cc: All Parties of Record (w/encls.)

ED Dudley  
1  
orig x 3  
FCH  
SD  
WAS  
OTH

Ms. Blanca S. Bayo  
May 19, 1995  
Page 2

CERTIFICATE OF SERVICE

I HEREBY CERTIFY that a true copy of the foregoing testimony and exhibits, filed on behalf of Tampa Electric Company, has been furnished by U. S. Mail or hand delivery (\*) on this 19<sup>th</sup> day of May, 1995 to the following:

Ms. Martha C. Brown\*  
Ms. Mary Elizabeth Culpepper  
Division of Legal Services  
Florida Public Service  
Commission  
101 East Gaines Street  
Tallahassee, FL 32399-0863

Mr. James A. McGee  
Senior Counsel  
Florida Power Corporation  
Post Office Box 14042  
St. Petersburg, FL 33733

Mr. Joseph A. McGlothlin  
Ms. Vicki Gordon Kaufman  
McWhirter, Reeves, McGlothlin,  
Davidson & Bakas  
315 S. Calhoun St., Suite 716  
Tallahassee, FL 32301

Mr. Jack Shreve  
Office of Public Counsel  
Room 812  
111 West Madison Street  
Tallahassee, FL 32399-1400

Mr. Matthew M. Childs  
Steel Hector & Davis  
Suite 601  
215 South Monroe Street  
Tallahassee, FL 32301

Mr. John W. McWhirter  
McWhirter, Reeves, McGlothlin,  
Davidson & Bakas  
Post Office Box 3350  
Tampa, FL 33601

Ms. Suzanne Brownless  
Suzanne Brownless P.A.  
1546 Blairstone Pines Drive  
Tallahassee, FL 32301

Mr. Floyd R. Self  
Messer, Vickers, Caparello,  
Madsen, Lewis, Goldman & Metz  
Post Office Box 1876  
Tallahassee, FL 32301-1876

Mr. G. Edison Holland, Jr.  
Beggs & Lane  
Post Office Box 12950  
Pensacola, FL 32576

Mr. Barry Huddleston  
Destec Energy  
2500 CityWest Blvd. Suite 150  
Houston, TX 77042

Mr. Eugene M. Trisko  
Post Office Box 596  
Berkeley Springs, WV 25411

Mr. Roger Yott  
Air Products & Chemicals, Inc.  
7540 Windsor Drive, Suite 301  
Allentown, PA 18195

Mr. Richard J. Salem  
Ms. Marian B. Rush  
Salem, Saxon & Nielsen, P.A.  
Post Office Box 3399  
Tampa, FL 33601

Ms. Blanca S. Bayo  
May 19, 1995  
Page 3

Mr. Peter J. P. Brickfield  
Brickfield, Burchette & Ritts  
1025 Thomas Jefferson St. N.W.  
Eighth Floor, West Tower  
Washington, D.C. 20007-0805

Mr. Stephen R. Yurek  
Dahlen, Berg & Co.  
2150 Dain Bosworth Plaza  
60 South Sixth Street  
Minneapolis, MN 55402

  
\_\_\_\_\_  
ATTORNEY

ORIGINAL  
FILE COPY

DOCKET NO. 950001-EI

TAMPA ELECTRIC COMPANY

SUBMITTED FOR FILING 5/19/95

(TRUE UP)

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

PREPARED DIRECT TESTIMONY

OF

GEORGE A. KESELOWSKY

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14 Q. Will you please state your name, business address, and employer?

15  
16 A. My name is George A. Keselowsky and my business address is Post Office Box  
17 111, Tampa, Florida 33601. I am employed by Tampa Electric Company.

18  
19 Q. Please furnish us with a brief outline of your educational background and business  
20 experience.

21  
22 A. I graduated in 1972 from the University of South Florida with a Bachelor of  
23 Science Degree in Mechanical Engineering. I have been employed by Tampa  
24 Electric Company in various engineering positions since that time. My current  
25 position is that of Senior Consulting Engineer -Production Engineering.

1 Q. What are your current responsibilities?

2  
3 A. I am responsible for testing and reporting unit performance, and the compilation  
4 and reporting of generation statistics.

5  
6 Q. What is the purpose of your testimony?

7  
8 A. My testimony presents the actual performance results from unit equivalent  
9 availability and station heat rate used to determine the Generating Performance  
10 Incentive Factor (GPIF) for the period October 1994 through March 1995. I will  
11 also compare these results to the targets established prior to the beginning of the  
12 period.

13  
14 Q. Have you prepared an exhibit with the results for this six month period?

15  
16 A. Yes. Under my direction and supervision an exhibit has been prepared entitled,  
17 "Tampa Electric Company, October 1994 - March 1995, Generating Performance  
18 Incentive Factor Results" consisting of 30 pages that was filed with this testimony  
19 (Have identified as Exhibit GAK-1).

20  
21 Q. Have you calculated the results of Tampa Electric Company for its performance  
22 under the GPIF during this period?

23  
24 A. Yes I have. This is shown on page 4 of my exhibit. Based upon -2.775 GPIF  
25 points, the result is a penalty amount of \$471,209 for the period.

1 Q. Please proceed with your review of the actual results for the October 1994 -  
2 March 1995 period.

3  
4 A. On page 3 of my exhibit, the actual average common equity for the period is  
5 shown on line 8 as \$953,527,765. This produces the maximum penalty or reward  
6 figure of \$1,938,772 as shown on line 15, page 3. Page 2 of my exhibit  
7 demonstrates that this calculated incentive amount has been modified to comply  
8 with the constraint set forth by the Commission that incentive dollars are not to  
9 exceed fifty percent of fuel savings.

10  
11 Q. Would you please explain how you arrived at the actual equivalent availability  
12 results for the six units included within the GPIF?

13  
14 A. Yes I will. Operating data on each of our operating units is filed monthly with  
15 the Florida Public Service Commission on the Actual Unit Performance data  
16 form. Additionally, outage information is reported to the Commission on a  
17 monthly basis. A summary of this data for the six months provides the basis for  
18 the GPIF.

19  
20 Q. Are the equivalent availability results shown on page 6, column 2, directly  
21 applicable to the GPIF table?

22  
23 A. Not exactly. Adjustments to equivalent availability may be required as noted in  
24 section 4.3.3 of the GPIF Manual. The actual equivalent availability including  
25 the required adjustment is shown on page 6 of my exhibit. The necessary  
26  
27

1 adjustments as prescribed in the GPIF Manual are further defined by a letter dated  
2 October 23, 1981, from Mr. J.H. Hoffsis of the Commission's Staff. The  
3 adjustments for each unit are as follows:  
4

5 Gannon Unit No. 5

6 On this unit, no planned outage hours were originally scheduled to fall within the  
7 Winter 1994 period. A major outage scheduled for the month immediately  
8 following the Winter 1994 period was postponed until later in the year. This  
9 necessitated a short fuel system planned outage during the period, which required  
10 173.4 hours. Consequently, the actual equivalent availability of 90.4% is adjusted  
11 to 94.2% as shown on page 7 of my exhibit.  
12

13 Gannon Unit No. 6

14 On this unit, 408 planned outage hours were originally scheduled to fall within  
15 the Winter 1994 period. A planned fuel system outage was rescheduled to take  
16 place after the period ended, and planned outage activities within the period  
17 required 243.1 hours. Consequently, the actual equivalent availability of 84.6%  
18 is adjusted to 81.2%, as shown on page 8 of my exhibit.  
19

20 Big Bend Unit No. 1

21 On this unit, no planned outage hours were originally scheduled to fall within the  
22 Winter 1994 period. A planned outage was moved forward from the month  
23 following the period and took place within the Winter 1994 period. The outage  
24 required 335.2 planned outage hours. Consequently, the actual equivalent  
25 availability of 84.7% is adjusted to 91.8% as shown on page 9 of my exhibit.  
26  
27

1 Big Bend Unit No. 2

2 On this unit 1344 planned outage hours were originally scheduled to occur during  
3 the Winter 1994 period. The actual planned outage activities required 1297.8  
4 hours. Consequently, the actual equivalent availability of 59.3% is adjusted to  
5 58.4% as shown on page 10 of my exhibit.  
6

7 Big Bend Unit No. 3

8 On this unit 840 planned outage hours were originally scheduled to fall within the  
9 Winter 1994 period. Due to a revision of the outage schedule, the outage was  
10 shifted to begin after the end of the period, and no planned outage hours fell  
11 within the Winter 1994 period. Consequently, the actual equivalent availability  
12 of 87.4% is adjusted to 70.6% as shown on page 11 of my exhibit.  
13

14 Big Bend Unit No. 4

15 This unit was not originally scheduled to have a planned outage during the Winter  
16 1994 period. Due to a revision of the outage schedule, an outage scheduled to  
17 occur after the end of the period was rescheduled to take place during the Winter  
18 1994 period and required 822.4 planned outage hours. Consequently, the actual  
19 equivalent availability of 71.1% is adjusted to 87.6% as shown on page 12 of my  
20 exhibit.  
21

22 Q. How did you arrive at the applicable equivalent availability points for each unit?  
23

24 A. The final adjusted equivalent availabilities for each unit are shown on page  
25 6, column 4, of my exhibit. This number is entered into the respective Generating  
26  
27  
28



1 Performance Incentive Point (GPIP) Table for each particular unit on pages 23  
2 through 28. Page 4 of my exhibit summarizes the equivalent availability points  
3 to be awarded or penalized.

4  
5 Q. Would you please explain the heat rate results relative to the GPIP?

6  
7 A. The actual heat rate and adjusted actual heat rate for Gannon and Big Bend Station  
8 are shown on page 6 of my exhibit. The adjustment was developed based on the  
9 guidelines of section 4.3.6 of the GPIP Manual. This procedure is further defined  
10 by a letter dated October 23, 1981, from Mr. J.H. Hoffsis of the FPSC Staff.  
11 The final adjusted actual heat rates are also shown on page 5 of my exhibit. This  
12 heat rate number is entered into the respective GPIP table for the particular unit,  
13 shown on pages 23 through 28. Page 4 of my exhibit summarizes the weighted  
14 heat rate and equivalent availability points to be awarded.

15  
16 Q. What is the overall GPIP for Tampa Electric Company during this six month  
17 period?

18  
19 A. This is shown on page 30 of my exhibit. Essentially, the weighing factors shown  
20 on page 4, column 3, plus the equivalent availability points and the heat rate  
21 points shown on page 4, column 4, are substituted within the equation. This  
22 resultant value, -2.775, is then entered into the GPIP table on page 2. Using  
23 linear interpolation, a penalty amount of \$471,209 is calculated.

GPIF CALCULATIONS OF MAXIMUM ALLOWED INCENTIVE DOLLARS	3
CALCULATIONS OF SYSTEM ACTUAL GPIF POINTS	4
GPIF UNIT PERFORMANCE SUMMARY, EQUIVALENT AVAILABILITY	5
GPIF UNIT PERFORMANCE SUMMARY, AVERAGE NET OPERATING HEAT RATE	5
GPIF UNIT PERFORMANCE DATA	6
GPIF ( EAF & HEAT RATE ) ADJUSTMENT COMPUTATIONS	7 - 18
PLANNED OUTAGE SCHEDULE - ACTUAL	19
CRITICAL PATH DIAGRAM	20 - 22
GENERATING PERFORMANCE INCENTIVE POINTS TABLES (ACTUAL)	23 - 28
COMPARISON OF GPIF TARGET VS ACTUAL PERFORMANCE	29
GENERATING PERFORMANCE INCENTIVE POINTS CALCULATIONS	30

**TAMPA ELECTRIC COMPANY  
GENERATING PERFORMANCE INCENTIVE POINTS TABLE  
REWARD/PENALTY TABLE - ACTUAL  
OCTOBER 1994 - MARCH 1995**

<u>GENERATING PERFORMANCE INCENTIVE POINTS (GPIP)</u>	<u>FUEL SAVINGS/(LOSS) (\$000)</u>	<u>GENERATING PERFORMANCE INCENTIVE FACTOR (\$000)</u>
+10	3,396.1	1,698.1
+9	3,056.5	1,528.2
+8	2,716.9	1,358.4
+7	2,377.3	1,188.6
+6	2,037.7	1,018.8
+5	1,698.1	849.0
+4	1,358.4	679.2
+3	1,018.8	509.4
+2	679.2	339.6
+1	339.6	169.8
0	0.0	0.0
-1	(454.5)	(169.8)
-2	(909.0)	(339.6)
-3	(1,363.5)	(509.4)
-4	(1,818.0)	(679.2)
-5	(2,272.4)	(849.0)
-6	(2,726.9)	(1,018.8)
-7	(3,181.4)	(1,188.6)
-8	(3,635.9)	(1,358.4)
-9	(4,090.4)	(1,528.2)
-10	(4,544.9)	(1,698.1)

← **GPIP  
Points  
-2.775**

**PENALTY  
DOLLARS  
(\$471,209)** →

**TAMPA ELECTRIC COMPANY  
GENERATING PERFORMANCE INCENTIVE FACTOR  
CALCULATION OF MAXIMUM ALLOWED INCENTIVE DOLLARS  
ACTUAL  
OCTOBER 1994 – MARCH 1995**

Line 1	Beginning of period balance of common equity End of month common equity:	\$966,461,765
Line 2	Month of   October       1994	\$936,029,507
Line 3	Month of   November      1994	\$947,006,620
Line 4	Month of   December      1994	\$949,255,681
Line 5	Month of   January       1995	\$934,556,935
Line 6	Month of   February      1995	\$966,919,918
Line 7	Month of   March         1995	\$974,463,930
Line 8	(summation of line 1 through line 7 divided by 7)	\$953,527,765
Line 9	25 Basis points	0.0025
Line 10	Revenue expansion factor	61.3738%
Line 11	Maximum allowed incentive Dollars (Line 8 times line 9 divided by line 10 times 0.5)	\$1,942,050
Line 12	Jurisdictional Sales	6,572,598 MWH
Line 13	Total Sales	6,583,711 MWH
Line 14	Jurisdictional Separation Factor (Line 12 divided by line 13)	99.83%
Line 15	Maximum Allowed Jurisdictional Incentive Dollars (Line 11 times Line 14)	\$1,938,772

TAMPA ELECTRIC COMPANY  
CALCULATION OF SYSTEM GPIF POINTS .  
OCTOBER 1994 - MARCH 1995  
ACTUAL

<u>PLANT/UNIT</u>	<u>6 MO ADJ ACTUAL PERFORMANCE</u>	<u>WEIGHTING FACTOR %</u>	<u>UNIT POINTS</u>	<u>WEIGHTED UNIT POINTS</u>
GANNON 5	94.2 EAF	1.30%	10.000	0.130
GANNON 6	81.2 EAF	2.87%	10.000	0.287
BIG BEND 1	91.8 EAF	6.41%	10.000	0.641
BIG BEND 2	58.4 EAF	3.37%	-6.814	-0.230
BIG BEND 3	70.6 EAF	7.73%	3.785	0.293
BIG BEND 4	87.6 EAF	9.72%	-4.212	-0.409
GANNON 5	10524 ANOHR	9.33%	0.000	0.000
GANNON 6	10662 ANOHR	13.66%	-10.000	-1.366
BIG BEND 1	9935 ANOHR	13.63%	0.000	0.000
BIG BEND 2	9932 ANOHR	10.77%	0.000	0.000
BIG BEND 3	9926 ANOHR	9.02%	-10.000	-0.902
BIG BEND 4	10092 ANOHR	12.19%	-10.000	-1.219
		100.00%		-2.775

GPIF REWARD:	(\$471,209)
--------------	-------------

TAMPA ELECTRIC COMPANY  
GPIF TARGET AND RANGE SUMMARY  
OCTOBER 1994 - MARCH 1995

EQUIVALENT AVAILABILITY

<u>PLANT/UNIT</u>	<u>WEIGHTING FACTOR (%)</u>	<u>EAP TARGET (%)</u>	<u>EAP MAX. (%)</u>	<u>RANGE MIN. (%)</u>	<u>MAX. FUEL SAVINGS (\$000)</u>	<u>MAX. FUEL LOSS (\$000)</u>	<u>EAP ADJUSTED ACTUAL %</u>	<u>ACTUAL FUEL SAVINGS/LOSS (\$000)</u>
GANNON 5	1.30%	88.1	90.5	83.3	44.0	(85.4)	94.2	44.0
GANNON 6	2.87%	75.9	79.3	69.0	97.5	(236.2)	81.2	97.5
BIG BEND 1	6.41%	85.4	88.3	79.6	217.6	(407.9)	91.8	217.6
BIG BEND 2	3.37%	62.3	65.3	56.6	114.4	(304.1)	58.4	(207.8)
BIG BEND 3	7.73%	69.4	72.6	62.9	262.5	(599.3)	70.6	99.4
BIG BEND 4	<u>9.72%</u>	89.4	91.5	85.2	<u>330.2</u>	<u>(582.1)</u>	87.6	<u>(245.3)</u>
GPIF SYSTEM	31.40%				1,066.2	(2,215.0)		10.4

AVERAGE NET OPERATING HEAT RATE  
FOR  
GPIF COAL GENERATING UNITS

<u>PLANT/UNIT</u>	<u>WEIGHTING FACTOR (%)</u>	<u>ANOHR Btu/kwh</u>	<u>TARGET NOP</u>	<u>ANOHR TARGET RANGE</u>		<u>MAX. FUEL SAVINGS (\$000)</u>	<u>MAX. FUEL LOSS (\$000)</u>	<u>ACTUAL ADJUSTED ANOHR</u>	<u>ACTUAL FUEL SAVINGS/LOSS (\$000)</u>
				<u>MIN.</u>	<u>MAX.</u>				
GANNON 5	9.33%	10454	63.5	10041	10867	316.9	(316.9)	10524	0.0
GANNON 6	13.66%	10288	63.1	9945	10631	464.0	(464.0)	10662	(464.0)
BIG BEND 1	13.63%	9957	83.7	9737	10177	462.8	(462.8)	9935	0.0
BIG BEND 2	10.77%	9895	85.6	9655	10135	365.8	(365.8)	9932	0.0
BIG BEND 3	9.02%	9610	82.8	9423	9797	306.4	(306.4)	9926	(306.4)
BIG BEND 4	<u>12.19%</u>	9832	93.9	9641	10023	<u>414.0</u>	<u>(414.0)</u>	10092	<u>(414.0)</u>
GPIF SYSTEM	68.60%					2,329.9	(2,329.9)		(1,184.4)

5.00.30.

**ACTUAL UNIT PERFORMANCE DATA  
TAMPA ELECTRIC COMPANY  
OCTOBER 1994 – MARCH 1995**

<u>PLANT/UNIT</u>	<u>ACTUAL EAF %</u>	<u>ADJUSTMENTS (1) EAF %</u>	<u>EAF ADJUSTED ACTUAL %</u>
GANNON 5	90.4	3.8	94.2
GANNON 6	84.6	-3.4	81.2
BIG BEND 1	84.7	7.1	91.8
BIG BEND 2	59.3	-0.9	58.4
BIG BEND 3	87.4	-16.8	70.6
BIG BEND 4	71.1	16.5	87.6

<u>PLANT/UNIT</u>	<u>ACTUAL ANOHR Btu/kwh</u>	<u>ADJUSTMENT (2) TO ANOHR Btu/kwh</u>	<u>ANOHR ADJUSTED ACTUAL Btu/kwh</u>
GANNON 5	10166	358	10524
GANNON 6	10435	227	10662
BIG BEND 1	9903	32	9935
BIG BEND 2	9933	-1	9932
BIG BEND 3	9924	2	9926
BIG BEND 4	10246	-154	10092

(1) Documentation of adjustments to Actual EAF on pages 7-12

(2) Documentation of adjustment to Actual ANOHR on pages 13-18

TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO PERFORMANCE  
GANNON UNIT NO. 5  
OCTOBER 1994 - MARCH 1995

WEIGHTING FACTOR = 1.30%

	<u>6 MO. TARGET</u>	<u>6 MO. ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
P.H.	4369.0	4369.0	4369.0
E.A.F.	88.1	90.4	94.2
P.O.H.	0.0	173.4	0.0
F.O.H. + E.F.O.H	419.0	223.0	232.2
M.O.H. + E.M.O.H	100.0	22.1	23.0
P.O.F.	0.0	4.0	0.0
E.F.O.F.	9.6	5.1	5.3
E.M.O.F.	2.3	0.5	0.5

10.000 E. A. POINTS

ADJUSTMENTS TO EAF:

$$\frac{P.H. - TGT\ POH}{P.H. - ACT\ POH} \times (FOH + EFOH + MOH + EMOH) = \text{ADJUSTED EUOH}$$

$$\frac{4369.0 - 0.0}{4369.0 - 173.4} \times (71.9 + 151.1 + 3.2 + 18.9) = 1.0413 \times 245.1 = 255.2$$

$$\frac{POH + EUOH}{PH} \times 100\% = POF + EUOF = \frac{0.0 + 255.2}{4369.0} = 5.8$$

$$100.0 - (POF + EUOF) = EAF = 100.0 - 5.8 = 94.2$$

PH = PERIOD HOURS  
EAF = EQUIVALENT AVAILABILITY FACTOR  
POH = PLANNED OUTAGE HOURS  
FOH = FORCED OUTAGE HOURS  
MOH = MAINTENANCE OUTAGE HOURS  
EUOH = EQUIVALENT UNPLANNED OUTAGE HOURS  
POF = PLANNED OUTAGE FACTOR  
EFOF = EQUIVALENT FORCED OUTAGE FACTOR  
EMOF = EQUIVALENT MAINTENANCE OUTAGE FACTOR  
EUOF = UNPLANNED OUTAGE FACTOR



TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO PERFORMANCE  
GANNON UNIT NO. 6  
OCTOBER 1994 - MARCH 1995

WEIGHTING FACTOR = 2.87%

	<u>6 MO. TARGET</u>	<u>6 MO. ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
P.H.	4369.0	4369.0	4369.0
E.A.F.	75.9	84.6	81.2
P.O.H.	408.0	243.1	408.0
F.O.H. + E.F.O.H	547.0	112.5	108.0
M.O.H. + E.M.O.H	99.0	315.8	303.2
P.O.F.	9.3	5.6	9.3
E.F.O.F.	12.5	2.6	2.5
E.M.O.F.	2.3	7.2	6.9

10.000 E. A. POINTS

ADJUSTMENTS TO EAF:

$$\frac{P.H. - TGT\ POH}{P.H. - ACT\ POH} \times (FOH + EFOH + MOH + EMOH) = ADJUSTED\ EUOH$$

$$\frac{4369.0 - 408.0}{4369.0 - 243.1} \times (13.8 + 98.7 + 276.5 + 39.3) = 0.9600 \times 428.3 = 411.2$$

$$\frac{POH + EUOH}{PH} \times 100\% = POF + EUOF = \frac{408.0 + 411.2}{4369.0} = 18.8$$

$$100.0 - (POF + EUOF) = EAF = 100.0 - 18.8 = 81.2$$

PH = PERIOD HOURS  
EAF = EQUIVALENT AVAILABILITY FACTOR  
POH = PLANNED OUTAGE HOURS  
FOH = FORCED OUTAGE HOURS  
MOH = MAINTENANCE OUTAGE HOURS  
EUOH = EQUIVALENT UNPLANNED OUTAGE HOURS  
POF = PLANNED OUTAGE FACTOR  
EFOF = EQUIVALENT FORCED OUTAGE FACTOR  
EMOF = EQUIVALENT MAINTENANCE OUTAGE FACTOR  
EUOF = UNPLANNED OUTAGE FACTOR

TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO PERFORMANCE  
BIG END UNIT NO. 1  
OCTOBER 1994 - MARCH 1995

WEIGHTING FACTOR = 6.41%

	<u>6 MO. TARGET</u>	<u>6 MO. ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
P.H.	4369.0	4369.0	4369.0
E.A.F.	85.4	84.7	91.8
P.O.H.	0.0	335.2	0.0
F.O.H. + E.F.O.H	489.0	195.6	211.9
M.O.H. + E.M.O.H	149.0	136.6	148.0
P.O.F.	0.0	7.7	0.0
E.F.O.F.	11.2	4.5	4.9
E.M.O.F.	3.4	3.1	3.4

10.000 E. A. POINTS

ADJUSTMENTS TO EAF:

$$\frac{P.H. - TGT\ POH}{P.H. - ACT\ POH} \times (FOH + EFOH + MOH + EMOH) = \text{ADJUSTED EUOH}$$

$$\frac{4369.0 - 0.0}{4369.0 - 335.2} \times (168.5 + 27.1 + 86.5 + 50.1) = 1.0831 \times 332.2 = 359.8$$

$$\frac{POH + EUOH}{PH} \times 100\% = POF + EUOF = \frac{0.0 + 359.8}{4369.0} = 8.2$$

$$100.0 - (POF + EUOF) = \text{EAF} = 100.0 - 8.2 = 91.8$$

PH = PERIOD HOURS  
EAF = EQUIVALENT AVAILABILITY FACTOR  
POH = PLANNED OUTAGE HOURS  
FOH = FORCED OUTAGE HOURS  
MOH = MAINTENANCE OUTAGE HOURS  
EUOH = EQUIVALENT UNPLANNED OUTAGE HOURS  
POF = PLANNED OUTAGE FACTOR  
EFOF = EQUIVALENT FORCED OUTAGE FACTOR  
EMOF = EQUIVALENT MAINTENANCE OUTAGE FACTOR  
EUOF = UNPLANNED OUTAGE FACTOR

TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO PERFORMANCE  
BIG BEND UNIT NO. 2  
OCTOBER 1994 - MARCH 1995

WEIGHTING FACTOR = 3.37%

	<u>6 MO. TARGET</u>	<u>6 MO. ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
P.H.	4369.0	4369.0	4369.0
E.A.F.	62.4	59.3	58.4
P.O.H.	1344.0	1297.8	1344.0
F.O.H. + E.F.O.H	215.0	378.2	372.5
M.O.H. + E.M.O.H	85.0	100.4	98.9
P.O.F.	30.8	29.7	30.8
E.F.O.F.	4.9	8.7	8.5
E.M.O.F.	1.9	2.3	2.3

-6.814 E. A. POINTS

ADJUSTMENTS TO EAF:

$$\frac{P.H. - TGT POH}{P.H. - ACT POH} \times (FOH + EFOH + MOH + EMOH) = \text{ADJUSTED EUOH}$$

$$\frac{4369.0 - 1344.0}{4369.0 - 1297.8} \times (296.5 + 81.7 + 52.3 + 48.1) = 0.9850 \times 478.6 = 471.4$$

$$\frac{POH + EUOH}{PH} \times 100\% = POF + EUOF = \frac{1344.0 + 471.4}{4369.0} = 41.6$$

$$100.0 - (POF + EUOF) = \text{EAF} = 100.0 - 41.6 = 58.4$$

PH = PERIOD HOURS  
EAF = EQUIVALENT AVAILABILITY FACTOR  
POH = PLANNED OUTAGE HOURS  
FOH = FORCED OUTAGE HOURS  
MOH = MAINTENANCE OUTAGE HOURS  
EUOH = EQUIVALENT UNPLANNED OUTAGE HOURS  
POF = PLANNED OUTAGE FACTOR  
EFOF = EQUIVALENT FORCED OUTAGE FACTOR  
EMOF = EQUIVALENT MAINTENANCE OUTAGE FACTOR  
EUOF = UNPLANNED OUTAGE FACTOR

TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO PERFORMANCE  
BIG BEND UNIT NO. 3  
OCTOBER 1994 - MARCH 1995

WEIGHTING FACTOR = 7.73%

	<u>6 MO. TARGET</u>	<u>6 MO. ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
P.H.	4369.0	4369.0	4369.0
E.A.F.	69.4	87.4	70.6
P.O.H.	840.0	0.0	840.0
F.O.H. + E.F.O.H	371.0	415.2	335.4
M.O.H. + E.M.O.H	126.0	134.4	108.6
P.O.F.	19.2	0.0	19.2
E.F.O.F.	8.5	9.5	7.7
E.M.O.F.	2.9	3.1	2.5

3.785 E. A. POINTS

ADJUSTMENTS TO EAF:

$$\frac{P.H. - TGT\ POH}{P.H. - ACT\ POH} \times (FOH + EFOH + MOH + EMOH) = ADJUSTED\ EUOH$$

$$\frac{4369.0 - 840.0}{4369.0 - 0.0} \times (178.3 + 236.9 + 6.4 + 128.0) = 0.8077 \times 549.6 = 443.9$$

$$\frac{POH + EUOH}{PH} \times 100\% = POF + EUOF = \frac{840.0 + 443.9}{4369.0} = 29.4$$

$$100.0 - (POF + EUOF) = EAF = 100.0 - 29.4 = 70.6$$

PH = PERIOD HOURS  
EAF = EQUIVALENT AVAILABILITY FACTOR  
POH = PLANNED OUTAGE HOURS  
FOH = FORCED OUTAGE HOURS  
MOH = MAINTENANCE OUTAGE HOURS  
EUOH = EQUIVALENT UNPLANNED OUTAGE HOURS  
POF = PLANNED OUTAGE FACTOR  
EFOF = EQUIVALENT FORCED OUTAGE FACTOR  
EMOF = EQUIVALENT MAINTENANCE OUTAGE FACTOR  
EUOF = UNPLANNED OUTAGE FACTOR

TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO PERFORMANCE  
3IG BEND UNIT NO. 4  
OCTOBER 1994 - MARCH 1995

WEIGHTING FACTOR = 9.72%

	<u>6 MO. TARGET</u>	<u>6 MO. ACTUAL PERFORMANCE</u>	<u>ADJUSTED ACTUAL PERFORMANCE</u>
P.H.	4369.0	4369.0	4369.0
E.A.F.	89.4	71.1	87.6
P.O.H.	0.0	822.4	0.0
F.O.H. + E.F.O.H	354.0	311.7	384.0
M.O.H. + E.M.O.H	109.0	127.0	156.4
P.O.F.	0.0	18.8	0.0
E.F.O.F.	8.1	7.1	8.8
E.M.O.F.	2.5	2.9	3.6

-4.212 E. A. POINTS

ADJUSTMENTS TO EAF:

$$\frac{P.H. - TGT\ POH}{P.H. - ACT\ POH} \times (FOH + EFOH + MOH + EMOH) = ADJUSTED\ EUOH$$

$$\frac{4369.0 - 0.0}{4369.0 - 822.4} \times (265.7 + 46.0 + 49.3 + 77.7) = 1.2319 \times 438.7 = 540.4$$

$$\frac{POH + EUOH}{PH} \times 100\% = POF + EUOF = \frac{0.0 + 540.4}{4369.0} = 12.4$$

$$100.0 - (POF + EUOF) = EAF = 100.0 - 12.4 = 87.6$$

PH = PERIOD HOURS  
EAF = EQUIVALENT AVAILABILITY FACTOR  
POH = PLANNED OUTAGE HOURS  
FOH = FORCED OUTAGE HOURS  
MOH = MAINTENANCE OUTAGE HOURS  
EUOH = EQUIVALENT UNPLANNED OUTAGE HOURS  
POF = PLANNED OUTAGE FACTOR  
EFOF = EQUIVALENT FORCED OUTAGE FACTOR  
EMOF = EQUIVALENT MAINTENANCE OUTAGE FACTOR  
EUOF = UNPLANNED OUTAGE FACTOR

TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO HEAT RATE  
GANNON 5  
HEAT RATE DATA  
OCTOBER 1994 - MARCH 1995

WEIGHTING FACTOR = 9.33%

	<u>6 MO. TARGET</u>	<u>6 MO ACTUAL PERFORMANCE</u>
ANOHR (Btu/kwh)	10454	10166
STA. NET GEN. (GWH)	457.1	748.7
OPER. Btu (10 <sup>9</sup> btu)	4778.194	7611.626
NET OUTPUT FACTOR	63.5	80.4

0.000 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON:

$$\text{CURRENT EQUATION } \text{NOF}(-21.12600) + 11795.9 = \text{ANOHR}$$

$$80.4(-21.12600) + 11795.9 = 10096$$

$$10166 - 10096 = 70$$

$$10454 + 70 = 10524$$

ANOHR = AVERAGE NET OPERATING HEAT RATE  
NOF = NET OPERATING FACTOR

TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO HEAT RATE  
GANNON 6  
HEAT RATE DATA  
OCTOBER 1994 - MARCH 1995

WEIGHTING FACTOR = 13.66%

	<u>6 MO. TARGET</u>	<u>6 MO ACTUAL PERFORMANCE</u>
ANOHR (Btu/kwh)	10288	10435
STA. NET GEN. (GWH)	813.1	1080.0
OPER. Btu (10 <sup>9</sup> btu)	8364.894	11270.156
NET OUTPUT FACTOR	63.1	79.4

-10.000 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON:

$$\text{CURRENT EQUATION } \text{NOF}(-13.96700) + 11169.0 = \text{ANOHR}$$

$$79.4(-13.96700) + 11169.0 = 10061$$

$$10435 - 10061 = 374$$

$$10288 + 374 = 10662$$

ANOHR = AVERAGE NET OPERATING HEAT RATE  
NOF = NET OPERATING FACTOR

TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO HEAT RATE  
BIG BEND UNIT 1  
HEAT RATE DATA  
OCTOBER 1994 - MARCH 1995

WEIGHTING FACTOR = 13.63%

	<u>6 MO. TARGET</u>	<u>6 MO ACTUAL PERFORMANCE</u>
ANOHR (Btu/kwh)	9957	9903
STA. NET GEN. (GWH)	1328.4	1399.0
OPER. Btu ( $10^9$ btu)	13226.445	13553.943
NET OUTPUT FACTOR	83.7	88.8

0.000 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON:

CURRENT EQUATION  $\text{NOF}(-6.21460) + 10476.7 = \text{ANOHR}$

$88.8(-6.21460) + 10476.7 = 9925$

$9903 - 9925 = -22$

$9957 + -22 = 9935$

ANOHR = AVERAGE NET OPERATING HEAT RATE  
NOF = NET OPERATING FACTOR



TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO HEAT RATE  
BIG BEND UNIT 2  
HEAT RATE DATA  
OCTOBER 1994 - MARCH 1995

WEIGHTING FACTOR = 10.77%

	<u>6 MO. TARGET</u>	<u>6 MO ACTUAL PERFORMANCE</u>
ANOHR (Btu/kwh)	9895	9933
STA. NET GEN. (GWH)	990.4	957.5
OPER. Btu ( $10^9$ btu)	9800.153	9511.331
NET OUTPUT FACTOR	85.6	83.1

0.000 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON:

$$\text{CURRENT EQUATION } \text{NOF}(-0.44770) + 9933.1 = \text{ANOHR}$$

$$83.1(-0.44770) + 9933.1 = 9896$$

$$9933 - 9896 = 37$$

$$9895 + 37 = 9932$$

ANOHR = AVERAGE NET OPERATING HEAT RATE  
NOF = NET OPERATING FACTOR

TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO HEAT RATE  
BIG BEND 3  
HEAT RATE DATA  
OCTOBER 1994 - MARCH 1995

WEIGHTING FACTOR = 9.02%

	<u>6 MO. TARGET</u>	<u>6 MO ACTUAL PERFORMANCE</u>
ANOHR (Btu./kwh)	9610	9924
STA. NET GEN. (GWH)	1126.4	1509.5
OPER. Btu (10 <sup>9</sup> btu)	10624.983	14979.965
NET OUTPUT FACTOR	82.8	83.0

-10.000 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON:

$$\text{CURRENT EQUATION } \text{NOF}(-11.54800) + 10566.2 = \text{ANOHR}$$

$$83.0(-11.54800) + 10566.2 = 9608$$

$$9924 - 9608 = 316$$

$$9610 + 316 = 9926$$

ANOHR = AVERAGE NET OPERATING HEAT RATE  
NOF = NET OPERATING FACTOR

TAMPA ELECTRIC COMPANY  
ADJUSTMENTS TO HEAT RATE  
FIG BEND UNIT 4  
HEAT RATE DATA  
OCTOBER 1994 - MARCH 1995

WEIGHTING FACTOR = 12.19%

	<u>6 MO. TARGET</u>	<u>6 MO ACTUAL PERFORMANCE</u>
ANOHR (Btu/kwh)	9832	10246
STA. NET GEN. (GWH)	1704.5	1230.0
OPER. Btu ( $10^9$ btu)	16759.083	12603.450
NET OUTPUT FACTOR	93.9	85.2

-10.000 HEAT RATE POINTS

ADJUSTMENTS TO ACTUAL HEAT RATE FOR COMPARISON:

$$\text{CURRENT EQUATION } \text{NOF}(-17.56300) + 11481.4 = \text{ANOHR}$$

$$85.2(-17.56300) + 11481.4 = 9986$$

$$10246 - 9986 = 260$$

$$9832 + 260 = 10092$$

ANOHR = AVERAGE NET OPERATING HEAT RATE  
NOF = NET OPERATING FACTOR


TAMPA ELECTRIC COMPANY  
GPIF PLANNED OUTAGE SCHEDULE – ACTUAL  
OCTOBER 1994 – MARCH 1995

<u>STATION/UNIT</u>	<u>PLANNED OUTAGE DATES</u>	<u>OUTAGE REASON</u>
* BIG BEND 1	MAR 18 – APR 02	HTSH REPLACEMENT FURNACE FLOOR INSPECTION REPLACE SH TUBES REPLACE ACCESS DOORS RESEAL END BELLS GENERATOR HYDRO FOR LEAKAGE
BIG BEND 2	OCT 22 – DEC 13	PENTHOUSE PRESSURIZATION REPL. HTRH REPL. PULV SH/THROAT LINERS REPL. LOWER WW TUBES REPL. HT. GAS DUCT (PHASE II) REPL. BOILER FLOOR TUBES HP INSPECTION LP TURBINE MOD. INSPECT GOV. VV'S/THRTL/ INT. VV'S GEN. INSPECTION PRECIPITATOR REPAIRS
BIG BEND 4	FEB 6 – MAR 12	LP. INSPECTION INSPECT CT. VV'S COMB AHT/STOP VV'S INSP. FRT. STD. INSP. MID STD. BFPT. INSP. REHEAT MAINTENANCE BOILER CIRC. PP. OVERHAUL FGD DUCT REPL. FGD REHTR. BUNDLE REPL.
** GANNON 5	MAR 9 – MAR 16	SLAG TANK & COOLING COIL REPAIR
** GANNON 6	DEC 12 – DEC 21	FUEL SYSTEM CLEAN-UP


Milestone or Critical Path Charts of actual schedule are included on pages 20 through 22.

\* Start / End date outside of GPIF period


\*\* Outage is less than two weeks in duration and a CPM was not included for this unit.



TAMPA ELECTRIC COMPANY  
 BIG BEND UNIT NO. 1  
 PLANNED OUTAGE 1995  
 ACTUAL CPM  
 04/30/95



TAMPA ELECTRIC COMPANY  
 BIG BEND UNIT NO. 2  
 PLANNED OUTAGE 1994  
 ACTUAL CPM  
 12/31/94



TAMPA ELECTRIC COMPANY  
 BIG BEND UNIT NO. 4  
 PLANNED OUTAGE 1995  
 ACTUAL CPM  
 03/31/95

TAMPA ELECTRIC COMPANY  
GENERATING PERFORMANCE INCENTIVE POINTS TABLE

OCTOBER 1994 - MARCH 1995

GANNON 5

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS/(LOSS) (\$±1000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS/(LOSS) (\$±1000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	44.0	90.5	+10	316.9	10041
+9	39.6	90.3	+9	285.2	10075
+8	35.2	90.0	+8	253.5	10109
+7	30.8	89.8	+7	221.8	10142
+6	26.4	89.5	+6	190.1	10176
+5	22.0	89.3	+5	158.5	10210
+4	17.6	89.1	+4	126.8	10244
+3	13.2	88.8	+3	95.1	10278
+2	8.8	88.6	+2	63.4	10311
+1	4.4	88.3	+1	31.7	10345
0	0.0	88.1	0	0.0	10379
-1	(8.5)	87.6	-1	(31.7)	10454
-2	(17.1)	87.1	-2	(63.4)	10529
-3	(25.6)	86.7	-3	(95.1)	10563
-4	(34.2)	86.2	-4	(126.8)	10597
-5	(42.7)	85.7	-5	(158.5)	10630
-6	(51.2)	85.2	-6	(190.1)	10664
-7	(59.8)	84.7	-7	(221.8)	10698
-8	(68.3)	84.3	-8	(253.5)	10732
-9	(76.9)	83.8	-9	(285.2)	10766
-10	(85.4)	83.3	-10	(316.9)	10799

BAP Points 10,000

Adjusted BAP 94.2

AHR Points 0,000

Adjusted Actual AHR 10524

Weighting Factor = 1.30%

Weighting Factor = 9.33%



TAMPA ELECTRIC COMPANY  
GENERATING PERFORMANCE INCENTIVE POINTS TABLE  
OCTOBER 1994 - MARCH 1995  
GANNON 8

<u>EQUIVALENT AVAILABILITY POINTS</u>	<u>FUEL SAVINGS/(LOSS) (\$x1000)</u>	<u>ADJUSTED ACTUAL EQUIVALENT AVAILABILITY</u>	<u>AVERAGE HEAT RATE POINTS</u>	<u>FUEL SAVINGS/(LOSS) (\$x1000)</u>	<u>ADJUSTED ACTUAL AVERAGE HEAT RATE</u>
+10	97.5	79.3	+10	464.0	9945
+9	87.8	79.0	+9	417.6	9972
+8	78.0	78.6	+8	371.2	9999
+7	68.3	78.3	+7	324.8	10025
+6	58.5	77.9	+6	278.4	10052
+5	48.8	77.6	+5	232.0	10079
+4	39.0	77.3	+4	185.6	10106
+3	29.3	76.9	+3	139.2	10133
+2	19.5	76.6	+2	92.8	10159
+1	9.8	76.2	+1	46.4	10186
0	0.0	75.9	0	0.0	10213
-1	(23.6)	75.2	-1	(46.4)	10288
-2	(47.2)	74.5	-2	(92.8)	10363
-3	(70.9)	73.8	-3	(139.2)	10390
-4	(94.5)	73.1	-4	(185.6)	10417
-5	(118.1)	72.5	-5	(232.0)	10443
-6	(141.7)	71.8	-6	(278.4)	10470
-7	(165.3)	71.1	-7	(324.8)	10497
-8	(189.0)	70.4	-8	(371.2)	10524
-9	(212.6)	69.7	-9	(417.6)	10551
-10	(236.2)	69.0	-10	(464.0)	10577

HAP Points  
10,000

Adjusted HAP  
81.2

AHR Points  
-10,000

Adjusted Actual ANOHR  
10662

Weighting Factor = 2.87%

Weighting Factor = 13.66%

TAMPA ELECTRIC COMPANY  
GENERATING PERFORMANCE INCENTIVE POINTS TABLE  
OCTOBER 1994 - MARCH 1995  
BIG BEND 1

<u>EQUIVALENT AVAILABILITY POINTS</u>	<u>FUEL SAVINGS/(LOSS) (\$x1000)</u>	<u>ADJUSTED ACTUAL EQUIVALENT AVAILABILITY</u>	<u>AVERAGE HEAT RATE POINTS</u>	<u>FUEL SAVINGS/(LOSS) (\$x1000)</u>	<u>ADJUSTED ACTUAL AVERAGE HEAT RATE</u>
+10	217.6	88.3	+10	462.8	9737
+9	195.8	88.0	+9	416.5	9752
+8	174.1	87.7	+8	370.2	9766
+7	152.3	87.4	+7	324.0	9781
+6	130.6	87.1	+6	277.7	9795
+5	108.8	86.9	+5	231.4	9810
+4	87.0	86.6	+4	185.1	9824
+3	65.3	86.3	+3	138.8	9839
+2	43.5	86.0	+2	92.6	9853
+1	21.8	85.7	+1	46.3	9868
0	0.0	85.4	0	0.0	9882
-1	(40.8)	84.8	-1	(46.3)	10047
-2	(81.6)	84.2	-2	(92.6)	10061
-3	(122.4)	83.7	-3	(138.8)	10076
-4	(163.2)	83.1	-4	(185.1)	10090
-5	(204.0)	82.5	-5	(231.4)	10105
-6	(244.7)	81.9	-6	(277.7)	10119
-7	(285.5)	81.3	-7	(324.0)	10134
-8	(326.3)	80.8	-8	(370.2)	10148
-9	(367.1)	80.2	-9	(416.5)	10163
-10	(407.9)	79.6	-10	(462.8)	10177

BAP Points  
10,000

Adjusted BAP  
91.8

AHR Points  
0.000

Adjusted Actual  
ANOHR  
9935

Weighting Factor = 6.41%

Weighting Factor = 13.63%

TAMPA ELECTRIC COMPANY  
GENERATING PERFORMANCE INCENTIVE POINTS TABLE  
OCTOBER 1994 - MARCH 1995  
BIG BEND 2

<u>EQUIVALENT AVAILABILITY POINTS</u>	<u>FUEL SAVINGS/(LOSS) (\$x1000)</u>	<u>ADJUSTED ACTUAL EQUIVALENT AVAILABILITY</u>	<u>AVERAGE HEAT RATE POINTS</u>	<u>FUEL SAVINGS/(LOSS) (\$x1000)</u>	<u>ADJUSTED ACTUAL AVERAGE HEAT RATE</u>
+10	114.4	65.3	+10	365.8	9655
+9	103.0	65.0	+9	329.2	9672
+8	91.5	64.7	+8	292.6	9688
+7	80.1	64.4	+7	256.1	9705
+6	68.6	64.1	+6	219.5	9721
+5	57.2	63.8	+5	182.9	9738
+4	45.8	63.5	+4	146.3	9754
+3	34.3	63.2	+3	109.7	9771
+2	22.9	62.9	+2	73.2	9787
+1	11.4	62.6	+1	36.6	9804
				0.0	9820
0	0.0	62.3	0	0.0	9895
				0.0	9970
-1	(30.4)	61.7	-1	(36.6)	9987
-2	(60.8)	61.2	-2	(73.2)	10003
-3	(91.2)	60.6	-3	(109.7)	10020
-4	(121.6)	60.0	-4	(146.3)	10036
-5	(152.1)	59.4	-5	(182.9)	10053
-6	(182.5)	58.9	-6	(219.5)	10069
-7	(212.9)	58.3	-7	(256.1)	10086
-8	(243.3)	57.7	-8	(292.6)	10102
-9	(273.7)	57.2	-9	(329.2)	10119
-10	(304.1)	56.6	-10	(365.8)	10135

BAF Points  
-6.798

Adjusted  
BAF  
58.4

AHR  
Points  
0.000

Adjusted  
Actual  
ANOHR  
9932

Weighting Factor = 3.37%

Weighting Factor = 10.77%

TAMPA ELECTRIC COMPANY  
GENERATING PERFORMANCE INCENTIVE POINTS TABLE  
OCTOBER 1994 - MARCH 1995  
BIG BEND 3

<u>EQUIVALENT AVAILABILITY POINTS</u>	<u>FUEL SAVINGS/(LOSS) (\$x1000)</u>	<u>ADJUSTED ACTUAL EQUIVALENT AVAILABILITY</u>	<u>AVERAGE HEAT RATE POINTS</u>	<u>FUEL SAVINGS/(LOSS) (\$x1000)</u>	<u>ADJUSTED ACTUAL AVERAGE HEAT RATE</u>
+10	262.5	72.6	+10	306.4	9423
+9	236.3	72.3	+9	275.8	9434
+8	210.0	71.0	+8	245.1	9445
+7	183.8	71.6	+7	214.5	9457
+6	157.5	71.3	+6	183.8	9468
+5	131.3	71.0	+5	153.2	9479
+4	105.0	70.7	+4	122.6	9490
+3	78.8	70.4	+3	91.9	9501
+2	52.5	70.0	+2	61.3	9513
+1	26.3	69.7	+1	30.6	9524
				0.0	9535
0	0.0	69.4	0	0.0	9610
				0.0	9685
-1	(59.9)	68.8	-1	(30.6)	9696
-2	(119.9)	68.1	-2	(61.3)	9707
-3	(179.8)	67.5	-3	(91.9)	9719
-4	(239.7)	66.8	-4	(122.6)	9730
-5	(299.7)	66.2	-5	(153.2)	9741
-6	(359.6)	65.5	-6	(183.8)	9752
-7	(419.5)	64.9	-7	(214.5)	9763
-8	(479.4)	64.2	-8	(245.1)	9775
-9	(539.4)	63.6	-9	(275.8)	9786
-10	(599.3)	62.9	-10	(306.4)	9797

HAF  
Points  
3.785

Adjusted  
HAF  
70.6

AHR  
Points  
-10.009

Adjusted  
Actual  
ANHR  
9926

Weighting Factor = 7.73%

Weighting Factor = 9.02%

TAMPA ELECTRIC COMPANY  
GENERATING PERFORMANCE INCENTIVE POINTS TABLE  
OCTOBER 1994 - MARCH 1995  
BIG BEND 4

<u>EQUIVALENT AVAILABILITY POINTS</u>	<u>FUEL SAVINGS/(LOSS) (\$1000)</u>	<u>ADJUSTED ACTUAL EQUIVALENT AVAILABILITY</u>	<u>AVERAGE HEAT RATE POINTS</u>	<u>FUEL SAVINGS/(LOSS) (\$1000)</u>	<u>ADJUSTED ACTUAL AVERAGE HEAT RATE</u>
+10	330.2	91.5	+10	414.0	9641
+9	297.2	91.3	+9	372.6	9653
+8	264.2	91.1	+8	331.2	9664
+7	231.1	90.9	+7	289.8	9676
+6	198.1	90.7	+6	248.4	9687
+5	165.1	90.5	+5	207.0	9699
+4	132.1	90.2	+4	165.6	9711
+3	99.1	90.0	+3	124.2	9722
+2	66.0	89.8	+2	82.8	9734
+1	33.0	89.6	+1	41.4	9745
				0.0	9757
0	0.0	89.4	0	0.0	9832
				0.0	9907
-1	(58.2)	89.0	-1	(41.4)	9919
-2	(116.4)	88.6	-2	(82.8)	9930
-3	(174.6)	88.1	-3	(124.2)	9942
-4	(232.8)	87.7	-4	(165.6)	9953
-5	(291.1)	87.3	-5	(207.0)	9965
-6	(349.3)	86.9	-6	(248.4)	9977
-7	(407.5)	86.5	-7	(289.8)	9988
-8	(465.7)	86.0	-8	(331.2)	10000
-9	(523.9)	85.6	-9	(372.6)	10011
-10	(582.1)	85.2	-10	(414.0)	10023

EAP Points -4.215	Adjusted EAP 87.6	AHR Points -10.000	Adjusted Actual AHOHR 10092
-------------------------	-------------------------	--------------------------	--------------------------------------

Weighting Factor =	9.72%	Weighting Factor =	12.19%
--------------------	-------	--------------------	--------

TAMPA ELECTRIC COMPANY

COMPARISON OF GPIF TARGETS VS. PRIOR PERIOD ACTUAL PERFORMANCE

AVAILABILITY

PLANT/UNIT	TARGET WEIGHTING FACTOR	NORMALIZED WEIGHTING FACTOR	TARGET PERIOD OCT 94 - MAR 95			ACTUAL PERFORMANCE OCT 94 - MAR 95		
			POF	EUOF	EUOR	POF	EUOF	EUOR
BIG BEND 1	6.41%	20.4	0.0	14.6	14.6	7.7	7.6	8.2
BIG BEND 2	3.37%	10.7	30.8	6.9	9.9	29.7	11.0	15.6
BIG BEND 3	7.73%	24.6	19.2	11.4	14.1	0.0	12.6	12.6
BIG BEND 4	9.72%	31.0	0.0	10.6	10.6	18.8	10.0	12.3
GANNON 5	1.30%	4.1	0.0	11.9	11.9	4.0	5.6	5.8
GANNON 6	2.87%	9.1	9.3	14.6	16.3	5.6	9.8	10.4
	31.40%	100.0	8.9	11.6	12.6	11.3	10.1	11.5
GPIF SYSTEM WGT'D AVG.								
GPIF SYSTEM WEIGHTED EQUIVALENT AVAILABILITY			<u>79.5</u>			<u>78.7</u>		
			5 PERIOD AVERAGE			5 PERIOD AVERAGE		
			<u>POF</u>	<u>EUOE</u>	<u>EUOR</u>	<u>EAF</u>		
			8.3	11.9	13.1	79.8		

AVERAGE NET OPERATING HEAT RATE (Btu/kwh)

PLANT/UNIT	TARGET WEIGHTING FACTOR	NORMALIZED WEIGHTING FACTOR	HEAT RATE TARGET	ADJUSTED
				ACTUAL HEAT RATE OCT 94 - MAR 95
GANNON 5	9.33%	13.6	10454	10524
GANNON 6	13.66%	19.9	10288	10662
BIG BEND 1	13.63%	19.9	9957	9935
BIG BEND 2	10.77%	15.7	9895	9932
BIG BEND 3	9.02%	13.1	9610	9926
BIG BEND 4	12.19%	17.8	9832	10092
	68.60%	100.0		
GPIF SYSTEM WEIGHTED AVERAGE H.R. (Btu/kwh)			10013	10186

TAMPA ELECTRIC COMPANY  
GENERATING PERFORMANCE INCENTIVE POINTS CALCULATION  
OCTOBER 1994 - MARCH 1995

Points are calculated according to the formula:

$$GPIP = \sum_{i=1}^n [ (a_i) (EAP_i) + (e_i) (AHRP_i) ]$$

Where:

$$i = 1, n$$

a = Unit equivalent availability weighting factor

EAP = Unit equivalent availability points

e = Station average heat rate weighting factor

AHRP = Station average heat rate points

Weighting factors and point values are listed in separate tables.

$$\begin{aligned} GPIP &= 1.30\% (GN5 EAP) + 2.87\% (GN6 EAP) + 6.41\% (BB1 EAP) \\ &+ 3.37\% (BB2 EAP) + 7.73\% (BB3 EAP) + 9.72\% (BB4 EAP) \\ &+ 9.33\% (GN5 AHRP) + 13.66\% (GN6 AHRP) + 13.63\% (BB1 AHRP) \\ &+ 10.77\% (BB2 AHRP) + 9.02\% (BB3 AHRP) + 12.19\% (BB4 AHRP) \end{aligned}$$

$$\begin{aligned} GPIP &= 1.30\% (10.000) + 2.87\% (10.000) + 6.41\% (10.000) \\ &+ 3.37\% (-6.814) + 7.73\% (3.785) + 9.72\% (-4.212) \\ &+ 9.33\% (0.000) + 13.66\% (-10.000) + 13.63\% (0.000) \\ &+ 10.77\% (0.000) + 9.02\% (-10.000) + 12.19\% (-10.000) \end{aligned}$$

$$\begin{aligned} GPIP &= (0.130) + (0.287) + (0.641) + (-0.230) + (0.293) \\ &+ (-0.409) + (0.000) + (-1.366) + (0.000) + (0.000) \\ &+ (-0.902) + (-1.219) \end{aligned}$$

$$GPIP = -2.775 \text{ POINTS}$$

REWARD/PENALTY dollar amounts of the Generating Performance Incentive Factor (GPIF) are determined directly from the table for the corresponding Generating Performance Points (GPIP) - see page 2.

$$GPIP = \underline{\$-471,209}$$