

805

GATLIN, WOODS & CARLSON
Attorneys at Law
a partnership including a professional association

The Mahan Station
1709-D Mahan Drive
Tallahassee, Florida 32308

**ORIGINAL
FILE COPY**

TELEPHONE (904) 877-7191
TELEFAX (904) 877-9031

B. KENNETH GATLIN, P.A.
THOMAS F. WOODS
JOHN D. CARLSON
WAYNE L. SCHIEFELBEIN

April 3, 1996

HAND DELIVERY

Ms. Blanca S. Bayo, Director
Division of Records and Reporting
Florida Public Service Commission
2540 Shumard Oak Blvd.
Tallahassee, Florida 32399-0850

RE: Docket No. 950387-SU
Application of Florida Cities Water Company, North Ft. Myers Division,
for an Increase in Wastewater Rates in Lee County, Florida

Dear Ms. Bayo:

Enclosed for filing are an original and fifteen copies of our Certificate of Service and Rebuttal Testimony with Exhibits of the following persons:

- 1) Michael Acosta; 03833-96
- 2) Julie L. Karleskint with the following exhibit: 03834-96
Exhibit ___ (JLK-4) Letter to Jim Bishop, Lochmoor Country Club, with signed Reuse Agreement;
- 3) Robert Dick; 03835-96
- 4) Douglas R. Young; 03836-96
- 5) Larry N. Coel, with the following exhibits: 03837-96
Exhibit ___ (LC-3) Affiliate Transactions Audit Report
Exhibit ___ (LC-4) Letter from Charles Hill dated May 23, 1995 establishing the MFRs filing date
Exhibit ___ (LC-5) Rate Case Expenses (Through HEARING); and
- 6) Joseph Schifano; 03838-96
- 7) Thomas A. Cummings, with the following exhibit: 03839-96
Exhibit ___ (TAC-1) Notification of completion of construction

ACK ✓
 AFA 2
 APP _____
 CAF _____
 CMU _____
 CTR _____
 EAG _____
 LEG 1
 LIN 3
 OPC _____
 RCH _____
 SEC _____
 WAS Willis
 OTH _____

RECEIVED & FILED

[Signature]
FPSC-BUREAU OF RECORDS

Letter to Blanca S. Bayo, Director
April 3, 1996
Page 2 of 2

Please acknowledge receipt of foregoing by stamping the enclosed extra copy of this letter and returning same to my attention.

Very truly yours,

A handwritten signature in cursive script that reads "B. Kenneth Gatlin". The signature is written in dark ink and is positioned above the printed name.

B. Kenneth Gatlin

BKG/met
Enclosures

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

Re: Application of Florida Cities Water)
Company, North Ft. Myers Division,)
for an increase in wastewater rates in)
Lee County, Florida)

Docket No. 950387-SU

Filed: April 3, 1996

CERTIFICATE OF SERVICE

I HERBY CERTIFY that a true and correct copy of the following Rebuttal Testimony and Exhibit:

- 1) Michael Acosta;
- 2) Julie L. Karleskint with the following exhibit:
Exhibit ___ (JLK-4) Letter to Jim Bishop, Lochmoor Country Club, with signed Reuse Agreement;
- 3) Robert Dick;
- 4) Douglas R. Young;
- 5) Larry N. Coel, with the following exhibits:
Exhibit ___ (LC-3) Affiliate Transactions Audit Report
Exhibit ___ (LC-4) Letter from Charles Hill dated May 23, 1995 establishing the MFRs filing date
Exhibit ___ (LC-5) Rate Case Expenses (Through HEARING)
- 6) Joseph Schifano;
- 7) Thomas A. Cummings, with the following exhibit:
Exhibit ___ (TAC-1) Notification of completion of construction

has been furnished by hand delivery to Mr. Ralph Jaeger, Esquire, Division of Legal Services, Florida Public Service Commission, 2540 Shumard Oak Boulevard, Tallahassee, Florida 32399-0850, and to Harold McLean, Esquire, Office of Public Counsel, 111 W. Madison Street, Room 812, Claude Pepper Building, Tallahassee, Florida 32399-1400, and by regular U.S. Mail on this 3rd day of April, 1996 to:

Harry Bowne
4274 Harbour Lane
N. Ft. Myers, FL 33903

Nancy L. McCullough
683 Camellia Drive
N. Ft. Myers, FL 33903

Eugene W. Brown
2069 W. Lakeview Boulevard
N. Ft. Myers, FL 33903

Fay A. Schweim
4640 Vinsetta Avenue
N. Ft. Myers, FL 33903

Eugene F. Pettenelli
4300 Glasgow Court
N. Ft. Myers, FL 33903

Jerilyn L. Victor
1740 Dockway Drive
N. Ft. Myers, FL 33903

Beverly and Robert Hemenway
4325 S. Atlantic Circle
N. Ft. Myers, FL 33903

C. Belle Morrow
691 Camellia Drive
N. Ft. Myers, FL 33903


Dawn E. Coward
951 Tropical Palm Avenue
N. Ft. Myers, FL 33903

Kevin A. Morrow
905 Poinsettia Drive
N. Ft. Myers, FL 33903

Doris T. Hadley
1740 Dockway Drive
N. Ft. Myers, FL 33903

Cheryl Walla
1750 Dockway Drive
N. Ft. Myers, FL 33903

Respectfully submitted



B. Kenneth Gatlin
Fla. Bar #0027966
Gatlin, Woods, Carlson & Cowdery
1709-D Mahan Drive
Tallahassee, Florida 32308
(904) 877-7191

Attorneys for
FLORIDA CITIES WATER COMPANY

**ORIGINAL
FILE COPY**

1 FLORIDA CITIES WATER COMPANY
2 NORTH FORT MYERS DIVISION
3 REBUTTAL TESTIMONY OF THOMAS A. CUMMINGS
4 TO DIRECT TESTIMONY OF KIMBERLY DISMUKES
5 AND BENNIE T. SHOEMAKER
6 Docket No. 950387-SU

7 Q. Please state your name and business address.

8 A. My name is Thomas A. Cummings. My business address is
9 Black & Veatch, 2701 North Rocky Point Drive, Suite
10 960, Tampa, Florida 33607.

11 Q. Could you briefly describe your educational background
12 and your professional qualifications?

13 A. I received my Bachelor of Science degree in Civil
14 Engineering from Purdue University in 1979, and have
15 completed Master of Science degree course work in
16 Environmental Engineering and Science from the
17 University of Missouri through 1985. I am a
18 registered professional engineer in the States of
19 Florida and Kansas. I was originally registered in
20 Kansas, in March, 1984, after passing the examination
21 in sanitary engineering, and registered in Florida in
22 August, 1990.

23 Q. Please describe your professional engineering
24 experience concerning water and wastewater utilities?

25 A. I have over 12 years continuous experience as a

1 registered professional engineer specializing in
2 studying, planning, designing, permitting and managing
3 the construction of water and wastewater facilities
4 for public and private investor-owned utilities in the
5 State of Florida. I have been engineer-of-record for
6 the design and permitting of five wastewater and/or
7 water treatment plants, and assisted with the design,
8 permitting and construction management of numerous
9 others. I have studied and designed water treatment
10 facilities utilizing biological and chemical
11 treatments. I have been involved in the hydraulic
12 model analysis and mechanical review of over fifteen
13 water and wastewater systems and the preparation of
14 over 25 water and/or wastewater treatment plant
15 facility designs. My design and permitting experience
16 also includes over 30 miles of raw water mains,
17 potable water mains and force mains ranging in size
18 from 4 inches to 60 inches.

19 Q. By whom are you presently employed?

20 A. I am currently employed by Black & Veatch.

21 Q. Can you briefly describe the services that Black &
22 Veatch provides?

23 A. Yes. Black & Veatch is a professional engineering and
24 consulting firm that has 80 offices and over 6,000
25 employees. The services that Black & Veatch can

1 provide are capabilities in the environmental, civil,
2 electric, power, building, process, and management
3 consulting fields as well as procurement and
4 construction.

5 Q. Has Florida Cities Water Company (FCWC) ever utilized
6 the expertise of a Black & Veatch employee as an
7 expert witness before the PSC at a rate case hearing?

8 A. Yes, in FCWC's South Ft. Myers wastewater rate case,
9 PSC Order No. PSC-93-1288-FOF-SU, Docket No. 920808-SU
10 (9/7/93).

11 Q. Specifically, what did Black & Veatch attest to in
12 that rate case?

13 A. Black & Veatch's witness testified to the used and
14 useful treatment plant components in that proceeding.

15 Q. Did the PSC accept Black & Veatch's testimony related
16 to used and useful components?

17 A. Yes.

18 Q. What is your position with that firm?

19 A. I am a project manager/project engineer.

20 Q. How long have you held that position?

21 A. I have held the position since 1985.

22 Q. What are your normal duties for the firm?

23 A. The majority of my time I am responsible for
24 engineering duties for numerous projects and clients
25 for which my role is either the project manager, or

1 project engineer, depending upon the nature and scope
2 of our services.

3 Q. What is the purpose of your testimony?

4 A. The purpose of my testimony is to establish the
5 capacity of the Waterway Estates Advanced Wastewater
6 Treatment Plant (WWTP) in response to the direct
7 testimony of Office of Public Counsel witness Kimberly
8 Dismukes and PSC staff witness Bennie Shoemaker.

9 Q. Are you the Black & Veatch project manager for the
10 Waterway Estates WWTP expansion to provide advanced
11 wastewater treatment?

12 A. Yes, I am.

13 Q. Did you prepare the preliminary design report and the
14 Florida Department of Environmental Protection (FDEP)
15 permit application for the Waterway Estates WWTP
16 expansion to provide advanced wastewater treatment?

17 A. Yes, I did.

18 Q. Aren't you also the engineer of record for this
19 facility?

20 A. Yes, I am.

21 Q. Did Black & Veatch provide the final design and
22 construction management services for the Waterway
23 Estates WWTP expansion?

24 A. Yes, they did.

25 Q. Were you also the project manager of these portions of

1 the project for Black & Veatch?

2 A. Yes, I was.

3 Q. Do you agree with witness Dismukes' use of a plant
4 capacity of 1.5 MGD?

5 A. No.

6 Q. What was the design capacity of the plant contained in
7 the preliminary design report and FDEP permit
8 application?

9 A. 1.30 million gallons per day (MGD) expandable to 1.5
10 MGD.

11 Q. On what basis was the plant capacity expansion
12 designed and rated?

13 A. The plant expansion was originally designed to treat
14 1.30 MGD on an average annual daily flow basis.

15 Q. Did FCWC direct you to change the design after the
16 preliminary design report was prepared and the FDEP
17 permit application was filed?

18 A. Yes. FCWC directed us to change the design capacity
19 to a maximum of 1.25 MGD based on the annual average
20 daily flow and the design waste concentration
21 associated with this flow.

22 Q. Why was this change made?

23 A. The plant capacity of the original plant was
24 determined based upon providing reclaimed water at an
25 annual rate of 0.30 MGD to the Lochmoor Country Club

1 Golf Course for irrigation. After the design was
2 completed, it became apparent that the actual
3 irrigation rate was less than originally estimated.

4 Q. What was the original irrigation rate use in the
5 design?

6 A. The original irrigation rate used in the design was
7 0.96 inches per week over 81 acres. This was reduced
8 to account for reduced usage during wet weather
9 periods.

10 Q. Did you make the design change?

11 A. Yes.

12 Q. In your professional opinion, was this change prudent?

13 A. Yes.

14 Q. What is the capacity of the facility that was actually
15 constructed by FCWC?

16 A. The plant capacity will be equal to 1.25 MGD based
17 upon the average annual daily flow and the waste
18 concentration associated with this flow.

19 Q. Is this capacity change reflected in the construction
20 permit?

21 A. No. In discussions with FDEP staff, it was decided
22 that it would be best to reflect this change in design
23 capacity on the operating permit application, rather
24 than submitting an application for modification of the
25 construction permit.

1 Q. Does the notification of completion of construction
2 for the Waterway Estates WWTP reflect the design
3 changes associated with reducing the capacity to 1.25
4 MGD?

5 A. Yes, it does. Please see Exhibit ____ (TAC-1) for a
6 copy of the notification.

7 Q. Did you assist FCWC with the preparation of the
8 operating permit application for this facility?

9 A. Yes.

10 Q. When will you submit the operating permit application
11 to FDEP for approval?

12 A. The application will be submitted in early May, 1996.

13 Q. What design capacity is shown on the operating permit
14 application?

15 A. 1.25 MGD.

16 Q. What basis of design flow is shown on the operating
17 permit application?

18 A. The basis of design flow is the annual average daily
19 flow.

20 Q. Could the plant, as constructed, be permitted to treat
21 a flow greater than 1.25 MGD?

22 A. No.

23 Q. Please explain how plant capacity is determined?

24 A. Wastewater treatment plants are normally designed to
25 remove solids and dissolved pollutants contained in

1 the raw wastewater received by the plant. The plants
2 are normally permitted by the regulatory agency to
3 meet effluent requirements on an annual average basis.
4 Of course, the flow received by a wastewater treatment
5 plant is not constant, but varies during the day in
6 relationship to the activities of the customers
7 connected to the plant. The flows also vary daily and
8 seasonally throughout any given year in response to
9 weather conditions, the influx of seasonal and tourist
10 population, changes in the number of wastewater
11 customers, etc. Therefore, these variations must be
12 considered when designing the plant and are normally
13 calculated from historical or industry literature data
14 as a multiple of the annual average daily design flow.

15 The peak hour flow results when customers are most
16 active during the daytime hours and the plant design
17 must be able to hydraulically allow this flow to pass
18 through the plant to prevent the treatment units from
19 overflowing and at the same time, provide full
20 treatment.

21 Each individual unit process must be analyzed in
22 relationship to accepted design standards to determine
23 its ability to meet effluent quality limits under
24 varying flow conditions associated with the annual
25 average daily design flow. Even though these unit

1 processes may provide acceptable effluent quality in
2 response to short-term variations in influent flow,
3 the plant generally will not be able to meet these
4 limits on a continuous basis.

5 The plant capacity is not only based upon the
6 hydraulic capacity received by the facility, it is
7 also based upon the load or quantity of pollutants
8 carried by the flow which require treatment or removal
9 in order to meet the effluent limitations. The
10 pollutant load is normally determined based upon the
11 average annual daily design flow and the associated
12 design pollutant concentrations. Therefore, the plant
13 capacity determination must also take into account the
14 ability of the unit processes to remove the influent
15 pollutant load down to levels that meet the effluent
16 limitations.

17 The final determination of plant capacity is based
18 upon the ability to respond to variations in raw
19 wastewater flow and pollutant load, and whichever of
20 these variables is the most limiting upon plant
21 capacity is usually the final determining factor.

22 Q. Is the limiting plant capacity factor at Waterway
23 Estates WWTP the disposal capacity as stated in the
24 direct testimony of Witness Shoemaker?

25 A. No.

- 1 Q. What is the limiting factor regarding plant capacity?
- 2 A. The treatment process.
- 3 Q. What qualifications and experience are required to
- 4 determine capacity of a wastewater treatment facility?
- 5 A. A person would need to thoroughly understand all
- 6 technical aspects of the operations and functions of
- 7 the various components of the wastewater facility,
- 8 have knowledge of the variations of raw wastewater
- 9 quality and quantity, have knowledge of the applicable
- 10 rules, regulations, industry standards and reference
- 11 documents that govern its design, and possess the
- 12 experience and training required to analyze and
- 13 evaluate each of these to make a determination of the
- 14 capacity of a facility. These qualifications and
- 15 experience would normally be possessed by a
- 16 professional engineer practicing in the areas of
- 17 sanitary or environmental engineering with specific
- 18 training and experience in the design and operation of
- 19 wastewater treatment facilities.
- 20 Q. Could a person not possessing these qualifications
- 21 determine the capacity of a wastewater treatment
- 22 facility such as Waterway Estates?
- 23 A. No.
- 24 Q. What qualifications and experience are required to
- 25 obtain an FDEP permit for a wastewater treatment

- 1 plant?
- 2 A. At a minimum, a person must be a registered
3 professional engineer in the State of Florida in order
4 to sign and seal the application form and certify the
5 completion of construction as required by the FDEP in
6 accordance with the provisions of s. 403.0877, Florida
7 Statutes. Moreover, Rule 62-600.715, Florida
8 Administrative Code, requires that a preliminary
9 design report signed and sealed by the engineer of
10 record accompany the application. Additionally, the
11 rules of practice for professional engineers prohibit
12 them from performing assignments when they are not
13 qualified by training or experience in the field or
14 discipline of engineering involved. Rule 61G15-
15 19.001(6)(c), Florida Administrative Code, Rules Of
16 The State Board of Professional Engineers. In
17 essence, this means that the engineer, besides being
18 registered, should practice in the areas of sanitary
19 or environmental engineering and have specific
20 educational background or experience in the design and
21 operation of wastewater treatment facilities, as well
22 as knowledge of applicable rules, regulations, and
23 guidance documents.
- 24 Q. In your professional opinion, what capacity should be
25 utilized to determine the used and useful percentage

1 for the Waterway Estates WWTP?

2 A. The average annual daily flow capacity of 1.25 MGD
3 should be used.

4 Q. Does this conclude your testimony?

5 A. Yes.

6

EXHIBIT _____ (TAC-1)

NOTIFICATION OF COMPLETION
OF CONSTRUCTION



NOTIFICATION OF COMPLETION OF CONSTRUCTION FOR WASTEWATER FACILITIES

1. Instructions

- a. In accordance with Rule 62-620.610, F.A.C., this form must be submitted to the Department's appropriate district office or approved local program prior to placing a newly constructed facility or modified portion of an existing facility into operation for any purpose other than testing for leaks and equipment operation.
- b. Each applicable item must be completed in full. Where attached sheets or other technical documentation are used in lieu of the blank spaces provided, indicate appropriate cross-references in the spaces.
- c. Three (3) copies of this notification with supporting documentation shall be submitted with this form.
- d. All information is to be typed or printed in ink. Dates are to be entered in MM/DD/YR format.

2. Facility Information

a. Permit Number DC36-237227 b. Facility Identification Number 5236P01630

c. Project/Facility Name Waterway Estates WRF

d. Contact Name Robert Dick
 Number and Street 7401 College Parkway
 City/State/Zip Code Fort Myers, Florida 33907
 Telephone (941) 936-0247

3. Description of Facilities to be Placed into Operation:

See Attachment A

4. Description of Substantial Deviations from the Permit, Approved Preliminary Design Report, and Application Materials:

See Attachment B

5. Implementation Dates

a. Actual Date Construction Began	<u>03/15/95</u>
b. Scheduled Date to Place Facilities into Operation	<u>05/15/96</u>
c. Scheduled Date to Attain Operational Level	<u>02/15/96</u>
d. Scheduled Date to Submit DEP Form 62-620.910(13) ¹	<u>03/15/95</u>

¹In accordance with Rule 17-620.610, F.A.C., DEP Form 17-620.910(13) Notification of Availability of Record Drawings and Final Operation and Maintenance Manuals for Wastewater Facilities must be submitted within six months after the facilities are placed into operation.

SM

6. Certifications

a. Applicant or Authorized Representative

I certify that the statements made in this notification and all attachments are true, correct and complete to the best of my knowledge and belief. I agree to operate and maintain these wastewater facilities in such a manner as to comply with the provisions of Chapter 403, F.S., Chapter 62-600, F.A.C., and all other applicable rules of the Department. Further, an appropriate draft operation and maintenance manual which has been examined by a professional engineer as certified below is available and located at The Waterway Estates, WRF and can be submitted upon request.

of the expanded facilities

Mike Acosta

3/2/96

(Signature of Applicant or Authorized Representative²)

(Date)

Name (please type) Mike Acosta, P.E. Company Name Florida Cities Water Company
Title V.P. Engineering & Operation Company Address 4837 Swift Rd, Suite 100
Phone (813) 925-3088 City/State/Zip Code Sarasota, FL 34231

b. Professional Engineer Registered in Florida

I certify that the facilities listed above have been completed to the point where the facilities are functionally complete. I further certify that construction on these facilities has proceeded substantially in accordance with the permit and the approved preliminary design report and application materials, or that deviations noted above will not prevent the system from functioning in compliance with all applicable statutes of the State of Florida and rules of the Department when properly operated and maintained. These determinations have been based upon on-site observation of construction, scheduled and conducted by me or by a project representative ~~under my direct supervision~~ for the purpose of determining if the work proceeded in compliance with the permit and the approved preliminary design report and application materials.

Company Name Black & Veatch
Company Address 2701 N. Rocky Point
City/State/Zip Code Tampa, FL 33607
Phone Number (813) 281-0032

Name (please type) Thomas A. Cummings, P.E.
Drive, Suite 960

Thomas A. Cummings
4/23/96
43476

(Seal, Signature, Date, and Registration Number)

c. Professional Engineer Registered in Florida

I certify that the draft operation and maintenance manual for these wastewater facilities has been prepared or examined by me or by individual(s) under my direct supervision and that there is reasonable assurance, in my professional judgement, that the facilities, when properly operated and maintained in accordance with this manual, will comply with all applicable statutes of the State of Florida and rules of the Department.

Company Name Black & Veatch
Company Address 2701 N. Rocky Point
City/State/Zip Code Tampa, FL 33607
Phone Number (813) 281-0032

Name (please type) Thomas A. Cummings, P.E.
Drive, Suite 960

Thomas A. Cummings
4/23/96
43476

(Seal, Signature, Date, and Registration Number)

²If signed by the authorized representative, attach a letter of authorization.

ATTACHMENT A

3. Description of Facilities to be Placed into Operation.

- **Rotating Drum Screen**
- **Mechanical Mixer for Equalization Tank**
- **Chlorine Feed System**
- **Compressed Air System for Automatic Pinch Valves**
- **Mixed Liquor Suspended Solids Recycle Pumping System**
- **Lime Storage/Feed Silo for Sludge Stabilization**
- **Blower Addition/Rehabilitation for Increased Aeration**
- **Additional Diffusers in Biological Treatment Unit No. 1.**
- **Reclaimed Water Pumping System**
- **Reclaimed Water Transmission Pipeline**
- **Miscellaneous Structural, Mechanical and Instrumentation Improvements**

ATTACHMENT B**4. Description of Substantial Deviations from the Permit, Approved Preliminary Design Report, and Application Materials:**

- Reclaimed water discharge structure at Lochmoor Golf Course pond was provided as an exposed surface discharge in a protective cage. A submerged diffuser type discharge was originally submitted.
- New buried yard piping at the plant was provided as AWWA C900, C905 PVC pipe with ductile iron mechanical joint fittings and mega-lug wedge acting restrainers.
- Only eight of the originally submitted eleven new diffuser banks were installed in BTU #1.
- A sludge recirculation pipe was provided to flow equalization tank.
- The lime storage/feed silo for sludge stabilization is installed in its entirety. All components of silo have not been tested due to the pending FDEP air pollution permit.
- Controls for the reclaimed water transmission system have been set in accordance with the attached Operating Protocol.
- The Waterway Estates WRF capacity is 1.25 MGD based on Annual Average Daily Flow.

OPERATING PROTOCOL

WATERWAY ESTATES WATER RECLAMATION FACILITY REUSE WATER SYSTEM

The Waterway Estates Water Reclamation Facility has a present design capacity of 1.25 MGD which can be expanded to 1.5 MGD upon the installation of additional mechanical equipment. The plant is equipped with ultraviolet disinfection with a surface water discharge to the Caloosahatchee River, flow can also be diverted after UV disinfection and chlorinated in the reclaimed water main for discharge to the Lochmoor Country Club storage ponds. From the storage ponds it will be utilized by Lochmoor for irrigation.

Normal plant discharge will be by gravity to the river. However, when reclaimed water is required by Lochmoor the reclaimed water pump and chlorinator will be started and chlorinated flow will be diverted to the Lochmoor storage pond. When there is no reclaimed water demand the pump will stop and all flow will go to the river.

Demand for the reclaimed water is controlled by a float valve located at the golf course pond. When the level in the pond drops to a preset limit the float valve will open and the pressure in the main will drop. The pressure sensor will actuate the reuse pump when a preset pressure is noted. When the pond level rises to a predetermined height, the float valve will close causing an increase in pressure in the main which will in turn shut off the reuse pump.

The reuse system can be monitored by the plant computer system at both Waterway Estates and Fiesta Village. The Fiesta Village Plant is staffed 24 hours/day. The plant computers are able to monitor the reuse valve status, main pressure, irrigation pump status, chlorine residuals and turbidity. The system can also operate the reuse pump from remote locations.

In order to assure reliability of the reuse system, continuous on-line monitoring for turbidity and total chlorine residual is provided and monitored by both plant computer systems. In the event that the total residual chlorine drops below 1.3 mg/l or the turbidity exceeds 3 NTU, the reuse pumps will automatically shut off by the computer, the isolation valve will close and all flow will go to the river. The reuse pumps will not restart until the operator manually checks the system and turns the system back on.

The Waterway Estates WRP will provide reclaimed water to Lochmoor except under the following conditions:

- 1) Total Residual Chlorine falls below 1.3 mg/L (flow will be automatically diverted to river per plant computer).
- 2) Turbidity exceeds 3 NTU (flow will be automatically diverted to river per plant computer).
- 3) TSS prior to application of disinfectant exceeds 5 mg/L.
- 4) Any one fecal coliform sample detects 25 colonies/100mls after chlorination.
- 5) Other conditions such as failures, breakdowns, plant upsets, etc that have been confirmed and may have a potential adverse impact on the public health.

In the event any one or more of the above conditions are met the following actions will be taken:

A. Immediate Action

- 1) Shut off the irrigation pumps if this has not already been completed by the computer.
- 2) Investigate and identify exact cause/source of problem and determine if short or long term corrective actions are needed. Assess the problem as it relates to the operational capabilities of the system.
- 3) Provide immediate preliminary report to key management personnel.

B. Short Term Corrective Actions (2 Hours)

- 1) Make necessary corrections/repairs.
- 2) If repairs are to exceed 2 hours, follow long term corrective actions.

C. Long Term Corrective Actions

- 1). Irrigation valve shall be closed and pump shut down either automatically or manually. Restart will only be done manually by operator. All flow will be diverted to river.
- 2) Notify Lochmoor of system shutdown (995-0081)
- 3) The reclaimed water system will remain shut down until all corrective action has been completed and quality standards are met before the system placed back on line. Customer will be notified prior to restoration of service.
- 4) Notify the proper authorities of the possible problem and system shut down.