


BEFORE THE  
FLORIDA PUBLIC SERVICE COMMISSION

-----  
In the Matter of

DOCKET NO. 950495-WS

Application for rate increase and increase in service availability charges by Southern States Utilities, Inc. for Orange-Osceola Utilities, Inc. in Osceola County, and in Bradford, Brevard, Charlotte, Citrus, Clay, Collier, Duval, Highlands, Lake, Lee, Marion, Martin, Nassau, Orange, Osceola, Pasco, Putnam, Seminole, St. Johns, St. Lucie, Volusia, and Washington Counties.



-----  
NINTH - EVENING SESSION

VOLUME 38

Pages 4583 through 4758

PROCEEDINGS:

HEARING

BEFORE:

CHAIRMAN SUSAN F. CLARK  
COMMISSIONER J. TERRY DEASON  
COMMISSIONER JULIA L. JOHNSON  
COMMISSIONER DIANE K. KIESLING  
COMMISSIONER JOE GARCIA

DATE:

Thursday, May 9, 1996

TIME:

Commenced at 9:00 a.m.

PLACE:

Betty Easley Conference Center  
4075 Esplanade Way, Room 148  
Tallahassee, Florida

REPORTED BY:

JANE FAUROT, RPR

(Appearances as heretofore noted.)

DOCUMENT NUMBER-DATE

05360 MAY 10 96

FPSC-RECORDS/REPORTING

I N D E X

## WITNESSES

Name:	Page
STEPHEN BAILEY (rebuttal)	
Direct Examination by Mr. Armstrong	4586
Prefiled Testimony Inserted	4588
Cross Examination by Mr. Beck	4601
Cross Examination by Mr. Jacobs	4601
BRUCE PASTER (rebuttal)	
Direct Examination by Mr. Armstrong	4611
Prefiled Testimony Inserted	4613
Cross Examination by Mr. Beck	4624
Cross Examination by Mr. Jacobs	4629
RAFAEL A. TERRERO (rebuttal)	
Direct Examination by Mr. Feil	4632
Prefiled Testimony Inserted	4635
Cross Examination by Mr. Riley	4709
Cross Examination by Mr. Twomey	4733
Cross Examination by Mr. Pellegrini	4747

## EXHIBITS

Number:		Identified	Admitted
220	SEB-1 and SEB-2	4598	4611
221	BP-1 and PB-2	4622	4632
222	RAT-3 through RAT-14	4709	4709
223	Recent Water Analyses of Leisure Lakes	4747	
224	Late-filed deposition Exhibit No. 6, January 1996	4747	
225	SSU's response to Staff's Interrogatory Number 305	4747	
226	EPA Handbook, et cetera	4747	
227	Three letters from HRS and one response from SSU	4749	

## P R O C E E D I N G S

(Transcript continues in sequence from Volume 37.)

CHAIRMAN CLARK: We are ready to go back on the record. Mr. Armstrong, I believe it's Mr. Bailey.

MR. ARMSTRONG: Yes, Madam Chair.

STEPHEN BAILEY

was called as a rebuttal witness on behalf of Southern States Utilities, Incorporated, and having been duly sworn, testified as follows:

## D I R E C T E X A M I N A T I O N

BY MR. ARMSTRONG:

Q Mr. Bailey, do you have before you ten pages of prefiled rebuttal testimony in this proceeding?

A Yes, I do.

Q Do you have any changes to that prefiled rebuttal?

A Yes, I do.

Q Could you give them.

A On Page 3, Line 19, change "witnesses" to "witness." On Line 20 of the same page, delete "Bertram and." The same page, Line 22, change "their" to "his," and "witnesses are" to "witness is." That's all.

Q With those changes, if I would ask you the questions contained in these ten pages, would your answers be the same?

A Yes, they would.



1           MR. ARMSTRONG: Madam Chair, we request that the  
2 ten pages of prefiled rebuttal testimony of Mr. Bailey be  
3 incorporated into the record as though read.

4           CHAIRMAN CLARK: The prefiled rebuttal testimony  
5 of Mr. Steven Bailey will be inserted in the record as  
6 though read.

7           MR. ARMSTRONG: Thank you.

8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

1 Q. WHAT IS YOUR NAME AND BUSINESS ADDRESS?

2 A. My name is Stephen E. Bailey, P.E. and my business  
3 address is 1000 Color Place, Apopka, Florida 32703.

4 Q. BY WHOM ARE YOU EMPLOYED AND WHAT IS YOUR POSITION?

5 A. I am employed by Southern States Utilities, Inc.  
6 ("Southern States") as a Senior Project Engineer in  
7 the Planning and Engineering Department.

8 Q. WHAT IS YOUR EDUCATION BACKGROUND AND WORK  
9 EXPERIENCE?

10 A. I received a Bachelor of Science in Engineering  
11 Degree from the University of Central Florida in  
12 1979 majoring in Environmental Engineering. I  
13 received a Masters in Business Administration  
14 Degree from the Crummer Graduate School of  
15 Business, Rollins College in 1992.

16 I have worked for Southern States for 10  
17 months. At Southern States I am performing as  
18 project manager for both water and wastewater  
19 related facilities. I am also responsible for  
20 facility design and certain aspects of construction  
21 permitting for various utility related facilities.

22 Prior to working at Southern States, I spent  
23 15 years working for private consulting firms  
24 specializing in serving both private and municipal  
25 water and wastewater utilities. I started work at

1 the firm of Dyer, Riddle, Mills and Precourt, Inc.  
2 in 1981 as a design engineer. I was responsible  
3 for the design, permitting and construction  
4 monitoring of water and wastewater treatment  
5 plants, and all necessary facilities to make them  
6 operational including but not limited to wastewater  
7 collection systems, water distribution systems and  
8 effluent disposal facilities. In 1983 I began  
9 working at Commonwealth Engineering Associates,  
10 Inc. ("Commonwealth") as a project engineer.  
11 During my 12 year tenure at Commonwealth I  
12 progressed until I was the Manager of the  
13 Environmental Engineering Department. Assignments  
14 included evaluations of existing utility related  
15 facilities, master planning new water and  
16 wastewater utilities, including all associated  
17 appurtenances, and improving the operation and  
18 service provided by treatment facilities by  
19 upgrading or expanding process units. I also  
20 designed, permitted, provided construction  
21 administrative services, assisted with facility  
22 start-up and monitored system operation for  
23 numerous utility related projects.

24 I have an additional 2 years experience  
25 working in the construction industry and performing

1 civil engineering.

2 **Q. WHAT ARE YOUR PROFESSIONAL AFFILIATIONS?**

3 A. I am a Professional Engineer and have been  
4 registered to practice in the State of Florida  
5 since 1984. I am a member of the American Water  
6 Works Association and the Florida Engineering  
7 Society.

8 **Q. HAVE YOU EVER TESTIFIED BEFORE A REGULATORY AGENCY?**

9 A. Yes. I testified before the Florida Public Service  
10 Commission in 1991. I presented testimony on  
11 behalf of Florida Cities Water Company, Inc.  
12 regarding the suitability of a new wastewater  
13 treatment facility and that facility's ability to  
14 meet effluent discharge criteria.

15 **Q. WHAT IS THE PURPOSE OF YOUR REBUTTAL TESTIMONY?**

16 A. During customer service hearings, several customers  
17 expressed doubt that the majority of plant being  
18 placed into service by SSU was to fulfill  
19 regulatory mandates. Sugarmill Woods witnesses  
20 Bertram and Hansen also submitted pre-filed  
21 testimony raising similar allegations. It appears  
22 from their testimony that the witnesses are  
23 assuming that "regulatory mandate" is synonymous  
24 with "environmental justification". Although a  
25 regulatory mandate may be an environmental

1 justification, it is not always the case. Attached  
2 as Exhibit \_\_\_\_\_ (SEB-1) is a schedule identifying  
3 the regulatory mandated projects placed into  
4 service for the service areas under my  
5 responsibility. This exhibit also identifies the  
6 regulatory requirement necessitating the project to  
7 be performed.

8 Customers and their Counsel also suggested  
9 that the Commission should not permit Southern  
10 States to charge rates which include projections of  
11 plant in service, generally suggesting that  
12 Southern States' projections were not credible. I,  
13 and other SSU engineers, will present evidence  
14 confirming that SSU's projections are credible and  
15 that the Commission should permit SSU to charge  
16 rates that include SSU's projected plant in  
17 service.

18 **Q. HAS SSU PRESENTED COMMISSION STAFF, PUBLIC COUNSEL**  
19 **AND OTHER PARTIES WITH PLANT IN SERVICE INFORMATION**  
20 **AS OF DECEMBER 31, 1995 WHICH IN YOUR OPINION**  
21 **VALIDATES SSU'S PROJECTIONS AND REBUTS PUBLIC**  
22 **COUNSEL'S SLIPPAGE ADJUSTMENT?**

23 A. Yes. Exhibit \_\_\_\_\_ (SEB-2) provides a schedule  
24 identifying the actual plant placed in service by  
25 SSU in 1995 in the service areas under my

1 responsibility. I have been informed that SSU  
2 provided this information to all parties on March  
3 4, 1996 in response to a Commission Staff document  
4 request. Only three projects out of the 1995  
5 projects included in the MFRs under my  
6 responsibility were not actually completed in 1995.  
7 More importantly, the total cost of these three  
8 projects was only \$327,248 as compared to the total  
9 of \$2,981,235 projected in the MFRS. Also, one of  
10 the three projects has already been placed in  
11 service in February 1996. SSU witness Kimball  
12 addresses these and other facts which demonstrate  
13 that Public Counsel's proposed slippage adjustment,  
14 which is premised upon plant in service completion  
15 dates, should be rejected.

16 **Q. COULD YOU PLEASE IDENTIFY THE CURRENT STATUS OF THE**  
17 **THREE PROJECTS UNDER YOUR RESPONSIBILITY IDENTIFIED**  
18 **IN THE MFRS AS PROJECTED TO BE COMPLETED IN 1995**  
19 **BUT WHICH WERE NOT PLACED IN SERVICE AS OF DECEMBER**  
20 **31, 1995?**

21 A. The above 3 projects under my responsibility which  
22 were not completed in 1995 but which either have  
23 been or will be completed in 1996 are the Beacon  
24 Hills/Cobblestone Chemical Feed Facility, the  
25 Beacon Hills Duval County Utility Relocate and the

1           Wooten Water Treatment Plant Improvements.

2           The Wooten's Water Treatment Plant  
3           improvements cannot be implemented until land  
4           ownership issues are resolved and land usage rights  
5           are obtained. SSU is currently in the process of  
6           obtaining a lease for property at the plant site  
7           but the property owner has been reluctant to work  
8           with us to date.

9           The Beacon Hills Duval County Utility  
10          Relocation project was postponed due to an  
11          unexpected delay in obtaining a Right-of-Way Use  
12          Permit from the County. The County required SSU to  
13          prepare a traffic control plan. We could not have  
14          contemplated that this type of requirement would be  
15          placed upon us as it was without precedent. The  
16          requirement for preparing the traffic control plan  
17          was ultimately found to be unnecessary as SSU  
18          originally had argued. The project was completed,  
19          cleared for use and placed in service on February  
20          22, 1996.

21          The Beacon Hills/Cobblestone Chemical Feed  
22          project was delayed because of the unavailability  
23          of specified construction materials. The project  
24          is currently under construction and is expected to  
25          be in service by June 30, 1996.

1 Q. LOOKING AT EXHIBIT \_\_\_\_\_ (SEB-2), ONE NOTES THE  
2 REFERENCE TO TWO PROJECTS WHICH WERE EXPENSED.  
3 COULD YOU EXPLAIN THIS DESIGNATION?

4 A. Yes. These two projects were completed in 1995;  
5 however, when SSU's expense/capitalization criteria  
6 were applied, the people responsible for booking  
7 SSU's investment in the indicated lead and copper  
8 control projects, which totalled only \$3,946,  
9 determined that the investment should be expensed,  
10 not capitalized.

11 Q. WERE THERE ANY PROJECTS UNDER YOUR RESPONSIBILITY  
12 WHICH WERE IDENTIFIED BY SSU IN THE MFR'S FOR  
13 COMPLETION IN 1995 THAT WERE CANCELED?

14 A. Yes. There were three flow meter installation  
15 projects identified in the MFRs that were canceled.  
16 The projects were: (1) a flow meter installation  
17 at the Beechers Point Wastewater Treatment Plant,  
18 (2) a flow meter installation at the Palm Port  
19 Wastewater Treatment Plant and (3) a flow meter  
20 installation at the Park Manor Wastewater Treatment  
21 Plant. Each of these three flow meter  
22 installations were canceled after we determined  
23 that because of the small size of the facilities  
24 involved and the constraints on capital available,  
25 it was not prudent to expend the funds for flow



1 meters when other methods of determining flow at  
2 the treatment plants were available to SSU. The  
3 total projected cost of these three projects in the  
4 MFRs was only \$12,501.

5 **Q. WERE THERE ANY PROJECTS COMPLETED IN 1995 UNDER**  
6 **YOUR RESPONSIBILITY WHICH WERE NOT PROJECTED TO BE**  
7 **COMPLETED IN THE MFR PROJECTIONS FOR 1995?**

8 A. Yes. SSU completed 1 project in 1995 that was  
9 under my responsibility but was not in the MFRs.  
10 This project related to our Beacon Hills wastewater  
11 treatment plant outfall facility which cost  
12 \$302,949. The schedule for completing this project  
13 was accelerated to comply with regulatory mandates,  
14 set forth by the Florida Department of  
15 Environmental Protection and the U.S.E.P.A. The  
16 mandate required SSU to replace the facility.  
17 SSU requests that the actual cost of this project  
18 be considered by the Commission as an offset to any  
19 reduction that the Commission would make to rate  
20 base so long as total revenue requirements are not  
21 increased.

22 It is not unusual and in fact is to be  
23 expected that the necessity to complete projects  
24 not budgeted will arise during the course of the  
25 year as a result of inspections by environmental

1 regulators, the imposition of new and unexpected  
2 permit conditions at permit renewal time, mandated  
3 utility relocations, equipment failures or other  
4 similar circumstances. Due to the limitations on  
5 capital available to SSU, when projects like this  
6 arise, we typically review other projects under our  
7 responsibility to determine whether they can be  
8 cancelled or delayed so that we can remain within  
9 the capital budget. Of course, if projects are  
10 mandated by public health or environmental concerns  
11 there is little possibility for compromise on such  
12 projects.

13 **Q. THE MFRS INDICATE A PROJECTED COST FOR IMPROVEMENTS**  
14 **TO THE WASTEWATER COLLECTION SYSTEM AT BEACON HILLS**  
15 **OF \$283,785. HOWEVER, THE ACTUAL COST OF THE**  
16 **PROJECT TOTALLED \$338,797. CAN YOU EXPLAIN WHY THE**  
17 **PROJECT COST INCREASED?**

18 A. Yes. This project represented the second and third  
19 phases of a multi-phase proposed collection system  
20 improvements project. The project was planned to  
21 include sewer line improvements only, with the cost  
22 for this work submitted in the MFRs. Upon  
23 completion of the first phase, unexpected problems  
24 occurred in other sections of the existing  
25 collection system. Therefore, the subsequent

1           phases were altered to eliminate this problem by  
2           including the design and installation of pump  
3           station upgrades and the construction of additional  
4           pipelines. Since the final cost of the project  
5           remains reasonable, SSU requests that the actual  
6           cost be considered by the Commission as an offset  
7           to any reduction, if any, to rate base so long as  
8           total revenue requirements are not increased.

9           **Q. DOES THAT CONCLUDE YOUR REBUTTAL TESTIMONY?**

10          A. Yes.

1 BY MR. ARMSTRONG:

2 Q Mr. Bailey, you're sponsoring two exhibits  
3 identified as SEB-1 and SEB-2, is that correct?

4 A That's correct.

5 MR. ARMSTRONG: Madam Chair, we request that those  
6 exhibits be identified with the next available exhibit  
7 number.

8 CHAIRMAN CLARK: They will be identified as  
9 Exhibit 220.

10 MR. ARMSTRONG: Thank you.

11 (Exhibit Number 220 marked for identification.)

12 BY MR. ARMSTRONG:

13 Q Mr. Bailey, do you have a summary?

14 A Yes, I do.

15 Q Could you please provide that?

16 A Yes. The purpose of my rebuttal testimony is to  
17 respond to comments made in public hearings and intervenor  
18 testimony contesting the credibility of Southern States' MFR  
19 projections of planned additions. I want to make it clear  
20 that projects SSU states has included -- or states as have  
21 been included in the MFRs are, one, in fact, required by  
22 regulatory mandate or public safety, the projects and  
23 associated in-service amounts projected in the MFRs are  
24 reasonable and adjustment for project slippage is not  
25 warranted.

1           As Senior Project Engineer for the North Region of  
2 SSU, I am responsible for capital improvements and in  
3 assisting the operations department with certain aspects  
4 pertaining to project management. This includes assuring  
5 public health, safety, and welfare, maintaining regulatory  
6 compliance, and providing facilities necessary to meet  
7 minimum service levels and providing for growth of the  
8 facilities.

9           Now, regulatory compliance encompasses more than  
10 environmental justification referred to by the intervenor  
11 witnesses. Southern States must comply with all applicable  
12 rules, statutes, ordinance, and standards of federal, state,  
13 and local jurisdictions, plus other organizations such as  
14 the water management districts. Compliance may include  
15 environmental concerns and they may also include  
16 non-environmental concerns.

17           Now, in the year that I have been working at SSU,  
18 I have spent a majority of my time primarily on projects  
19 that are necessary to comply with regulatory requirements.  
20 Of the 49 engineering projects in the north region included  
21 in the '95 MFRs, only three were incomplete at the end of  
22 that year. An additional three projects were canceled and  
23 two were expensed. The total plant-in-service amount not  
24 spent for the projects completed were substantially offset  
25 by completion of a project which had not been anticipated to

1 be done in the '95, and therefore was not included in the  
2 MFRs for '95. The actual '95 in-service amount for '95 was  
3 97.5 percent of projects filed with the MFRs. As for the  
4 '96 test year, Southern States has included only those  
5 projects that are carried over from 1995, the high priority  
6 projects, and blanket projects that respond to repair and  
7 replacement with the dollars based on historical levels for  
8 these type of projects. Therefore, I believe that we will  
9 continue to make the investments provided for in the MFRs.  
10 I do not believe that project slippage should be factored  
11 into the case, because historically for the four years '92  
12 through '95, SSU has placed more plant in service than the  
13 projected total for those years. Also, Southern States'  
14 Witness Ms. Kimball will also provide testimony confirming  
15 that no adjustment slippage is appropriate.

16 In summary, Southern States has proven the  
17 credibility of the '95 and '96 plant-in-service amounts made  
18 in the MFRs. We have made the financial investments we have  
19 said we were going to make.

20 Q Does that conclude your summary?

21 A Yes, it does.

22 MR. ARMSTRONG: Thank you, Mr. Bailey. The  
23 witness is available for cross.

24 CHAIRMAN CLARK: Mr. Beck.

25 MR. BECK: Thank you, Madam Chairman.

## 1 CROSS EXAMINATION

2 BY MR. BECK:

3 Q Mr. Bailey, could you turn to your Exhibit SEB-2?

4 A Yes.

5 Q Would you accept that if you exclude the canceled  
6 or expensed projects, you list 44 projects there, is that  
7 correct?8 A I thought that the number was slightly higher than  
9 that. I believe that number was 46. Excuse me, 49.10 Q But if you exclude the expensed or canceled  
11 projects, it will be slightly less, will it not?

12 A Okay. That's fine, yes.

13 Q And would you accept that of the 44 projects that  
14 were neither canceled nor expensed, 31 of them were later  
15 than the projected date?16 A Yes. But then that assumes that some of them were  
17 earlier, as well.

18 MR. BECK: That's all I have. Thank you.

19 CHAIRMAN CLARK: Mr. Jacobs.

20 MR. JACOBS: Just a few questions, Madam Chairman.

## 21 CROSS EXAMINATION

22 BY MR. JACOBS:

23 Q Mr. Bailey, what is your relationship to Mr.  
24 Goucher in a professional fashion in the company?

25 A In a professional fashion?

1 Q In the company, yes.

2 A We are co-employees.

3 Q All right, sir. And what are his responsibilities  
4 versus your responsibilities?

5 A Basically they are very similar with the exception  
6 that he has one region and I have a separate one.

7 Q All right, sir. His discussion earlier, and you  
8 were here present whenever he had his moment of --

9 A Yes, I was.

10 Q He talked earlier about priorities that the  
11 company has as to how they prioritize projects?

12 A Yes.

13 Q He talked about priority one was public safety?

14 A Yes.

15 Q And number two was regulatory --

16 A Yes.

17 Q -- requirements. He didn't remember the third and  
18 the fourth and the fifth, do you remember what those are?

19 A Yes, I have that here. Number one is safety,  
20 number two, regulatory mandated, number three, quality of  
21 service, number four, growth, and, number five, general  
22 improvements.

23 COMMISSIONER KIESLING: Could I ask a question on  
24 that?

25 WITNESS BAILEY: Certainly.



1           COMMISSIONER KIESLING: Where does maintenance fit  
2 in? Which of those categories would you call maintenance?

3           WITNESS BAILEY: Typically, I think that would be  
4 under general improvements.

5           COMMISSIONER KIESLING: So maintaining an  
6 improvement you have already put there is also the same as  
7 putting another improvement there.

8           WITNESS BAILEY: Well, let me read you the  
9 definition for general improvement, it may assist you. It  
10 says projects initiated to enhance operational efficiency.  
11 I realize this is very broad, but we are trying to keep  
12 these broad so that we can have some variability with it. A  
13 lot of other times with the operational projects, some of  
14 those improvements may also be included under quality of  
15 service. And, again, it's kind of a definition, who is  
16 doing the paperwork, who is assigning the priority.

17           COMMISSIONER KIESLING: Okay. And let me just ask  
18 you one more now that I've interrupted your train of  
19 thought. For example, one of the earlier witnesses talked  
20 about replacing a crumbling manhole.

21           WITNESS BAILEY: Yes, uh-huh.

22           COMMISSIONER KIESLING: And I guess, you know, in  
23 my way of thinking it seemed like that's a maintenance thing  
24 as opposed to a regulatory mandate. There is no rule that  
25 says you have to go out and fix that manhole, there is just

1 a rule that says you've got to keep it in good and proper  
2 running order.

3 WITNESS BAILEY: Yes. I think what happens is  
4 there has to be a judgment made, and the judgment is is this  
5 maintenance, or if something happens here and it fails, will  
6 it cause noncompliance, will it subject people to health,  
7 safety, and welfare concerns.

8 COMMISSIONER KIESLING: Okay. Thank you.

9 MR. JACOBS: Madam Chairman, may I proceed?

10 CHAIRMAN CLARK: Yes.

11 BY MR. JACOBS:

12 Q Mr. Bailey, you just made the statement, I know,  
13 and Commissioner Kiesling asked you that it's a judgment  
14 call, and if it's a general improvement it's also considered  
15 to be maintenance. And I think you said that it could be  
16 that is a mandatory requirement by the government, as well.  
17 Do all of these things -- I guess my question is do all of  
18 these things really fade into some grayness in a mass and  
19 become requirements of the government at sometime in their  
20 necessity of being done?

21 A No, I don't believe so.

22 Q Well, then you disagree with Mr. Goucher, who said  
23 earlier that growth really kind of pushes you into  
24 regulatory mandate, and growth and regulatory mandate can be  
25 the same justification?

1           A     For growth, that is correct.  When I answered your  
2 question I had envisioned the possibility of other  
3 improvements that would not be related to growth.

4           Q     Well, you just said for maintenance as an example,  
5 maintenance, the water pipe has got to be -- if the water  
6 pipe starts leaking because it wasn't maintained properly,  
7 then the governmental authority gets in and then you go to  
8 fix it and you say we did that because the government  
9 mandated it.

10          A     Yes, in some cases.

11          Q     All right, sir.  Whenever you get to quality, the  
12 quality of service, if the service breaks down so it's not  
13 quality service, then a governmental agency gets a phone  
14 call and they step in and all of a sudden that becomes  
15 governmentally mandated then, is that correct?

16          A     In some cases, yes.

17          Q     These priorities are set down by your company, is  
18 that right?

19          A     Yes.

20          Q     So it's a judgment call on your part?

21          A     Yes.

22          Q     And when it ceases to be a judgment call is  
23 whenever the government gets involved?

24          A     Not necessarily, no.

25          Q     Well, if the government says go fix it, you have

1 got to go fix it?

2 A In some instances, yes.

3 Q But if you had properly maintained it before the  
4 government got into it, then it would be within your  
5 discretion to keep it up and keep it going, right?

6 A In some cases, yes.

7 Q All right, sir. I guess the issue is is that  
8 there seems to be a lot of discussion here about the fact  
9 that you all are building and doing all of these things  
10 because of the government requiring you to do so, but isn't  
11 it true that whenever you have things like growth, you get  
12 more customers, isn't that true?

13 A Yes.

14 Q And so if, for an example, you needed 20 PSI at a  
15 maximum hourly demand, let's say that is the pressure  
16 required, and you had growth in the system and all of a  
17 sudden the 20 PSI goes away because you have more customers.  
18 Do you wait for the government to step in, or do you go  
19 ahead and fix it and then you have more people coming in to  
20 help pay for that, and don't you solve the problem that way  
21 without waiting for the government?

22 A In some instances, yes. And if you look back at  
23 the MFRs, and the improvements that are listed in the  
24 filing, you can see where those projects have been  
25 implemented and that type of thing.

1 Q So you implemented those projects without having  
2 the government mandate you do that, then, is that correct?

3 A That's correct.

4 Q So, these statements that have been made  
5 throughout this process that we did it because the  
6 government made us do it, that's not necessarily true, then  
7 is it? A lot of this work you do because you have made a  
8 judgment that it needed to be maintained, you made a  
9 judgment that quality control or quality service ought to be  
10 delivered, and you have made a judgment that growth is  
11 sufficient to cover the needs, is that not correct?

12 A And I think that's reflected in the filing.

13 Q All right, sir. And so the discussions by the  
14 President of Minnesota Power or Chairman of the Board and  
15 others that all of this problem that has put you on this  
16 edge of financial ruin is not just government requirement  
17 then, is it?

18 MR. ARMSTRONG: Objection. Madam Chair, I don't  
19 think that has been his testimony nor is there a factual  
20 predicate. The filing does lay out the different categories  
21 of capital expenditures and they are not all under  
22 regulatory requirement.

23 MR. JACOBS: I thought it was a fair question.

24 MR. ARMSTRONG: Without a factual predicate, that  
25 is my objection.

1           MR. JACOBS: Well, I don't know what you need for  
2 a factual predicate, Madam Chairman. We have had a  
3 discussion here about -- Mr. Bailey says that he couldn't  
4 really distinguish between growth and regulatory mandate  
5 because one kind of faded into the other. Now this witness  
6 is making -- I mean, Mr. Goucher said that, and now Mr.  
7 Bailey is making distinctions and saying, "Gosh, some of  
8 these projects we did because we thought in our judgment  
9 they ought to be done," and they weren't regulatory  
10 mandated. Now we have had converse testimony from the CEO  
11 of Minnesota Power that we are on the brink of ruin because  
12 of governmental requirements, and I'm just trying to get  
13 into the distinction here that is made by two different  
14 voices coming from the same place.

15           CHAIRMAN CLARK: All right. Give me your question  
16 again.

17           MR. BECK: Good luck.

18           CHAIRMAN CLARK: I think you may have combined a  
19 lot of thoughts into one question, and --

20           MR. JACOBS: And you want me to separate them out.

21           CHAIRMAN CLARK: Try to do that.

22           MR. JACOBS: I guess I will go back, and if you  
23 will bear with me, Mr. Bailey.

24 BY MR. JACOBS:

25           Q     You have said that many of the projects in the

1 MFRs were done because you thought, number one, that the  
2 maintenance needed to be done, or you had growth sufficient  
3 to have expanded customer base to pay for it, or you wished  
4 to render quality service to your customers, and those are  
5 many reasons, or the reasons that you used for these many 45  
6 projects, right?

7 A Yes.

8 Q So, you would disagree, then, with statements made  
9 earlier that this stuff you're having to do for improvements  
10 of your different facilities are all mandated by government  
11 requirements?

12 MR. ARMSTRONG: Objection. And that is the point  
13 of my objection, there is no factual predicate for that  
14 statement being made that it was all done for regulatory  
15 requirements. The information in the records shows 35  
16 percent for regulatory requirement, 9 percent for safety, 35  
17 percent for growth, the remaining is the other. There is no  
18 factual predicate for that statement and that question.

19 MR. JACOBS: I will withdraw the question.

20 CHAIRMAN CLARK: Okay.

21 BY MR. JACOBS:

22 Q Mr. Bailey, of the 35 percent that's done for  
23 growth, and the 35 percent that's done for regulatory  
24 requirement, do you sense growth edging into regulatory  
25 requirement, or is that a specific, distinct, absolute 35

1 percent for growth, and it's not to be confused that it is  
2 being fudged into the government requirement?

3 A Fudged?

4 Q Yes, sir, moved into that category.

5 A No, I don't believe that at all.

6 Q Okay. The improvements that are done in your  
7 venue, which include Amelia Island Utility Company, right?

8 A Correct.

9 Q Mr. Wright works for you there, I believe, doesn't  
10 he?

11 A Yes.

12 Q Okay. And you are doing those improvements in  
13 your work at Amelia Island, does that benefit inure to the  
14 benefits of a user located in Mr. Goucher's area?

15 A No, it does not. Not directly.

16 MR. JACOBS: Okay. No further questions.

17 CHAIRMAN CLARK: Mr. Twomey.

18 MR. TWOMEY: I don't have any questions.

19 CHAIRMAN CLARK: Staff.

20 MS. CAPELESS: Staff has no questions.

21 CHAIRMAN CLARK: Exhibits. Oh, redirect, excuse  
22 me.

23 MR. ARMSTRONG: No redirect. The company moves  
24 Exhibit 220.

25 CHAIRMAN CLARK: Exhibit 220 will be entered in



1 the record without objection.

2 (Exhibit Number 220 received into evidence.)

3 CHAIRMAN CLARK: Thank you, Mr. Bailey. Mr.  
4 Paster. You're excused, Mr. Bailey. Thank you.

5 WITNESS BAILEY: Thank you.

6 BRUCE PASTER

7 was called as a rebuttal witness on behalf of Southern  
8 States Utilities, Incorporated, and having been duly sworn,  
9 testified as follows:

10 DIRECT EXAMINATION

11 BY MR. ARMSTRONG:

12 Q Good evening, Mr. Paster.

13 A Good evening.

14 Q Do you have before you nine pages of prefiled  
15 rebuttal testimony in this proceeding?

16 A Yes, I do.

17 Q Do you have any changes to that prefiled rebuttal?

18 A Yes, I do.

19 Q Could you please give them now.

20 A On Page 3, Line 3, change the word "witnesses" to  
21 "witness." Line 4, strike the words "Bertram and." Line 6,  
22 change the word "their" to "his," and the words "the  
23 witnesses are," to "he is."

24 Q With those changes, if I asked you the questions  
25 contained in these nine pages would your answers be the

1 same?

2 A Yes, they would.

3 MR. ARMSTRONG: Thank you. Madam Chair, we  
4 request that the nine pages of prefiled rebuttal testimony  
5 of Mr. Paster be incorporated into the record as though  
6 read.

7 CHAIRMAN CLARK: It will be incorporated in the  
8 record as though read.

9 MR. ARMSTRONG: Thank you.

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 Q. WHAT IS YOUR NAME AND BUSINESS ADDRESS?

2 A. My name is Bruce Paster, P.E. and my business  
3 address is 1000 Color Place, Apopka, Florida 32703.

4 Q. WHAT IS YOUR POSITION WITH SOUTHERN STATES  
5 UTILITIES, INC.?

6 A. I am employed by Southern States Utilities, Inc.  
7 ("Southern States") as Senior Engineer in the  
8 Planning and Engineering Department.

9 Q. WHAT IS YOUR EDUCATIONAL BACKGROUND AND WORK  
10 EXPERIENCE?

11 A. I received a Bachelor of Science degree in Civil  
12 Engineering in 1984 from the University of  
13 Massachusetts. I have 8 years experience working  
14 for private consulting engineering firms in the  
15 water and wastewater industry and have been working  
16 for Southern States for the past three and one-half  
17 years.

18 In 1984, I began working as an Environmental  
19 Engineer with the consulting firm of Camp Dresser  
20 and McKee, Inc. in Boston, Massachusetts. Project  
21 assignments included analyses, planning, report  
22 writing and design of various water and industrial  
23 wastewater treatment facilities.

24 From 1986 to 1990, I worked as an  
25 Environmental Engineer for Camp Dresser and McKee,

1 Inc. in Orlando, Florida. I primarily was assigned  
2 to municipal wastewater projects including the  
3 analyses, preliminary and final design of  
4 wastewater collection, treatment and effluent  
5 disposal facilities.

6 From 1990 to 1992, I served as a Project  
7 Manager for Dyer, Riddle, Mills & Precourt, Inc. in  
8 Orlando, Florida. I was assigned to various water  
9 and wastewater planning and design projects for  
10 both municipal and private utility clients.

11 In September of 1992, I began employment with  
12 Southern States in their Planning and Engineering  
13 Department in Apopka, Florida. I am currently  
14 serving as a Senior Engineer with project  
15 management responsibilities for both water and  
16 wastewater facilities.

17 **Q. WHAT ARE YOUR PROFESSIONAL AFFILIATIONS?**

18 A. I am a Professional Engineer registered in the  
19 State of Florida since 1989. I am a member of the  
20 American Society of Civil Engineers and the Florida  
21 Water and Pollution Control Operators Association.

22 **Q. HAVE YOU EVER TESTIFIED BEFORE A REGULATORY AGENCY?**

23 A. No.

24 **Q. WHAT IS THE PURPOSE OF YOUR REBUTTAL TESTIMONY?**

25 A. During customer service hearings, several customers

1 expressed doubt that the majority of plant being  
2 placed into service by SSU was to fulfill  
3 regulatory mandates. Sugarmill Woods witnesses  
4 Bertram and Hansen also submitted pre-filed  
5 testimony raising similar allegations. It appears  
6 from their testimony that the witnesses are  
7 assuming that "regulatory mandate" is synonymous  
8 with "environmental justification". Although a  
9 regulatory mandate may be an environmental  
10 justification, it is not always the case. Attached  
11 as Exhibit \_\_\_\_\_ (BP-1) is a schedule identifying  
12 the regulatory mandate projects placed into service  
13 for the service areas under my responsibility.

14 **Q. HAS SSU PRESENTED COMMISSION STAFF, PUBLIC COUNSEL**  
15 **AND THE OTHER PARTIES WITH PLANT IN SERVICE**  
16 **INFORMATION AS OF DECEMBER 31, 1995 WHICH IN YOUR**  
17 **OPINION VALIDATES SSU'S PROJECTIONS AND REBUTS**  
18 **PUBLIC COUNSEL'S SLIPPAGE ADJUSTMENT?**

19 A. Yes. Exhibit \_\_\_\_\_ (BP-2) provides a schedule  
20 identifying the actual plant placed in service by  
21 SSU in 1995 in the service areas under my  
22 responsibility. Only 8 of the 1995 projects were  
23 not completed. The total filed in service amount  
24 of these projects is \$3,280,612 as compared to the  
25 total 1995 plant in service additions under my

1 responsibility of \$5,849,023 projected in the MFRs.  
2 Of these projects, 2 have now been placed in  
3 service totaling \$2,382,520. SSU witness Kimball  
4 addresses facts which demonstrate that Public  
5 Counsel's proposed slippage adjustment, which is  
6 premised upon plant in service completion dates,  
7 should be rejected.

8 **Q. COULD YOU PLEASE IDENTIFY THE PROJECTS UNDER YOUR**  
9 **RESPONSIBILITY WHICH WERE INCLUDED IN THE MFRS FOR**  
10 **1995 BUT NOT PLACED INTO SERVICE AS OF DECEMBER 31,**  
11 **1995?**

12 A. There are only eight projects under my  
13 responsibility which were not completed in 1995 but  
14 which either have been or will be completed in  
15 1996. The projects are identified in Exhibit \_\_\_\_  
16 (JDW-8). These projects include: in the Deltona  
17 Lakes service area, the Wellington water treatment  
18 plant expansion, the Agatha/Saxon water treatment  
19 plant improvements and the Sagamore Drive water  
20 treatment plant distribution system. Cumulatively,  
21 the projected 1995 cost of these three projects in  
22 the MFRs was \$1,883,450. To date in 1996, the  
23 Wellington water treatment plant expansion project  
24 has been completed and was in service as of  
25 February 16, 1996 at a cost of \$1,380,372, within

1 1% of the projected cost of \$1,365,786 projected in  
2 the MFRs. The project actually was completed as of  
3 January 10, 1996, but booking to "in service" was  
4 delayed because of delays in receiving DEP  
5 clearance. The Agatha/Saxon water treatment plant  
6 improvements were completed in early March and are  
7 currently in the clearance process. A portion of  
8 the Sagamore project was cleared for service on  
9 December 11, 1995; the remainder of the project was  
10 requested for clearance on March 14, 1996 and is  
11 awaiting DEP acceptance.

12 The University Shores lead and copper control  
13 project was delayed because SSU is attempting to  
14 reduce costs by using in house labor to complete  
15 it. The equipment is on site and I have been  
16 informed that operations personnel have begun  
17 installation. Then DEP clearance will be required.

18 The hydropneumatic tank at Tropical Park was  
19 delayed due to local regulatory permitting issues.  
20 It is expected to be cleared as in service on April  
21 30, 1996.

22 The hydro tank and new well for the Carlton  
23 Village service area is projected to be complete by  
24 March 31, 1996. The project was delayed due to  
25 difficulties experienced by the general contractor

1 including delays in receiving required electrical  
2 permits and bacteriological testing.

3 The water treatment plant and distribution  
4 improvements for the Silver Lakes Estates/Western  
5 Shores service area also were not placed in service  
6 in 1995 but were placed in service on January 29,  
7 1996. The actual cost of completing this project  
8 was \$1,002,148 as compared to the projected cost in  
9 the MFRs of \$862,100. The project was delayed  
10 primarily due to a delay in delivery of the  
11 electrical control panel. Since the final cost of  
12 completing the project remains reasonable, SSU  
13 requests that the actual cost be considered by the  
14 Commission as an offset to any reduction, if any,  
15 to rate base so long as total revenue requirements  
16 are not increased.

17 The eighth project was the DHCC effluent  
18 easement project at the Glen Abbey Golf Course.  
19 SSU witness Carlyn Kowalsky will address this  
20 project.

21 **Q. LOOKING AT EXHIBIT \_\_\_\_\_ (BP-2), ONE NOTES THE**  
22 **REFERENCE TO PROJECTS WHICH WERE EXPENSED. COULD**  
23 **YOU EXPLAIN THIS DESIGNATION?**

24 **A.** Yes, the six lead and copper projects were  
25 completed in 1995. However, when SSU's



1 expense/capitalization criteria were applied, the  
2 people responsible for booking SSU's investment,  
3 which was projected at only \$21,048, determined  
4 that the investment should be expensed, not  
5 capitalized.

6 **Q. WERE ANY 1995 PROJECTS UNDER YOUR RESPONSIBILITY**  
7 **CANCELLED, AND, IF SO, CAN YOU TELL THE COMMISSION**  
8 **WHY?**

9 A. Yes. Five projects under my supervision totalling  
10 only \$54,315 were cancelled. SSU anticipated  
11 spending \$13,290 to relocate facilities required  
12 due to a notification received by SSU from the  
13 Volusia County Department of Transportation ("DOT")  
14 for road widening projects. Volusia County and the  
15 DOT did not perform the road widening and notified  
16 SSU that the road widening would not occur.  
17 Therefore, SSU did not incur the costs and  
18 cancelled the project.

19 The Meredith Manor storage tank dome project  
20 and the Bay Lakes Estates water treatment plant  
21 building project were cancelled because, upon  
22 further investigation, it was determined that the  
23 existing facilities could be maintained.  
24 Therefore, the funds (\$25,596) for these projects  
25 were used for other reprioritized projects.

1            Similarly, the Deltona Lakes valve replacement  
2 project for the water distribution system and the  
3 corrosion control equipment (\$15,429) were  
4 cancelled due to scheduling conflicts brought on by  
5 reprioritizing available manpower for other  
6 critical projects.

7        **Q. WERE THERE ANY PROJECTS COMPLETED IN 1995 UNDER**  
8        **YOUR RESPONSIBILITY WHICH WERE NOT PROJECTED TO BE**  
9        **COMPLETED IN THE MFR PROJECTIONS FOR 1995?**

10       A. Yes. We completed and placed into service one  
11 project which was not included in the MFRs but was  
12 completed in 1995. The project is referred to as  
13 the Deltona Lakes Force Main Upgrade (95CC742).  
14 The in service amount for this project was \$49,219.  
15 It is not unusual and in fact is to be expected  
16 that the necessity to complete projects not  
17 budgeted will arise during the course of the year  
18 as a result of inspections by environmental  
19 regulators, the imposition of new and unexpected  
20 permit conditions at permit renewal time, equipment  
21 failures or other similar circumstances. Due to  
22 the limitations on capital available to SSU, when  
23 projects like these arise, we typically review  
24 other projects under our responsibility to  
25 determine whether they can be cancelled or delayed

1 so that we can remain within the capital budget.  
2 Of course, if projects are mandated by public  
3 health or environmental concerns there might be no  
4 room for compromise on such projects. SSU requests  
5 that the actual cost of this project be considered  
6 by the Commission as an offset to any reduction  
7 that the Commission would make to rate base so long  
8 as total revenue requirements are not increased.

9 **Q. DOES THAT CONCLUDE YOUR REBUTTAL TESTIMONY?**

10 A. Yes, it does.

1 BY MR. ARMSTRONG:

2 Q Mr. Paster, you're sponsoring two exhibits, BP-1  
3 and BP-2, is that correct?

4 A That's correct.

5 Q And you have no changes to those exhibits?

6 A Correct.

7 MR. ARMSTRONG: Madam Chair, could they be  
8 identified with the next available exhibit number?

9 CHAIRMAN CLARK: The next available number is 211.

10 MR. ARMSTRONG: Thank you.

11 (Exhibit Number 221 marked for identification.)

12 BY MR. ARMSTRONG:

13 Q Mr. Paster, do you have a summary of your  
14 testimony?

15 A Yes, I do.

16 Q Could you provide that now, please.

17 A Yes, sir. The purpose of my rebuttal testimony is  
18 to respond to comments made in public hearings and  
19 intervenor testimony contesting the credibility of Southern  
20 States' MFR projections of plant additions. I want to make  
21 it clear that projects Southern States has included in the  
22 MFRs are, in fact, required by regulatory mandate. Projects  
23 and associated in-service amounts projected in the MFRs are  
24 reasonable and accurate, and adjustments for project  
25 slippage is not warranted.

1 I am the Senior Engineer for the Central Region of  
2 SSU. As such, I am responsible for capital improvements,  
3 assisting the operations department with certain aspects  
4 pertaining to project management. This includes ensuring  
5 public health, safety, and welfare, maintaining regulatory  
6 compliance, providing facilities necessary to meet minimum  
7 service levels, providing for growth of the facilities.

8 Regulatory compliance encompasses more than the  
9 environmental justification referred to by intervenor  
10 witnesses. Southern States must comply with all applicable  
11 rules, statutes, ordinances, and standards of federal, state  
12 and local jurisdictions. Compliance may include  
13 environmental concerns or non-environmental concerns. In  
14 the three and one-half years I have worked at Southern  
15 States Utilities, I have spent my time predominantly on  
16 projects which were required by regulatory agencies. Of the  
17 64 capital projects for the central region included in the  
18 1995 MFRs, only eight projects were not completed. Five  
19 projects were canceled, and six were completed but expensed.  
20 Of the eight projects not completed in 1995, five are now in  
21 service and two are expected to be in service by the end of  
22 this month.

23 As for the 1996 test year, Southern States has  
24 included only 1995 carry-over projects, high priority  
25 projects, and blanket projects such as renewal and

1 replacements which were projected based on historical levels  
2 of these types of projects. For these reasons we believe  
3 that Southern States Utilities will continue to make the  
4 investments provided for in the MFRs. I do not believe that  
5 project slippage should be factored into this case because  
6 historically for the four years, 1992 through 1995,  
7 reflected in this rate case, SSU has actually placed more  
8 plant-in-service than the projected total plant-in-service  
9 for these years. Southern States Witness Kimball will also  
10 provide testimony confirming that no slippage adjustment is  
11 appropriate.

12 In summary, Southern States has proven the  
13 credibility of the 1995 and 1996 plant-in-service  
14 projections made in the MFRs. Simply stated, SSU has made  
15 the financial investments we have said we were going to  
16 make. That concludes my summary.

17 MR. ARMSTRONG: Thank you, Mr. Paster. The  
18 witness is available for cross.

19 COMMISSIONER DEASON: Mr. Beck.

20 MR. BECK: Thank you.

21 CROSS EXAMINATION

22 BY MR. BECK:

23 Q Mr. Paster, we have received an inquiry from the  
24 Imperial Terrace West Homeowners Association about a well  
25 that you project to place into service in 1996. Are you

1 familiar with that project?

2 A Yes, I am.

3 Q What is the status of that project?

4 A At this time we have done a preliminary  
5 investigation and preliminary design for the construction of  
6 a second well, an emergency back up well for that system.  
7 We have also looked at other alternatives. A much more  
8 efficient alternative than construction of a new well would  
9 be to interconnect with the City of Tavares, a utility  
10 abutting our small service area. We are still in  
11 negotiations with the City of Tavares. If we are unable to  
12 negotiate with them for an interconnect, we would then  
13 proceed with the construction of a new well.

14 Q When do you expect to finish your negotiations  
15 with the City of Tavares?

16 A I'm expecting this summer to know one way or the  
17 other from the City of Tavares whether they will be willing  
18 to allow us an interconnect with their system.

19 Q And you said that if those negotiations are  
20 unsuccessful you are going to go ahead and drill a well  
21 there, is that correct?

22 A At this time, yes, that is our plan.

23 Q Where in proximity to the Imperial Mobile Terrace  
24 location is your back up well that you propose to drill?

25 A The proposed area, we have looked -- right now

1 there are two areas we are looking at. One is to purchase a  
2 plot of land adjacent to our service area from a large land  
3 owner. We would purchase approximately two to three acres  
4 in that area, and then run piping into our service  
5 territory. Another option would be to purchase a number of  
6 mobile home sites in that area. The problem there being the  
7 location, the proximity of existing septic tanks in that  
8 area. And, of course, the third option is the one I have  
9 mentioned, an interconnect which would probably be less than  
10 half the cost, approximately a third of the cost of drilling  
11 a new well.

12 Q Can you express any opinion as to the likelihood  
13 of which course will wind up being taken?

14 A Well, I'm hoping that the interconnect will work,  
15 and that the City of Tavares will agree that that is the  
16 most prudent solution for this situation.

17 Q And if that does not prove to be successful, what  
18 is the likelihood of completing a new well during 1996, in  
19 your opinion?

20 A I think it would be difficult right now. I think  
21 we would try to get it in by December. We would have to go  
22 through the permitting process first, and it would be -- I  
23 think it would be very close. I think for this project we  
24 are hoping to find a better solution, a more cost efficient  
25 solution, and for that reason that we are holding off on



1 that.

2 Q Could you turn to your exhibit to your testimony?

3 A Uh-huh.

4 Q Exhibit BP-2, and I believe you said in your  
5 summary, if I heard you right, that there are 64 projects  
6 listed there, is that correct?

7 A Yes, sir.

8 Q And 11 of those have either been canceled or  
9 expensed, is that correct?

10 A Yes, sir.

11 Q That leaves a balance of 53 projects?

12 A That's correct.

13 Q And would you agree with me that of those 53  
14 projects, 38 were placed in service after the projected  
15 in-service date?

16 A I haven't made that count.

17 Q Would you accept that subject to check?

18 A Yes.

19 Q I have placed a copy of Exhibit 218 by you when  
20 you came up there. Do you have that there?

21 A Yes, I do.

22 Q Could you turn to your section of that exhibit,  
23 which is, I believe, on the back of Page 4 that is written  
24 in the upper right-hand corner, and on Page 5?

25 A Yes, sir.

1           Q     Do those show projects for which you are  
2 responsible?

3           A     Yes, they do.

4           Q     Okay. And this is the status of those projects as  
5 of the end of March of 1996, is that right?

6           A     That's correct.

7           Q     And am I reading correctly on Page 5 that for the  
8 central region through the end of March of 1996, the actual  
9 direct spending was \$253,735 out of a total authorization  
10 for the year of \$2,039,098, is that right?

11          A     That number is a direct spending number, not a  
12 plant-in-service number for central region or for 1996. My  
13 understanding is the plant-in-service number for the company  
14 is already at approximately 30 percent or \$4.6 million. My  
15 understanding is by the end of this month plant-in-service  
16 in 1996 will be approximately \$9.2 million dollars or 60  
17 percent. This number that you're looking at, the 253 is a  
18 spending number, not a plant-in-service number.

19               MR. BECK: I move to strike the answer as being  
20 non-responsive to my question.

21               COMMISSIONER DEASON: Mr. Armstrong.

22               MR. ARMSTRONG: I think he responded to the  
23 question. The question related to an exhibit which reflects  
24 spending, not plant-in-service, and I don't know if that --  
25 I mean, what the witness was clarifying was that this

1 reflects spending, not plant-in-service.

2 COMMISSIONER DEASON: I will let the answer stand,  
3 Mr. Beck. You may re-ask your question to get further  
4 clarification.

5 BY MR. BECK:

6 Q This exhibit on Page 5 shows the spending, direct  
7 spending of the numbers that I just cited to you, is that  
8 correct?

9 A That's correct.

10 Q And if I'm reading that correct, or would you  
11 accept subject to check that that reflects 12.4 percent of  
12 actual through the end of March compared to the total amount  
13 authorized for 1996?

14 A Yes.

15 MR. BECK: Thank you, Mr. Paster. That's all I  
16 have.

17 COMMISSIONER DEASON: Mr. Jacobs.

18 CROSS EXAMINATION

19 BY MR. JACOBS:

20 Q Mr. Paster, now the projects that we are talking  
21 about here that are within the year or the 13 months that we  
22 are talking about here, what is the number of those projects  
23 now?

24 A I'm sorry, which projects are you referring to?

25 Q What are the numbers of projects now that you're

1 talking about that you all are trying to get some  
2 adjustments here for? What is the number, is it 64  
3 projects, is it 53 projects, how many projects are we  
4 talking about?

5 A I'm not sure I understand the question.

6 Q Mr. Beck asked you a question of those projects  
7 which ones were finished by a certain date, and you said 53  
8 projects.

9 A 64 projects are the number of projects that were  
10 filed in 1995, plant-in-service additions.

11 Q All right. And that is the one you're seeking to  
12 have your adjustment based on, is that right?

13 A I'm not sure.

14 Q Let me ask it another way, then. Let's say the  
15 number is 64, how many of those projects are you doing  
16 because some mandate of a regulatory agency?

17 A I don't have the breakdown in front of me. I'm  
18 assuming it would be similar to the rest of the company.  
19 The breakdown that I've heard in testimony is approximately  
20 35 percent.

21 Q So, in other words, 22 projects of that amount  
22 you're saying are done because of regulatory mandate?

23 A If that's what it works out to, yes.

24 Q Mr. Paster, in the central district, do the  
25 improvements that you're doing, let's say there are 64 of

1 those, those 64 improvements, do any of those inure to the  
2 benefit of folks that are in Mr. Bailey's district directly?

3 A I believe they do, yes.

4 Q And how do they do it directly?

5 A I believe indirectly they all do in that any time  
6 that a lot of these projects are to stay in environmental  
7 compliance to help the environment, to help -- the testimony  
8 I have heard that we all share the same aquifer, and that if  
9 we are doing projects to protect that aquifer here it does  
10 help not just Mr. Bailey, but other customers of ours and  
11 other citizens in Florida.

12 Q So it's your testimony that somebody who is  
13 connected to Amelia Island receives direct benefit from  
14 money you're spending down in Central Florida?

15 A Indirect benefit, yes, and I would have to think  
16 about --

17 Q I said in direct benefits.

18 A A direct benefit?

19 Q Yes.

20 A I would have to think further on that.

21 Q You would have to do what?

22 A I would have to think further on that.

23 Q You couldn't give me yes or no?

24 A No.

25 MR. JACOBS: No further questions.

1 COMMISSIONER DEASON: Mr. Twomey.

2 MR. TWOMEY: I have no questions.

3 COMMISSIONER DEASON: Staff.

4 MS. SUMMERLIN: No questions.

5 COMMISSIONER DEASON: Commissioners. Redirect.

6 MR. ARMSTRONG: No redirect.

7 COMMISSIONER DEASON: Exhibits.

8 MR. ARMSTRONG: The company moves Exhibit 221.

9 COMMISSIONER DEASON: Without objection, Exhibit  
10 221 is admitted.

11 (Exhibit Number 221 received into evidence.)

12 COMMISSIONER DEASON: You may call your next  
13 witness.

14 MR. FEIL: The next witness would be Rafael  
15 Terrero.

16 RAFAEL A. TERRERO

17 resumed the stand on behalf of Southern States Utilities,  
18 Incorporated, and having previously been duly sworn,  
19 testified as follows:

20 DIRECT EXAMINATION

21 BY MR. FEIL:

22 Q Are you ready now, Mr. Terrero?

23 A Yes, sir.

24 Q You were sworn when you were testifying on direct,  
25 were you not?

1 A That's correct.

2 Q Could you state your name for the record, please.

3 A My name is Rafael Terrero, T like in Thomas,  
4 E-R-R-E-R-O.

5 Q And you are the same Rafael Terrero who testified  
6 on direct in this case, correct?

7 A That's correct.

8 Q Are you the same Rafael A. Terrero for whom  
9 prefiled testimony was filed in this case, prefiled rebuttal  
10 testimony consisting of 74 pages?

11 A That's correct.

12 Q Do you have any changes or corrections to that  
13 testimony?

14 A Yes, I do. I have Page 4, Line 17, change  
15 "channel" to "pipe." I have Page 13, Line 11, change  
16 "updated" to "upgraded." Page 21, Line 13, should read,  
17 "Mr. Bidy has not." Page 28, Line 4, remove "where". Page  
18 31 --

19 Q Excuse me, I didn't catch that last one. That was  
20 Line 4, Page 28?

21 A That's correct.

22 Q And what was the word?

23 A Where. Copies of, remove where.

24 Q Delete where, okay.

25 A Delete where, right. Page 31, take out reuse.

1 COMMISSIONER KIESLING: What line?

2 WITNESS TERRERO: Line 13, I'm sorry.

3 A (Continuing) Page 51, Line 13, that line should  
4 read, "Tank remained in service until recently." That is  
5 all the changes I have.

6 Q With those corrections, if I asked you the  
7 questions in your prefiled written rebuttal today would your  
8 answers to them be the same?

9 A Yes, sir.

10 MR. FEIL: Commissioner Deason, I ask that Mr.  
11 Terrero's prefiled rebuttal be inserted into the record as  
12 though record.

13 COMMISSIONER DEASON: Without objection, it will  
14 be so inserted.

15

16

17

18

19

20

21

22

23

24

25



1 Q. ARE YOU THE SAME RAFAEL A. TERRERO WHO PREVIOUSLY  
2 FILED DIRECT TESTIMONY?

3 A. Yes, I am.

4 Q. HAVE YOU REVIEWED THE PREFILED DIRECT TESTIMONY OF  
5 TED BIDDY, BUDDY L. HANSEN, HUGH LARKIN, JR., DONNA  
6 DERONNE, MICHAEL WOEFFLER, ALBERT E. BERTRAM, KIM  
7 DISMUKES, AND WITNESS FROM ENVIRONMENTAL AGENCIES?

8 A. Yes, I have.

9 Q. WHAT IS THE PURPOSE OF YOUR REBUTTAL TESTIMONY?

10 A. My rebuttal testimony will focus primarily on three  
11 areas: (1) addressing Staff witness Dodrill's  
12 assertions regarding the 212 acres SSU purchased in  
13 Collier County; (2) addressing Public Counsel  
14 witness Biddy's proposed adjustments to the used  
15 and useful levels indicated on SSU's MFRs; and (3)  
16 addressing the comments of the witnesses from the  
17 Department of Environmental Protection, which I  
18 will refer to as DEP, and other regulatory  
19 authorities concerning SSU's compliance with  
20 applicable rules at each of our service areas.

21 Q. DO YOU AGREE WITH STAFF WITNESS DODRILL THAT THE  
22 MAJORITY OF THE 212 ACRES PURCHASED BY CONDEMNATION  
23 FOR FUTURE WATER SUPPLIES SHOULD BE TREATED AS NON-  
24 UTILITY PROPERTY?

25 A. No, for several reasons. First, the property

1           acquired not only includes the lakes but also the  
2           property upon which SSU's pumping facilities and  
3           water lines are located to withdraw the water and  
4           transport it to Marco Island. The lakes would have  
5           been useless to SSU if we did not purchase the  
6           adjoining land upon and through which these  
7           facilities are located. To understand this point,  
8           please understand that SSU would not have been able  
9           to use any of the facilities on the adjoining  
10          property without paying the Colliers for the  
11          property upon which they are located as the  
12          Colliers expressly stated that they did not wish  
13          the lease to continue. The area which SSU  
14          purchased adjacent to the lakes also acts as a  
15          recharge area for the lakes water supply during  
16          periods of heavy rain.

17                 Another reason the adjacent area was acquired  
18                 was to protect the water source from potential  
19                 pollution sources. It is estimated that all of the  
20                 acquired area is necessary to protect the surface  
21                 water supply from spills on the highway, developers  
22                 (including the Collier family from whom we  
23                 purchased the property), commercial properties that  
24                 could be considered industrial pollution  
25                 contributors, etc. The property also will be the

1 site where water supplies from sources such as the  
2 160 acres will be combined, stored and re-pumped to  
3 Marco Island.

4 SSU and our legal, engineering and land  
5 appraisal experts determined that the purchase of  
6 212 acres was the optimum way to protect the  
7 quality of its water supply to Marco Island in the  
8 most economical way. All of the area acquired  
9 replenishes the water supply and keeps the drawdown  
10 at a level that regulatory agencies require in  
11 order to protect the supply from saline water  
12 intrusion. Also, as SSU witness, Robert Dilg, Esq.  
13 will testify, if the area adjoining the lakes had  
14 not been acquired, SSU potentially would have been  
15 forced to incur additional costs above the \$8  
16 million to secure the property from development and  
17 protect the lakes.

18 Also, SSU realized that the site was the best  
19 location for the Aquifer Storage and Recovery  
20 facility which is being constructed on the site.  
21 Exhibit \_\_\_\_\_ (RAT-3) provides a map identifying  
22 the purchased parcel, the ASR site and the lakes.  
23 Construction of the ASR facility on this site was  
24 the most economical as well as the most technically  
25 strategic placement of the facility. As

1 demonstrated by the rings which surround the ASR  
2 well on this map, the concentration of water placed  
3 in the ASR well will confirm that the total site is  
4 needed to protect SSU against the possibility of  
5 other entities, such as the Colliers or their  
6 licensee from drilling wells in this area and  
7 tapping our stored ASR water supplies.

8 **Q. ARE THERE ANY OTHER REASONS WHY THE BALANCE OF THE**  
9 **ACREAGE AT THE CONDEMNED COLLIER LAKES PARCEL**  
10 **SHOULD NOT BE CONSIDERED NON-UTILITY AND, THUS,**  
11 **NON-USED AND USEFUL?**

12 A. Yes. The strategic placement of this site is  
13 evidenced by the fact that the Henderson Creek  
14 passes the site and water from the creek will  
15 recharge the source of the water and enable us to  
16 use the excess water to be stored in the ASR  
17 facility. Also, SSU plans to channel the water SSU  
18 will obtain from the 160 acre (Section 35) site  
19 into the Collier Lakes and the ASR well. If the  
20 Collier Lakes and surrounding property had not been  
21 purchased by SSU, SSU would have incurred  
22 additional costs to acquire a site for the ASR  
23 facility, if such a site could be located -- and,  
24 almost certainly, no other site would have been so  
25 strategically located. Also, if the purchase had

1 not been made, SSU would have had to install  
2 additional pipelines from the 160 acre site to  
3 SSU's transmission facilities because SSU would  
4 have lost the pipe on the Collier Lakes property  
5 which we will now continue to use to transport the  
6 water to our existing transmission facilities. SSU  
7 will be saving a great cost to our customers by  
8 locating the ASR facility in this area and using  
9 the existing pumps and piping to convey the water  
10 needed to be delivered to the ASR well and  
11 ultimately Marco Island.

12 **Q. DO YOU AGREE WITH MR. BIDDY'S TESTIMONY IN**  
13 **REFERENCE TO MARGIN RESERVE?**

14 A. Definitely not. It is apparent that Mr. Bidy has  
15 not been exposed to the regulatory constraints and  
16 third party opposition confronting investor owned  
17 utilities, even though he expresses concern on page  
18 3, lines 19 and 20, of his testimony that "the  
19 utilities may have to expand WWTP quickly."

20 **Q. DO YOU FEEL THAT WATER TREATMENT PLANTS SHOULD**  
21 **FOLLOW THE SAME PLANNING STRATEGIES AS THOSE OF**  
22 **WASTEWATER TREATMENT FACILITIES?**

23 A. Yes. On Page 4, line 2, Mr. Bidy appears to  
24 assume that because it is a water plant to be  
25 added, there should not be a planning period for

1           it.    Due to the Commission's existing used and  
2           useful policy, the utility is discouraged from  
3           having available sites in inventory for future  
4           facilities. It is our position that in most cases,  
5           due to factors such as land acquisition, zoning  
6           changes, site constraints, third-party opposition,  
7           etc., it will take a long time to obtain permits  
8           and design facilities, which may not only include  
9           treatment facilities, storage facilities, etc. but  
10          also transmission and distribution improvements and  
11          pumping facilities to deliver water where demanded.  
12          Regulatory agencies are presently requiring that  
13          information be provided at permit application and  
14          renewal time for water plant capacities similar to  
15          that provided for wastewater facilities in the  
16          Capacity Analysis Reports.        Presently, this  
17          information is being requested by the Central,  
18          Northeast and Southwest Districts of the Department  
19          of Environmental Protection, which I will refer to  
20          as "DEP," when construction permit requests are  
21          submitted by utilities for approval.

22        **Q.   MR. BIDDY'S OPINION AT PAGE 4 OF HIS TESTIMONY THAT**  
23        **SSU'S PLANNING STAGES FOR THE MARION OAKS FACILITY**  
24        **ARE PRUDENT. COULD YOU DESCRIBE THE DATES AND**  
25        **CAPACITY CHANGES FOR EACH PHASE OF THE PLANNED**

1           **MARION OAKS PLANT EXPANSION?**

2           A.    Yes.  The Phase 3-A expansion to 0.275 MGD would be  
3                    in service by 2003.  The Phase 3-B expansion to  
4                    0.350 MGD would be in service by 2019.  The Phase 4  
5                    expansion to 0.500 MGD would be in service by 2050.  
6                    The Phase 5 expansion to 1.000 MGD would be in  
7                    service by 2085.

8           **Q.    DOES THIS SHOW THAT BUILDING IN PHASES RECONFIRMS**  
9                    **THE NEED FOR MARGIN RESERVE?**

10          A.    Yes.  These planning stages include margin reserve  
11                    periods for Phases 3A through 5 as follows:

12                    Phases 3A to 3B	16 years
13                    Phases 3B to 4	31 years
14                    Phases 4 to 5	35 years

15                    As can be seen by this example, Mr. Bidy's  
16                    acknowledgement that this is the prudent way to  
17                    expand plant provides compelling confirmation of  
18                    the tremendous need for economies of scale,  
19                    discussed further in Mr. Hartman's rebuttal  
20                    testimony, and the need for a margin reserve period  
21                    to recognize such economies.

22                    The utility, under present Commission used and  
23                    useful policy, is discouraged from proceeding with  
24                    plans such as the prudent plan for Marion Oaks.  
25                    This type of planning has not only been provided

1 for Marion Oaks but for other plants as well, such  
2 as Citrus Springs, Sugarmill Woods and Spring Hill.  
3 These master plans represent the most economical  
4 plans for our customers, but again, due to existing  
5 used and useful policy, this will not be the way  
6 any utility could proceed to construct plant until  
7 the antiquated rules are revised to allow recovery  
8 and a rate of return on the associated investment  
9 in such facilities.

10 **Q. SHOULD FIRE FLOW REQUIREMENTS BE CONSIDERED IN THE**  
11 **USED AND USEFUL CALCULATIONS?**

12 A. Yes. Contrary to what Mr. Bidy suggests, fire  
13 flow capacity should be included in used and useful  
14 calculations for any plant where fire flows have  
15 been included in the design. For example, the  
16 Citrus Springs water distribution system was  
17 designed for fire flows, but SSU is not responsible  
18 for the installation of the hydrants. Even though  
19 the hydrants have not been installed, allowance for  
20 fire flows should be allowed. Public Counsel  
21 witness Bidy states on Page 6, line 7, "If a  
22 system is not designed or proven to provide  
23 required fire flow, it is dangerous and unfair to  
24 assume the fire flow requirement in used and useful  
25 analysis." Thus, Mr. Bidy recognizes that when



1 the distribution system has been designed to  
2 provide fire flow, it is only fair to the utility  
3 to consider this flow in the used and useful  
4 calculation. Again, the utility is not encouraged  
5 by existing used and useful rules to provide the  
6 excess capacity required for fire flow since it is  
7 not known when fire hydrants will be added to the  
8 distribution system.

9 **Q. DO SMALL WATER DISTRIBUTION SYSTEMS WITHOUT A**  
10 **STORAGE TANK HAVE FIRE FIGHTING CAPABILITIES?**

11 A. There are some small distribution systems that have  
12 fire fighting capabilities such as our Point 'O  
13 Woods plant, where the fire flow is obtained from a  
14 single well and there are no large storage  
15 facilities. There are other small facilities at  
16 which storage is available but not in quantities  
17 sufficient for fire storage, however, the  
18 facilities have been designed to provide fire  
19 flows. An example of such a facility is Fox Run.

20 **Q. HOW DOES AWWA MANUAL M31 ACCOUNT FOR RATES OF WATER**  
21 **USE?**

22 A. Page 16 of AWWA manual M31 addresses the water  
23 demands in a water system as follows:

24 "RATES OF WATER USE

25 Three historical or predicted water

1 demand rates are involved in the  
2 discussion of fire protection. They  
3 are:

4 Average daily demand--the  
5 average of the total amount of water  
6 used each day during a  
7 one-year period.

8 Maximum daily demand--the  
9 maximum total amount of water used  
10 during any 24-h period in a three-  
11 year period. (This number should  
12 consider and exclude any unusual and  
13 excessive uses of water that would  
14 affect the calculation.)

15 Maximum hourly demand--the  
16 maximum amount of water used in any  
17 single hour, of any day, in a three-  
18 year period. It is normally  
19 expressed in gallons per day by  
20 multiplying the actual peak hour use  
21 by 24.

22 Where specific data on past  
23 consumption are not available, a  
24 good rule of thumb is that maximum  
25 daily demand is 1.5 times the

1 average daily demand, while the peak  
2 hourly rate may vary from **two to**  
3 **four times** the average daily rate.  
4 In small water systems, peaking  
5 factors may vary significantly  
6 higher than this.

7 Design flow should be based on  
8 the maximum hourly demand or the  
9 maximum daily demand plus the fire  
10 flow requirement, whichever is  
11 greater. The distribution system  
12 should be designed to maintain a  
13 minimum pressure of 20 psi at all  
14 points in the system under all  
15 conditions of design flow."

16 Mr. Biddy suggests that page 33 of the Manual  
17 supports his proposition that reliability considerations  
18 should not be part of the used and useful equation.  
19 However, I have reviewed page 33 of M-31 and have found  
20 that the Manual states as follows:

21 " Major System Components  
22 Specifying the reliability required  
23 for major transmission mains, pump  
24 stations, and storage tanks is  
25 difficult because the outage of any

1           one of these components can affect a  
2           large area. Furthermore, the chance  
3           that a fire will occur during an  
4           outage of one of these components is  
5           considerably higher than during an  
6           outage of local lines. The rule for  
7           determining reliability of these  
8           components is that all required fire  
9           flows be delivered downstream, even  
10          when one of these major components  
11          is out of service. In the case of  
12          pumps, the impact of loss of power  
13          to the pumps for an extended period  
14          of time needs to be considered and  
15          planned for. However the system  
16          should be designed to provide some  
17          water at 20 psi."

18          It should be clear from this passage that Mr.  
19          Biddy's proposition that the Commission ignore  
20          reliability criteria for purposes of used and  
21          useful analysis is in direct conflict with design  
22          criteria reflected in the Manual.

23          **Q. DO YOU AGREE WITH MR. BIDDY'S SUGGESTION THAT THE**  
24          **CAPACITY OF THE BEACON HILLS WASTEWATER TREATMENT**  
25          **PLANT UNDER PERMIT NO. DO16-213087 IS INCORRECTLY**

1           **STATED IN THE MFR'S?**

2       A.    No.    Existing operation of the plant in the  
3            extended air mode results in a the 0.836 MGD  
4            capacity of the existing plant.

5            To operate this plant in the contact  
6            stabilization mode, investment in additional  
7            facilities would be needed to comply with existing  
8            regulations and meet class III reliability, which  
9            includes among other things, an additional  
10           clarifier, dual chlorine contact chambers, etc.  
11           Even if this plant were to be updated for the  
12           additional capacity, no adjustment of used and  
13           useful should be done since the cost incurred for  
14           tankage in the extended air mode is the same as for  
15           contact stabilization mode with no increase in cost  
16           to our customers for the tanks. This is an example  
17           of economies of scale at its best.

18           Finally, SSU should not be penalized by a  
19           hypothetical increase in the plant capacity.

20       **Q.    IS MR. BIDDY'S STATEMENT ON PAGE 8, LINES 21 AND**  
21       **22, IN REFERENCE TO ERP PERMITS CORRECT?**

22       A.    No.    The 1993 Environmental Resources Permit, which  
23            I will refer to as the ERP program, does not  
24            consider the combination of construction and  
25            operation permits. The ERP is a combination of the

1 wetlands and dredge and fill permits and surface  
2 water management.

3 Chapter 62-620 Wastewater Facilities  
4 Permitting, implemented in November 1994,  
5 incorporates the delegation of the EPA NPDES permit  
6 to the DEP which resulted in a single permit to be  
7 issued for construction and operation of wastewater  
8 facilities.

9 **Q. DO YOU HAVE ANY COMMENTS CONCERNING MR. BIDDY'S**  
10 **PROPOSALS FOR USED AND USEFUL DETERMINATIONS**  
11 **RELATED TO WATER SUPPLY WELLS, STORAGE AND HIGH**  
12 **SERVICE FACILITIES?**

13 A. Yes. I disagree with Mr. Bidy's methodology in  
14 reference to the "firm reliable capacity" method of  
15 facilities with storage and pumping facilities.

16 It should be noted that mechanical equipment  
17 will fail at the "worst possible time" and this is  
18 not limited to one component. In instances where  
19 demands are in excess of the capabilities of the  
20 equipment, it very well may be that in order to  
21 keep the system above 20 p.s.i., it is stressed to  
22 the maximum; then, if extended, the equipment may  
23 fail.

24 **Q. DO YOU AGREE WITH MR. BIDDY'S USE OF A 1.3 RATIO OF**  
25 **PEAK FLOW TO MAXIMUM DAY DEMAND?**

1       A.    No.  The size of the facilities operated by SSU are  
2            such that it will require a larger ratio as shown  
3            on AWWA M31, Page 16, which specifically states,  
4            "... a good rule of thumb is that maximum daily  
5            demand is 1.5 times the average daily demand, while  
6            peak hourly rate may vary from two to four times  
7            the average daily rate.  In small water systems,  
8            peaking factors may vary significantly higher than  
9            this."

10       **Q.    WHAT WERE THE METHODS USED TO DESIGN STORAGE**  
11       **FACILITIES IN MOST OF THE ORIGINAL SYSTEMS?**

12       A.    The rule of thumb method was to have a maximum day  
13            capacity available as storage.

14            Even though in the original design the term  
15            "emergency storage" was not used as such, when you  
16            analyze the proposed rules and compare them to the  
17            original design, it is obvious that emergency  
18            storage was included in the design.  Recent  
19            experience has confirmed that this design was  
20            prudent and necessary.  During a Marco Island raw  
21            water main break emergency, it took the cooperation  
22            of the media and the residents to limit their usage  
23            during a period of time in which SSU was able to  
24            provide service by utilizing full production from  
25            our R.O. plant.  At other facilities where we have

1 installed less than maximum day storage due to used  
2 and useful considerations, we have been able to  
3 satisfy fire flow demands, but we also have, on  
4 occasion, had some areas with less than 20 p.s.i.  
5 during fire flow demands due to lack of storage  
6 facilities. In such situations, we have had to  
7 serve boil water notices to our customers. Please  
8 understand that even in these situations SSU always  
9 has been able to provide the necessary fire flow to  
10 put out the fire.

11 **Q. DO YOU AGREE WITH MR. BIDDY'S STATEMENTS ON**  
12 **FACILITY LANDS?**

13 A. No. All lands occupied by any facility should be  
14 100% used and useful. The utility has been  
15 diligent in acquiring the land necessary to provide  
16 service to its customers in a prudent process.  
17 Under the existing rules, the utility has no  
18 incentive to acquire any more land than is  
19 necessary--although master planning might otherwise  
20 suggest land should be acquired ahead of time. For  
21 example, SSU acquired a raw water supply site in  
22 Collier County at a cost of approximately \$240,000  
23 in 1984. This location was acquired to provide a  
24 source of supply to meet future demand. SSU has  
25 not obtained any return on this investment even



1           though this site was used to store sludge from the  
2           lime softening treatment plant at Marco Island,  
3           which saved a lot of money for existing customers.

4           SSU's predecessor, after having one of the  
5           first groundwater models for Marco Island, found  
6           that the build out demands were going to be 5 MGD  
7           in addition to the then existing facilities. In  
8           looking out for the existing customers, since they  
9           will share this water with future customers, SSU  
10          acquired the 160 acre site after testing the site  
11          for water quality and quantity. This site was  
12          selected to be developed at a later date due to its  
13          distance to our existing facilities and due to the  
14          utility's desire not to expend money unnecessarily.  
15          The utility actually evaluated different  
16          alternatives to provide water to the Island but was  
17          not successful in obtaining them. SSU provided  
18          information identifying these alternatives in  
19          detail to all parties in response to FPSC  
20          Interrogatories 43, 298 and 341; OPC Document  
21          Request 33; and OPC Interrogatory 290. As I will  
22          discuss, we are in the throes of developing the 160  
23          acre water supply source at this time. If SSU did  
24          not already own the property perhaps SSU would be  
25          required to secure additional property in the area

1           which, as demonstrated by the Collier Lakes  
2           condemnation, is not an easy or inexpensive  
3           process. Since the 160 acres is in SSU's land  
4           inventory, we and our customers are saved from a  
5           potentially expensive outlay of funds.

6           **Q. DO YOU AGREE WITH MR. BIDDY'S STATEMENTS REGARDING**  
7           **HYDRO TANKS AND AUXILIARY POWER?**

8           A. No. All hydro tanks and auxiliary power should be  
9           100% used and useful since they have been installed  
10          for surge suppression and to avoid disruption of  
11          service from broken water distribution mains.  
12          Standby power to provide and maintain a reliable  
13          level of service is required by FPSC and by DEP  
14          regulations.

15                 In addition, standby power equipment has been  
16          designed to meet the minimum loading  
17          characteristics of our facilities and in most cases  
18          this equipment has been phased in order to provide  
19          the least amount of power required to meet the  
20          needs of each plant.

21          **Q. IS IT REQUIRED THAT MARCO SHORES WATER TREATMENT**  
22          **PLANT PROVIDE STANDBY POWER?**

23          A. Yes. Marco Shores serves more than 350 people, so  
24          standby power should be installed to provide the  
25          reliability required by DEP Regulation

1 62.555.320(6). Please refer to Exhibit \_\_\_\_\_ (RAT-  
2 4).

3 **Q. DO YOU AGREE WITH MR. BIDDY'S ANALYSIS CALCULATING**  
4 **THE USED AND USEFUL PERCENTAGES OF WATER**  
5 **TRANSMISSION AND DISTRIBUTION SYSTEMS?**

6 A. No. The hydraulic analysis method is a tool not  
7 only used to evaluate the most economical  
8 distribution system but is also versatile in  
9 evaluating the flow through pipes during any  
10 condition. Hydraulic analyses have been performed  
11 either manually when computers were scarce, to  
12 presently, when the evaluation of a system can be  
13 completed economically with desktop computers in a  
14 fraction of the time that was required in the  
15 1950's, 60's and 70's.

16 Hydraulic analysis has been used not only for  
17 modeling flow in pipes but also to model water  
18 quality behavior within drinking water distribution  
19 systems. It tracks the flow of water in each pipe,  
20 the pressure at each junction, the height of water  
21 in each storage tank, and the concentration of a  
22 substance throughout a distribution system during  
23 multi-time period simulation. In addition to  
24 substance concentrations, water age and source  
25 tracing can also be performed. In addition to the

1 above-mentioned multi-task of a hydraulic analysis,  
2 hydraulic flow modeling can be used to measure used  
3 and useful in a simple and accurate way. The four  
4 systems submitted in the MFRs were originally  
5 designed the same way with fire flow considerations  
6 and as such should be analyzed with fire flow  
7 capabilities throughout the territory. The  
8 distribution systems were designed at an early  
9 stage of the development, were constructed under  
10 the same specifications and were installed in  
11 accordance with the original design. Minor  
12 revisions have been done through the years to  
13 optimize the system or accommodate growth and  
14 economic efficiency.

15 The original developers intended to prevent  
16 scattered development, but since most of the lots  
17 sold were to people from different states and  
18 countries, it was/is very difficult to manage the  
19 growth of any Florida community. All or virtually  
20 all of the lots in Citrus Springs, Pine Ridge and  
21 Marion Oaks have been sold by Deltona Corporation,  
22 and Sunny Hills has a remainder of 12,000 lots to  
23 be sold of the original, 35,000 or so lots. As  
24 mentioned above, the lots were sold in groups in  
25 order to phase the growth, but as we all know, the

1 people who bought these properties probably will  
2 not retire and build homes at the same time, or  
3 move to their property in the same order that  
4 Deltona's original development plan suggested.

5 It is the responsibility of the utility to  
6 serve its customers in the most economical way  
7 possible, but at the same time have a reliable  
8 source where the quality of the water service is  
9 monitored to meet federal, state and local  
10 regulations.

11 **Q. HAS MR. BIDDY ANALYZED THE COST TO SERVE THE 100**  
12 **HOMES REFERRED TO ON PAGE 16, LINES 5 THROUGH 20?**

13 A. No. Mr. Bidy has presented an economic analysis  
14 of the costs to 100 homes for a water distribution  
15 system to serve 1,000. I just pointed out that Mr.  
16 Bidy has looked at a case where 10% of lots are  
17 connected. what about areas where 70 of 100, 80 of  
18 100 or 90 of 100 lots are connected? Can anyone  
19 reasonably suggest that pipeline in front of these  
20 connected houses are at all non-used and useful  
21 simply because 1 to 3 lots of every 10 are not  
22 connected? To get back to Mr. Bidy's example, Mr.  
23 Bidy also is assuming that the development is a  
24 planner's dream and has developed in the form of a  
25 mushroom, which is not a realistic pattern for

1 development. It should be noted that the utility  
2 must follow regulations in that if fire flows are  
3 mandated by local or state regulations, we must  
4 comply and design the system for fire flow  
5 capabilities. It is an engineering and utility  
6 goal to provide the quality of service which meets  
7 the demands of customers and regulatory agencies.  
8 Serving one of five lots does not mean that service  
9 can be provided with a garden hose to the one  
10 connected lot. A 1/2" garden hose probably could  
11 serve the domestic needs for a 50 foot long  
12 service, but at what cost? What about lawn  
13 irrigation? If the customer has an irrigation  
14 system, the demand could be 15 to 35 gpm, with a  
15 low pressure sprinkler system, at approximately 35  
16 p.s.i.

17 The distribution system should be able to  
18 provide fire flows if designed to handle fire  
19 demands, and it should not be based on the number  
20 of connected lots. If fire service is designed,  
21 then at the time the utility serves so much as one  
22 customer, fire flows should be adequate. By  
23 today's used and useful rules, there is little  
24 incentive to design adequately for fireflow.

25 **Q. DO YOU AGREE WITH MR. BIDDY'S COMMENTS ON PAGE 17,**

1           **REGARDING THE COMPLEXITIES OF HYDRAULIC MODELING?**

2       A.    No.   Hydraulic analysis modeling is a very simple  
3            setup, and will save the utility tremendous time  
4            and effort to provide good service.   In fact, as  
5            pointed out by Mr. Biddy, Page 15, lines 7, 8 and  
6            9, "The hydraulic analysis method indeed is a  
7            reliable design tool for designing water  
8            transmission and distribution systems."   Included  
9            as Exhibit \_\_\_\_ (RAT-5) are copies of 2 loops  
10           manually computed for Marco Island done in 1964.  
11           This manual task appears to have taken  
12           approximately one week to perform.   With today's  
13           programming and computers, a network of  
14           approximately 50 loops and 150 pipes could be  
15           completed in approximately 4 hours; this task would  
16           have taken months to complete in the old days and  
17           perhaps this is what Mr. Biddy is referring to.  
18           Please refer to Exhibit \_\_\_\_ (RAT-6).

19                    The purpose of the hydraulic modeling is, "the  
20           basis for preliminary design in terms of sizing and  
21           phasing new facilities and maximize the use of  
22           existing facilities."   Please refer to Exhibit  
23           \_\_\_\_ (RAT-7).

24       **Q.    WHAT METHOD WAS USED TO ORIGINALLY DESIGN THE**  
25       **DISTRIBUTION SYSTEMS MODELED IN THE MFR'S?**

1 A. The program used originally was a mainframe program  
2 entitled, "Water Flow In A Pipe Network By Hardy  
3 Cross Solution," by D. R. Wood. Please refer to  
4 Exhibit \_\_\_\_\_ (RAT-8). It should be noted that the  
5 author of this program actually improved the system  
6 to publish the "Kentucky Pipe" hydraulic analysis  
7 used by most utilities, consulting engineers, etc.  
8 "Kentucky Pipe" rights were sold to Cybernet and  
9 presently the Cybernet analysis is the "Kentucky  
10 Pipe" with Auto Cad integrated to make it more  
11 versatile.

12 **Q. DO YOU AGREE WITH THE LOT COUNT METHOD FOR ANALYSIS**  
13 **OF USED AND USEFUL?**

14 A. No. The lot count method does not follow  
15 engineering methodology at all; it only addresses  
16 density without consideration of properly sized  
17 distribution systems which must comply with  
18 federal, state and local regulation including fire  
19 flow regulations. The lot count method does not  
20 take advantage of the economies of scale principle.  
21 In other words, this method is antiquated and  
22 counterproductive to good engineering results for  
23 our customers. In the end, if utilities design  
24 facilities under the lot count principle, the  
25 results will be ineffective construction costs to



1 our customers and unreliable service.

2 **Q. HOW SHOULD EXCESS INFLOW AND INFILTRATION BE**  
3 **EVALUATED?**

4 A. Infiltration and inflow should be evaluated in  
5 accordance with EPA Handbook, "Sewer System  
6 Infrastructure Analysis and Rehabilitation."  
7 EPA/625/6-91/030. Please refer to the pertinent  
8 excerpt in Exhibit \_\_\_\_\_ (RAT-9). This  
9 addresses the most economical method of analyzing  
10 infiltration/inflow to the system. Any facility  
11 not exceeding these limits should not be penalized  
12 in the used and useful analysis.

13 **Q. HAS THE 160 ACRE RAW WATER SUPPLY SITE OF MARCO**  
14 **ISLAND BEEN EVALUATED IN REFERENCE TO ITS CAPACITY?**

15 A. Yes. The 160 Acre, Section 35 raw water supply has  
16 been evaluated as to the capacity of water that the  
17 utility will be able to withdraw from the site.  
18 Copies of these studies have been submitted to all  
19 parties in this proceeding. This parcel should be  
20 100% used and useful since permitting is at an  
21 advanced stage and construction of this facility  
22 will commence as soon as permits have been  
23 obtained.

24 The water obtained from the 160 acres will be  
25 combined with that of the existing raw water lakes

1 in order to meet demands on the island. In  
2 addition, during the wet season, the additional  
3 water available will be stored in the Aquifer  
4 Storage and Recovery (ASR) facilities being  
5 constructed at this time at the Collier raw water  
6 lakes site.

7 It is of utmost importance to finalize the  
8 permitting of the 160 acre site in order to provide  
9 the additional raw water to create a freshwater  
10 lens that will provide the quality of water that  
11 our lime softening facility is capable of treating.

12 **Q. DO YOU DISAGREE WITH MR. BIDDY'S STATEMENTS ABOUT**  
13 **EFFLUENT REUSE FACILITIES NOT BEING 100% USED AND**  
14 **USEFUL?**

15 **A.** Yes. We agree with Richard Harvey, former Director  
16 of the Water Facilities Division of DEP, that all  
17 effluent reuse facilities should be considered 100%  
18 used and useful. The facilities serving Marco  
19 Island and Marco Shores have been permitted by all  
20 regulatory agencies and they match the capacity of  
21 the wastewater treatment plant and should be 100%  
22 used and useful.

23 To demonstrate what facilities are included as  
24 reuse facilities, I will describe the additional  
25 facilities required at Marco Island to supply reuse

1 to the golf courses on Marco Island and at Marco  
2 Shores as well as the Marco Island median. Those  
3 facilities include the following: (a) equalization  
4 basin; (b) automatic screens; (c) dual aeration  
5 tanks; (d) dual filters; (e) dual chlorine contact  
6 chambers; (f) substandard ponds; (g) injection  
7 well; (h) monitoring equipment (chlorine residual,  
8 turbidity); (i) pumping facilities; (j)  
9 transmission mains; (k) booster stations; (l)  
10 percolation ponds; and (m) standby power.

11 The utility must manage the different effluent  
12 disposal areas in order to be able to dispose of  
13 the effluent in accordance with regulatory  
14 requirements. To provide a more economical way of  
15 disposing of the effluent, when the golf courses  
16 are not using the reclaimed wastewater at Marco  
17 Island, it is pumped into the injection well in  
18 order to save energy and costs. Ms. Kowalsky will  
19 address the plans to use reclaimed water on other  
20 sites which will decrease the disposal of  
21 wastewater into the injection well in accordance  
22 with new directions from the regulatory agencies,  
23 environmentalists and most of all concerned  
24 citizens' groups.

25 **Q. SHOULD THE MARCO ISLAND INJECTION WELL BE**

1           **CONSIDERED 100% USED AND USEFUL?**

2           A.    Yes.    The Marco Island injection well should be  
3                considered 100% used and useful.   SSU has provided  
4                FPSC copies of where the permitted capacity of the  
5                existing well.    The injection well presently  
6                disposes the concentrate from the R.O. water plant  
7                and also serves as a backup to the reuse facilities  
8                in case of inclement weather.

9                The injection well has provided the utility  
10               with an ultimate disposal during times of inclement  
11               weather and avoided discharges to surface waters.  
12               Since the injection well is completely sealed, any  
13               flood in the area that forecloses effluent disposal  
14               to golf courses or percolation ponds can be  
15               disposed into the well.

16           **Q.    WHAT WAS THE PURPOSE IN OBTAINING WATER FROM THE**  
17                **"DUDE PIT" FOR RAW WATER SUPPLY?**

18           A.    The utility has expeditiously reviewed several  
19                sites in the area near our existing Marco Lakes in  
20                order to augment and/or replace our existing  
21                source.

22                The need for additional water sources arose  
23                from the impending expiration of an existing lease  
24                agreement with the Collier's and the limitations of  
25                the Collier site to provide additional water.

1           Of all of the sites that were evaluated by the  
2 utility, the Dude Pit property was the one with the  
3 best projected quality water through the years.  
4 SSU pursued a water agreement with the then owners  
5 of Dude Pit. SSU investigated the permitting  
6 requirements and all agencies agreed that  
7 permitting of the site was possible.

8           SSU immediately contracted to have a design of  
9 the proposed facilities and permits were obtained  
10 from all agencies with the exception of Collier  
11 County.

12           The amount of water to be withdrawn and  
13 permitted by regulatory agencies was 4.0 MGD.

14           The County did not approve this site largely  
15 as a result of opposition from agricultural  
16 interests which opposed development of the site.

17   **Q. WAS THE WATER FROM THE DUDE PIT TO SUPPLY WATER TO**  
18   **MASS MUTUAL GOLF COURSE AT MARCO SHORES?**

19   A. SSU had preliminary conversations and a draft  
20 agreement was completed to provide irrigation water  
21 for the Mass Mutual Golf Course from the Dude Pit,  
22 but this never materialized. Also, the provision  
23 of water from the Dude Pit to the Golf Course would  
24 have been only one customer for the water. The  
25 golf course was not going to take the entire four

1 million gallons a day which would have been  
2 available. In fact, the golf course usage would  
3 have been only approximately 350,000 gallons per  
4 day, or only 8.75% of the water. The remainder  
5 would have been used to supply SSU's existing  
6 customers. The attempt to suggest that SSU pursued  
7 the Dude Pit water resources solely to supply the  
8 Mass Mutual Golf Course is ridiculous and,  
9 depending on how closely the information available  
10 to the parties was read, could be said to be  
11 intentionally misleading.

12 Please note that Mass Mutual also inquired  
13 about obtaining reclaimed water from SSU facilities  
14 but these efforts never materialized either.

15 **Q. HAS SSU SPENT ANY FUNDS FOR "PROTECTING THE**  
16 **ENVIRONMENT OR ENVIRONMENTAL COMPLIANCE"?**

17 A. Of course, I completely disagree with Mr. Bertram's  
18 statements to the contrary.

19 Since 1989, SSU has embarked on hundreds of  
20 projects in order to be in environmental compliance  
21 and to protect the environment.

22 Just a few examples of these projects are as  
23 follows:

24 Soon after acquiring the Deltona Lakes service  
25 area, SSU entered in a consent order with DEP due

1 to a concern over potential negative impact on Lake  
2 Monroe from effluent discharges.

3 SSU diligently proceeded to improve the  
4 facilities to include reclaimed water use at two  
5 golf courses. One of these golf courses was having  
6 trouble with high chlorides and SSU was requested  
7 by the St. Johns River Water Management District to  
8 install a line to the Deltona Hills and Country  
9 Club, and later, another line was installed to  
10 serve Glen Abbey Golf Course.

11 At University Shores, SSU ceased the surface  
12 water discharge of effluent in 1994 by agreeing to  
13 connect the facilities to Orange County reuse  
14 facilities and paying for the connection. This was  
15 a solution designed to protect the environment and  
16 also to maintain environmental compliance.

17 At Seaboard, SSU invested in an interconnect  
18 of SSU's wastewater facility to the City of Tampa  
19 thus ending an era of discharges of effluent into a  
20 creek. The cessation of this discharge also  
21 diminished the mosquito population in an area of  
22 low income residents previously plagued by  
23 mosquitoes.

24 At Marco Island, SSU provides wastewater to  
25 two golf courses using the reclaimed water to its

1 maximum--thus saving precious fresh water for  
2 residential use. SSU is also presently providing  
3 Reverse Osmosis water to Marco Island residents  
4 from the brackish aquifer, saving 4.0 MGD of fresh  
5 water during periods of high demand. Saving this  
6 fresh water is necessary for recharging the aquifer  
7 and fighting saltwater intrusion.

8 These are just a few of the hundreds of  
9 projects completed by SSU. SSU is proud of our  
10 record with regulatory agencies in working with  
11 them to protect the environment and the public  
12 health in so many different ways. Mr. Bertram's  
13 suggestion that all that was required to comply  
14 with environmental and safety requirements was  
15 additional sampling requirements has no basis in  
16 fact and, obviously, would never be made by any  
17 provider of water and wastewater service nor should  
18 it be condoned by regulators, environmental or  
19 economic, of such service providers.

20 **Q. DO YOU AGREE WITH MR. BERTRAM'S STATEMENT ABOUT**  
21 **WELL CONSTRUCTION TECHNIQUES?**

22 A. No. The wells drilled by SSU have been permitted  
23 by regulatory agencies. In fact, in most cases,  
24 the regulatory personnel have been present during  
25 construction. I agree that in some cases the high



1 iron concentrations may result from failure of the  
2 shoe or the casing. However, SSU has completed a  
3 great deal of research on our existing facilities  
4 which has confirmed that iron may appear in our  
5 water supply as a result of sink holes which may  
6 develop at a significant distance from our wells;  
7 nonetheless, our supplies have been contaminated by  
8 the pollutants, such as iron, which are introduced  
9 into the aquifer through the sink holes.

10 SSU complies with regulations in that we  
11 provide water within MCL requirements to our  
12 customers. It could cost millions of dollars to  
13 identify and correct deficiencies in the earth's  
14 natural systems. Would any investor propose that  
15 this be done by SSU?

16 **Q. IS THERE A LIMIT IMPOSED FOR ACCEPTABLE IRON**  
17 **CONCENTRATION IN THE EXISTING REGULATIONS , AND IF**  
18 **SUCH LIMITATION EXISTS, HOW WOULD YOU CLASSIFY THE**  
19 **ADDITIONAL TREATMENT TO MEET THIS LIMITATION?**

20 A. Iron has a limit of 0.3 mg/l. If a well does not  
21 have a concentration above .3 mg/l, there is no  
22 need to treat any further. But, if the  
23 concentration is above .3 mg/l, the additional  
24 treatment would be classified for "environmental  
25 compliance."

1       **Q. DO YOU AGREE WITH SUGARMILL WOODS' WITNESS HANSEN**  
 2       **IN REFERENCE TO SUGARMILL WOODS WASTEWATER**  
 3       **TREATMENT AND DISPOSAL?**

4       A. No. As I mentioned before in this testimony, more  
 5       and more rules require additional evaluations of  
 6       existing and potential plant expansions or  
 7       improvements and more often than not these re-  
 8       evaluations require a reduction of capacity because  
 9       some component of the facility, such as percolation  
 10      ponds, cannot handle the loading under new rules or  
 11      do not have the reliability needed.

12               The capacity of the Sugarmill Woods wastewater  
 13      plant was reduced in 1995 because the clarifier  
 14      maximum capacity is 0.4 MGD as stated in the  
 15      Capacity Analysis Report of the Sugarmill Woods  
 16      facility which was prepared for SSU by Berryman &  
 17      Henigar in October 1995. I have included the cover  
 18      page and the pertinent page from this report in  
 19      Exhibit \_\_\_\_\_ (RAT-10).

20      **Q. WHAT IS THE CURRENT CAPACITY OF THE BURNT STORE**  
 21      **WATER TREATMENT PLANT?**

22      A. The current capacity of the water treatment plant  
 23      is as follows:

24	Each Skid		240,000 gpd
25	2 Skids @ 240,000 gpd	=	480,000 gpd



1           These facilities should be evaluated with the  
2 permitted capacity recently issued in permit  
3 FL0039446-001 and not what was permitted under the  
4 old permit when the area was treated by DEP as  
5 experimental wetlands. Through the evaluation of  
6 several years of historical data, it was determined  
7 that the disposal capacity was 100,000 gallons per  
8 day -- the experiment is over, the wetlands are a  
9 permitted disposal source. A copy of the permit is  
10 included in Exhibit \_\_\_\_\_ (RAT-11).

11           It should be noted that any facility that was  
12 being evaluated as experimental wetlands to meet  
13 regulations 5 to 10 years ago will likely  
14 experience capacity reductions upon permit renewal,  
15 due to new, more strict regulations and new methods  
16 of evaluating disposal capacity. The utility  
17 should not be penalized for acquiring a parcel of  
18 land that met engineering criteria at the time of  
19 study, but by means of more stringent environmental  
20 analysis, the capacity has been reduced. The  
21 Buenaventura Lakes wetlands were originally  
22 designed as follows:

23           "Wetland Disposal

24                   After alum and denitrification  
25                   treatment, 0.3 mgd of the treated

1 effluent will be pumped to the  
2 northernmost portion of the upper  
3 60-acre wetland for disposal. A  
4 line discharge is employed to  
5 achieve a more uniform flow through  
6 the wetlands. The treated effluent  
7 will be retained in 60 acres of  
8 upper wetland, 70 acres of middle  
9 wetland and 39 acres of lower  
10 wetland for nutrient uptake by the  
11 vegetation. A schematic of the  
12 wetland disposal area is depicted in  
13 Figure 4.

14 Based on a study conducted by  
15 Jammal & Associates, (Orlando,  
16 Florida), the disposal capacity of  
17 the 169-acre wetland disposal area  
18 was approximately 0.4 mgd for a  
19 normal rainfall year. Under this  
20 loading rate, the water depth in the  
21 169-acre wetland disposal area was  
22 estimated to be less than 1 foot,  
23 thus providing about 2 feet of  
24 freeboard below the overflow weirs.  
25 The 169-acre wetland disposal area

1           has an existing 3-foot high  
2           perimeter dike to prevent any  
3           surface runoff from entering or  
4           leaving the system.

5           A copy of the Figure 4 "Schematic of Wetland  
6           Disposal Area" mentioned in the above quote is  
7           provided in Exhibit \_\_\_\_\_ (RAT-12). It should be  
8           understood that without the wetlands as a source of  
9           overflow disposal, the environment and public  
10          health could be adversely effected because SSU  
11          would have no other alternative available for  
12          disposal -- would it be preferred to have the  
13          overflow running in the streets or discharging into  
14          preserved surface water systems?

15       **Q.   REGARDING THE ZEPHYR SHORES WASTEWATER TESTIMONY**  
16       **FROM MR. PETE BURGHARDT OF DEP, WOULD YOU AGREE**  
17       **THAT THE ADEQUACY OF THE COLLECTION SYSTEM IS**  
18       **UNKNOWN?**

19       A.   The collection system is known to be adequate for  
20       the intended purpose. There is minimal or no  
21       inflow/infiltration and the average flows indicate  
22       that the influent is being conveyed properly. We  
23       also maintain our lift stations and pumping  
24       appurtenances to ensure adequacy of the collection  
25       system.

1       **Q.    DO YOU AGREE THAT THE PASCO COUNTY FLOW DIVERSION**  
2       **ENABLES THE FACILITY TO BE IN COMPLIANCE?**

3       A.    The facility is quite capable of maintaining  
4       compliance based on the current treatment system,  
5       but diverting a portion of the influent flow to  
6       Pasco County enables our effluent ponds to function  
7       better due to lessened flow.

8       **Q.    DOES THE ZEPHYR SHORES FACILITY HAVE PROBLEMS**  
9       **MAINTAINING COMPLIANCE WITH ODORS?**

10      A.    We rarely receive complaints from neighbors or  
11      customers, and the DEP has not required us to take  
12      any actions to minimize the natural effects  
13      resulting from operation of this wastewater plant.

14      **Q.    REGARDING THE PALM TERRACE WATER TESTIMONY FROM DEP**  
15      **MR. WILLIAM DUNN, WOULD YOU AGREE THAT THERE IS A**  
16      **NEED FOR ADDITIONAL TREATMENT TO CONTROL HIGH LEAD**  
17      **AND COPPER RESULTS?**

18      A.    There may be a future need, but at this time it is  
19      unwarranted since, under applicable regulations,  
20      the treatment system construction deadline is  
21      January 1, 1997. We are still fine tuning our  
22      process and have taken two consecutive six-month  
23      samples prior to the January 1, 1997 deadline. We  
24      also received a permit from DEP on January 1, 1995  
25      for our C.L. Smith treatment system. As with any

1 new requirement, we are adjusting our feed rates  
2 and are confident we can reduce the exceedances.

3 **Q. REGARDING THE APACHE SHORES WASTEWATER TESTIMONY**  
4 **FROM MS. PHYLLIS JAMES, COULD YOU ELABORATE ON THE**  
5 **CONSENT ORDER CONTAINED IN EXHIBIT PJ-1?**

6 A. This issue was resolved nearly a year ago and we  
7 demonstrated an immediate good faith effort to  
8 resolve these issues after discovery of the issues,  
9 as DEP noted on Part III of their computation  
10 worksheet included in Exhibit \_\_\_\_\_ (RAT-13).

11 **Q. REGARDING THE POINT O'WOODS WASTEWATER TESTIMONY**  
12 **FROM DEP MS. PHYLLIS JAMES, WOULD YOU AGREE THAT**  
13 **THERE WERE A FEW MINOR DEFICIENCIES DURING THE**  
14 **CONSTRUCTION PERIOD?**

15 A. Yes, there were some very minor matters as are  
16 sometimes experienced during construction  
17 activities, but as she also states, this system was  
18 noncompliant for several years before we acquired  
19 it, and we have brought this system into  
20 compliance.

21 **Q. REGARDING THE SPRING GARDENS WASTEWATER TESTIMONY**  
22 **FROM DEP MS. PHYLLIS JAMES, COULD YOU PLEASE**  
23 **EXPLAIN THE STATUS OF THE PERMIT RENEWAL AND**  
24 **BUILDING MORATORIUM?**

25 A. Since we acquired this system during March 1995 we



1 have reduced infiltration and inflow by over  
2 100,000 gpd and are now less than our 0.02 mgd  
3 limit, which should allow release of the moratorium  
4 since we have capacity to accept additional flow.  
5 We submitted the permit renewal documents on April  
6 and November, 1995 and January 1996. Mr. Edward  
7 Coppock of the DEP is the permit writer and he  
8 recently called to tell us that the permit has been  
9 approved and will be issued soon.

10 **Q. OTHER MISCELLANEOUS ITEMS ARE SUGGESTED BY MS.**  
11 **JAMES REGARDING THE SPRING GARDENS FACILITY. COULD**  
12 **YOU RESPOND TO EACH?**

13 A. We have already sodded and seeded the berms but no  
14 growth occurred to prevent erosion, and additional  
15 costs to repeat are therefore unwarranted, but we  
16 will rake and maintain these berms. Once the ponds  
17 dry, we are planning to remove sludge, add fresh  
18 sand, and rototill. We do not keep records of pond  
19 rotations, and have a second blower available but  
20 not installed since it is not required to date.

21 **Q. REGARDING THE SUGARMILL WOODS WASTEWATER TESTIMONY**  
22 **FROM MS. PHYLLIS JAMES, WHAT WERE THE CIRCUMSTANCES**  
23 **REGARDING IMPROPER NOTIFICATION OF MALFUNCTIONS AND**  
24 **ESTIMATIONS OF MOR FLOWS?**

25 A. Lightning disabled a flow meter and composite

1 equipment, and it appears that the above did occur  
2 during this emergency situation. The flow meter  
3 and Parshall flume are back in service and  
4 additional efforts will be made to further improve  
5 proper communications of such events.

6 **Q. REGARDING THE PALM TERRACE WASTEWATER TESTIMONY**  
7 **FROM DEP DAVID MACCOLEMAN, IS THE PLANT EXCEEDING**  
8 **IT'S PERMITTED CAPACITY?**

9 A. Our permit limitation of 0.13 mgd has not been  
10 exceeded since it is an annual average limitation,  
11 which allows occasional higher flows as long as the  
12 annual average is maintained. Some monthly and  
13 three month flows have been greater than 0.13 but  
14 are of no consequence to the issue of permit  
15 exceedance.

16 **Q. IS IT CORRECT THAT A CAPACITY ANALYSIS REPORT (CAR)**  
17 **IS DUE FROM THE PALM TERRACE FACILITY AND MAY**  
18 **REQUIRE PLANT IMPROVEMENTS?**

19 A. An updated CAR will be submitted this month, and  
20 could possibly indicate the need for improvements  
21 or expansion, but we are currently within our  
22 permit limits regarding flow, BOD and TSS.

23 **Q. DOES GROUND WATER EXHIBIT RADIAL FLOW WHICH MAY BE**  
24 **ASSOCIATED WITH FLOW RATES AT THE PALM TERRACE**  
25 **FACILITY?**

1 A. It is possible that the groundwater flow is  
2 influenced by the effluent, but it is unlikely. We  
3 are currently taking monthly readings to further  
4 ascertain flow directions and influence.

5 **Q. REGARDING THE GOSPEL WOODS WATER FACILITY TESTIMONY**  
6 **FROM DEP WILLIAM RYLAND, IS IT POSSIBLE THAT THE**  
7 **HIGH WATER TABLE HAS CAUSED A SURFACE WATER POND TO**  
8 **DIRECTLY INFLUENCE THE WATER SUPPLY WELL?**

9 A. We are currently evaluating this situation since it  
10 is possible to have interference due to proximity,  
11 but recent bacteriological analyses have been in  
12 compliance.

13 **Q. REGARDING THE POINT O'WOODS WATER TESTIMONY FROM**  
14 **DEP WILLIAM RYLAND, PLEASE PROVIDE RESPONSES TO THE**  
15 **FOLLOWING:**

16 **1. ARE THE COPPER LEVELS EXCEEDING THE 90TH**  
17 **PERCENTILE LIMITS? AND,**

18 **2. WILL PAST TURBIDITY PROBLEMS WITH WELL NO. 4**  
19 **INTERFERE WITH REACTIVATION OF WELL NO. 5?**

20 A. 1. The copper levels have decreased and we are  
21 still in the progress of fine tuning our treatment  
22 system, which, by rule, has a January 1, 1997  
23 compliance deadline.

24 2. Lightning damaged well No. 5 and we received a  
25 temporary permit to utilize well No. 4 while being

1 repaired. Past turbidity problems have not  
2 resurfaced during testing and we recently received  
3 clearance to place well No. 5 back on line.

4 **Q. REGARDING THE ROLLING GREEN/ROSEMONT WATER**  
5 **TESTIMONY FROM MR. RYLAND, PLEASE RESPOND TO THE**  
6 **FOLLOWING:**

7 **1. IRON LIMITS ARE BEYOND THE MCL.**

8 **2. A SECOND BACK-UP WELL MAY BE NEEDED SOON.**

9 A. 1. We are currently evaluating the iron  
10 exceedance. If additional dosing or other  
11 alternatives do not lower the results, we will  
12 consider additional treatment and related  
13 permitting issues.

14 2. The two well requirement only applies to  
15 facilities with more than 150 connections or  
16 serving more than 350 people. SSU's January 1996  
17 billing records indicate a total of 127 connections  
18 for these facilities. Also, using 2.26 people per  
19 household per county census data equates to only  
20 287 people. Therefore, neither statement applies  
21 at this time.

22 **Q. REGARDING THE MARION OAKS WASTEWATER SYSTEM**  
23 **TESTIMONY FROM DEP MR. NEAL SCHOBERT, IS IT TRUE**  
24 **THAT THERE IS NO VALID OPERATING DOCUMENT?**

25 A. We received Permit No. FLA012669 on February 27,

1 1996 after much negotiation due to complexities of  
2 phased expansion increments. Previous nitrate  
3 exceedances have been eliminated from reoccurrence  
4 and, according to the permit, DEP has allowed us to  
5 postpone major construction at this facility.  
6 Please refer to the documentation in Exhibit \_\_\_\_  
7 (RAT-14).

8 **Q. REGARDING THE APACHE SHORES WATER TESTIMONY FROM**  
9 **DEP MS. SANDRA SEQUEIRA, COULD YOU PLEASE ELABORATE**  
10 **ON THE NEED FOR AN AUXILIARY POWER SOURCE,**  
11 **ADDITIONAL ANALYSES, AND AN IRON FILTER?**

12 A. We are negotiating an interconnect with Citrus  
13 County and expect to complete it in the first half  
14 of 1996, which will negate the need to install  
15 additional equipment or take more analyses.

16 **Q. REGARDING THE SPRING GARDENS WATER TESTIMONY BY MS.**  
17 **SANDRA SEQUEIRA, IS IT CORRECT THAT AUXILIARY POWER**  
18 **IS REQUIRED?**

19 A. We submitted information to the DEP on December 18,  
20 1995 to explain that we only had 127 connections  
21 and 287 people based on the census data. The DEP's  
22 follow-up Request for Additional Information  
23 acknowledged that this information was less than  
24 the 150 connections and 350 person requirement  
25 which would have required auxiliary power.

1       **Q.    IS THE DEP AWAITING AN AFTER THE FACT PERMIT REVIEW**  
2       **FOR A PUMP REPLACEMENT WHICH WAS INSTALLED DURING**  
3       **AUGUST 1993?**

4       A.    No.  The pump was actually installed during August  
5       of 1995, not 1993.  We notified the DEP of the  
6       emergency replacement by letter on August 17, 1995,  
7       filed an application on October 18, 1995, and have  
8       responded to two requests for additional  
9       information on December 18, 1995 and February 13,  
10      1996.  Correspondence is now due from DEP and a  
11      permit is expected soon.

12      **Q.    REGARDING THE PINE RIDGE WATER TESTIMONY FROM MS.**  
13      **SANDRA SEQUEIRA, IS IT TRUE THAT AUXILIARY POWER IS**  
14      **PROVIDED FOR WELL NO. 4 BUT NOT FOR TWO OTHER**  
15      **WELLS?**

16      A.    Well No. 2 has an auxiliary power supply but does  
17      not have an auto-start feature.  Well No. 3 is a  
18      small pump and is not a lead pump.  We are planning  
19      to add auxiliary power to well no. 3 but it has not  
20      yet been budgeted.

21      **Q.    REGARDING THE LAKESIDE WATER TESTIMONY FROM MS.**  
22      **SANDRA SEQUEIRA, IS A SECOND WELL NEEDED?**

23      A.    No.  We only have 86 connections and less than 350  
24      persons, which makes us exempt from the second well  
25      requirements.  It should be noted that there is an

1 existing second well which is not connected to our  
2 facilities at this time. In the event a second  
3 well is required, SSU will test the second well to  
4 determine if it is viable in the hope that we can  
5 save customers money.

6 **Q. DO YOU AGREE WITH DEP MR. SCOTT A. BREITENSTEIN'S**  
7 **TESTIMONY REGARDING THE NEED FOR AUXILIARY POWER**  
8 **FOR THE LAKE AJAY WATER FACILITY?**

9 A. No. According to SSU's billing records for  
10 February 1996, the Lake Ajay water treatment plant  
11 currently serves 94 connections. According to Rule  
12 62-555.320(6) Florida Administrative Code (F.A.C.),  
13 auxiliary power is not required.

14 **Q. DO YOU AGREE WITH MR. SCOTT A. BREITENSTEIN'S**  
15 **TESTIMONY REGARDING THE NEED TO MONITOR GROUP II**  
16 **VOC'S FOR THE LAKE AJAY WATER FACILITY?**

17 A. No. According to SSU's billing records for  
18 February 1996, the Lake Ajay water treatment plant  
19 currently serves 94 connections -- less than 350  
20 people. SSU currently has a waiver for Group II  
21 VOC's from the DEP in accordance to Rule 62-  
22 550.521(4).

23 **Q. DO YOU AGREE WITH MR. SCOTT A. BREITENSTEIN'S**  
24 **TESTIMONY REGARDING THE STATUS OF THE BACKUP**  
25 **WELL/PLANT FOR THE TROPICAL PARK WATER FACILITY?**

1 A. No. The backup well/plant for the Tropical Park  
2 water system was placed back into service on  
3 January 17, 1996. Consequently, this system is  
4 currently meeting the requirements of Rule 62-  
5 555.315(1).

6 **Q. DO YOU AGREE WITH MR. ROBERTO C. ANSAG'S TESTIMONY**  
7 **REGARDING AUXILIARY POWER FOR THE SILVER LAKE**  
8 **ESTATES/WESTERN SHORES WATER FACILITY?**

9 A. No. Plant improvements, including the installation  
10 of a 250 kw diesel generator, which was permitted  
11 under DEP construction permit no. WC35-266211, were  
12 completed and cleared for use on March 6, 1996.  
13 SSU, therefore, has adequate auxiliary power in the  
14 event of a power outage at this facility.

15 **Q. DO YOU AGREE WITH MR. ROBERTO C. ANSAG'S TESTIMONY**  
16 **REGARDING AUXILIARY POWER AND WELL LOCATION**  
17 **REQUIREMENTS FOR THE HOLIDAY HAVEN WATER FACILITY?**

18 A. No. The Holiday Haven water system is a  
19 consecutive system. The primary water supplier is  
20 Astor-Astor Park Water Company. Consequently, the  
21 auxiliary power requirement does not apply for this  
22 system. The well location requirement also does  
23 not apply for this facility for the same reason.

24 **Q. DO YOU AGREE WITH MR. ROBERTO C. ANSAG'S TESTIMONY**  
25 **REGARDING AUXILIARY POWER AND WELL LOCATION**



1           **REQUIREMENTS FOR THE WESTMONT WATER FACILITY?**

2           A.    No.    The Westmont water facility is a consecutive  
3           water system.    The primary water supplier is the  
4           Orange    County    Public    Utilities    Department.  
5           Consequently, the auxiliary power requirement does  
6           not apply for this facility.    The well location  
7           requirement also does not apply for this facility  
8           for the same reason.

9           **Q.    DO YOU AGREE WITH MR. ROBERTO C. ANSAG'S TESTIMONY**  
10           **REGARDING    AUXILIARY    POWER    AND    WELL    LOCATION**  
11           **REQUIREMENTS FOR THE DAETWYLER SHORES AND THE LAKE**  
12           **CONWAY PARK WATER FACILITIES?**

13          A.    No.    The Daetwyler Shores and the Lake Conway Park  
14          water facilities are consecutive systems.    The  
15          primary water supplier is the Orange County  
16          Utilities Commission.    Consequently, the auxiliary  
17          power requirement does not apply for these  
18          facilities.    The well location requirement also  
19          does not apply for these facilities for the same  
20          reason.

21          **Q.    DO YOU AGREE WITH MR. CLARENCE C. ANDERSON'S**  
22          **TESTIMONY    REGARDING    THE    CHULUOTA    WASTEWATER**  
23          **FACILITY?**

24          A.    No.    A rainfall gauge is located at the Chuluota  
25          wastewater treatment plant site and is read and

1 recorded daily. Approximately 11.43 inches and  
2 10.2 inches of rainfall were recorded for the  
3 months of August and October 1995, respectively.  
4 According to the Monthly Operating Reports, monthly  
5 average daily flows for the months of August and  
6 October 1995 were 0.060 mgd and 0.050 mgd,  
7 respectively. The permitted capacity of the  
8 Chuluota wastewater treatment plant is 0.1 mgd.  
9 Excessive rain contributed to increased flows  
10 during these months, however, the flows did not  
11 exceed plant capacity or cause hydraulic overload.

12 **Q. WHAT IS THE STATUS OF PERMIT NUMBERS 1695-WD-3311**  
13 **AND 1695-WD-3312, FOR THE CORROSION CONTROL SYSTEMS**  
14 **AT BEACON HILLS AND COBBLESTONE, RESPECTIVELY?**

15 A. Both facilities were cleared for use on January 22,  
16 1996.

17 **Q. WERE THE CORROSION CONTROL IMPROVEMENTS CONSTRUCTED**  
18 **WITHIN THE SCHEDULES MANDATED BY FAC 62-551 AND THE**  
19 **SCHEDULES CONTAINED IN THE PERMITS?**

20 A. Yes. FAC Rule 62-551 mandates that corrosion  
21 control treatment be installed for medium systems  
22 within 24 months after the Department approves its  
23 recommended treatment. Corrosion control permits  
24 for Beacon Hills and Cobblestone were issued on  
25 June 30, 1995, with expiration dates of January 1,

1 1997.

2 **Q. WHAT IS THE STATUS OF THE COMPLIANCE LETTER ISSUED**  
3 **APRIL 26, 1995 CONCERNING PUBLIC EDUCATION FOR**  
4 **EXCEEDING LEAD ACTION LEVELS?**

5 A. Public education concerning lead action levels was  
6 conducted May 1, 1995, consistent with the  
7 requirements contained in FAC 62-551.810.

8 **Q. DID THE UTILITY TAKE AN AERATION/GROUND STORAGE**  
9 **TANK OFF LINE IN FEBRUARY, 1993 WITHOUT**  
10 **AUTHORIZATION FROM THE DEP?**

11 A. No. The aerator on the small ground storage tank  
12 was removed from the tank, however, the storage  
13 tank remains in service. The aerator had  
14 deteriorated to an extent that water quality could  
15 have been compromised had it been left in service.  
16 Our records indicate that there was verbal  
17 communication with DEP regarding removal of the  
18 aerator, but there was not subsequent written  
19 follow-up.

20 **Q. DID THE UTILITY HAVE AN ACTIVE CONSTRUCTION PERMIT**  
21 **FROM DEP FOR THE POSTMASTER VILLAGE WATER FACILITY**  
22 **IN 1995?**

23 A. Yes. DEP permit number DS10-271324 for  
24 distribution system improvements was issued May 10,  
25 1995 and cleared for service on November 14, 1995.

1 Q. DOES THE UTILITY HAVE A CROSS-CONNECTION CONTROL  
2 PLAN APPLICABLE TO THE PALM VALLEY WATER FACILITY.

3 A. Yes. The Company's cross-connection control plan  
4 is applicable to all of the company's distribution  
5 facilities, and is on file at each DEP district  
6 office in which SSU owns and operates a water  
7 supply facility.

8 Q. DOES THE UTILITY HAVE A CURRENT CONSTRUCTION PERMIT  
9 FROM DEP FOR THE REMINGTON FOREST WATER FACILITY?

10 A Yes. DEP permit number WC55-279787 was issued  
11 December 28, 1995, and expires December 28, 1997.  
12 The permit is for construction of an additional 4"  
13 well to meet peak water demands and provide  
14 additional system reliability.

15 Q. WHAT IS THE STATUS OF THE GENERAL PERMIT FOR  
16 CORROSION CONTROL ISSUED BY DEP FOR THE PALM PORT  
17 WATER FACILITY?

18 A. Permit Number WC54-263113 for implementing  
19 corrosion control treatment with pH adjustment  
20 (caustic soda addition) was issued January 26, 1995  
21 and expires January 26, 1997. In October, 1995, the  
22 Palm Port facility switched from disinfection with  
23 gaseous chlorine to hypochlorination, which  
24 increased the pH of the finished water. Results of  
25 lead and copper distribution system samples taken

1 after conversion from gas chlorination to  
2 hypochlorination demonstrated lead and copper  
3 levels below the action levels. Consequently, the  
4 permit to install corrosion control treatment has  
5 not been implemented. DEP has been notified that  
6 the permit will not be implemented at this time.  
7 However, lead and copper distribution samples will  
8 continue to be monitored to assure that optimal  
9 treatment is achieved.

10 **Q. WHAT IS THE STATUS OF THE GENERAL PERMIT FOR**  
11 **CORROSION CONTROL ISSUED BY DEP FOR THE RIVER GROVE**  
12 **WATER FACILITY?**

13 A. The River Grove corrosion control permit was issued  
14 for installation of a polyphosphate blend. The  
15 polyphosphate system has been installed and was  
16 certified complete to DEP on January 25, 1996.

17 **Q. WHAT IS THE STATUS OF THE CURRENT CONSTRUCTION**  
18 **PERMIT FOR THE WOOTENS WATER FACILITY?**

19 A. Permit No. WC54-278064 was issued October 5, 1995  
20 for the addition of an aerator and storage tank.  
21 The permit expiration date is October 5, 1997.  
22 Improvements proposed under this permit are  
23 necessary to resolve water quality violations for  
24 turbidity, color, and odor addressed under Consent  
25 Order No. 93-0332. Implementation of the permit has

1           been delayed due to the necessity to acquire  
2           property or easement rights to install the aerator.  
3           The current owner of the property is not amenable  
4           to selling the property or granting an easement for  
5           a reasonable price. The legal costs associated  
6           with exercising the power of eminent domain would  
7           result in unacceptable rates for the customers  
8           under the stand-alone capped rate structure due to  
9           the limited number of customers served by the  
10          Wootens facility.

11       **Q. DO YOU AGREE WITH MR. ALLEN'S TESTIMONY THAT LEAD**  
12       **SAMPLING RESULTS EXCEEDED THE ALLOWABLE LIMITS IN**  
13       **MORE THAN 10% OF RANDOM SAMPLING?**

14       A. No. The lead and copper rule requires the  
15       establishment of a sampling plan approved by DEP,  
16       or in this case, the DHRS since the drinking water  
17       program is delegated in Lee County, which targets  
18       areas in the distribution system which have the  
19       greatest potential for lead and copper  
20       contamination. Sampling within these areas is  
21       random, but sampling is not random within the  
22       entire distribution system. The October, 1995  
23       resampling results to which Mr. Allen refers were  
24       within the allowable limits in more than 90% of the  
25       samples randomly collected in the potentially worst

1 areas within the distribution system.

2 **Q. DO YOU AGREE WITH MR. FAIRCLOTH'S TESTIMONY THAT**  
3 **THE SUGAR MILL COUNTRY CLUB FACILITY DOES NOT MEET**  
4 **THE MAXIMUM CONTAMINANT LEVELS FOR PRIMARY AND**  
5 **SECONDARY WATER QUALITY STANDARDS?**

6 A. No. The trihalomethane standard is not applicable  
7 to the Sugar Mill Country Club facility because it  
8 serves less than 10,000 people. Additionally, lead  
9 concentrations in the finished water produced by  
10 the utility are below the maximum contaminant level  
11 contained in the primary drinking water standards,  
12 FAC 62-550.310. Sampling of water at the  
13 customers' taps, in accordance with the  
14 requirements of the lead and copper rule, FAC 62-  
15 551 did indicate that lead levels exceeded the  
16 action level in that rule. SSU has completed the  
17 required steps for facilities exceeding the action  
18 level in a timely manner in accordance with the  
19 schedule contained in the rule.

20 **Q. IS TREATMENT FOR THE REDUCTION OF HALOGEN FORMATION**  
21 **MANDATED BY RULE, BASED ON THE RESULTS OF CHEMICAL**  
22 **ANALYSES OF RAW AND FINISHED WATER WHEN COMPARED TO**  
23 **REGULATIONS?**

24 A. No, SSU is not required to treat the water to  
25 reduce the level of halogen formation indicated by

1 Mr. Faircloth since the facilities do not serve  
2 more than 10,000 people -- thus, we have not spent  
3 money to treat the water. SSU further believes  
4 that the expenditure of these funds would not be  
5 economical given the unreasonable standard applied  
6 -- a level which would increase the likelihood of  
7 cancer by 1 in 10,000 to a person who drinks 2  
8 liters of water everyday for 70 years from this  
9 supply source. We believe our action in this type  
10 of situation comports with the customer attitude  
11 demonstrated during customer service hearings which  
12 encouraged SSU to restrict the level of investment  
13 made to meet such standards when possible.

14 **Q. DO YOU AGREE WITH MR. FAIRCLOTH'S TESTIMONY THAT**  
15 **THE WATER PRODUCED BY SSU AT DELTONA LAKES DOES NOT**  
16 **MEET THE STATE AND FEDERAL MAXIMUM CONTAMINANT**  
17 **LEVELS FOR PRIMARY AND SECONDARY WATER QUALITY**  
18 **STANDARDS?**

19 A. No. FAC 62-550.325(2) states that "Suppliers of  
20 water may use sequestering agents in lieu of  
21 meeting the maximum contaminant level for iron and  
22 manganese when the maximum iron and manganese  
23 concentration does not exceed 1.0 mg/l. By using  
24 phosphate injection as a sequestering agent, the  
25 water is treated so as to comply with the rule.



- 1       **Q.    DOES THE UTILITY HAVE A CURRENT ACTIVE CONSTRUCTION**  
2       **PERMIT FROM THE DEP SOUTH DISTRICT DRINKING WATER**  
3       **PROGRAM FOR THE BURNT STORE WATER TREATMENT PLANT?**
- 4       A.    Yes.  DEP Permit No. WC08-279073 was issued January  
5       5, 1996 to permit SSU to add an additional 0.240  
6       MGD R.O. skid to the existing facility.
- 7       **Q.    IS THERE A DEVIATION BETWEEN THE RULES FOR DESIGN**  
8       **OF WATER SUPPLY WELLS AND THE ACTUAL DESIGN AND**  
9       **CONSTRUCTION SPECIFICATIONS OF THE WELLS SUPPLYING**  
10       **THE REVERSE OSMOSIS FACILITY ON MARCO ISLAND?**
- 11      A.    No.  Potable water well permitting, along with the  
12      authority to develop rules to implement DEP  
13      requirements into the well permitting procedure,  
14      was delegated by DEP to the South Florida Water  
15      Management District.  Subsequently, the District  
16      delegated well construction permitting authority to  
17      Collier County.  This delegation is authorized  
18      under Section 373.308, Florida Statutes.  Collier  
19      County ordinance contain specifications for  
20      constructing potable water wells in areas subject  
21      to flooding.  The ordinance is consistent with  
22      Florida Statutes, concerning the protection of  
23      drinking water supplies.  Section 373.326, F.S.  
24      contains provisions to grant exemptions in cases  
25      where rule requirements would create undue hardship

1 to the applicant. The County Ordinance affords  
2 protection to the water supply by specifying  
3 additional construction techniques in areas subject  
4 to flooding. Design and construction of the wells  
5 on Marco Island is consistent with the requirements  
6 contained in the Collier County Ordinance, which is  
7 the proper authority for permitting potable water  
8 well construction on Marco Island.

9 **Q. HAS SSU ADDRESSED THE CONCERNS REPORTED BY DEP IN**  
10 **THE MOST RECENT SANITARY SURVEY CONDUCTED AT THE**  
11 **MARCO ISLAND WATER TREATMENT FACILITY?**

12 A. At the reverse osmosis plant, operations personnel  
13 have verified that the storage tank vents are  
14 properly screened and sealed to prevent  
15 contamination. A finer screen has been installed  
16 on the degassifier blower motor to prevent the  
17 entrance of insects, and hose bibb vacuum breakers  
18 have been installed to prevent backflow  
19 contamination of the water supply. The leaking  
20 sample taps have been replaced, and painting of the  
21 sulfuric acid room is scheduled to be completed  
22 this year.

23 For the lime softening plant, the alarm system  
24 requested by DEP for loss of chlorine capacity was  
25 installed at the time of the inspection, but was

1 out of service for repairs. The alarm system is  
2 back in service at this time. The operator assured  
3 that all storage tank vents were properly screened  
4 and sealed to prevent contamination, and repaired  
5 the access hatchway to the clearwell to assure that  
6 it is watertight. The storage tanks were inspected  
7 by the operations staff and were found to have all  
8 access points watertight. A predictive maintenance  
9 program is being implemented this year which will  
10 address the recommendations to continually paint  
11 and clean sections of the water treatment facility  
12 as needed. This program will also incorporate a  
13 finished water storage tank inspection and cleaning  
14 schedule. The operator also verified that there is  
15 adequate backflow protection between the wastewater  
16 treatment facility and the water treatment  
17 facility.

18 SSU does not currently have funds available to  
19 complete the improvements to the chlorine gas  
20 facilities in the 1996 budget year. The existing  
21 chlorine feed facilities at the lime softening  
22 plant were constructed over twenty years ago, prior  
23 to the requirement for a separate enclosed room,  
24 and were constructed in accordance with  
25 requirements in effect at that time. Available

1 funding has been allocated to complete improvements  
2 to the R.O. plant and raw water supply to assure  
3 adequate water supply and safe pressures are  
4 available to the service area.

5 **Q. HAS SSU ADDRESSED THE CONCERNS REPORTED BY DEP IN**  
6 **THE APRIL 13, 1995 SANITARY SURVEY CONDUCTED AT THE**  
7 **MARCO SHORES WATER TREATMENT FACILITY?**

8 A. Yes. The operations staff has ensured that vents  
9 on storage tanks are completely screened. Adequate  
10 backflow prevention devices have been installed on  
11 all hose bibbs. The Company's predictive  
12 maintenance program currently being implemented  
13 addresses periodic storage tank inspection and  
14 cleaning, and painting and cleaning of the water  
15 treatment plant area as needed.

16 **Q. WHAT IS THE CAPACITY STATUS OF THE AMELIA ISLAND**  
17 **WASTEWATER TREATMENT FACILITY?**

18 A. Capacity of the facility has been increased from  
19 0.850 MGD to 0.950 MGD under DEP Permit No.  
20 DC45260421, which was certified complete as of  
21 December 8, 1995. The highest three-month average  
22 daily flow for the facility in 1995 was 0.852 MGD,  
23 which is approximately 90% of the rated capacity of  
24 the facility. The annual average daily flow for  
25 1995 was 0.701 MGD, which is about 74% of the rated

1 capacity of the facility. Projections contained in  
2 the most recent Capacity Analysis Report dated  
3 March, 1994 indicate that the current capacity will  
4 be sufficient until 1999, at which time additional  
5 improvements will be required. Funds have been  
6 budgeted for engineering and commencement of  
7 construction in 1998, with the remaining funds  
8 budgeted to complete construction in 1999.

9 **Q. DID SSU ADDRESS INFILTRATION/INFLOW (I/I) IN THEIR**  
10 **MOST RECENT CAPACITY ANALYSIS REPORT FOR THE AMELIA**  
11 **ISLAND WASTEWATER FACILITY?**

12 A. No. The DEP Guidelines for Preparation of Capacity  
13 Analysis Reports, July, 1992, do not require that  
14 I/I be evaluated. The Guidelines do require an  
15 evaluation of seasonal variations in flow, which  
16 was included in the March, 1994 Capacity Analysis  
17 Report Update. Flow records show consistent peaks  
18 in the summer months of August and September.  
19 There is typically strong tourist activity during  
20 these months since the service area is a resort  
21 community. The Operation and Maintenance  
22 Performance Report completed in December, 1992  
23 stated that although there is no evidence of I/I,  
24 that a preliminary I/I study be conducted. A  
25 preliminary study based on approved USEPA

1 methodology was completed in 1995, which concluded  
2 that I/I in the Amelia Island collection system is  
3 marginally excessive, based on typical per capita  
4 wastewater generation. A more detailed assessment  
5 of the system including televising the lines will  
6 be conducted in 1996 to identify specific areas  
7 potentially for corrective action, if feasible from  
8 a cost/benefit perspective.

9 **Q. HOW DOES SSU DETERMINE THE AMOUNT OF FLOW FROM THE**  
10 **WOODMERE WASTEWATER SERVICE AREA TO THE UNITED**  
11 **WATER FLORIDA'S MONTEREY WASTEWATER TREATMENT**  
12 **FACILITY?**

13 A. Flow to the Monterey facility is collected in the  
14 southwest portion of the Woodmere service area, and  
15 flows by gravity to what is referred to by the  
16 operators as the "golf course lift station." This  
17 portion of the service area is not connected to the  
18 remainder of the Woodmere collection system. Flow  
19 is estimated based on lift station pump run times  
20 and pumping capacity. Flow data was forwarded to  
21 the DEP in November, 1995 as part of the wastewater  
22 facility permit application. Flow in this area  
23 averages about 35,000 gallons per day.

24 **Q. DO YOU AGREE WITH MS. RODRIGUEZ' TESTIMONY THAT THE**  
25 **WOODMERE WASTEWATER TREATMENT FACILITY NEEDS AN**

1           **OVERHAUL OR REPLACEMENT?**

2       A.     Yes.     Design of a replacement facility was  
3           completed in December, 1995 and submitted to DEP in  
4           February, 1996, along with additional support  
5           documentation, including a Reuse Feasibility Study.  
6           Construction of a replacement facility is budgeted  
7           to begin in the fourth quarter of 1996, and to be  
8           completed in 1997.     The replacement facility  
9           considers continuation of the existing surface  
10          water discharge since the reuse alternatives are  
11          estimated to cost the individual customers an  
12          additional \$100 per year above the surface water  
13          discharge alternative.

14       **Q.     WHAT IS THE STATUS OF THE EFFLUENT DISPOSAL ISSUE**  
15       **AT THE BEECHER'S POINT WASTEWATER FACILITY?**

16       A.     SSU completed a report which evaluates land  
17          application alternatives for the Beecher's Point  
18          facility.     Technologically feasible alternatives  
19          were identified, however, with stand-alone capped  
20          rates in place, the improvements were determined to  
21          be economically infeasible to construct.

22       **Q.     WHAT IS THE STATUS OF SSU'S PERMIT MODIFICATION TO**  
23       **ADD A DIGESTER AT BEECHER'S POINT?**

24       A.     As SSU engineer Steve Bailey will testify, the  
25          digester has been installed, and certification of

1 completion by DEP is pending.

2 **Q. WHAT IS THE STATUS OF SSU'S PERMIT MODIFICATION TO**  
3 **ADD A DIGESTER AT PARK MANOR?**

4 A. The digester addition was not implemented due to  
5 inability to access the proposed digester location.  
6 In order to install the digester, the contractor  
7 would have had to traverse private property to  
8 place the tank in the desired location. The  
9 property owner was not amenable to allowing a  
10 temporary access easement at a reasonable cost.  
11 Therefore, the digester was not installed.  
12 Residuals are currently hauled and treated by a  
13 contract hauler prior to land application. SSU  
14 continues to seek an economical alternative but we  
15 cannot resolve the problem by paying what the  
16 property owner expected. There is no danger to the  
17 environment from our current resolution. SSU  
18 should not be penalized for refusing to accept the  
19 just alternative available to save customers' money  
20 in the long term.

21 **Q. WHAT IS THE STATUS OF THE EFFLUENT DISPOSAL ISSUE**  
22 **AT THE PALM PORT WASTEWATER FACILITY?**

23 A. SSU completed a report which evaluates land  
24 application alternatives for the Palm Port  
25 facility. Technologically feasible alternatives



1 were identified, however, with stand-alone capped  
2 rates in place, the improvements were determined to  
3 be economically infeasible to construct.

4 **Q. WHAT IS THE STATUS OF THE TEMPORARY OPERATING**  
5 **PERMIT FOR THE FISHERMAN'S HAVEN WASTEWATER**  
6 **TREATMENT FACILITY?**

7 A. Temporary Operating Permit No. DT43-236192 was  
8 modified and assigned a new permit number, DT43-  
9 269020 on November 6, 1995. The modification  
10 included a revised schedule for construction of a  
11 sludge holding tank to be completed by August 15,  
12 1996. Construction of the sludge holding tank was  
13 substantially complete as of December 21, 1995.  
14 Certification to DEP is pending.

15 **Q. WHAT IS THE STATUS OF THE MAINTENANCE ITEMS**  
16 **IDENTIFIED BY MR. THEIL REGARDING THE FISHERMAN'S**  
17 **HAVEN WASTEWATER TREATMENT FACILITY?**

18 A. The ventilator fan in the chlorine cylinder  
19 enclosure has been replaced. The loose filter  
20 dosing pump float switch electrical box has been  
21 secured. All of the blower manifold piping was  
22 replaced concurrent with the installation of the  
23 sludge holding tank. The seam between the filter  
24 dosing tank and lid has been grouted to eliminate  
25 leakage. The filters were returned to service

1           shortly after the referenced storm, as soon as the  
2           media was cleaned.

3           **Q.   REFERRING TO THE LEILANI HEIGHTS WASTEWATER**  
4           **TREATMENT FACILITY, WHAT IS THE STATUS OF THE**  
5           **RECOMMENDED COLLECTION SYSTEM IMPROVEMENTS**  
6           **ADDRESSED IN THE BOYD ENVIRONMENTAL ENGINEERING**  
7           **REPORT DATED JUNE, 1995?**

8           A.   Repairs to the collection system where problems  
9           were noted have been completed.   Additional  
10           investigations, including televising lines will be  
11           conducted this year, with corrective action to  
12           follow this year or next, depending on the  
13           magnitude of repairs indicated and the cost/benefit  
14           determination.

15           **Q.   WHAT ACTIVITIES HAS SSU UNDERTAKEN TO RESOLVE**  
16           **NONCOMPLIANCE ISSUES AT THE ENTERPRISE WASTEWATER**  
17           **FACILITY?**

18           A.   SSU periodically cleans and mows vegetation from  
19           the percolation pond and sprayfield.   The most  
20           significant problem associated with the facility  
21           involves inadequate sprayfield capacity.  
22           Evaluations of capacity of the existing sprayfield  
23           and potential alternate sites on the island  
24           indicate that no additional reliable effluent  
25           disposal capacity is available on the island.   The

1 most feasible technological solution is to abandon  
2 the facility and connect the collection system to  
3 the Deltona Lakes facility.

4 SSU has prepared preliminary design plans and  
5 cost estimates to implement the only reasonable  
6 technical solution. However, with a stand-alone  
7 capped rate structure, the necessary improvements  
8 are economically not feasible to implement.

9 **Q. WHAT IS THE STATUS OF THE UNAUTHORIZED DISCHARGE TO**  
10 **SURFACE WATERS FROM THE DELTONA LAKES WASTEWATER**  
11 **FACILITY?**

12 A. Discharges to surface waters occurred during  
13 extended wet weather periods in 1994 and early  
14 1995. SSU had permitted effluent disposal (reuse)  
15 capacity sufficient to meet effluent disposal needs  
16 during normal weather conditions. Also, SSU had  
17 permitted wet weather storage capacity at the Glen  
18 Abbey Golf Course. Subsequent to extended wet  
19 weather conditions experienced in 1993 and 1994,  
20 the capacity of the storage facility was no longer  
21 available for effluent storage due to stormwater  
22 contributions from adjacent development. SSU also  
23 had construction permits for construction of  
24 additional storage ponds at the Deltona Hills Golf  
25 Course, and additional effluent disposal capacity

1 at the drainfield on the Florida Power and Light  
2 (FP&L) easement. Prior to the discharge to surface  
3 waters, these permits were not implemented because  
4 adequate effluent disposal and storage capacity had  
5 always been available in previous years. These  
6 permitted sites were planned to handle future  
7 expansion of the wastewater treatment facility.

8 After several months of extremely rainy  
9 conditions, and the resulting multiple surface  
10 water discharges, the decision was made to  
11 implement effluent disposal at the drainfield on  
12 the FP&L easement, and to attempt to increase the  
13 rated capacity based on operational experience with  
14 the facility after construction. Construction of  
15 the FP&L easement was completed on July 1, 1995.  
16 No discharges to surface waters have occurred since  
17 that time.

18 Concurrent with the decision to construct the  
19 FP&L drainfield, SSU also decided to apply for a  
20 limited wet weather discharge permit to provide  
21 additional reliability in the effluent disposal  
22 system. The limited wet weather discharge permit  
23 application was submitted on March 20, 1995. The  
24 application is pending additional hydrologic  
25 information needed to clearly define the

1           circumstances under which a discharge might occur,  
2           and a limited analysis of water quality based  
3           effluent limitations.

4           **Q.   WHAT IS THE NATURE OF THE ENFORCEMENT ACTION FROM**  
5           **DEP   CONCERNING   COMPLETION   OF   CONSTRUCTION   OF**  
6           **PERMITTED DISPOSAL AREAS?**

7           A.   SSU applied for and was issued permits for  
8           construction of additional areas to prepare for  
9           expanded effluent disposal capacity for the  
10          facility. With the Deltona Hills golf course, and  
11          the Glen Abbey golf course reuse sites and the  
12          permitted storage capacity at the Glen Abbey golf  
13          course, it did not appear prudent at the time to  
14          construct additional effluent disposal sites.  
15          After two consecutive seasons of extraordinarily  
16          wet weather, the necessity to construct additional  
17          sites was obvious. Construction of the FP&L  
18          easement drainfield was complete by July 1, 1995,  
19          and is currently being evaluated to define its  
20          actual capacity. Construction of additional  
21          storage ponds on the Deltona Hills golf course has  
22          been determined to be infeasible due to the current  
23          philosophy of the golf course management. They have  
24          communicated to us that they are not interested in  
25          altering the architecture of the golf course to

1 include additional ponds. Additionally, further  
2 review of the proposed golf course storage pond  
3 system indicates that the system would not provide  
4 the desired reliability during wet weather  
5 conditions.

6 Alternate effluent disposal sites that have  
7 been identified as required by the consent order  
8 include expanding the FP&L easement drainfield to  
9 the east if the current evaluation demonstrates the  
10 need to construct additional capacity.

11 **Q. DO YOU AGREE WITH MR. BARIENBROCK'S TESTIMONY THAT**  
12 **THE BURNT STORE WASTEWATER TREATMENT FACILITY IS**  
13 **CURRENTLY OPERATING UNDER PERMIT NO. D008-168047,**  
14 **WHICH WAS ISSUED ON APRIL 11, 1990, WITH AN**  
15 **EXPIRATION DATE OF APRIL 4, 1995?**

16 A. No. The facility is operating under Wastewater  
17 Facility Permit No. FLA014083-267014, issued  
18 January 3, 1996.

19 **Q. ARE YOU AWARE OF NEGATIVE COMMENTS FROM CUSTOMERS**  
20 **REGARDING WATER SERVICE FROM THE BEACON HILLS**  
21 **FACILITIES?**

22 A. Yes. SSU recognizes that the customers may be  
23 frustrated at times in this area due to water  
24 quality issues. But it should be understood that  
25 the water source in the entire Arlington area is

1 naturally high in sulfur. Water that is high in  
2 sulfur has strong odor and poor taste. Sulfur is  
3 treated by aeration and chlorination. Chlorination  
4 is also used for disinfection. SSU has recently  
5 completed improvements to the aeration, storage,  
6 and chlorination facilities at the Beacon Hills  
7 plant, and is in the process of installing  
8 chlorination improvements at the Cobblestone plant.  
9 Additional aeration and storage capabilities are  
10 proposed for Cobblestone in 1997. These  
11 improvements will allow chlorine to be fed  
12 automatically, paced evenly with the demand, to  
13 allow a more consistent chlorine residual. In the  
14 past, complaints related to high chlorine taste or  
15 odor resulted from manually fed chlorine, which was  
16 often set high to match high demands, then as the  
17 demand reduced during off-peak hours, chlorine  
18 residuals were excessive. Additionally, we are  
19 required to maintain a minimum free chlorine  
20 residual of 0.2 mg/l in the distribution system to  
21 assure adequate disinfection. With manually fed  
22 chlorine, it is difficult to maintain an even  
23 residual concentration as demand fluctuates during  
24 the day. To consistently maintain a minimum  
25 chlorine residual in the distribution system,

1 chlorine is manually set to accommodate higher  
2 demands.

3 As the Commission is probably aware, in 1993,  
4 the EPA established maximum contaminant levels for  
5 lead and copper at the customer's tap. The lead  
6 and copper rule, as implemented by the DEP in FAC  
7 62-551 became effective January 1, 1993. Prior to  
8 that time, standards for lead and copper in  
9 drinking water were contained in the National  
10 Primary and Secondary Drinking Water Standards set  
11 forth in FAC 62-550.310 and 62-550.320 and were  
12 applied to water entering the finished water  
13 distribution system. The current rule applies to  
14 water quality at the customer's tap after having  
15 remained stagnant for at least six hours in the  
16 customer's plumbing. Water quality characteristics  
17 can change over time and through contact with  
18 corrosive materials. The rule requires that public  
19 water suppliers optimize treatment techniques to  
20 minimize the potential for lead and copper to leach  
21 from plumbing fixtures and concentrate in the  
22 drinking water.

23 Prior to implementation of the lead and copper  
24 rule, the quality of water supplied by SSU was  
25 consistent with the National Primary and Secondary



1 Drinking Water Standards. SSU has collected  
2 samples in compliance with the lead and copper rule  
3 and reported results to the Duval County Public  
4 Health Unit, which has been delegated authority for  
5 the drinking water program in Duval County by DEP.  
6 SSU has applied for and received permits for  
7 implementing corrective measures, and we have  
8 installed equipment to optimize treatment for the  
9 Beacon Hills/Cobblestone water treatment  
10 facilities. In accordance with the regulatory  
11 requirement in FAC 62-551.530(4), optimal treatment  
12 must be demonstrated within 36 months after  
13 installation of corrosion control treatment. SSU  
14 remains in compliance with these time frames. It  
15 would be wrong for SSU to be penalized for not  
16 complying with the rule sooner since it is apparent  
17 from the rule that the EPA recognized early on that  
18 it would take some time and money to achieve  
19 compliance and thus wrote an extended compliance  
20 period into the rule.

21 **Q. DO YOU HAVE ANY COMMENTS REGARDING THE PROBLEMS**  
22 **BEACON HILLS CUSTOMERS HAVE WITH CORRODING PIPES?**

23 A. Yes. As several customers indicated at the  
24 customer service hearing on September 20, 1995, the  
25 corrosion problems relates primarily to the

1 proliferation of the copper plumbing in  
2 Jacksonville area homes which reacts with the water  
3 native to the region. As customer Sandi Hubbard  
4 noted, the City of Jacksonville is in the process  
5 of revising the building code to "eliminate copper  
6 from Jacksonville." As witness Mazer indicated,  
7 SSU bears little blame for the fact that builders  
8 have installed and apparently continue to install  
9 copper plumbing, valves or fixtures in their homes.

10 **Q. A CUSTOMER SERVED BY THE ZEPHYR SHORES WATER**  
11 **FACILITIES COMPLAINED TO THE COMMISSION THAT A PUMP**  
12 **HAD FALLEN INTO A WELL AT ZEPHYR SHORES AND SSU HAD**  
13 **NOT REMOVED IT. SHOULD ZEPHYR SHORES' CUSTOMERS BE**  
14 **CONCERNED ABOUT WATER CONTAMINATION FROM THE PUMP?**

15 A. No. SSU continues to monitor water obtained from  
16 the well. This water has continued to meet all  
17 standards despite the pump having fallen in without  
18 any additional treatment being required. Thus,  
19 there is no benefit to customers for SSU to incur  
20 the cost to remove the pump.

21 **Q. DOES THAT CONCLUDE YOUR REBUTTAL TESTIMONY?**

22 A. Yes, it does.

1 BY MR. FEIL:

2 Q And, Mr. Terrero, did you also have attached to  
3 your prefiled rebuttal some exhibits numbered RAT-3 through  
4 RAT-14?

5 A Yes, sir.

6 MR. FEIL: Commissioner Deason, I ask that RAT-3  
7 through RAT-14 receive the next exhibit number for  
8 identification.

9 COMMISSIONER DEASON: Yes. It will be Composite  
10 Exhibit 222.

11 (Composite Exhibit Number 222 marked for  
12 identification.)

13 MR. FEIL: Thank you, Commissioner, and I tender  
14 the witness for cross.

15 COMMISSIONER DEASON: Public Counsel.

16 CROSS EXAMINATION

17 BY MR. RILEY:

18 Q Good afternoon, Mr. Terrero.

19 A Good afternoon.

20 Q On Pages 3 and 4 of your rebuttal testimony you  
21 talk about the 212-acre site for the aquifer storage and  
22 recovery facility. And on those pages you make reference to  
23 your Exhibit RAT-3, which I believe is a one-page map that I  
24 guess is your first exhibit attached to the rebuttal  
25 testimony, is that correct?

1 A That's correct.

2 Q Could I have you refer to that map, and I just  
3 need to ask you a few questions so I could better understand  
4 it.

5 A Okay.

6 Q And on this map there is delineated two shaded  
7 areas, could you explain to me what those shaded areas  
8 represent?

9 A Those two shaded areas are the existing surface  
10 area of the lakes where we withdraw water.

11 Q And those lakes -- I mean, they just seem so --  
12 they didn't seem like natural shapes of lakes, and that was  
13 going to be one of my follow-up questions, but the lakes  
14 really have that shape?

15 A They do have that shape.

16 Q Are they man-made lakes?

17 A Yes, they are.

18 Q Okay. Can you delineate on this map where the  
19 boundary of the 212 acres falls? I see here the proposed  
20 ASR well, so I'm assuming that that point there is in the  
21 212 acres, is that correct?

22 A That's correct.

23 Q And this map doesn't really describe where the 212  
24 acres is, is there a way that you can describe it verbally,  
25 the approximate location of the -- is that the center of the

1 212 acres or where does that well lie on the 212 acres?

2 A That is the southeast corner of the -- in the  
3 southeast corner of the 212 acres. I have a map that shows  
4 approximately the boundaries of the 212 acres.

5 Q Now, the 212 acres includes both of the man-made  
6 lakes?

7 A Yes, it does.

8 Q And may I assume, if I'm reading this map, that  
9 north is to the -- east would be to the right of the  
10 proposed well site?

11 A That's correct. North is straight up.

12 Q Now, to get some idea of scale, for instance,  
13 Section 35, does that represent a square mile?

14 A It's supposed to.

15 Q And that equates with 640 acres?

16 A Roughly, yes, sir.

17 Q So this 212-acre site represents about one-third  
18 approximately of what would be the area of a section, let's  
19 say Section 35, is that correct? I'm just getting -- so how  
20 is it that this is in the southeast corner? I'm trying to  
21 visualize.

22 A What do you mean by that?

23 Q So the well is -- the property basically goes up  
24 to the north of this well site?

25 A That's correct.

1 Q And to the west?

2 A Yes.

3 Q Okay. Can you tell me where the 160-acre raw  
4 water site is located with reference to this 212-acre site?

5 A You don't see the 160 acres in this map.

6 Q And yet it is located in Section 35?

7 A No. It's located in Section 35, but it's in  
8 another township.

9 Q Oh, it's in a completely different township?

10 A It's in the same county, it's just about five  
11 miles to the east.

12 Q Okay. And yet this is one of the arguments for  
13 the 212-acre site is its proximity to the 160 acres?

14 A Could you clarify that for me, please.

15 Q I thought I read in your testimony that one of the  
16 positive aspects of this location was its proximity to the  
17 160-acre site, and when I kept hearing references to Section  
18 35, I just began to assume that it was quite close.

19 A No. The Section 35 where the 160 acres is located  
20 is about five miles, but if you have a pipeline we could  
21 pump to this site here with no problem.

22 Q There is a reference here to -- Henderson Creek is  
23 on this map, and can you tell me which direction the water  
24 flows?

25 A South.

1 Q Okay. And there is also on this map a Henderson  
2 Creek weir. Who owns this weir?

3 A The county.

4 Q And what is its purpose?

5 A The purpose is to make sure that the salt water  
6 doesn't go into the area behind it. It's a salt water  
7 barrier.

8 Q Henderson Creek, then, flows into salt water?

9 A It goes into Rookery Bay, yes.

10 Q And that is as it continues to progress in a  
11 southerly direction?

12 A That's correct.

13 Q Okay. Moving back to your testimony on Page 4,  
14 Lines 12 through 17, you say that the strategic placement of  
15 this site is evidenced by the fact that the Henderson Creek  
16 passes the site and water from the creek will recharge the  
17 source of the water and enable you to use excess water to be  
18 stored in the ASR facility, is that correct?

19 A That's correct.

20 Q Could you explain to me how the Henderson Creek  
21 recharges this area, the ASR facility?

22 A Okay. Henderson Creek doesn't do all the  
23 recharging in the area. Henderson Creek actually provides  
24 some recharge to where the lakes are at, and the area that  
25 we have of the 212 acres. Depending on the height of that

1 creek depends on how much water we can withdraw from there.

2 Q So the water that's flowing in the creek  
3 physically is connected to the man-made lake?

4 A No, it's not.

5 Q And it helps fill up that lake? It appears from  
6 this map, and I'm going back -- I'm still referring to RAT-3  
7 -- it seems that Henderson Creek is right next to the  
8 boomerang shaped lake, is that correct?

9 A It is adjacent to, but it's not connected.

10 Q It is not connected.

11 A Adjacent to, but not connected.

12 Q Okay. So my question is, physically what is the  
13 hydraulics, what is the process that allows the water from  
14 Henderson Creek to make its way either into the lakes and/or  
15 ultimately into the ASR facility?

16 A Well, what would happen is you have a  
17 transmissivity (phonetic) from the Henderson Creek that will  
18 recharge the lakes at a faster rate due to the height  
19 elevation on the creek. So if the creek is dry it won't  
20 recharge as much, but if the creek is running and running  
21 over the dam, of course, you can pull more water out of  
22 there.

23 Q So it has to overflow the bank between the lake  
24 and --

25 A I didn't say that. Overflow over the dam that you



1 saw there in that little drawing where it says Henderson  
2 Creek weir.

3 Q Right.

4 A So we will build a head there and then we will  
5 recharge our lakes.

6 Q And does it just go through the ground, the soil?

7 A Yes, through the ground. Like a filter, yes.

8 Q Okay. So this is a natural process, it's not  
9 something that you can turn on and turn off. Man can't  
10 interrupt that recharge process?

11 A That's correct. The purpose of the ASR is  
12 actually to get the excess water from probably July through  
13 September when there is heavy rains and you have excess  
14 water flowing down the creek.

15 Q Okay. And now if I could just have you briefly go  
16 back to Page 2 of your testimony, and it's on Lines 17  
17 through 19. You make another statement basically justifying  
18 the need for the full 212 acres for this ASR facility, and  
19 it says another reason the adjacent area was acquired was to  
20 protect the water source from potential pollution sources.  
21 Now, my first question is this term adjacent area, is this  
22 the area adjacent to the well site itself, and this is a  
23 justification for the full 212 acres?

24 A No, the area that we are talking about is the area  
25 adjacent to the lakes, which is the recharge area to the

1 lakes, a portion of the recharge area to the lakes and that  
2 is what we are talking about is all that area there.

3 Q Meaning the adjacent area is the 212 acres that  
4 you wanted to put in rate base?

5 A That's correct.

6 Q Excuse me?

7 A Excuse me. The 212 acres includes the lakes,  
8 right.

9 Q And the land around the lakes and the well site?

10 A That's correct.

11 Q But you need this much acreage because you need to  
12 protect the ASR storage facility from pollution sources?

13 A No. What you need to protect is the surface water  
14 that you have in there, the lakes, from pollution sources.

15 Q And how do you do that by having the acreage  
16 around the lakes?

17 A Well, what you do is you have area around it and  
18 you have a time interval by where if you have a spillage on  
19 the highway it will take some time to get to our lakes. So  
20 actually I have run a model, which I have as an exhibit here  
21 if you want it, by where we show that if you have a spillage  
22 on the highway it will take 365 days to get into our water  
23 supply. In that period of time we should be able to remedy  
24 that.

25 Q I guess that where I'm headed with this line of

1 questioning is that you are touting the benefits of the  
2 Henderson Creek in providing extra water to -- quantities of  
3 water for your ASR facility, and yet at the same time  
4 expressing concern about polluting the ASR water source by  
5 potential pollution. I'm wondering if this Henderson Creek  
6 could not, in fact, become the source of pollution to this  
7 ASR. What is a benefit of recharging could, in fact, become  
8 a problem by the creek bringing to the ASR facility  
9 pollution upstream. If, in fact, there is through natural  
10 processes water coming from Henderson Creek into this  
11 212-acre site in the ASR facility, I can see where that is  
12 beneficial up to the point until the land that is connected  
13 to the Henderson Creek could, in fact, bring pollution by  
14 way of the creek into the ASR. Have you considered, or did  
15 SSU consider how the Henderson Creek could counteract what  
16 you think you're accomplishing here by buying up additional  
17 acreage around these lakes?

18 A Like I said before, the reason for buying the  
19 additional area that we have there is to protect the area.  
20 As a matter of fact, you know, if you look at it, we had not  
21 only the 212 acres, we have 1,620 acres on a lease and we  
22 never got adjusted for any used and useful. 1,620 acres.  
23 So we actually have gone back and retracted to 212 acres to  
24 protect the source. If you go to any source protection, if  
25 you are familiar with any source protection you know that

1 you have to have some areas adjacent, that you have to  
2 protect your source. If you take like 500 feet around that  
3 perimeter probably it will take you all the way to the edge  
4 of the property.

5 Q If you're recharging the ASR facility with local  
6 rain water collecting on the 212 acres, you know, I can see  
7 that you could gain some degree of control over pollution  
8 sources on that water coming into the ASR facility. But if  
9 your facility is designed to receive water from Henderson  
10 Creek that's coming from great distances away, isn't there a  
11 considerable risk of polluting your entire ASR facility with  
12 pollution that could be caused along Henderson Creek?

13 A The DEP and the EPA have reviewed this application  
14 and they have agreed to allow us to be build the ASR  
15 facilities there. They are sure that the way we have our  
16 facilities there and the way we are protecting our  
17 facilities is sufficient to allow us to build this ASR with  
18 no problem.

19 Q Now, was that a yes or a no to my question?

20 A Will you repeat your question again.

21 Q That's a familiar strategy. The question was  
22 don't you run the risk of locating this facility as you have  
23 next to Henderson Creek, which has through natural processes  
24 being recharged by Henderson Creek, don't you open yourself  
25 up to subjecting the ASR facility to any pollution sources

1 that could be put into Henderson Creek?

2 A No. We have been there for 30-something years,  
3 and we never had that problem, so I don't feel that we will  
4 have that problem now.

5 Q Now, however, it is true that any pollution that  
6 makes its way into Henderson Creek through what your earlier  
7 answers to my questions were could, in fact, make their way  
8 into your ASR facility, is that true or not?

9 A It might be true. What kind of pollutants are you  
10 talking about?

11 Q Any pollution that could make its way into a creek  
12 that goes by hundreds and hundreds and hundreds of acres  
13 upstream.

14 A If you look at the way we are going to do it, we  
15 are going to be -- we are not going to take the water direct  
16 from the creek, we are going to go through the lakes which  
17 will be like another natural filter. Before we go to the  
18 ASR, we are going to also chlorinate.

19 Q Okay. Let's move on to Page 7 of your rebuttal  
20 testimony, and here you're critiquing some comments that  
21 Mr. Biddy made of the Marion Oaks wastewater treatment  
22 plant.

23 A Correct.

24 Q And I think to characterize Mr. Biddy's comments,  
25 I think he used that particular small wastewater treatment

1 plant to show the benefits of phased development, phased  
2 additions to a plant to accommodate growth. And I believe  
3 here in this Page 7 you are criticizing his testimony, is  
4 that correct?

5 A That's correct.

6 Q And you suggest, in fact, that Marion Oaks is a  
7 good example -- in fact, right around Lines 15 through 20  
8 you say this is really a very good example, your exact  
9 words, "Provides compelling confirmation of the tremendous  
10 need for economies of scale." And further down it shows the  
11 need for the margin reserve period, is that correct?

12 A What I said here is Mr. Bidy's acknowledgement  
13 that this a prudent way to expand a plant provides  
14 compelling confirmation of the tremendous need for economies  
15 of scale.

16 Q So you believe that Marion Oaks, contrary to what  
17 Mr. Bidy suggested it meant to him, is that the Marion Oaks  
18 example shows a compelling confirmation for the need for  
19 economies of scale, is that correct?

20 A I would say the way he addressed his comments is  
21 that this is the way that a wastewater treatment plant  
22 should be designed and built for existing customers or  
23 future customers. I think that what he is addressing is  
24 that the phasing was right and the economies of scale are  
25 there.

1 Q What is the current capacity of the plant at  
2 Marion Oaks, is it 200,000 gallons a day?

3 A Yes, it is.

4 Q And when did the Marion Oaks plant first begin  
5 operation?

6 A In the early '70s.

7 Q Early '70s?

8 A I would say.

9 Q And according to the SSU information that we have  
10 gotten, it's going to be seven more years before it is  
11 projected to be increased to 275,000 gallons a day, is that  
12 correct?

13 A That's what the report said.

14 Q And according to your testimony here on Page 7,  
15 it's going to be another 16 years for it to be expanded from  
16 275,000 to 350,000 gallons a day, is that correct?

17 A That's correct.

18 Q And 31 years to be further expanded from 350,000  
19 to 500,000 gallons, and another 35 years to expand it from  
20 half a million to a million gallons a day, is that the  
21 projection?

22 A Right. I'm not promoting that we build a plant  
23 for 35 years, what I was saying here is that Mr. Biddy  
24 agreed with the thought of having phased construction  
25 instead of having an increment of 30,000 gallons every 18

1 months. I think 18 months margin reserve doesn't give us  
2 enough time to do any planning whatsoever, even to get  
3 permits. And it will be a complete cycle. It will be  
4 construction, planning, construction again. It won't stop.

5 Q Thank you for that testimony. If I could just get  
6 you to maybe answer my direct questions.

7 A I thought I did.

8 Q Okay. What is the depreciable life of a  
9 wastewater treatment plant like Marion Oaks?

10 A I'm not an accountant.

11 Q But as an engineer -- forget the accounting  
12 depreciation, what is the real life, depreciable life of a  
13 facility like this?

14 A 20 or 30 years.

15 Q So, basically isn't it correct that before the  
16 plant would ever reach a million gallons a day, this plant  
17 would virtually have to be built or rebuilt two or three  
18 times?

19 A That might be the case.

20 Q And doesn't this frankly give a pretty good  
21 example about the hazards of economies of scale, that you  
22 really have to have the growth to really support those  
23 economies? The fact that if the customers do not come you  
24 could be literally rebuilding plants --

25 A I agree with you on that, and that is why I am



1 opposed so much to the lot count method, because you are  
2 relying on the growth there that might never take place.

3 Q Hear on this Page 7, you also say that this is a  
4 good example for the need for a margin of reserve. I'm  
5 curious in this particular real-life fact situation, what do  
6 you see as the approach margin reserve that these people  
7 should have to pay?

8 A The margin reserve that we apply is five years on  
9 wastewater and three years for water.

10 Q And that is what you would recommend for this  
11 situation?

12 A I would recommend ten years on the wastewater.

13 Q Excuse me?

14 A I would recommend ten years on wastewater if you  
15 put it up to me. But actually we went with five years and  
16 that is what we are going for.

17 Q On Page 8 of this rebuttal testimony you talk  
18 about -- I think we are looking at Lines 3 through 9, that  
19 we have done master planning under the current rules, but  
20 this will not be the way any of the utility could proceed,  
21 is that correct?

22 A What lines are you talking about, sir?

23 Q Lines 3 through about 9. Again, it's kind of  
24 talking about the Marion Oaks situation, that this is an  
25 example of planning, master planning. But that this is

1 highly discouraged apparently by the current used and useful  
2 policy employed by the Commission. And somehow you're  
3 suggesting in this testimony, I want you to correct me if  
4 I'm wrong, that given these used and useful policies, this  
5 will not be the way any utility could proceed to construct  
6 plant until antiquated rules are revised. And my question  
7 to you is even under the current regulatory scheme employed  
8 by the Commission, SSU has, in fact, employed these. You  
9 have admitted in Citrus Springs, Sugarmill Woods,  
10 Springhill, that you employed these prudent practices, why  
11 couldn't other utilities also do the same?

12 A Well, what I'm saying here is that the master  
13 planning of any utility should be done the way that you have  
14 a site, you have a master plan, and you have a growth, and  
15 based on that you build your facilities. If by any reason  
16 your growth doesn't happen to go the way that you're  
17 projecting, then you have to make another plan. On this  
18 plan here in Marion Oaks, for example, I would not recommend  
19 the company to do this way even though we have approved  
20 plans. As I said, what I would recommend the company to do  
21 with the present used and useful rules is go ahead and build  
22 a 30,000 gallon plant for the next 18 months. Now, that  
23 doesn't do anything for our customers, it doesn't do  
24 anything in engineering, doesn't do anything for the  
25 environment. It's a nightmare.

1 Q Now, are you suggesting that it's Mr. Biddy's  
2 recommendation to the Commission that the utilities build  
3 plants in 18 month increments?

4 A No, sir.

5 Q Okay. Good.

6 A I'm not recommending that you build any plant for  
7 18 months.

8 Q Excuse me. You didn't understand my point. I  
9 said are you suggesting that Mr. Biddy has recommended to  
10 this Commission that utilities build utility plant in 18  
11 month increments?

12 A I think that's what he is saying.

13 Q Could you pull out Mr. Biddy's revised --

14 A I don't have it here.

15 Q -- testimony. He never made any such statement.

16 A Okay.

17 Q Let move to Pages 11 and 12 of your rebuttal  
18 testimony. Here on these pages you criticize Mr. Biddy's  
19 characterization of AWWA M31 manual. In fact --

20 A What lines are you on?

21 Q Well, we are starting on, I guess, Line 16.

22 A Okay.

23 Q And you're saying that he is mischaracterizing,  
24 and, in fact, you go on to include a quote that you took  
25 apparently or allegedly from AWWA M31 manual. Do you have a

1 copy of that manual handy?

2 A I don't have it with me, no, sir.

3 Q I have one copy I will let you look at.

4 A Sure.

5 Q My concern is, and why I want you to look at it, I  
6 believe my question is have you misquoted in your quote the  
7 AWWA manual that you have referred to? Now, the section  
8 that you quote or that you allegedly quote is titled major  
9 system components. I hope you're on -- did you get the  
10 right page? And my question for you is did you, in fact --  
11 I'm just curious if this last sentence is even in the manual  
12 that you're quoting, or was that just a mistake? This is  
13 the sentence, "However, the system should be designed to  
14 provide some water at 20 PSI"?

15 A You mean, are you talking about Lines 7 through 15  
16 or are you talking Lines 21 through --

17 Q I'm talking about Lines 15 through 17 in your  
18 testimony. Page 12 now. I'm suggesting that language is  
19 not --

20 A Page 12 or 11?

21 Q Page 12. It's the end of your quote. The quote  
22 which began on Page 11. And I'm suggesting that you have  
23 added some language to the manual.

24 A I didn't change the language of the manual. I  
25 might have the wrong -- 31, it could be 32, but this came

1 out of the AWWA manual.

2 Q You say this quote that you put in your testimony  
3 came out of an AWWA manual?

4 A Yes, it did.

5 Q Well, I don't know which manual you're referring  
6 to. I got a copy of the manual that you're referencing in  
7 your testimony, and I went to the portion that you quoted,  
8 and I didn't find it to be the same.

9 A Let me ask you what is the manual that Mr. Bidy  
10 has in there?

11 Q He has AWWA M31, the same manual that you're  
12 making reference to. In fact, you're critiquing him, saying  
13 that he got it wrong.

14 A I wonder if we have got the same edition.

15 Q You didn't bring your sources?

16 A No, I did not. I thought that by quoting what I  
17 had here was sufficient, so I didn't bring my book.

18 Q I will have to go back there just a second.

19 A Okay. The next time I will specify which edition  
20 it is.

21 Q Or bring the materials with you.

22 A Right. I will have to bring the public library to  
23 pack up all of this.

24 Q You nearly did, didn't you? Isn't it correct,  
25 though, that Mr. Bidy used firm reliable capacity on high

1 service pumps used and useful analysis just like the AWWA  
2 M31 suggests here in this edition?

3 A I don't know what it says in that edition there.

4 Q Well, I mean, I think AWW talks about firm  
5 reliable capacity for high service pumps, any edition. Are  
6 you aware of any edition that doesn't require that?

7 A They do require firm capacity, yes.

8 Q And my question to you is does not Mr. Bidy in  
9 his used and useful recommendation provide for firm reliable  
10 capacity in his high service pumps?

11 A If I put something different here, he was not  
12 addressing it the way that it should have been addressed.

13 Q So my question is yes or no, did Mr. Bidy use  
14 firm reliable capacity on high service pumps in his  
15 recommendation to the Commission, or do you know?

16 A I couldn't tell you.

17 Q You couldn't tell me?

18 A I couldn't tell you at this moment.

19 Q If we could move on to Page 16, Lines 4 through 6.  
20 You state -- again, we are talking about fire flow demand  
21 and a 20 PSI requirement. You state --

22 A What page are you on, sir?

23 Q Page 16, Lines 4 through 6. And in this area  
24 you're talking about fire flow demands and the 20 PSI  
25 requirement. You make a statement, "But we also have on

1 occasion had some areas with less than 20 PSI during fire  
2 flow demands due to lack of storage facilities." Do you see  
3 that?

4 A That's correct.

5 Q And my question is could you elaborate on which  
6 areas you have experienced those below 20 PSI conditions?

7 A We have some areas like Deltona where we are  
8 saying that our storage capacities -- bear with me one  
9 second.

10 Q Okay.

11 A We have some areas like Deltona where we have had  
12 fires and we don't have like the maximum day storage, and we  
13 have run into problems in meeting the 20 PSI at times for  
14 the forest fire, and it wasn't at the forest fire itself,  
15 but it was in other areas. And then you go to Mr. Biddy's  
16 used and useful and what he has here is, I believe, 51  
17 percent of used and useful for storage at Deltona. That  
18 tells you how reliable that computation is.

19 Q Well, that's interesting testimony, but I was just  
20 trying to get an idea of where the locations of where these  
21 less than 20 PSI conditions existed and you said Deltona.  
22 Are there others?

23 A There was Deltona and there was Marco Island, one  
24 area of Marco Island, they have high grounds and it was  
25 lower than 20 PSI.

1           Q     Let me move you over to Page 35 of your rebuttal  
2 testimony, Lines 8 through 12. We are talking about Burnt  
3 Store water treatment plant, and with reference to that  
4 plant, you make the statement on Lines 8 through 12 that a  
5 reduction of approximately 10 percent of the total capacity  
6 should be allowed for maintenance procedures. Do you see  
7 that?

8           A     Yes, sir.

9           Q     How did you arrive at your request for a 10  
10 percent allowance for maintenance procedures?

11          A     I believe what I arrived at that is having the  
12 experience of having other plants, RO plants like Marco  
13 Island, this plant even though it is rated at 4 million  
14 gallons per day you can never get a continuous 4 million  
15 gallons per day. Usually 3.8, 3.2, so I estimated that we  
16 should have a margin for maintenance so when the membranes  
17 need any maintenance or any flushing, we should be able to  
18 run the plant.

19          Q     Now, you may have answered my next question  
20 because you said you estimated. Now, was the basis of this  
21 estimate through your personal experience or can you refer  
22 me to any supporting documents, or manuals, or so forth that  
23 would have a provision for such a 10 percent maintenance  
24 allowance?

25          A     No, this was based on the experience we have at



1 Marco Island. And I want you to know that all these manuals  
2 that we are looking about and looking at are based on all of  
3 the utility's experiences. This manual are not written by  
4 somebody that is in a room all enclosed. This manual that  
5 AWWA produced and things like that are based on experience  
6 that people in the field allows them to have. And this is  
7 something that it should be in the manual. It's not in the  
8 manual, but it should be in the manual. This is our own  
9 experience.

10 Q Okay. So there is no manual support for that?

11 A My experience as support.

12 Q Okay. Still talking about the Burnt Store water  
13 treatment plant on Page 57, on Lines 4 through 6, you make  
14 the statement that, "Yes, DEP permit certain number was  
15 issued January 5, 1996, to permit SSU to add an additional  
16 240,000 gallons per day RO skid to the existing facility,"  
17 is that correct?

18 A That's correct.

19 Q Now, from your prior testimony there were two RO  
20 skids at the Burnt Store water plant, is that correct?

21 A That's correct.

22 Q And here SSU is adding another skid?

23 A That's correct.

24 Q And my question is how many more RO skids can be  
25 added to the existing facility?

1           A     What we are talking about, the existing facility  
2 means actually the utility. You know, in the future you can  
3 have 8 million gallons per day.

4           Q     Excuse me?

5           A     What I'm saying is, you know, you have to add as  
6 the utility grows.

7           Q     Sure.

8           A     And that's what it is.

9           Q     I guess my question is the building, the water  
10 treatment facility building is a certain size. Is it  
11 designed to receive 3, 4, 5, 6 additional skids given the  
12 existing piping and so forth that is there at the facility,  
13 do you know?

14          A     I don't recall that. That should have been asked  
15 of Mr. Westrick.

16          Q     Who now?

17          A     Mr. Westrick.

18          Q     As an operational man for SSU, you have no  
19 information as to the additional skids that could be added  
20 to the current plant?

21          A     Could you ask the question again, please.

22          Q     As an operational man for SSU, you have no  
23 information on the capacity of the current plant to receive  
24 additional skids?

25          A     I'm not the project manager for the utility, so I

1 wouldn't know if they are going to add a building there. I  
2 imagine they are, because the building we have is limited.  
3 Instead of giving you a wrong answer, I won't give you an  
4 answer.

5 Q But regardless of how many additional skids might  
6 be able to be added to this plant, SSU is proposing that the  
7 current plant should be considered, and the land, and the  
8 structures associated with it should be considered 100  
9 percent used and useful?

10 A Yes. The reason being is that this facility is  
11 not, the facility that we have there, the water plant, is  
12 not the only thing on the site. You have wells that are  
13 distributed around the site which make full use of the site.

14 MR. RILEY: No further questions.

15 COMMISSIONER DEASON: Mr. Jacobs.

16 MR. JACOBS: Thank you, Mr. Chairman. I have no  
17 questions.

18 COMMISSIONER DEASON: Mr. Twomey.

19 MR. TWOMEY: Yes, sir.

20 CROSS EXAMINATION

21 BY MR. TWOMEY:

22 Q Let me ask you first, Mr. Terrero, the other day  
23 you had obtained a copy of Mr. Minot's (phonetic) bill, I  
24 think, from the latter part of 1994 which showed that they  
25 had that text on it of a message, right?

1           A       That's correct.

2                   MR. TWOMEY: Mr. Feil, we had that identified but  
3 not entered in the record, right?

4                   MR. FEIL: Correct, it was Exhibit 82.

5 BY MR. TWOMEY:

6           Q       Do you have a copy of that? Or maybe can one of  
7 your attorneys get you a copy?

8           A       I do now.

9           Q       Okay. Would you look at that and apparently,  
10 there is -- first of all, what is the date of the bill?

11           A       Let me tell you, first of all, I'm not a billing  
12 expert, though.

13           Q       I'm sorry, sir.

14           A       The bill seems to be 11-30-94.

15           Q       11-30-94. Okay. And it has on it the text about  
16 some homes in this community have elevated lead, right?

17           A       That's correct.

18           Q       Would you agree with me, Mr. Terrero, that the  
19 text of the message is in the same size type as the rest of  
20 the text on the message on the bill?

21           A       Come back with that again.

22           Q       Yes, sir. Would you agree with me that the size  
23 of the type that that message is printed in is the same size  
24 type as the rest of the text and numbers that appears on the  
25 bill?

1           A     It looks like it, yes.

2           Q     So if there was a -- if the Florida Administrative  
3 Code Section 62-551.810(2)(a), required that along with the  
4 following alert on the water bill itself in large print,  
5 that SSU would not have complied in that regard, is that  
6 correct?

7           A     I would say that the print that we have there is  
8 readable. The reason they say large print is because we  
9 don't want to miss the payment either, so we have it about  
10 the same size.

11          Q     I'm sorry, what?

12          A     So it's large enough to be read. DEP doesn't  
13 specify how big a font you have to have, sir.

14          Q     Well, if it says here -- I want to read this to  
15 you. It says along with the following alert on the water  
16 bill itself in large print. And then it gives the text of  
17 the message. Doesn't that mean to you, Mr. Terrero, large  
18 print, that it has to be larger than the surrounding print?

19          A     No, I think that what they mean is don't put it in  
20 small print like a car dealer.

21          Q     Well, we don't want to talk bad about car dealers,  
22 do we, Mr. Terrero?

23          A     No, sir.

24          Q     Of course not. But isn't the -- well, we won't  
25 debate this.

1           MR. TWOMEY: Mr. Chairman, I would like to ask you  
2 to require SSU to prepare and submit a late-filed exhibit  
3 that shows that it has met the requirements, the public  
4 education requirements of Rule 62-551.800 for the lead  
5 exceedences and the copper exceedences that occurred at  
6 Beacon Hills since January 1st of 1994. I would like you to  
7 require them to do the same for the lead exceedences that we  
8 heard from the DEP witnesses today wherein the Volusia  
9 County health department is apparently responsible for  
10 compliance as well as any other exceedences since January  
11 1st of 1994.

12           COMMISSIONER DEASON: Mr. Feil.

13           MR. FEIL: Well, Commissioner, I thought that with  
14 respect to Beacon Hills we had already dealt with that  
15 extensively when Mr. Terrero was up on direct. But I  
16 suppose if it will speed things along, and if Mr. Terrero  
17 doesn't have a problem with preparing such a late-filed  
18 hearing exhibit, that I don't have a problem with it.

19           WITNESS TERRERO: Well, I have a problem with it,  
20 because I think we clarified everything on the last time. I  
21 said that we were late in the publication, we have not got a  
22 consent order, we have not got a violation, so I don't see  
23 why are we looking for anything else in that. As the  
24 witnesses said this morning, we have complied with the  
25 studies, we have installed equipment, so what is the

1 problem?

2 COMMISSIONER KIESLING: I just have one question.  
3 Didn't one of the either HRS or DEP witnesses this afternoon  
4 from Jacksonville say that they had satisfied all of their  
5 education --

6 MR. TWOMEY: No, I don't think any of them --

7 WITNESS TERRERO: Yes.

8 COMMISSIONER DEASON: Hold it. Right now  
9 Commissioner Kiesling is speaking, nobody else talks until  
10 she gets her question asked and she will direct it to one  
11 person.

12 COMMISSIONER KIESLING: Thanks. And right now I  
13 was directing that to Mr. Twomey or to anyone else who might  
14 happen in terms of counsel to remember that same question  
15 and answer.

16 MR. TWOMEY: I don't think anybody knew whether  
17 the public education requirements were met or not. But my  
18 larger, if I can expand upon the basis for my request, we  
19 heard testimony today that lead exceedence has been exceeded  
20 and is currently being exceeded, as I recall, in at least  
21 two other systems aside from Beacon Hills. I would think, I  
22 mean, I'm curious on behalf of my clients, I would think the  
23 Commission would be curious, be compelled to know whether  
24 this utility is in compliance with the requirements that it  
25 educate the public when such exceedences exist. And it

1 seems to me that if Mr. Terrero or the company has the  
2 documents they can put them together and prove to the  
3 Commission that they have properly notified schools,  
4 television stations, radio stations, and the like in  
5 compliance with the law.

6 MR. FEIL: Commissioner Kiesling, if I may, a few  
7 things. First, I was in the room, and as I recall Ms.  
8 Rodriguez was speaking with regard to that issue and was  
9 told by Mr. Hamilton as he was standing there, and Ms.  
10 Rodriguez said that we had met the public education  
11 requirements. Secondly, Mr. Twomey had requested a good  
12 deal of this information through discovery already, so I  
13 would surmise that he has it already. Now, I'm all in favor  
14 of speeding things along, but at the same time I have some  
15 trepidation about the prospect of conducting discovery  
16 through a late-filed hearing exhibit.

17 COMMISSIONER KIESLING: Well, I'm not the one  
18 ruling on it. My question only related to my memory that,  
19 in fact, Ms. Rodriguez did say that after consulting with  
20 Mr. Hamilton that they had satisfied all of the public  
21 education requirements for the Jacksonville problem, and  
22 that was my only point.

23 MR. TWOMEY: And, again, I think she said that he  
24 said kind of a deal, so I would just ask that -- I'm not  
25 looking for discovery in that regard. Everybody knows the



1 level of concern generated by lead in the water and the  
2 health consequences with respect to children and so forth,  
3 and we ought to put it to bed.

4 MR. FEIL: Commissioner, the other problem I have  
5 with respect to the late-filed exhibit would be the degree  
6 of specificity that Mr. Twomey is requesting. Even if we  
7 filed something I would have no idea whether or not we sated  
8 his concern, and it seems to me since he has asked for a  
9 good deal of information through discovery, if there is a  
10 specific problem that he has identified it would be easiest  
11 for him to be able to ask a question of Mr. Terrero while  
12 Mr. Terrero is here and identify the problem, then we can  
13 move on.

14 COMMISSIONER DEASON: We are going to move on.  
15 I'm going to ask our staff to take a look at this matter, I  
16 think, if they think the record is sufficient or  
17 insufficient. And at the conclusion of cross examination of  
18 this witness, I will get a recommendation from staff in that  
19 regard, and depending on their recommendation I will take  
20 your request again, Mr. Twomey, at that point.

21 MR. TWOMEY: That's excellent. I appreciate it,  
22 Mr. Chairman.

23 BY MR. TWOMEY:

24 Q You have responded to -- let me start over again.  
25 You had, had you not, Mr. Terrero, in your MFRs requested a

1 used and useful calculation of 90.46 percent for the  
2 Sugarmill Woods wastewater treatment plant based upon your  
3 statement that its capacity was 400,000 gallons a day,  
4 right?

5 A Yes. My job at Southern States Utilities is  
6 environmental manager, and one of my responsibilities is to  
7 make sure that we comply with effluent limitations. An  
8 engineer made a study of the facilities and concluded that  
9 the capacity of the clarifier was .4 million gallons per  
10 day, and even though the permit says that it is .5 million  
11 gallons per day, the way that I would recommend the company  
12 is to go to 400,000 gallons per day and do some other  
13 improvements. But since we agree that we are going to leave  
14 it at .5, that is the way it is.

15 Q Right. And you did that only after -- isn't it  
16 true that you did that only after Mr. Hansen caught the  
17 difference and raised it as an issue in his testimony?

18 MR. FEIL: Commissioner, I mean, I'm getting deja  
19 vu here. I thought we had been through all of this when Mr.  
20 Terrero was on direct. I mean, we talked about the  
21 engineering report, we talked about the clarifier, we talked  
22 about how the used and useful percentage we have requested  
23 is based on .5 MGD. I mean, how much more repetition do we  
24 need?

25 COMMISSIONER DEASON: Mr. Twomey.

1 MR. TWOMEY: I will drop the question. Let me go  
2 to this point.

3 BY MR. TWOMEY:

4 Q What I want to know, Mr. Terrero, given that under  
5 the uniform rate structure being requested here, that Mr.  
6 Hansen and my other clients, most of them will be subject to  
7 pay for all used and useful calculations in this case, are  
8 there any other water or wastewater treatment plant  
9 capacities in your filing that are lower than the operating  
10 permit capacities?

11 MR. FEIL: Objection. Mr. Twomey asked that  
12 identical question of Mr. Bliss, and Mr. Bliss gave a  
13 response.

14 MR. TWOMEY: And what did Mr. Bliss respond, I  
15 don't recall.

16 MR. FEIL: As I recall he said not that he know  
17 of.

18 MR. TWOMEY: Well, I'm asking Mr. Terrero because  
19 it's not asked of Mr. Terrero yet, and I would suggest, Mr.  
20 Chairman, that if he knows he can tell me, if he doesn't he  
21 can say so.

22 COMMISSIONER DEASON: I will allow the question.

23 WITNESS TERRERO: Not that I know of.

24 BY MR. TWOMEY:

25 Q Okay. On Beacon Hills, you had in your rebuttal

1 testimony --

2 A The page, please.

3 Q Well, I'm trying to find it, Mr. Terrero, just a  
4 minute. Page 12. You had requested for the Beacon Hills  
5 wastewater treatment plant that you were entitled to a used  
6 and useful percentage of 100 based on the permitted capacity  
7 of the plant being 836,000 gallons per day, and also on an  
8 average daily flow of the maximum day with a five year  
9 margin reserve of 1,079,374 gallons, is that correct?

10 A I just see here that I'm saying that the plant is  
11 operating at 8.36, and, yes, I agree that it's 100 percent,  
12 but that's about the extent of it.

13 Q How can you have an average daily flow for maximum  
14 day in excess of a million gallons in a plant that only has  
15 a capacity of 836,000 gallons?

16 A Where do you see the flow of over a million  
17 gallons? I don't see it.

18 Q I see it on Page 868 of Volume 6, Book 1 of 2, in  
19 the F schedules.

20 A Could you show that to me, please.

21 Q Sure. Did you see it?

22 A Yes.

23 Q And that's a fact, is it not?

24 A Well, that's what was projected by the rate  
25 department until there is an analysis.

1           Q     Right. And the projections are that you're going  
2 to have a -- your used and useful calculation based upon  
3 flows in excess of one million gallons per day in a plant  
4 that you claim only has capacity of 836,000 gallons per day,  
5 right?

6           A     It's operating today at .836. The process could  
7 be changed and we could treat the amount that we say on that  
8 with the same plant that we have here, and still claim that  
9 it is 100 percent. I don't think that by just changing the  
10 process you can go and change your used and useful. I mean,  
11 your tankage is there, because you change a number just of  
12 the capacity doesn't mean that your used and useful should  
13 go down.

14          Q     Okay. I want to show you Volume 11 of your MFRs,  
15 Book 15 of 17, and ask you to look -- do you have that  
16 volume?

17          A     No, I don't.

18          Q     Do your attorneys have it?

19               MR. FEIL: No.

20               MR. TWOMEY: I will show you this one in a minute.

21 BY MR. TWOMEY:

22          Q     And ask you to look at Permit Number D016-213087,  
23 which was issued March 25th, 1993, and expires June 10th,  
24 1997. And I want to read this statement to you, and then  
25 I'm going to ask you to look it and help me figure out what

1 it means. It's the second paragraph, it says, "The  
2 department" -- meaning the DEP -- "permits the operation of  
3 a 0.836 million gallons per day extended aeration wastewater  
4 facility (which can also be operated as a 1.78 million  
5 gallon per day contact stabilization wastewater facility)"  
6 -- I don't know if it should be course, it says C-O-A-S-E --  
7 "screening, grit removal, chlorination and sulfur dioxide,  
8 dechlorination discharging into the St. Johns River via a  
9 20-inch diameter force main." Let me know when you finish  
10 reading that, please.

11 A I got it. I read it.

12 Q Now, that permit seems to say to me that you can  
13 operate the plant at up to 1.78 million gallons per day.

14 A No, sir. That permit says that you can change the  
15 process and go to 1.78, but you have to do a lot of  
16 additional work to get to that capacity, which we don't have  
17 the facilities in there. It says the course screening, it  
18 says rate chamber, it says more different equipment. Also  
19 since that time, since '93 rules have changed. In order to  
20 go to the river you have to go to Class 3 reliability which  
21 will add an additional clarifier.

22 Q I'm sorry, go ahead. Are you finished?

23 A I'm finished.

24 Q So it's your testimony that you can only operate  
25 the plant at the .836?

1           A     At this time, yes, without doing further  
2     evaluations.

3           Q     Now, I had asked you earlier if you knew whether  
4     the hydraulic modeling proposed by the company for the four  
5     systems involved would result in necessarily -- or it did  
6     result in higher used and useful percentages than the lot  
7     method, lot count method, do you recall that?

8           A     Yes, sir.

9           Q     Are you aware now whether or not the hydraulic  
10    method results in a higher used and useful percentage for  
11    each of those systems than the lot count method?

12          A     I was educated on these books, so if you look  
13    at --

14          Q     If the answer is yes --

15          A     Yes, the answer is yes. But I think the lot count  
16    method is not a method to really design or evaluate any  
17    system. As a matter of fact, in addition to looking up this  
18    information that you wanted, I went ahead and I ran a model  
19    given a pipe size that you are not even allowing me to, you  
20    know, the cost of the used and useful is even lower than  
21    that. And I ran a Cybernet with it, and I ended up with  
22    pressures of minus 120 pounds, minus 40 pounds. That's what  
23    you want me to build. Engineering-wise that is not what we  
24    are looking for.

25                MR. TWOMEY: Mr. Chairman, that was my last

1 question, so I had just as soon that -- I am satisfied with  
2 the yes. If counsel wants to get more of the Cybernet on  
3 redirect, that's fine. Thank you, Mr. Terrero.

4 COMMISSIONER DEASON: Staff.

5 MR. PELLEGRINI: Commissioner Deason, I would  
6 suggest that we address the question that you posed to staff  
7 at this time, if that's appropriate.

8 COMMISSIONER DEASON: I said we would do it at the  
9 end of your cross examination. You're talking about the  
10 question on the lead exceedences notice?

11 MR. PELLEGRINI: Yes, I am.

12 COMMISSIONER DEASON: We will do it at the end of  
13 your cross examination.

14 MR. PELLEGRINI: All right.

15 Commissioner Deason, we are distributing four  
16 exhibits which we intend to use in our cross examination of  
17 Mr. Terrero. The first of these is entitled Recent Water  
18 Analyses at Leisure Lakes.

19 COMMISSIONER DEASON: That would be Exhibit 223.

20 MR. PELLEGRINI: The second of these is entitled  
21 Late-filed Deposition Exhibit Number 6 from Mr. Terrero's  
22 January 1996 deposition.

23 COMMISSIONER DEASON: 224.

24 MR. PELLEGRINI: The third of these is SSU's  
25 response to Staff's Interrogatory Number 305.



1 COMMISSIONER DEASON: 225.

2 MR. PELLEGRINI: And the fourth is entitled EPA  
3 Handbook, et cetera.

4 COMMISSIONER DEASON: 226.

5 (Exhibit Numbers 223 through 226 marked for  
6 identification.)

7 CROSS EXAMINATION

8 BY MR. PELLEGRINI:

9 Q Good evening, Mr. Terrero.

10 A Good evening.

11 Q You will recall, I think, or recollect a sanitary  
12 survey letter dated October 5th, 1995 issued by HRS in  
13 connection with the Deltona water service area?

14 A Yes, sir.

15 Q And you may recall that that letter required a  
16 response by the utility with reference to the deficiencies  
17 cited by December 5th, 1995?

18 A That date that you are quoting there was a wrong  
19 date. The letter, as we addressed this morning in the  
20 conference call, was a letter with no signature. The letter  
21 that came in to us actually was a two-page letter, and it  
22 had a date of February 1996 to be answered. I will be glad  
23 to provide that as an exhibit.

24 Q Are you saying that the utility has made a  
25 response to those deficiencies?

1 A Yes, we have.

2 Q And do have you that response with you?

3 A Yes, we do.

4 Q And can you then use that to inform us as to what  
5 the utility's response was?

6 MR. FEIL: If I may, for clarity, as Mr. Terrero  
7 said, the letter attached to Mr. Faircloth's testimony, if I  
8 have the correct staff witness, was an unsigned four-page  
9 letter. The letter that Mr. Terrero believes we received  
10 was a two-page letter, so the response that Mr. Terrero is  
11 going to refer to is going to be the response to the  
12 two-page letter, not the four-page letter, for  
13 clarification.

14 MR. PELLEGRINI: I accept the clarification.

15 WITNESS TERRERO: I have the letter.

16 MR. PELLEGRINI: Would you describe its contents?  
17 That is, the responses made to the deficiencies cited in the  
18 HRS letter?

19 MR. FEIL: We have copies of it, if you would like  
20 us to distribute them.

21 WITNESS TERRERO: We can provide you copies. I  
22 have got copies for everybody, if you want copies.

23 MR. PELLEGRINI: That would be acceptable.

24 Commissioner Deason, I would suggest that that be  
25 identified as an exhibit.

1 COMMISSIONER DEASON: 227.

2 (Composite Exhibit Number 227 marked for  
3 identification.)

4 MR. FEIL: Just so everybody knows what they are  
5 getting, we are circulating our response to the letter, the  
6 two-page letter we received, and the four-page letter, as  
7 well. I apologize that they are not numbered. We didn't  
8 anticipate necessarily providing them as exhibits, but thus  
9 they are.

10 COMMISSIONER DEASON: So the record is clear, the  
11 two-page letter and the response to that letter -- I'm  
12 sorry, you have a two-page letter and a four-page letter  
13 enclosed?

14 MR. FEIL: Yes, sir. I think the two-pager and  
15 four-pager are together.

16 COMMISSIONER DEASON: Okay. It will be a  
17 composite exhibit, Exhibit 227.

18 MR. FEIL: So you are combining all three as  
19 Composite 227?

20 COMMISSIONER DEASON: Yes. That being both  
21 versions of the letter, along with the response from  
22 Southern States.

23 MR. FEIL: Thank you, Commissioner Deason.

24 BY MR. PELLEGRINI:

25 Q Mr. Terrero, would you direct your attention to

1 the exhibit marked 223 for identification, and entitled  
2 Recent Water Analyses at Leisure Lakes?

3 A Okay.

4 Q Do you have that?

5 A Yes, sir.

6 Q Is it true that this response contains a water  
7 analysis conducted on Leisure Lakes since February, since  
8 the February service hearing?

9 A Yes.

10 Q Is it not true that the test results do not  
11 indicate any water quality problems?

12 A That's correct.

13 Q With reference now to the Collier Pits property,  
14 Mr. Terrero, the land condemned, the land taken by  
15 condemnation by SSU consists of 212 acres, is that correct?

16 A Yes, sir.

17 Q Is it true that there are no surface water  
18 protection setbacks?

19 A That's correct. Collier County has not presently  
20 come up with an ordinance to protect the surface water.

21 Q It is true, is it not, that DEP has been given  
22 primacy regarding the drinking water standards for Florida?

23 A Yes, sir.

24 Q Is it not also true that utilities which obtain  
25 water from a surface water supply must meet much stricter

1 treatment standards than those which utilize ground water  
2 sources?

3 A In some cases, yes.

4 Q Would you agree with me, then, that those stricter  
5 treatment standards probably would have something to do with  
6 the vulnerability of the surface water to contamination, the  
7 surface water source to contamination?

8 A Not really.

9 Q Why is that?

10 A Well, you can have a deep well like Sugarmill  
11 Woods, and it's a sandy soil, and if you have a spill of  
12 gasoline ten feet away from it, it will be down in the well  
13 in a day.

14 Q Page 3 of your rebuttal testimony. On Line 18,  
15 where you are discussing the aquifer storage and recovery  
16 well.

17 A Yes, sir.

18 Q Do you know whether that site was -- prior to the  
19 condemnation, do you know whether that site was evaluated  
20 for its suitability as an ASR site?

21 A We have talked about it, and like I mentioned to  
22 you in my deposition, the engineers or the hydrologists that  
23 were doing the evaluation are the same, the ASR for the  
24 county is about two miles south of our property. So, yes,  
25 we thought that this property could be used for ASR.

1 Q Prior to the condemnation proceeding?

2 A Yes.

3 Q You have agreed to provide at this hearing an  
4 overlay of the Exhibit RAT-3?

5 A I do have that, sir.

6 Q Do you have that with you this evening?

7 A Yes, sir.

8 MR. PELLEGRINI: Could we have that introduced as  
9 an exhibit, please. Commissioner Deason, I would so  
10 request.

11 COMMISSIONER DEASON: While that is being done, I  
12 need some clarification. On Exhibit 227, apparently there  
13 are three versions of the letter contained within that  
14 exhibit. And I need to know the distinction between the two  
15 four-page letters. Are they the same, drafts of the same  
16 letter? One has some hand notations on it.

17 WITNESS TERRERO: The hand notations, sir, were  
18 done by our operations personnel while they were doing the  
19 review of the letters.

20 COMMISSIONER KIESLING: The thing that I'm having  
21 trouble understanding is that there is a two-page  
22 October 5th, 1995 letter, a four-page October 5th, 1995  
23 letter, and a four-page December 7th, 1995 letter all in the  
24 same packet in which you said there were only two letters.

25 WITNESS TERRERO: I obtained as much information

1 as I could and that's what I found. It seems like there was  
2 a miscommunication from --

3 COMMISSIONER KIESLING: Wait a minute. I don't  
4 need an explanation. I need to know what is in the exhibit,  
5 Mr. Feil.

6 MR. FEIL: That is what is there as I see it under  
7 this cover sheet.

8 COMMISSIONER KIESLING: Okay. But you originally  
9 identified it as a two-page letter and a four-page letter.  
10 Is the December 7th letter supposed to be a part of this?

11 MR. FEIL: It appears to have the exact same  
12 statements as the October 5th four-page letter with some  
13 notations. And interestingly enough, they all apparently  
14 have the same certified mail --

15 COMMISSIONER KIESLING: Well, I noticed that, too,  
16 which confused me even more. I mean, how you can use the  
17 same certified mail number on two letters two months apart  
18 was another quandary that I couldn't resolve in my own mind.

19 MR. FEIL: And I believe Mr. Armstrong attempted  
20 to suggest that when Mr. Faircloth was on the stand by  
21 asking him questions about whether or not the letter was  
22 transmitted informally prior to being sent formally.  
23 Neither of the two four-page letters there are signed.

24 COMMISSIONER KIESLING: I noticed that also.

25 So you have no other explanation that will help me

1 understand what this exhibit is.

2 MR. FEIL: Mr. Terrero may.

3 WITNESS TERRERO: The letter that has the exhibit  
4 number on top, the four-page letter, I think it has Lee  
5 Faircloth on top, I believe.

6 COMMISSIONER KIESLING: Not on what I have. You  
7 are confusing me more.

8 WITNESS TERRERO: That's what we had in the files,  
9 and that's what I provided. The letter that was signed was  
10 a two-page letter. To me, the HRS sent us a courtesy copy  
11 before sending the formal letter for us to take a look and  
12 take care of the problems that we had. And after a period  
13 of time they sent the second two-page letter signed. I  
14 don't want to confuse the issue, but that is --

15 MR. FEIL: I don't think the issue needs any help.

16 MR. PELLEGRINI: I would note that the SSU  
17 responses to the December letter, the unsigned December  
18 letter --

19 COMMISSIONER DEASON: Well, the exhibit, I guess,  
20 will speak for itself. But we have clarified that there are  
21 three letters from HRS, and that there is one response, and  
22 the response that is included is the response to the  
23 December 7th letter. And all of that comprises Composite  
24 Exhibit Number 227. Now we need to identify the next  
25 exhibit, which I think has just been passed out, which is an



1 overlay map, and that will be identified as Exhibit Number  
2 228.

3 (Exhibit Number 228 marked for identification.)

4 BY MR. PELLEGRINI:

5 Q Mr. Terrero, in reference to the exhibit marked  
6 228 for identification, or with reference to that exhibit,  
7 would you briefly explain how the ASR will work?

8 A The way the ASR will work is that we will pump  
9 water from the lakes into a well, and we will recharge an  
10 aquifer. Since this model was done, further studies have  
11 been completed, and instead of needing one well, we are  
12 going to need four wells to recharge and withdraw the water.  
13 It's not uncommon to have more than one well to recharge and  
14 withdraw water from the aquifer.

15 What will happen is that from June through about  
16 September there will be excess flow on the creek at Rookery  
17 Bay, which is downstream near Marco Island claims that is  
18 damaging the microbiology there. We will take the excess  
19 water through the lake, pump it into the injection well,  
20 store there, and then on the dry season we will be able to  
21 pump the water out and send it to Marco Island. That way  
22 the quality of the water will be good quality, it will be a  
23 steady quality of the water.

24 Q Is the utility required to own or control an  
25 amount of surface land in order to control or protect

1 withdrawals from the ASR?

2 A I would say that -- as an owner and a responsible  
3 party, we should open and control this area, because you  
4 don't want to have somebody else go and drill a well and  
5 take your water from there, or at the same time go and  
6 inject some water that is going to be damaging to your  
7 treatment.

8 Once you take and have the water down, at the time  
9 that you pull it you will have a specific quality, the one  
10 that you're going to be treating, you will have a treatment  
11 plant for that type of quality.

12 Like I said, I have an additional drawing that I  
13 would like to pass along with the additional wells on that  
14 site.

15 Q But before you do, and further to the explanation  
16 which you have just given us, is there an addition, a  
17 requirement as a matter of rule or statute, or is it a  
18 matter of prudent management?

19 A I believe that I have said in my testimony that it  
20 is a professional concept of how we are going to protect it.  
21 We have been in this business for a long time, we know the  
22 area, and we feel that this area here is the minimal amount  
23 of land that we can have to protect the ASR and the surface  
24 water, too.

25 Q I understand that, but is there also a requirement

1 as a matter of rule?

2 A No, there is not.

3 Q And now you said you wished to introduce a further  
4 exhibit on this subject?

5 A Yes.

6 Q And what is that?

7 COMMISSIONER DEASON: While that exhibit is being  
8 obtained, let me ask staff, I take it you still have quite a  
9 bit of cross examination for this witness?

10 MR. PELLEGRINI: Yes, sir, we do.

11 COMMISSIONER DEASON: When you get to a convenient  
12 breaking point, let me know, because we are going to recess  
13 for the evening, and you will just have to pick up with your  
14 cross examination tomorrow morning.

15 MR. PELLEGRINI: Commissioner Deason, this might  
16 be an appropriate point at which to break.

17 COMMISSIONER DEASON: Has the exhibit been  
18 located?

19 MR. FEIL: He is having trouble locating it.

20 COMMISSIONER DEASON: Well, this may be a good  
21 time.

22 MR. FEIL: Yes, sir. Thank you.

23 COMMISSIONER DEASON: Before we recess, I need to  
24 make an announcement.

25 Tomorrow morning, the Commission will be convening

1 an Internal Affairs meeting at 9:00 a.m. I cannot tell you  
2 how long that meeting is going to last. But the Chairman  
3 asked me to put everyone on notice that this hearing will  
4 convene ten minutes after the conclusion of Internal  
5 Affairs. As a guide, I think that there is only one item on  
6 the Internal Affairs agenda, I don't think that it will take  
7 an extraordinary length of time, but I can't tell you how  
8 long that will be. So just guide yourselves accordingly.

9 Mr. Feil.

10 MR. FEIL: We should be here at 9:11 then.

11 COMMISSIONER DEASON: Guide yourselves  
12 accordingly.

13 MR. FEIL: All right. Thank you, sir.

14 COMMISSIONER DEASON: Is there anything else  
15 before we recess for the evening? Hearing nothing, this  
16 hearing is recessed for the evening. See you tomorrow.

17 (Transcript continues in sequence with Volume 39.)

18

19

20

21

22

23

24

25

DOCKET 950495-WS  
 EXHIBIT NO. 220  
 CASE NO. 96-04227

EXHIBIT (SEP-1)

PAGE 1 OF 18

**SOUTHERN STATES UTILITIES, INC.**  
**PLANT ADDITIONS & REGULATORY REQUIREMENT(S)**  
 North Region

DOCUMENT NUMBER-DATE

03383 MAR 21 86

FPSC-RECORDS/REPORTING

Year	Project	Description	Plant In Service Amount	Regulatory Mandate
<b>Amelia Island - Water</b>				
1993	92CN522	REBUILD #2 WELL MOTOR	956.69	17-555.350
1993	92CN451	CHLORINE ALARM SYSTEM	408.21	17-555.320(5)
1994	90CN366	VACUUM CHLORINATION SYSTEM	4,466.46	17-555.320(5)
1994	91CN452	AERATOR ENCLOSURE	3,024.96	17-555.350
1994	92CN451	CHLORINE ALARM SYSTEMS	1,233.46	17-555.320(5)
1995	95CO211	LG WATER METER RETROFIT	2,235.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	171.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	55.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO004	CLARIFER REHAB	71,400.00	62-600.410
1996	96RO057	LARGE METER RETROFIT	3,124.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	87,074.78	

FLORIDA PUBLIC SERVICE COMMISSION  
 DOCKET NO. 950495  
 COMPANY/ EXHIBIT NO. 220  
 WITNESS: SSU Bailey  
 DATE: 4/29/96

EXHIBIT (SEB-2)

PAGE 2 OF 18

Year	Project	Description	Plant In Service Amount	Regulatory Mandate
------	---------	-------------	-------------------------	--------------------

Amelia Island - Wastewater				
1994	91CN280	MANHOLE & 15" PVC PIPE	16,635.68	17-604.500
1994	94CN305	LIFT STATION 1518-1 ALARM WIRING	1,382.81	WL93-0024DW45, 17-604.130, 400, 500
1995	94CN035	WWTP RERATING/EXPANSION	403,693.00	62-600.405
1995	95CN305	LS/MANHOLE REPLACEMENT	87,382.70	62-604.130, 400, 500
1995	94CN088	LS REHAB & MANHOLE REPL	48,914.77	17-604.130, 400, 500
1996	96RO005	COLLECTION IMPROVEMENTS	71,400.00	62-604.130, 400, 500
1996	96RO003	LIFT STATION UPGRADE	41,650.00	62-604.130, 400, 500
1996	96RO001	MANHOLE REFURBISHMENT	23,800.00	62-604.130, 400, 500
		Subtotal	694,858.96	

Year	Project	Description	Plant In Service Amount	Regulatory Mandate
<b>Beacon Hills - Water</b>				
1993	92CN500	ADDITION TO CHLORINE FEED SYSTEM	14,836.37	17-555.320(5)
1993	93CN517	WELL PUMP AND CASING	12,056.41	17-555.315,350
1993	92CN342	GROUND STORAGE TANK REFURBISHMENT	7,774.14	17-555.350(1), Duval Co. PHU Inspection 11/18/92
1993	92CN451	CHLORINE ALARM SYSTEMS	2,474.91	17-555.320(5)
1993	92CN546	REBUILD WELL PUMP	2,279.42	17-555.315,350
1993	92CN089	AUTOMATIC DIALER & PHONE LINES	839.76	17-555.320(5)
1994	91CN208	CL2 LEAK DETECTOR/ALARM/STOR. TANK	10,512.95	17-555.320(5)
1994	94CN441	CHLORINE BUILDING	7,196.50	17-555.320(5)
1994	93CN529	DIESEL FUEL TANK CONTAINMENT	7,101.59	17-762
1994	93CN517	WELL PUMP AND CASING	684.16	17-555.315,350
1995	94CN040	WTP EXPANSION & IMPROVE	796,392.78	62-551, 555, Duval Co. PHU NNC 5/31/94, Duval Co. PHU Permit 1693WD2842
1995	93CN064	COBBLESTONE CHEMICAL FEED	182,077.75	62-551, 555, Duval Co. PHU Permit 1693WD2842
1995	95CN702	HIDDEN HILLS WATER MAIN	86,520.50	62-555\*.350(1)
1995	95CN309	CHLORINE ANALYZERS(2)	7,381.10	62-555.320(5)a
1995	95CO211	LG WATER METER RETROFIT	4,631.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	354.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	109.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	6,471.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	1,149,693.35	
<b>Beacon Hills - Wastewater</b>				
1993	92CA550	H2S CONTROL	6,768.22	17-604.400
1993	92CN536	MANHOLE REFURBISHMENT	3,963.08	17-604.400,500
1993	92CN273	FORCE MAIN REFURBISHMENT	3,865.32	17-604.500
1993	92CN525	REFURBISH LIFT STATION PUMPS	2,562.75	17-604.130,400,500
1993	89CN010	WWTP DECHLORINATION	1,855.54	USEPA NOV 4/1/91, 17-3, NPDES Permit #FL0026778
1993	92CN526	PUMP - LIFT STATION	965.52	17-604.130,400,500
1993	92CN535	REFURBISH SUBMERSIBLE PUMP	881.65	17-604.130,400,500
1993	92CN532	PUMP - LIFT STATION	645.51	17-604.130,400,500
1993	92CN533	REFURBISH SUBMERSIBLE PUM -L/S 886- 8	595.87	17-604.130,400,500
1994	93CN125	LIFT STATION UPGRADE	92,275.65	17-604.130,400,500

EXHIBIT (SEB-1)

PAGE 4 OF 18

Year	Project	Description	Plant In Service Amount	Regulatory Mandate
1994	93CN057	ELECTRIC CONTROL PANEL - L/S	45,689.00	17-604.130,400,500
1994	93CN528	DIESEL FUEL TANK CONTAINMENT	10,619.62	17-762
1994	92CN272	UPGRADE SPLITTER & INFLUENT BOX	9,116.80	17-600.410
1994	94CN344	PUMP - HARBOUR ISLAND - L/S 886-19	6,065.71	17-604.130,400,500
1994	93CN385	REFURBISH PUMP - BEACON MASTER L/S	5,461.75	17-604.130,400,500
1994	93CN611	PUMP - EAST POINTE	3,332.39	17-604.130,400,500
1994	93CN690	PUMP - EAST POINTE	2,913.03	17-604.130,400,500
1994	91CN356	HARBOUR ISLAND L/S IMPROVEMENTS	1,226.85	17-604.130,400,500
1994	93CN610	PUMP - ST. JOHN'S LANDING	1,078.44	17-604.130,400,500
1995	95CN314	TROUGH REPLACEMENT	29,762.50	62-600.740, *410
1995	95CN313	MANHOLE REFURBISHMENTS	23,810.00	17-604.130,400,500
1995	95CN310	REPLACE AIR DIFFUSERS	8,571.60	62-600.740, *410
1996	96RO010	MANHOLE REFURBISHMENT	23,800.00	17-604.130,400,500
		Subtotal	285,826.80	



Year	Project	Description	Plant In Service Amount	Regulatory Mandate
<b>Beecher's Point - Water</b>				
1993	92CN427	CL2 KIT & SCOTT AIR PAK	55.57	17-555.330, 29CFR1910.134
1993	92CN451	CHLORINE ALARM SYSTEMS	26.99	FDEP 93-0332, 17-555.320(5), WL920071PW54NED
1994	93CN054	WATER SYSTEM CONNECTION TO WELAKA	62,153.76	FDEP 93-0332, 17-550, WL920071PW54NED
1994	92CN451	CHLORINE ALARM SYSTEMS	1,639.42	FDEP 93-0332, 17-555.320(5), WL920071PW54NED
1995	95CO211	LG WATER METER RETROFIT	66.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	5.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	2.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	92.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	<b>64,040.74</b>	
<b>Beecher's Point - Wastewater</b>				
1993	92CN609	SEWER MAIN	8,806.85	17-604.500
1993	92CN516	BEECHER'S POINT FORCE MAIN RELOCATION	3,274.52	17-604.400
1994	93CN607	INSTALL BLOWER	4,891.54	17-600.410
1995	95CN315	INSTALL FLOW METER AT WW	4,166.75	62-601.300
		Subtotal	<b>21,139.66</b>	
<b>Geneva Lake Estates - Water</b>				
1993	92CN507	HYDRO PNEUMATIC TANK	14,683.96	17-555.350(1)
1993	92CN451	CHLORINE ALARM SYSTEM	91.84	FDEP Inspection letter 3/10/92, 17-555.320(5)
1994	92CN451	CHLORINE ALARM SYSTEM	1,076.14	17-555.320(5)
1995	95CO211	LG WATER METER RETROFIT	133.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	10.00	62-555.320(5)
1995	95CO101	METER TEST/INSTALL EQUIP	3.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	185.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	<b>16,182.94</b>	

Year	Project	Description	Plant In Service Amount	Regulatory Mandate
<b>Hermits Cove - Water</b>				
1993	90CN151	LINE EXTENSION TO TIE INTO PLANT 438	6,068.92	17-555.315, 320(6)
1994	93CN048	MANGANESE REMOVAL SYSTEMS	4,796.37	17-550.320
1994	92CN451	CHLORINE ALARM SYSTEMS	3,257.28	C.O. 93-0332, 17-555.320(5)
1995	95CO211	LG WATER METER RETROFIT	265.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	20.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	6.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	371.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	14,784.57	

Year	Project	Description	Plant In Service Amount	Regulatory Mandate
<b>Holiday Haven - Water</b>				
1995	95CO211	LG WATER METER RETROFIT	169.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	13.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	4.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	236.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	422.00	
<b>Interlachen Lakes/Park Manor - Water</b>				
1993	89CN146	WTP GENERATORS	31,553.09	17-555.320(6)
1993	92CN307	WATER SYSTEM INTERCONNECT W/PARK MANOR	27,515.67	17-555.310
1993	92CN451	CHLORINE ALARM SYSTEMS	43.23	C.O. 93-0332, 17-555.320(5)
1994	92CN451	CHLORINE ALARM SYSTEMS	1,639.56	C.O. 93-0332, 17-555.320(5)
195	95CN355	REPLACE ROOF	5,357.25	62-555.350\*(1)
1995	95CO211	LG WATER METER RETROFIT	375.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	29.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	9.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO031	HIGH SERVICE PUMPS	13,090.00	62-555.350\*(1)
1996	96RO057	LARGE METER RETROFIT	524.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	80,135.80	

Year	Project	Description	Plant In Service Amount	Regulatory Mandate
<b>Jungle Den - Water</b>				
1995	95CO211	LARGE WATER METER RETROFIT	172.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	13.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	4.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	241.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	430.00	
<b>Keystone Club Estates - Water</b>				
1993	92CN451	CHLORINE ALARM SYSTEM	537.92	FDEP Sanitary Survey 3/10/92, 17-555.320(5)
1994	92CN451	CHLORINE ALARM SYSTEM	1,086.51	FDEP Sanitary Survey 3/10/92, 17-555.320(5)
1995	95CO211	LG WATER METER RETROFIT	232.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	18.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	5.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	324.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	2,203.43	

Year	Project	Description	Plant In Service Amount	Regulatory Mandate
<b>Keystone Heights - Water</b>				
1993	92CN105	PUMP AND MOTOR - WELL #2	14,121.33	17-555.350(1)
1993	92CN505	FIRE HYDRANTS	1,709.01	Clay County Ordinance #88, 17-555.330(3)
1993	92CN494	RELOCATION OF EMERGENCY GENERATOR	1,159.75	17-555.320(6) & 350(1)
1993	92CN451	CHLORINE ALARM SYSTEMS	900.14	17-555.320(5)
1993	92CN420	WELL FLOW METER REBUILD	524.21	SJRWMD 40C-2
1994	93CN074	WTP IMPROVEMENTS	104,710.97	17-555.320(4) & 350(1)
1994	93CN075	CLAY COUNTY ROADWAY IMPROVEMENTS	33,632.01	FS 337.403
1994	92CN451	CHLORINE ALARM SYSTEM	2,873.83	17-555.320(5)
1995	93CN075	CLAY CTY/DOT UTILITY RELO	50,816.00	FS 337.403
1995	95CO211	LG WATER METER RETROFIT	1,502.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	115.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	35.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	2,100.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	214,199.25	
<b>Lakeview Villas - Water</b>				
1995	95CO211	LG WATER METER RETROFIT	18.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	1.00	62-555.320(5)a
1996	96RO057	LARGE METER RETROFIT	26.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	45.00	

Year	Project	Description	Plant In Service Amount	Regulatory Mandate
------	---------	-------------	-------------------------	--------------------

Palm Port - Water				
1993	92CN421	INSTALL SOLENOID VALVE ON WELL	720.89	17-555.315
1993	92CN378	FLOW METERS	696.23	SJRWMD 40C-2, 17-555.320(8)
1993	92CN451	CHLORINE ALARM SYSTEMS	118.85	C.O. 93-0332, 17-555.320(5)
1994	93CN050	WTP HYDRO TANK	43,495.00	17-555.350(1)
1994	93CN051	REPIPE PLANT & INSTALL HPT BYPASS	4,008.17	17-555.350(1)
1994	92CN451	CHLORINE ALARM SYSTEMS	1,640.19	17-555.320(5)
1995	95CN399	REPLACE AERATOR ON GST	11,905.00	62-555.350\*(1)
1995	95CN714	LEAD AND COPPER CONTROL	1,973.25	62-551
1995	95CO211	LG WATER METER RETROFIT	151.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	12.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	4.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	211.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	64,935.58	
Palm Port - Wastewater				
1993	91CN509	SPRAY FIELD (WWTP EFFLUENT DISP IMPR)	92,071.11	17-610.320
1994	93CN049	IMPROVE SEWER GRAVITY MAIN	7,425.89	17-604.130, 400, 500
1995	95CN398	INSTALL FLOW METER/WW PLT	4,166.75	62-601.300
1996	96RO054	REBUILD MAIN LIFT STATION	11,900.00	62-604.130, 400, 500
		Subtotal	115,563.75	

Year	Project	Description	Plant In Service Amount	Regulatory Mandate
<b>Palm Valley - Water</b>				
1993	91CN014	WATER DISTRIBUTIONS/SYSTEM IMPROVEMENT I	823,466.88	17-550.310, 320, 350(1), C.O. 92-1400
1993	92CN318	CHLORINE FEED SYSTEM	2,882.15	17-555.320(5)
1994	91CN014	WATER DISTRIBUTIONS/SYSTEM IMPROVEMENT II	36,693.78	17-550.310, 320, 350(1), C.O. 92-1400
1994	92CN451	CHLORINE ALARM SYSTEMS	2,264.16	17-555.320(5)
1994	91CN269	REBUILD PUMP	1,030.27	17-555.350(1)
1995	95CO211	LG WATER METER RETROFIT	314.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	24.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	7.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	439.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	867,121.24	
<b>Park Manor - Water</b>				
1995	95CN402	INSTALL FLOW METER/WW PLT	4,166.75	62-601.300
		Subtotal	4,166.75	
<b>Park Manor - Wastewater</b>				
1994	93CN607	INSTALL BLOWER	5,760.67	17-600.410
		Subtotal	5,760.67	

Year	Project	Description	Plant In Service Amount	Regulatory Mandate
------	---------	-------------	-------------------------	--------------------

Pomona Park - Water				
1993	92CN347	WTP GENERATOR	46,337.98	C.O. 93-0332, 17-555.320(6), WL92-0072-PW54NED
1993	92CN451	CHLORINE ALARM SYSTEMS	2,751.67	C.O. 93-0332, 17-555.320(5)
1993	92CN427	CL2 REPAIR KIT & SCOTT AIR PAK	1,375.35	17-555.320(5) & 29CFR1910.134
1993	92CN378	FLOW METERS	696.23	17-555.320(8)
1994	91CN410	CHLORINATOR	1,735.09	17-555.320(5)
1994	94CN521	SUBMERSIBLE WELL PUMP	1,001.77	17-555.350
1994	93CN121	CHEMICAL FEED PUMPS (4)	601.09	17-555.320(5)
1995	95CO211	LG WATER METER RETROFIT	254.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	19.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	6.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	356.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	55,134.18	
Postmaster Village - Water				
1993	92CN566	PUMP & MOTOR WELL #2	3,108.30	17-555.350
1993	92CN502	PUMP, MOTOR AND WIRE	1,498.67	17-555.350
1993	92CN451	CHLORINE ALARM SYSTEMS	452.16	FDEP Sanitary Survey 7/14/92, 17-555.320(5)
1994	93CN076	WTP GENERATOR	68,537.34	FDEP Sanitary Survey 7/14/92, 17-555.320(6)
1994	90CN233	2200 FT. OF 6" LINE - REPLACE 1 1/2"	2,738.04	17-555.350(1)
1994	92CN451	CHLORINE ALARM SYSTEMS	1,085.79	17-555.320(5)
1995	95CO211	LG WATER METER RETROFIT	238.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	18.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	6.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	332.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	78,014.30	



Year	Project	Description	Plant In Service Amount	Regulatory Mandate
<b>Remington Forest - Water</b>				
1993	92CN541	CHLORINE ALARM SYSTEM	373.91	17-555.320(5)
1994	92CN451	CHLORINE ALARM SYSTEMS	23.14	17-555.320(5)
1995	95CN406	CHLORINE ANALYZERS	3,690.55	62-555.320(5)a
1995	95CO211	LG WATER METER RETROFIT	98.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	7.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	2.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	136.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	4,330.60	
<b>River Grove - Water</b>				
1993	92CN378	FLOW METERS	696.23	17-555.320(8)
1993	92CN451	CHLORINE ALARM SYSTEMS	91.82	17-555.320(5), C.O. 930332
1994	92CN451	CHLORINE ALARM SYSTEMS	3,286.95	17-555.320(5), C.O. 930332
1995	95CN410	REPLACE AERATOR ON GST	5,952.50	62-555.350\*(1), FDEP Sanitary Survey 9/2/94
1995	95CN719	LEAD AND COPPER CONTROL	1,973.25	62-551
1995	95CO211	LG WATER METER RETROFIT	160.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	12.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	4.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	224.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	12,400.75	

Year	Project	Description	Plant In Service Amount	Regulatory Mandate
------	---------	-------------	-------------------------	--------------------

River Park - Water				
1993	90CN434	WTP GENERATORS	25,093.05	17-555.320(6)
1993	92CN451	CHLORINE ALARM SYSTEMS	31.55	C.O. 93-0332, 17-555.320(5)
1994	90CN451	CHLORINE ALARM SYSTEMS	1,639.46	C.O. 93-0332, 17-555.320(5)
1994	94CN520	SUBMERSIBLE WELL PUMP	1,438.74	17-555.350*(1)
1994	90CN434	WTP GENERATORS	606.59	17-555.320(6)
1995	95CO211	LG WATER METER RETROFIT	536.00	62-555.320(6)*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	41.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	13.00	62-555.320(6)*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	750.00	62-555.320(6)*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	30,149.39	

EXHIBIT (SEP-1)

PAGE 15 OF 18

Year	Project	Description	Plant In Service Amount	Regulatory Mandate
<b>Salt Springs - Water</b>				
1993	93CW475	CHLORINE EMERGENCY KIT	1,376.51	17-555.320(5)
1994	92CW109	LAB EQUIPMENT	722.47	17-550.500, 550
1995	95CO211	LG WATER METER RETROFIT	177.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	14.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	4.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	247.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	2,540.98	
<b>Salt Springs - Wastewater</b>				
1993	91CW445	WWTP IMPROVEMENTS	118,688.94	17-600.400, 405, 410
1996	96RO061	REPLACE L.S. ELECTRIC BOX	14,280.00	62-604.130, 400, 500
		Subtotal	132,968.94	
<b>Silver Lake Oaks - Water</b>				
1994	93CN055	HYRDRO TANK	27,175.69	17-555.350(1)
1994	90CN156	WTP UPGRADE	2,060.48	17-555.350(1)
1994	94CN451	RELOCATE WATER MAIN	751.69	17-555.314(1)
1995	95CO211	LG WATER METER RETROFIT	40.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	3.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	1.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	55.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	30,086.86	
<b>Silver Lake Oaks - Wastewater</b>				
1994	90CN155	WWTP UPGRADE	22,183.58	17-600.410(6)
1994	93CN607	INSTALL BLOWER	6,799.60	17-600.410(6)
1995	95CN414	INSTALL FLOW METER/WW PLT	4,166.75	62-601.300
		Subtotal	33,149.93	

Year	Project	Description	Plant In Service Amount	Regulatory Mandate
<b>St. John's Highlands - Water</b>				
1993	90CN151	LINE EXTENSION TO TIE INTO PLANT # 438	9,547.72	17-555.315, 320(6)
1994	93CN120	GAS CHLORINATORS	2,809.40	17-555.320(5)
1994	92CN451	CHLORINE ALARM SYSTEMS	1,610.29	17-555.320(5)
1995	95CN421	REPLACE ROOF	2,083.38	62-555.315(2)(d))
1995	95CO211	LG WATER METER RETROFIT	125.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	10.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	3.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	175.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	16,363.79	
<b>Welaka/Saratoga Harbour - Water</b>				
1993	92CN427	CL2 REPAIR KIT & SCOTT AIR PAK	65.69	17-555.320(5), 330, 29CFR1910.134
1993	92CN451	CHLORINE ALARM SYSTEM	32.40	17-555.320(5)
1994	92CN451	CHLORINE ALARM SYSTEM	1,639.47	17-555.320(5)
1994	93CN121	CHEMICAL FEED PUMPS (4)	601.09	17-555.320(4), 350(1)
1995	95CO211	LG WATER METER RETROFIT	206.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	16.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	5.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	287.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	2,852.65	
<b>Woodmere - Water</b>				
1993	92CN451	CHLORINE ALARM SYSTEMS	323.59	17-555.320(5)
1994	93CN485	HIGH SERVICE PUMP REBUILD	4,077.22	17-555.350(1)
1994	92CN451	CHLORINE ALARM SYSTEMS	1,060.47	17-555.320(5)
1995	95CN439	CHLORINE ANALYZERS	3,690.55	62-555.320(5)a
1995	95CO211	LG WATER METER RETROFIT	1,778.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	136.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	42.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	2,485.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	13,592.83	

Year	Project	Description	Plant In Service Amount	Regulatory Mandate
------	---------	-------------	-------------------------	--------------------

Woodmere - Wastewater				
1993	92CN567	REFURBISH LIFT STATION	19,539.50	17-604.130, 400, 500
1993	92CN087	BLOWER CONTROLS	5,698.55	17-600.410
1993	92CN541	WARNING ALARMS: CL2 & SO2	2,513.12	29CFR1910.119, 17-600.300
1993	92CN568	REWIND BLOWER MOTOR	1,004.14	17-600.410
1994	93CN124	EMERGENCY BYPASS L/S PUMP	9,152.66	17-604.130, 400, 500
1994	94CN470	FLOW RECORDER	3,223.77	17-600.400\*601.300
1994	91CN011	WWTP DECHLORINATION	3,187.26	EPA Admin. Order 93-078, 17-302
1994	92CN271	REFURBISH MANHOLE AT UNIVERSITY	2,208.75	17-604.130, 400, 500
1996	96RO076	MANHOLE REFURBISHMENT	23,800.00	62-604.130, 400, 500
		Subtotal	70,327.75	
Wooten - Water				
1995	93CN053	WTP IMPROVEMENTS	23,671.50	17-550.310, 320, OGC-93-0332
		Subtotal	23,671.50	
Wooten - Water				
1995	95CO211	LG WATER METER RETROFIT	32.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	2.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	1.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	45.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	80.00	
		TOTAL	\$4,194,249.72	

Year	Project	Description	Plant In Service Amount	Regulatory Mandate
------	---------	-------------	-------------------------	--------------------

F:\Engineer\SB\JDW\docs\153-N.doc (Rev.3/19/96)

- C.O. - Consent Order
- Char. Co. Agmt. - Charlotte County Agreement
- DO - Domestic Operating
- DT - Domestic Temporary
- FS - Florida Statutes
- NNC - Notice of Non-Compliance
- NWWMD - Northwest Florida Water Management District
- OGC - Office of General Counsel
- SFWMD - South Florida Water Management District
- SJRWMD - St. Johns River Water Management District
- SWFWMD - Southwest Florida Water Management District
- TOP - Temporary Domestic Operating
- WL - Warning Letter

**Southern States Utilities, Inc. - North Region**  
**1995 Filed and Actual FPSC Plant in Service Additions (w/o General Plant)**  
**As of December 31, 1995**

Project #	Project Description	In-Service Date		In-Service Amount	
		Filed	Actual	Filed	Actual
<b>AMELIA ISLAND</b>					
95CN303	REPLACE WELL PUMP #1	03/31/95	06/16/95	11,310	10,861
	Total Water			11,310	10,861
94CN035	WWTP RERATING/EXPANSION	11/22/95	11/21/95	403,693	513,794
95CN700	SUMMER BEACH EFF LINE	06/26/95	06/15/95	106,163	81,611
95CN305	LS/MANHOLE REPLACEMENT	12/31/95	11/27/95	87,383	92,252
94CN088	LS REHAB & MANHOLE REPL	03/31/95	07/28/94	48,915	49,164
95CN304	CATWALK ON CLARIFIER	05/31/95	12/27/95	11,905	25,663
	Total Wastewater			658,058	762,485
	Total Amelia Island			669,368	773,347
<b>BEACON HILLS</b>					
94CN040	WTP EXPANSION & IMPROVE	05/30/95	06/09/95	796,393	733,259 (b)
93CN056	COBBLESTONE WELL #2	06/20/95	06/09/95	203,513	168,111
93CN064	COBBLESTONE CHEMICAL FEED	12/12/95		182,078	0
94CN037	DUVAL COUNTY UTILITY RELO	11/07/95		121,498	0
95CN702	HIDDEN HILLS WATER MAIN	07/11/95	11/21/95	86,521	95,854
95CN309	CHLORINE ANALYZERS(2)	05/31/95	03/01/95	7,381	7,451
	Total Water			1,397,383	1,004,676
93CN061	WW COLL SYS IMPROVE	07/25/95	12/28/95	283,785	388,797
95CN314	TROUGH REPLACEMENT	04/30/95	12/21/95	29,763	21,723
95CN313	MANHOLE REFURBISHMENTS	06/01/95	11/28/95	23,810	22,923
95CN312	REPLACE LS PUMPS	12/31/95	11/28/95	14,286	7,291
95CN310	REPLACE AIR DIFFUSERS	03/31/95	07/28/95	8,572	8,231
95CN308	SHOWER/EYEWASH STATIONS	02/28/95	03/02/95	3,095	2,079
	Total Wastewater			363,311	451,043
	Total Beacon Hills			1,760,694	1,455,719
<b>BEECHER'S POINT</b>					
95CN316	INSTALL 5,000 GAL TANK	03/31/95	11/15/95	8,929	10,357
95CN315	INSTALL FLOW METER AT WW	Cancelled		4,167	0
	Total Beecher's Point - Wastewater			13,096	10,357
<b>INTERLACHEN LAKE EST.</b>					
95CN355	REPLACE ROOF	03/31/95	06/23/95	5,357	5,488
	Total Interlachen Lake Est. - Water			5,357	5,488
<b>KEYSTONE HEIGHTS</b>					
93CN075	CLAY CTY/DOT UTILITY RELO	12/18/95	07/24/95	50,816	42,694
	Total Keystone Heights - Water			50,816	42,694
<b>NORTH REGION PLANT</b>					
95CN209	NEW METERS/CHANGE OUT PRG	12/31/95	12/29/95	186,906	83,579
95CN210	WATER SERVICES	12/31/95	12/29/95	60,849	42,418
95CN207	HYDRANTS	10/31/95	12/01/95	16,905	8,274
	Total North Region - Water			264,660	134,271
<b>PALM PORT</b>					
95CN399	REPLACE AERATOR ON OST	03/31/95	08/01/95	11,905	12,085
95CN714	LEAD AND COPPER CONTROL	Expensed		1,973	0 (a)
	Total Water			13,878	12,085
95CN397	CULVERT & IMPRV DRIVEWAY	02/28/95	04/07/95	4,167	2,973
95CN398	INSTALL FLOW METER/WW PLT	Cancelled		4,167	0
	Total Wastewater			8,334	2,973
	Total Palm Port			22,212	15,058

(a) Completed and expensed rather than capitalized.

(b) Reflects completion of a phase, but not entire project.

(c) Not required because gov't authority did not perform it's project.

(d) Refers to Refundable Advance, with zero rate base impact.

**Southern States Utilities, Inc. - North Region**  
**1995 Filed and Actual FPSC Plant in Service Additions (w/o General Plant)**  
**As of December 31, 1995**

Project #	Project Description	In-Service Date		In-Service Amount	
		Filed	Actual	Filed	Actual
<b>PARK MANOR</b>					
95CN403	INSTALL 5,000 GAL TANK	02/28/95	12/19/95	8,929	32
95CN402	INSTALL FLOW METER/WW PLT	Cancelled		4,167	0
Total Park Manor - Wastewater				13,096	32
<b>POMONA PARK</b>					
95CN405	INSTALL AIR RITE COMPRESS	03/31/95	06/12/95	2,083	1,058
Total Pomona Park - Water				2,083	1,058
<b>POSTMASTER VILLAGE</b>					
94CN480	W DIST SYS IMPRV/PHASE I	11/09/95	11/14/95	116,296	98,076
Total Postmaster Village - Water				116,296	98,076
<b>REMINGTON FOREST</b>					
95CN406	CHLORINE ANALYZERS	05/31/95	03/01/95	3,691	3,790
Total Remington Forest - Water				3,691	3,790
<b>RIVER GROVE</b>					
95CN410	REPLACE AERATOR ON GST	02/28/95	08/04/95	5,953	6,058
95CN409	REPIPE PUMP ROOM	04/30/95	06/12/95	4,167	2,437
95CN408	REPLACE ROOF	04/30/95	06/12/95	2,381	2,137
95CN407	INSTALL AIR RITE COMPRESS	03/31/95	06/12/95	2,083	974
95CN719	LEAD AND COPPER CONTROL	Expensed		1,973	0 (a)
Total River Grove - Water				16,557	11,606
<b>SILVER LAKE OAKS</b>					
95CN414	INSTALL FLOW METER/WW PLT	03/31/95	03/22/95	4,167	723
Total Silver Lake Oaks - Wastewater				4,167	723
<b>ST. JOHN'S HIGHLANDS</b>					
95CN421	REPLACE ROOF	04/30/95	09/01/95	2,083	1,181
Total St. John's Highlands - Water				2,083	1,181
<b>WELAKA</b>					
95CN434	INSTALL AIR RITE COMPRESS	03/31/95	06/12/95	2,083	2,327
95CN411	INSTALL AIR RITE COMPRESS	03/31/95	06/12/95	2,083	974
Total Welaka - Water				4,167	3,301
<b>WOODMERE</b>					
95CN441	WELL #2 CONTROL PANEL	06/30/95	10/01/95	11,905	9,638
95CN439	CHLORINE ANALYZERS	05/31/95	03/01/95	3,691	3,790
Total Water				15,596	13,428
94CN497	REFURBISH LIFT STATION	02/28/95	11/28/95	26,886	25,819
95CN442	PUMP REPLACEMENTS	12/31/95	11/28/95	14,286	4,979
95CN438	SHOWER/EYEWASH STATIONS	02/28/95	11/28/95	3,095	2,079
Total Wastewater				44,268	32,876
Total Woodmere				59,864	46,304
<b>WOOTEN</b>					
93CN053	WTP IMPROVEMENTS	06/26/95		23,672	0
Total Wooten - Water				23,672	0
Total 1995 Plant In-Service Additions - As Filed in MFR's				3,031,877	2,603,004
Less: Non-FPSC Plants Project Allocation Adjustments				(50,642)	
Total Per MFR's				2,981,235	

- (a) Completed and expensed rather than capitalized.  
(b) Reflects completion of a phase, but not entire project.  
(c) Not required because gov't authority did not perform it's project.  
(d) Refers to Refundable Advance, with zero rate base impact.



DOCKET 950495-WLS  
EXHIBIT NO. 221  
CASE NO. 96-04027

FLORIDA PUBLIC SERVICE COMMISSION  
DOCKET NO. 950495  
COMPANY: *Florida Power*  
WITNESS: *9/29/96*  
DATE: \_\_\_\_\_  
EXHIBIT NO. 221

**SOUTHERN STATES UTILITIES, INC.**  
**PLANT ADDITIONS & REGULATORY REQUIREMENT(S)**  
Central Region

DOCUMENT NUMBER-DATE  
03402 MAR 21 96  
FPSC-RECORDS/REPORTING

Year	Project	Description	Plant In Service Amount	Regulatory Mandate
------	---------	-------------	-------------------------	--------------------

Apple Valley - Water				
1993	92CC344	VIRGINIA DRIVE WATER MAIN RELOC.	161,937.22	FS 337.403
1993	93CC427	DUAL CHLORINE SCALE	1,062.57	17-555.320(5)
1994	92CC344	WATER MAIN RELOCATION (VIRGINIA DR)	2,446.54	FS 337.403
1994	93CC568	FENCING FOR PLANT PROPERTIES	2,220.60	17-555.310,315
1994	93CC501	AUTO DIALER FOR CHLORINE ALARM	930.26	17-555.320(5)
1995	95CC701	LEAD AND COPPER CONTROL	6,577.50	62-551
1995	95CO211	LG WATER METER RETROFIT	1,446.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	111.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	34.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	2,020.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	178,785.69	
Bay Lake Estates - Water				
1993	92CC503	WELL PUMP	6,634.31	17-555.315
1994	93CC559	CHLORINE ALARMS	1,079.64	17-555.320(5)
1995	95CO211	LG WATER METER RETROFIT	107.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	8.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	3.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	150.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	7,981.95	

EXHIBIT (BP-1)  
PAGE 2 OF 24

Year	Project	Description	Plant In Service Amount	Regulatory Mandate
------	---------	-------------	-------------------------	--------------------

Buenaventura Lakes - Water				
1996	96RO057	LARGE METER RETROFIT	18,310.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	18,310.00	
Carlton Village - Water				
1993	92CC407	WTP GENERATOR	37,418.88	17-555.320(6)
1994	92CC407	WTP GENERATOR	1,466.98	17-555.320(6)
1995	94CC017	HYDRO TANK & NEW WELL PHASE I	117,468.54	62-555.350
1995	94CC018	DISTRIBUTION SYS UPGRADE	106,908.65	62-555.350(1)
1995	95CO211	LG WATER METER RETROFIT	192.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	15.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	5.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	94CC017	HYDRO TANK & NEW WELL PHASE II	123,881.00	62-555.350*(1)
1996	96RO057	LARGE METER RETROFIT	268.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	387,624.05	
Chuluota - Water				
1994	91CC421	SCALES FOR CHLORINE CYLINDER	915.47	17-555.320(5)
1995	95CO211	LG WATER METER RETROFIT	1,012.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	77.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	24.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	94CC020	DISTRIBUTION SYSTEM UPGRD	425,433.00	17-550,\*555.350(1)
1996	96RO057	LARGE METER RETROFIT	1,414.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	428,875.47	
Chuluota - Wastewater				
1993	91CC265	REBUILD 2 HP LIFT PUMP	696.34	17-604.130,400,500
1993	92CC621	REBUILD # 1 LIFT PUMP	620.26	17-604.130,400,500
1994	94CC498	PLANT FLOW METER	3,362.87	17-601.200(17), \*.300, FDEP Insp. Report 3/5/93, Inspection letter 11/29/94,
1994	93CC417	REBUILD 2 PUMPS	804.80	17-604.130,400,500
1994	93CC540	FLOW CHART RECORDER	784.95	17-600.410(6), FDEP Inspection Report 3/5/93
1994	92CC281	INSTALL 2" MONITORING WELL # 3	777.00	17-610.424, 17-522
		Subtotal	7,046.22	

Year	Project	Description	Plant In Service Amount	Regulatory Mandate
------	---------	-------------	-------------------------	--------------------

Daetwyler Shores - Water				
1994	92CC498	PUMPS	6,372.02	17-555.315(5)
1995	95CO211	LG WATER METER RETROFIT	190.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	15.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	4.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	266.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	\$6,847.02	
Deltona Lakes - Water				
1993	89CN078	WELL # 33	467,357.26	17-555.320, 350
1993	92CN511	WELL #23	78,808.71	17-555.320, 350
1993	92CN451	CHLORINE ALARM SYSTEM	3,237.37	FDEP Sanitary Survey 3/11/91, 17-555.320(5)
1993	92CN453	ELECTRIC POWER SENTRY MODULE	2,987.63	17-555.320(6)
1993	92CN366	CHLORINE VENTILATOR FAN	621.53	17-555.320(5)
1994	93CN097	DOT & COUNTY ROADWAY IMP/UTILITY RELOC	145,257.96	FS 337.403
1994	89CN078	WELL 33	10,856.83	17-555.320, 350
1994	94CN112	8" TURBINE WATER METERS (3)	8,571.45	17-555.320, \*SJRWMD 40C-2
1994	92CN451	CHLORINE ALARM SYSTEMS	5,020.14	17-555.320(5)
1994	94CN328	CORROSION CONTROL	2,506.25	17-551.510
1994	91CS476	CHART RECORDER	530.05	17-555.350(1)
1995	95CO211	LG WATER METER RETROFIT	34,810.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC705	VOLUSIA CTY/DOT UTILITY	13,290.00	F.S. 337.403
1995	95CC341	ROOF REPLACEMENTS (5)	4,464.38	62-555.315,350\*(1)
1995	95CC340	CORROSION CONTROL EQUIP	3,571.50	Volusia Co. HRS.\*62-551
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	2,660.00	62-555.320(5)a
1995	95CC342	TELEMETRY EQUIPMENT	2,526.57	62-160.120, \*62-555.350(1)
1995	95CO101	METER TEST/INSTALL EQUIP	817.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	48,643.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	836,537.63	

Year	Project	Description	Plant In Service Amount	Regulatory Mandate
------	---------	-------------	-------------------------	--------------------

Deltona Lakes - Wastewater				
1993	92CN461	ABS PUMP	4,990.04	17-604.130,400,500
1993	92CN445	REBUILD PUMP	1,507.77	17-604.130,400,500
1993	92CN365	SHAFT BEARING #3 CLARIFIER	1,079.15	17-600.410(6)
1993	92CN602	REBUILD RETURN PUMP	589.50	17-600.410(6)
1994	93CN100	WWTP SUBSTANDARD HOLDING FACILITIES	1,311,706.76	17-610.464(3)
1994	93CN380	DHCC - EFFLUENT DISPOSAL IMPROVEMENTS	4,042.25	17-610.320
1995	94CN046	FP&L EASEMENT EFF IRG.SYS	726,332.25	17-600.405, WL OWL-DW940014
1995	94CN341	DHCC - EFF DISP IMPROVE	330,625.00	17-600.405, WL OWL-DW940014
1995	95CC347	TELEMETRY EQUIP UPGRADE	9,131.14	62-555.320(5)a, \*62-604.130,400,500
1995	95CC342	TELEMETRY EQUIPMENT	2,527.10	62-160.120\*62-160.120, \*62-604.500(2)(3)
1996	96RO027	L/S UPGRADE (5)	17,850.00	62-604.130,400,500
1996	96RO025	TELEMETRY EQUIPMENT WW	10,115.00	62-160.120\*62-604.130,400,500
		Subtotal	2,420,495.95	
Dol Ray Manor - Water				
1994	93CC588	CHLORINATION ALARMS	1,028.01	FDEP Inspection letter 2/7/94, 17-555.320(5)
1995	95CO211	LG WATER METER RETROFIT	91.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	7.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	2.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO029	CHLORINATOR EQUIPMENT	11,900.00	62-555.350, \*320(5)
1996	96RO057	LARGE METER RETROFIT	128.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	13,156.01	

Year	Project	Description	Plant In Service Amount	Regulatory Mandate
------	---------	-------------	-------------------------	--------------------

Druid Hills - Water				
1993	92CC383	AERATOR	37,341.19	FDEP Sanitary Survey 2/10/93, 17-555.320, 350(1)
1993	92CC012	5000 GAL HYDRO TANK	21,435.78	17-555.350(1)
1994	94CC316	CHLORINE BUILDING	10,832.89	17-555.320(5)
1994	92CC383	AERATOR	3,376.15	FDEP Sanitary Survey 2/10/93, 17-555.320, 350(1)
1994	93CC588	CHLORINATION ALARMS	1,028.01	FDEP Inspection letter 2/7/94, 17-555.320(5)
1995	95CO211	LG WATER METER RETROFIT	379.00	62-555.320(6)*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	29.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	9.00	62-555.320(6)*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	530.00	62-555.320(6)*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	74,961.02	
East Lake Harris Estates - Water				
1994	93CC630	CHLORINATORS (4) - REGAL MODEL A210	1,625.04	17-555.320(5)
1994	93CC588	CHLORINATION ALARMS	1,028.01	17-555.320(5)
1995	94CC023	PLANT IMPROVEMENTS	226,743.59	62-555.320*62-555.315
1995	95CO211	LG WATER METER RETROFIT	264.00	62-555.320(6)*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	20.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	6.00	62-555.320(6)*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	368.00	62-555.320(6)*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	230,054.64	
Enterprise - Water				
1995	95CO211	LG WATER METER RETROFIT	332.00	62-555.320(6)*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	25.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	8.00	62-555.320(6)*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	464.00	62-555.320(6)*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	829.00	
Enterprise - Wastewater				
1993	92CN604	ROOTS 45 URAL BLOWER UNIT	549.13	17-600.410
1994	94CN416	LIFT STATION PUMP	1,021.07	17-600 *17-604.130,400,500
		Subtotal	1,570.20	

EXHIBIT (BP-1)  
PAGE 6 OF 24

Year	Project	Description	Plant In Service Amount	Regulatory Mandate
------	---------	-------------	-------------------------	--------------------

Fern Park - Water				
1993	93CC376	ROOF ON STORAGE TANK	7,071.20	17-555.350(1)
1994	93CC588	CHLORINATION ALARMS	1,028.01	FDEP Inspection Report 2/7/94, 17-555.320(5)
1995	94CC457	REPLACE HYDRO TANK	24,830.42	62-555.350(1)
1995	95CO211	LG WATER METER RETROFIT	274.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	21.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	6.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	383.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	33,613.63	
Fern Terrace - Water				
1992	91CC203	GENERATOR 50 KW W/AUTO TRANSFER SWITCH	19,438.38	17-555.320(6)
1994	93CC579	FLOW METER FOR WELL PUMP	2,724.87	SJRWMD 40C-2
1994	93CC630	CHLORINATORS (4) - REGAL MODEL A210	1,625.04	17-555.320(5)
1994	93CC588	CHLORINATION ALARMS	1,028.01	17-555.320(5)
1994	91CC008	NEW WELL # 2	565.59	17-555.315
1994	93CC646	CHLORINE SCALES	314.32	17-555.320(5)
1995	95CO211	LG WATER METER RETROFIT	187.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	14.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	4.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	262.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	26,163.21	
FL Central Commerce Park - Wastewater				
1993	92CC469	FLOW RECORDER	3,239.00	17-600.400(4), 601.300
1993	92CC283	POND PUMP	681.52	17-600.410
		Subtotal	3,920.52	

Year	Project	Description	Plant In Service Amount	Regulatory Mandate
------	---------	-------------	-------------------------	--------------------

Fountains - Water				
1994	93CC559	CHLORINE ALARMS	1,105.42	17-555.320(5)
1995	95CC706	LEAD AND COPPER CONTROL	1,973.25	62-551
1995	95CO211	LG WATER METER RETROFIT	44.00	62-555.320(6)\*(8), SFWMD 40E-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	3.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	1.00	62-555.320(6)\*(8), SFWMD 40E-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	62.00	62-555.320(6)\*(8), SFWMD 40E-2, 25-30.262,263,264
		Subtotal	3,188.67	
Friendly Center - Water				
1995	95CO211	LG WATER METER RETROFIT	30.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	2.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	1.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	43.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	76.00	
Grand Terrace - Water				
1994	93CC588	CHLORINATION ALARMS	1,028.01	17-555.320(5)
1995	95CC708	LEAD AND COPPER CONTROL	1,973.25	62-551
1995	95CO211	LG WATER METER RETROFIT	168.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	13.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	4.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	234.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	3,420.26	

EXHIBIT (BP-1)  
PAGE 8 OF 24

Year	Project	Description	Plant In Service Amount	Regulatory Mandate
<b>Harmony Homes - Water</b>				
1993	91CC324	BACK FLOW DEVICE	698.09	17-555.360
1994	91CC202	PUMP WELL	3,989.44	17-555.315
1994	94ZZ777	CHLORINATOR	1,792.54	17-555.320(5)
1994	93CC490	FENCING FOR PLANT PROPERTY	1,617.49	17-555.310, .315
1994	93CC588	CHLORINATION ALARMS	1,028.01	FDEP Inspection letter 2/7/94, 17-555.320(5)
1995	95CO211	LG WATER METER RETROFIT	96.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	7.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	2.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	134.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	9,364.57	
<b>Hobby Hills - Water</b>				
1994	93CC630	CHLORINATORS (4) - REGAL MODEL A210	1,625.04	17-555.320(5)
1994	93CC588	CHLORINATION ALARMS	1,028.01	17-555.320(5)
1994	93CC018	3" FLOW METER # 1 WELL	855.46	SJRWMD 40C-2
1994	93CC646	CHLORINE SCALES	314.32	17-555.320(5)
1995	95CO211	LG WATER METER RETROFIT	146.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	11.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	3.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	204.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	4,186.83	
<b>Holiday Heights - Water</b>				
1994	93CC009	3000 GALLON HYDRO TANK	43,723.36	17-555.350(1)
1994	93CC588	CHLORINATION ALARMS	1,028.01	17-555.320(5)
1995	95CO211	LG WATER METER RETROFIT	81.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	6.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	2.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	113.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	44,953.37	



EXHIBIT (BP-17)  
PAGE 9 OF 24

Year	Project	Description	Plant In Service Amount	Regulatory Mandate
------	---------	-------------	-------------------------	--------------------

Imperial Mobile Terrace - Water				
1994	94CC368	WELL PUMP	7,338.37	17-555.350(1)
1994	93CC588	CHLORINATION ALARMS	1,028.01	17-555.320(5)
1995	95CO211	LG WATER METER RETROFIT	367.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	28.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	9.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	513.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	9,283.38	
Intercession City - Water				
1994	90CC190	WTP - AUXILIARY GENERATORS	6,464.43	17-555.320(6)
1994	93CC631	REBUILD # 2 TURBINE WELL PUMP	4,340.77	17-555.315 & 350
1994	93CC412	PLANT FLOW METER	3,232.61	17-555.320(8)
1994	93CC559	CHLORINE ALARMS	1,079.62	17-555.320(5)
1995	95CO211	LG WATER METER RETROFIT	386.00	62-555.320(6)\*(8), SFWMD 40E-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	29.00	62-555.320(6)\*(8), SFWMD 40E-2, 25-30.262,263,264
1995	95CO101	METER TEST/INSTALL EQUIP	9.00	62-555.320(6)\*(8), SFWMD 40E-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	539.00	62-555.320(6)\*(8)
		Subtotal	16,080.43	
Kingswood - Water				
1993	92CN451	CHLORINE ALARM SYSTEM	257.61	17-555.320(5)
1994	92CN451	CHLORINE ALARM SYSTEMS	1,212.19	17-555.320(5)
1995	95CO211	LG WATER METER RETROFIT	94.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	7.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	2.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	132.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	1,704.80	

EXHIBIT (BP-1)  
PAGE 10 OF 24

Year	Project	Description	Plant In Service Amount	Regulatory Mandate
------	---------	-------------	-------------------------	--------------------

Lake Ajay - Water				
1994	93CC036	WTP MASTER METER	4,857.87	17-555.320(8)
1994	92CC263	# 1 WELL	3,315.20	17-555.320
1994	93CC576	CHLORINE STORAGE FACILITY	2,417.70	17-555.320(5)
1994	90CC188	WTP - AUXILIARY GENERATORS	1,809.02	17-555.320(6)
1994	93CC559	CHLORINE ALARMS	1,131.24	17-555.320(5)
1995	95CO211	LG WATER METER RETROFIT	130.00	62-555.320(6)\*(8), SFWMD 40E-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	10.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	3.00	62-555.320(6)\*(8), SFWMD 40E-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	181.00	62-555.320(6)\*(8), SFWMD 40E-2, 25-30.262,263,264
		Subtotal	13,855.03	
Lake Brantley - Water				
1994	94ZZ777	CHLORINATOR	1,792.54	17-555.320(5)
1994	93CC588	CHLORINATION ALARMS	1,028.01	17-555.320(5)
1995	94CC030	HYDRO TANK AND AERATOR	123,370.53	62-555.330\*(3), 320(1), 350(1)
1995	95CO211	LG WATER METER RETROFIT	101.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	8.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	2.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	141.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	126,443.08	

EXHIBIT (BP-1)  
 PAGE 11 OF 24

Year	Project	Description	Plant In Service Amount	Regulatory Mandate
------	---------	-------------	-------------------------	--------------------

Lake Conway Park - Water				
1994	92CC499	PUMPS	3,729.96	17-555.315(5)
1995	95CO211	LG WATER METER RETROFIT	130.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	10.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	3.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	181.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	4,053.96	
Lake Harriet Estates - Water				
1994	94ZZ777	CHLORINATOR	1,792.54	17-555.320(5)
1994	93CC571	CHLORINE SCALE	1,461.23	17-555.320(5)
1994	93CC588	CHLORINATION ALARMS	1,028.01	17-555.320(5)
1995	95CC358	REPLACE AERATOR TRAYS	17,262.25	62-555.350(1)
1995	95CO211	LG WATER METER RETROFIT	430.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	33.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	10.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	600.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	22,617.03	
Meredith Manor - Water				
1994	91CC373	NEW AERATOR ON STORAGE TANK	15,098.66	17-555.350(1)
1994	93CC502	AUTO DIALER FOR CHLORINE ALARM	930.26	17-555.320(5)
1995	95CO211	LG WATER METER RETROFIT	992.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	76.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	23.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	1,386.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	18,505.92	

EXHIBIT (BP-1)

PAGE 12 OF 24

Year	Project	Description	Plant In Service Amount	Regulatory Mandate
------	---------	-------------	-------------------------	--------------------

<b>Morningview - Water</b>				
1994	93CC588	CHLORINATION ALARMS	1,028.01	17-555.320(5)
1994	93CC646	CHLORINE SCALES	314.32	17-555.320(5)
1995	95CO211	LG WATER METER RETROFIT	55.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	4.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	1.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	77.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	1,479.33	
<b>Oakwood - Water</b>				
1993	92CN451	CHLORINE ALARM SYSTEM	344.98	17-555.320(5)
1994	92CN451	CHLORINE ALARM SYSTEM	1,245.49	17-555.320(5)
1995	95CO211	LG WATER METER RETROFIT	309.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	24.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	7.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	432.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	2,362.47	
<b>Palisades Country Club - Water</b>				
1994	93CC588	CHLORINATION ALARMS	1,028.01	17-555.320(5)
1995	95CO211	LG WATER METER RETROFIT	52.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	4.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	1.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	72.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	1,157.01	

Year	Project	Description	Plant In Service Amount	Regulatory Mandate
------	---------	-------------	-------------------------	--------------------

Palms Mobile Home Park - Water				
1993	92CC280	IRON FILTERS	64,021.64	17-550.320
1994	93CC588	CHLORINATION ALARMS	1,028.01	17-555.320(5)
1994	93CC646	CHLORINE SCALES	314.32	17-555.320(5)
1995	95CO211	LG WATER METER RETROFIT	88.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	7.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	2.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	124.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	65,584.97	
Picciola Island - Water				
1994	93CC588	CHLORINATION ALARMS	1,028.01	17-555.320(5)
1994	93CC646	CHLORINE SCALES	314.32	17-555.320(5)
1995	95CO211	LG WATER METER RETROFIT	201.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	15.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	5.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	281.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	1,844.33	
Pine Ridge Estates - Water				
1994	93CC575	CHLORINE STORAGE FACILITY	3,392.60	17-555.320(5)
1994	90CC189	WTP - AUXILIARY GENERATIONS	3,167.96	17-555.320(6)
1994	93CC559	CHLORINE ALARMS	1,135.61	17-555.320(5)
1995	95CC716	LEAD AND COPPER CONTROL	1,973.25	62-551
1995	95CO211	LG WATER METER RETROFIT	323.00	62-555.320(6)\*(8), SFWMD 40E-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	25.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	8.00	62-555.320(6)\*(8), SFWMD 40E-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	451.00	62-555.320(6)\*(8), SFWMD 40E-2, 25-30.262,263,264
		Subtotal	10,476.42	

Year	Project	Description	Plant In Service Amount	Regulatory Mandate
<b>Piney Woods - Water</b>				
1993	92CC471	A-210 CHLORINATOR	1,367.21	17-555.320(5)
1994	90CC352	AUXILIARY GENERATOR	26,117.52	17-555.320(6)
1994	93CC588	CHLORINATION ALARMS	2,056.14	17-555.320(5)
1994	93CC630	CHLORINATORS (4) - REGAL MODEL A210	1,625.04	17-555.320(5)
1994	93CC646	CHLORINE SCALES	314.32	17-555.320(5)
1995	95CO211	LG WATER METER RETROFIT	254.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	19.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	6.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	356.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	32,115.23	
<b>Quail Ridge Estates - Water</b>				
1994	93CC588	CHLORINATION ALARMS	1,028.01	17-555.320(5)
1995	95CO211	LG WATER METER RETROFIT	23.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	2.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	1.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	32.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	1,086.01	
<b>Silver Lake Est./W. Shores - Water</b>				
1993	92CC513	REWIND 60 HP WELL PUMP MOTOR	1,302.91	17-555.350(1)
1994	93CC588	CHLORINATION ALARMS	1,028.01	17-555.320(5)
1994	93CC588	CHLORINATION ALARMS	1,012.07	17-555.320(5)
1994	90CC157	WATER PLANT UPGRADE	670.55	17-555.320 & 350
1994	93CC646	CHLORINE SCALES	314.32	17-555.320(5)
1995	94CC032	WTP & DIST. IMPROVEMENT	862,099.56	62-555.320, 350(1)
1995	95CO211	LG WATER METER RETROFIT	2,051.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	157.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	48.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	2,866.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	871,549.42	

EXHIBIT (BP-1)

PAGE 15 OF 24

Year	Project	Description	Plant In Service Amount	Regulatory Mandate
<b>Skycrest - Water</b>				
1993	92CC018	PORTABLE GENERATOR	7,897.87	17-555.320(6)
1994	93CC014	WTP IMPROVEMENTS	288,403.22	17-555.315, 320(6), 350(8)
1994	93CC588	CHLORINATION ALARMS	1,028.01	17-555.320(5)
1995	95CO211	LG WATER METER RETROFIT	174.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	13.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	4.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	243.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	297,763.10	
<b>Stone Mountain - Water</b>				
1995	95CO211	LG WATER METER RETROFIT	11.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	1.00	62-555.320(5)a
1996	96RO057	LARGE METER RETROFIT	15.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	27.00	
<b>Sugar Mill - Water</b>				
1994	92CN267	550 GALLON FUEL STORAGE TANK	10,602.42	17-761,762, 17-555.320(6)
1994	93CN083	CHLORINATORS	2,981.44	17-555.320(5)
1995	95CC721	LEAD AND COPPER CONTROL	6,577.50	62-551
1995	95CO211	LG. WATER METER RETROFIT	946.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	72.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	22.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	1,322.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	22,523.36	
<b>Sugar Mill - Wastewater</b>				
1994	94CN339	FLOW METER - CHART RECORDER	4,515.59	17-601.200(17), \*300
1995	95CC424	REWORK BLOWERS (2)	3,214.35	62-604.500(2), \*62-600.410(6)
1995	95CC422	CHLORINE CYLINDER SCALE	616.68	62.555.320(5)
		Subtotal	8,346.62	

EXHIBIT (BP-1)

PAGE 14 OF 24

Year	Project	Description	Plant In Service Amount	Regulatory Mandate
------	---------	-------------	-------------------------	--------------------

Sunshine Parkway - Water				
1993	92CC473	LADDER & SAFETY CAGE FOR STORAGE TANK	1,372.83	29CFR1910.27(d)(1)(II)
1994	93CC041	CHLORINATORS; BOOSTER PUMPS	5,039.66	17-555.320(5)
1994	93CC424	8" FLOW METERS FOR WELL PUMPS (2)	3,936.57	SJRWMD 40C-2
1994	93CC588	CHLORINATION ALARMS	1,028.01	17-555.320(5)
1995	95CO211	LG WATER METER RETROFIT	15.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	1.00	62-555.320(5)a
1996	96RO057	LARGE METER RETROFIT	21.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	11,414.07	
Sunshine Parkway - Wastewater				
1993	88CC003	EFFLUENT DISPOSAL SYSTEM & LAND	690,779.04	Lake Co. Reg. 6.10.01, TOP DT35-131150
1993	91CC320	FLOW DEVICE	689.16	17-601.300
1994	93CC694	ISCO AUTO SAMPLER - MODEL 3710R	4,363.74	17-601.500
1994	94CC491	FLOW METER	3,430.51	17-601.300, D035-220437\*DO0035
		Subtotal	699,262.45	
Tropical Park - Water				
1994	90CC191	WTP - AUXILIARY GENERATORS	4,452.76	17-555.320(6)
1994	93CC577	CHLORINE STORAGE FACILITY	3,467.00	17-555.320(5)
1994	93CC559	CHLORINE ALARMS	1,131.26	17-555.320(5)
1995	94CC034	HYRO TANK REPLACEMENT	46,717.54	62-555.350\*(1)
1995	95CO211	LG WATER METER RETROFIT	827.00	62-555.320(6)\*(8), SFWMD 40E-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	63.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	19.00	62-555.320(6)\*(8), SFWMD 40E-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	1,156.00	62-555.320(6)\*(8), SFWMD 40E-2, 25-30.262,263,264
		Subtotal	57,833.56	



Year	Project	Description	Plant In Service Amount	Regulatory Mandate
------	---------	-------------	-------------------------	--------------------

University Shores - Water				
1993	92CC408	#2 TURBINE WELL PUMP IMPROVEMENTS	10,504.26	17-555.350(1)
1993	92CC371	CHLORINATION EQUIPMENT	2,597.15	17-555.320(5)
1993	92CC388	REBUILD 100HP SERVICE PUMP MOTOR	2,276.29	17-555.350(1)
1993	92CC285	CHLORINE SCALES	946.32	17-555.320(5)
1994	91CC381	SUNCREST CHLORINE MONITOR ALARM	6,192.84	17-555.320(5)
1994	93CC556	CHLORINATION EQUIPMENT	6,178.78	17-555.320(5)
1994	93CC463	REBUILD # 3 HIGH SERVICE PUMP	3,355.15	17-555.350(1)
1994	93CC358	REBUILD # 1 WELL PUMP MOTOR	1,451.61	17-555.320
1994	92CC003	CHLORINE VACUUM LOSS ALARM SYSTEM	705.21	17-555.320(5)
1994	93CC559	CHLORINE CAPACITY ALARMS	341.26	17-555.320(5)
1995	95CC724	LEAD AND COPPER CONTROL	40,251.00	62-551
1995	95CO211	LG WATER METER RETROFIT	5,154.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	394.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	121.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	7,201.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	87,669.87	

EXHIBIT (BP-1)

PAGE 18 OF 24

Year	Project	Description	Plant In Service Amount	Regulatory Mandate
------	---------	-------------	-------------------------	--------------------

University Shores - Wastewater				
1993	92CC004	REFURBISH STP - #1	63,423.70	17-600.410
1993	91CC001	IRRIGATION UPGRADE CHAPEL HILL	10,111.05	17-610.462, 463
1993	92CC635	REBUILD 76HP LIFT PUMP	2,461.58	17-604.130, 400, 500
1993	92CC623	REBUILD CLARIFIER	2,065.62	17-600.410
1993	92CC287	REBUILD LIFT PUMP SUNCREST L/S	1,229.94	17-604.130, 400, 500
1993	92CC416	REBUILD LIFT PUMP BRADFORD COVE	1,113.19	17-604.130, 400, 500
1993	92CC384	PROGRAMMER FOR 1MGD FILTER	969.41	17-600.410
1994	92CC008	EMERGENCY GENERATOR STP # 2	39,453.60	17-610.462
1994	94CC317	2,000 GALLON ABOVE GROUND TANK	21,256.16	17-761 & 762, Orange Co. NNC 1/3/94
1994	94CC447	LIFT STATION PUMPS (2)	18,893.37	17-604.500*(2),(3), WLODCEDW0207
1994	93CC360	EFFLUENT DISPOSAL MODIFICATIONS	13,475.76	17-610.320
1994	90CC138	DECHLORINATION	7,786.25	NPDES Permit FL0024856, 17-302
1994	93CC371	20 HP EFFLUENT PUMP	6,446.00	17-610.320
1994	93CC621	CHLORINATION EQUIPMENT	6,248.64	17-600.440
1994	92CC474	EFFLUENT FLOW METER / INSTALL PH METER	5,487.91	17-600.445, 601.300
1994	91CC385	FLOW METER RELOCATION	5,165.01	17-601.300
1994	93CC503	2 L/S PUMPS @ CHAPEL HILL	4,701.40	17-610.320
1994	93CC599	DUAL CHLORINE SCALES (3)	4,384.75	17-600.440
1994	91CC415	FLOW METER RELOCATION	2,807.84	17-601.300
1994	91CC308	CHLORINE & BLOWER ROOM DOOR	2,174.87	17-600.410
1994	93CC384	INSTALL 2 MONITORING WELLS	2,025.24	17-522, 610.424
1994	92CC005	BLOWER/GENERATOR HOUSING	1,645.46	17-600.410
1994	93CC383	REBUILD LIFT PUMP @ LAKE IRMA L/S	1,422.21	17-604.130, 400, 500
		Subtotal	224,748.96	

EXHIBIT (BP-1)

PAGE 19 OF 24

Year	Project	Description	Plant In Service Amount	Regulatory Mandate
<b>Valencia Terrace - Water</b>				
1995	95CO211	LG WATER METER RETROFIT	686.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	52.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	16.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	958.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	1,712.00	
<b>Venetian Village - Water</b>				
1993	92CC470	A-210 CHLORINATOR	1,367.21	17-555.320(5)
1994	92CC020	5000 GALLON HYDRO TANK	52,211.82	17-555.350(1)
1994	94CC446	FENCING AND BACKFILL	9,926.67	LAKE COUNTY ZONING
1994	93CC588	CHLORINATION ALARMS	1,028.01	17-555.320(5)
1994	90CC178	CHLORINATION EQUIPMENT	1,002.68	17-555.320(5)
1994	93CC646	CHLORINE SCALES	314.32	17-555.320(5)
1995	95CO211	LG WATER METER RETROFIT	207.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	16.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	5.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	290.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	66,368.71	
<b>Westmont - Water</b>				
1995	95CO211	LG WATER METER RETROFIT	200.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	15.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	5.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	279.00	62-555.320(6)\*(8), SJRWMD 40C-2, 25-30.262,263,264
		Subtotal	499.00	

Year	Project	Description	Plant In Service Amount	Regulatory Mandate
------	---------	-------------	-------------------------	--------------------

Windsong - Water				
1994	94CC352	MASTER METER	1,098.81	17-555.320(8)
1994	93CC559	CHLORINE ALARMS	1,079.64	17-555.320(5)
1995	95CC727	LEAD AND COPPER CONTROL	1,973.25	62-551
1995	95CO211	LG WATER METER RETROFIT	160.00	62-555.320(6)\*(8), SFWMD 40E-2, 25-30.262,263,264
1995	95CC331	CHLORINATR/BSTR PMP/EJETR	12.00	62-555.320(5)a
1995	95CO101	METER TEST/INSTALL EQUIP	4.00	62-555.320(6)\*(8), SFWMD 40E-2, 25-30.262,263,264
1996	96RO057	LARGE METER RETROFIT	224.00	62-555.320(6)\*(8), SFWMD 40E-2, 25-30.262,263,264
		Subtotal	4,551.70	

Year	Project	Description	Plant In Service Amount	Regulatory Mandate
<b>Administrative - General Plant</b>				
1992	89CS122	4.0 MGD R.O. PLANT	10,130.87	17-555.320, 350(1)
1993	91CW002	WWTP EXPANSION/IMPROVEMENTS	18,592.07	17-600.405, 410
1993	93CW278	HYDRAULIC PIPE PUSHER	14,427.10	Marion Co. Ordinance 89-24, 17-555.320
1993	93CN109	LAB EQUIPMENT - LAB COUNTERS	11,032.66	17-55.320, 601.400, 550, EPA 570/9-82-002
1993	92CA369	UNDERGROUND STORAGE - SEWER	10,752.49	17-761, 762
1993	92CA369	UNDERGROUND STORAGE	10,421.09	17-761, 762
1993	92CA369	UNDERGROUND STORAGE	6,969.16	17-761, 762
1993	88CS009	PLANT EXPANSION	6,290.97	17-600.405
1993	92CA633	BACKFLOW PREVENTION TESTER	5,232.14	17-555.360
1993	92CN031	FLOW PROPORTIONAL SAMPLERS	4,485.10	Beacon Hills NPDES Permit No. FLO026778, 17-601
1993	92CN086	LAB EQUIPMENT	4,132.26	17-601.400
1993	93CN518	CONFINED SPACE ENTRY SAFETY EQUIPMENT	4,082.51	29CFR1910.146
1993	92CC620	INCUBATOR	3,179.48	17-601.400
1993	93CW467	SAFETY EQUIPMENT	2,821.93	29CFR1910.134
1993	N/A	GARAGE EQUIPMENT	2,632.62	29CFR1910.134
1993	93CW272	SAFETY EQUIPMENT	2,488.07	29CFR1910.134
1993	93CW457	BREATHING APPARATUS	1,997.47	29CFR1910.134
1993	92CN427	CL2 REPAIR KIT & SCOTT AIR PAK	1,665.68	29CFR1910.134
1993	93CW253	CL2 REPAIR KIT - TYPE A	1,660.36	17-555.320(5), 600.300, 440
1993	93CW291	CHLORINE REPAIR KITS	1,632.68	17-555.320(5)
1993	92CN544	REFRIGERATOR	1,524.39	17-601.400(3)
1993	92CN542	REFRIGERATOR	1,524.39	17-601.400(3)
1993	92CA608	PORTABLE TEST KIT	763.43	17-555.350, 600.410
1993	92CS563	SELF-CONTAINED BREATHING APPARATUS	620.83	29CFR1910.134
1993	92CN547	WATER LEVEL INDICATOR	594.61	SJRWMD 40D-2
1993	92CW584	PH METER	551.26	40CFR503 & 17-640, 40CFR257
1993	92CW634	PH METER	543.64	40CFR503 & 17-640, 40CFR257
1993	92CN451	CHLORINE ALARM SYSTEMS	65.21	17-555.320(5)

EXHIBIT (BP-1)

PAGE 22 OF 24

Year	Project	Description	Plant In Service Amount	Regulatory Mandate
1993	93CW291	CHLORINE REPAIR KITS	1.12	17-555.320(5)
1994	92CA370	UNDERGROUND STORAGE	95,271.79	17-761, 762
1994	93CA697	SAFETY EQUIPMENT	69,825.47	29CFR1910.134
1994	93CC553	GROUND MAINTENANCE EQUIPMENT	39,081.01	17-610.320, D048193001
1994	92CN572	PORTABLE EMERGENCY PUMP	28,783.61	17-604.500(2)
1994	93CO136	ENVIRONMENTAL COMPLIANCE SOFTWARE	28,719.87	17-600.405, 17-555 & 600
1994	92CN347	WTP GENERATORS	27,570.60	17-555.320(6)
1994	92CC642	PORTABLE 4" TRASH PUMP	12,524.12	17-604.130, 400, 500
1994	94CW313	FLOW PROPORTIONED COMPOSITE SAMPLERS	12,294.83	17-600/*17-601.500
1994	93CO683	LAB EQUIPMENT	11,755.60	17-550 & 601
1994	94CA486	LOW VISION ACCOMMODATION	10,353.93	Federal Americans w. Disabilities Act
1994	94CN495	COMMUNICATION EQUIPMENT	9,047.42	17-604.400
1994	92CC579	REFURBISH LABORATORY	8,105.03	17-16, 17-601.400(3)
1994	92CA606	POLYSONIC FLOW METERS	7,835.09	17-555.350(1), 17-600.410, 604.400
1994	93CN492	SAFETY EQUIPMENT-CONFINED SPACE	7,180.79	29CFR1910.146
1994	93CW641	MONITORING WELL CONTROLLER	5,797.62	17-522, 17-601.700
1994	MFRADJ	LABORATORY EQUIPMENT	5,250.87	17-550 & 601
1994	92CC257	CHLORINE SCALES	5,098.97	17-555.320 (5)
1994	91CN451	LAB EQUIPMENT	4,919.17	17-601.400(3)
1994	92CS329	LAB EQUIPMENT	4,655.96	17-601.400(3), 17-550
1994	92CC258	CONVERT ENGINE TO 45 KW GENERATOR	4,582.56	17-600.400
1994	93CN066	AIR CONDITIONER/HEATER UNIT	4,536.55	17-600.400, 17-550, 601
1994	93CC554	ISCO AUTOMATIC SAMPLER - MODEL # 3710R	4,317.88	17-601.500
1994	92CW109	LABORATORY EQUIPMENT	4,194.04	17-600.400, 17-601.400(3)
1994	93CW258	LAB EQUIPMENT	4,061.59	17-601.400(3)
1994	90CW059	EQUIPMENT	3,719.64	17-550
1994	92CW468	PH2 CL2 ANALYZERS/COMPOSITE SAMPLER	3,685.78	17-600.445, 17-601.500
1994	93CO534	HUNTRON MODEL 1000	3,220.14	17-600.400, 604.400
1994	94CC362	FENCING OF PLANT PROPERTY	2,498.66	17-555.310, 315(2)(d), Code 93-25
1994	93CN072	CONFINED SPACE ENTRY SAFETY KIT	2,438.31	29CFR1910.146
1994	93CN128	ICE MACHINE	2,083.91	17-601.400(3)
1994	93CO533	PRESSURE CALIBRATOR	1,791.47	17-555.350, 17-600.410, 17-604.500

EXHIBIT (BP-1)

PAGE 23 OF 24

Year	Project	Description	Plant In Service Amount	Regulatory Mandate
1994	94CO121	ROSEMONT SMART MAG CALIBRATOR	1,731.04	17-555.350, 17-600.410, 17-604.500
1994	93CW277	LABORATORY EQUIPMENT	1,693.91	17-601.400
1994	92CS570	PH METER	1,663.24	17-555.350(1)
1994	93CN109	LAB EQUIPMENT - LAB COUNTERS	1,316.21	17-550 & 601.400
1994	93CN627	PH METER FOR LABORATORY	1,255.09	17-601.400(3), 17-550 & 601
1994	93CN472	PH METER FOR LAB W/ ELECTRONIC STAND	1,245.12	17-601.400(3), 17-550 & 601
1994	91CC417	AMPEROMETRIC TITRATOR	1,103.67	University Shores NPDES Permit #0024856
1994	94CO122	SET CLASS S WEIGHTS	1,049.67	17-160
1994	92CW109	LAB EQUIPMENT	776.92	17-600.400, 601.400(3)
1994	93CN076	WTP GENERATOR	744.94	17-555*.320(6)
1994	91CN226	LAB EQUIPMENT	513.91	17-600.410
1994	89CS122	4.0 MGD R.O. PLANT	86.43	17-555.320, 350
1995	95CO216	AUTO DIALER BLANKET	34,589.98	62-555.320(5)
1995	95CO104	CORROSION TESTING METER	6,006.07	62-551
1995	95CO103	C. W. COX FLOW METER	5,654.88	WMD Chapters 40A-2, 40C-2, 40D-2, 40E-2
1995	95CS377	AUTO SAMPLER	4,857.24	62-601.500(1), DO11-221557
1995	95CO102	PROCESS CALIBRATOR	4,197.70	62-600.410(6), 62-555.350(1), HRS, FDEP*62-550, 601
		Subtotal	634,503.89	
		TOTAL	\$8,059,385.02	

F:\Engineer\SB\JDW\docs\153-C.doc (Rev.3/19/96)

- C.O. - Consent Order
- Char. Co. Agmt. - Charlotte County Agreement
- DO - Domestic Operating
- DT - Domestic Temporary
- FS - Florida Statutes
- NNC - Notice of Non-Compliance
- NWWMD - Northwest Florida Water Management District
- OGC - Office of General Counsel
- SFWMD - South Florida Water Management District
- SJRWMD - St. Johns River Water Management District
- SWFWMD - Southwest Florida Water Management District
- TOP - Temporary Domestic Operating

EXHIBIT (BR-1)

PAGE 24 OF 24

Year	Project	Description	Plant In Service Amount	Regulatory Mandate
------	---------	-------------	-------------------------	--------------------

WL - Warning Letter



**Southern States Utilities, Inc. - Central Region**  
**1995 Filed and Actual FPSC Plant in Service Additions (w/o General Plant)**  
**As of December 31, 1995**

Project #	Project Description	In-Service Date		In-Service Amount	
		Filed	Actual	Filed	Actual
<b>APPLE VALLEY</b>					
95CC701	LEAD AND COPPER CONTROL		Expensed	6,578	0 (a)
95CC306	REPLACE MAIN ELEC BREAKER	04/30/95	12/20/95	1,429	1,142
	<b>Total Apple Valley - Water</b>			<b>8,006</b>	<b>1,142</b>
<b>BAY LAKE ESTATES</b>					
95CC307	WTP BUILDING		Cancelled	1,786	0
	<b>Total Bay Lake Estates - Water</b>			<b>1,786</b>	<b>0</b>
<b>CARLTON VILLAGE</b>					
94CC017	HYDRO TANK & NEW WELL	08/15/95		117,469	0
94CC018	DISTRIBUTION SYS UPGRADE	05/15/95	08/09/95	106,909	98,075
	<b>Total Carlton Village - Water</b>			<b>224,377</b>	<b>98,075</b>
<b>CENTRAL REGION PLANT</b>					
95CC202	WATER SERVICES	12/31/95	12/29/95	133,937	59,809
95CC203	NEW METERS/CHANGE OUT PRG	12/31/95	12/29/95	107,582	89,996
95CC331	CHLORINATR/BSTR PMP/EJETR	01/31/95	12/20/95	12,015	12,015
95CC201	WATER MAIN EXTENSIONS	12/31/95	12/29/95	5,953	16,131
95CC200	FIRE HYDRANTS	12/01/95	12/29/95	2,143	4,419
	<b>Total Water</b>			<b>261,629</b>	<b>182,371</b>
95CC204	HAND RAILS/WALKWAY	05/31/95	12/28/95	81,852	78,721
	<b>Total Wastewater</b>			<b>81,852</b>	<b>78,721</b>
	<b>Total Central Region</b>			<b>343,481</b>	<b>261,092</b>
<b>CHULUOTA</b>					
94CC019	COLLECTION SYSTEM UPGRADE	08/28/95	04/07/95	202,138	229,226
	<b>Total Chuluota - Wastewater</b>			<b>202,138</b>	<b>229,226</b>
<b>DELTONA LAKES</b>					
93CN660	WELLINGTON WTP EXPANSION	10/12/95		1,365,786	0
93CN661	AGATHA/SAXON WTP IMPRV	09/14/95		284,873	0
93CN659	SAGAMORE DR WTP DIST SYS	12/12/95		232,790	0
95CC353	PULL WELL TURBINES (4)	05/31/95	10/26/95	38,096	42,773
95CC352	REPLACE 4" WATER MAIN	02/28/95	07/28/95	35,715	9,763
95CC351	MASTER METERS	05/31/95	12/29/95	21,429	21,023
95CC705	VOLUSIA CTY/DOT UTILITY	Cancelled		13,290	0 (c)
95CC349	REPLACE VALVES - DIST SYS	Cancelled		11,857	0
95CC341	ROOF REPLACEMENTS (5)	01/31/95	08/04/95	4,464	5,029
95CC340	CORROSION CONTROL EQUIP	Cancelled		3,572	0
95CC342	TELEMETRY EQUIPMENT	01/31/95	04/04/95	2,527	2,427
	<b>Total Water</b>			<b>2,014,400</b>	<b>81,016</b>
94CN046	FP&L EASEMENT EFF IRG SYS	09/20/95	06/30/95	726,332	604,035
94CN341	DHCC - EFF DISP IMPROVE	05/26/95		330,625	0
95CC350	ENTERPRISE SCHOOL L/S 016	03/31/95	12/07/95	17,727	19,183
95CC348	L/S AT BRISTOL CT - 006	02/28/95	11/22/95	11,830	12,723
95CC347	TELEMETRY EQUIP UPGRADE	03/31/95	04/18/95	9,131	8,769
95CC346	DELTONA LK ELM L/S - #024	04/30/95	12/19/95	8,928	9,088
95CC345	ANTILLES L/S - 002	01/31/95	06/30/95	6,251	6,364
95CC344	JESSAMINE COURT L/S - 013	02/28/95	10/30/95	6,113	7,069
95CC338	FOUNTAINHEAD L/S - 004	01/31/95	06/30/95	2,769	2,819
95CC339	L/S AT CONDO B - #022	03/31/95	12/19/95	2,769	5,478
95CC342	TELEMETRY EQUIPMENT	01/31/95	04/04/95	2,527	2,426
	<b>Total Wastewater</b>			<b>1,125,002</b>	<b>677,953</b>
	<b>Total Deltona Lakes</b>			<b>3,139,402</b>	<b>758,969</b>

(a) Completed and expensed rather than capitalized.

(b) Reflects completion of a phase, but not entire project.

(c) Not required because gov't authority did not perform it's project.

(d) Refers to Refundable Advance, with zero rate base impact.

**Southern States Utilities, Inc. - Central Region**  
 1995 Filed and Actual FPSC Plant in Service Additions (w/o General Plant)  
 As of December 31, 1995

Project #	Project Description	In-Service Date		In-Service Amount	
		Filed	Actual	Filed	Actual
<i>EAST LAKE HARRIS EST.</i>					
94CC022	DISTRIBUTION SYSTEM UPGRADE	06/13/95	06/16/95	262,782	248,010
94CC023	PLANT IMPROVEMENTS	04/10/95	06/09/95	226,744	247,327 (b)
<i>Total East Lake Harris Est. - Water</i>				<u>489,526</u>	<u>495,337</u>
<i>FERN PARK</i>					
94CC457	REPLACE HYDRO TANK	03/31/95	01/19/95	24,830	24,107
<i>Total Fern Park - Water</i>				<u>24,830</u>	<u>24,107</u>
<i>FOUNTAINS</i>					
95CC706	LEAD AND COPPER CONTROL	Expensed		1,973	0 (a)
<i>Total Fountains - Water</i>				<u>1,973</u>	<u>0</u>
<i>GRAND TERRACE</i>					
95CC708	LEAD AND COPPER CONTROL	Expensed		1,973	0 (a)
<i>Total Grand Terrace - Water</i>				<u>1,973</u>	<u>0</u>
<i>HARMONY HOMES</i>					
94CC027	DISTRIBUTION SYS UPGRADE	02/27/95	02/14/95	35,619	29,064
<i>Total Harmony Homes - Water</i>				<u>35,619</u>	<u>29,064</u>
<i>LAKE AJAY</i>					
95CC356	FENCE PROPERTY	04/30/95	12/29/95	4,762	841
<i>Total Lake Ajay - Water</i>				<u>4,762</u>	<u>841</u>
<i>LAKE BRANTLEY</i>					
94CC030	HYDRO TANK AND AERATOR	04/24/95	05/31/95	123,371	120,584
<i>Total Lake Brantley - Water</i>				<u>123,371</u>	<u>120,584</u>
<i>LAKE HARRIET</i>					
95CC358	REPLACE AERATOR TRAYS	07/31/95	10/12/95	17,262	14,994
95CC357	ELECTRIC PANEL UPGRADE	07/31/95	12/06/95	4,762	4,998
<i>Total Lake Harriet - Water</i>				<u>22,024</u>	<u>19,992</u>
<i>MEREDITH MANOR</i>					
95CC391	STORAGE TANK DOME	Cancelled		23,810	0
95CC390	REPLACE ROOF	06/30/95	05/24/95	3,572	1,122
<i>Total Meredith Manor- Water</i>				<u>27,382</u>	<u>1,122</u>
<i>PINE RIDGE ESTATES</i>					
94CC414	WELL PUMP UPGRADE	02/27/95	03/07/95	14,323	12,465
95CC716	LEAD AND COPPER CONTROL	Expensed		1,973	0 (a)
<i>Total Pine Ridge Estates- Water</i>				<u>16,296</u>	<u>12,465</u>
<i>SILVER LAKE EST./W. SHORES</i>					
94CC032	WTP & DIST. IMPROVEMENT	11/09/95		862,100	0
<i>Total Silver Lake/W. Shores - Water</i>				<u>862,100</u>	<u>0</u>

(a) Completed and expensed rather than capitalized.  
 (b) Reflects completion of a phase, but not entire project.  
 (c) Not required because gov't authority did not perform it's project.  
 (d) Refers to Refundable Advance, with zero rate base impact.

**Southern States Utilities, Inc. - Central Region**  
**1995 Filed and Actual FPSC Plant in Service Additions (w/o General Plant)**  
**As of December 31, 1995**


Project #	Project Description	In-Service Date		In-Service Amount	
		Filed	Actual	Filed	Actual
<i>SUGAR MILL CC</i>					
95CC721	LEAD AND COPPER CONTROL		Expensed	6,578	0 (a)
95CC426	OVERHAUL #2 PUMP	01/31/95	03/23/95	4,149	3,983
95CC425	REPLACE CHLORINATOR	01/31/95	02/28/95	3,572	3,849
95CC423	REPLACE ROOF	02/28/95	02/28/95	2,976	3,029
	Total Water			17,274	10,862
95CC428	REPLACE CONTROL PANEL (2)	03/31/95	07/01/95	10,238	6,336
95CC427	REPLACE PUMPS	02/28/95	03/24/95	8,691	8,326
95CC424	REWORK BLOWERS (2)	02/28/95	05/15/95	3,214	3,267
95CC422	CHLORINE CYLINDER SCALE	01/31/95	02/23/95	617	544
	Total Wastewater			22,760	18,473
	Total Sugar Mill CC			40,034	29,335
<i>SUNSHINE PARKWAY</i>					
94CC512	WTP IMPROVEMENTS	11/15/95	11/02/95	189,952	161,687
94CC033	PRETREATMENT REPAIR	01/30/95	03/09/95	64,779	69,529
	Total Sunshine Parkway - Water			254,732	231,217
<i>TROPICAL PARK</i>					
94CC034	HYDRO TANK REPLACEMENT	09/28/95		46,718	0
	Total Tropical Park - Water			46,718	0
<i>UNIVERSITY SHORES</i>					
95CC724	LEAD AND COPPER CONTROL	11/15/95		40,251	0
	Total Water			40,251	0
94CC083	CHAPEL HILL CEMETERY UPGR	01/31/95	01/28/95	29,997	29,780
94CC507	MASTER LIFT STATION HOIST	03/31/95	12/30/94	5,629	3,094
	Total Wastewater			35,626	32,873
	Total University Shores			75,877	32,873
<i>WINDSONG</i>					
95CC727	LEAD AND COPPER CONTROL		Expensed	1,973	0 (a)
	Total Windsong - Water			1,973	0
Total 1995 Plant In-Service Additions - As Filed in MFR's				5,948,380	2,345,440
Less: Non-FPSC Plants Project Allocation Adjustments				(99,357)	
Total Per MFR's				5,849,023	

(a) Completed and expensed rather than capitalized.

(b) Reflects completion of a phase, but not entire project.

(c) Not required because gov't authority did not perform it's project.

(d) Refers to Refundable Advance, with zero rate base impact.



FLORIDA PUBLIC SERVICE COMMISSION  
 DOCKET NO. 950495 EXHIBIT NO. 222  
 COMPANY/  
 WITNESS:  
 DATE: 4/29/96

**ViroGroup**

AIR • WATER • SOIL TECHNOLOGY  
 DRN BY: CAM DWG. NO. A-013183KB-5 DATE: 3/13/96  
 PROJECT NAME: SSU - MARCO ASR NUMBER: 01-03183.00

HORIZONTAL EXTENT OF INJECTED WATER, AS C/C<sub>0</sub>, IN THE LOWER HAWTHORN BASAL TRANSMISSIVE UNIT AFTER INJECTING AT A RATE OF 2.5 MILLION GALLONS PER DAY FOR 1,000 DAYS. C/C<sub>0</sub> OF 0.4 INDICATES 40 PERCENT INJECTED, 60 PERCENT NATIVE WATER.

DOCUMENT NUMBER - DATE  
 03406 MAR 21 96  
 FPSC-RECORDS/REPORTING

PERMITTING AND CONSTRUCTION OF PUBLIC WATER SYSTEMS  
DEP 62-555.320(5)(c) 12/94

PART III: CONSTRUCTION, OPERATION, AND MAINTENANCE

supported by an engineering study certified by a professional engineer registered in the State of Florida that the hypochlorination facility would be safer than a gas chlorination system, that it would be as reliable as a gas chlorination system, and that a chlorine residual can be maintained continuously throughout the system.

(6) Auxiliary Power.

(a) Community systems that serve 350 or more persons, or have 150 or more service connections, shall provide auxiliary power for operation of the source, treatment units and pumps at a rate equal to one-half maximum daily flow.

(b) The auxiliary power requirements may be met by providing:

1. a connection to at least two independent power lines, or
2. an interconnection to at least one other public water supply system that has sufficient reserve capacity, or
3. in-place auxiliary power which, together with storage capacity, meets the requirements of Paragraph (a). In-place auxiliary power sources shall be equipped with an automatic start-up device. Portable power without an automatic start-up device may be provided where 24 hour, 7 days per week supervision is provided.

(c) The auxiliary power source shall be operated at least once per month continuously for a minimum of four hours under load to ensure dependability.

(d) For demineralization type systems such as reverse osmosis or electro dialysis, source, distribution, pumping and disinfection capability requirements only apply.

(e) Each community water system shall maintain a written auxiliary power plan that details how it meets the requirements of this subsection. This plan shall be available for review by the Department during the time of a routine sanitary survey.


(7) High Service Pumps - High service pumping and distribution facilities shall be designed to provide maximum hourly system demand without either development of a distribution pressure lower than 20 psi or other health hazards. Elevated storage with appropriate hydraulic characteristics may be combined with service pumping units or distribution components to meet this system demand.

(8) Meters - All community water systems shall be equipped with a metering device that accurately indicates pumpage of finished water. Non-community and non-transient non-community systems shall be equipped with at least an elapsed time clock or other device in conjunction with field calibration of the pump that will permit determination of flow.

(9) Piping - All pump intake lines located outside of the water treatment plant building shall be located above grade or otherwise be protected from infiltration. The system shall demonstrate that the below grade lines will have a positive head greater than the pump inlets at their volutes under all operating conditions.

CIRCUIT FOR HARDY-CROSS ANALYSIS

7-21-61



CAM

	LINE	LENGTH	DIAM	C	ASSUMED Q	$h_c/1000'$	TOTAL	$h_c/Q$	$\Delta Q$	NEW Q			
					GM7	C=100	$h_c (ft)$			GM7			
TRIAL 1													
I	A B	3,000	16"	100	1920	2.2	2.8	0.005	+ 41	1961			
	B C	7,000	16"	100	1500	3.0	14.0	0.009	+ 41	1541			
	C D	3,500	16"	100	850	0.7	2.5	0.029	+ 41	891			
	D E	6,000	16"	100	200	0.1	0.6	0.003	+ 41	241			
* A E R					9,000	8"	100	350	4.3	38.7	0.111	- 157	193
II	* A E R	9,000	8"	100	350	4.3	38.7	0.111	- 157	193			
	E F R	5,000	8"	100	150	0.9	4.5	0.030	- 116	39			
	A G	4,000	16"	100	1554	2.2	8.8	0.006	+ 116	1670			
	G F	6,200	16"	100	499	0.3	1.9	0.009	+ 116	610			
$\Delta Q = \frac{h_c - h_c'}{1.85 \times (0.157)}$													
TRIAL 2													
I	A B	3,500	16"	140	1961	1.8	6.3	0.003	- 125	1836			
	B C	7,000	16"	140	1591	3.3	9.1	0.006	- 125	1466			
	C D	3,500	16"	140	891	0.44	1.5	0.002	- 125	766			
	D E	6,000	16"	140	241	0.08	0.5	0.002	- 125	116			
* A E R					9,000	8"	140	193	0.72	6.5	0.028	+ 137	320
II	* A E R	9,000	8"	140	193	0.72	6.5	0.028	+ 127	320			
	E F R	5,000	8"	140	37	0.06	0.3	0.009	+ 2	36			
	A G	4,000	16"	140	1670	1.4	5.6	0.003	- 2	1668			
	G F	6,200	16"	140	610	0.24	1.7	0.002	- 2	608			
$\Delta Q = \frac{h_c - h_c'}{1.85 \times (0.028)}$													
TRIAL 3													
I	A B	3,500	16"	140	1836	1.9	6.7	0.009	+ 36	1872			
	B C	7,000	16"	140	1466	0.9	6.3	0.004	+ 36	1502			
	C D	3,500	16"	140	766	0.3	1.1	0.001	+ 36	802			
	D E	6,000	16"	140	116	0.04	0.2	0.002	+ 36	152			
* A E R					9,000	8"	140	320	2.1	18.9	0.059	- 53	267
II	* A E R	9,000	8"	140	320	2.1	18.9	0.059	- 53	267			
	E F R	5,000	8"	140	36	0.06	0.3	0.008	- 89	30			
	A G	4,000	16"	140	1668	1.5	6.0	0.004	+ 89	1757			
	G F	6,200	16"	140	608	0.2	1.2	0.002	+ 89	697			
$\Delta Q = \frac{h_c - h_c'}{1.85 \times (0.059)}$													

HARRY CROSS ANALYSIS

2-28-64




LINE	LENGTH FT	DIAM (INCHES)	C	ASSUMED		TERR h	h/R	ΔQ	Q
				Q	h/1000'				
Trial 1									
I	00	16	140	1872	18	6.3	0.003	-37	1833
	06	16	140	1752	11	7.2	0.005	-35	1713
	10	16	140	1632	2.35	1.3	0.002	-38	1613
	06	16	140	1512	0.05	0.3	0.002	-37	1513
	06	8	140	267	1.3	11.7	0.043	+2	269
							0.005		
II	06	8	140	267	1.3	11.7	0.043	+2	269
	11	8	140	310	0.05	0.35	0.008	+37	310
	06	16	140	1757	1.6	6.7	0.004	+37	1734
	06	16	140	627	0.3	1.9	0.100	+37	734
				$AGQ = \frac{117 \cdot 16 \cdot 140}{(117 \cdot 16 \cdot 140)} = \frac{2.6}{117} = 0.022$					
				$AGQ = \frac{117 \cdot 8 \cdot 140}{(117 \cdot 8 \cdot 140)} = \frac{1.3}{117} = 0.011$					
Trial 5									
I	06	16	140	1833	17	5.85	0.003	-17	1816
	06	16	140	1713	10	7.0	0.004	-17	1696
	10	16	140	1613	0.85	1.33	0.003	-17	1616
	06	16	140	1513	0.05	0.30	0.003	-17	1516
	06	8	140	269	1.4	12.60	0.007	-19	250
				$AGQ = \frac{1260 \cdot 16 \cdot 140}{(1260 \cdot 16 \cdot 140)} = \frac{1.4}{111} = 0.012$					
II	06	8	140	269	1.4	12.60	0.007	-19	250
	06	8	140	30	0.05	0.35	0.008	-36	136
	06	16	140	1724	1.7	6.8	0.004	+35	1730
	06	16	140	754	0.33	1.0	0.003	+36	770
				$AGQ = \frac{171 \cdot 16 \cdot 140}{(171 \cdot 16 \cdot 140)} = \frac{0.004}{111} = 0.004$					
Trial 6									
I	00	16	140	1816	17	5.85	0.003	-12	1804
	06	16	140	1696	0.96	6.73	0.003	-31	1661
	10	16	140	1616	0.30	1.16	0.003	-31	1614
	06	16	140	1516	0.05	0.30	0.003	-31	1514
	06	8	140	270	1.2	10.8	0.003	+29	279
				$AGQ = \frac{10.8 \cdot 16 \cdot 140}{(10.8 \cdot 16 \cdot 140)} = \frac{0.003}{111} = 0.003$					
II	06	8	140	270	1.2	10.8	0.003	+29	279
	06	8	140	126	0.33	1.65	0.013	+3	129
	06	16	140	1533	1.70	6.7	0.004	+3	1533
	06	16	140	770	0.34	2.01	0.003	+3	771
				$AGQ = \frac{10.8 \cdot 16 \cdot 140}{(10.8 \cdot 16 \cdot 140)} = \frac{0.003}{111} = 0.003$					
Trial 7									
I	00	16	140	1816	18.0	6.30	0.003	-29	1805
	06	16	140	1704	1.0	7.0	0.004	-29	1695
	10	16	140	1616	0.30	1.05	0.001	-29	1585
	06	16	140	1516	0.05	0.30	0.003	-29	1515
	06	8	140	279	1.30	11.70	0.003	+21	300
				$AGQ = \frac{11.70 \cdot 16 \cdot 140}{(11.70 \cdot 16 \cdot 140)} = \frac{0.003}{111} = 0.003$					
II	06	8	140	279	1.30	11.70	0.003	+21	300
	06	8	140	139	0.35	1.25	0.012	+8	140
	06	16	140	1833	1.7	6.8	0.004	+8	1840
	06	16	140	773	0.35	2.17	0.003	+8	780
				$AGQ = \frac{11.70 \cdot 16 \cdot 140}{(11.70 \cdot 16 \cdot 140)} = \frac{0.003}{111} = 0.003$					




LINE	LENGTH 1000 FT	DIAM INCHES	C	ASSUMED Q GPM	h <sub>f</sub> /1000'	TOTAL h <sub>f</sub>	h <sub>f</sub> /Q	ΔQ	NEXT Q
TABLE B									
I	AB	3.5	16	180	180	6.3	0.003	-12	184.3
	BC	7.0	10	140	133.5	6.58	0.005	-12	132.3
	CD	3.5	16	140	68.5	3.15	0.005	-12	67.3
	DE	6.0	16	140	35	—	—	-12	23
	AE	9.0	B	140	306	15.3	0.051	-19	280
	ΔQ	$\frac{16.3 - 25.3}{(180 + 133.5 + 68.5 + 35)} = \frac{-9}{416.5} = -0.0216$					0.069		
II	AF	7.0	B	140	300	17	0.051	-19	280
	EF	15.0	B	140	137	140	0.015	+31	165
	AE	10	16	140	140	6.8	0.004	+31	177
	GF	6.2	16	140	280	39	0.023	+31	210
	ΔQ	$\frac{10.3 - 15.3}{(300 + 137 + 140 + 280)} = \frac{-5}{857} = -0.0058$					0.023		
TABLE C									
I	AG								
	BC								
	CD								
	DE								
	AE								
	AC								
	AD								
	AE								
	GF								



# Modeling, Analysis, and Design of Water Distribution Systems



Lee  
Cesario



American Water Works Association



## Modeling

**Early computer models and programs.** Analog models consisting of electronic circuitry were used in the 1950s. Computer programs for network modeling began to appear in the 1960s. Often called mathematical models, these models consisted of a network solver (i.e., a network solution program or network modeling system) and a network data file. The network solver performed the calculations and provided results based on the network data file, which described the physical components of the network.

**Advantages of using computer modeling.** As simple and slow as the early computer programs were, they were still a faster and more efficient means of computing pressures, flows, and velocities in pipelines than manual methods. In addition, computer programs made it feasible to solve larger networks. Manual Hardy Cross calculation methods were just too time consuming to be used on networks containing more than a few loops. Thus, computer programs made it feasible to study larger systems and so enabled the engineer or planner to spend more time thinking and less time on tedious, time-consuming calculations. Computer modeling allowed analysis of larger systems in a time-saving, cost-effective manner.

**Advancements in computer modeling packages.** With time, additional capabilities were added to standard network solution programs. For example, sophisticated routines to generate pressure contours, reservoir use graphs, pumping costs, and automated hydrant flows were developed. Of course, the introduction of graphics, including the ability to generate network plots (drawings) and display pressure and flow values, was one of the first major additions to traditional capabilities.

**Steady-state and extended-period simulations.** Early modeling applications focused primarily on steady-state conditions. *Steady-state* refers to conditions that remain constant with time. For example, it was common to model only maximum-hour and minimum-hour conditions. Maximum hour represents the highest consumption during a one-hour period for the entire year. Minimum hour, sometimes referred to as replenishment, represents the lowest consumption during a one-hour time period. Thus, to provide steady-state solutions, the system would be modeled for each time period separately. Maximum hour would represent the time period during which the system would be most stressed, whereas replenishment was modeled to ensure that reservoirs could be refilled; sometimes pipeline usage is greater during replenishment when reservoirs are being refilled and nighttime demands are being met.

Today, extended-period simulation (EPS) refers to simulating the system for many consecutive time periods, e.g., 24 hourly time periods in a single day. Thus, it is assumed that flows and pressure are constant for the interval of time between solutions—an hour in this case. EPS can be especially useful for studying the operation of small systems. Flow in and out of tanks on an hourly basis, hourly pump rates, and hourly flow rates in pipes can be determined easily; facility sizing can therefore be done more effectively. Thus, pressure and flow values for the mystery time periods occurring between maximum hour and replenishment can be determined. Of course, EPS can be applied to large distribution systems, but the amount of data required increases substantially and calibration becomes more difficult.

**The changing role of consultants.** In the early years, network analysis programs were expensive and required considerable maintenance; as a result,

they were beyond the resources of most water utilities. Utilities would hire an engineering consulting firm to develop a master plan. The consultant would develop a model of the water system and use that model to develop the plan. In some cases the model would be turned over to the utility, and in other cases the consulting firm would retain the model, update it periodically, and use it to solve other problems as requested by the utility.

As the price of network solution packages and computer hardware decreased, more and more water utilities purchased their own packages and created their own network databases. Today, all utilities can afford the price of a modeling package. In fact, the trend seems to be that a utility cannot afford *not* to have one. The challenge today is in creating and maintaining the database and managing the tools, support, and applications.

## Applications

The use of models, or applications, has also evolved over the years as technology has improved. The results of the Treated-Water System Modeling Questionnaire (appendix D) show that 63 percent of utilities that have a model use it at least monthly and often weekly for a wide variety of applications. The results also show that models are most often used by the engineering group (250 responses), followed by planning (106) and operations (76). Historically, the group with the expertise generally does most of the modeling. It is interesting to note the number of times that operations groups use the models. Chapter 8 goes into detail about numerous applications. The following is a brief overview of some of these applications.

**Pipe sizing.** Early applications of computer models focused on sizing a particular pipe proposed as part of new development. A calibrated model of the system provided the benchmark, or starting point. System performance could be studied for current demand and for the new demand created by the new development. Various combinations of routing and sizing of the new pipe could be simulated relatively easily at a minimal cost (relative to the cost of installing the new main) to arrive at an "optimal" solution of route and size. The potential to save money was great. Without a model, a designer might tend to oversize the main to be safe. Modeling provided a more scientific method of properly sizing mains and other facilities.

**Master plan.** The next step was development of a master plan for the water system's future. Modeling allowed a systematic method of determining the size and timing required for new facilities. Thus, a size, schedule, and cost could be determined for the facilities necessary to meet a projected demand for a particular time in the future. The plan was often associated with a specific year, but it could have been developed for a particular future demand regardless of the expected year. Computers allowed numerous scenarios to be analyzed relatively quickly and easily.

**Operations studies.** Models also provided a sophisticated means to study current operations and thus help solve current operations problems. Plans could be developed to solve problems that were causing low pressure in particular areas, to plan for facility outages, and to examine emergency "what if" situations; thus, the industry entered the age of using models to develop operations strategies.

**In-house modeling and system integration.** Because of the decreasing costs of software and hardware, many utilities have eagerly developed their own models and maintain them. Thus, in-house experts create, maintain, and

use models on a regular basis in many utilities. Vendors and engineering consultants are still used, but in a somewhat different capacity. For instance, conversion of existing network data and data file creation are often done by consultants. Of course, master plans are still developed, but now time and effort are often focused on integrating the network modeling package with other packages, such as a supervisory control and data acquisition (SCADA) system, a geographic information system (GIS), and a customer information system (CIS).

## Modeling From Various Perspectives

For one to understand the importance of modeling and the significance it can have throughout a water utility, it helps to imagine wearing different hats and being responsible for different organizational functions. One's perspective on modeling differs depending on one's position and job duties. The following is a discussion of modeling from the perspectives of planning, engineering, operations, and management (Cesario 1991).

### Planning

Planning is the process of examining the present, recognizing trends, making projections, and designing programs to meet established goals. In other words, planning is generally the process of developing plans, maintenance programs, and policies to ensure adequate service to customers in the future. Modeling is the basis for preliminary design in terms of sizing and phasing new facilities and maximizing use of existing facilities. Models can also be used to compare existing system performance to that under various scenarios. \*

For the chief planner, modeling should form the basis for numerous programs, such as the main rehabilitation program, system improvement program, long-range capital plan, annual capital plan, fire flow studies, water availability studies, system design criteria, and emergency planning. Modeling can be used to determine new facility requirements to maintain present pressure standards, determine pressure increases resulting from the installation of a new facility, estimate operating costs, track water from various sources, and perform a myriad of other applications.

Modeling is a tool to examine system performance and provide answers to "what if" questions. If a major facility must be taken out of service, what operational changes, if any, must be made to the system? What if the primary and secondary sources of raw water are reversed from year to year? What treated-water system operations will be necessary to maximize use of the source?

Modeling can be used to assess the impact of a major new development, such as a shopping center or airport, and to determine facility requirements. Flow to meet fire demand requirements can be modeled to determine system performance characteristics and operations changes. Modeling also provides a basis for developing a master plan and system design. Pressure zones, facilities, and operations can be planned, implemented, and examined before changes are made to the real system.

Modeling can be used to examine how the water system currently operates and to determine operations strategies that will maximize use of the

system and minimize operating costs. The effects of possible conservation plans can also be studied.

**Engineering.** Engineering is responsible for final sizing, designing, building, and inspecting of the facility and turning it over to operations personnel. What use is modeling to the chief of engineering? Modeling, usually done by the planning people, provides the base data — a solid starting point — for design. Values for pipe size, tank capacity, high water elevation, and pump capacity and head are all determined during the modeling and design stages. Engineers must therefore work with the planning department to design facilities that will meet the overall systemwide specifications.

**Operations.** Operations is concerned about utilizing the existing distribution system to provide adequate supply and pressure to customers, to meet emergency situations, and to meet operational strategies. The use of models by the planning department or the operations people themselves can provide insight into these issues, and it is operations people who provide data for the modeler. Furthermore, models can be excellent training tools for operators.

**Management.** Managers should be especially concerned about modeling because it is the technical backbone of programs and policies. Modeling provides a foundation for programs and policies and gives numbers and values to justify them. It provides a basis for developing such vital features as the system improvement program, the capital plan, the main rehabilitation program, and the operations plan; and it helps determine equipment requirements and the resulting costs for system improvements. Modeling also provides an indication of when new facilities are required, which impacts income, revenue, and financing.


In addition to these applications, management must be concerned about data management and data maintenance because both are essential to developing answers accurately and quickly. Staffing, budgeting, coordinating, and other routine management functions apply to modeling and are important

Application	Organization Functional Area		
	Planning	Engineering	Operations
Capital budgeting	x		
Conservation studies	x		x
Emergency planning	x		x
Fire flow studies	x		
Long-range planning	x	x	
Main rehabilitation	x	x	x
Model calibration	x		x
Operations	x		x
Operations efficiency	x		x
Operator training			x
Planned outages	x	x	x
Pump station sizing	x	x	x
Reservoir siting	x	x	
Reservoir sizing	x	x	x
Source tracking	x		x
Substance tracking	x		x
System improvements	x	x	x
Valve sizing	x	x	x
Water quality	x	x	x

**Table 1-1**  
Applications and organization functions of network modeling







DISCLAIMER

Although each program has been tested by its contributor, no warranty, express or implied, is made by the contributor or 1620 USERS Group, as to the accuracy and functioning of the program and related program material, nor shall the fact of distribution constitute any such warranty, and no responsibility is assumed by the contributor or 1620 USERS Group, in connection therewith.



WATER FLOW IN A PIPE NETWORK BY HARDY CROSS SOLUTION

TABLE OF CONTENTS

Abstract	1
Program Description	2
Flow Chart	4
Input/Output Formats	8
Sample Problem	9
Operating Instructions	11
Program Listing	12

WATER FLOW IN A PIPE NETWORK BY HARDY CROSS SOLUTION

D.R. Wood  
Calgary Power Limited  
140 - 1st Avenue West  
Calgary, Alberta

Modifications or revisions to this program, as they occur, will be announced in the appropriate Catalog of Programs for IBM Data Processing Systems. When such an announcement occurs, users should order a complete new program from the Program Information Department.

1620 USERS GROUP LIBRARY

Program Abstract.

Title: Water Flow in a Pipe Network by Hardy Cross Solution.

Subject Classification: Engineering (Other) - 9.7

Author; Organization: D. R. Wood, Calgary Power Ltd.,  
140 - 1st Avenue West, Calgary, Alberta.

Purpose/Description: This program calculates the water flow in a pipe network by means of the Hardy Cross iterative technique. The IBM 1620 program, "Distribution of Water Flow in a Pipe Network", file number 9.7.001 solves the basic water flow problem but is limited because it was restricted to a 20,000 digit storage computer. This program has been rewritten with many modifications for a 40,000 digit storage computer. Some advantages of this program are: a different Hazen-Williams Coefficient can be used for each pipe eliminating the necessity of calculating an equivalent length of pipe for the one Hazen-Williams coefficient used; output consists of the corrected flow in gallons per minute and, in addition, the resistance factor and resultant pressure drop for each pipe. The accuracy control to stop calculations has been changed from "the sum of the absolute value of the correction currents for an iteration" to the maximum algebraic sum of the pressure drops (or error of closure) allowable around any one loop. In addition the larger storage allows the storing of the actual pipe numbers assigned and does not assume the sequential storing of the pipes thus allowing the same three digit number assigned to be used for the same pipe in all problems.

Computer: This program requires card input with a 40,000 digit storage computer. It was written in Fortran with format control ~~statements~~ and automatic divide.

Program Details:

- Range - A pipe network with up to 150 pipes and 70 loops can be calculated. This could be expanded with a small program modification.
- Storage Requirements - The entire 40,000 digits are used with the exception of the area from approximately 14,200 to approximately 24,000.
- Running Time - The data card reading time is about 1 3/4 seconds per card with the punching time at rated speed. If the output is desired on the typewriter it averages about 11 seconds per pipe. The calculating time is about 4/5 second per pipe per iteration with the number of iterations dependent upon the accuracy desired and the original flows estimated.

Water Flow Program Description

The program uses the Hardy Cross method using the Hazen-Williams pipe coefficient.

The formulae used are:

$$H = RQ^{1.85}$$

$$R = \frac{10.43 L}{C^{1.85} \times D^{4.87}}$$

Where H = head loss in feet  
Q = water flow in U.S. gallons per minute  
R = pipe resistance factor  
C = Hazen-Williams constant  
L = pipe length in feet  
D = pipe diameter in inches

$$\Delta Q = \frac{-\Sigma H}{1.85 \Sigma |RQ^{0.85}|}$$

Where  $\Delta Q$  = flow correction factor for loop  
H = the algebraic sum of the head loss around any loop. (Clockwise direction is arbitrarily chosen as positive).  
R and Q are defined above.

Note:- In this program it was desirable for the input and output of flow to be in imperial gallons. Therefore, immediately upon reading Q (Imp.) it is multiplied by 1.2009 to convert it to Q (U.S.) and stored. After calculations are completed Q is reconverted back to Imperial gallons. An alternative method would have been to change the basic formula for R to calculate the head loss directly from Imperial gallons. This was not done because R is printed and the value listed was more familiar. If it is desirable to have input and output in U.S. gallons the two conversion instructions indicated should be removed.


The program reads one master card followed by one detail card for each pipe. The master card contains the job number, the number of pipes, the number of loops and the accuracy desired. The accuracy is the maximum magnitude of the algebraic sum of the head loss around any one loop with clockwise flow arbitrarily chosen as positive. The detail cards contain the pipe number which may be any three digit number, the pipe diameter in inches, the Hazen-Williams constant, the pipe length in feet, the primary loop number,



the secondary loop number (which is 00 if there is no secondary loop), and the estimated water flow which is in Imperial gallons per minute in this program. After reading each pipe detail card the pipe resistance factor (R) is calculated and stored. It should be noted that although the pipe numbers are just an identification number and any three digit numbers may be used, the loop numbers must be continuous. For example, a problem with 10 loops must have them numbered 1 through to 10. A loop number of 12 would not be allowed in this problem.

After the last pipe detail card is read (controlled by a count of the number of pipes punched in the master card) the program calculates the head loss in each pipe. The head loss is then totaled around each loop and stored. If the error of closure around every loop is less than the accuracy desired, the results are either punched on cards or typed or both, as determined by the console switches. If the accuracy is not achieved, a flow correction ( $\Delta Q$ ) is calculated for each loop and applied to each pipe depending upon its primary and secondary loop numbers. After completing the flow adjustments a new head loss is calculated for each pipe and the entire procedure is repeated until the desired accuracy is achieved. If the results do not come out in what is considered to be a reasonable time, turning console switch number one to on will cause an output of the results after the next head loss calculations are completed. The first output card will list the job number, the number of iterations calculated, the accuracy desired, and the number of loops not closed to the accuracy desired. The number of loops not closed will be zero unless the output has been achieved by putting switch number one on. This first card is then followed by detail cards for each pipe giving information identical to the input cards with the exception of the corrected water flow and the addition of the pipe resistance factor and head loss. The output card is arranged in such a fashion that it could be used as input for some other problem if all details are applicable.


FLOW CHART

WATER FLOW CALCULATIONS









Input Format.

1. Master Card -

Column	Format	Description
1 - 4	xxxx	Job number
5 - 7	xxx	Number of pipes
8 - 9	xx	Number of loops
10 - 12	xxx	Accuracy in feet

Note: Although the accuracy is in the form xx.x feet the decimal point is not punched.

2. Pipe Detail Cards -

Column	Format	Description
2 - 4	xxx	Pipe number
7 - 8	xx	Pipe diameter in inches
13 - 15	xxx	Pipe Hazen-Williams constant
20 - 26	xxxxx.x	Pipe length in feet
42 - 43	xx	Primary loop number
47 - 48	xx	Secondary loop number
51 - 58	+ xxxxx.x	Pipe flow in Imperial gallons per minute

Note: Decimal points and signs are punched where indicated. If there is no secondary loop, 00 is punched for secondary loop number.


Output Format

The output is on punched card or typewriter or both depending upon the console switches. The program lists the answers in columns with headings. Listing the cards on a tabulator with a standard 80 column board will give the same output format as that on the typewriter. The card output is punched with the same format as the input and could therefore be used as new input for another problem if the values are reasonable and data correct. For example:- If output is obtained by turning switch number one on and the results seem reasonable but not quite accurate enough, the original master card followed by the output pipe detail cards will be acceptable for the input to a new pass through, thus continuing the calculation from the point where calculations had stopped.


Note: If the format does not seem to allow for the range of numbers desired a change in the Fortran Input and Output Format Statements should be made. It should also be noted that the numbers are "rounded off" before the output and may also have to be revised if any change is made to the size of numbers.

WATER FLOW - SAMPLE PROBLEM

PIPE NETWORK



PIPE ( LOOP NUMBERS WITH ESTIMATED FLOWS



INPUT INFORMATION -

JOB No. 423  
 No. OF PIPES 5  
 No. OF LOOPS 2  
 ACCURACY DESIRED 0.5'

- PUNCHING -

(REFER TO INPUT FORMAT - PAGE 8)

CARD COLUMN	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
MATER CARD	0	6	2	3	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0
DETAIL CARD #1	001	06			090			01000.0		01	00									
#2	002	06			120			00025.0		01	07									
#3	003	08			120			01000.0		01	00									
#4	004	06			120			01800.0		07	00									
#5	005	08			120			01000.0		07	00									

LOAD DATA  
 WATER NETWORK - FLOW CALCULATIONS

JOB NO.	ITERATIONS	ACCURACY	LOOPS NOT CLOSED
+623	+2	+5	+0

PIPE	DIA	C	LENGTH	R	PRI	SEC	Q	H
+1	+6.	+90.	+1000.0	+0.00041052	+1	+0	+163.0	+7.1
+2	+6.	+120.	+25.0	+0.00000603	+1	+2	+22.2	+0.
+3	+8.	+120.	+1000.0	+0.00010691	+1	+0	-337.0	-7.1
+4	+6.	+120.	+1800.0	+0.00042399	+2	+0	+90.8	+2.6
+5	+8.	+120.	+1000.0	+0.00005940	+2	+0	-259.2	-2.4

Operating Instructions

Console Settings:

Switch Number 1 on causes the results to be output before the desired accuracy is achieved.

Switch Number 2 in the off position causes the answers to be on punched cards.

Switch Number 2 in the on position results in the answers to be on the typewriter.

Switch Number 3 is used in conjunction with switch number 2 to obtain output on both punched cards and typewriter. For this condition switch No. 2 should be off and switch No. 3 on.

Procedure:

1. Set Console switches as desired (normally all off).
2. Clear machine, push reset, and load object deck followed by data cards.
3. "Load Data" will be typed out. Push start.
4. If two or more separate problems are to be done sequentially the start button must be pushed after each problem is completed.

```

ENTER SOURCE PROGRAM, PUSH START
C NOTE- SWITCH 1 ON - OUTPUT RESULTS OVERRIDING THE ACCURACY CONTROL
C SWITCH 2 OFF- OUTPUT ON PUNCHED CARDS
C SWITCH 3 ON - OUTPUT ON TYPEWRITER
C SWITCHES 2 AND 3 MAY BE USED TOGETHER FOR BOTH CARD AND TYPED OUTPUT
C 1 FORMAT(4,13,12,F3.1)
C 2 FORMAT(1X13,2XF2.0,4XF3.0,4XF7.1,15X12,3X12,2XF8.1)
C 3 FORMAT(22HJOB NO. ITERATIONSSXRHACCURACY6X16HLOOPS NOT CLOSED/
C 4 FORMAT(14HPIPE DIA CSX6HLENGT8X1HRGXSHPRI SEC6X1HG8X1HH/)
C 5 FORMAT(15,9X15,9XF5.1,14X14//)
C 6 FORMAT(14,1XF4.0,2XF5.0,2XF8.1,2XF10.8,2X13,2X13,2XF8.1,2XF7.1)
C 8 FORMAT(1X////)
C 85 FORMAT(33HWATER NETWORK - FLOW CALCULATIONS/)
C DIMENSION R(150),NO(150),D(150),C(150),AL(150),HP(150),NS(150)
C DIMENSION Q(150),H(150),SUMH(70),SUMD(70)
C 9 READ 1,JOBNO,N,L,ACC
C DO 10 I=1,N
C READ 2,NO(I),D(I),C(I),AL(I),HP(I),NS(I),Q(I)
C Q(I)=Q(I)*1.2009
C 10 R(I)=(10.43*AL(I))/(C(I)**1.85*D(I)**4.87)
C IT=0
C 11 DO 12 I=1,L
C SUMH(I)=0.0
C 12 SUMD(I)=0.0
C DO 20 I=1,N
C QW=0(I)
C IF (QW) 13,20,14
C 13 QW=-QW
C 14 DIV=R(I)*QW**0.85
C H(I)=DIV*QW
C IF (Q(I)) 15,20,16
C 15 H(I)=-H(I)
C 16 J=NP(I)
C K=NS(I)
C SUMH(J)=SUMH(J)+H(I)
C SUMD(J)=SUMD(J)+DIV
C IF (K) 20,20,17
C 17 SUMH(K)=SUMH(K)-H(I)
C SUMD(K)=SUMD(K)+DIV
C 20 CONTINUE
C M=0
C DO 30 I=1,L
C IF (SUMH(I)) 21,22,22
C 21 IF (SUMH(I)+ACC) 24,30,30
C 22 IF (SUMH(I)-ACC) 30,30,24
C 24 M=M+1
C 30 CONTINUE
C IF (M) 60,60,31
C 31 IF (SENSE SWITCH 1) 60,32
C 32 DO 40 I=1,L
C IF (SUMD(I)) 33,40,33
C 33 SUMD(I)=-SUMH(I)/(SUMD(I)*1.85)
C 40 CONTINUE
C DO 50 I=1,N
C J=NP(I)
C K=NS(I)
C IF (K) 42,42,41
C 41 Q(I)=Q(I)+SUMD(J)-SUMD(K)
C GO TO 50
C 42 Q(I)=Q(I)+SUMD(J)
C 50 CONTINUE
C IT=IT+1
C GO TO 11

```

```

12204      R()=R()+0.00000005
T288      F (Q()) 63,65,64.
T2368    63 Q(1)=Q(1)-0.05
T2452      H(1)=H(1)-0.05
T2536      GO TO 65
T2544    64 Q(1)=Q(1)+0.05
T2628      H(1)=H(1)+0.05
T2712    65 CONTINUE
T2748      IF (SENSE SWITCH 2) 70,61
T2768    61 PUNCH 85,
T2780      PUNCH 3,
T2792      PUNCH 5, JOBNO, IT, ACC, M
T2852      PUNCH 4,
T2864      DO 62 I=1, N
T2876    62 PUNCH 6, NO(1), D(1), C(1), AL(1), R(1), NP(1), NS(1), Q(1), H(1)
T3248      PUNCH 8,
T3260      IF (SENSE SWITCH 3) 70,80
T3280    70 PRINT 85,
T3292      PRINT 3,
T3304      PRINT 5, JOBNO, IT, ACC, M
T3364      PRINT 4,
T3376      DO 79 I=1, N
T3388    79 PRINT 6, NO(1), D(1), C(1), AL(1), R(1), NP(1), NS(1), Q(1), H(1)
T3760      PRINT 8,
T3772    80 PAUSE
T3784      GO TO 9
T3792      END

```

PROG SW 1 ONFOR SYMBOL TABLE, PUSH START

```

39999 SIN
39989 SIN
39979 COS
39969 COSF
39959 ATAN
39949 ATANF
39939 EXP
39929 EXPF
39919 LOG
39909 LOGF
39899 SQRT
39889 SQRTF
39879 UC01
39869 UC01
39859 UC00
39849 UC00
39839 UC03
39829 UC03
39819 UC04
39809 UC04
39799 UC05
39789 UC05
39779 UC06
39769 UC06
39759 UC08
39749 UC08
39739 UC85
39729 UC85
39719 R      38229
38219 NO     36729
36719 D      35229
35219 C      33729
33719 AL     32229
32219 NP     30729
30719 NS     29229

```

```

26219 SUMH 25529
25519 SUMD 24129
24819 UC09
24809 JOBNO
24799 N
24789 L
24779 ACC
24769 UC1C
24759 I
24749 T200900001
24739 UC00
24729 T043000002
24719 UC01
24709 T650000001
24699 UC03
24689 467000001
24679 UC04
24669 IT
24659 UC00
24649 UC11
24639 UC01
24629 UC000000009
24619 UC020
24609 OW
24599 UC13
24589 UC14
24579 DIV
24569 8500000000
24559 UC15
24549 UC16
24539 J
24529 K
24519 UC17
24509 M
24499 UC30
24489 UC21
24479 UC02
24469 UC04
24459 UC0T
24449 UC060
24439 UC31
24429 UC32
24419 UC40
24409 UC33
24399 UC50
24389 UC42
24379 UC41
24369 UC65
24359 8327088000
24349 UC000000008
24339 UC63
24329 UC64
24319 UC00000000T
24309 UC70
24299 UC61
24289 UC62
24279 UC6C
24269 UC79

```

SW 1 OFF TO IGNORE SUBROUTINES, PUSH START  
1620 FORTRAN SUBR. AUTO DIV 9/30/61  
PROCESSING COMPLETE

```

C NOTE- SWITCH 1 ON - OUTPUT RESULTS OVERRIDING THE ACCURACY CONTROL
C SWITCH 2 OFF- OUTPUT ON PUNCHED CARDS
C SWITCH 3 ON - OUTPUT ON TYPEWRITER
C SWITCHES 2 AND 3 MAY BE USED TOGETHER FOR BOTH CARD AND TYPED OUTPUT
1 FORMAT(14,13,12,F3,1)
2 FORMAT(1X13,2XF2.0,4XF3.0,4XF7.1,15X12,3X12,2XF8.1)
3 FORMAT(22HJOB NO. ITERATIONS5X8HACCURACY6X16HLOOPS NOT CLOSED/)
4 FORMAT(14HPIPE DIA C5X6HLENGHT8X1HR6X8HPR1 SEC6X1H08X1HH/)
5 FORMAT(15,9X15,9XF5.1,14X14//)
6 FORMAT(14,1XF4.0,2XF5.0,2XF8.1,2XF10.8,2X13,2X13,2XF8.1,2XF7.1)
8 FORMAT(1X////)
85 FORMAT(33HWATER NETWORK - FLOW CALCULATIONS/)
DIMENSION R(150),HO(150),D(150),C(150),AL(150),NP(150),NS(150)
DIMENSION Q(150),H(150),SUMH(70),SUMD(70)
9 READ 1,JOBNO,N,L,ACC
DO 10 I=1,N
READ 2,NO(I),D(I),C(I),AL(I),NP(I),NS(I),Q(I)
Q(I)=Q(I)*1.2009
10 R(I)=(10.43*AL(I))/(C(I)**1.85*D(I)**4.87)
IT=0
11 DO 12 I=1,L
SUMH(I)=0.0
12 SUMD(I)=0.0
DO 20 I=1,N
QW=Q(I)
IF (QW) 13,20,14
13 QW=-QW
14 DIV=R(I)*QW**0.85
H(I)=DIV*QW
IF (Q(I)) 15,20,16
15 H(I)=-H(I)
16 J=NP(I)
K=NS(I)
SUMH(J)=SUMH(J)+H(I)
SUMD(J)=SUMD(J)+DIV
IF (K) 20,20,17
17 SUMH(K)=SUMH(K)-H(I)
SUMD(K)=SUMD(K)+DIV
20 CONTINUE
H=0
DO 30 I=1,L
IF (SUMH(I)) 21,22,22
21 IF (SUMH(I)+ACC) 24,30,30
22 IF (SUMH(I)-ACC) 30,30,24
24 M=M+1
30 CONTINUE
IF (M) 40,60,31
31 IF (SENSE SWITCH 1) 60,32
32 DO 40 I=1,L
IF (SUMD(I)) 33,40,33

```

```

001 33 SUMD(I)=-SUMH(I)/(SUMD(I)*1.85)
002 40 CONTINUE
003 DO 50 I=1,N
004 J=NP(I)
005 K=NS(I)
006 IF (K) 42,42,41
007 41 Q(I)=Q(I)+SUMD(J)-SUMD(K)
008 GO TO 50
009 42 Q(I)=Q(I)+SUMD(J)
010 50 CONTINUE
011 IT=IT+1
012 GO TO 11
013 DO 65 I=1,N
014 Q(I)=Q(I)*0.8327088
015 R(I)=R(I)+0.000000005
016 IF (Q(I)) 63,65,64
017 63 Q(I)=Q(I)-0.05
018 H(I)=H(I)-0.05
019 GO TO 65
020 64 Q(I)=Q(I)+0.05
021 H(I)=H(I)+0.05
022 65 CONTINUE
023 IF (SENSE SWITCH 2) 70,61
024 61 PUNCH 85,
025 PUNCH 3,
026 PUNCH 5,JOBNO,IT,ACC,M
027 PUNCH 4,
028 DO 62 I=1,N
029 62 PUNCH 6,NO(I),D(I),C(I),AL(I),R(I),NP(I),NS(I),Q(I),H(I)
030 PUNCH 8,
031 IF (SENSE SWITCH 3) 70,80
032 70 PRINT 85,
033 PRINT 3,
034 PRINT 5,JOBNO,IT,ACC,M
035 PRINT 4,
036 DO 79 I=1,N
037 79 PRINT 6,NO(I),D(I),C(I),AL(I),R(I),NP(I),NS(I),Q(I),H(I)
038 PRINT 8,
039 80 PAUSE
040 GO TO 9
041 END.
042
043
044
045
046
047
048
049
050
051
052
053
054
055
056
057
058
059
060
061
062
063
064
065
066
070
071
072
074
075
076
077
078
080
081
082
083
084
085
086
087
088
089
090
091
092
093
094
095
096
097
098

```

United States  
Environmental Protection  
Agency

Office of  
Research and Development  
Cincinnati, OH 45268


EPA/625/6-91/030  
October 1991

Technology Transfer



# Handbook

## Sewer System Infrastructure Analysis and Rehabilitation



## CHAPTER 2

### Regulatory Requirements

#### 2.1 Historical Background

The Water Pollution Control Act Amendments (Public Law 92-500, October 18, 1972), require that the U.S. EPA construction grant applicants investigate the condition of their sewer systems. The grant cannot be approved unless it is documented that each sewer system discharging into such treatment works is not subject to "excessive infiltration and inflow." This requirement was implemented in the Rules and Regulations for Sewer Evaluation and Rehabilitation (40CFR35.927). In addition, I/I analysis and Sewer System Evaluation Surveys (SSES) were required to be conducted on a routine basis to document I/I, and also to indicate the most cost effective method of rehabilitation required to correct the sewer pipe and manhole structure damage.<sup>1</sup>

The I/I analysis should document the non-existence or possible existence of excessive I/I in each sewer system tributary to the treatment works. The analysis should identify the presence and type of I/I that exists in the sewer system including estimated flow rates. The following information should be evaluated and included:

- Estimated flow data at the treatment facility, all significant overflows and bypasses, and, if necessary, flows at key points within the sewer system
- Relationship of existing population and industrial contribution to flows in the sewer system
- Geographical and geological conditions which may affect the present and future flow rates or correction costs for the I/I
- A discussion of age, length, type, materials of construction and known physical conditions of the sewer system

The SSES should include a systematic examination of the sewer system to determine the specific locations, estimated flow rates, method of rehabilitation and cost of rehabilitation versus the cost of transportation and treatment for each defined source of infiltration and each defined source of inflow.<sup>1</sup> The results of the SSES should be summarized in a report that should include:<sup>2</sup>

- A justification for each sewer section cleaned and internally inspected
- A proposed rehabilitation program for the sewers system to eliminate all defined excessive I/I

#### 2.2 Summary of Applicable U.S. EPA and State Regulations

The following is a Summary of Federal and State Regulations and Guidelines for I/I analysis and SSES applicable under the U.S. EPA construction grant program.<sup>1,3</sup>

The grant applicant must determine the I/I conditions in the sewer system by analyzing the preceding year's flow records from existing treatment plant and pump stations. For smaller systems where flow records may not be available, the grant applicant shall obtain flow data by conducting flow monitoring at a single point at the treatment plant during high groundwater periods and also during rainstorms. If there is a likelihood of excessive I/I in a portion of the collection system, it is desirable to monitor that portion separately. No further I/I analysis will be necessary if domestic wastewater plus non-excessive infiltration does not exceed 120 gallons per capita per day (gpcd) during periods of high groundwater. The total daily flow during a storm should not exceed 275 gpcd, and there should be no operational problems, such as surcharges, bypasses or poor treatment performance resulting from hydraulic overloading of the treatment works during storm events. The flow rate of 120 gpcd for infiltration analysis contains two flow components: 80 gpcd of domestic base flow and 40 gpcd of non-excessive infiltration. This is a national average based on the results of a needs survey of 270 Standard Metropolitan Statistical Area Cities. Where the flow rate (domestic base flow and infiltration based on the highest 7 to 14 day average) does not significantly exceed 120 gpcd (in the range of 130 gpcd) the city may proceed with the treatment works design without further analysis. When infiltration significantly exceeds 120 gpcd, further evaluation of the sewer system must be performed to determine the possibility of excessive I/I through a cost effectiveness



**CAPACITY ANALYSIS REPORT**

**FOR**

**SUGARMILL WOODS  
WASTEWATER TREATMENT FACILITY**

**Citrus County, Florida**

**GMS NO. 4009P05400  
PERMIT NO. DO09-158879  
PLANT INSPECTION: JUNE 19, 1995**

**Prepared by:  
BERRYMAN & HENIGAR  
640 East Highway 44  
Crystal River, Florida 34429-4399**

**Prepared For:  
Southern States Utilities, Inc.  
1000 Color Place  
Apopka, Florida 32703**

**OCTOBER 1995**



Richard D. Garrity, Ph.D.  
August 7, 1995  
Page 3

The remaining, permitted work that will be constructed at a later date includes: the second clarifier and the additional sprayfield (expansion from 33 acres to 53.35 acres). The reasons for delaying the construction of these items are presented below:

#### Second Clarifier

The maximum three month average daily flow (M3MADF) for the years 1992, 1993, 1994, and 1995 was 0.264 mgd, 0.242 mgd, 0.260 mgd, and 0.294 mgd, respectively. These flows are significantly less than the flow projections presented in the Engineering Report. Because the existing single clarifier is capable of handling 0.4 mgd, the construction of the second clarifier is not needed, at this time, and has therefore been delayed. According to current projections, the second clarifier will need to be constructed in early 1998. The RAS and WAS improvements would be made concurrent with the construction of the second clarifier.

#### Sprayfield Expansion

The effluent sprayfield was originally permitted for 1.5 mgd on 50 acres, at a loading rate of approximately 7.5 inches per week. At this rate, the existing 33-acre sprayfield would have a capacity of approximately 0.99 mgd. Because this capacity is greater than the current plant flows (0.294 mgd, M3MADF for 1995), the construction of the remaining 20.35 acres of sprayfield has been postponed. A revised hydrogeological study for the 33-acre site, only, is currently being prepared. This report will include a revised groundwater monitoring plan for the 33 acre site. Based on the latest flow projections, the sprayfield expansion will not be required for at least ten years.

Based on the information presented above, SSU would like to modify the construction schedule included as Specific Condition No. 25 of the Operating permit. We have completed DEP form 62-620.910(9) "Application for a Minor Revision to a Wastewater Facility Permit" for this schedule modification request (see Attachment A). The revised construction schedule is presented below:

- A. Prepare final design drawings by 04/01/94
- B. Obtain State and County permits by 05/01/94
- C. Bid/Award project by ~~08/01/94~~ 03/22/95
- D. ~~Begin construction (Notice to Proceed) by 09/01/94~~
- E. D. Substantial completion (In-Service) by ~~02/01/95~~ 11/26/95
- F. E. Final Completion by ~~04/01/95~~ 12/26/95
- G. F. Modification of this operation permit by 10/01/95

In addition to the schedule above, SSU proposes to submit DEP form 62-620.910(1) "Wastewater Permit Application Form 1 General Information" and DEP form 62-620.910(2)



## Department of Environmental Protection

Lawton Chiles  
Governor

Central District  
3319 Maguire Boulevard, Suite 232  
Orlando, Florida 32803-3767

Virginia B. Wetherell  
Secretary

### STATE OF FLORIDA DOMESTIC WASTEWATER FACILITY PERMIT

**PERMITTEE:**

Orange Osceola Utilities, Inc.  
2507 Boggy Creek Road, Suite D  
Kissimmee, Florida 34744

PERMIT NUMBER: FL0039446-001

ISSUANCE DATE:

PATS NUMBER: 219202-268476

EXPIRATION DATE: October 10, 2000

FACILITY I.D. NO.: 3049P00029

Mike Johnson, General Manager

**FACILITY:**

Buenaventura Lakes WWTP  
839C West Birchwood Circle  
Osceola County  
Kissimmee, Florida

Latitude: 28° 19' 28" N Longitude: 81° 22' 22" W

This permit is issued under the provisions of Chapter 403, Florida Statutes, and applicable rules of the Florida Administrative Code and constitutes authorization to discharge to waters of the state under the National Pollutant Discharge Elimination System. The above named permittee is hereby authorized to construct and/or operate the facilities shown on the application and other documents attached hereto or on file with the Department and made a part hereof and specifically described as follows:

**TREATMENT FACILITIES:**

An existing 1.8 MGD annual average daily flow (AADF) permitted capacity Bardenpho process wastewater treatment plant consisting of influent screening, grit removal, surge control, fermentation zone, first anoxic zone, aeration, second anoxic zone, reaeration zone, clarification, chemical feed facilities, filtration, disinfection by chlorination, a 4-cell, inline 6-acre hyacinth polishing pond (3 days detention time), post aeration, aerobic storage of residuals, rotary drum thickener and lime stabilization with:

**EFFLUENT DISPOSAL:**

**Surface Water Discharge:** An existing 1.080 MGD AADF permitted capacity rapid-rate land application system consisting of three (3) rapid exfiltration basins (REB's) with an effective seepage length of 520 linear feet each. Effluent is discharged to surface waters by seepage through the easterly exfiltration berms of the REB's to an adjacent stormwater canal, which discharges to Bass Slough and hence to Lake Tohopekaliga, all Class III waters. Emergency discharge from each REB is westerly to the south wetland cell. The point of discharge (D004) and REB's are located approximately at latitude 28° 19' 15" N, longitude 81° 22' 07" W. Construction of REB #4 is hereby authorized adjacent to and north of the existing REB's, with an effective seepage length of 450 linear feet and an increase in permitted capacity of 0.250 MGD AADF of the REB system to a total disposal capacity of 1.33 MGD AADF.

Orange Osceola Utilities, Inc.  
Buenaventura Lakes WWTP

Permit Number: FL0039446-001  
Facility I. D. Number: 3049P00029

**REUSE:**

**Surface Water Discharge:** An existing 0.100 MGD AADF permitted capacity non-jurisdictional, 3-cell, 169 acre, treatment wetland reuse system (R001) required to hold emergency discharge from the REB's, storage during wet weather and reuse water for wetlands enhancement to maintain a productive wildlife habitat. Discharge from the wetland system is only authorized due to a 10-year 24-hour storm event. The discharge point (D001) from the overflow structure of the south wetland cell to the adjacent stormwater canal, which discharges to Bass Slough and hence to Lake Tohopekaliga, is located approximately at latitude 28° 19' 07" N, longitude 81° 22' 10" W. (Note: Previous outfalls D002 and D003 have been sealed and abandoned.)

**Land Application:** An existing 0.500 MGD AADF permitted capacity public access reuse system (R002) consisting of golf course pond reclaimed water storage and irrigation of the 65-acre Buenaventura Lakes Golf Course located approximately at latitude 28° 20' 20" N, longitude 81° 22' 00" W.

DISPOSAL CAPACITY SUMMARY

MGD AADF

1. REB's #1, #2 #3 & #4	1.330
2. Golf Course	0.500
3. Wetland System	<u>0.100</u>

Total: 1.930

**IN ACCORDANCE WITH:** The limitations, monitoring requirements and other conditions set forth in Part I 11 pages, Part II 2 pages, Part III 2 pages, Part IV 2 pages, Part V 1 page, Part VI 1 page, Part VII 0 pages, Part VIII 2 pages and Part IX 2 pages of this permit, including the enclosed Discharge Monitoring Reports (DMR's), Ground Water Monitoring Well Completion Report and Groundwater Monitoring Reports.

**I. RECLAIMED WATER AND EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS**

**A. Surface Water Discharges**

1. During the period beginning on the issuance date and lasting through the expiration date of this permit, the permittee is authorized to discharge effluent from REB's Outfall D004 to the adjacent stormwater canal, which discharges to Bass Slough and hence to Lake Tohopekaliga. Such discharge shall be limited and monitored by the permittee as specified below:  
[62-600, 6-8-93]; [62-601, 5-31-93], [62-650, 11-27-89], [62-302, 1-5-93], [62-610.860, 4-2-90]

Parameter	Units	Max/Min	Effluent Limitations				Monitoring Requirements				Notes
			Annual Average	Monthly Average	Weekly Average	Single Sample	Monitoring Frequency	Sample Type	Monitoring Location Site Number		
Flow	mgd	Maximum	1.33	-	-	-	Continuous	Flow Meter	ML005	See Item I.A.4.	
Carbonaceous Biochemical Oxygen Demand (5 day)	mg/L	Maximum	3.3	4.125	-	6.6	1 day/week	See Notes	ML004	See Item I.A.7.	
Total Suspended Solids	mg/L	Maximum	5.0	6.25	-	10.0	1 day/week	See Notes	ML004	See Item I.A.7.	
Fecal Coliform Bacteria	See Permit Condition I. A. 5.						1 day/week	Grab	ML004		
pH	std. units	Range	-	-	-	6.0-8.5	7 days/week	Grab	ML004		
Total Residual Chlorine (For Disinfection)	mg/L	Minimum	-	-	-	0.5	Continuous	Analyzer	ML007	See Items I.A.3. & 6.	
Total Residual Chlorine (For Dechlorination)	mg/L	Maximum	-	-	-	0.01	7 days/week	Grab	ML004		
Dissolved Oxygen (DO)	mg/L	Minimum	-	-	-	6.0	7 days/week	Grab	ML004		
Total Nitrogen (as N)	mg/L	Maximum	1.25	1.56	-	2.5	1 day/week	See Notes	ML004	See Item I.A.7.	
Total Phosphorus (as P)	mg/L	Maximum	0.20	0.25	-	0.40	1 day/week	See Notes	ML004	See Item I.A.7.	
CBOD <sub>5</sub>	See Permit Condition I. A.*8.										

Orange Osceola Utilities, Inc.  
Buenaventura Lakes WWTP

Permit Number: FL0039446-001  
Facility I. D. Number: 3049P00029

2. Effluent samples shall be taken at the monitoring site locations listed in Permit Condition I. A. 1. and as described below:

Monitoring Location Site Number	Description of Monitoring Location
ML004	Post aeration tank pump station wetwell
ML005	Flow meter to REB system after post aeration tank
ML007	Discharge from final chlorination tank

3. Hourly measurement during the period of required operator attendance may be substituted for continuous measurement. [Chapter 62-601, Figure 2, Footnotes 1 and 2, 5-31-93]
4. Recording flow meters and totalizers shall be utilized to measure flow. [62-601.200(17) and .500(6), 5-31-93]
5. The arithmetic mean of the monthly fecal coliform values collected during an annual period shall not exceed 200 per 100 mL of effluent sample. The geometric mean of the fecal coliform values for a minimum of 10 samples of effluent each collected on a separate day during a period of 30 consecutive days (monthly), shall not exceed 200 per 100 mL of sample. No more than 10 percent of the samples collected during a period of 30 consecutive days shall exceed 400 fecal coliform values per 100 mL of sample. Any one sample shall not exceed 800 fecal coliform values per 100 mL of sample. [62-600.440(4)(c), 6-8-93]
6. A minimum of 0.5 mg/L total residual chlorine must be maintained for a minimum contact time of 15 minutes based on peak hourly flow. [62-600.440(4)(b), 6-8-93]
7. Flow proportioned 16-hour composite sample is required. [62-601.500(3), 5-31-93]
8. The annual average value of CBOD<sub>5</sub> shall not exceed 2.5 mg/L as sampled from any of the ground water monitoring wells located in the effluent discharge berms of the REB's and as recorded on the quarterly ground water monitoring reports for wells MW-1 through MW-4 identified in permit condition III. 3. [62-620.320(6), 11-29-94]
9. As a result of this discharge, surface water quality monitoring shall be required at stations BS-1 and BS-2, as previously established at the Lapaz Drive overflow structure and Boggy Creek Road overpass, respectively. Grab samples shall be collected quarterly during January, April, July and October of each year and the data submitted, in accordance with the previously established format, by the 28th day following each sample month for the following parameters: [62-620.320(6), 11-29-94]
- a. Flow
  - b. CBOD<sub>5</sub>
  - c. TSS
  - d. Chlorides
  - e. Conductivity
  - f. pH
  - g. Dissolved Oxygen (DO)
  - h. TKN (as N)
  - i. Nitrates/Nitrites (as N)
  - j. Ammonia (as N)
  - k. Total Phosphorus (as P)
  - l. Temperature
  - m. Macroinvertebrates (semi-annually during January and July using Hester-Dendy artificial substrates)
10. Florida water quality criteria and standards shall not be violated as a result of the discharge. Should violations occur, the permittee shall provide additional treatment by modifications or additions to the wastewater treatment facilities. [Chapter 62-600.500, 6-8-93]

I. RECLAIMED WATER AND EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)

A. Surface water Discharges

11. During the period beginning on the issuance date and lasting through the expiration date of this permit, the permittee is not authorized to discharge to surface waters from Wetlands Outfall D001, except as provided by permit condition I.A.14. Such discharge shall be monitored by the permittee as specified below: [62-600, 6-8-93], [62-601, 5-31-93], [62-610, 4-2-90], [62-620.320(6), 11-29-94]

Parameter	Units	Max./Min.	Discharge Data				Monitoring Requirements			
			Annual Average	Monthly Average	Weekly Average	Daily Sample	Monitoring Frequency	Sample Type	Monitoring Location Site Number	Notes
Flow	mgd	Report	-	-	-	-	Daily	-	ML010	See Item I.A.13.
Carbonaceous Biochemical Oxygen Demand (5 day)	mg/L	Report	-	-	-	-	Daily	Grab	ML009	
Total Suspended Solids	mg/L	Report	-	-	-	-	Daily	Grab	ML009	
Fecal Coliform Bacteria	#/100	Report	-	-	-	-	Daily	Grab	ML009	
pH	std. units	Report	-	-	-	-	Daily	Grab	ML009	
Total Residual Chlorine (For Dechlorination)	mg/L	Report	-	-	-	-	Daily	Grab	ML009	
Total Nitrogen (as N)	mg/L	Report	-	-	-	-	Daily	Grab	ML009	
Total Phosphorus (as P)	mg/L	Report	-	-	-	-	Daily	Grab	ML009	
Rainfall	inchs	Report	-	-	-	-	Daily	-	ML012	See Item I.A.14.

Orange Osceola Utilities, Inc.  
 Buenaventura Lakes WWTP

Permit Number: FL0039446-001  
 Facility I. D. Number: 3049P00029

12. Reclaimed water samples shall be taken at the monitoring site locations listed in Permit Condition I. A. 11. and as described below:

Monitoring Location Site Number	Description of Monitoring Location
ML009	South wetland cell overflow structure
ML010	Weir in south wetland cell overflow structure
ML012	Master rain gauge at wastewater treatment plant

13. The daily volume discharged (in MGD) based on calculations shall be recorded on the Discharge Monitoring Report (DMR) and the calculations provided as an attachment to the DMR. If no discharge occurs during the reporting period, so indicate on the DMR, but report daily rainfall data.

[62-620.610(18), 11-29-94]

14. The graph included on the following page, entitled "10-Year Localized Storm Curve, Orange Osceola Utilities, Inc.", shall be used to determine when a discharge is allowed. In order to support a permissible discharge, it is required that rain gauge readings be taken at the same time on each day. Compare the number of inches of rain received in a given time period to the graph. If the point lies on or above the curve on the graph, the discharge is permissible. If the point lies below the curve on the graph, a discharge will be in violation to this permit.


The actual rainfall period used for comparison to the graph must be a period of consecutive days of cumulative rainfall. The period of consecutive days of cumulative rainfall may include days for which no rainfall occurs. Discharge is allowed only in amounts equal to the volume of excess rainfall (i.e., rainfall in excess of the 10-year storm times the surface area of the 169-acre wetlands).

A minimum one (1) foot of freeboard should be maintained in all wetland cells at all times to preclude any discharge to surface waters.

[62-620.320(6), 11-29-94], [62-600.500, 6-8-93]

15. Upon review of any information provided by the permittee as a result of any discharge, this permit may be modified or alternatively revoked and reissued to require additional or more stringent conditions or effluent limitations.

[62-620.345, 11-29-94]



10-YEAR LOCALIZED STORM CURVE  
ORANGE OSCEOLA UTILITIES, INC.

	Ardaman & Associates, Inc. Geotechnical, Environmental and Materials Consultants
LOCALIZED STORM CURVE ORANGE OSCEOLA UTILITIES, INC. OSCEOLA COUNTY, FLORIDA	
Drawn by: WWC	Checked by: WWC
File No:	12/11 051251
PD-125	FIGURE 1

W125-12, 1976



I. RECLAIMED WATER AND EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)

B. Reuse and Land Application Systems

1. During the period beginning on the issuance date and lasting through the expiration date of this permit, the permittee is authorized to land apply reclaimed water from Wetlands Reuse System R001. Such reclaimed water shall be limited and monitored by the permittee as specified below:  
[62-600, 6-8-93], [62-601, 5-31-93], [62-610, 4-2-90]

Parameter	Units	Max/Min	Reclaimed Water Limitations				Monitoring Requirements				Notes
			Annual Average	Monthly Average	Weekly Average	Single Sample	Monitoring Frequency	Sample Type	Monitoring Location Site Number		
Flow	mgd	Maximum	0.100	-	-	-	Continuous	Flow Meter	ML002 or ML005	See Items I.B.3 & 6.	
Carbonaceous Biochemical Oxygen Demand (5 day)	mg/L	Maximum	20	30	45	60	1 day/week	16-hour flow proportioned composite	ML004 or ML008		
Total Suspended Solids	mg/L	Maximum	20	30	45	60	1 day/week	16-hour flow proportioned composite	ML004 or ML008		
Fecal Coliform Bacteria	See Permit Condition I. C. 4.						1 day/week	Grab	ML004 or ML008		
pH	std. units	Range	-	-	-	6.0-8.5	Daily	Grab	ML004 or ML008		
Total Residual Chlorine (For Disinfection)	mg/L	Minimum	-	-	-	0.5	Daily	Grab	ML007 or ML008	See Item I.B.5.	

Orange Osceola Utilities, Inc.  
Buenaventura Lakes WWTP

Permit Number: FL0039446-001  
Facility I. D. Number: 3049P00029

2. Reclaimed water samples shall be taken at the monitoring site locations listed in Permit Condition I. B. 1. and as described below:

Monitoring Location Site Number	Description of Monitoring Location
ML004	Post aeration tank pump station wetwell
ML005	Flow meter after post aeration tank
ML008	Gravity flow from per-filter dosing tank
ML002	Master flow meter at pre-filter chlorination tank
ML007	Discharge from final chlorination tank

3. Recording flow meters and totalizers shall be utilized to measure flow.  
*[62-601.200(17) and .500(6), 5-31-93]*
4. The arithmetic mean of the monthly fecal coliform values collected during an annual period shall not exceed 200 per 100 mL of reclaimed water sample. The geometric mean of the fecal coliform values for a minimum of 10 samples of reclaimed water, each collected on a separate day during a period of 30 consecutive days (monthly), shall not exceed 200 per 100 mL of sample. No more than 10 percent of the samples collected during a period of 30 consecutive days shall exceed 400 fecal coliform values per 100 mL of sample. Any one sample shall not exceed 800 fecal coliform values per 100 mL of sample.  
*[62-600.440(4)(c), 6-8-93]*
5. A minimum of 0.5 mg/L total residual chlorine must be maintained for a minimum contact time of 15 minutes based on peak hourly flow.  
*[62-600.440(4)(b), 6-8-93]*
6. Gravity flow to the wetlands shall be the difference between the master flow meter data and the measured flows to the REB's and/or golf course reclaimed water holding pond.  
*[62-601.200(17), 5-31-93]*

I. RECLAIMED WATER AND EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)

C. Reuse and Land Application Systems

1. During the period beginning on the issuance date and lasting through the expiration date of this permit, the permittee is authorized to land apply reclaimed water from Golf Course Reuse System R002. Such reclaimed water shall be limited and monitored by the permittee as specified below:

[62-600, 6-8-93], [62-601, 5-31-93], [62-610, 4-2-90]

Parameter	Units	Max./Min	Reclaimed Water Limitations				Monitoring Requirements			
			Annual Average	Monthly Average	Weekly Average	Single Sample	Monitoring Frequency	Sample Type	Monitoring Location Site Number	Notes
Flow	mgd	Maximum	0.500				Continuous	Flow Meter	ML003	See Item I.C.3.
Carbonaceous Biochemical Oxygen Demand (5 day)	mg/L	Maximum	20	30	45	60	1 day/week	16-hour flow proportioned composite	ML007	
Total Suspended Solids	mg/L	Maximum	-	-	-	5.0	4 days/week	Grab	ML006	See Item I.C.4.
Fecal Coliform Bacteria	See Permit Condition I. C. 4.						4 days/week	Grab	ML007	
pH	std. units	Range	-	-	-	6.0-8.5	7 days/week	Grab	ML007	
Total Residual Chlorine (For Disinfection)	mg/L	Minimum	-	-	-	1.0	Continuous	Analyzer	ML007	See Item I. C. 5.
Turbidity	NTU	Maximum	See Permit Condition I. C. 6.				Continuous	Analyzer	ML006	

Orange Osceola Utilities, Inc.  
Bucnaventura Lakes WWTP

Permit Number: FL0039446-001  
Facility I. D. Number: 3049P00029

- 2. Reclaimed water samples shall be taken at the monitoring site locations listed in Permit Condition I. C. 1. and as described below:

Monitoring Location Site Number	Description of Monitoring Location
ML003	Flow meter to public access reuse system
ML006	After filtration and prior to disinfection
ML007	Discharge from final chlorination tank

- 3. Recording flow meters and totalizers shall be utilized to measure flow.

[62-601.200(17) and .500(6), 5-31-93]

- 4. Over a 30 day period, 75 percent of the fecal coliform values shall be below the detection limits. Any one sample shall not exceed 25 fecal coliform values per 100 mL of sample. Any one sample shall not exceed 5.0 milligrams per liter of total suspended solids (TSS) at a point before application of the disinfectant.

[62-600.440(5)(f), 6-8-93]

- 5. The minimum total chlorine residual shall be limited as described in the approved operating protocol, such that the permit limitation for fecal coliform bacteria will be achieved. In no case shall the total chlorine residual be less than 1.0 mg/L.

[62-600.440(5)(b) and (6)(b), 6-8-93]

- 6. The maximum turbidity shall be limited as described in the approved operating protocol, such that the permit limitations for total suspended solids and fecal coliforms will be achieved.

[62-610.463, 4-2-90]

I. RECLAIMED WATER AND EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)

D. Other Limitations and Monitoring and Reporting Requirements

1. During the period beginning on the issuance date and lasting through the expiration date of this permit, the treatment facility shall be limited and monitored by the permittee as specified below:

[62-601.300(1), 5-31-93]

Parameter	Units	Max/Min	Limitations				Monitoring Requirements				Notes
			Annual Average	Monthly Average	Weekly Average	Single Sample	Monitoring Frequency	Sample Type	Monitoring Location Site Number		
Carbonaceous Biochemical Oxygen Demand (5 day)	mg/L	Report	-	-	-	-	Weekly	16-hour flow proportioned composite	ML001	See Item I.D.3.	
Total Suspended Solids	mg/L	Report	-	-	-	-	Weekly	16-hour flow proportioned composite	ML001	See Item I. D. 3.	
Dissolved Oxygen (DO)	mg/L	Minimum	5.0	-	-	-	Weekly	Grab	ML011	See Items I.D.4. & I.D.5.	

Orange Osceola Utilities, Inc.  
 Bucnaventura Lakes WWTP

Permit Number: FL0039446-001  
 Facility I. D. Number: 3049P00029

2. Samples shall be taken at the monitoring site locations listed in Permit Condition I. D. I. and as described below:

Monitoring Location Site Number	Description of Monitoring Location
ML001	Influent discharge to headworks barscreen
ML011	Between canal surface aerator and REB's exfiltration berms

3. Influent samples shall be collected so that they do not contain digester supernatant or return activated sludge, or any other plant process recycled waters.

*[62-601.500(4), 5-31-93]*

4. The permittee shall maintain in operable condition at all times the surface aerator located in the stormwater canal adjacent to the REB's discharge point(s).

*[62-620.320(6), 11-29-94]*

5. Dissolved oxygen data for the stormwater canal shall be recorded on the DMR for outfall D004.

6. All flow measuring device(s) shall be calibrated at least annually.

*[62-601.500(6) and 62-601.200(17), 5-31-93]*

7. Parameters which must be monitored as a result of a surface water discharge shall be analyzed using a sufficiently sensitive method in accordance with 40 CFR Part 136. Parameters which must be monitored as a result of a ground water discharge (i.e., underground injection or land application system) shall be analyzed in accordance with Chapter 62-601, F.A.C.

*[62-620.610(18), 11-29-94]*

8. The permittee shall provide safe access points for obtaining representative influent, reclaimed water, and effluent samples which are required by this permit.

*[62-601.500(5), 5-31-93]*

9. During the period of operation authorized by this permit, the permittee shall complete and submit to the Department on a monthly basis a Discharge Monitoring Report (DMR), Form 62-620.910(10), for each outfall, discharge point, and reuse system specified in Item(s) I.A., I.B., & I.C. above. Each DMR shall include the test results for the parameters required to be sampled on the enclosed DMR forms. The permittee shall make copies of these partially completed forms for future monthly submittals. All DMR forms shall be submitted to the Department by the twenty-eighth (28th) of the month following the month of operation at the address specified below:

Florida Department of Environmental Protection  
 Wastewater Facilities Regulation Section, Mail Station 3550  
 Twin Towers Office Building  
 2600 Blair Stone Road  
 Tallahassee, Florida 32399-2400

*[62-620.610(18), 11-29-94][62-601.300(1), (2), and (3), 5-31-93]*

Orange Osceola Utilities, Inc.  
Bucnaventura Lakes WWTP

Permit Number: FL0039446-001  
Facility I. D. Number: 3049P00029

OPS

- 10. During the period of operation authorized by this permit, reclaimed water or effluent shall be monitored annually for the primary and secondary drinking water standards contained in Chapter 62-550, F.A.C., (except for turbidity, total coliforms, color, and corrosivity). Twenty-four hour composite samples shall be used to analyze reclaimed water or effluent for the primary and secondary drinking water standards. These monitoring results shall be reported to the Department annually on the Reclaimed Water or Effluent Analysis Report, Form 62-601.900(4), or in another format if requested by the permittee and if approved by the Department as being compatible with data entry into the Department's computer system. During years when a permit is not renewed, a certification stating that no new non-domestic wastewater dischargers have been added to the collection system since the last reclaimed water or effluent analysis was conducted may be submitted in lieu of the report. The annual reclaimed water or effluent analysis report or the certification shall be completed and submitted in a timely manner so as to be received by the Department's Central District Office by August 31 of each year.

[62-601.300(4), 5-31-93], [62-601.500(3), 5-31-93]

- 11. Within 90 days of placing the new REB #4 in operation, the permittee shall characterize the volume and composition of the effluent discharged to ground waters. The DMR for the domestic wastewater treatment facility, at that time, shall satisfy this requirement. The initial quarterly ground water monitoring report shall be deemed sufficient to characterize the receiving ground water at the new monitoring well (MW-4) location.

[62-522.600(11)(a), 4/14/94]

- 12. Unless specified otherwise in this permit, all reports and notifications required by this permit, including 24-hour notifications, shall be submitted to or reported to, as appropriate, the Department's Central District Office at the address specified below:

Florida Department of Environmental Protection  
3319 Maguire Boulevard, Suite 232  
Orlando, Florida 32803-3767

Phone Number - (407)894-7555  
FAX Number - (407)897-2966

Note: All FAX copies shall be followed by original copies.

Orange Osceola Utilities, Inc.  
Bucnaventura Lakes WWTP

Permit Number: FL0039446-001  
Facility I. D. Number: 3049P00029

## II. RESIDUALS MANAGEMENT REQUIREMENTS

1. The method of residuals use or disposal by this facility is land application.
2. Land application of residuals shall be in accordance with the conditions of this permit and the requirements of Chapter 62-640, F.A.C. [62-640, 3-1-91]
3. The domestic wastewater residuals for this facility are classified as stabilization Class B.
4. The wastewater treatment facility permittee shall be responsible for proper handling, use, and disposal of its residuals and will be held responsible for any disposal violations that occur unless the permittee can demonstrate that it has delivered residuals that meet the chemical criteria and appropriate stabilization requirements of this permit and that the disposer (e.g. hauler, contractor, or disposal/land application site owner) has legally agreed in writing to accept responsibility for proper disposal. [62-640.300(3), 3-1-91]
5. The permittee shall sample and analyze the residuals at least once every 3 months. All samples shall be representative and shall be taken after final treatment of the residuals but before use or disposal. Sampling and analysis shall be in accordance with the U.S. Environmental Protection Agency publication - POTW Sludge Sampling and Analysis Guidance Document, 1989. The following parameters shall be sampled and analyzed:

Parameter	Maximum Concentration	Maximum Cumulative Loading
Total Nitrogen	(Report only) % dry weight	Not applicable
Total Phosphorus	(Report only) % dry weight	Not applicable
Total Potassium	(Report only) % dry weight	Not applicable
Cadmium	100 mg/kg dry weight	4.4 pounds /acre
Copper	3000 mg/kg dry weight	125 pounds/acre
Lead	1500 mg/kg dry weight	500 pounds/acre
Nickel	500 mg/kg dry weight	125 pounds/acre
Zinc	10,000 mg/kg dry weight	250 pounds/acre
pH	(Report only) standard units	Not applicable
Total Solids	(Report only) %	Not applicable

6. Florida water quality criteria and standards shall not be violated as a result of land application of residuals. [62-640.700(3)(c), 3-1-91]
7. Class B residuals shall not be used on unrestricted access areas. [62-640.600(6)(b), 3-1-91]



Orange Osceola Utilities, Inc.  
Buenaventura Lakes WWTP

Permit Number: FL0039446-001  
Facility I. D. Number: 3049P00029

8. Class B residuals application shall be in accordance with the Agricultural Use Plans (AUP's) approved by the Department for this facility. [62-640.300(1), 3-1-91]
9. Root crops, and fruits and vegetables which touch the soil and which are to be consumed raw shall not be grown on the application site for 18 months after the last application of Class B residuals. [62-640.600(6)(c), 3-1-91]
10. Pasture vegetation on the application site shall not be cut or used for grazing by livestock for 30 days following the last application of Class B residuals. [62-640.600(6)(e), 3-1-91]
11. The public shall be restricted from the application area for 12 months after the last application of Class B residuals. [62-640.600(6)(f), 3-1-91]
12. The wastewater treatment facility permittee shall notify the Department's Central District Office by letter of any modifications or expansions of the approved residuals land application sites. The notice shall be submitted prior to such expansion or modification. Expansions include additional site locations for the permittee's residuals. The letter shall include a site location map and shall state how the modified or expanded residuals land application site will be operated in accordance with all requirements of Chapter 62-640, F.A.C. A new or revised AUP shall be submitted to the Department's Central District Office with the annual update required by Rule 62-640.500(1)(f), F.A.C. The current AUP's identify residuals landspreading on 140 dedicated acres at the Crescent O Ranch located southwest of the Florida Turnpike, south of Canoe Creek and 140 dedicated acres at the L. J. Harvy site located northwest of Kenansville, both in Osceola County, Florida. [62-640.300(2), 3-1-91]
13. Annual residuals application rates shall not exceed the agronomic rates based on the nitrogen requirements of the site vegetation in accordance with the approved AUP. [62-640.700(3)(d), 3-1-91]
14. Residuals shall be applied with techniques and equipment to assure uniform application over the site. [62-640.700(3)(n), 3-1-91]
15. The pH of the domestic wastewater residuals soil mixture shall be 6.5 or greater at the time domestic wastewater residuals are applied. At a minimum, testing shall be done annually. [62-640.700(3)(h), 3-1-91]
16. The permittee shall maintain records of application areas and application rates on DEP Form 62-640.900(3) and shall have these records available for inspection upon request by the Department or the appropriate Local Environmental Program. These records shall include:
  - a. Date of application of the residuals,
  - b. Location of the residuals application site,
  - c. Amount of residuals applied or delivered,
  - d. Identification of specific areas of the site where residuals were applied and acreage of that area,
  - e. Method of incorporation of residuals (if any),
  - f. Water table level at time of application, and
  - g. Concentration of nitrogen and heavy metals in the residuals, percent solids, and date of last analysis.

OPS

The permittee shall provide annual updates to the AUP's as required by permit condition II.12.; summaries of the total residuals, nitrogen, and heavy metals applied on an annual basis; and annual summaries of the cumulative metals applied. Updates to the AUP and annual summaries, including copies of the wastewater residuals analysis for that period, shall be submitted to the Department's Central District Office by August 31 of each year. [62-640.700(3)(c) and (p), 3-1-91]

Orange Osceola Utilities, Inc.  
Bucnaventura Lakes WWTP

Permit Number: FL0039446-001  
Facility I. D. Number: 3049P00029

**III. GROUND WATER MONITORING REQUIREMENTS**

1. During the period of operation authorized by this permit, the permittee shall continue to sample ground water at the existing monitoring wells identified in Item III. 3., below, in accordance with this permit and the approved ground water monitoring plan prepared in accordance with Rule 62-522.600, F.A.C. Within 90 days of placing the REB #4 in operation, the permittee shall begin sampling ground water at the new monitoring well identified in Item III. 3., below, in accordance with this permit and the approved groundwater monitoring plan. [62-522.600, 4-14-94], [62-610.424, 62-610.474, 62-610.524, 62-610.574, 62-610.624, 62-610.660, and 62-610.830(1)(d), 4-2-90]
2. The new ground water monitoring well identified in Item III. 3., below, shall be installed within 90 days of issuance of this permit. Within 30 days of installation of a new monitoring well, the permittee shall submit to the Department's Central District Office detailed information on the well's location and construction on the enclosed DEP Form 62-522.900(3), Monitor Well Completion Report. [62-522.600, 4/14/94]
3. The following monitoring wells shall be sampled quarterly.

DEP Well Name	OOU Label	Monitoring Location Site Number	Aquifer Monitored	Well Type	New or Existing
<b>REB's</b>					
MW-1	NW-1	6305	Shallow	Compliance	Existing
MW-2	NW-2	6304	Shallow	Compliance	Existing
MW-3	NW-3	6303	Shallow	Compliance	Existing
MW-4	NW-4	24323	Shallow	Compliance	New
<b>Wetlands</b>					
1L	LW-1	6314	Shallow	Intermediate	Existing
2L	LW-2	6323	Shallow	Intermediate	Existing
3L	LW-3	6319	Shallow	Background	Existing
4L	LW-4	6322	Shallow	Intermediate	Existing
5L	LW-5	6320	Shallow	Intermediate	Existing
6L	LW-6	6321	Shallow	Compliance	Existing
7U	LW-7	6325	Shallow	Compliance	Existing
8U	LW-8	6327	Shallow	Intermediate	Existing
10U	LW-10	6328	Shallow	Intermediate	Existing
11U	LW-11	6324	Shallow	Intermediate	Existing
<b>Golf Course</b>					
MW-1	UGC-1	6299	Shallow	Intermediate	Existing
MW-2	UGC-2	6317	Shallow	Background	Existing
MW-3	UGC-3	6312	Shallow	Compliance	Existing
MW-4	LGC-4	6316	Shallow	Intermediate	Existing
MW-5	LGC-5	6318	Shallow	Background	Existing
MW-6	LGC-6	6313	Shallow	Compliance	Existing
MW-7	UGC-6	6315	Shallow	Intermediate	Existing

[62-522.600, 4-14-94], [62-610.424, .474, .524, .624, .660, and 62-610.830(1)(d), 4-2-90]

Orange Osceola Utilities, Inc.  
Buenaventura Lakes WWTP

Permit Number: FL0039446-001  
Facility I. D. Number: 3049P00029

4. The following parameters shall be analyzed quarterly for the monitoring wells identified in Item III. 3.
- a. Water level (field measurement)
  - b. Nitrate (as N)
  - c. Total dissolved solids
  - d. Chloride
  - e. Fecal Coliform
  - f. pH
  - g. Turbidity
  - h. CBOD<sub>5</sub>

(Note: CBOD<sub>5</sub> for REB's only)

*[62-522.600(11)(b), 4-1-94], [62-601.300(3), 62.601.700, and Figure 3 of 62-601]*

5. Ground water monitoring parameters shall be analyzed in accordance with Chapter 62-601, F.A.C.
- [62-620.610(18), 11-29-94]*

6. Ground water monitoring test results shall be submitted on Part D of Form 62-620.910(10). Results shall be submitted with the April, July, October and January DMR's for each year during the period of operation allowed by this permit.
- [62-522.600(10) and (11)(b), 4-14-94], [62-601.300(3), 62.601.700, and Figure 3 of 62-601, 5-31-93], [62-620.610(18), 11-29-94]*

7. Ground water monitoring wells shall be purged prior to sampling to obtain representative samples.
- [62-601.700(5), 5-31-93]*

8. In accordance with Part D of Form 62-620.910(10), water levels shall be recorded before evacuating wells for sample collection. Elevation references shall include the top of the well casing and land surface at each well site (NVGD allowable) at a precision of plus or minus 0.1 foot.
- [62-610.424(3), 4-2-94]*

9. Prior to construction of the new ground water monitoring well, a soil boring shall be made at the new monitoring well location in order to properly size the well depth and screen interval.
- [62-522.900(3), 4-14-94]*

Orange Osceola Utilities, Inc.  
Buenaventura Lakes WWTP

Permit Number: FL0039446-001  
Facility I. D. Number: 3049P00029

IV. ADDITIONAL REUSE AND LAND APPLICATION REQUIREMENTS

1. This reuse system includes the following major users (i.e., using 0.1 mgd or more of reclaimed water):

User Name	User Type	Capacity (mgd)
Buenaventura Lakes	Golf Course Irrigation	0.500
Wetlands System	Enhancement	0.100
Future Reuse	Green Areas Irrigation	-
Total		0.600

[62-610.820(1), 4/2/90]

2. All ground water quality criteria specified in Chapter 62-520, F.A.C., shall be met at the edge of the zone of discharge. For major users of reclaimed water (i.e., using 0.1 mgd or more), the zone of discharge shall extend horizontally to the site property line and vertically to the base of the surficial aquifer.

[62-520.200(23), 4-14-94], [62-522.400 and 62-522.410, 4-14-94]

OPS

3. The treatment facilities shall be operated in accordance with the approved operating protocol. Only reclaimed water that meets the criteria established in the approved operating protocol may be released to system storage or to the golf course for irrigation. Reclaimed water that fails to meet the criteria in the approved operating protocol shall be directed to either the wetlands system (D001) or to the rapid exfiltration basins (D004). The operating protocol shall be reviewed and updated periodically (at least once each year) to ensure continuous compliance with the minimum treatment and disinfection requirements. Updated operating protocols shall be submitted to the Department's Central District Office for review and approval by August 31 of each year.

[62-610.463(2), 4-2-90]

4. Cross-connections to the potable water system are prohibited. [62-610.470(1), 4-2-90]
5. Maximum obtainable separation of reclaimed water lines and potable water lines shall be provided and the minimum separation distances specified in Rule 62-610.470(3), F.A.C., shall be provided. Reuse facilities shall be color coded or marked.

[62-610.470(3) and (4), 4-2-90]

6. In constructing reclaimed water distribution piping, the permittee shall maintain a 75-foot setback distance from a reclaimed water transmission facility to public water supply wells. No setback distances are required to other potable water supply wells or to any nonpotable water supply wells.

[62-610.471(3), 4-2-90]

7. A setback distance of 75 feet shall be maintained between the edge of the wetted area and potable water supply wells, unless the utility adopts and enforces an ordinance, or other legal means, prohibiting private potable water supply wells within the Buenaventura Lakes Development. No setback distances are required to any nonpotable water supply wells, to any surface waters, to any developed areas, or to any private swimming pools, hot tubs, spas, saunas, picnic tables, barbecue pits, or barbecue grills.

[62-610.471(1),(2),(5) and (7), 4-2-90]

Orange Oscola Utilities, Inc.  
Buenaventura Lakes WWTP

Permit Number: FL0039446-001  
Facility I. D. Number: 3049P00029

8. Reclaimed water shall not be used to fill swimming pools, hot tubs, or wading pools.  
*[62-610.469(3), 4-2-90]*
9. Low trajectory nozzles, or other means to minimize aerosol formation shall be used within 100 feet from outdoor public eating, drinking, or bathing facilities.  
*[62-610.471(6), 4-2-90]*
10. The public shall be notified of the use of reclaimed water. This shall be accomplished by posting of advisory signs in areas where reuse is practiced, notes on scorecards, or other methods.  
*[62-610.468(2), 4-2-94]*
11. Routine aquatic weed control and regular maintenance of reuse storage pond embankments and access areas are required.  
*[62-610.415(6), 4-2-90]*
12. Overflows from emergency discharge facilities on the golf course irrigation reclaimed water storage pond, which discharge to the north wetland cell, shall be reported as an abnormal event to the Department's Central District Office within 24 hours of an occurrence as an abnormal event. The provisions of Rule 62-610.880, F.A.C., shall be met.  
*[62-610.880, 62-610.415(5), and 62-610.465, 4-2-90]*
13. Reclaimed water shall only be released to the reuse system storage pond or reuse systems during periods of operator attendance in compliance with the approved operating protocol or in accordance with permit condition V.I.  
*[62-610.462(2), 4-2-90]*
14. Exfiltration basins or trenches, and storage ponds shall be enclosed with a fence or provided with features to discourage the entry of animals and unauthorized persons.  
*[62-610.518, 4-2-90]*
15. Rapid-rate systems shall be routinely maintained to control vegetation growth and to maintain percolation capability by scarification or removal of deposited solids.  
*[62-610.523(6), 4-2-90]*
16. Overflows from exfiltration ponds, basins, or trenches shall be reported as an abnormal event to the Department's Central District Office within 24 hours of an occurrence as an abnormal event. The provisions of Rule 62-610.880, F.A.C., shall be met.  
*[62-610.880, 62-610.415(5), 62-610.515, and 62-610.516, 4-2-90]*

Orange Osceola Utilities, Inc.  
Bucnaventura Lakes WWTP

Permit Number: FL0039446-001  
Facility I. D. Number: 3049P00029

#### V. OPERATION AND MAINTENANCE REQUIREMENTS

1. During the period of operation authorized by this permit, the wastewater facilities shall be operated under the supervision of operators certified in accordance with Chapter 61E12-41, F.A.C. In accordance with Chapter 62-699, F.A.C., this facility is a Category I, Class B facility and, at a minimum, operators with appropriate certification must be on the site as follows: A Class C or higher operator 16 hours/day for 7 days/week. The lead operator must be a Class B operator, or higher, and must be on-site for eight (8) hours per day for five (5) days per week, provided a lead/chief operator, or a backup Class B lead operator, is available by phone or pager during weekends and/or holidays and must be capable of immediately responding to any emergency situation that may occur at the plant. Acceptable quality reclaimed water may be diverted to public access reuse systems at all times contingent upon the following: Automatic computer/telemetry controls, monitoring equipment and automatic diversion equipment must be in operation and functional at all times including weekends and/or holidays; and a Class C certified operator, or higher, must be available by phone or pager at all times when not in attendance at the wastewater treatment plant site. *[62-699, 5-20-94], [62-620.630(3), 11-29-94], [62-699.311(3), 5-20-92], [62-610.462(2), 4-2-90]*
2. The application to renew this permit shall include an updated Capacity Analysis Report prepared in accordance with Rule 62-600.405, F.A.C. *[62-600.405(5), 6-8-93]*
3. The application to renew this permit shall include a detailed Operation and Maintenance Performance Report prepared in accordance with Rule 62-600.735, F.A.C. *[62-600.735(1), 6-8-93]*
4. The permittee shall maintain the following records and make them available for inspection on the site of the permitted facility:
  - a. Records of all compliance monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation and a copy of the laboratory certification showing the certification number of the laboratory, for at least three years from the date the sample or measurement was taken;
  - b. Copies of all reports required by the permit for at least three years from the date the report was prepared;
  - c. Records of all data, including reports and documents, used to complete the application for the permit for at least three years from the date the application was filed;
  - d. Monitoring information, including a copy of the laboratory certification showing the laboratory certification number, related to the residuals use and disposal activities for the time period set forth in Chapter 62-640, F.A.C., for at least three years from the date of sampling or measurement;
  - e. A copy of the current permit;
  - f. A copy of the current operation and maintenance manual as required by Chapter 62-600, F.A.C.;
  - g. A copy of the facility record drawings;
  - h. Copies of the licenses of the current certified operators; and
  - i. Copies of the logs and schedules showing plant operations and equipment maintenance for three years from the date of the logs or schedules. The logs shall, at a minimum, include identification of the plant; the signature and certification number of the operator(s) and the signature of the person(s) making any entries; date and time in and out; specific operation and maintenance activities; tests performed and samples taken; and major repairs made. The logs shall be maintained on-site in a location accessible to 24-hour inspection, protected from weather damage, and current to the last operation and maintenance performed.

*[62-620.350, 11-29-94][61E12-41.010(1)(e), 11-02-93]*

Orange Osceola Utilities, Inc.  
Buenaventura Lakes WWTP

Permit Number: FL0039446-001  
Facility I. D. Number: 3049P00029

#### VI. COMPLIANCE SCHEDULES AND SELF-IMPOSED IMPROVEMENT SCHEDULES

1. In accordance with the Operation and Maintenance Performance Report submitted as part of the permit application for this facility, dated April 1995 and prepared by Dyer, Riddle, Mills and Precourt, Inc., the following corrective actions shall be completed according to the following schedule:

Corrective Action	Scheduled Completion Date
1. Post reclaimed water signs at the golf course holding pond.	November 1, 1995
2. Post non-potable water signs near all appropriate spigots and hose bibbs at the wastewater treatment plant site.	November 1, 1995
3. Install appropriate safety eyewash station near lime stabilization facilities as required in the construction plans.	November 1, 1995
4. Install appropriate safety shower and eyewash station near chlorine storage area and alum pump room as required in the construction plans.	November 1, 1995

[62-600.735(1), 6-8-93]

2. The following construction schedule for new REB #4 shall be followed, unless notification of a schedule revision is provided to the Department:

Implementation Step	Scheduled Completion Date
1. Complete detailed plans and specifications.	Complete
2. Start construction.	December 1, 1995
3. Place the new REB #4 in operation.	February 1, 1996
4. Comply with effluent limitations for REB #4.	February 1, 1996

[62-620.450(3)(a), 11-29-94]

3. The permittee shall develop additional reuse sites and implement public access irrigation at the 9-hole golf course and little league ballfield complex, as a minimum, according to the following schedule:

Implementation Step	Scheduled Completion Date
1. Submit permit application and supporting design documentation.	March 1, 1996
2. Start construction.	June 1, 1996
3. Complete construction.	September 1, 1996
4. Submit notification of completion and place in operation.	October 1, 1996

[62-620, 11-29-94]

#### VII. INDUSTRIAL PRETREATMENT PROGRAM REQUIREMENTS (N/A)

Orange Osceola Utilities, Inc.  
Buenaventura Lakes WWTP

Permit Number: FL0039446-001  
Facility I. D. Number: 3049P00029

#### VIII. OTHER SPECIFIC CONDITIONS

1. Prior to placing REB #4 into operation for any purpose other than testing equipment for leaks and operation, the permittee shall complete and submit to the Department DEP Form 62-620.910(12), Notification of Completion of Construction for Domestic Wastewater Facilities.  
*[62-620.630(2), 11-29-94]*
2. Within six months after REB #4 is placed in operation, the permittee shall provide written certification to the Department on Form 62-620.910(13) that record drawings pursuant to Chapter 62-600, F.A.C., and that a revised operation and maintenance manual pursuant to Chapters 62-600 and 62-610, F.A.C., as applicable, are available at the location specified on the form.  
*[62-620.630(7), 11-29-94]*
3. If the permittee wishes to continue operation of this wastewater facility after the expiration date of this permit, the permittee shall submit an application for renewal, using Department Forms 62-620.910(1) and (2), no later than one-hundred and eighty days (180) prior to the expiration date of this permit.  
*[62-620.410(5), 11-26-94]*
4. The facilities shall comply with any conditions that the Secretary of the Army (United States Army Corps of Engineers) considers necessary to ensure that navigation and anchorage will not be substantially impaired.  
*[62-620.620(1)(g), 11-29-94]*
5. In the event that the treatment facilities or equipment no longer function as intended, are no longer safe in terms of public health and safety, or odor, noise, aerosol drift, or lighting adversely affects neighboring developed areas at the levels prohibited by Rule 62-600.400(2)(a), F.A.C., corrective action (which may include additional maintenance or modifications of the permitted facilities) shall be taken by the permittee. Other corrective action may be required to ensure compliance with rules of the Department.  
*[62-600.410(8), 6-8-93]*
6. The deliberate introduction of stormwater in any amount into collection/transmission systems designed solely for the introduction (and conveyance) of domestic/industrial wastewater; or the deliberate introduction of stormwater into collection/transmission systems designed for the introduction or conveyance of combinations of storm and domestic/industrial wastewater in amounts which may reduce the efficiency of pollutant removal by the treatment plant is prohibited.  
*[62-604.130(3), 5-31-93]*
7. Collection/transmission system overflows shall be reported to the Department in accordance with Permit Condition IX. 20.  
*[62-604.550, 5-31-93], [62-620.610(20), 11-29-94]*

ENV



Orange Osceola Utilities, Inc.  
Buenaventura Lakes WWTP

Permit Number: FL0039446-001  
Facility I. D. Number: 3049P00029

8. The acceptance, by the operating authority of a collection/transmission system or by the permittee of a treatment plant, of connections of wastewater discharges which have not received necessary pretreatment or which contain materials or pollutants (other than normal domestic wastewater constituents):
- Which may cause fire or explosion hazards; or
  - Which may cause excessive corrosion or other deterioration of wastewater facilities due to chemical action or pH levels; or
  - Which are solid or viscous and obstruct flow or otherwise interfere with wastewater facility operations or treatment; or
  - Which result in treatment plant discharges having temperatures above 40°C,
- is prohibited.

[62-604.130(4), 5-31-93]

9. The treatment facility shall be enclosed with a fence or otherwise provided with features to discourage the entry of animals and unauthorized persons.

[2-600.400(2)(b), 6-8-93]

10. Screenings and grit removed from the wastewater facilities shall be collected in suitable containers and hauled to a Department approved Class I landfill or to a landfill approved by the Department for receipt and disposal of screenings and grit.

[62-7.540, 12-10-85]

11. The permittee shall provide adequate notice to the Department of the following:

- Any new introduction of pollutants into the facility from an industrial discharger which would be subject to Chapter 403, F.S., and the requirements of Chapter 62-620, F.A.C., if it were directly discharging those pollutants; and
- Any substantial change in the volume or character of pollutants being introduced into that facility by a source which was identified in the permit application and known to be discharging at the time the permit was issued.

Adequate notice shall include information on the quality and quantity of effluent introduced into the facility and any anticipated impact of the change on the quantity or quality of effluent or reclaimed water to be discharged from the facility.

[62-620.625(2), 11-29-94]

Orange Osceola Utilities, Inc.  
Buenaventura Lakes WWTP

Permit Number: FL0039446-001  
Facility I. D. Number: 3049P00029

#### IX. GENERAL CONDITIONS

1. The terms, conditions, requirements, limitations and restrictions set forth in this permit are binding and enforceable pursuant to Chapter 403, Florida Statutes. Any permit noncompliance constitutes a violation of Chapter 403, Florida Statutes, and is grounds for enforcement action, permit termination, permit revocation and reissuance, or permit revision. *[62-620.610(1), 11-29-94]*
2. This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviations from the approved drawings, exhibits, specifications or conditions of this permit constitutes grounds for revocation and enforcement action by the Department. *[62-620.610(2), 11-29-94]*
3. As provided in Subsection 403.087(6), F.S., the issuance of this permit does not convey any vested rights or any exclusive privileges. Neither does it authorize any injury to public or private property or any invasion of personal rights, nor authorize any infringement of federal, state, or local laws or regulations. This permit is not a waiver of or approval of any other Department permit or authorization that may be required for other aspects of the total project which are not addressed in this permit. *[62-620.610(3), 11-29-94]*
4. This permit conveys no title to land or water, does not constitute state recognition or acknowledgment of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the State. Only the Trustees of the Internal Improvement Trust Fund may express State opinion as to title. *[62-620.610(4), 11-29-94]*
5. This permit does not relieve the permittee from liability and penalties for harm or injury to human health or welfare, animal or plant life, or property caused by the construction or operation of this permitted source; nor does it allow the permittee to cause pollution in contravention of Florida Statutes and Department rules, unless specifically authorized by an order from the Department. The permittee shall take all reasonable steps to minimize or prevent any discharge, reuse of reclaimed water, or residuals use or disposal in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. *[62-620.610(5), 11-29-94]*
6. If the permittee wishes to continue an activity regulated by this permit after its expiration date, the permittee shall apply for and obtain a new permit. *[62-620.610(6), 11-29-94]*
7. The permittee shall at all times properly operate and maintain the facility and systems of treatment and control, and related appurtenances, that are installed and used by the permittee to achieve compliance with the conditions of this permit. This provision includes the operation of backup or auxiliary facilities or similar systems when necessary to maintain or achieve compliance with the conditions of the permit. *[62-620.610(7), 11-29-94]*
8. This permit may be modified, revoked and reissued, or terminated for cause. The filing of a request by the permittee for a permit revision, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. *[62-620.610(8), 11-29-94]*
9. The permittee, by accepting this permit, specifically agrees to allow authorized Department personnel, including an authorized representative of the Department and authorized EPA personnel, when applicable, upon presentation of credentials or other documents as may be required by law, and at reasonable times, depending upon the nature of the concern being investigated, to:

Orange Osceola Utilities, Inc.  
Bucnaventura Lakes WWTP

Permit Number: FL0039446-001  
Facility I. D. Number: 3049P00029

- a. Enter upon the permittee's premises where a regulated facility, system, or activity is located or conducted, or where records shall be kept under the conditions of this permit;
- b. Have access to and copy any records that shall be kept under the conditions of this permit;
- c. Inspect the facilities, equipment, practices, or operations regulated or required under this permit; and
- d. Sample or monitor any substances or parameters at any location necessary to assure compliance with this permit or Department rules.

*[62-620.610(9), 11-29-94]*

10. In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data, and other information relating to the construction or operation of this permitted source which are submitted to the Department may be used by the Department as evidence in any enforcement case involving the permitted source arising under the Florida Statutes or Department rules, except as such use is proscribed by Section 403.111, Florida Statutes, or Rule 62-620.302, Florida Administrative Code. Such evidence shall only be used to the extent that it is consistent with the Florida Rules of Civil Procedure and applicable evidentiary rules. *[62-620.610(10), 11-29-94]*
11. When requested by the Department, the permittee shall within a reasonable time provide any information required by law which is needed to determine whether there is cause for revising, revoking and reissuing, or terminating this permit, or to determine compliance with the permit. The permittee shall also provide to the Department upon request copies of records required by this permit to be kept. If the permittee becomes aware of relevant facts that were not submitted or were incorrect in the permit application or in any report to the Department, such facts or information shall be promptly submitted or corrections promptly reported to the Department. *[62-620.610(11), 11-29-94]*
12. Unless specifically stated otherwise in Department rules, the permittee, in accepting this permit, agrees to comply with changes in Department rules and Florida Statutes after a reasonable time for compliance; provided, however, the permittee does not waive any other rights granted by Florida Statutes or Department rules. A reasonable time for compliance with a new or amended surface water quality standard, other than those standards addressed in Rule 62-302.500, F.A.C., shall include a reasonable time to obtain or be denied a mixing zone for the new or amended standard. *[62-620.610(12), 11-29-94]*
13. The permittee, in accepting this permit, agrees to pay the applicable regulatory program and surveillance fee in accordance with Rule 62-4.052, F.A.C. *[62-620.610(13), 11-29-94]*
14. This permit is transferable only upon Department approval in accordance with Rule 62-620.340, F.A.C. The permittee shall be liable for any noncompliance of the permitted activity until the transfer is approved by the Department. *[62-620.610(14), 11-29-94]*
15. The permittee shall give the Department written notice at least 60 days before inactivation or abandonment of a wastewater facility and shall specify what steps will be taken to safeguard public health and safety during and following inactivation or abandonment. *[62-620.610(15), 11-29-94]*
16. The permittee shall apply for a revision to the Department permit in accordance with Rules 62-620.300, 62-620.420 or 62-620.450, F.A.C., as applicable, at least 90 days before construction of any planned substantial modifications to the permitted facility is to commence or with Rule 62-620.300 for minor modifications to the permitted facility. A revised permit shall be obtained before construction begins except as provided in Rule 62-620.300, F.A.C. *[62-620.610(16), 11-29-94]*

Orange Osceola Utilities, Inc.  
Bucnaventura Lakes WWTP

Permit Number: FL0039446-001  
Facility I. D. Number: 3049P00029

17. The permittee shall give advance notice to the Department of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements. The permittee shall be responsible for any and all damages which may result from the changes and may be subject to enforcement action by the Department for penalties or revocation of this permit. The notice shall include the following information:

- a. A description of the anticipated noncompliance;
- b. The period of the anticipated noncompliance, including dates and times; and
- c. Steps being taken to prevent future occurrence of the noncompliance.

[62-620.610(17), 11-29-94]

18. Sampling and monitoring data shall be collected and analyzed in accordance with Rule 62-4.246, Chapters 62-160 and 62-601, F.A.C., and 40 CFR 136, as appropriate.

- a. Monitoring results shall be reported at the intervals specified elsewhere in this permit and shall be reported on a Discharge Monitoring Report (DMR), DEP Form 62-620.910(10).
- b. If the permittee monitors any contaminate more frequently than required by the permit, using Department approved test procedures, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR.
- c. Calculations for all limitations which require averaging of measurements shall use an arithmetic mean unless otherwise specified in this permit.
- d. Any laboratory test required by this permit for domestic wastewater facilities shall be performed by a laboratory that has been certified by the Department of Health and Rehabilitative Services (DHRS) under Chapter 10D41, F.A.C., to perform the test. On-site tests for dissolved oxygen, pH, and total chlorine residual shall be performed by a laboratory certified to test for those parameters or under the direction of an operator certified under Chapter 61E12-41, F.A.C.
- e. Under Chapter 62-160, F.A.C., sample collection shall be performed by following the protocols outlined in "DER Standard Operating Procedures for Laboratory Operations and Sample Collection Activities" (DER-QA-001/92). Alternatively, sample collection may be performed by an organization who has an approved Comprehensive Quality Assurance Plan (CompQAP) on file with the Department. The CompQAP shall be approved for collection of samples from the required matrices and for the required tests.

[62-620.610(18), 11-29-94]

19. Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule detailed elsewhere in this permit shall be submitted no later than 14 days following each schedule date. [62-620.610(19), 11-29-94]

20. The permittee shall report to the Department any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the permittee becomes aware of the circumstances. A written submission shall also be provided within five days of the time the permittee becomes aware of the circumstances. The written submission shall contain: a description of the noncompliance and its cause; the period of noncompliance including exact dates and

Orange Osceola Utilities, Inc.  
Buenaventura Lakes WWTP

Permit Number: FL0039446-001  
Facility I. D. Number: 3049P00029

time, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent recurrence of the noncompliance.

- a. The following shall be included as information which must be reported within 24 hours under this condition:
    1. Any unanticipated bypass which causes any reclaimed water or effluent to exceed any permit limitation or results in an unpermitted discharge.
    2. Any upset which causes any reclaimed water or the effluent to exceed any limitation in the permit,
    3. Violation of a maximum daily discharge limitation for any of the pollutants specifically listed in the permit for such notice, and
    4. Any unauthorized discharge to surface or ground waters.
  - b. If the oral report has been received within 24 hours, the noncompliance has been corrected, and the noncompliance did not endanger health or the environment, the Department shall waive the written report. *[62-620.610(20), 11-29-94]*
21. The permittee shall report all instances of noncompliance not reported under Permit Conditions IX. 18. and 19. of this permit at the time monitoring reports are submitted. This report shall contain the same information required by Permit Condition IX. 20 of this permit. *[62-620.610(21), 11-29-94]*
22. Bypass Provisions.
- a. Bypass is prohibited, and the Department may take enforcement action against a permittee for bypass, unless the permittee affirmatively demonstrates that:
    1. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage; and
    2. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
    3. The permittee submitted notices as required under Permit Condition IX. 22. b. of this permit.
  - b. If the permittee knows in advance of the need for a bypass, it shall submit prior notice to the Department, if possible at least 10 days before the date of the bypass. The permittee shall submit notice of an unanticipated bypass within 24 hours of learning about the bypass as required in Permit Condition IX. 20. of this permit. A notice shall include a description of the bypass and its cause; the period of the bypass, including exact dates and times; if the bypass has not been corrected, the anticipated time it is expected to continue; and the steps taken or planned to reduce, eliminate, and prevent recurrence of the bypass.
  - c. The Department shall approve an anticipated bypass, after considering its adverse effect, if the permittee demonstrates that it will meet the three conditions listed in Permit Condition IX. 22. a. 1. through 3. of this permit.



### FDEP MONITORING WELL COMPLETION REPORT

FACILITY NAME / COUNTY: Buena Ventura Lakes / Osceola County

FDEP PERMIT NUMBER: \_\_\_\_\_ Site ID NUMBER: FL0039446

FDEP WELL NUMBER: 24323 WELL NAME: MW-4

AQUIFER MONITORED: \_\_\_\_\_ WELL TYPE: Compliance

DATE INSTALLED: \_\_\_\_\_ DRILLING METHOD: \_\_\_\_\_

INSTALLED BY: \_\_\_\_\_

HOLE DIAMETER: \_\_\_\_\_ TOTAL DEPTH: \_\_\_\_\_ BLS\*

CASING TYPE: \_\_\_\_\_ CASING DIAMETER / LENGTH: \_\_\_\_\_

SCREEN TYPE: \_\_\_\_\_ SCREEN SLOT SIZE / LENGTH: \_\_\_\_\_

FILTER PACK TYPE / SIZE: \_\_\_\_\_ INTERVAL: \_\_\_\_\_ to \_\_\_\_\_ BLS

SEALANT TYPE: \_\_\_\_\_ INTERVAL: \_\_\_\_\_ to \_\_\_\_\_ BLS

GROUT TYPE: \_\_\_\_\_ INTERVAL: \_\_\_\_\_ to \_\_\_\_\_ BLS

WELL MEASURING POINT: \_\_\_\_\_ ELEVATION (NGVD): \_\_\_\_\_

GROUND SURFACE ELEVATION (NGVD): \_\_\_\_\_

STATIC WATER LEVEL ELEVATION (NGVD): \_\_\_\_\_

WELL LATITUDE AND LONGITUDE: \_\_\_\_\_

DESCRIBE WELL DEVELOPMENT (METHOD, APPROXIMATE VOLUME REMOVED, FINAL WATER CLARITY, PROBLEMS):  
\_\_\_\_\_  
\_\_\_\_\_

NAME / TITLE OF PERSON PREPARING REPORT: \_\_\_\_\_

ATTACH AS-BUILT MONITORING WELL CONSTRUCTION DIAGRAM AND LITHOLOGIC LOG FOR THIS INDIVIDUAL WELL.

\* BLS = Below Land Surface.

GROUNDWATER MONITORING REPORT - PART D  
Buena Ventura Lakes - Osceola County

Facility ID Number: FL0039446

Test Site ID: 6305

Sample Period - From Month/Year: \_\_\_\_\_ To Month/Year \_\_\_\_\_

Well Type: Compliance

Date Sample Obtained: \_\_\_\_\_

Ground Water Class: GII

Was the well purged before sampling? Yes No

Well Name: MW-1

Parameter	Store Code	Sampling Method	Samples Filtered (Y/N)	Preservatives Added	Analysis Method	Analysis Result/Units	Detection Limits/Units
Water Level	82545						
Nitrate (mg/L as N)	618						
TDS (mg/L)	70301						
Chloride (mg/L)	942						
Fecal Coliform (#/100ML)	31611						
pH (standard units)	406						
Turbidity	76						
CBOD <sub>5</sub>	80082						

Comments and Explanations:



**GROUNDWATER MONITORING REPORT - PART D**  
**Buena Ventura Lakes - Osceola County**

Facility ID Number: FL0039446

Test Site ID: 6304

Sample Period -From Month/Year: \_\_\_\_\_ To Month/Year \_\_\_\_\_

Well Type: Compliance

Date Sample Obtained: \_\_\_\_\_

Ground Water Class: G11

Was the well purged before sampling? Yes  No

Well Name: MW-2

Parameter	Storet Code	Sampling Method	Samples Filtered (Y/N)	Preservatives Added	Analysis Method	Analysis Result/Units	Detection Limits/Units
Water Level	82545						
Nitrate (mg/L as N)	618						
TDS (mg/L)	70301						
Chloride (mg/L)	942						
Fecal Coliform (#/100ML)	31611						
pH (standard units)	406						
Turbidity	76						
CBOD <sub>5</sub>	80082						

Comments and Explanations:

GROUNDWATER MONITORING REPORT - PART D  
Buena Ventura Lakes - Osceola County

Facility ID Number: FL0039446

Test Site ID: 6303

Sample Period -From Month/Year: \_\_\_\_\_ To Month/Year \_\_\_\_\_

Well Type: Compliance

Date Sample Obtained: \_\_\_\_\_

Ground Water Class: GII

Was the well purged before sampling?  Yes  No

Well Name: MW-3

Parameter	Store Code	Sampling Method	Samples Filtered (Y/N)	Preservatives Added	Analysis Method	Analysis Result/Units	Detection Limits/Units
Water Level	82545						
Nitrate (mg/L as N)	618						
TDS (mg/L)	70301						
Chloride (mg/L)	942						
Fecal Coliform (#/100ML)	31611						
pH (standard units)	406						
Turbidity	76						
CBOD <sub>5</sub>	80082						

Comments and Explanations:



GROUNDWATER MONITORING REPORT - PART D  
Buena Ventura Lakes - Osceola County

Facility ID Number: FL0039446

Test Site ID: 24323

Sample Period -From Month/Year: \_\_\_\_\_ To Month/Year \_\_\_\_\_

Well Type: Compliance

Date Sample Obtained: \_\_\_\_\_

Ground Water Class: GII

Was the well purged before sampling? Yes  No

Well Name: MW-4

Parameter	Store Code	Sampling Method	Samples Filtered (Y/N)	Preservatives Added	Analysis Method	Analysis Result/Units	Detection Limits/Units
Water Level	82545						
Nitrate (mg/L as N)	618						
TDS (mg/L)	70301						
Chloride (mg/L)	942						
Fecal Coliform (#/100ML)	31611						
pH (standard units)	406						
Turbidity	76						
CBOD <sub>5</sub>	80082						

Comments and Explanations:



GROUNDWATER MONITORING REPORT - PART D  
Buena Ventura Lakes - Osceola County

Facility ID Number: FL0039446

Test Site ID: 6314

Sample Period - From Month/Year: \_\_\_\_\_ To Month/Year: \_\_\_\_\_

Well Type: Intermediate

Date Sample Obtained: \_\_\_\_\_

Ground Water Class: QII

Was the well purged before sampling? Yes  No

Well Name: 1L

Parameter	Store Code	Sampling Method	Samples Filtered (Y/N)	Preservatives Added	Analysis Method	Analysis Result/Units	Detection Limits/Units
Water Level	82545						
Nitrate (mg/L as N)	618						
TDS (mg/l.)	70301						
Chloride (mg/L)	942						
Fecal Coliform (#/100ML)	31611						
pH (standard units)	406						
Turbidity	76						

Comments and Explanations:



GROUNDWATER MONITORING REPORT - PART D  
Buena Ventura Lakes - Osceola County

Facility ID Number: FL0039446

Test Site ID: 6323

Sample Period - From Month/Year: \_\_\_\_\_ To Month/Year: \_\_\_\_\_

Well Type: Intermediate

Date Sample Obtained: \_\_\_\_\_

Ground Water Class: GII

Was the well purged before sampling? Yes No

Well Name: 2L

Parameter	Storet Code	Sampling Method	Samples Filtered (Y/N)	Preservatives Added	Analysis Method	Analysis Result/Units	Detection Limits/Units
Water Level	82545						
Nitrate (mg/L as N)	618						
TDS (mg/L)	70301						
Chloride (mg/L)	942						
Fecal Coliform (#/100ML)	31611						
pH (standard units)	406						
Turbidity	76						

Comments and Explanations:

**GROUNDWATER MONITORING REPORT - PART D**  
**Buena Ventura Lakes - Osceola County**

Facility ID Number: FL0039446Test Site ID: 6319

Sample Period - From Month/Year: \_\_\_\_\_ To Month/Year: \_\_\_\_\_

Well Type: Background

Date Sample Obtained: \_\_\_\_\_

Ground Water Class: GIIWas the well purged before sampling? Yes NoWell Name: 3L

Parameter	Store Code	Sampling Method	Samples Filtered (Y/N)	Preservatives Added	Analysis Method	Analysis Result/Units	Detection Limits/Units
Water Level	82545						
Nitrate (mg/L as N)	618						
TDS (mg/L)	70301						
Chloride (mg/L)	942						
Fecal Coliform (#/100ML)	31611						
pH (standard units)	406						
Turbidity	76						

Comments and Explanations:

GROUNDWATER MONITORING REPORT - PART D  
Buena Ventura Lakes - Osceola County

Facility ID Number: FL0039446

Test Site ID: 6322

Sample Period -From Month/Year: \_\_\_\_\_ To Month/Year \_\_\_\_\_

Well Type: Intermediate

Date Sample Obtained: \_\_\_\_\_

Ground Water Class: QII

Was the well purged before sampling? Yes No

Well Name: 4L

Parameter	Store Code	Sampling Method	Samples Filtered (Y/N)	Preservatives Added	Analysis Method	Analysis Result/Units	Detection Limits/Units
Water Level	82545						
Nitrate (mg/L as N)	618						
TDS (mg/L)	70301						
Chloride (mg/L)	942						
Fecal Coliform (#/100ML)	31611						
pH (standard units)	406						
Turbidity	76						

Comments and Explanations:

Buena Ventura Lakes - Osceola County

Facility ID Number: FL0039446

Test Site ID: 6320

Sample Period -From Month/Year: \_\_\_\_\_ To Month/Year \_\_\_\_\_

Well Type: Intermediate

Date Sample Obtained: \_\_\_\_\_

Ground Water Class: GII

Was the well purged before sampling? Yes No

Well Name: 5L

Parameter	Store Code	Sampling Method	Samples Filtered (Y/N)	Preservatives Added	Analysis Method	Analysis Result/Units	Detection Limits/Units
Water Level	82545						
Nitrate (mg/L as N)	618						
TDS (mg/L)	70301						
Chloride (mg/L)	942						
Fecal Coliform (#/100ML)	31611						
pH (standard units)	406						
Turbidity	76						

Comments and Explanations:



### GROUNDWATER MONITORING REPORT - PART D Buena Ventura Lakes - Osceola County

Facility ID Number: FL0039446

Test Site ID: 6321

Sample Period - From Month/Year: \_\_\_\_\_ To Month/Year \_\_\_\_\_

Well Type: Compliance

Date Sample Obtained: \_\_\_\_\_

Ground Water Class: GII

Was the well purged before sampling?  Yes  No

Well Name: 6L

Parameter	Store Code	Sampling Method	Samples Filtered (Y/N)	Preservatives Added	Analysis Method	Analysis Result/Units	Detection Limits/Units
Water Level	82545						
Nitrate (mg/L as N)	618						
TDS (mg/L)	70301						
Chloride (mg/L)	942						
Fecal Coliform (#/100ML)	31611						
pH (standard units)	406						
Turbidity	76						

Comments and Explanations:



GROUNDWATER MONITORING REPORT - PART D  
Buena Ventura Lakes - Osceola County

Facility ID Number: FL0039446

Test Site ID: 6325

Sample Period - From Month/Year: \_\_\_\_\_ To Month/Year: \_\_\_\_\_

Well Type: Compliance

Date Sample Obtained: \_\_\_\_\_

Ground Water Class: QII

Was the well purged before sampling? Yes No

Well Name: 7U

Parameter	Store Code	Sampling Method	Samples Filtered (Y/N)	Preservatives Added	Analysis Method	Analysis Result/Units	Detection Limits/Units
Water Level	82545						
Nitrate (mg/L as N)	618						
TDS (mg/L)	70301						
Chloride (mg/L)	942						
Fecal Coliform (#/100ML)	31611						
pH (standard units)	406						
Turbidity	76						

Comments and Explanations:



GROUNDWATER MONITORING REPORT - PART D  
Buena Ventura Lakes - Osceola County

Facility ID Number: FL0039446

Test Site ID: 6327

Sample Period -From Month/Year: To Month/Year

Well Type: Intermediate

Date Sample Obtained:

Ground Water Class: GII

Was the well purged before sampling? Yes No

Well Name: 8U

Parameter	Store Code	Sampling Method	Samples Filtered (Y/N)	Preservatives Added	Analysis Method	Analysis Result/Units	Detection Limits/Units
Water Level	82545						
Nitrate (mg/L as N)	618						
TDS (mg/L)	70301						
Chloride (mg/L)	942						
Fecal Coliform (#/100ML)	31611						
pH (standard units)	406						
Turbidity	76						

Comments and Explanations:

DEP Form 620.910(10), Effective November 29, 1994

Buena Ventura Lakes - Osceola County

Facility ID Number: FL0039446

Test Site ID: 6328

Sample Period - From Month/Year: \_\_\_\_\_ To Month/Year: \_\_\_\_\_

Well Type: Intermediate

Date Sample Obtained: \_\_\_\_\_

Ground Water Class: GII

Was the well purged before sampling? Yes No

Well Name: 10U

Parameter	Store Code	Sampling Method	Samples Filtered (Y/N)	Preservatives Added	Analysis Method	Analysis Result/Units	Detection Limits/Units
Water Level	82545						
Nitrate (mg/L as N)	618						
TDS (mg/L)	70301						
Chloride (mg/L)	942						
Fecal Coliform (#/100ML)	31611						
pH (standard units)	406						
Turbidity	76						

Comments and Explanations:

GROUNDWATER MONITORING REPORT - PART D  
Buena Ventura Lakes - Osceola County

Facility ID Number: FL0039446

Test Site ID: 6324

Sample Period -From Month/Year: \_\_\_\_\_ To Month/Year \_\_\_\_\_

Well Type: Intermediate

Date Sample Obtained: \_\_\_\_\_

Ground Water Class: GII

Was the well purged before sampling? Yes No

Well Name: 11U

Parameter	Storet Code	Sampling Method	Samples Filtered (Y/N)	Preservatives Added	Analysis Method	Analysis Result/Units	Detection Limits/Units
Water Level	82545						
Nitrate (mg/L as N)	618						
TDS (mg/L)	70301						
Chloride (mg/L)	942						
Fecal Coliform (#/100ML)	31611						
pH (standard units)	406						
Turbidity	76						

Comments and Explanations:



GROUNDWATER MONITORING REPORT - PART D  
Buena Ventura Lakes - Osceola County

Facility ID Number: FL0039446

Test Site ID: 6299

Sample Period -From Month/Year: \_\_\_\_\_ To Month/Year \_\_\_\_\_

Well Type: Intermediate

Date Sample Obtained: \_\_\_\_\_

Ground Water Class: Oil

Was the well purged before sampling? Yes No

Well Name: MW-1

Parameter	Store Code	Sampling Method	Samples Filtered (Y/N)	Preservatives Added	Analysis Method	Analysis Result/Units	Detection Limits/Units
Water Level	82545						
Nitrate (mg/L as N)	618						
TDS (mg/L)	70301						
Chloride (mg/L)	942						
Fecal Coliform (#/100ML)	31611						
pH (standard units)	406						
Turbidity	76						

Comments and Explanations:

EXHIBIT (RAT-11)

PAGE 46 OF 51

GROUNDWATER MONITORING REPORT - PART D  
Buena Ventura Lakes - Osceola County

Facility ID Number: FL0039446

Test Site ID: 6317

Sample Period -From Month/Year: \_\_\_\_\_ To Month/Year \_\_\_\_\_

Well Type: Background

Date Sample Obtained: \_\_\_\_\_

Ground Water Class: GII

Was the well purged before sampling? Yes No

Well Name: MW-2

Parameter	Storet Code	Sampling Method	Samples Filtered (Y/N)	Preservatives Added	Analysis Method	Analysis Result/Units	Detection Limits/Units
Water Level	82545						
Nitrate (mg/L as N)	618						
TDS (mg/L)	70301						
Chloride (mg/L)	942						
Fecal Coliform (#/100ML)	31611						
pH (standard units)	406						
Turbidity	76						

Comments and Explanations:

Buena Ventura Lakes - Osceola County

Facility ID Number: FL0039446

Test Site ID: 6312

Sample Period -From Month/Year: To Month/Year

Well Type: Compliance

Date Sample Obtained:

Ground Water Class: GII

Was the well purged before sampling? Yes No

Well Name: MW-3

Parameter	Storet Code	Sampling Method	Samples Filtered (Y/N)	Preservatives Added	Analysis Method	Analysis Result/Units	Detection Limits/Units
Water Level	82545						
Nitrate (mg/L as N)	618						
TDS (mg/L)	70301						
Chloride (mg/L)	942						
Fecal Coliform (#/100ML)	31611						
pH (standard units)	406						
Turbidity	76						

Comments and Explanations:





**GROUNDWATER MONITORING REPORT - PART D**  
**Buena Ventura Lakes - Osceola County**

Facility ID Number: FL0039446

Test Site ID: 6316

Sample Period - From Month/Year: \_\_\_\_\_ To Month/Year \_\_\_\_\_

Well Type: Intermediate

Date Sample Obtained: \_\_\_\_\_

Ground Water Class: GII

Was the well purged before sampling? Yes No

Well Name: MW-4

Parameter	Store Code	Sampling Method	Samples Filtered (Y/N)	Preservatives Added	Analysis Method	Analysis Result/Units	Detection Limits/Units
Water Level	82345						
Nitrate (mg/L as N)	618						
TDS (mg/L)	70301						
Chloride (mg/L)	942						
Fecal Coliform (#/100ML)	31611						
pH (standard units)	406						
Turbidity	76						

Comments and Explanations:

GROUNDWATER MONITORING REPORT - PART D  
Buena Ventura Lakes - Osceola County

Facility ID Number: FL0039446

Test Site ID: 6318

Sample Period - From Month/Year: \_\_\_\_\_ To Month/Year \_\_\_\_\_

Well Type: Background

Date Sample Obtained: \_\_\_\_\_

Ground Water Class: GII

Was the well purged before sampling? Yes No

Well Name: MW-5

Parameter	Store Code	Sampling Method	Samples Filtered (Y/N)	Preservatives Added	Analysis Method	Analysis Result/Units	Detection Limits/Units
Water Level	82545						
Nitrate (mg/L as N)	618						
TDS (mg/L)	70301						
Chloride (mg/L)	942						
Fecal Coliform (#/100ML)	31611						
pH (standard units)	406						
Turbidity	76						

Comments and Explanations:

GROUNDWATER MONITORING REPORT - PART D  
Buena Ventura Lakes - Osceola County

Facility ID Number: FL0039446

Test Site ID: 6313

Sample Period -From Month/Year: \_\_\_\_\_ To Month/Year \_\_\_\_\_

Well Type: Compliance

Date Sample Obtained: \_\_\_\_\_

Ground Water Class: GII

Was the well purged before sampling? Yes No

Well Name: MW-6

Parameter	Store Code	Sampling Method	Samples Filtered (Y/N)	Preservatives Added	Analysis Method	Analysis Result/Units	Detection Limits/Units
Water Level	82545						
Nitrate (mg/L as N)	618						
TDS (mg/L)	70301						
Chloride (mg/L)	942						
Fecal Coliform (#/100ML)	31611						
pH (standard units)	406						
Turbidity	76						

Comments and Explanations:



GROUNDWATER MONITORING REPORT - PART D  
Buena Ventura Lakes - Osceola County

Facility ID Number: FL0032446

Test Site ID: 6315

Sample Period - From Month/Year: \_\_\_\_\_ To Month/Year \_\_\_\_\_

Well Type: Intermediate

Date Sample Obtained: \_\_\_\_\_

Ground Water Class: GII


Was the well purged before sampling? Yes No

Well Name: MW-7

Parameter	Store Code	Sampling Method	Samples Filtered (Y/N)	Preservatives Added	Analysis Method	Analysis Result/Units	Detection Limits/Units
Water Level	82545						
Nitrate (mg/L as N)	618						
TDS (mg/L)	70301						
Chloride (mg/L)	942						
Fecal Coliform (#/100ML)	31611						
pH (standard units)	406						
Turbidity	76						

Comments and Explanations:

AF 42148B



**SCHEMATIC OF WETLAND DISPOSAL AREA**

PROJECT: *Wetland Disposal Area*  
 DRAWN BY: *W. J. Henderson*  
 CHECKED BY: *W. J. Henderson*  
 DATE: 02/15/01  
 SHEET NO. 02-0134  
 PROJECT NO. 02-0134

**Ardemars & Associates, Inc.**  
 Consulting Engineers & Surveyors  
 10000 W. 11th Avenue, Suite 100  
 Golden, Colorado 80401  
 PHONE: 303-440-1100  
 FAX: 303-440-1101  
 WWW: www.ardemars.com

Exhibit PJ-1 (Page 1 of 8)



Lawton Chiles  
Governor

# Florida Department of Environmental Protection

Southwest District  
3804 Coconut Palm Drive  
Tampa, Florida 33619  
813-744-6100

Virginia B. Wetzel  
Secretary

April 20, 1994

CERTIFIED MAIL  
RETURN RECEIPT REQUESTED

Citrus County DW

Mr. Rafael A. Terrero, P.E.  
Chief Engineer  
Southern States Utilities  
1000 Color Place  
Apopka, FL 32703

WARNING LETTER No. 94-0031DW09SFD  
Subject: Apache Shores STP

Dear Mr. Terrero:

A field inspection conducted on 4/19/93, 6/10/93, and 3/23/94 and a review of the file of the above referenced facility indicates that a violation of Chapter 403, Florida Statutes, and the rules promulgated thereunder may exist at the above described facility. Department personnel observed the following.

1. A sample of the effluent was taken during the 3/23/94 inspection and analyzed at the Department's laboratory. The result was 355 mg/L for TSS which exceeds the permitted maximum limitation of 60 mg/L.
2. A sample of the effluent was taken during the 4/19/93 inspection and analyzed at the Department's laboratory. The results were 2483 mg/L for TSS, and 271 mg/L for CBOD<sub>5</sub>.
3. A review of the file show no record of the Capacity Analysis Report. The three month average daily flow reported on the Monthly Operating Reports exceeded 50 percent of the 0.017 MGD permitted capacity on the months below in 1993 and 1994 to date.

Month	Three Month Average
February 1994	0.011 MGD
January 1994	0.010 MGD
April 1993	0.009 MGD
March 1993	0.009 MGD
February 1993	0.010 MGD
January 1993	0.010 MGD

Exhibit PJ-1 (Page 2 of 8)

WARNING LETTER No. 94-0031DW095WD  
Subject: Apache Shores STP  
Page Two

4. The file shows the previous sludge analysis was performed on 2/4/93.
5. The Department has no record of flow calibration.
6. A review of the operator's calibration records indicated that the pH meter and colorimeter for chlorine residual measurements were last calibrated on 12/20/93.
7. A review of the on-site operator log indicated that on 11/26/93 the blower was tripping out, and on 12/10/93 the blower was not working. The Department was not notified of these abnormal events.
8. An excessive amount of wet and dried sludge was observed on the bottom of the percolation pond, which indicated frequent plant upsets. The Department was not notified of these plant upsets.
9. The effluent distribution system for the percolation was predominantly plugged with solids. The threaded plugs at the ends of the distribution pipe were removed to allow the effluent to flow into the pond.

It is a violation of Rule 17-600.740(1)(b)1.d., Florida Administrative Code (F.A.C.), to exceed 60 mg/L of CBOD<sub>5</sub>, and TSS on any one sample of effluent.

It is a violation of Rule 17-600.405(3), F.A.C., to fail to submit to the Department a capacity analysis report when the most recent three-month average daily flow exceed 50 percent of the permitted capacity of the treatment plant.

It is a violation of Rule 17-640.700(1), F.A.C., to fail to perform domestic wastewater residuals analysis every 12 months for a Type III facility.

It is a violation of Rule 17-601.200(17)(b), F.A.C., to fail to calibrate a flow metering device at least annually.

It is a violation of Rule 17-601.400, F.A.C., to fail to use approved test procedures and established quality control procedures for field testing and laboratory testing.

It is a violation of Rule 17-600.750(1), F.A.C., to fail to notify the department within 24 hours of events which result in the violation of any condition of a permit.

Exhibit PJ-1 (Page 3 of 8)

WARNING LETTER No. 94-0031DW095WD  
Subject: Apache Shores STP  
Page Four

by the Department in the Notice of Violation. The Department can also resolve any violation through entry into a Consent Order.

Sincerely,

Richard D. Garrity, Ph.D.  
Director of District Management  
Southwest District

cc: Dawn Shaw, Citrus County PHU

P 079 940 696

RECEIPT FOR CERTIFIED MAIL

POSTAGE AND FEES PROVIDED  
BY ADDRESSEE  
(See Reverse)

<p>NOTE: Please print or type in all items.</p> <p>1. Complete items 1 and/or 2 for additional services, items 3, and 4a &amp; b.</p> <p>2. Print our name and address on the reverse of this form so that we can return it to you.</p> <p>3. Attach this form to the front of the mailpiece, or on the back if space permits.</p> <p>4. "Return Receipt Requested" on the mailpiece below the article number. The Return Receipt will show to whom the article was delivered and the date.</p>		<p>I also wish to receive the following services (for an extra fee):</p> <p>1. <input type="checkbox"/> Addressee's Address</p> <p>2. <input type="checkbox"/> Restricted Delivery</p> <p>Consult postmaster for fee.</p>	
<p>Article Addressed to:</p> <p>Enrique A. Terrero, P.E. District Engineer Southern States Utilities 10000 Color Place Orlando, FL 32703</p>		<p>4a. Article Number P 079 940 696</p>	
<p>4b. Service Type</p> <p><input type="checkbox"/> Registered <input type="checkbox"/> Insured</p> <p><input checked="" type="checkbox"/> Certified <input type="checkbox"/> COD</p> <p><input type="checkbox"/> Express Mail <input type="checkbox"/> Return Receipt for Merchandise</p>		<p>7. Date of Delivery 4-22-94</p>	
<p>8. Addressee's Address (Only if requested and fee is paid)</p>		<p>Signature (Agent) <i>[Signature]</i></p>	

Thank you for using Return Receipt Service.



Exhibit PJ-1 (Page 4 of 8)

## PENALTY COMPUTATION WORKSHEET

Violator's Name: Southern States Utilities

Identify Violator's Facility: Apache Shores WWTP

Name of Department Staff Responsible for the Penalty Computations:

Phyllis James

Date: April 28, 1995

PART I - Class B (no penalty) Determination

Rationale for Class B determination: N/A

PART II - Class A Penalty Determinations

Violation Type	Potential Extent for Harm of Dev.	Matrix Amount	Multi-day	Adjustments	Total
			(600- 1199)		
1. <u>Poor effluent</u>	<u>Minor Mod.</u>	\$600.00		<u>(-\$300.00)</u>	<u>\$300.00</u>
			(2,000-3199)		
2. <u>Lack of records</u>	<u>Mod. Mod.</u>	\$2,000.00		<u>(-\$1,000.00)</u>	<u>\$1,000.00</u>
			(1200-1999)		
3. <u>Failure to main. equip.</u>	<u>Mod. Minor</u>	\$1200.00		<u>(-600.00)</u>	<u>\$600.00</u>
			(3200-4599)		
4. <u>Failure to notifv</u>	<u>Mod. Major</u>	\$3200.00		<u>(-\$1600.00)</u>	<u>\$1600.00</u>
Total Penalties for all Violations:				\$3,500.00	
Department Expenses					<u>250.00</u>
Total Proposed Settlement					<u>\$3,750.00</u>

Exhibit PJ-1 (Page 5 of 8)

PENALTY COMPUTATION WORKSHEET

Part III - Multi-day Penalties and Adjustments

ADJUSTMENTS	Dollar Amount
Good faith/Lack of good faith prior to discovery: _____	
Justification: _____	
Good faith/Lack of good faith after discovery: _____	(-\$3,500.00)
Justification: <u>Good faith after discovery</u> _____	
History of non-compliance: _____	
Justification: _____	
Economic benefit of non-compliance: _____	
Justification: _____	
Ability to pay: _____	
Justification: _____	
Total Adjustments: _____	
(-\$3,500.00)	

MULTI-DAY PENALTIES	Dollar Amount
Number of days adjustment factor(s) to be applied: _____	
Justification: _____	
_____	
Or	
Number of days matrix amount is to be multiplied: _____	
Justification: _____	
_____	

Exhibit PJ-1 (Page 6 of 8)

PENALTY ASSESSMENT MATRIX\*

EXTENT OF DEVIATION FROM REQUIREMENT

		MAJOR	MODERATE	MINOR
P O T A B L E I N F R A C T I O N S	MAJOR	\$10,000 to \$ 8,000	\$ 7,999 to \$ 6,000	\$ 5,999 to \$ 4,600
	MODERATE	\$ 4,599 to \$ 3,200	\$ 3,199 to \$ 2,000	\$ 1,999 to \$ 1,200
	MINOR	\$ 1,199 to \$ 600	\$599 to \$200	\$199 to \$100

\*Reduced by 1/2 all categories for potable water cases.

Exhibit PJ-1 (Page 7 of 8)

Lawton Chiles  
GovernorDepartment of  
Environmental ProtectionSouthwest District  
3804 Coconut Palm Drive  
Tampa, Florida 33619D.E.P.  
MAY 19 1995  
SOUTHWEST DISTRICT  
TAMPAVirginia B. Wetherell  
SecretaryMay 5, 1995  
Citrus CountyScott Vierma, Interim President  
Southern States Utilities  
1000 Color Place  
Apopka, Florida 32703Re: Proposed Settlement by Short Form Consent Order in Case  
of Southern States Utilities dba Apache Shores WWTP, OGC  
File No. 95-0314.

Dear Mr. Vierma:

The purpose of this letter is to complete the settlement of the violations previously identified by the Department of Environmental Protection ("DEP") in Warning Letter No. WL94-0031DW09SWD dated April 20, 1994, which is attached. The corrective actions required to bring your facility into compliance have been performed. However, you must pay to the Department the amount of \$3,500.00 in civil penalties to complete settlement of the violations described in the attached Warning Letter along with \$250.00 to reimburse DEP's costs, for a total of \$3,750.00. This payment must be made to "The Department of Environmental Protection" by certified check or money order and shall include thereon the OGC number assigned above and the notation "Pollution Recovery Fund". The payment shall be sent to the Department of Environmental Protection, Southwest District Office, 3804 Coconut Palm Drive, Tampa, Florida 33619-8318 within 20 days of your signing this letter.

Your signing of this letter where indicated at the end of page two of this letter constitutes your acceptance of DEP's offer to settle this case on these terms. If you sign this letter, please return it to DEP at the address above. DEP will then countersign the letter and file it with the Clerk of the DEP. When the signed letter is filed with the Clerk, the letter shall constitute a Consent Order, which is final agency action of the DEP, the terms and conditions of


Exhibit PJ-1 (Page 8 of 8)

Southern States Utilities  
Apache Shores WWTP  
OGC File No. 95-0314  
Page 2'

which may be enforced in a court of competent jurisdiction pursuant to Sections 120.69 and 403.121, Florida Statutes. Failure to comply with the terms of this letter once signed by you and entered by the DEP Clerk shall constitute a violation of Section 403.161(1)(b), Florida Statutes.

By countersigning this settlement offer, DEP waives its right to seek judicial imposition of damages, costs and expenses, or civil penalties for the violations described above. By accepting this settlement offer, you waive your right to an administrative hearing to contest this settlement pursuant to Section 120.57, Florida Statutes, and your right to appeal this settlement pursuant to Section 120.69, Florida Statutes. This offer to settle is open until May 26, 1995 or until DEP otherwise withdraws the offer. If you do not sign and return this letter to the Department at the Southwest District address given above by this date, the case will be referred to the DEP's Office of General Counsel with a recommendation that formal enforcement action be taken against you. None of your rights or substantial interests are determined by this letter unless you sign it and it is filed with the DEP Clerk.

Sincerely,



Richard D. Garrity, Ph.D.  
Director of District Management  
Southwest District

I ACCEPT THE TERMS OF THIS SETTLEMENT OFFER.

For Southern States Utilities:

For the DEP:

By:

Scott Vierma  
Scott Vierma, Interim Pres.  
Southern States Utilities  
1000 Color Place  
Apopka, Florida 32703

By:

Richard D. Garrity  
Richard D. Garrity, Ph.D.  
Director of District Management  
State of Florida Department of  
Environmental Protection

ENTERED this 30<sup>th</sup> day of May 1995 in TAMPA, FLORIDA.

FILED, on this date, pursuant to S120.52 Florida Statutes, with the designated Department Clerk, receipt of which is hereby acknowledged.

Thelma Otisley 5-30-95  
Clerk Date

: Citrus County PHU

Attachments



## Department of Environmental Protection

Lawton Chiles  
Governor

Southwest District  
3804 Coconut Palm Drive  
Tampa, Florida 33619

Virginia B. Wetherell  
Secretary

### STATE OF FLORIDA DOMESTIC WASTEWATER FACILITY PERMIT

**PERMITTEE:**

Southern States Utilities, Inc.  
1000 Color Place  
Apopka, FL 32703

<b>PERMIT NUMBER</b>	FLA012669
<b>ISSUANCE DATE</b>	2/27/96
<b>EXPIRATION DATE</b>	11/29/00
<b>FACILITY I.D. NO</b>	FLA012669

Attn.: Mr. Rafael Terrero, P.E.  
Manager, Environmental Services

**FACILITY:**

Marion Oaks WWTF  
14170 S.W. 34th Terrace  
Marion County  
Ocala, FL 34473  
Latitude: 29° 00' 06" N Longitude: 82° 10' 44" W

Received  
FEB 29 1996  
Environmental Services

This permit is issued under the provisions of Chapter 403, Florida Statutes, and applicable rules of the Florida Administrative Code. The above named permittee is hereby authorized to operate the facilities shown on the application and other documents attached hereto or on file with the Department and made a part hereof and specifically described as follows:

**TREATMENT FACILITIES:**

An existing 0.200 MGD three-month average daily flow permitted capacity, Type II extended aeration secondary wastewater treatment facility consisting of one (1) aeration tank with a capacity of approximately 200,000 gallons, one (1) clarifier with a capacity of approximately 85,000 gallons and a surface area of approximately 1,256 square feet, two (2) chlorine contact chambers of 25,224 gallons total volume and three (3) digesters of 128,000 gallons total volume with:

**EFFLUENT DISPOSAL:**

Land Application: An existing 0.200 MGD three-month average daily flow permitted capacity rapid rate (R001) land application system consisting of two (2) rapid-rate restricted public access Part IV percolation/evaporation basins of approximately 86,600 square feet total bottom area. Land application system R001 is located approximately at latitude 29° 00' 06" N, longitude 82° 10' 44" W.

**IN ACCORDANCE WITH:** The limitations, monitoring requirements and other conditions as set forth in Pages 1 through 18 of this permit and the enclosed Discharge Monitoring Report (DMR) and Ground Water Monitoring Report (GWMR).

PERMITTEE: Southern States Utilities, Inc.  
 1000 Color Place  
 Apopka, FL 32703

PERMIT NUMBER: FLA012669  
 EXPIRATION DATE: 11/29/00  
 FACILITY I.D. NO.: FLA012669

I. RECLAIMED WATER AND EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

A. Reuse and Land Application Systems

1. During the period beginning on the issuance date and lasting through the expiration date of this permit, the permittee is authorized to land apply effluent from land application System R001. Such land application shall be limited and monitored by the permittee as specified below:

Parameter	Units	Max./Min.	Reclaimed Water Limitations				Monitoring Requirements			
			Annual Average	Monthly Average	Weekly Average	Single Sample	Monitoring Frequency	Sample Type	Monitoring Location Site Number	Notes
Flow	mgd	Maximum	0.200	-	-	-	Continuous	Recording Flowmeter and Totalizer	EFF-13393	See Condition I.A.4.
Carbonaceous Biochemical Oxygen Demand (5 day)	mg/L	Maximum	20	30	45	60	Every Two Weeks	8-hour flow proportioned composite	EFF-13393	
Total Suspended Solids	mg/L	Maximum	20	30	45	60	Every Two Weeks	8-hour flow proportioned composite	EFF-13393	
Fecal Coliform Bacteria	See Permit Condition I.A.5.						Every Two Weeks	grab	EFF-13393	See Condition I.A.5.
pH	std. units	Range	-	-	-	6.0-8.5	Daily, 5/week	grab	EFF-13393	
Total Residual Chlorine (For Disinfection)	mg/L	Minimum	-	-	-	0.5	Daily, 5/week	grab	EFF-13393	See Condition I.A.6.
Nitrate (as N)	mg/L	Maximum	-	-	-	12	Every Two Weeks	8-hour flow proportioned composite	EFF-13393	





PERMITTEE: Southern States Utilities, Inc.  
 1000 Color Place  
 Apopka, FL 32703

PERMIT NUMBER: FLA012669  
 EXPIRATION DATE: 11/29/00  
 FACILITY I.D. NO.: FLA012669

**B. Other Limitations and Monitoring and Reporting Requirements**

1. During the period beginning period and lasting through the expiration date of this permit, the treatment facility shall be limited and monitored by the permittee as specified below:

Parameter	Units	Max/Min	Limitations				Monitoring Requirements				Notes
			Annual Average	Monthly Average	Weekly Average	Single Sample	Monitoring Frequency	Sample Type	Monitoring Location Site Number		
Carbonaceous Biochemical Oxygen Demand (5 day)	mg/L	Report	-	-	-	-	monthly	8-hour flow proportioned composite	INF-24803	See I.B.3	
Total Suspended Solids	mg/L	Report	-	-	-	-	monthly	8-hour flow proportioned composite	INF-24803	See I.B.3.	

PERMITTEE: Southern States Utilities, Inc.  
 1000 Color Place  
 Apopka, FL 32703

PERMIT NUMBER: FLA012669  
~~EXPIRATION DATE: 11/29/00~~  
 FACILITY I.D. NO.: FLA012669

2. Samples shall be taken at the monitoring site locations listed in Permit Condition I.B.1. and as described below:

Monitoring Location Site Number	Description of Monitoring Location
INF-24803	At headworks, prior to treatment and ahead of return activated sludge line

3. Influent samples shall be collected so that they do not contain digester supernatant or return activated sludge, or any other plant process recycled waters. [62-601.500(4), 5-31-93]
4. Parameters which must be monitored as a result of a ground water discharge (i.e., underground injection or land application system) shall be analyzed in accordance with Chapter 62-601, F.A.C. [62-620.610(18), 11-29-94]
5. The permittee shall provide safe access points for obtaining representative influent, reclaimed water, and effluent samples which are required by this permit. [62-601.500(5), 5-31-93]
6. During the period of operation authorized by this permit, the permittee shall complete and submit to the Department on a monthly basis Discharge Monitoring Report(s) (DMR), Form 62-620.910(10), as attached to this permit. The permittee shall make copies of the attached DMR form(s) and shall submit the completed DMR form(s) to the Southwest District Office at the address specified in Permit Condition I. B. 7 by the twenty-eighth (28th) of the month following the month of operation.

[62-620.610(18), 11-29-94][62-601.300(1), (2), and (3), 5-31-93]

7. Unless specified otherwise in this permit, all reports and notifications required by this permit, including 24-hour notifications, shall be submitted to or reported to, as appropriate, the Department's Southwest District Office at the address specified below:

Florida Department of Environmental Protection  
 Southwest District Office  
 3804 Coconut Palm Drive  
 Tampa, Florida 33619-8318

Phone Number - (813) 744-6100  
 FAX Number - (813) 744-8198

**II. RESIDUALS MANAGEMENT REQUIREMENTS**

**Basic Management Requirements**

1. The residuals generated by this facility shall be lime stabilized to stabilization Class B in accordance with 40 CFR Part 503 and the Operating Protocol submitted with the application for this permit. The lime stabilized residuals shall be land applied.
2. Land application of residuals shall be in accordance with the conditions of this permit and the requirements of Chapter 62-640, F.A.C. [62-640, 3-1-91]
3. The wastewater treatment facility permittee shall be responsible for proper handling, use, and disposal of its residuals and will be held responsible for any disposal violations that occur unless the permittee can demonstrate that it has delivered residuals that meet the chemical criteria and appropriate stabilization requirements of this permit and that the

**PERMITTEE:** Southern States Utilities, Inc.  
1000 Color Place  
Apopka, FL 32703

**PERMIT NUMBER:** FLA012669  
**EXPIRATION DATE:** 11/29/00  
**FACILITY LD. NO.:** FLA012669

disposer (e.g. hauler, contractor, or disposal/land application site owner) has legally agreed in writing to accept responsibility for proper disposal. [62-640.300(3), 3-1-91]

4. The permittee shall sample and analyze the residuals at least once every 12 months. All samples shall be representative and shall be taken after final treatment of the residuals but before use or disposal. Sampling and analysis shall be in accordance with the U.S. Environmental Protection Agency publication - POTW Sludge Sampling and Analysis Guidance Document, 1989. The following parameters shall be sampled and analyzed:

Parameter	Maximum Concentration	Maximum Cumulative Loading
Total Nitrogen	(Report only) % dry weight	Not applicable
Total Phosphorus	(Report only) % dry weight	Not applicable
Total Potassium	(Report only) % dry weight	Not applicable
Cadmium	100 mg/kg dry weight	4.4 pounds /acre
Copper	3000 mg/kg dry weight	125 pounds/acre
Lead	1500 mg/kg dry weight	500 pounds/acre
Nickel	500 mg/kg dry weight	125 pounds/acre
Zinc	10,000 mg/kg dry weight	250 pounds/acre
pH	(Report only) standard units	Not applicable
Total Solids	(Report only) %	Not applicable

5. The annual application rate for cadmium shall not exceed 0.5 lbs/acre/year. [62 - 640.700(3)(e), 3-1-91]
6. Florida water quality criteria and standards shall not be violated as a result of land application of residuals. [62-640.700(3)(c), 3-1-91]

#### *Agricultural Sites*

7. Class B residuals shall not be used on unrestricted access areas. [62-640.600(6)(b), 3-1-91]
8. Class B residuals application shall be in accordance with the Agricultural Use Plan approved by the Department for this facility. [62-640.300(1), 3-1-91]
9. Root crops, and fruits and vegetables which touch the soil and which are to be consumed raw shall not be grown on the application site for 18 months after the last application of Class B residuals. [62-640.600(6)(c), 3-1-91]
10. Fruits and vegetables which do not touch the soil and which are to be consumed raw shall not be harvested from the application site for 30 days following the last application of Class B residuals. Orchard tree crops, which do not come in contact with the residuals due to the

PERMITTEE: Southern States Utilities, Inc.  
 1000 Color Place  
 Apopka, FL 32703

PERMIT NUMBER: FLA012669  
 EXPIRATION DATE: 11/29/00  
 FACILITY I.D. NO.: FLA012669

application method, are exempted. This exemption does not apply to orchard tree crops which have fallen to the ground before harvesting. [62-640.600(6)(d), 3-1-91]

11. Pasture vegetation on the application site shall not be cut or used for grazing by livestock for 30 days following the last application of Class B residuals. [62-640.600(6)(e), 3-1-91]
12. The public shall be restricted from the application area for 12 months after the last application of Class B residuals. [62-640.600(6)(f), 3-1-91]
13. The wastewater treatment facility permittee shall apply for a minor permit revision on DEP Form 62-620.910(9) for new, modified, or expanded residuals land application sites. The facility's permit shall be revised to include the new or revised Agricultural Use Plan(s) prior to application of residuals to the new, modified, or expanded sites. The current Agricultural Use Plan identifies that the residuals shall be lime stabilized prior to land spreading on the following sites:

Site Name	Area in acres Application/Total	Section, Township, and Range	Latitude and Longitude	County	Hauler
Homer Gary - West	15.14 / 100	37 / 16S / 22E	29° 07' 30" N 82° 08' 40" W	Marion	American Pipe & Tank
Homer Gary - South	130 / 160	5 / 16S / 22E	29° 07' 55" N 82° 07' 58" W	Marion	American Pipe & Tank
Gary Garner - North	208 / 276	34 / 13S / 22E	29° 19' 15" N 82° 06' 08" W	Marion	American Pipe & Tank
Hampton Site	40 / 48	11 / 16S / 22E	29° 07' 30" N 82° 04' 03" W	Marion	American Pipe & Tank

[62-620.330, 11-29-94]

14. Annual residuals application rates shall not exceed the agronomic rates based on the nitrogen requirements of the site vegetation in accordance with the approved Agricultural Use Plan. [62-640.700(3)(d), 3-1-91]
15. Residuals shall be applied with techniques and equipment to assure uniform application over the site. [62-640.700(3)(n), 3-1-91]
16. The pH of the domestic wastewater residuals soil mixture shall be 6.5 or greater at the time domestic wastewater residuals are applied. At a minimum, testing shall be done annually. [62-640.700(3)(h), 3-1-91]
17. The permittee shall maintain records of application areas and application rates on DEP Form 62-640.900(3) and shall have these records available for inspection upon request by the Department or the appropriate Local Environmental Program. These records shall include:



PERMITTEE: Southern States Utilities, Inc.  
 1000 Color Place  
 Apopka, FL 32703

PERMIT NUMBER: FLA012669  
 EXPIRATION DATE: 11/29/00  
 FACILITY I.D. NO.: FLA012669

- d. Sodium
- e. Chloride
- f. Fecal Coliform
- g. pH (field measurement)
- h. Sulfate
- i. Ammonia
- j. Specific Conductance (field measurement)
- k. Temperature (field measurement)
- l. Turbidity

[62-522.600(11)(b), 4/14/94]

6. All ground water monitoring wells shall be sampled, analyzed and the results reported in accordance with the following schedule:

<u>Sample Period</u>	<u>Report Due Date</u>
1st Quarter (January-March)	April 15
2nd Quarter (April-June)	July 15
3rd Quarter (July-September)	October 15
4th Quarter (October-December)	January 15

[62-522.600(11)(b), 4/14/94]

7. Ground water monitoring well test results shall be submitted on Part D of Form 62-620.910(10). Results shall be submitted at the intervals specified in Permit Condition III.9. for each year during the period of operation allowed by this permit. Results shall be submitted with the DMR in accordance with Permit Condition I.D.2. [62-522.600(11)(b), 4/14/94] [62-601.300(3), 62.601.700 and Figure 3 of 62-601] [62-620.610.(18), 11/29/94]
8. The permittee shall submit to the Department an annual cumulative summary of the quarterly ground water data. This document will be submitted with the 3rd Quarter DMR pursuant to Item III.9. The data shall be presented in both graphical and tabular formats for each ground water monitoring well. The specific parameters are to include the following:

Nitrate (as N)	mg/L
Sodium	mg/L
Chlorides	mg/L
Total Dissolved Solids (TDS)	mg/L
Ammonia (NH <sub>3</sub> as N)	mg/L
Fecal Coliform	cts/100 ml
Specific Conductivity	uhmos/cm
pH	std. units
Turbidity	NTUs
Water Level	feet (above Mean Sea Level)

[62-522.600(11)(b), 4/14/94]

9. The ground water minimum criteria specified in Rule 62-520.400, shall be met within the zone of discharge. [62-520.400 and 62-522.300(1), 4/14/94]
10. All ground water quality criteria specified in Chapter 62-520 and Chapter 62-522 shall be met at the edge of the zone of discharge. The zone of discharge shall extend horizontally

PERMITTEE: Southern States Utilities, Inc.  
1000 Color Place  
Apopka, FL 32703

PERMIT NUMBER: FLA012669  
EXPIRATION DATE: 11/29/00  
FACILITY I.D. NO.: FLA012669

100 feet or to the site property line, whichever is less, and vertically to the base of the surficial aquifer. [62-520.200(23), 62-520.400, 62-520.420, 4/14/94, 62-522.300(1), 62-522.400, and 62-522.410, 4/14/94]

11. If at any time, background ground water standards are exceeded at the edge of the zone of discharge, the permittee has fifteen (15) days from receipt of the laboratory analysis in which to resample the monitor well(s) to verify the original analysis. The monitoring test results must be submitted to the Department within fifteen (15) days of receipt of the reanalyses from the laboratory. Should the permittee choose not to resample, the Department will consider the water quality analysis as representative of current ground water conditions at the facility. [62-522.500, 4/14/94]
12. Sixty (60) days prior to the submittal of the wastewater facility renewal application of this permit, the permittee shall sample all groundwater monitor wells for the Florida Primary and Secondary Drinking Water Standards contained in Chapter 62-550, F.A.C. (excluding asbestos, acrylamide, and epichlorohydrin), fecal coliform, and EPA Methods 601 and 602. The analyses shall be submitted on Part D of Form 62-620.910(10) to the Department and with the renewal application. [62-522.500, 4/14/94]
13. Sixty (60) days prior to the submittal of the wastewater facility renewal application of this permit, the permittee shall provide a 24 hour composite effluent sample prior to discharge to the facility reuse system. The composite sample shall be analyzed for the Florida Primary and Secondary Drinking Water Standards in accordance with Chapter 62-550, F.A.C., the EPA Priority Pollutants and fecal coliform. The effluent analysis shall be submitted to the Department with the renewal application. The analyses results will be reported on Form 62-601.900(4), or a Department approved exact replica, compatible with the data entry into the Department's computer system. [62-522.500, 4/14/94]

#### IV. ADDITIONAL REUSE AND LAND APPLICATION REQUIREMENTS

##### Part IV Rapid-rate/restricted access system(s)

1. All ground water quality criteria specified in Chapter 62-520, F.A.C., shall be met at the edge of the zone of discharge. The zone of discharge for this project shall extend horizontally to the site property line and vertically to the base of the surficial aquifer. [62-520.200(23), 4/14/94] [62-522.400 and 62-522.410, 4/14/94]
2. Warning signs shall be posted around the site boundaries to designate the nature of the project area. [62-610.518, 4/2/90]
3. Percolation ponds, infiltration basins or trenches, and storage ponds shall be enclosed with a fence or provided with features to discourage the entry of animals and unauthorized persons. [62-610.518, 4/2/90]
4. The annual average hydraulic loading rate shall be limited to a maximum of 3 inches per day (as applied to the entire bottom area). [62-610.523(3), 4/2/90]
5. Rapid-rate systems shall be routinely maintained to control vegetation growth and to maintain percolation capability by scarification or removal of deposited solids. [62-610.523(6), 4/2/90]
6. Routine aquatic weed control and regular maintenance of storage pond embankments and access areas are required. [62-610.515 and 62-610.415(6), 4/2/90]

PERMITTEE: Southern States Utilities, Inc.  
1000 Color Place  
Apopka, FL 32703

PERMIT NUMBER: FLA012669  
EXPIRATION DATE: 11/29/00  
FACILITY I.D. NO.: FLA012669

7. Overflows from emergency discharge facilities on storage ponds or on infiltration ponds, basins, or trenches shall be reported as an abnormal event to the Department's Southwest District Office, within 24 hours of an occurrence as an abnormal event. The provisions of Rule 62-610.880, F.A.C.; shall be met. [62-610.880, 62-610.415(5), 62-610.515, and 62-610.516, 4/2/90]

#### V. OPERATION AND MAINTENANCE REQUIREMENTS

##### *Staffing Requirements*

1. During the period of operation authorized by this permit, the wastewater facilities shall be operated under the supervision of a(n) operator(s) certified in accordance with Chapter 61E12-41, F.A.C. In accordance with Chapter 62-699, F.A.C., this facility is a Category III, Class C facility and, at a minimum, operators with appropriate certification must be on the site as follows:

A Class C or higher operator 1/2 hour/day for 5 days/week and one weekend visit. The lead operator must be a Class C operator, or higher.

2. A certified operator shall be on call during periods the plant is unattended. [62-699.311(1), 5-20-92]

##### *Capacity Analysis Report and Operation and Maintenance Performance Report Requirements*

3. An updated capacity analysis report shall be submitted to the Department with the next wastewater permit renewal application. The updated capacity analysis report shall be prepared in accordance with Rule 62-600.405, F.A.C. [62-600.405(5), 6-8-93]
4. The application to renew this permit shall include a detailed operation and maintenance performance report prepared in accordance with Rule 62-600.735, F.A.C. [62-600.735(1), 6-8-93]

##### *Recordkeeping Requirements*

5. The permittee shall maintain the following records and make them available for inspection on the site of the permitted facility:
  - a. Records of all compliance monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation and a copy of the laboratory certification showing the certification number of the laboratory, for at least three years from the date the sample or measurement was taken;
  - b. Copies of all reports required by the permit for at least three years from the date the report was prepared;
  - c. Records of all data, including reports and documents, used to complete the application for the permit for at least three years from the date the application was filed;
  - d. Monitoring information, including a copy of the laboratory certification showing the laboratory certification number, related to the residuals use and disposal activities for the time period set forth in Chapter 62-640, F.A.C., for at least three years from the date of sampling or measurement;





PERMITTEE: Southern States Utilities, Inc.  
1000 Color Place  
Apopka, FL 32703

PERMIT NUMBER: FLA012669  
EXPIRATION DATE: 11/29/00  
FACILITY I.D. NO.: FLA012669

5. Collection/transmission system overflows shall be reported to the Department in accordance with Permit Condition IX. 20. [62-604.550, 5-31-93] [62-620.610(20), 11-29-94]
6. The acceptance, by the operating authority of a collection/transmission system or by the permittee of a treatment plant, of connections of wastewater discharges which have not received necessary pretreatment or which contain materials or pollutants (other than normal domestic wastewater constituents):
  - a. Which may cause fire or explosion hazards; or
  - b. Which may cause excessive corrosion or other deterioration of wastewater facilities due to chemical action or pH levels; or
  - c. Which are solid or viscous and obstruct flow or otherwise interfere with wastewater facility operations or treatment; or
  - d. Which result in treatment plant discharges having temperatures above 40° C is prohibited.  
[62-604.130(4), 5-31-93]
7. The treatment facility shall be enclosed with a fence or otherwise provided with features to discourage the entry of animals and unauthorized persons. [62-600.400(2)(b), 6-8-93]
8. Screenings and grit removed from the wastewater facilities shall be collected in suitable containers and hauled to a Department approved Class I landfill or to a landfill approved by the Department for receipt/disposal of screenings and grit. [62-7.540, 12-10-85]
9. The permittee shall provide adequate notice to the Department of the following:
  - a. Any new introduction of pollutants into the facility from an industrial discharger which would be subject to Chapter 403, F.S., and the requirements of Chapter 62-620, F.A.C. if it were directly discharging those pollutants; and
  - b. Any substantial change in the volume or character of pollutants being introduced into that facility by a source which was identified in the permit application and known to be discharging at the time the permit was issued.

Adequate notice shall include information on the quality and quantity of effluent introduced into the facility and any anticipated impact of the change on the quantity or quality of effluent or reclaimed water to be discharged from the facility.

[62-620.625(2), 11-29-94]

#### IX. GENERAL CONDITIONS

1. The terms, conditions, requirements, limitations and restrictions set forth in this permit are binding and enforceable pursuant to Chapter 403, Florida Statutes. Any permit noncompliance constitutes a violation of Chapter 403, Florida Statutes, and is grounds for enforcement action, permit termination, permit revocation and reissuance, or permit revision. [62-620.610(1), 11-29-94]
2. This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviations from the approved

PERMITTEE: Southern States Utilities, Inc.  
1000 ~~Color Plaza~~  
Apopka, FL 32703

PERMIT NUMBER: FLA012669  
EXPIRATION DATE: 11/29/00  
FACILITY I.D. NO.: FLA012669

drawings, exhibits, specifications or conditions of this permit constitutes grounds for revocation and enforcement action by the Department. [62-620.610(2), 11-29-94]

3. As provided in Subsection 403.087(6), F.S., the issuance of this permit does not convey any vested rights or any exclusive privileges. Neither does it authorize any injury to public or private property or any invasion of personal rights, nor authorize any infringement of federal, state, or local laws or regulations. This permit is not a waiver of or approval of any other Department permit or authorization that may be required for other aspects of the total project which are not addressed in this permit. [62-620.610(3), 11-29-94]
4. This permit conveys no title to land or water, does not constitute state recognition or acknowledgment of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the State. Only the Trustees of the Internal Improvement Trust Fund may express State opinion as to title. [62-620.610(4), 11-29-94]
5. This permit does not relieve the permittee from liability and penalties for harm or injury to human health or welfare, animal or plant life, or property caused by the construction or operation of this permitted source; nor does it allow the permittee to cause pollution in contravention of Florida Statutes and Department rules, unless specifically authorized by an order from the Department. The permittee shall take all reasonable steps to minimize or prevent any discharge, reuse of reclaimed water, or residuals use or disposal in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. [62-620.610(5), 11-29-94]
6. If the permittee wishes to continue an activity regulated by this permit after its expiration date, the permittee shall apply for and obtain a new permit. [62-620.610(6), 11-29-94]
7. The permittee shall at all times properly operate and maintain the facility and systems of treatment and control, and related appurtenances, that are installed and used by the permittee to achieve compliance with the conditions of this permit. This provision includes the operation of backup or auxiliary facilities or similar systems when necessary to maintain or achieve compliance with the conditions of the permit. [62-620.610(7), 11-29-94]
8. This permit may be modified, revoked and reissued, or terminated for cause. The filing of a request by the permittee for a permit revision, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [62-620.610(8), 11-29-94]
9. The permittee, by accepting this permit, specifically agrees to allow authorized Department personnel, including an authorized representative of the Department and authorized EPA personnel, when applicable, upon presentation of credentials or other documents as may be required by law, and at reasonable times, depending upon the nature of the concern being investigated, to:
  - a. Enter upon the permittee's premises where a regulated facility, system, or activity is located or conducted, or where records shall be kept under the conditions of this permit;
  - b. Have access to and copy any records that shall be kept under the conditions of this permit;

PERMITTEE: Southern States Utilities, Inc.  
1000 Color Place  
Apopka, FL 32703

PERMIT NUMBER: FLA012669  
EXPIRATION DATE: 11/29/00  
FACILITY I.D. NO.: FLA012669

- c. Inspect the facilities, equipment, practices, or operations regulated or required under this permit; and
- d. Sample or monitor any substances or parameters at any location necessary to assure compliance with this permit or Department rules.

*[62-620.610(9), 11-29-94]*

10. In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data, and other information relating to the construction or operation of this permitted source which are submitted to the Department may be used by the Department as evidence in any enforcement case involving the permitted source arising under the Florida Statutes or Department rules, except as such use is proscribed by Section 403.111, Florida Statutes, or Rule 62-620.302, Florida Administrative Code. Such evidence shall only be used to the extent that it is consistent with the Florida Rules of Civil Procedure and applicable evidentiary rules. *[62-620.610(10), 11-29-94]*
11. When requested by the Department, the permittee shall within a reasonable time provide any information required by law which is needed to determine whether there is cause for revising, revoking and reissuing, or terminating this permit, or to determine compliance with the permit. The permittee shall also provide to the Department upon request copies of records required by this permit to be kept. If the permittee becomes aware of relevant facts that were not submitted or were incorrect in the permit application or in any report to the Department, such facts or information shall be promptly submitted or corrections promptly reported to the Department. *[62-620.610(11), 11-29-94]*
12. Unless specifically stated otherwise in Department rules, the permittee, in accepting this permit, agrees to comply with changes in Department rules and Florida Statutes after a reasonable time for compliance; provided, however, the permittee does not waive any other rights granted by Florida Statutes or Department rules. A reasonable time for compliance with a new or amended surface water quality standard, other than those standards addressed in Rule 62-302.500, F.A.C., shall include a reasonable time to obtain or be denied a mixing zone for the new or amended standard. *[62-620.610(12), 11-29-94]*
13. The permittee, in accepting this permit, agrees to pay the applicable regulatory program and surveillance fee in accordance with Rule 62-4.052, F.A.C. *[62-620.610(13), 11-29-94]*
14. This permit is transferable only upon Department approval in accordance with Rule 62-620.340, F.A.C. The permittee shall be liable for any noncompliance of the permitted activity until the transfer is approved by the Department. *[62-620.610(14), 11-29-94]*
15. The permittee shall give the Department written notice at least 60 days before inactivation or abandonment of a wastewater facility and shall specify what steps will be taken to safeguard public health and safety during and following inactivation or abandonment. *[62-620.610(15), 11-29-94]*
16. The permittee shall apply for a revision to the Department permit in accordance with Rules 62-620.300, 62-620.420 or 62-620.450, F.A.C., as applicable, at least 90 days before construction of any planned substantial modifications to the permitted facility is to commence or with Rule 62-620.300 for minor modifications to the permitted facility. A revised permit shall be obtained before construction begins except as provided in Rule 62-620.300, F.A.C. *[62-620.610(16), 11-29-94]*

PERMITTEE: Southern States Utilities, Inc.  
1000 Color Place  
Apopka, FL 32703

PERMIT NUMBER: FLA012669  
EXPIRATION DATE: 11/29/00  
FACILITY LD. NO.: FLA012669

17. The permittee shall give advance notice to the Department of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements. The permittee shall be responsible for any and all damages which may result from the changes and may be subject to enforcement action by the Department for penalties or revocation of this permit. The notice shall include the following information:
- A description of the anticipated noncompliance;
  - The period of the anticipated noncompliance, including dates and times; and
  - Steps being taken to prevent future occurrence of the noncompliance.
- [62-620.610(17), 11-29-94]
18. Sampling and monitoring data shall be collected and analyzed in accordance with Rule 62-4.246, Chapters 62-160 and 62-601, F.A.C., and 40 CFR 136, as appropriate.
- Monitoring results shall be reported at the intervals specified elsewhere in this permit and shall be reported on a Discharge Monitoring Report (DMR), DEP Form 62-620.910(10).
  - If the permittee monitors any contaminate more frequently than required by the permit, using Department approved test procedures, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR.
  - Calculations for all limitations which require averaging of measurements shall use an arithmetic mean unless otherwise specified in this permit.
  - Any laboratory test required by this permit for domestic wastewater facilities shall be performed by a laboratory that has been certified by the Department of Health and Rehabilitative Services (DHRS) under Chapter 10D41, F.A.C., to perform the test. On-site tests for dissolved oxygen, pH, and total chlorine residual shall be performed by a laboratory certified to test for those parameters or under the direction of an operator certified under Chapter 61E12-41, F.A.C.
  - Under Chapter 62-160, F.A.C., sample collection shall be performed by following the protocols outlined in "DER Standard Operating Procedures for Laboratory Operations and Sample Collection Activities" (DER-QA-001/92). Alternatively, sample collection may be performed by an organization who has an approved Comprehensive Quality Assurance Plan (CompQAP) on file with the Department. The CompQAP shall be approved for collection of samples from the required matrices and for the required tests.
- [62-620.610(18), 11-29-94]
19. Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule detailed elsewhere in this permit shall be submitted no later than 14 days following each schedule date. [62-620.610(19), 11-29-94]
20. The permittee shall report to the Department any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the permittee becomes aware of the circumstances. A written submission shall also be provided within five days of the time the permittee becomes aware of the circumstances. The written submission shall contain: a description of the noncompliance and its cause; the period of noncompliance including exact dates and time, and if the noncompliance has not

PERMITTEE: Southern States Utilities, Inc.  
1000 Color Place  
Apopka, FL 32703

PERMIT NUMBER: FLA012669  
EXPIRATION DATE: 11/29/00  
FACILITY I.D. NO.: FLA012669

been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent recurrence of the noncompliance.

a. The following shall be included as information which must be reported within 24 hours under this condition:

1. Any unanticipated bypass which causes any reclaimed water or effluent to exceed any permit limitation or results in an unpermitted discharge,
2. Any upset which causes any reclaimed water or the effluent to exceed any limitation in the permit,
3. Violation of a maximum daily discharge limitation for any of the pollutants specifically listed in the permit for such notice, and
4. Any unauthorized discharge to surface or ground waters.

b. If the oral report has been received within 24 hours, the noncompliance has been corrected, and the noncompliance did not endanger health or the environment, the Department shall waive the written report.

[62-620.610(20), 11-29-94]

21. The permittee shall report all instances of noncompliance not reported under Permit Conditions IX. 18. and 19. of this permit at the time monitoring reports are submitted. This report shall contain the same information required by Permit Condition IX. 20 of this permit.

[62-620.610(21), 11-29-94]

22. Bypass Provisions.

a. Bypass is prohibited, and the Department may take enforcement action against a permittee for bypass, unless the permittee affirmatively demonstrates that:

1. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage; and
2. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
3. The permittee submitted notices as required under Permit Condition IX. 22. b. of this permit.

b. If the permittee knows in advance of the need for a bypass, it shall submit prior notice to the Department, if possible at least 10 days before the date of the bypass. The permittee shall submit notice of an unanticipated bypass within 24 hours of learning about the bypass as required in Permit Condition IX. 20. of this permit. A notice shall include a description of the bypass and its cause; the period of the bypass, including exact dates and times; if the bypass has not been corrected, the anticipated time it is expected to continue; and the steps taken or planned to reduce, eliminate, and prevent recurrence of the bypass.

PERMITTEE: Southern States Utilities, Inc.  
1000 Color Place  
Apopka, FL 32703

PERMIT NUMBER: FLA012669  
EXPIRATION DATE: 11/29/00  
FACILITY I.D. NO.: FLA012669

- c. The Department shall approve an anticipated bypass, after considering its adverse effect, if the permittee demonstrates that it will meet the three conditions listed in Permit Condition IX. 22. a. 1. through 3. of this permit.
- d. A permittee may allow any bypass to occur which does not cause reclaimed water or effluent limitations to be exceeded if it is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of Permit Condition IX. 22. a. through c. of this permit.

[62-620.610(22), 11-29-94]

23. Upset Provisions

- a. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed contemporaneous operating logs, or other relevant evidence that:
  - 1. An upset occurred and that the permittee can identify the cause(s) of the upset;
  - 2. The permitted facility was at the time being properly operated;
  - 3. The permittee submitted notice of the upset as required in Permit Condition IX. 20. of this permit; and
  - 4. The permittee complied with any remedial measures required under Permit Condition IX. 5. of this permit.
- b. In any enforcement proceeding, the permittee seeking to establish the occurrence of an upset has the burden of proof.
- c. Before an enforcement proceeding is instituted, no representation made during the Department review of a claim that noncompliance was caused by an upset is final agency action subject to judicial review.

[62-620.610(23), 11-29-94]

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

PLEASE PRINT AND MAIL THIS REPORT TO: FDEP; Water Facilities Section; 4404 Coconut Palm Drive; Tampa, FL 33619-8318

Marion County

PERMITTEE NAME: Southern States Utilities, Inc.  
 MAILING ADDRESS: 1000 Color Place  
 Apopka, FL 34473

PERMIT NUMBER: FLA012669

MONITORING PERIOD--From:

To:

LIMIT: Final

CLASS SIZE: Minor

GROUP: Domestic

FACILITY ID: FLA012669

DISCHARGE POINT NUMBER: R001 (13393)

PLANT SIZE/TREATMENT TYPE: 3C

FACILITY: Marion Oaks WWTF  
 LOCATION: 14170 S.W. 34th Terrace, Ocala, FL 34473

Please read instructions before completing this form.

Parameter		Quantity or Loading			Quality or Concentration			No. Ex.	Frequency of Analysis	Sample Type
		Average	Maximum	Units	Minimum	Average	Maximum			
Flow (Three-Month Annual Average Daily Flow) Storet No.: 50053	Sample Measurement		.....	MGD	.....	.....	.....			
	Permit Requirement	0.200	.....	MGD	.....	.....	.....		Continuous	Record Flowmeters and Totalizer
CBOD, 5 day 20°C Storet No.: 80082	Sample Measurement	.....	.....	.....	.....	.....	.....			
	Permit Requirement	.....	.....	.....	.....	20 Annual 30 Monthly 45 Weekly	60 Single Sample	mg/L	Every Two Weeks	Grab
Solids, Total Suspended Storet No.: 00530	Sample Measurement	.....	.....	.....	.....	.....	.....			
	Permit Requirement	.....	.....	.....	.....	20 Annual 30 Monthly 45 Weekly	60 Single Sample	mg/L	Every Two Weeks	Grab
Fecal Coliform Bacteria Storet No.: 31616	Sample Measurement	.....	.....	.....	.....	.....	.....			
	Permit Requirement	.....	.....	.....	.....	200 Annual 200 Monthly	800/100 mL Single Sample	#/100 mL	Every Two Weeks	Grab
pH Storet No.: 00400	Sample Measurement	.....	.....	.....	.....	.....	.....			
	Permit Requirement	.....	.....	.....	6.00	.....	8.50	Standard	Daily, 5/wk	Grab
Total Residual Chlorine (For disinfection) Storet No.: 50060	Sample Measurement	.....	.....	.....	.....	.....	.....			
	Permit Requirement	.....	.....	.....	0.5	.....	.....	mg/L	Daily, 5/wk	Grab
Nitrate (as N) Storet No.: 00620	Sample Measurement	.....	.....	.....	.....	.....	.....			
	Permit Requirement	.....	.....	.....	.....	.....	12.0 Single Sample	mg/L	Every Two Weeks	Grab

I certify under penalty of law that I have personally examined and am familiar with the information submitted herein; and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT (Type or Print)	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO. ( )	DATE (YY/MM/DD)
---	--	----------------------	-----------------

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

PAGE 19 OF 26

EXHIBIT (Part 14)



ADDITIONAL SHEET 1 (To be used if more space is needed)

PERMITTEE NAME: Southern States Utilities, Inc.  
 MAILING ADDRESS: 1000 Color Place  
 Apopka, FL 34473

PERMIT NUMBER: FLA012669  
 MONITORING PERIOD--From: To:  
 LIMIT: Final  
 CLASS SIZE: Minor GROUP: Domestic  
 FACILITY ID: FLA012669  
 DISCHARGE POINT NUMBER: Effluent Point 24803  
 PLANT SIZE/TREATMENT TYPE: 3C

FACILITY: Marion Oaks WWTF  
 LOCATION: 14170 S.W. 34th Terrace, Ocala, FL 34473

Please read instructions before completing this form.

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION			No. Ex.	Frequency of Analysis	Sample Type	
		Average	Maximum	Units	Minimum	Average	Maximum				Units
COD, 5 day 20°C	Sample Measurement	*****	*****	*****	*****		*****	mg/L	*****		
(INFLUENT) Storet No.: 80082	Permit Requirement	*****	*****	*****	*****	Report Monthly Sample	*****	mg/L	*****	Monthly	Grab
Soilds, Total Suspended	Sample Measurement	*****	*****	*****	*****		*****	mg/L	*****		
(INFLUENT) Storet No.: 00530	Permit Requirement	*****	*****	*****	*****	Report Monthly Sample	*****	mg/L	*****	Monthly	Grab

DAILY SAMPLE RESULTS - PART B

Facility ID: FLA00069  
Month/Year:

Three-month Average Daily Flow:  
Daily Flow % of Permitted Capacity:

Days of the Month	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30/31
Flow (MGD)																														
Chlorine Residual after Contact (mg/L as Cl <sub>2</sub> )																														
CBOD, Influent (mg/L as O <sub>2</sub> )																														
TSS Influent (mg/L)																														
CBOD, Effluent (mg/L as O <sub>2</sub> )																														
TSS Effluent (mg/L)																														
pH Effluent (standard units)																														
Fecal Coliform (#/100ML)																														

PLANT STAFFING: Day Shift Operator Class: Certificate No.: Name:  
Evening Shift Operator Class: Certificate No.: Name:  
Night Shift Operator Class: Certificate No.: Name:  
Lead Operator Class: Certificate No.: Name:

Type of Effluent Disposal or Reclaimed Water Reuse:  
Limited Wet Weather Discharge Activated: Yes: No: Not Applicable: If yes, cumulative days of wet weather discharge:  
\*Attach additional sheets if necessary to list all certified operators.

EXHIBIT \_\_\_\_\_  
(PAGE 14)  
PAGE 21 OF 26

**GROUNDWATER MONITORING REPORT - PART D**

Facility ID: FLA012699  
 Month/Year:  
 Sample Obtained:  
 Was the well pumped before sampling? Yes No

Test Site ID: 13399 (MW-2A)  
 Well Type: Background  
 Ground Water Class: G-2

Parameter	Store Code	Sampling Method	Samples Filtered (Y/N)	Preservatives Added	Analysis Method	Analysis Result/Units	Detection Limits/Units
Water Level (feet) above Mean Sea Level							
Nitrate (mg/L as N)							
TDS (mg/L)							
Sodium (mg/L)							
Chloride (mg/L)							
Fecal Coliform (#/100ML)							
pH (standard units) (field measurement)							
Sulfate							
Ammonia (NH <sub>3</sub> as N)							
Specific Conductance (uhms/cm) (field measurement)							
Temperature (° C) (field measurement)							
Turbidity (NTUs)							

Comments and Explanations:

EXHIBIT \_\_\_\_\_  
 (PARTIAL)  
 PAGE 22 OF 26

GROUNDWATER MONITORING REPORT - PART D

Well ID: FLA012699

Test Site ID: 13397 (MW-4A)

Year:

Well Type: Compliance

Sample Obtained:

Ground Water Class: G-2

Was the well pumped before sampling? Yes No

Parameter	Store Code	Sampling Method	Samples Filtered (Y/N)	Preservatives Added	Analysis Method	Analysis Result/Units	Detection Limits/Units
Water Level (feet) above Mean Sea Level							
Nitrate (mg/L as N)							
TDS (mg/L)							
Sodium (mg/L)							
Chloride (mg/L)							
Fecal Coliform (#/100ML)							
pH (standard units) (field measurement)							
Sulfate							
Ammonia (NH <sub>3</sub> as N)							
Specific Conductance (uhms/cm) (field measurement)							
Temperature (° C) (field measurement)							
Turbidity (NTUs)							

Comments and Explanations:

EXHIBIT \_\_\_\_\_  
 PAGE 23 OF 26  
 (PART 14)

GROUNDWATER MONITORING RING REPORT - PART D

Facility ID: FLA012699

Month/Year:

Sample Obtained:

Was the well pumped before sampling? Yes No

Test Site ID: 13396 (MW-5A)

Well Type: Compliance

Ground Water Class: G-2

Parameter	Store Code	Sampling Method	Samples Filtered (Y/N)	Preservatives Added	Analysis Method	Analysis Result/Units	Detection Limits/Units
Water Level (feet) above Mean Sea Level							
Nitrate (mg/L as N)							
TDS (mg/L)							
Sodium (mg/L)							
Chloride (mg/L)							
Fecal Coliform (#/100ML)							
pH (standard units) (field measurement)							
Sulfate							
Ammonia (NH <sub>3</sub> as N)							
Specific Conductance (uhms/cm) (field measurement)							
Temperature (°C) (field measurement)							
Turbidity (NTUs)							

Comments and Explanations:

EXHIBIT \_\_\_\_\_  
 (RM-14)  
 PAGE 24 OF 26

PART B - DAILY SAMPLE RESULTS contd.

Enter the type of effluent disposal or reclaimed water reuse (surface water discharge, ocean outfall, slow rate land application-public access, slow rate land application-restricted public access, rapid rate land application, absorption field, underground injection).

If this plant does not have a limited wet weather discharge permitted under the provision of Rule 62-610.860, F.A.C., check not applicable. If the plant activated the wet weather discharge during the reporting month, check yes and attach PART C - LIMITED WET WEATHER DISCHARGE.

PART C - LIMITED WET WEATHER DISCHARGE

This part is applicable only to limited wet weather discharges from reuse systems describe in Rule 62-610.860, F.A.C. If applicable, this part is to be completed and submitted each month reclaimed water or effluent is discharged by a limited wet weather discharge. For months with no discharge, Part C need not be submitted. All information is to be provided for each day on which the limited wet weather discharge was activated. All information is to be typed or printed in ink.

Facility ID: This is the identification number assigned by the Department for the facility.

Month/Year: This is the period during which the data on this report was collected and analyzed.

Rainfall Information: Rainfall gauging station requires entry of the name and location of the station. Source of Climatological (normal rainfall) data is the source of the information required for Cumulative rainfall for the average rainfall year which is the amount of rain, in inches, which falls during an average rainfall year from January through the month for which this part contains data. Cumulative rainfall to date for this calendar year is the total amount of rain, in inches, that has been recorded since January 1 of the current year through the month for which this Part contains data.

Date: Enter the date on which the discharge occurred.

Duration of Discharge: Enter the number of hours, to the nearest 0.1 of an hour (0.1 = 6 min.) during each day of discharge that reclaimed water was actually discharged to surface waters.

Gallons Discharged: Enter the quantity in millions of gallons of reclaimed water discharged during the period shown in Duration of Discharge. Show the units as millions of gallons (mg), accurate to the nearest 0.01.

Average Discharge Flow Rate: Divide Gallons Discharged by Duration of Discharge. Record in million gallons per day (MGD).

Average Upstream Flow Rate: Enter the average flow rate in the receiving stream upstream from the point of discharge for the period shown in Duration of Discharge. The average flow rate can be calculated based on two measurements; one made at the start and one made at the end of the discharge period. Measurements are to be made at the upstream gauging station described in the permit.

Stream Dilution Factor: Enter the stream dilution ratio accurate to the nearest 0.1. To calculate the factor, divide the Average Upstream Flow Rate by the Average Discharge Flow Rate.

CBOD<sub>5</sub>: Enter the average CBOD<sub>5</sub> of the reclaimed water discharged during the period shown in Duration of Discharge.

TKN: Enter the average TKN of the reclaimed water discharged during the period shown in Duration of Discharge.

Reason for Discharge: Provide a brief explanation of the factors contributing to the need to activate the limited wet weather discharge.

PART D - GROUNDWATER MONITORING REPORT

This part is applicable only to groundwater monitoring wells. Type or print in ink the required data. All samples shall be collected and analyzed in accordance with Chapter 62-160, F.A.C. Laboratory reports shall be kept on file in the location indicated in your permit and made available for inspection upon request by the Department.

Facility ID: This is the identification number of the facility assigned by the Department.

Test Site ID: This is the identification number of the sampling site listed in your permit.

Month/Year: This is the period during which the data on this report was collected and analyzed. If the period is greater than one month, indicate beginning month to ending month.

Well Type: Indicate if the well being sampled is background, intermediate, compliance, or other. If other, explain in the comment section.

Date Sample Obtained: This is the date the sample was taken.

Ground Water Class: This is the classification of the ground water under Chapter 62-522, F.A.C.

Parameter: Analyze the parameters the permit requires. List any additional parameters from the permit which are not pre-listed here. If there are any parameters listed here which are not required by your permit, enter NR on that line.

Storet Code: Enter the Storet Code associated with the parameter.

Sampling Method: Describe the sampling method used.

Samples Filtered: Indicate whether the sample obtained was filtered (Y) or unfiltered (N).

Preservatives Added: State what preservatives were added to the sample.

Analysis Method: Indicate the analytical method used. Record the number from Chapter 62-160 or Chapter 62-601, F.A.C., or from other sources.

Analysis Result/Units: Record the results of the analysis. If the result was below the minimum detection limit, indicate that. Enter the units associated with the results of the analysis.

Detection Limits/Units: Record the detection limits and the units associated with them.

Comments and Explanations: Use this space to make any comments on or explanations of results which are unexpected.

## QUARTERLY REPORT ON GROUND WATER MONITORING

Permit Number FLA012699

Date \_\_\_\_\_

Marion Oaks WWTF  
Facility/Installation Name

Address \_\_\_\_\_ City \_\_\_\_\_ State \_\_\_\_\_ Zip \_\_\_\_\_ County \_\_\_\_\_

Owner or Authorized Representative's Name \_\_\_\_\_ Title \_\_\_\_\_

Method of Discharge \_\_\_\_\_

Type of Industry \_\_\_\_\_

Report for Period \_\_\_\_\_ Date \_\_\_\_\_ to \_\_\_\_\_ Date \_\_\_\_\_

Attach monitoring data as approved in monitoring plan using parameter monitoring report forms. When applicable, attach additional sheets describing any changes in the background water quality and the discharge plume since the last reported description. Include any changes in size, direction of movement, rate of movement, and concentration changes of plume constituents in violation of the applicable standards.

NOTE: Pursuant to Rule 62-4.700(6)(k)3., at any time there is a change in the permitted volume, location or chemical, physical or microbiological composition of the discharge plume, the permittee shall notify the Department and, if required by the Department, submit a new report stating the volume and chemical, physical and microbiological compositions of the discharge at the point of release or contact with the ground water at the site boundary.

## CERTIFICATION

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment.

\_\_\_\_\_  
Owner or Authorized Representative's Signature\_\_\_\_\_  
Date

**DOCKET** 950495-WS  
**EXHIBIT NO.** 223  
**CASE NO.** 96-04227

**EXHIBIT NO.** 223

**WITNESS: TERRERO**

**DOCKET NO. 950495-WS**

**APPLICATION FOR RATE INCREASE BY  
SOUTHERN STATES UTILITIES, INC.**

**BEFORE THE  
FLORIDA PUBLIC SERVICE COMMISSION**

**DESCRIPTION:**

**RECENT WATER ANALYSES AT  
LEISURE LAKES**

FLORIDA PUBLIC SERVICE COMMISSION  
DOCKET  
NO. 950495 EXHIBIT NO 223  
COMPANY/  
WITNESS:  
DATE 4/29/96



SOUTHERN STATES UTILITIES, INC.  
RESPONSE TO REQUEST FOR PRODUCTION OF DOCUMENTS  
DOCKET NO.: 950495-WS

REQUESTED BY: FPSC  
SET NO: 11  
DOCUMENT REQUEST NO: 80  
ISSUE DATE: 03/18/96  
WITNESS: Rafael A. Terrero  
RESPONDENT: Rafael A. Terrero

DOCUMENT REQUEST: 80

Please provide the results, if any, of any testing done on Leisure Lakes' drinking water completed since the February 7, 1996 service hearing.

RESPONSE: 80

Attached as Appendix 80-A are copies of Leisure Lakes' test results.

04/10/1996 09:38 8136394

BURNSTORE

PAGE 02



State of Florida  
Department of Health and Rehabilitative Services  
Office of Laboratory Services  
Jacksonville, Miami, Pensacola  
Tampa, West Palm Beach

FOR LAB USE ONLY

Short Environmental Lab HRS #85344  
Received On: 2-13-96 @ 1410  
Received By: C. Williams  
Date/Time of Analysis: 2-13-96 @ 1715

DRINKING WATER  
BACTERIOLOGICAL ANALYSIS

SYSTEM NAME: Southern States Utilities SYSTEM I.D. NO: 5280064 SYSTEM PHONE #: 493-6118  
ADDRESS: 1000 Color Place, Apopka COUNTY: Highlands DER DISTRICT: 5  
COLLECTOR: Scott Faircloth COLLECTOR PHONE #: 471-1400  
SAMPLE SITE (Locality or Subdivision): Leisure Lakes/Covered Bridge, Lake Placid  
DATE AND TIME COLLECTED: 2-13-96 1:30 PM  
TYPE OF SUPPLY(Circle one): Community water system Noncommunity water system Nontransient - noncommunity water system  
Private well Swimming pool Bottled water Limited use system  
TYPE OF SAMPLE(Circle one): Compliance Repeat Replacement Main clearance Well survey Other  
(Check Box) (Check Box) (Specify)  
 Distribution  TNC or C  
 Raw  Turbid  
REMARKS:

TO BE COMPLETED BY COLLECTOR OF SAMPLE				TO BE COMPLETED BY LAB				
COLL. NO.	SAMPLE POINT (Specific Address)	CL RES'D	pH	ANALYSIS METHOD (Circle one): MF NTF MND-MND PA				
				NON COLIFORM	*TOTAL	CONFIRM TOTAL	CONFIRM FECAL E. COLI	SAMPLE NUMBER
1	10" Well - Raw	-	6.9		A			46580
2	4" Well - Raw	-	5.0		A			46581
3	Clubhouse	12	7.6		A			46582
4	101 Hillcrest	1.4	7.7		A			46583

Results in this column are preliminary. Fecal coliform confirmation on community and noncommunity water systems and total coliform confirmation on all types of water systems will follow in 24-48 hours.

P - Coliforms are present C - Confluent growth TA - Turbid, Absence of gas or acid  
A - Coliforms are absent TNC - Too numerous to count

INTERPRETATIONS-REMARKS BY PROGRAM REVIEWER

NAME AND MAILING ADDRESS OF PERSON/FIRM TO RECEIVE REPORT

Short Utility Service, Inc.  
P.O. Box 1088  
Sebring, FL 33871

- ( )
- ( ) SATISFACTORY
- ( ) INCOMPLETE COLLECTION INFORMATION
- ( ) COLLECT REPEAT SAMPLES
- ( ) COLLECT REPLACEMENT SAMPLES

REVIEWING OFFICIAL: \_\_\_\_\_

Form which may be used  
 Number: 5710 (Rev. 8/85)

04/10/1996 09:38 8136394

BURNSTORE

PAGE 03

04/03/1996 14:06 9414712102

SHORT UTILITY SVC

PAGE 03



State of Florida  
Department of Health and Rehabilitative Services  
Office of Laboratory Services  
Jacksonville, Miami, Pensacola  
Tampa, West Palm Beach

**DRINKING WATER  
BACTERIOLOGICAL ANALYSIS**

FOR LAB USE ONLY

Received On: 3-26-96

Received By: [Signature]

Time of Analy: 1700

SYSTEM NAME: Southern States Utilities SYSTEM I.D. NO: 5280064 SYSTEM PHONE #: 639-0331  
 ADDRESS: 1000 Color Place, Apopka COUNTY: Highlands DISTRICT: 5  
 COLLECTOR: Scott Faircloth COLLECTOR PHONE #: 471-1400  
 SAMPLE SITE (Locality or Subdivision): Leisure Lakes/Covered Bridge, Lake Placid  
 DATE AND TIME COLLECTED: 3-26-96 9:40 AM  
 TYPE OF SUPPLY(Circle one):  Community water system  Noncommunity water system  Nontransient - noncommunity water system  
Private well Swimming pool Bottled water Limited use system  
 TYPE OF SAMPLE(Circle one):  Compliance  Repeat  Replacement  Main clearance  Well survey  Other \_\_\_\_\_  
(Check Box) [ ] TNC or C [ ] Turbid [ ] [ ] (Specify)  
 REMARKS:

TO BE COMPLETED BY COLLECTOR OF SAMPLE				TO BE COMPLETED BY LAB				
COLL. NO.	SAMPLE POINT (Specific Address)	CL RES'D	PH	ANALYSIS METHOD (Circle one)			CONFIRM FECAL E. COLI	HND-MSB (PA) SAMPLE NUMBER
				MON COLIFORM	*TOTAL	CONFIRM TOTAL		
1	10" Well - Rav	-	6.8		A			47876
2	4" Well - Rav	-	4.9		A			47877
3	Clubhouse	2.0	7.8		A			47878
4	101 Hillcrest	1.8	7.8		A			47879

\* Results in this column are preliminary. Fecal coliform confirmation on community and noncommunity water systems and total coliform confirmation on all types of water systems will follow in 24-48 hours.

P - Coliforms are present C - Confluent growth TA - Turbid, absence of gas or acid  
 A - Coliforms are absent TNC - Too numerous to count

INTERPRETATIONS-REMARKS BY PROGRAM REVIEWER

NAME AND MAILING ADDRESS OF PERSON/FIRM TO RECEIVE REPORT

Short Utility Service, Inc.  
P.O. Box 1088  
Sebring, FL 33871

- ( )
- ( ) SATISFACTORY
- ( ) INCOMPLETE COLLECTION INFORMATION
- ( ) COLLECT REPEAT SAMPLES
- ( ) COLLECT REPLACEMENT SAMPLES

REVIEWING OFFICIAL: \_\_\_\_\_

TITLE: \_\_\_\_\_

This is a copy of the report of the  
 laboratory and is not to be used  
 for any other purpose. (See 40 CFR 131.10)

04/09/1996 15:33 8136394665

BURNSTORE

PAGE 02

March 25, 1996

Mr. Gary Maier  
Department of Environmental Protection  
2295 Victoria Avenue, Suite 364  
Fort Myers, Florida 33901-3881

Re: Highlands County - PW  
SSU / Leisure Lakes WTP  
PWS I.D. Number: 5280064

Dear Mr. Maier:

The finished water meter at Leisure Lakes has been replaced. The entire system was flushed to assure a chlorine residual at the ends of all lines. Attached are the results of the bacteriological samples taken after the installation of the finished water meter. If you have any questions, please call at 941-639-0331.

Sincerely,

*Wayne Vowell*

Wayne Vowell

C  
T  
TY  
REN  
EX  
NC  
ultra  
iforc  
P  
A  
NA

TITLE: \_\_\_\_\_

04/09/1996 15:33 8136394665

BURNSTORE

PAGE 03

State of Florida  
 Department of Health and Rehabilitative Services  
 Office of Laboratory Services  
 Jacksonville, Miami, Pensacola  
 Tampa, West Palm Beach

FOR LAB USE ONLY  
 Short Environmental Labs HRS #85344  
 Received On: 3-13-96 @ 1140  
 Received By: A. Watkins  
 Date/Time of Analysis: 3-13-96 @ 1825

**DRINKING WATER  
 BACTERIOLOGICAL ANALYSIS**

Press hard, (5) copies **(SSW)**

SYSTEM NAME: Covered Bridge SYSTEM I.D. NO.: 5280064 SYSTEM PHONE #: 493-6118  
 ADDRESS: 1000 COLOR PLACE, APOPKA COUNTY: HIGHLANDS DISTRICT: 5  
 COLLECTOR: SCOTT FAIRCLOTH COLLECTOR PHONE #: 941 471 1400  
 SAMPLE SITE (Locality or Subdivision): Covered Bridge  
 DATE AND TIME COLLECTED: 3-13-96 10:00 AM  
 TYPE OF SUPPLY (Circle one):  Community water system  Noncommunity water system  Nontransient - noncommunity water system  
 Private well  Swimming pool  Bottled water  Limited Use system  
 TYPE OF SAMPLE (Circle one): Compliance  Repeat  Replacement  ~~Other~~ Well survey  Other **CHANGED OUT METER AT WATER PLANT**  
 Distribution  Raw  Check here if payment made to county public health unit

TO BE COMPLETED BY COLLECTOR OF SAMPLE			
COLL. NO.	SAMPLE POINT (Specific Address)	CL RES'D	pH
1	108 Hillcrest	1.0	7.8

TO BE COMPLETED BY LAB					
ANALYSIS METHOD:		MF	MTF	MFC-MUG	PA
NON COLIFORM	TOTAL	CONFIRM TOTAL	CONFIRM FECAL E. COLI	SAMPLE NUMBER	
	A			47414	

Results in this column are presumptive. Total coliform and fecal coliform or E. coli confirmation will follow in 24-48 hours.

P - Coliforms are present      C - Confluent growth      TA - Turbid, Absence of gas or acid  
 A - Coliforms are absent      TNTC - Too numerous to count

ADDRESS (if different than address below): \_\_\_\_\_ INTERPRETATIONS-REMARKS BY PROGRAM REVIEWER \_\_\_\_\_

NAME AND MAILING ADDRESS OF PERSON/FIRM TO RECEIVE REPORT

SHORT UTILITY SERVICE INC  
 P O BOX 1088  
 SEBRING FL 33871

- ( )
- ( ) SATISFACTORY
- ( ) INCOMPLETE COLLECTION INFORMATION
- ( ) REPEAT SAMPLES
- ( ) REPLACEMENT SAMPLES

REVIEWING OFFICIAL: \_\_\_\_\_

TITLE: \_\_\_\_\_

SEBRING FL 33871

- ( ) INCOMPLETE COLLECTION INFORMATION
- ( ) COLLECT REPEAT SAMPLES
- ( ) COLLECT REPLACEMENT SAMPLES

04/09/1996 15:33 8136394665

BURNTSTORE

PAGE 04



State of Florida  
Department of Health and Rehabilitative Services  
Office of Laboratory Services  
Jacksonville, Miami, Pensacola  
Tampa, West Palm Beach

FOR LAB USE ONLY  
Short Environmental Labs HRS #85344  
Received On: 3-12-96 @ 12:40  
Received By: A. Watkins  
Time of Analysis: 3-12-96 @ 1:20

DRINKING WATER  
BACTERIOLOGICAL ANALYSIS

SYSTEM NAME: Covered Bridge (SSW) SYSTEM I.D. NO: 5280064 SYSTEM PHONE #: 493-6118  
ADDRESS: 1000 COLOR PLACE, APOPKA COUNTY: HIGHLANDS DER DISTRICT: 5  
COLLECTOR: Scott Faircloth COLLECTOR PHONE #: 941 47114  
SAMPLE SITE (Locality or Subdivision): Covered Bridge  
DATE AND TIME COLLECTED: 3-12-96 11:50 AM  
TYPE OF SUPPLY(Circle one):  Community water system  Noncommunity water system  Nontransient - noncommunity water system  
 Private well  Swimming pool  Bottled water  Limited use system  
TYPE OF SAMPLE(Circle one): Compliance (Check Box)  Repeat  Replacement (Check Box)  ~~Other~~ Well survey  CHANGED OUT  
 Distribution  TNTC or C  Turbid  Raw  HETER AT  
 Raw  Turbid  Raw  (Specify)  
WATER PLANT

REMARKS:

TO BE COMPLETED BY COLLECTOR OF SAMPLE				TO BE COMPLETED BY LAB					
COLL. NO.	SAMPLE POINT (Specific Address)	CI RES'D	pH	ANALYSIS METHOD (Circle one):					
				NON COLIFORM	*TOTAL	CONFIRM TOTAL	CONFIRM FECAL E. COLI	MPN-MUG PA	SAMPLE NUMBER
	<u>108 Hillcrest St.</u>	<u>1.0</u>	<u>7.6</u>		<u>A</u>				<u>4737A</u>

Results in this column are preliminary. Fecal coliform confirmation on community and noncommunity water systems and total coliform confirmation on all types of water systems will follow in 24-48 hours.

P - Coliforms are present C - Confluent growth TA - Turbid, Absence of gas or acid  
A - Coliforms are absent TNTC - Too numerous to count

INTERPRETATIONS-REMARKS BY PROGRAM REVIEWER

NAME AND MAILING ADDRESS OF PERSON/FIRM TO RECEIVE REPORT

SHORT UTILITY SERVICE INC  
P O BOX 1088  
SEBRING FL 33871

- ( )
- ( ) SATISFACTORY
- ( ) INCOMPLETE COLLECTION INFORMATION
- ( ) COLLECT REPEAT SAMPLES
- ( ) COLLECT REPLACEMENT SAMPLES

REVIEWING OFFICIAL:

... which may be used  
as Number 1748-000-0055-3

DOCKET 950495-WS  
EXHIBIT NO. 224  
CASE NO. 96-04227

EXHIBIT NO. 224

WITNESS: TERRERO

DOCKET NO. 950495-WS

APPLICATION FOR RATE INCREASE BY  
SOUTHERN STATES UTILITIES, INC.

BEFORE THE  
FLORIDA PUBLIC SERVICE COMMISSION

DESCRIPTION:

LATE FILED DEPOSITION EXHIBIT NO. 6  
FROM MR. TERRERO'S JANUARY 1996  
DEPOSITION PERTAINING TO  
MARCO ISLAND/MARCO SHORES  
EFFLUENT DISPOSAL

FLORIDA PUBLIC SERVICE COMMISSION  
DOCKET  
NO. 950495 EXHIBIT NO. 224  
COMPANY/  
WITNESS: \_\_\_\_\_  
DATE: 4/29/96

Rafael A. Terrero

Deposition Late File Exhibits 4, 5 and 6

Gallons of effluent by month into the injection well under column titled, "Deep Well Inj. WWTP (MG)"

Gallons of concentrate (brine) by month into injection well under column titled, "Deep Well Inj. Brine (MG)"

Gallons of effluent per month to golf courses under columns titled, "Marco Shores Golf Course (MG)", "Marco Island Golf Course (MG)"

Effluent to percolation ponds from Marco Shores under column titled, "Marco Shores Perc Ponds, (MG)"



MARCO ISLAND  
EFFLUENT DISPOSAL

DATE	DEEP WELL INJ. BRINE (MG )	DEEP WELL INJ. WWTP EFFL. (MG )	TOTAL INJ. (MG )	MARCO ISLAND PERC PONDS (MG. )	MARCO SHORES GOLF COURSE (MG. )	MARCO ISLAND GOLF COURSE (MG. )	GOLF COURSES TOTAL (MG. )	MARCO SHORES PERC PONDS (MG )
DEC 95								
TOTAL	29.224	38.692	67.916		6.073	4.592	10.665	1.110
NOV 95								
TOTAL	26.753	32.337	58.919		11.407	7.679	18.862	1.192
OCT 95								
TOTAL	19.816	58.949	78.765		3.305	0.003	3.308	1.115
SEP 95								
TOTAL	16.383	49.566	65.949		1.886	0.012	1.898	0.708
AUG 95								
TOTAL	6.008	43.423	49.431		7.157	4.336	11.493	0.930
JUL 95								
TOTAL	20.162	56.314	76.476		2.756	0.000	2.756	0.921
JUN 95								
TOTAL	26.102	53.947	79.636		2.661	0.872	3.533	0.943
MAY 95								
TOTAL	36.929	28.440	65.369		6.490	7.014	13.504	1.111
APR 95								
TOTAL	36.464	49.616	86.080		5.923	2.970	8.893	1.697
MAR 95								
TOTAL	35.775	47.083	82.858		9.147	11.697	20.844	2.385
FEB 95								
TOTAL	28.887	53.674	82.561		3.363	5.553	8.916	2.293
JAN 95								
TOTAL	34.908	58.721	93.629		2.383	3.485	5.868	2.029

MARCO ISLAND  
EFFLUENT DISPOSAL

DATE	DEEP WELL INJ. BRINE (MG )	DEEP WELL INJ. WWTP EFFL. (MG )	TOTAL INJ. (MG. )	MARCO ISLAND PERC PONDS (MG )	MARCO SHORES GOLF COURSE (MG. )	MARCO ISLAND GOLF COURSE (MG )	GOLF COURSES TOTAL (MG )	MARCO SHORES PERC PONDS (MG )
DEC 94								
TOTAL	48.685	42.665	91.350		3.882	3.845	7.727	1.549
NOV 94								
TOTAL	33.323	37.785	71.108		4.092	5.086	9.178	1.543
OCT 94								
TOTAL	32.451	34.279	66.730		4.328	4.075	8.403	1.256
SEP 94								
TOTAL	19.406	37.192	56.598		1.134	2.444	3.578	1.032
AUG 94								
TOTAL	22.945	45.368	68.313		2.175	1.704	3.879	1.269
JUL 94								
TOTAL	35.843	49.287	85.130		0.979	2.886	3.865	1.338
JUN 94								
TOTAL	48.875	26.218	75.093		6.880	5.890	12.770	1.181
MAY 94								
TOTAL	64.677	16.606	81.283		7.516	12.084	19.600	1.148
APR 94								
TOTAL	64.478	39.663	104.141		5.662	9.792	15.454	1.546
MAR 94								
TOTAL	61.288	52.267	113.555		9.063	8.381	17.444	1.923
FEB 94								
TOTAL	40.786	48.809	89.595		5.024	6.790	11.814	1.755
JAN 94								
TOTAL	46.832	40.965	87.797		4.408	4.752	9.160	1.623

MARCO ISLAND  
EFFLUENT DISPOSAL

DATE	DEEP WELL INJ. BRINE (MG )	DEEP WELL INJ. WWTP EFFL. (MG )	TOTAL INJ. (MG )	MARCO ISLAND PERC PONDS (MG )	MARCO SHORES GOLF COURSE (MG )	MARCO ISLAND GOLF COURSE (MG )	GOLF COURSES TOTAL (MG )	MARCO SHORES PERC PONDS (MG )
DEC 93								
TOTAL	50.395	29.499	79.894		6.515	8.167	14.682	1.148
NOV 93								
TOTAL	35.438	41.660	77.098		0.491	3.519	4.010	1.038
OCT 93								
TOTAL	28.301	41.262	69.563		0.784	5.038	5.822	0.968
SEP 93								
TOTAL	19.676	42.536	62.212		0.000	0.000	0.000	0.842
AUG 93								
TOTAL	19.025	32.297	51.322	7.989	6.006	3.488	9.494	0.908
JUL 93								
TOTAL	31.393	32.145	63.538		3.273	9.443	12.716	0.958
JUN 93								
TOTAL	28.421	18.933	47.354		5.525	0.013	5.538	0.935
MAY 93								
TOTAL	35.095	7.140	42.235	24.861	9.850	3.410	13.260	0.933
APR 93								
TOTAL	33.074	32.959	66.033	10.640	9.392	9.313	18.705	1.301
MAR 93								
TOTAL	36.696	57.615	94.311	3.358	6.326	7.011	13.337	1.879
FEB 93								
TOTAL	40.988	55.570	96.558		5.085	4.644	9.729	1.882
JAN 93								
TOTAL	27.873	49.600	77.473	13.370	1.903	3.402	5.305	1.547

MARCO ISLAND  
EFFLUENT DISPOSAL

DATE	DEEP WELL INJ. BRINE (MG )	DEEP WELL INJ. WWTP EFFL. (MG )	TOTAL INJ. (MG. )	MARCO ISLAND PERC PONDS (MG )	MARCO SHORES GOLF COURSE (MG )	MARCO ISLAND GOLF COURSE (MG )	GOLF COURSES TOTAL (MG. )	MARCO SHORES PERC PONDS (MG )
DEC 92								
TOTAL					23.259	7.616	30.875	1.056

**DOCKET** 950495-WS  
**EXHIBIT NO.** 225  
**CASE NO.** 96-04227

**EXHIBIT NO.** 225

**WITNESS: UNDETERMINED**

**DOCKET NO. 950495-WS**

**APPLICATION FOR RATE INCREASE BY  
SOUTHERN STATES UTILITIES, INC.**

**BEFORE THE  
FLORIDA PUBLIC SERVICE COMMISSION**

**DESCRIPTION:**

**SSU RESPONSE TO FPSC INTERROGATORY No. 305  
REGARDING THE MARCO ISLAND PERC PONDS  
AND ALLOCATIONS TO MARCO SHORES**

FLORIDA PUBLIC SERVICE COMMISSION  
DOCKET  
NO. 950495 EXHIBIT NO 225  
COMPANY/  
WITNESS:  
DATE 4/29/96

SOUTHERN STATES UTILITIES, INC.  
DOCKET NO.: 950-95-WS  
RESPONSE TO INTERROGATORIES

REQUESTED BY: FPSC  
SET NO: 6  
INTERROGATORY NO: 305  
ISSUE DATE: 12/12/95  
WITNESS: Undetermined  
RESPONDENT: J. Dennis Westrick

INTERROGATORY NO: 305

Please refer to the Utility's capital addition project number 91CS015, which pertains to the off-site percolation ponds for Marco Island. Is/was any of the capital addition allocated to Marco Shores? If not, why not?

RESPONSE: 305

The entire addition for work order 91CS015 was recorded as Marco Island plant in service. It is the company's policy to record assets where they are physically residing, to assist in implementation of a fixed asset inventory as well as to properly record tangible personal property for property tax assessment purposes.

**DOCKET** 950495-WS  
**EXHIBIT NO.** 226  
**CASE NO.** 96-04227

**EXHIBIT NO.** 226

**WITNESS: TERRERO**

**DOCKET NO. 950495-WS**

**APPLICATION FOR RATE INCREASE BY  
SOUTHERN STATES UTILITIES, INC.**

**BEFORE THE  
FLORIDA PUBLIC SERVICE COMMISSION**

**DESCRIPTION:**


**EPA HANDBOOK (EPA/625/6-91/030)**

FLORIDA PUBLIC SERVICE COMMISSION  
DOCKET  
NO. 950495 EXHIBIT NO 226  
COMPANY/  
WITNESS:  
DATE: 4/29/96



# Handbook

## Sewer System Infrastructure Analysis and Rehabilitation





other cases it might be channelled by sewer trenches to potential points of direct human exposure. Data based on a study conducted by the U.S. EPA indicates the following conclusions and findings regarding the impact of RII:<sup>3</sup>

- RII is a type of infiltration since it enters the sewer system through defects. However, its flow characteristics resemble those of inflow i.e., there is a rapid increase in flow which mirrors the rainfall event followed by a decrease as the rain stops.
- Because of its flow characteristics, RII has occasionally been misidentified as inflow in many cases. Consequently, rehabilitation programs aimed at inflow sources have not achieved the anticipated reduction in extraneous flows in these cases.
- RII appears to represent a significant portion of the flow to some wastewater treatment plants during wet weather periods. In the 10 case studies conducted by U.S. EPA, the peak wet weather flows were 3.5-20 times the dry weather flow. The contribution from RII was estimated to be between 60-90 percent of the wet weather flows, the remainder being groundwater infiltration and inflow.
- Collection and treatment systems often do not have the capacity to handle peak wet weather flows. Peak flows, therefore, can cause wastewater backups into buildings, overflows and treatment system bypasses. Such occurrences are a hazard to public health and a violation of the municipality's discharge permit.
- Sewer trenches can act as collectors of rainfall percolating into the soil. The trenches channel the water, thus providing multiple opportunities for the water to seep into the collection system at defective points.
- The shallow portions of a collection system, e.g. building laterals, manhole defects, etc. are more vulnerable to RII. Interceptors sewers, which are typically deeper, do not appear to be a significant entry point for RII, but are more likely sources of groundwater infiltration, which normally minimizes peak to average flow ratios.
- The extent of RII problems in sanitary sewer systems is related to the age and condition of the sewers, material of construction, pipe, lateral and manhole defects, climate, geology, groundwater levels, and depth of sewers.

Figure 3-6 presents the typical entry points of RII.

#### 3.5.7.4 Method of Analysis

The following techniques can be used to estimate the total infiltration in a sewer system:

##### a. Water Use Evaluation

This method uses the water supply records for the purpose of estimating the amount of domestic wastewater discharged to the sanitary sewer system. Monthly water

use records are obtained. As an estimate, the percentage of the water that would reach the sanitary sewer would range from 70 percent in summer to 90 percent in winter. Given these facts, the rates at which domestic, industrial and commercial wastewater should flow into the sanitary sewers can be determined. These calculated flow rates can be subtracted from the total flow measured at the wastewater treatment plant to obtain an estimate of the infiltration entering the sewer system. Factors that should be considered when using this method for infiltration analysis are:

- Confirmation of the consumptive use mentioned above
- The amount of unaccounted water supplied through the system through wells, springs, or reservoirs that would not be accurately measured due to faulty or inaccurate meters or lack of metering. Unaccounted for water also includes illegal taps and unmetered withdrawals from fire fighting lines, street flushing fire lines, or hydrants.
- For areas supplied with a secondary water system, the water balance must include this source.

##### b. BOD Evaluation

The mass BOD loading from domestic and industrial sources are used in this method. The method assumes that the average BOD of domestic waste without infiltration is 200 mg/L. Monthly treatment plant flow records are used to determine total flow and average actual BOD daily loading. The industrial flow and BOD loading must also be estimated in order to use this method.

First, the total BOD load to the treatment plant is calculated in mass/d from the plant influent flow and actual influent BOD. Next the industrial flow and BOD load is estimated and subtracted from the total plant load. The normal domestic flow is calculated by knowing the domestic BOD load and using an influent BOD concentration of 200 mg/L. The infiltration is then calculated by subtracting the calculated domestic flow plus the estimated industrial flow from the actual plant flow. The procedure can be completed on a daily, monthly or annual basis. The accuracy of the procedure depends on the accuracy of estimating industrial flow and BOD load. It should be applied to the total system rather than to sub-systems because of limitations due to unequal distribution of domestic and industrial flows in smaller sub-systems.

##### c. Maximum-Minimum Daily Flow Comparison

This method assumes that infiltration will be constant throughout the day if there is no precipitation. Industrial flows are also assumed to be constant throughout the day, so the daily flow variations measured are strictly attributed to the domestic flow contribution. Treatment plant influent data can be evaluated to obtain the domestic

DOCKET 950495-WS Ex. No. 227  
EXHIBIT NO. 227  
CASE NO. 96-04227



Southern States Utilities • 255 Enterprise Rd. • Deltona, FL 32725 • 407/571-6830 • DELTONA OFFICE

January 23, 1996

Mr. Mark A. Halverstadt  
Environmental Specialist II  
Environmental Health Engineering  
Volusia County Public Health Unit  
Post Office Box 9190  
Daytona Beach, FL 32120-9190

RE: SANITARY SURVEY DATED 12/07/95

Dear Mr. Halverstadt:

This letter is in reference to the sanitary survey dated 12/07/95 to Mr. Daniel DeBaca, Chief Operator, and William M. Schrader, Lead Operator. The survey was in reference to the Deltona system permitted under ID #3640237.

The following is to address each deficiency in the order of your survey:

1. Maintenance problem (housekeeping) and cross-connections were corrected. Routine plant maintenance and inspection program. Please note a copy of standard operating protocol which addresses these issues. Four out of five tanks scheduled for painting were completed in 1995. The two million tank at Sagamore (Plant #12) will be done in 1996. The unused equipment is now being addressed through our Engineering Department. This should be completed in 1996. We are reviewing our fuel containment structures, and we believe two will have to be sealed again. These two are Plants #6 and #14. This work will be completed by 2/16/96.
2. The auxiliary generators were reviewed, and we found that some were exercising, but the timer was not recording. This item has been corrected and will be monitored in the future.

FLORIDA PUBLIC SERVICE COMMISSION  
DOCKET  
NO. 950495 EXHIBIT NO 227  
COMPANY/  
WITNESS:  
DATE: 1/23/96




Mr. Mark A. Halverstadt  
RE: SANITARY SURVEY DATED 12/07/95  
January 23, 1996  
Page 2 of 2 Pages

3. Please note the attached Engineering report concerning this request of the Deltona Lakes Water Supply System Auxilliary Power Plan.
4. There has been work done on a valve maintenance program of which I am attaching a sample sheet. I do agree that maybe a more formal plan should be drafted and submitted to your department for review. I will be processing a plan that will be added to our Standard Operating Protocol.
5. The fire hydrants in Deltona are not the responsibility of Southern States. The Deltona Fire District is totally responsible for their installation operations and maintenance.
6. Please note a plan was approved and submitted to DEP in August, 1992. I am attaching a copy for your records.
7. We have reviewed your concerns, and they are now monitoring 6 sites daily for remote chlorine residuals. We will also make this a part of our Standard Operating Protocol for both chlorine residuals and flushing program.
8. We have finished tying in Wells #3 and #25 blending water leaving this site. We believe this will correct the 1.0 mg per liter for phosphate rec. Testing.

Please advise if there are any further questions you wish us to consider.

We again want to thank your Department for a positive approach to areas of both our concerns.

Thank you,

  
Douglas Lovell  
Area Supervisor II

DL:kj

# Environmental Health

VOLUSIA COUNTY PUBLIC HEALTH UNIT  
ENVIRONMENTAL HEALTH

904/947-3435

FAX TELEPHONE NUMBER 904/947-3485

The following material consists of 5 pages including cover page.

DELIVER TO: Doug Lovell

PHONE NUMBER: (407) 574-1680

FAX NUMBER: (407)

SPECIAL INSTRUCTIONS: Here is a preliminary look at my survey letter. A few things in it will probably change

FROM: Mark A. Halverson

This fax transmission may contain material which is confidential under Florida Statutes and is intended to be delivered to only the named addressee. Unauthorized dissemination of this information may be a violation of criminal statutes. If this information is received by anyone other than the named addressee, the recipient should immediately notify us at the address or telephone number shown above and obtain instructions as to the disposal thereof. Under no circumstances should this material be read, retained or copied by anyone other than the named addressee.



STATE OF FLORIDA  
 DEPARTMENT OF HEALTH AND REHABILITATIVE SERVICES

CERTIFIED Z 309 921 259

October 5, 1995

Southern States Utilities/Deltona  
 Attn.: Mr. Daniel DeBaca, Chief Operator and  
 Mr. William M. Schrader, Lead Operator  
 255 Enterprise Road  
 Deltona, FL 32725

Southern States Utilities/Deltona  
 PWS ID NUMBER: 3640287  
 Volusia County CWS

Dear Mr.'s DeBaca and Schrader,

This letter confirms my visit to the Deltona community public water system on December 29-30, 1994 in the presence of Dan DeBaca-Chief Operator, Bill Schrader-Lead Operator, and Ray Van Loon of HRS for the purpose of conducting a sanitary survey. The completed sanitary survey is enclosed for your reference and records.

Deficiencies were noted during the survey and were also determined from records on file in this office. On page six of the enclosed sanitary survey, deficiencies are listed with reference to the pertinent section of the Florida Administrative Code.

The following is a description of each noted deficiency:

1. There is no working chlorine gas alarm to indicate loss of gas pressure or chlorine residual at the following locations: Plant #3, Plant 5-wells #6 and #7, Plant #9, and Plant #12. *OK* *OK* *OK* *OK*  
*Alarm installed*
- COMPLETE* 2. There are hole(s) in the wall(s) of the chlorine rooms potentially venting chlorine gas to the pump rooms in the following locations: Plant #1-well #1, Plant #4-well #4, Plant #5-well #6, and Plant #10-well #20, and Plant #11-well #21.
- COMPLETE* 3. The required vents for floor level chlorine room ventilation are missing at the following locations: Plant #28-well #15, Plant #9-well #19, Plant #10-well #20, and Plant #15-well #29.
- COMPLETE* 4. Warning signs with emergency phone numbers are required at each chlorine storage site, and are missing or badly faded at the following locations: Plant #1-well #3, Plant #3-well #25, Plant #5-well #6, Plant #16-well #33, and Plant #28-well #15.
- COMPLETE* 5. There were two unsecured gas chlorine cylinders at Plant #3-well #25, a potential safety/fire hazard.

5. There is no record of a fire hydrant maintenance program in our files. Please provide the Department with one and give data on how many full-time equivalent people are or have been assigned to it. This may be combined with the valve maintenance program.
6. There is no written backflow preventer testing program in our records. Please provide one and include data on: how many full-time equivalent people are assigned to it, who is responsible, how records are maintained, and an inventory by number and type.
7. There were areas of the distribution system found to be less than 0.2 mg/l free available chlorine. A series of complaints in the records also indicates that this is a recurring problem. Develop a specific verifiable written program of flushing and residual maintenance to ensure compliance with the rules, and forward a copy to this Department.
8. There is an iron level of 1.2 mg/l in well #25, which is in excess of the 1.0 mg/l level acceptably treatable by phosphate sequestration. Please inform this Department as to the approximate time table for completion of the permitted modifications designed to correct this problem.

Furthermore, please inform the Department of any updates to the cross connections control program, and who is assigned the responsibility of ensuring that it is carried out.

You are required to correct the above deficiencies for the subject system and to provide a written statement to this Department no later than February 07, 1996 certifying that all listed deficiencies have been corrected, or listing specific reasonable dates for completion. If any items need further explanation, please contact this Department immediately.

Please provide the information, where available, for items marked unknown "ur.c") on the sanitary survey report. When such unknown information is not readily available, please note this as "NA".

The following reference materials: Chapters 62-550, 62-551, 62-555, 62-560 and 62-699 of the Florida Administrative Codes, (FAC), are available for a fee upon telephone request to Mrs. Kristine Sheets at (904) 947-3436.

If you have any questions concerning this letter, please feel free to contact this office at (904) 947-3421.

Sincerely,



Mark A. Halverstadt  
Environmental Specialist II  
Environmental Health Engineering

MAH/mah  
Enclosures

cc: L. Fsrcloth  
R. Van Loon  
PWS File (last-81.doc)



STATE OF FLORIDA  
DEPARTMENT OF HEALTH AND REHABILITATIVE SERVICES

CERTIFIED Z 309 921 259

October 5, 1995

Southern States Utilities/Deltona  
Attn.: Mr. Daniel DeBaca, Chief Operator and  
Mr. William M. Schrader, Lead Operator  
255 Enterprise Road  
Deltona, Fl 32725

Southern States Utilities/Deltona  
*PWS ID NUMBER: 3640287*  
*Volusia County CWS*

Dear Mr.'s DeBaca and Schrader,

This letter confirms my visit to the Deltona community public water system on December 29-30, 1994 in the presence of Dan DeBaca-Chief Operator, Bill Schrader-Lead Operator, and Ray Van Loon of HRS for the purpose of conducting a sanitary survey. The completed sanitary survey is enclosed for your reference and records.

Deficiencies were noted during the survey and were also determined from records on file in this office. On page six of the enclosed sanitary survey, deficiencies are listed with reference to the pertinent section of the Florida Administrative Code.

The following is a description of each noted deficiency:

1. There is no working chlorine gas alarm to indicate loss of gas pressure or chlorine residual at the following locations: Plant #3, Plant 5-wells #6 and #27, Plant #8, and Plant #12.
2. There are hole(s) in the wall(s) of the chlorine rooms potentially venting chlorine gas to the pump rooms in the following locations: Plant #1-well #1, Plant #4-well #4, Plant #5-well #6, and Plant #10-well #20, and Plant #11-well #21.
3. The required vents for floor level chlorine room ventilation are missing at the following locations: Plant #28-well #15, Plant #9-well #19, Plant #10-well #20, and Plant #15-well #29.
4. Warning signs with emergency phone numbers are required at each chlorine storage site, and are missing or badly faded at the following locations: Plant #2-well #3, Plant #3-well #25, Plant #5-well #6, Plant #16-well #33, and Plant #28-well #15.
5. There were two unsecured gas chlorine cylinders at Plant #3-well #25, a potential safety/fire hazard.

VOLUSIA COUNTY PUBLIC HEALTH UNIT  
P.O. BOX 9190 • 501 S. CLYDE MORRIS BLVD.  
DAYTONA BEACH, FL 32120-9190

LAWTON CHILES, GOVERNOR

There was not adequate lighting in the chlorine rooms at the following locations: Plant #4-well #4, Plant #10-well #20, Plant #11-well #21, and Plant #14-well #24 because of burned out light bulbs. The light switch at Plant #9-well #19 was broken and should be replaced.

6. There are openings to the following wells that pose potential contamination hazards:
  - Air/vacuum release valve drain openings need screening at wells nos.: 1, 16; 20, 21, 24, and 32 (each of the last three also should be turned down), and nos. 28 and 34.
  - Cover the vents at wells #24 and #25.
  - Cap the blow-off valve on well #1.
  - The air line level check openings need the proper plug seals at wells nos. 16, 22, 28, and 32.
  
7. The following facility repairs and maintenance are required:
  - Repair the door vent to well room for Plant #15-well #28.
  - Secure/repair or improve the fencing at Plants nos.: 6, 7, 14, and 15, to limit access and keep out potential vandals.
  - Outside Plant #7, remove the heavily-rusted southside liquid petroleum gas tank that is no longer in use.
  - Repair or replace the hinges in the master meter pit at Plant #7.
  - Repair, cover, or remove the exposed electrical wires in the master meter pit at the following locations: Plant #7, the uncovered electrical box near well #12 inside Plant #7, the exposed wires in Plant #16 near well #33 that were used for a chart recorder, the open conduit connector cover at Plant #9-well #19 for the remote reading meter, the exposed wires for the chlorine booster pump at Plant #7-well #12 and the exposed wires at Plant #1-well #2, Plant #12-wells #22 and #32.
  - Window repairs are required at Plant #6-well #27, and Plant #8-wells #15 and #17.
  - Diesel containment structures were flooded leading to extreme corrosion and loss of containment volume at Plant #3-well #28, Plant #11-well #21, Plant #12-well #22, high service pump buildings at Plant #8 and Plant #12, Plant #13-well #23, and Plant #15-well #28.
  
8. Plant #7 is in need of interior cleaning to improve safety.
  
9. Tank, piping and equipment repairs are required at the following locations:
  - At Plant #7 the ground storage tank air vent had missing screening, resulting in numerous small insects floating in the tank. Please furnish a ground storage tank cleaning schedule. The Department recommends that the air vents on the ground storage tanks be checked periodically for screening.
  - The larger high service pump in Plant #12 has a leaking knife valve.
  - The sanitary seal of Plant #1-well #2 is damaged and should be replaced or repaired.
  - Plant #7-well #14 has a leaking air and vacuum release valve, and a meter that is difficult to read.



- There is a leaking line to the chlorine booster pump at Plant #3-well #25 and extreme corrosion on the small pipe before the check valve.
  - Safety cages around connected linkages of manual auxiliary generators were not installed at all locations. This could be a serious safety problem under operating conditions.
  - There is a muffler from an auxiliary generator venting its exhaust directly into a chlorination outdoor facility area; a potential safety/fire problem at Plant #7.
10. The auxiliary generators are not being run a minimum of four continuous hours per month under load.
  11. There is no written auxiliary power plan in our records. Please provide this Department with one, and an assessment of the adequacy of current emergency power equipment by a professional engineer.
  12. There are cross connections which need immediate correction:
    - Air/vacuum release valve and bearing packing combined drain piping for the vertical turbines for wells #33 and #35. An air gap of two pipe diameters is required between the pipe outlet and the ground.
    - Threaded raw sampling taps and/or hose bibbs without vacuum breakers at wells nos. 2, 6, 16, 19, 21, 22, 24, 28, Plant #8 high service pump #2, and at the eyewash station at the chlorine facility for Plant #12.
    - Remove the fire hose connected to Plant 12.
  13. There is no written valve maintenance program. Please provide this Department with one, and give data on who will be responsible and how many full-time people are assigned to carry it out.
  14. There is no record of a fire hydrant maintenance program in our files. Please provide the Department with one and give data on how many full-time equivalent people are or have been assigned to it. This may be combined with the valve maintenance program.
  15. There is no written backflow preventer testing program in our records. Please provide one and include data on: how many full-time equivalent people are assigned to it, who is responsible, how records are maintained, and an inventory by number and type.
  16. There were areas of the distribution system found to be less than 0.2 mg/l free available chlorine. A series of complaints in the records also indicates that this is a recurring problem. Develop a specific verifiable written program of flushing and residual maintenance to ensure compliance with the rules and forward a copy to this Department.
  17. There is an iron level of 1.2 mg/l in well #25, which is in excess of the 1.0 mg/l level acceptably treatable by phosphate sequestration. Please inform this Department as to the approximate time table for completion of the permitted modifications designed to correct this problem.

Page 4  
SS94-81

Furthermore, please inform the Department of any updates to the cross connection control program, and who is assigned the responsibility of ensuring that it is carried out.

**You are required to correct the above deficiencies for the subject system and to provide a written statement to this Department no later than December 5, 1995 certifying that all listed deficiencies have been corrected, or listing specific reasonable dates for completion. If any items need further explanation, please contact this Department immediately.**

Please provide the information, where available, for items marked unknown ("unk") on the sanitary survey report. When such unknown information is not readily available, please note this as "NA".

The following reference materials: Chapters 62-550, 62-551, 62-555, 62-560, and 62-699 of the Florida Administrative Codes, (FAC), are available for a fee upon telephone request to Mrs. Kristine Sheets at (904) 947-3436.

If you have any questions concerning this letter, please feel free to contact this writer at (904) 947-3421.

Sincerely,

Mark A. Halverstadt  
Environmental Specialist II  
Environmental Health Engineering

MAH/mah  
Enclosures

cc: L. Faircloth  
R. Van Loon  
PWS File (ss94-81.doc)

7



STATE OF FLORIDA  
DEPARTMENT OF HEALTH AND REHABILITATIVE SERVICES

CERTIFIED Z 309 921 259

December 7, 1995

Southern States Utilities/Deltona  
Attn. Mr. Daniel DeBaca, Chief Operator and  
Mr. William M. Schrader, Lead Operator  
255 Enterprise Road  
Deltona, FL 32725

Southern States Utilities/Deltona  
PWS ID NUMBER: 3640287  
Volusia County CWS

Dear Mr.'s DeBaca and Schrader,

This letter confirms my visit to the Deltona community public water system on December 29-30, 1994 in the presence of Dan DeBaca-Chief Operator, Bill Schrader-Lead Operator, and Ray Van Loon of HRS for the purpose of conducting a sanitary survey. The completed sanitary survey is enclosed for your reference and records.

Deficiencies were noted during the survey and were also determined from records on file in this office. On page six of the enclosed sanitary survey, deficiencies are listed with reference to the pertinent section of the Florida Administrative Code.

The following is a description of each noted deficiency:

1. Various maintenance problems and cross-connections were noted in an earlier preliminary copy of this report transmitted to you. They were corrected, according to our phone conversation. A routine plant maintenance and inspection program, including written plant and tanks cleaning and painting schedules is needed. Please inform this Department as to whether the tanks needing painting were actually painted, or when they will be scheduled for painting. Remove unused equipment instead of abandoning it in place. The fuel spill containment basins under the Diesel tanks must be leak tested, since some of them obviously could not hold water from the large amount of rain the area had received in months prior to the inspection.
2. The auxiliary generators are not being run a minimum of four continuous hours per month under load.
3. There is no written auxiliary power plan in our records. Please provide this Department with one, and an assessment of the adequacy of current emergency power equipment by a professional engineer.
4. There is no written valve maintenance program. Please provide this Department with one, and give data on who will be responsible and how many full-time people are assigned to carry it out.

VOLUSIA COUNTY PUBLIC HEALTH UNIT  
P.O. BOX 9190 • 501 S. CLYDE MORRIS BLVD.  
DAYTONA BEACH, FL. 32120-9190

8

Comp.

There was not adequate lighting in the chlorine rooms at the following locations: Plant #4-well #4, Plant #10-well #20, Plant #11-well #21, and Plant #4-well #24 because of burned out light bulbs. The light switch at Plant #9-well #9 was broken and should be replaced.

Complete

6. There are openings to the following wells that pose potential contamination hazards:
- Air/vacuum release valve drain openings need screening at wells nos. 1, 16, 20, 21, 24, and 32 (each of the last three also should be turned down), and nos. 28 and 34.
  - Cover the vents at wells #24 and #25.
  - Cap the blow-off valve on well #1.
- Comp. (C) The air line level check openings need the proper plug seals at wells nos. 16, 22, 28, and 32.

7. The following facility repairs and maintenance are required:

- OK • Repair the door vent to well room for Plant #15-well #28.
- OK • Secure/repair or improve the fencing at Plants nos. 6, 7, 14, and 15, to limit access and keep out potential vandals.
- OK • Outside Plant #7, remove the heavily-rusted southside liquid petroleum gas tank that is no longer in use.
- OK • Repair or replace the hinges in the master meter pit at Plant #7.
- UNN • Repair, cover, or remove the exposed electrical wires in the master meter pit at the following locations: Plant #7, the uncovered electrical box near well #12 inside Plant #7, the exposed wires in Plant #16 near well #33 that were used for a chart recorder, the open conduit connector cover at Plant #9-well #19 for the remote reading meter, the exposed wires for the chlorine booster pump at Plant #7-well #12 and the exposed wires at Plant #1-well #6, Plant #12-wells #22 and #32.
- OK • Window repairs are required at Plant #6-well #27, and Plant #8-wells #15 and #17.
- OK • Diesel containment structures were flooded leading to extreme corrosion and loss of containment volume at Plant #3-well #28, Plant #11-well #21, Plant #12-well #22, high service pump buildings at Plant #8 and Plant #12, Plant #13-well #23, and Plant #15-well #28.

- OK 8. Plant #7 is in need of interior cleaning to improve safety.

9. Tank, piping and equipment repairs are required at the following locations:

- OK • At Plant #7 the ground storage tank air vent had missing screening, resulting in numerous small insects floating in the tank. Please furnish a ground storage tank cleaning schedule. The Department recommends that the air vents on the ground storage tanks be checked periodically for screening.

work on (C)

- OK • The larger high service pump in Plant #12 has a leaking life valve.
- (C) The sanitary seal of Plant #1-well #2 is damaged and should be replaced or repaired.

OK work on (C)

- (C) Plant #7-well #14 has a leaking air and vacuum release valve, and a meter that is difficult to read.

OK (C) There is a leaking line to the chlorine booster pump at Plant # 7 - well #25 and extreme corrosion on the small pipe before the check valve.  
NOT USED (C) Safety cages around connected linkages of manual auxiliary generators were not installed at all locations. This could be a serious safety problem under operating conditions.

NEW BRG (C) There is a muffler from an auxiliary generator venting its exhaust directly into a chlorination outdoor facility area; a potential safety/fire problem at Plant #7.  
9/2/01

OK - 10. The auxiliary generators are not being run a minimum of four continuous hours per month under load.

BLUCE 11. There is no written auxiliary power plan in our records. Please provide this Department with one, and an assessment of the adequacy of current emergency power equipment by a professional engineer.

12. There are cross connections which need immediate correction:

OK (C) Air/vacuum release valve and bearing packing combined drain piping for the vertical turbines for wells #33 and #35. An air gap of two pipe diameters is required between the pipe outlet and the ground.

OK (C) Threaded raw sampling taps and/or hose bibbs without vacuum breakers at wells nos. 2, 6, 16, 19, 21, 22, 24, 28, Plant #8 high service pump #2 and at the eyewash station at the chlorine facility for Plant #12.

OK (C) Remove the fire hose connected to Plant 12.

? 13. There is no written valve maintenance program. Please provide this Department with one, and give data on who will be responsible and how many full-time people are assigned to carry it out.

FIRE DEPT 14. There is no record of a fire hydrant maintenance program in our files. Please provide the Department with one and give data on how many full-time equivalent people are or have been assigned to it. This may be combined with the valve maintenance program.

? 15. There is no written backflow preventer testing program in our records. Please provide one and include data on: how many full-time equivalent people are assigned to it, who is responsible, how records are maintained, and an inventory by number and type.

PLANT #23 16. There were areas of the distribution system found to be less than 0.2 mg/l free available chlorine. A series of complaints in the records also indicates that this is a recurring problem. Develop a specific verifiable written program of flushing and residual maintenance to ensure compliance with the rules and forward a copy to this Department.  
I HAVE ESTABLISHED + CHECK DAILY

COMPLETE 17. There is an iron level of 1.2 mg/l in well #25, which is in excess of the 1.0 mg/l level acceptably treatable by phosphate sequestration. Please inform this Department as to the approximate time table for completion of the permitted modifications designed to correct this problem.

Page 4  
SS94-81

Furthermore, please inform the Department of any updates to the cross section control program, and who is assigned the responsibility of ensuring that it is carried out.

**You are required to correct the above deficiencies for the subject system and to provide a written statement to this Department no later than December 5, 1995 certifying that all listed deficiencies have been corrected, or listing specific reasonable dates for completion. If any items need further explanation, please contact this Department immediately.**

Please provide the information, where available, for items marked unknown ("unk") on the sanitary survey report. When such unknown information is not readily available, please note this as "NA".

The following reference materials: Chapters 62-550, 62-551, 62-553, 62-550, and 62-699 of the Florida Administrative Codes, (FAC), are available for a fee upon telephone request to Mrs. Kristine Sheets at (904) 947-3436.

If you have any questions concerning this letter, please feel free to contact this writer at (904) 947-3421.


Sincerely,

Mark A. Halverstadt  
Environmental Specialist II  
Environmental Health Engineering

MAH/mah  
Enclosures

cc: L. Faircloth  
R. Van Loon  
PWS File (ss94-81.doc)

EXHIBIT NO. 228  
CASE NO. 96-04227 27



T50S  
R26E  
T51S  
R26E

FLORIDA PUBLIC SERVICE COMMISSION  
DOCKET NO. 950495 EXHIBIT NO. 228  
COMPANY/  
WITNESS:  
DATE: 4/29/96

**ViroGroup**

AIR • WATER • SOIL TECHNOLOGY

DRN BY: CAM DWG. NO. A-013183KB-5 DATE: 4/25/96  
PROJECT NAME: SSU - MARCO ASR NUMBER: 01-03183.00

HORIZONTAL EXTENT OF INJECTED WATER, AS C/Co, IN THE LOWER HAWTHORN BASAL TRANSMISSIVE UNIT AFTER INJECTING AT A RATE OF 2.5 MILLION GALLONS PER DAY FOR 1,000 DAYS. C/Co OF 0.4 INDICATES 40 PERCENT INJECTED, 60 PERCENT NATIVE WATER.