

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18

TESTIMONY OF GERALD C. HARTMAN, P.E.
BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION
ON BEHALF OF
SOUTHERN STATES UTILITIES, INC.
DOCKET NO. 960258-WS

ACK _____
AFA _____ 19
APP _____ 20
CAF _____ 21
CMU _____
CTR _____ 22
EAC _____ 23
LEG _____ 24
LIN _____
OFC _____ 25
ROH _____ 26
SEC _____
WAS _____
OTH _____

1 Q. PLEASE STATE YOUR NAME AND BUSINESS ADDRESS.

2 A. My name is Gerald C. Hartman. My business address
3 is Hartman & Associates, Inc., Southeast Bank
4 Building, Suite 1000, 201 East Pine Street,
5 Orlando, Florida 32801.

6 Q. COULD YOU BRIEFLY DESCRIBE YOUR EDUCATIONAL
7 BACKGROUND AND YOUR PROFESSIONAL QUALIFICATIONS
8 RELATIVE TO THE WATER AND WASTEWATER INDUSTRY.

9 A. I received my Bachelors of Science degree in Civil
10 Engineering from Duke University in 1975 and my
11 Masters of Science degree in Environmental
12 Engineering in 1976 from Duke University. I have
13 published over thirty papers on water and
14 wastewater utility systems and have been involved
15 in numerous technical training sessions and
16 seminars. I have co-authored one book and my
17 second book concerning water and wastewater systems
18 is in preparation. I am a registered professional
19 engineer in the States of Florida, Georgia,
20 Maryland, North Carolina, South Carolina, Alabama,
21 Arizona, Mississippi, Pennsylvania and Virginia. I
22 am a Diplomate of the American Academy of
23 Environmental Engineers. I also am a member of and
24 have served as an officer in numerous organizations
25 and associations operating in the water/wastewater

1 industry.

2 Q. PLEASE DESCRIBE YOUR PROFESSIONAL ENGINEERING
3 EXPERIENCE CONCERNING WATER AND WASTEWATER
4 UTILITIES.

5 A. I have been the engineer of record for over forty
6 water and wastewater master plans and numerous
7 capital improvement programs. I have been involved
8 in over fifty hydraulic model analyses of water and
9 wastewater systems. In addition, I have been
10 involved in numerous studies and investigations
11 ranging from pilot programs to value engineering
12 investigations. I have performed numerous water
13 process evaluations from simple aeration to reverse
14 osmosis and wastewater process evaluations from
15 secondary treatment to advanced biological nutrient
16 removal systems.

17 I also have been involved in the design of
18 over \$500 million of water and wastewater
19 facilities in the State of Florida. These designs
20 range from small, single well systems to large
21 municipal and investor-owned systems. I have been
22 involved in over \$1 billion in publicly owned water
23 and wastewater financing in Florida. Finally, I
24 have prepared used and useful analyses on over 200
25 water and wastewater facilities for investor-owned

1 utilities across the State of Florida. A copy of
2 my resume and qualifications are attached to my
3 comments as Exhibit _____ (GCH-1).

4 **Q. HAVE YOU TESTIFIED PREVIOUSLY AS AN EXPERT IN THE**
5 **AREA OF WATER AND WASTEWATER FACILITY ENGINEERING**
6 **PREVIOUSLY?**

7 A. Yes. I have testified before this Commission as an
8 expert in the area of water and wastewater utility
9 engineering in a number of cases, including
10 Southern States' last four rate filings (Docket No.
11 950495-WS being the most recent). I have also
12 testified as an expert in water and wastewater
13 proceedings before county regulatory authorities.
14 I have been accepted by the Florida DOAH and
15 Florida courts as an expert in a variety of water
16 and wastewater utility cases for subject areas such
17 as water and wastewater facility design and
18 valuation.

19 **Q. WHAT IS THE PURPOSE OF YOUR COMMENTS?**

20 A. To present expert opinion on behalf of and to
21 present the position of Southern States Utilities,
22 Inc. ("SSU") regarding the Commission's proposed
23 Rule 25-30.431, Margin of Reserve.

24 **Q. WHAT IS THE POSITION OF SSU?**

25 A. SSU supports the position of the Florida Waterworks

1 Association ("FWWA") and the revisions to the
2 proposed rule which FWWA advocates in the comments
3 it has filed. In the event, however, that FWWA's
4 positions are not accepted, SSU supports certain
5 alternatives I will identify later in my testimony.
6 My comments focus primarily on economies of scale
7 and the traditional approach to margin reserve --
8 reminiscent of my testimony in Docket No. 950495-
9 WS.

10 Q. WOULD YOU LIKE TO MAKE ANY GENERAL COMMENTS FIRST?

11 A. Yes. As I have testified to previously and cannot
12 emphasize enough, it is absolutely critical that
13 the Commission consider investment required by
14 statutes, rules and regulations as used and useful.
15 The Commission must keep this in mind when
16 considering a proper margin reserve. In Section
17 367.111(2), Florida Statutes, the Commission is
18 charged with insuring that utilities provide
19 service "as prescribed by Part VI of Chapter 403
20 and Parts I and II of Chapter 373, or rules adopted
21 pursuant thereto; but such service will not be less
22 safe, less efficient, or less sufficient than is
23 consistent with the approved engineering design of
24 the system and the reasonable and proper operation
25 of the utility in the public interest." Rule 25-

1 30.225, Florida Administrative Code, reinforces
2 Section 367.111. It is improper for the Commission
3 to disallow through the used and useful mechanism
4 utility investment required by governmental
5 regulations or by generally accepted design
6 criteria referenced by those regulations. The
7 Commission should not put the utility in the
8 position where the utility cannot recover costs
9 sufficient to comply with the rules and regulations
10 which other governmental units and agencies (and
11 the Commission itself through the laws I have
12 cited) impose on the utility and for violation of
13 which the utility is held accountable. It is
14 similarly inappropriate for the Commission to
15 disallow through an artificially short margin
16 reserve period that investment necessary to provide
17 the "efficient" service which is "consistent with
18 the approved engineering design" of facilities, as
19 referred to in Section 367.111(2) (i.e., economy of
20 scale). The Commission must therefore utilize and
21 develop used and useful practices, and in this
22 situation margin reserve practices specifically,
23 which do not deprive utilities of investment in
24 facilities prudently planned and economically
25 sized. Used and useful cannot be divorced from

1 regulatory requirements and engineering
2 considerations.

3 There is no question that the incentive
4 created by the Commission's current used and useful
5 methodologies, and in particular the margin reserve
6 policy now reflected in the Commission's proposed
7 rule, is for utilities to design and construct
8 facilities in the smallest possible increments
9 necessary to meet only immediate demand as that
10 demand becomes clear and present. This incentive
11 does not promote the prudent planning, economies of
12 scale, and environmental protection goals the
13 Commission should promote. There is also no
14 question the incentive of the current policy will
15 increase the cost to the utility to current and
16 future customers, and to the State, as well as
17 increase the likelihood of harm to the environment.

18 The Commission's proposed Rule 25-30.431 does
19 not cure the inappropriate deprivation of required
20 and economic investment which is caused by the
21 Commission's current policies and does not strike a
22 more reasoned balance between proper incentives and
23 the Commission's concern with fair allocation of
24 costs to different generations of customers.

25 Q. WHY IS THAT?

1 A. The proposed rule reflects current Commission
2 policy on margin reserve and imputation of CIAC,
3 which ignores the concerns I have mentioned.

4 The unfairness of the current used and useful
5 policy is further underscored by the fact that
6 under this policy, current customers receive all of
7 the benefits of economies of scale -- a lower per
8 unit cost, more reliable service, environmental
9 safety -- while the utility must bear all of the
10 risk from economies of scale -- a cost difference
11 in unit sizes that is deemed non-used and useful
12 and relegated to uncertain recovery through AFPI.

13 Current margin reserve policy is that a
14 utility should have plant capacity available for
15 growth without having to undertake plant expansion;
16 therefore, the margin reserve period is equal to an
17 estimated average duration for plant construction,
18 when, the theory goes, most expansion costs are
19 incurred. Aside from its other flaws, this
20 reasoning is inconsistent in that the margin
21 reserve is considered a surrogate for plant
22 expansion, but the higher costs associated with
23 expansion are not considered. Current margin
24 reserve policy, a substitute for expansion, takes
25 full advantage of the lower cost characteristics of

1 existing plant -- due to economies of scale and
2 other factors -- while ignoring the higher cost
3 characteristics of the plant expansion the policy
4 would have utilities avoid.

5 It is beyond doubt that economies of scale
6 exist for utility facilities. The Economy of Scale
7 Evaluation which I presented in Docket No. 950495-
8 WS and which I will discuss herein proves the
9 extent of those economies. Yet, it has only been
10 in extremely rare cases, where a utility has
11 invested a great deal of time and expense to
12 present the Commission with a cost comparison/cost
13 separation study showing the economies of a
14 specific plant or plant component, that the
15 Commission has in any way reflected economies of
16 scale in used and useful. (E.g. Order No. PSC-93-
17 1288-FOF-SU, issued September 7, 1993, Florida
18 Cities Water Company, South Fort Myers.) Economies
19 of scale are known to exist. They can be and have
20 been measured. Yet economies of scale are
21 steadfastly ignored by the Commission on a routine
22 basis. It is not reasonable to require a
23 painstaking dissection of a known fact at a
24 considerable price in rate case expense. Nor is it
25 practical to expect a utility to build facilities

1 and take advantage of economies of scale when the
2 utility's investment in those facilities, despite
3 the fundamental existence of economies of scale, is
4 subject to this kind of uncertainty and risk in a
5 Commission rate proceeding.

6 I therefore strongly urge the Commission to
7 accept the industry's proposals.

8 **Q. WHY IS A MARGIN RESERVE, AND MORE SPECIFICALLY AN**
9 **ADEQUATE MARGIN RESERVE, NECESSARY?**

10 A. There are three basic reasons: (1) economic
11 benefit to the customers and the utility, (2)
12 public health and environmental protection, and (3)
13 reduced regulatory costs. First, a margin reserve
14 permits the utility an opportunity to achieve at
15 least some portion of the economy of scale benefits
16 I will describe. Second, if no margin reserve or
17 an inadequate margin reserve is permitted,
18 utilities will be forced into a situation where
19 they would constantly be butting up against the
20 capacity limitations of their facilities. The
21 dangers to the public health and the environment
22 which result from this are obvious: insufficient
23 water pressure, connection moratoria, insufficient
24 chlorine contact time, lack of sufficient disposal
25 facilities, improper discharge of wastewater, and

1 insufficient wastewater treatment to name a few.
2 All of these problems can occur due simply to the
3 variability of demand. Third, if utilities cannot
4 earn a return on economically sized plant, forcing
5 the utilities to constantly operate facilities on
6 the edge of their capacity limitations, all of the
7 activities associated with needed improvements and
8 expansions will likewise be in constant motion. A
9 perpetual permit and construction apparatus on the
10 part of utilities requires the perpetual attention
11 of the regulatory authorities' engineers,
12 inspectors, analysts, etc. -- all at an increased
13 cost to the utility, the customers and the state.
14 Each of these adverse consequences results from
15 there being no margin reserve or an inadequate
16 margin reserve and should be scrupulously avoided.

17 **Q. IS MARGIN RESERVE SOLELY FOR FUTURE CUSTOMERS?**

18 **A.** No. The existing customers benefit from the
19 capacity to serve their needs, to attenuate the
20 impacts of growth in connections, and from the
21 long-term economies of scale.

22 The variability of demand over the useful life
23 of an asset (30-50 years) can be great, and only
24 the existing customers create this variability, and
25 smaller facilities demonstrate higher variability

1 in demand than do larger facilities. To
2 illustrate, if growth were only about 3% per year,
3 in 3 years only 9% to 10% growth on the average
4 would occur. For most water plants, the
5 variability of the maximum day demand from existing
6 customers can easily be 10% from year to year.

7 Further, margin reserve is an accepted
8 regulatory allowance for growth in the need for
9 service from both existing and new customers. The
10 margin reserve cannot be sequestered for, or
11 dedicated exclusively to, future customers. Those
12 who oppose margin reserve expect the customers to
13 receive all the benefits of the margin reserve but
14 with the costs and risks therefor borne exclusively
15 by the utility.

16 **Q. COULD YOU PLEASE DESCRIBE ECONOMIES OF SCALE AND**
17 **HOW ECONOMIES OF SCALE SHOULD BE CONSIDERED IN**
18 **SETTING MARGIN RESERVE?**

19 **A.** Yes. First, an economy of scale is the phenomenon
20 of a decreased per unit cost attained through the
21 use of larger units. To illustrate, a 10,000
22 gallon per day (gpd) wastewater treatment plant may
23 cost \$60,000 to build and thus have a per unit cost
24 of \$6.00 per gallon per day, whereas a 100,000 gpd
25 plant may cost \$250,000 and have a per unit cost of

1 \$2.50 per gallon per day. In this example, the per
2 unit cost for building the larger plant is much
3 less than for building the smaller plant and
4 reflects an economy of scale. An economy of scale
5 can likewise be attained in the operation and
6 maintenance costs for running a larger versus a
7 smaller plant.

8 As I indicated earlier, that the economy of
9 scale phenomenon occurs with water and wastewater
10 facilities and facility components is without
11 question. The purpose of the Economy of Scale
12 Evaluation I prepared and which was submitted into
13 evidence in Docket No. 950495-WS was to identify
14 and measure the economies of scale for the capital
15 costs of water and wastewater treatment facilities
16 and components.

17 Briefly stated, this Evaluation examined the
18 average cost and per unit cost of the following
19 facilities/components: extended aeration package
20 wastewater treatment plants; contact stabilization
21 wastewater treatment plants; blowers, filters, and
22 chlorination units for wastewater plants; standby
23 generators for water and wastewater plants;
24 prestressed concrete ground storage tanks, steel
25 ground storage tanks; water plant disinfection

1 (chlorination) equipment; high service pumps;
2 hydropneumatic tanks; lime softening water
3 treatment plants; reverse osmosis water treatment
4 plants; gravity sewer lines; sewage pump stations;
5 sewer force mains; and water mains. Unit cost
6 curves, showing the cost per unit of capacity on
7 one axis of a graph and capacity on the other, were
8 created for all facilities/components examined and
9 appear in the Evaluation text. These unit cost
10 curves clearly demonstrate the economy of scale
11 associated with the identified facilities/
12 components. The unit cost curves in the Evaluation
13 also serve to illustrate the threshold minimum size
14 which selected facilities/components must be before
15 the rate of change in the per unit cost begins to
16 decline. For ease in reference, I have attached as
17 Exhibit _____ (GCH-2) a one page summary
18 illustration of water plant component unit cost
19 curves and a blow-up of the unit cost curve for a
20 steel ground storage tank ("GST").

21 From the steel GST unit cost curve in Exhibit
22 _____ (GCH-2), one should note the "inflection
23 point" in the curve. The "inflection point" of the
24 unit cost curve refers to the point at which the
25 relative maximum economy of scale is achieved and

1 beyond which the unit price remains nearly
2 constant. In the case of the steel GSTs, the
3 inflection point is at the 100,000 gallon tank.
4 Therefore, to take advantage of the optimal economy
5 of scale, a 100,000 gallon tank would be the
6 threshold size necessary. This is not to say,
7 however, that a tank of that size is appropriate in
8 all cases -- only that it is the threshold size
9 required to achieve the optimal economy of scale.

10 Exhibit _____ (GCH-3) contains a series of
11 graphs which illustrate the appropriate margin
12 reserve period needed to promote and preserve the
13 economies of scale for certain of the facilities/
14 components analyzed in the Economies of Scale
15 Evaluation, which is itself attached as Exhibit
16 _____ (GCH-4). Note that the presentation of
17 information on the illustrations in Exhibit _____
18 (GCH-3) is somewhat different from what was
19 presented in Docket No. 950495-WS. Modifications
20 were made so the presentation would be more
21 condensed and simplified. As before, however, all
22 of the underlying data comes from the Economy of
23 Scale Evaluation.

24 For purposes of illustration and analysis
25 here, I would group the facilities/components

1 included in the Economies of Scale Evaluation in
2 three categories: (1) facilities/components with a
3 nature conducive to expressing economies in terms
4 of growth in flow/volume over time, (2) lines
5 (water lines and wastewater gravity and force
6 mains) and (3) other components. Facilities/
7 components in the first group are generally sized
8 based on flow/volume requirements, so economies of
9 scale can be examined with growth in flow/volume
10 over a period of time. This group includes the
11 following: Steel ground storage tanks, prestressed
12 concrete ground storage tanks, pressure filters,
13 gravity filters, contact stabilization wastewater
14 treatment plants, extended aeration wastewater
15 treatment plants, reverse osmósis water treatment
16 plants, lime softening water treatment plants,
17 blowers, pumps, and water wells. Lines have been
18 segregated for analysis because of regulatory
19 requirements, design considerations, economic
20 features, etc. which are not conducive to
21 expressing economies in terms of growth over time.
22 The same is also true for components in the third
23 group, which includes auxiliary generators,
24 hydropneumatic tanks, and chlorination equipment.
25 As I will explain below, the approach for

1 demonstrating economies of scale for lines is
2 somewhat different than that for facilities in the
3 first group. Components in the third group are not
4 addressed in Exhibit _____ (GCH-3) and should be
5 considered 100% used and useful (and margin reserve
6 not a consideration) for reasons I will explain
7 below.

8 The illustrations in Exhibit _____ (GCH-3) are
9 largely self explanatory. I will however make a
10 few brief points to better relate their purpose.
11 The Exhibit covers a sample of various facilities/
12 components in the first group referenced above.
13 Each page of the Exhibit contains a number of
14 panels as follows: (1) a graph showing growth in
15 demand at a steady rate of 3% per year, (2) a
16 timeline comparison of various phasing scenarios,
17 (3) a graph depicting phasing intervals over time
18 for the same scenarios, and (4) a graph identifying
19 the investment savings associated with larger
20 sizing and the margin reserve period necessary to
21 insure that savings is captured. For example, the
22 steel GST on page 1 of Exhibit _____ (GCH-3)
23 requires a 15 year margin reserve to insure
24 customers receive the benefit of, and utilities
25 take advantage of, economies of scale. None of the

1 illustrations in Exhibit _____ (GCH-3) for
2 facilities/components in the first group reveal a
3 margin reserve period less than 7 years as the
4 duration necessary for insuring economies of scale
5 savings.

6 Attached as Exhibit _____ (GCH-5) are present
7 value charts, preceded by an explanation of those
8 charts, which illustrate an important point about
9 economies of scale. The charts show the present
10 value for installing a steel GST (as an example)
11 assuming the scenarios therein described. From
12 these charts one can clearly see the illogical
13 economic signal the Commission sends utilities by
14 measuring used and useful and limiting margin
15 reserve as it has in recent years. All things
16 being equal, the most cost effective choice for the
17 utility engineer is the choice with the lowest
18 present value (both to the utility and the
19 customer), but the Commission's used and useful and
20 margin reserve practices act as a disincentive to
21 economies of scale and corrupt the decision-making
22 process. Without a change to margin reserve
23 practices and assuming used and useful is
24 unchanged, the Commission encourages a utility to
25 install the smallest tank necessary so the utility

1 may recover the greatest portion of its total
2 investment. The present value tables reveal that
3 the smallest GST necessary is not the most cost-
4 effective choice. The Commission can correct this
5 illogical economic signal and encourage economies
6 of scale through an appropriate allowance for the
7 margin reserve.

8 **Q. ARE THERE OTHER REASONS ECONOMIES OF SCALE SUPPORT**
9 **THE FIVE YEAR MARGIN RESERVE?**

10 A. All of the arguments I have made above and those
11 asserted by FWWA support an economic investment
12 approach to margin reserve. The idea is to capture
13 in margin reserve the cost of the economic
14 investment needed to provide service during the
15 margin reserve period.

16 The proposed rule refers to the margin reserve
17 period as the "time period needed to install the
18 next economically feasible increment of plant
19 capacity that will preclude a deterioration in the
20 quality of service." I believe that such language
21 is appropriate. However, it stands to reason that
22 if the time period for installing the next
23 economically feasible increment of plant is
24 considered, the costs should be as well.

25 SSU supports FWWA's rule proposal for margin

1 reserve on water source and treatment and
2 wastewater treatment and effluent disposal (other
3 than reuse). The illustrations for the group one
4 facilities/components in Exhibit _____ (GCH-3)
5 clearly support FWWA's proposal. FWWA's proposal
6 is a step toward properly insuring economies of
7 scale consideration in used and useful and will
8 take the Commission one step closer to the
9 threshold sizing approach for used and useful which
10 the Commission should consider. Through that
11 approach one directly analyzes the level of
12 investment needed for the standard sized facilities
13 required for providing service to customers through
14 the margin reserve period. While that analysis may
15 be more complicated, the margin reserve period is
16 less critical because greater focus is placed on
17 the level of investment required for a facility
18 than on projections for demand.

19 There is a portion of required utility
20 investment which the FWWA proposal for group one
21 facilities/components does not fully capture in the
22 margin reserve which a threshold approach would,
23 including (1) saturation loss (the recognized
24 phenomenon that not all capacity required will be
25 utilized, e.g. not all lots will connect); (2) the

1 project costs which are incurred regardless of
2 facility size for planning, engineering, permitting
3 and start-up operations (hereinafter referred to as
4 "PEPO costs"); and (3) the material and
5 installation costs for threshold facility sizing
6 and the minimum facility sizing. The FWWA proposal
7 as to lines (and pump stations) does, however,
8 appropriately capture such costs.

9 **Q. WHAT IS "SATURATION LOSS"?**

10 A. Saturation loss is a well known and recognized
11 phenomenon in development. A project may have 100
12 platted lots, but it is rare that the project has
13 100 utility customers. In a single development
14 there are exceptions, although a utility has this
15 phenomenon compounded from development to
16 development for each one served. The phenomenon
17 occurs due to any of the following reasons
18 reminiscent of why the lot-count method is
19 inappropriate:

- 20 (1) A lot may be unbuildable.
21 (2) Redevelopment for stormwater, roads or other
22 reasons can use up lots.
23 (3) Utility facilities may encumber a few lots.
24 (4) A family may wish to locate their home on more
25 than one lot.

- 1 (5) Zoning can change to affect lots.
- 2 (6) A lot could be environmentally encumbered
- 3 (wetlands, vegetation, stormwater, pollution,
- 4 etc.)
- 5 (7) Due to regulations (i.e. septic tank density
- 6 agreements) lots may be unbuildable though the
- 7 water lines are present.
- 8 (8) A community may wish to convert lots into
- 9 parks, nature areas, etc.
- 10 (9) A lot may never sell.
- 11 (10) A lot may sell but never be built on, etc.

12 It is even less likely in larger more regional
13 facilities to attain saturation or build-out of all
14 lots, in fact the "saturation loss" increases. My
15 work in bonding over \$3 billion of public water and
16 wastewater facilities in the Southeast, my work
17 with both Moody's Standard & Poors and Fitch and my
18 work in the Easterly Orange County \$27 million
19 "tri-party" bonds all have exposed me to the
20 reality of this fact. Standard texts in Urban
21 Structure, Urban Studies, and Planning and Decision
22 Analysis reflect this concept. The amount can vary
23 from facility to facility. Taking the example for
24 the 100 lot subdivision possibly 10% of the lots
25 would never become customers (they may be sold but

1 will not result in customers) of the utility.

2 **Q. WHAT ARE "PEPO" COSTS?**

3 A. As indicated earlier, PEPO is the planning,
4 engineering, permitting and operations start-up
5 requirements of a project. PEPO costs will be
6 incurred regardless of the size of the facility
7 constructed. Typical PEPO costs are shown in the
8 table in Exhibit _____ (GCH-6). From a cost
9 standpoint, as a percent of construction cost
10 facilities, a PEPO curve, also shown in Exhibit
11 _____ (GCH-6) can be developed. Investment in PEPO
12 costs primarily occurs prior to construction.
13 Typically, PEPO costs for investor owned utilities
14 generally from 10 to 25 percent.

15 **Q. WHAT IS THRESHOLD SIZING?**

16 A. Threshold sizing involves three factors:

17 (a) Standard sizes or manufacture for pipelines
18 and plants.

19 (b) Minimum State/Local Regulatory Requirements
20 (e.g. gravity sewers being 8-inch in
21 diameter).

22 (c) Level of Service Requirements (such as minimum
23 pressure, chlorination, back-up requirements,
24 maintenance, etc.)

25 To illustrate, the standard size plant may be

1 20,000 gpd for a margin reserve period demand of
2 17.920 gpd. The cost for the remaining 2,080 gpd
3 in this example should be allocated to the margin
4 reserve as reasonably economically feasible and not
5 adjusted as non-used and useful for the simple
6 reason that the 20,000 gpd plant costs less than a
7 custom 17.920 gpd plant. Also, for a utility which
8 must serve a development the required pipe size may
9 be 6-inch though an approximate 4.5-inch pipe may
10 hydraulically suffice. The utility has no option
11 to build a 4.5-inch pipe as 4.5-inch pipe is not a
12 standard pipe size. The difference between a four
13 (4) inch and six (6) inch may be about \$2/foot or
14 15%. That 15% threshold extra cost should be
15 reflected in used and useful. Exhibit _____ (GCH-
16 7) contains a listing of standard facility and
17 component sizes as well as a brief list of
18 pertinent regulatory requirements which address
19 facility and component sizing.

20 **Q. WHAT DO YOU MEAN BY SAYING NO "LESS OF A FACILITY"**
21 **CAN BE USED?**

22 **A.** If you must serve a customer, and the smallest
23 facility or component to serve the customer or set
24 of customers is used, then nothing less would work.
25 This amount can be determined and should be

1 recognized as used and useful.

2 Q. PLEASE EXPLAIN WHY YOU SUPPORT FOR THE FWFA'S
3 POSITION ON LINES?

4 A. As I indicated earlier, water lines and wastewater
5 gravity and force mains must be constructed and
6 designed to meet certain regulatory requirements.
7 Where fireflow is required, for example, the
8 minimum size water line permittable is 6 inches.
9 Further, the utility is required to provide service
10 to all customers in it service area, and, as Mr.
11 Seidman states, there are economic considerations
12 to consider for repiping areas. Similarly, for
13 gravity lines the minimum size gravity sewer line
14 is 8-inches. This is a requirement set forth in
15 Rule 62-604.300(4)(b), F.A.C. In addition these
16 lines are required to be laid at relatively steep
17 slopes and have excess hydraulic capacity. The
18 minimum line size is a threshold size established
19 based on practical field experience. And for force
20 mains the minimum allowable force main size is four
21 inches and this is set forth in Rule 62-
22 604.300(4)(b), F.A.C. In addition to being state
23 requirements these minimum requirements are
24 consistent with the Land Development Regulations of
25 cities and counties throughout Florida.

1 Exhibit _____ (GCH-8) attached hereto contains
2 several tables and charts comparing the capacity
3 and costs for various line sizes and line types.
4 In summary, this Exhibit illustrates the following
5 points: (1) the cost of oversizing a line is
6 substantially less than the cost of undersizing a
7 line only to replace or run another line parallel
8 to the undersized line; (2) the difference in the
9 customer serving capacity of lines is significant
10 from one standard line size to the next, while the
11 cost difference is not as significant; and (3) the
12 economies of scale associated with installing lines
13 of a greater versus shorter linear distance is
14 substantial.

15 I believe it will be in extraordinarily rare
16 cases that the Commission may find an investor-
17 owned utility in Florida which has installed lines
18 of a size greater than required by and permissible
19 under the pertinent regulations. Such situations
20 would have to be examined case-by-case and cost
21 efficiencies considered. However, SSU believes
22 FWWA's proposed rule for lines (and sewage pump
23 stations) is appropriate because of regulatory
24 requirements, economic considerations, and, most
25 importantly, the utility's service obligation.

- 1 Q. WHAT IS THE PURPOSE OF THE INFORMATION FOR WATER
2 LINES, WASTEWATER GRAVITY LINES, AND WASTEWATER
3 FORCE MAINS IN EXHIBIT _____ (GCH-8)?
- 4 A. If the Commission rejects FWWA's proposal as to
5 lines (and sewage pump stations), the referenced
6 information should serve as the basis for an
7 alternative approval. The Exhibit shows the
8 tremendous economies of scale for different line
9 types -- economies which in large part arise from
10 savings in installation and PEPO costs. These
11 economies of scale should be considered in
12 establishing margin reserve for lines if FWWA's
13 proposal is rejected.
- 14 Q. COULD YOU PLEASE ADDRESS THE THIRD GROUP OF
15 FACILITIES EXAMINED IN THE ECONOMIES OF SCALE
16 EVALUATION?
- 17 A. Components in the third group are not addressed at
18 in Exhibit _____ (GCH-3) and should be considered
19 100% used and useful (and margin reserve not a
20 consideration). The economies of scale and
21 standard sizing for auxiliary generators,
22 hydropneumatic tanks, and chlorination equipment
23 specifically are displayed in the Economy of Scale
24 Evaluation, on pages 48, 62 and 47, respectfully,
25 in Exhibit _____ (GCH-4). The Commission ruled

1 that auxiliary generators and hydropneumatic tanks
2 should be 100 % used and useful in SSU's last rate
3 proceeding, Docket No. 950495-WS. Chlorination
4 equipment should not be treated any differently
5 because of economies of scale and threshold sizing
6 considerations.

7 **Q. REGARDING THE PROPOSED RULE, DO YOU HAVE ANY**
8 **RECOMMENDATIONS AS TO THE DEFINITION OF "MARGIN**
9 **RESERVE"?**

10 A. Yes. Margin reserve is not only what is stated but
11 also should include:

- 12 (1) variability in demand,
13 (2) long-term economic cost-effectiveness
14 considerations,
15 (3) regulatory reserve capacity requirements
16 (i.e., FDEP and WMD rules, regulations and
17 practices),
18 (4) standard sizing of facilities,
19 (5) threshold costs and
20 (6) the concept of no less of a facility would be
21 required.

22 The FWWA definition of Margin Reserve is
23 appropriate. Margin reserve should provide the
24 economic incentive to build facilities which can
25 attain lower long-term rates over the useful life

1 of the asset and to assure the quality of service
2 to meet the varying demand conditions. This
3 results in the lowest present value of all rates
4 paid by the customer. Currently, with the
5 practices of the Commission and the application of
6 the present used and useful and margin reserve
7 policies, the utility, which provides for the
8 public health, safety and welfare, is not put in
9 the position of being made-whole on a stand-alone
10 basis.

11 **Q. DO YOU AGREE WITH THE COMMISSION PROPOSED RULE'S**
12 **DEFINITION OF THE "MARGIN RESERVE PERIOD"?**

13 **A.** No. "Installation" refers solely to construction
14 time. The total time necessary is that to plan and
15 finance, plant, engineer/design, permit, construct
16 and "shake-down" operate the facility improvement/
17 expansion.

18 In the public sector, without economic
19 regulation, this period is shown in the utility
20 element of the Comprehensive planning documents. A
21 minimum of a 5-year planning period with the
22 commensurate capital improvement element/funding is
23 the Statewide practice. In my 20 years of Florida
24 water and wastewater utility consulting engineering
25 practice, all of the plans I have been associated

1 with include a minimum term of 5 years and a few
2 have gone out over forty (40) years. The necessary
3 margin reserve period is not just the construction
4 time the "PEPO" (planning, engineering, permitting
5 and initial start-up operations) time period is
6 missing.

7 **Q. IS EIGHTEEN MONTHS ADEQUATE TIME FOR PLANT**
8 **EXPANSION?**

9 A. No. In most instances today, if a utility must
10 construct additional capacity to keep ahead of the
11 customer demands, it needs more than eighteen
12 months to complete the process. This is especially
13 true in some areas such as Lehigh where there is a
14 fragile water supply and a relatively complex
15 treatment process necessary to treat the water.
16 Three years is more realistic. Attached as
17 Exhibit _____ (GCH-9) is a step by step process for
18 the addition of water treatment capacity. It
19 should be noted that the attached list is not all
20 inclusive and outlines only the major activities
21 for the addition of water treatment plant. This
22 outline assumes a relatively simple water treatment
23 facility with no major delays in the permitting,
24 design or construction processes. In a more
25 complicated process, for example one involving an

1 R.O. facility with an injection well, the
2 permitting and construction time would more than
3 likely be extended by at least one year.

4 The basic steps for wastewater treatment plant
5 expansion are extensive and similar to the water
6 treatment plant list discussed previously. With
7 wastewater plants, further delays can arise after
8 construction. Since effluent quality standards
9 must be met for all wastewater treatment plant
10 additions as of the start-up date, additional time
11 may be required to adjust treatment operations
12 prior to a plant's becoming fully operational.

13 As I have stated earlier, in prior rate cases,
14 the Commission has concluded that the margin
15 reserve for treatment plant should only represent
16 the time necessary to construct additional
17 treatment plant. This theory assumes the utility
18 has begun the construction phase as of the test
19 year and that construction will come off without a
20 hitch. In today's complex regulatory environment,
21 I believe this presumption is incomplete, in error,
22 and flawed. Moreover, this theory dictates that
23 the utility be forever at the point of constructing
24 an increment of capacity while it plans designs and
25 permits the increment needed after the one under

1 construction. The persuasive power of used and
2 useful is such that the reality of utility decision
3 making will mirror Commission theory. And it is
4 not fair, safe, efficient, or economical for the
5 Commission to promote this kind of reality.

6 Q. THE COMMISSION'S PROPOSED RULE DOES NOT CREATE A
7 SEPARATE USED AND USEFUL PROVISION FOR REUSE AS A
8 MEANS OF EFFLUENT DISPOSAL. DO YOU AGREE WITH
9 THIS?

10 A. No. As I testified in Docket No. 950495-WS, reuse
11 facilities should be considered 100% used and
12 useful. Therefore, margin reserve should not be a
13 consideration for reuse facilities. Sections
14 403.064(10) and 367.0817(3), Florida Statutes,
15 require that reuse facilities be considered 100%
16 used and useful. DEP, as evidenced by the letters
17 contained in Mr. Harvey's Exhibits _____ (RMH-2)
18 and (RAM-4) the DEP-Commission memorandum of
19 understanding contained in Mr. Harvey's Exhibit __
20 (RMH-1) support this position. Moreover, if the
21 Commission is to encourage reuse, it must consider
22 reuse facilities 100% used and useful.

23 Despite SSU and DEP testimony to the contrary,
24 in Docket No. 950495-WS, the Commission applied a
25 used and useful percentage to those reuse

1 facilities SSU claimed 100% used and useful. (Even
2 though DEP's definition of reuse is broader, SSU
3 only requested public access reuse facilities be
4 considered 100% used and useful.) In so doing, the
5 Commission treated SSU's investment in reuse
6 facilities no differently than its investment in
7 any other effluent disposal facilities and excluded
8 from rate base approximately \$4.6 million dollars
9 of plant-in-service for public access reuse. One
10 must therefore ask what the purpose of Sections
11 403.064(10) and 367.0817(3) is if reuse is treated
12 no differently than other means of effluent
13 disposal.

14 The Commission's decision in SSU's case will
15 definitely have a far-reaching chilling effect on
16 all investor-owned utilities contemplating reuse.
17 It will render reuse economically infeasible in
18 most cases because a utility not assured of
19 recovering its costs for reuse will not be able to
20 afford/finance reuse. As I have testified to
21 previously, reuse is essential to conserving
22 Florida's water resources and protecting Florida's
23 environment. The Commission's recent action is
24 clearly detrimental to these purposes. If the
25 Commission desires to encourage reuse and advance

1 the environmental and conservation benefits of
2 reuse, the Commission should reverse itself by
3 rule, as FWWA advocates. Further, the Commission's
4 definition of reuse facilities should follow DEP's
5 definition of reuse for consistency.

6 **Q. COULD YOU EXPLAIN THE SIGNIFICANCE OF DEP RULE 62-**
7 **600.405 ON MARGIN RESERVE?**

8 A. Yes. DEP's rules concerning planning for
9 wastewater facilities expansion dictate the
10 extension of the margin reserve period beyond
11 eighteen months for wastewater treatment
12 facilities. DEP Rule 62-600.405, F.A.C., attached
13 to my testimony as Exhibit _____ (GCH-10), requires
14 a utility to provide timely planning, design and
15 construction of plant expansions based on the
16 schedule delineated in the rule. Essentially, this
17 rule requires a utility providing wastewater
18 service to submit annual capacity analysis reports
19 to the DEP once a certain level of capacity is
20 reached. These reports must analyze an existing
21 facility and its capacity to provide service.
22 Basically, the rule has established four triggers
23 to determine when certain activities need to be
24 commenced concerning the design, permitting and
25 construction of additional wastewater treatment

1 facilities. If the projected flows of the facility
2 exceed the permitted capacity of the facility
3 within 5 years of the date of the report, then the
4 report must include a statement by a registered
5 engineer that planning and preliminary design of a
6 plant expansion has been initiated. When the
7 projected flows are expected to exceed the capacity
8 within 4 years, the report must include a statement
9 from the registered engineer that plans and
10 specifications for the expansion are being
11 prepared. If the engineer determines that projected
12 flows are going to exceed the capacity within 3
13 years, then a construction permit application must
14 be submitted to the DEP within 30 days of such a
15 determination. The final trigger is that if the
16 capacity analysis report indicates that the
17 projected flows are going to exceed the permitted
18 capacity of the treatment facilities within 6
19 months, an operating permit application must be
20 submitted by the utility along with the capacity
21 analysis report.

22 Although the rule does not directly state that
23 a utility must maintain capacity necessary to meet
24 demand for the next 5 years, the clear intent of
25 the rule is that capacity should be maintained for

1 a 5-year window, especially if the utility does not
2 wish to perpetually be in a permitting and
3 expansion mode for every wastewater treatment plant
4 it operates. The stated purpose of the rule is to
5 provide for the "timely planning, design, and
6 construction of wastewater facilities necessary to
7 provide proper treatment and reuse or disposal
8" Clearly, the rule reflects DEP's recognition
9 that the planning, design, and construction process
10 takes five years.

11 This situation with wastewater treatment plant
12 expansions appears to be an instance of DEP's
13 requiring one thing -- reserve capacity for five
14 years -- and the Commission's sending a contrary
15 signal -- by limiting utilities to an 18 month
16 margin reserve and by imputing CIAC. I can bring
17 this disparity into focus by stating that if a
18 utility filed a permit application in accordance
19 with this DEP rule and suggested in the application
20 that it would build capacity sufficient only to
21 serve 18 months of growth beyond its present
22 capacity, I have no doubt the application would be
23 rejected.

24 Q. IS IT PROPER TO CHARACTERIZE RULE 62-600-405,
25 F.A.C., AS ESTABLISHING NOTHING MORE THAN INTERVALS

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

FOR SUBMITTING A CAPACITY ANALYSIS REPORT?

A. No. The rule is applied by DEP to assure that at least a 5 year margin reserve of capacity exists or that the expansion process is underway. To interpret the rule as only a reporting requirement is to separate the words of the rule, which on the surface address reporting, from the rule's meaning, which focuses on performing the acts reported. Further, a shorter margin reserve period would place utilities in a position where the expansion activities for one interval and the next interval overlap, which makes no economic or regulatory sense whatsoever as I have already stated.

Q. DOES DEP HAVE IN PLACE A RULE FOR WATER FACILITIES SIMILAR TO RULE 62.600-405?

A. No. However, on recent submittals I have made to the DEP, adequate capacity has been an issue in the permit application process. Those reviewing water plant permit applications have asked with increased regularity if 5 years of water plant capacity is available or planned.

Q. DO THE COUNTIES AND CITIES WHICH YOU DO WORK FOR GENERALLY CONSTRUCT WASTEWATER TREATMENT PLANT IN INCREMENTS NEEDED TO MEET DEMAND OVER AT LEAST A 5-YEAR PERIOD?

1 A. Yes. A good number build for demand beyond five
2 years. Their reasons for building for at least
3 five years include all of those I've already
4 mentioned, the rule requirements, prudent planning,
5 environmental protection, and economies of scale.
6 Local governments also consider growth management
7 requirements. Although the Commission does not
8 enforce growth management laws, I mention this
9 because it relates to prudent planning. State
10 planning requirements are such that public
11 facilities, including utilities, must be in place
12 concurrent with growth. In order to fulfill these
13 requirements, local governments size their
14 wastewater and their water facilities to meet
15 planned changes in demand within their service
16 areas over a five year, or longer, period.

17 Q. DO THE COUNTIES AND CITIES WHICH YOU DO WORK FOR
18 GENERALLY CONSTRUCT WATER TREATMENT PLANT IN
19 INCREMENTS NEEDED TO MEET DEMAND OVER AT LEAST A 3-
20 YEAR PERIOD?

21 A. Yes, and frequently beyond, for the same reasons I
22 have just mentioned.

23 Q. ARE THERE ANY OTHER SOURCES OF INFORMATION YOU
24 WOULD REFER THE COMMISSION TO IN MAKING ITS
25 DECISION IN THIS MATTER?

1 A. Yes. In both of the letters contained in Mr.
2 Harvey's Exhibits _____ (RMH-2) and (RMH-4),
3 specifically in the second comment on page 2 of Mr.
4 Drew's letter and in the second paragraph of the
5 first page of Mr. Harvey's letter, DEP's
6 representatives state that the Commission's rules
7 should allow a utility to recover investment for
8 timely expenses for needed wastewater treatment
9 facilities **consistent with** the rule which I have
10 cited. I also note that in the May 12, 1995, draft
11 rule written by the Commission staff, Mr. Harvey's
12 Exhibit _____ (RMH-3), staff recognizes the need
13 for a three year margin reserve for water treatment
14 plant and a three year margin reserve for
15 wastewater treatment. This same draft rule also
16 states that utilities are encouraged to undertake
17 planning that recognizes conservation,
18 environmental protection, and economies of scale.
19 While I agree with the three year margin reserve
20 proposed for water treatment plant, a three year
21 margin reserve for wastewater treatment plant would
22 be in conflict DEP rules. For the reasons I have
23 explained, I believe a five year margin reserve for
24 wastewater treatment plant is appropriate.

25 Q. SHOULD CIAC BE IMPUTED ON MARGIN RESERVE AS THE

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

COMMISSION PROPOSES IN ITS RULE?

A. No. From an engineering standpoint, the imputation of CIAC on the margin reserve is incorrect because the margin reserve is a known and continuous obligation whereas the collection of CIAC is an unpredictable future event. The imputation of CIAC significantly undermines the stated purpose of the margin reserve and negatively impacts the goals of achieving proper planning, environmental preservation, and economies of scale for the benefit of the customers. I have reviewed instances where the CIAC imputed on the margin reserve has completely or substantially eliminated the margin reserve.

Q. DO YOU HAVE ANYTHING FURTHER TO ADD?

A. Yes. The cause-and-effect relationship at work with used and useful is simple. The Commission's used and useful practices of recent years, combined with no margin reserve, an insufficient margin reserve, or a margin reserve with CIAC imputed thereon provide utilities no incentive to take advantage of economies of scale and instead cause economic harm to those utilities who do. A utility company should not be asked to make investment of shareholder money when the recovery of and a return

1 on a substantial portion of that money is virtually
2 totally at risk. This is particularly true for
3 regulated utilities as the rate of return to the
4 shareholders is set by regulators, not the market,
5 and does not increase to the extent which would be
6 necessary to compensate for that risk. Thus, the
7 economic message under the Commission's proposed
8 rule is to build plant in small increments, ignore
9 economies of scale, and bear inordinate risk for
10 even threshold sizing.

11 Plant is not built to accommodate the need for
12 service on a gallon-for-gallon and lot-for-lot
13 basis. Used and useful should not treat utility
14 investment as though plant can be so built.

15 Q. DOES THIS CONCLUDE YOUR TESTIMONY?

16 A. Yes.

**GERALD C. HARTMAN, P.E.
PRESIDENT**

HARTMAN & ASSOCIATES, INC.

EDUCATION

B.S., Duke University, 1975
M.S., Duke University, 1976

PROFESSIONAL REGISTRATION

Professional Engineer No. 27703, Florida
Professional Engineer No. 12410, Maryland
Professional Engineer No. 131184, Virginia
Professional Engineer No. 15264, North Carolina
Professional Engineer No. 38216, Pennsylvania
Professional Engineer No. 17597, Georgia
Professional Engineer No. 15389, South Carolina
Professional Engineer No. 19422, Alabama
Professional Engineer No. 28939, Arizona
Professional Engineer No. 12717, Mississippi

PROFESSIONAL AFFILIATIONS

Diplomate - American Academy of Environmental Engineers
American Society of Civil Engineers
National Society of Professional Engineers
Florida Engineering Society
American Water Works Association
Florida Pollution Control Association
American Water Resources Association
Water Pollution Control Federation
Florida Water and Pollution Control Operators Association
Florida Waterworks Association

QUALIFICATIONS SUMMARY

Mr. Hartman is an experienced environmental engineer with special expertise in water and wastewater systems. Mr. Hartman is a qualified expert witness in the areas of water supply and treatment, wastewater treatment and effluent disposal, utility system valuation and financing, facility siting, and utility creation/management/acquisition projects.

EXPERIENCE

Mr. Hartman's experience exclusively involves water, wastewater, solids, and utility valuation/financing projects, and expert testimony assignments.



Financial Reports

Mr. Hartman has been involved in over 100 capital charge, impact fee, and installation charge studies involving water, wastewater and fire service for various entities. He also has participated in over 100 user rate adjustment reports. Mr. Hartman assisted in the development of over 50 revenue bond issues, 10 short-term bank loan systems, 2 general obligation bonds, 8 construction grant programs, 10 capacity sale programs, and 4 privatization programs. Mr. Hartman has been involved in over \$2 billion in utility financings for water and wastewater utilities.

Water and Wastewater Acquisition Valuations and Evaluations

Mr. Hartman has been involved in over 100 water and wastewater negotiations, valuations and evaluations, and has been a qualified expert witness by the courts with regard to water and wastewater negotiations, arbitrations, and condemnation cases. He has participated in the valuation of numerous major utility systems. His most recent experience in the 1987-96 period includes:

<u>Year</u>	<u>Project</u>	<u>Party Represented</u>
1996	Longwood Run Utility	Company
1996	Keystone Heights	City
1996	Keystone Club Estates	City
1996	Lakeview Villas	City
1996	Geneva Lakes	City
1996	Postmaster Village	City
1996	Tega Cay	County
1996	River Hills	County
1996	Consolidation Program Game Plan	Marion County
1996	Marion Oaks	Marion County (Ongoing)
1996	Marco Shores	Company (Ongoing)
1996	Marco Island	Company (Ongoing)
1996	Cayuga Water System	Authority
1996	Glendale Water System	Authority
1996	Lehigh Acres W & WW	Authority
1996	Lindrick Services Company	(Ongoing) Company
1996	Carolina Blythe Utility	Calabash
1996	Ocean Reef R.O. WTP's	NKLUA
1995	Sanibel Bayous	City of Sanibel
1995	Rotunda West Utilities	Investor
1995	Palm Coast Utility Corporation	ITT
1995	Sunshine State Parkway	Company
1995	Orange Grove Utilities, Inc.	Company (Ongoing)
1995	Georgia Utilities	(Ongoing) City of Peachtree City
1995	Beacon Hills Utilities	Company
1995	Woodmere Utilities	Company
1995	Springhill Utilities	Company
1995	Okeechobee Utility Authority	OUA
1995	Okeechobee Beach Water Association	OUA



Gerald C. Hartman, P.E., President (Continued)

Year	Project	Party Represented
1995	City of Okeechobee	OUA
1995	Mad Hatter Utilities, Inc.	Company
1994	Eastern Regional Water Treatment Plant	Owner
1994	GDU - Port St. Lucie Water and Wastewater	City of Port St. Lucie
1994	St. Lucie County Utilities	City of Port St. Lucie
1994	Marco Island/Marco Shores	Sun Bank
1994	Heater of Seabrook	Heater Utilities, Inc.
1994	Placid Lakes Utilities, Inc.	Company
1994	Ocean Reef Club Solid Waste System	ORCA
1994	Ocean Reef Club Wastewater System	ORCA
1994	South Bay Utilities, Inc.	Company
1994	Kensington Park Utilities, Inc.	Company
1993	River Park Water System	SSU
1993	Taylor Woodrow - Sarasota County	Taylor Woodrow
1993	Atlantic Utilities - Sarasota County	Company
1993	Alafaya Utilities, Inc.	Bank
1993	Anden Group Wastewater System	Company
1993	West Charlotte Utilities, Inc.	Englewood Water District
1993	Sanlando Utilities, Inc.	Investor
1993	Venice Gardens Utilities	Company
1992	Myakka Utilities, Inc.	City of North Port
1992	Kingsley Service Company	Clay County
1992	Mid Clay Utilities, Inc.	Clay County
1992	Clay Utilities, Inc.	Clay County
1992	RUD #1 - 4 Systems Review	Meadowoods/Kensington Park
1992	Martin Downs Utilities, Inc.	Martin County
1992	Fox Run Utility System	Martin County
1992	Leilani Heights	Martin County
1992	River Park Water and Sewer	SSU
1992	Central Florida Research Park	Barnett Bank
1992	Rolling Oaks Utility	Investor
1992	City of Palm Bay Utilities	PBUC
1992	South Bay Utilities, Inc.	Investor
1992	North Port - GDU Water and Sewer	City of North Port
1992	Palm Bay - GDU Water and Sewer	City of Palm Bay
1992	Sebastian - GDU Water and Sewer	City of Sebastian
1991	Sanibel - Sanibel Sewer System, Ltd.	City of Sanibel
1991	St. Augustine Shores - St. Johns County	SSU
1991	Remmington Forest - St. Johns County	SSU
1991	Palm Valley - St. Johns County	SSU
1991	Valrico Hills - Hillsborough County	SSU
1991	Hershel Heights - Hillsborough County	SSU
1991	Seaboard Utilities - Hillsborough County	UFUC
1991	Federal bankruptcy - Lehigh Acres	Topeka
1991	Meadowoods Utilities - Regional Utility District #1	Investor
1991	Kensington Park Utilities - Regional Utility District #1	Investor
1991	Industrial Park - Orange City	City of Orange City



Year	Project	Party Represented
1991	Country Village - Orange City	City of Orange City
1991	John Knox Village - Orange City	City of Orange City
1991	Land 'O Lakes - Orange City	City of Orange City
1990	Orange Osceola Utilities - Osceola County	Osceola County
1990	Morningside East and West - Osceola County	Osceola County
1990	Magnolia Valley Services, Inc. - New Port Richey	City of New Port Richey
1990	West Lakeland Industrial - City of Lakeland	City of Lakeland
1990	Highlands County Landfill	Owner
1990	Venice Gardens Utilities - Sarasota County	SSU
1990	South Hutchinson Services - St. Lucie County	SHS
1990	Indian River Utilities, Inc. - Edgewater	City of Edgewater
1990	Terra Mar Utility Company - Edgewater	City of Edgewater
1989	Seminole Utility Company - Winter Springs	Topeka
1989	North Hutchinson Services, Inc. - St. Lucie County	NHS
1989	Sugarmill Utility Company	Utilities Comm. City of New Smyrna Bch. Company
1989	Ocean Reef Club, Inc. ORCA	Company
1989	Prima Vista Utility Company - City of Ocoee	PVUC
1989	Deltona Utilities - Volusia County	SSU
1989	Poinciana Utilities, Inc. - Jack Parker Corporation	JPC
1989	Julington Creek	Investor
1989	Silver Springs Shores	Bank
1988	Eastside Water Company - Hillsborough County	Hillsborough County
1988	Twin County Utilities	Company
1988	Burnt Store Utilities	Company
1988	Deep Creek Utilities	Company
1988	North Beach Water Company - Indian River County	NBWC
1988	Bent Pine Utility Company - Indian River County	BPUC
1988	Country Club Village - SSU	CCV
1987	Sugarmill Utility Company - Florida Land Corporation	FLC
1987	North Orlando Water and Sewer Company - Winter Springs	NOWSCO
1987	Osceola Services Company - FCS (non-for-profit)	OSC
1987	Orange City Water Company - Orange City	City of Orange City
1987	West Volusia Utility Company - Orange City	City of Orange City
1987	Seacoast Utilities, Inc. - Florida Land Corporation	FLC

And numerous other water and wastewater utility valuations in the 1976-87 period.

Facility Planning

Mr. Hartman has been involved in over 50 water, wastewater and/or solid waste master plans, several interlocal negotiations and agreements, over 100 capital improvement programs, and numerous capital construction fund plans. He represented the American Society of Civil Engineers in the State Comprehensive Plan as a Policy Advisory Committee Member on the utility element, and participated in the preparation of Comprehensive Plans, Chapter 9J5, for more than 20 communities.



Gerald C. Hartman, P.E., President (Continued)

Analyses and Design

Mr. Hartman has participated in over 50 computer-assisted hydraulic analyses of water and wastewater transmission systems including extended period simulations as well as hydraulic transient analyses. He was involved in 4 wastewater treatment investigations, 2 sludge pilot testing programs, 14 effluent disposal pilot programs and investigations, several energy efficiency analyses, several odor control studies, and other process evaluations for operations. Mr. Hartman participated in 4 value engineering investigations oriented toward obtaining the most cost-effective alternatives for regional and private programs. Mr. Hartman has been involved in the design of package WWTP's through AWT facilities and simple well and chlorination systems through reverse osmosis facilities. He has been involved in numerous water blending, trihalomethane, synthetic organic contaminant removal, secondary precipitation, corrosion control, and alum precipitation studies. Mr. Hartman has performed process evaluations for simple aeration facilities, surface water sedimentation facilities, water softening facilities, as well as reverse osmosis facilities. He was involved in water conservation programs, as well as distribution system evaluation programs. He participated in both sanitary sludge management and disposal studies and co-authored the book entitled "Sludge Management and Disposal for the Practicing Engineer." He also participated in numerous lime sludge thickening, management, and utilization/disposal investigations. Mr. Hartman has been involved in wellfield management studies, wellfield protection ordinances, wellfield siting, water resource evaluations, and water resource planning for several entities in sand aquifer, sand and gravel aquifer and limestone aquifer systems.

Utility Management Consulting

Mr. Hartman has been involved in utility transfers from public, not-for-profit, district, investor-owned, and other entities to cities, counties, not-for-profit corporations, districts, and private investors. He has been involved in staffing, budget preparation, asset classification, form and standards preparation, utility policies and procedures manuals/training, customer development programs, standard customer agreements, capacity sales, and other programs. Mr. Hartman has been involved in over 50 interlocal agreements with respect to service area, capacity, service, emergency interconnects, back-up or other interconnects, rates, charges, service conditions, ownership, bonding, and other matters. Additionally, Mr. Hartman has assisted in the formation of newly certificated utilities, newly created utility departments for cities and counties, new regional water supply authorities, new district utilities, and other utility formations.



Gerald C. Hartman, P.E., President (Continued)

EXHIBIT LGCH-1
PAGE 6 OF 6

PUBLICATIONS/PRESENTATIONS

Mr. Hartman has presented several training sessions and seminars for the American Water Works Association, the American Society of Civil Engineers, the Water Pollution Association, and the Water and Pollution Control Operators Association. He has presented and/or published numerous papers on water, wastewater and utility management topics including:

Hartman, G.C., Utility Management and Finance, (presently under contractual preparation with Lewis Publishing Company/CRC press).

Vesilind, P.A., Hartman, G.C., Skene, E.T.; Sludge Management and Disposal for the Practicing Engineer; Lewis Publishers Inc.; Chelsea, Michigan; 1986.


Hartman, G.C., and R. J. Ori, "Water and Wastewater Utility Acquisition," AWWA Specialty Conference, 1994.

Hartman, G.C. and R.C. Copeland, "Utility Acquisitions - Practices, Pitfalls and Management," AWWA Annual Meeting, 1995.




UNIT COST RELATIONSHIP OF FACILITY EQUALS THE SUM OF ITS COMPONENTS


WATER TREATMENT PLANT FACILITY COMPONENTS



WELL + **GROUND STORAGE TANK** + **CHLORINATION SYSTEM** + **HIGH SERVICE PUMP** + **HYDRO-PNEUMATIC TANK** + **EMERGENCY POWER GENERATOR** = **COMPOSITE UNIT COST CURVE**



UNIT COST CURVES



WATER TREATMENT FACILITY COMPOSITE UNIT COST CURVE



EXHIBIT (GCH-2)

PAGE 1 OF 2

STEEL GROUND STORAGE TANK






EXHIBIT (6CH-2)
PAGE 2 OF 2

COST








CAPACITY UNIT COST








Notes:

- 1) Complete steel tank, concrete foundation, roof, roof manway, gravity vent, bottom manway hatch, ladder & cage assembly, top manway platform, protective bolt caps, and installation costs are included in the manufacturers' quotations.
- 2) Includes 5% piping, 0% electrical, and 5% sitework costs.
- 3) Costs are based on June 1995, ENR Index = 5433.









DEMAND (GPD) 100,000 GPD TO 300,000 GPD


PAGE 3 OF 13 (GCH-3)




FACILITY PHASING SCHEDULE AND CASH FLOW




DEMAND (GPD) 100,000 GPD TO 300,000 GPD








CUMULATIVE INVESTMENT / DOLLARS IN USED AND USEFUL




MARGIN RESERVE







DEMAND (GPD) 250,000 GPD TO 1,000,000 GPD




FACILITY PHASING SCHEDULE AND CASH FLOW




PLANT IN SERVICE



CUMULATIVE INVESTMENT / DOLLARS IN USED AND USEFUL




MARGIN RESERVE




5
12

(5 CH-3)


DEMAND (GPD) 250,000 GPD TO 1,000,000 GPD




FACILITY PHASING SCHEDULE AND CASH FLOW




PLANT IN SERVICE



CUMULATIVE INVESTMENT / DOLLARS IN USED AND USEFUL




MARGIN RESERVE




6 OF 12
 (GCH-3)

DEMAND (GPD) 250,000 GPD TO 1,000,000 GPD


PAGE 7 OF 12
(G-11-3)




FACILITY PHASING SCHEDULE AND CASH FLOW




PLANT IN SERVICE








CUMULATIVE INVESTMENT / DOLLARS IN USED AND USEFUL




MARGIN RESERVE







DEMAND (GPD) 10,000 GPD TO 50,000 GPD




FACILITY PHASING SCHEDULE AND CASH FLOW




PLANT IN SERVICE








CUMULATIVE INVESTMENT / DOLLARS IN USED AND USEFUL



MARGIN RESERVE




10 OF 12
 (GEN-3)




RO WTP - SMALL SYSTEMS 0.5 - 2.0 MGD




DEMAND (GPD) 1 MGD TO 4 MGD




FACILITY PHASING SCHEDULE AND CASH FLOW




PLANT IN SERVICE



CUMULATIVE INVESTMENT / DOLLARS IN USED AND USEFUL




MARGIN RESERVE




11 of 12
(644-3)


DEMAND (GPD) 144,000 GPD TO 720,000 GPD




FACILITY PHASING SCHEDULE AND CASH FLOW




PLANT IN SERVICE



CUMULATIVE INVESTMENT / DOLLARS IN USED AND USEFUL



MARGIN RESERVE



12 OF 12

(GCH-3)

ECONOMY OF SCALE EVALUATION

Prepared For



FEBRUARY, 1996

HAI Project No. 95-145.00



HARTMAN & ASSOCIATES, INC.

engineers, hydrogeologists, surveyors & management consultants

ORLANDO • JACKSONVILLE • TALLAHASSEE • FT. MYERS

TABLE OF CONTENTS

**SOUTHERN STATES UTILITIES
ECONOMY OF SCALE****TABLE OF CONTENTS**

<u>Section No.</u>	<u>Title</u>	<u>Page No.</u>
1.0	INTRODUCTION	
	1.1 Background	1-1
	1.2 Objective	1-2
	1.3 Summary and Conclusions	1-3
2.0	METHODOLOGY	
	2.1 General	2-1
	2.2 Sources	2-1
	2.2.1 USEPA	2-1
	2.2.2 Culp/Wesner/Culp	2-2
	2.2.3 Manufacturers	2-3
	2.2.4 Bid Tabulations	2-7
	2.3 Curve Design Summary	2-7
	2.3.1 Updating Process	2-8
	2.3.2 Design Consideration	2-8
	2.3.3 Finalization	2-8
3.0	ANALYSIS	
	3.1 Threshold Sizing	3-1
	3.1.1 Inflection Points	3-1
	3.1.2 Economic Minimum Threshold Sizes	3-4
	3.1.3 Curve Fitting	3-6
	3.1.4 Regulatory	3-6
4.0	WASTEWATER TREATMENT PLANT FACILITIES	
	4.1 Extended Aeration Package WWTP	4-1
	4.2 Contact Stabilization Package WWTP	4-4
	4.3 Blowers	4-7
	4.4 Filters	4-12
	4.5 Chlorination	4-12
	4.6 Standby Generator Sets	4-15

**SOUTHERN STATES UTILITIES
ECONOMY OF SCALE**

TABLE OF CONTENTS (Continued)

Section No.	Title	Page No.
5.0	WATER TREATMENT PLANT FACILITIES	
5.1	Prestressed Concrete Ground Storage Tanks	5-1
5.2	Steel Ground Storage Tanks	5-4
5.3	Chlorination	5-4
5.4	High Service Pumps	5-7
5.5	Hydropneumatic Tanks	5-11
5.6	Wells	5-14
5.7	Lime Softening WTP	5-14
5.8	Reverse Osmosis WTP	5-19
6.0	WASTEWATER COLLECTION/WATER DISTRIBUTION	
6.1	Gravity Sewers	6-1
6.2	Sewage Pump Stations	6-1
6.3	Force Mains	6-4
6.4	Water Mains	6-9
Appendix A -	Extended Aeration Package WWTP Supporting Data	
Appendix B -	Contact Stabilization Package WWTP Supporting Data	
Appendix C -	WWTP Positive Displacement and Centrifugal Blower Supporting Data	
Appendix D -	WWTP Tertiary Filter Supporting Data	
Appendix E -	Chlorine Feed System Supporting Data	
Appendix F -	Standby Generator Supporting Data	
Appendix G -	Concrete Ground Storage Tank Supporting Data	
Appendix H -	Steel Ground Storage Tank Supporting Data	
Appendix I -	Water Distribution High Service Pump Supporting Data	
Appendix J -	Hydropneumatic Tank Supporting Data	
Appendix K -	Water Supply Well Supporting Data	
Appendix L -	Lime Softening WTP Supporting Data	
Appendix M -	Reverse Osmosis WPT Supporting Data	
Appendix N -	Gravity Sewer System Supporting Data	
Appendix O -	Sewage Pump Station Supporting Data	
Appendix P -	Wastewater Force Main Supporting Data	
Appendix Q -	Water Main Supporting Data	

**SOUTHERN STATES UTILITIES
ECONOMY OF SCALE**

LIST OF TABLES

Table No.	Title	Page No.
1-1	Treatment Component Threshold Sizes	1-4

LIST OF FIGURES

Figure No.	Title	Page No.
3-1	Increasing and Decreasing Economy of Scale	3-2
3-2	Economy of Scale on Logarithmic Axes	3-3
3-3	Steel GST Inflection Point	3-5
4-1	Extended Aeration Unit Cost Curve	4-2
4-2	Extended Aeration Construction Cost Curve	4-3
4-3	Contact Stabilization Unit Cost Curve	4-5
4-4	Contact Stabilization Construction Cost Curve	4-6
4-5	Positive Displacement Blower Unit Cost Curve	4-8
4-6	Positive Displacement Blower Construction Cost Curve	4-9
4-7	Centrifugal Blower Unit Cost Curve	4-10
4-8	Centrifugal Blower Construction Cost Curve	4-11
4-9	Tertiary Treatment Filter Unit Cost Curve	4-13
4-10	Tertiary Treatment Filter Construction Cost Curve	4-14
4-11	Chlorine Feed System Unit Cost Curve	4-16
4-12	Standby Generator Unit Cost Curve	4-17
4-13	Standby Generator Construction Cost Curve	4-18

**SOUTHERN STATES UTILITIES
ECONOMY OF SCALE****LIST OF FIGURES**

<u>Figure No.</u>	<u>Title</u>	<u>Page No.</u>
5-1	Prestressed Concrete GST Unit Cost Curve	5-2
5-2	Prestressed Concrete GST Construction Cost Curve	5-3
5-3	Steel GST Unit Cost Curve	5-5
5-4	Steel GST Construction Cost Curve	5-6
5-5	Chlorine Feed System Unit Cost Curve	5-8
5-6	High Service Pump Unit Cost Curve	5-9
5-7	High Service Pump Construction Cost Curve	5-10
5-8	Hydropneumatic Tank Unit Cost Curve	5-12
5-9	Hydropneumatic Tank Construction Cost Curve	5-13
5-10	Supply Well Unit Cost Curve	5-15
5-11	Supply Well Construction Cost Curve	5-16
5-12	Lime Softening WTP Unit Cost Curve	5-17
5-13	Lime Softening WTP Construction Cost Curve	5-18
5-14	Reverse Osmosis WTP Unit Cost Curve	5-20
5-15	Reverse Osmosis WTP Construction Cost Curve	5-21
6-1	Gravity Sewer Design	6-2
6-2	Gravity Sewer Unit Cost Curve	6-3
6-3	Sewage Pump Station Unit Cost Curve	6-5
6-4	Sewage Pump Station Construction Cost Curve	6-6
6-5	PVC Force Main Unit Cost Curve	6-7
6-6	DIP Force Main Unit Cost Curve	6-8
6-7	PVC Water Main Unit Cost Curve	6-10
6-8	DIP Water Main Unit Cost Curve	6-11

SECTION 1

SECTION 1 INTRODUCTION

1.1 BACKGROUND

Individuals, companies, corporations, and institutions are all consumers. All purchase goods and services of others that are necessary to meet individual needs or supply materials and equipment necessary to produce a product that will be sold to others at a profit. In the case of the individual, consider a trip to the grocery store. The objective is to procure maximum food and supplies at the least cost. The way to optimize the purchase is by buying in bulk. In this way, a commodity is purchased for a lower unit price and the time before the next trip to the supermarket is maximized.

When a profit motive is involved, as is the case of a company or corporation, the market necessity of keeping operating costs low and profits high dictate that materials and goods be purchased at the lowest price possible. Most often, this is achieved by purchasing in bulk quantity. In this way, goods are procured at a lower unit price. Costs are thus kept low and/or profits are maximized, depending on market conditions.

Institutions, which provide services to the public, have an obligation to minimize costs and maximize services. Purchasing agents are usually astute at maximizing procurement of goods at a minimum price. This is accomplished through competitive bidding of bulk purchases.

This familiar everyday concept loosely known as "power buying" or "bulk purchases" is actually an economy of scale. An economy of scale exists when the unit cost decreases with size or amount purchased. In consumer products, economies of scale exist primarily due to manufacturer savings in packaging and handling. In many consumer situations, there exists an optimum point where the relative maximum economy of scale is achieved and beyond that point, the unit price of the product remains nearly constant. This would be known as an inflection point and it marks the range between the areas of increasing economy of scale and decreasing economy of scale. Provided one could use the commodity in a reasonable period of time, the most cost-effective purchase of the commodity would be made for the volume or quantity with the lowest unit price.

Economies of scale exist in the construction industry. For instance, a contractor who has just successfully bid two separate projects which utilize the same materials, such as blocks, will obtain a lower price by purchasing such material in a larger quantity and at a lower unit cost. Perhaps he made a calculated risk and won the projects with this strategy or will simply maximize his profit from the two projects. Economies of scale in construction are also maximized by elimination of "soft" costs. There are costs associated with engineering, permitting, contractor mobilization, building permit costs, etc. In the example above, if the two projects were within close proximity, the contractor would be able to bid lower mobilization costs for each project as a strategy for winning the jobs. If he won both projects, he would be moving men and material to essentially the same location, thus reducing his cost. If both projects were for the same owner, it would be to the owner's advantage to design, permit, bid, and construct the projects as a single project in which he would then certainly reap the financial benefits by obtaining an overall lower price for the same quantity of work performed.

The utility industry provides necessary services to the public. In order to meet the public need, it engages in the procurement of equipment, material, and construction services. Water and wastewater treatment, collection, and distribution systems consist of discrete components such as wells, tanks, pumps, etc., which, when combined together in proper proportion, serve the public need as a system with an overall reliable capacity. Upon the need for expansion of plant capacity, the utility must consider savings that would be derived through building fewer larger units rather than smaller multiple units. The prudent sizing and phasing of facilities allows the utility to provide cost-effective service to the public.

1.2 OBJECTIVE

The primary objective of this report is to demonstrate that economies of scale exist for the unit components that comprise water and wastewater facilities. In this light, more capacity can be obtained for a lower unit cost. The second objective is to demonstrate that there exists threshold sizes of unit components. This is the point where the increasing economy of scale ends and the decreasing economy of scale begins. In other words, threshold size is the minimum size component that should be considered due to its value on a cost per capacity basis. In the decreasing economy of scale range, the cost per capacity continues to decrease but at a much lower rate. Therefore, the minimum economic threshold size is the point at which the rate of change of the unit cost begins to decline.

The third objective is to demonstrate that economies of scale are achieved through savings in costs of engineering, mobilization, and permitting on projects in which there are not significant economies of scale in the materials.

1.3 SUMMARY AND CONCLUSIONS

Components and systems reviewed are classified as Wastewater Treatment Facilities, Water Treatment Facilities, and Wastewater Collection/Water Distribution. Economies of scale were found to exist on all unit components and systems. Table 1-1 presents the economic minimum threshold sizes for each component and system.

Such threshold sizes should not be construed or interpreted to mean that significant savings are not achieved above or greater than these values. They should be interpreted as the primary point at which the rate of change of the unit price begins to decrease. Thus, when considering system or component expansions, it is prudent to give serious consideration to construct or procure the component of the threshold size or larger.

The engineering economic considerations of the size of unit to construct are as follows:

- Initial demand of system
- Growth rate of system
- Projected build-out demand
- Useful life of the component
- Rules and Regulations
- Operational Considerations
- Interest rates and rate of inflation

If the initial or current demand of the system is less than the economic minimum threshold size, the selection of size must consider the build-out capacity of the facility and when it will be necessary to expand again, which can be computed using the growth rate. If the build-out demand is beyond the economic threshold size, it follows that phases of construction should be implemented in sizes to fully take advantage of the economy of scale offered.

TABLE 1-1

SOUTHERN STATES UTILITIES
ECONOMY OF SCALE

Treatment Component Threshold Sizes

Component/System	Economic Minimum Threshold Size
WASTEWATER TREATMENT FACILITY	
1) Extended Aeration WWTP	0.25 MGD
2) Contact Stabilization WWTP	0.5 MGD
3) Pos. Displacement Blower	500 scfm
4) Centrifugal Blower	2,000 scfm
5) Tertiary Filters	0.25 MGD
6) Generator	300 KW
WATER TREATMENT FACILITY	
1) Prestressed Concrete GST	600,000 gal.
2) Steel Ground Storage Tank	100,000 gal.
3) High Service Pumps	1,000 gpm
4) Hydropneumatic Tank	10,000 gal
5) 250 ft. Deep Water Supply Well	1,440,000 gpd
6) 500 ft. Deep Water Supply Well	1,440,000 gpd

If build-out is less than the economic minimum size, it follows that it does not make sense to purchase capacity that is not needed. However, in smaller systems and units, there are the factors of operational flexibility and standard sizes to be considered. With small systems, it is often impossible to predict peak demands and loadings. In these cases, special consideration should be given to oversizing to standard sizes to ensure satisfactory service and for environmental protection.

SECTION 2

SECTION 2 METHODOLOGY

2.1 GENERAL

This section details the sources of information for this report; as well as, the method used to construct the unit cost curves.

2.2 SOURCES

In order to give a fair and accurate representation of the costs of constructing water and wastewater systems, information was obtained from many balancing sources. Previous curves were obtained from the United States Environmental Protection Agency (USEPA) and Culp/Wesner/Culp, an engineering firm. Also, quotes were obtained from Florida manufacturers and suppliers. Rounding out the information were bid tabulations from completed construction that took place in the State of Florida.

2.2.1 USEPA

Throughout the years, the United States Environmental Protection Agency (EPA) developed many reports involving the cost of the different components of water and wastewater collection, treatment, disposal, and distribution. The figures presented in these technical reports display the cost of the process versus the capacity (or size) of the component. The curves are typically accompanied by text which explains the function of the cost component and the assumptions made in determining the overall cost. The conversion of the overall cost to unit cost is accomplished by simply dividing the cost by the capacity of the component being studied.

The EPA references used for this study range in years from 1977 to 1984. Therefore, the cost must be updated in order to allow for a present day comparison. The EPA sources that were used are as follows:

- (1) "State of the Art of Small Water Treatment Systems." U.S. Environmental Protection Agency, Office of Water Supply. Washington, D.C., August 1977.

- (2) "The Cost Digest: Cost Summaries of Selected Environmental Control Technologies." U.S. Environmental Protection Agency. Washington, D.C., October 1984.
- (3) "Construction Costs for Municipal Wastewater Treatment Plants: 1973-1978." U.S. Environmental Protection Agency, Facility Requirements Division. Washington, D.C., April 1980.
- (4) "Innovative and Alternative Technology Assessment Manual." U.S. Environmental Protection Agency, Office of Water Programs Operations. Washington, D.C., February 1980.
- (5) "Costs of Wastewater Treatment by Land Application." U.S. Environmental Protection Agency, Office of Water Program Operations. Washington, D.C., June 1975.
- (6) "Construction Costs for Municipal Wastewater Conveyance Systems: 1973-1979." U.S. Environmental Protection Agency, Facility Requirements Division. Washington, D.C., January 1981.
- (7) "Construction Costs for Municipal Wastewater Conveyance Systems: 1973-1977." U.S. Environmental Protection Agency. May 1978.
- (8) "Report on Initial Investment Costs, Operation and Maintenance Costs, and Manpower Requirements for Conventional Wastewater Treatment Plants." U.S. Environmental Protection Agency, Water Quality Office. Black & Veatch, 1971.

2.2.2 Culp/Wesner/Culp

The engineering firm Culp/Wesner/Culp, based in Santa Ana, California, produced water treatment, transmission, and distribution cost reports for the United States Environmental Protection Agency. They also produced an independent water component cost summary. For each component, the overall cost versus capacity is illustrated along with the operation and maintenance costs. As with the EPA generated curves, the Culp/Wesner/Culp curves were adjusted using ENR indexes to the present day cost. Also, a detailed explanation of each

component and the assumptions made to determine the cost are both included in each section. The Culp/Wesner/Culp sources that were used are as follows:

- (1) "Estimating Water Treatment Costs, Volume 2, Cost Curves Applicable to 1 to 200 MGD Treatment Plants." Gumerman, R.C., et al. (Culp/Wesner/Culp) Santa Ana, CA, August 1979. (Produced for USEPA).
- (2) "Estimating Water Treatment Costs, Volume 3, Cost Curves Applicable to 2,500 gpd to 1 MGD Treatment Plants." Hansen, S.P., et al. (Culp/Wesner/Culp) Santa Ana, CA, August 1979. (Produced for USEPA).
- (3) "Small Water System Treatment Costs." Gumerman, R.C., et al. (Culp/Wesner/Culp) Santa Ana, CA, August 1986.

2.2.3 Manufacturers

In order to establish a contemporary cost for the components of water and wastewater systems, quotations from Florida Manufacturers and sales representatives were obtained for all the equipment included in this study. At least two manufacturers' quotes were obtained for each component and the overall cost for the component was taken as the average of the two. This allows the high, and low quotes to form a solid representation. The costs are uniform and comparable due to the usage of state sales representatives. These sales representatives and manufacturers who provided the information are as follows:

- (1) Package Wastewater Treatment Plants
 - a. DAVCO, Davis Industries, Inc.
1828 Metcalf Avenue
Thomasville, Georgia
 - b. Sanitaire, via Moss/Kelley, Inc.
10100 West Sample Road
Coral Springs, Florida

(2) Blowers

- a. Hoffman, via Jacobs Group
160 Scarlet Blvd.
Oldsmar, Florida 34677
- b. Sutorbilt, via Jacobs Group
160 Scarlet Blvd.
Oldsmar, Florida 34677

(3) Wastewater Treatment Filters

- a. DAVCO, Davis Industries, Inc.
1828 Metcalf Avenue
Thomasville, Georgia
- b. Infilco-Degremont, via Moss/Kelley, Inc.
10100 West Sample Road
Coral Springs, Florida

(4) Chlorination Feed Systems

- a. Capital Control, via Blankenship & Associates
3004 Konarwood Court
Oviedo, Florida
- b. Wallace & Tiernan, via Heyward, Inc.
1865 North Semoran Boulevard
Winter Park, Florida

(5) Standby Generator Sets

- a. Ringhaver Equipment Company
9901 Ringhaver Drive
Orlando, Florida 32824

- b. Cummins Southeastern Power, Inc.
4820 North Orange Blossom Trail
Orlando, Florida 32810

(6) Ground Storage Tanks (Steel and Prestressed Concrete)

- a. The Crom Corporation, Prestressed Composite Tanks
250 S.W. 36th Terrace
Gainesville, Florida
- b. PRECON Corporation, Prestressed Concrete Tanks
115 S.W. 140th Terrace
Newberry, Florida
- c. Florida Aquastore, Water & Wastewater Technologies
2650 North Military Trail
Boca Raton, Florida

(7) High Service Pumps

- a. Worthington, via Barney's Pumps, Inc.
3907 Highway 98 South
Lakeland, Florida
- b. Peerless Pump Company
811 North 50th Street
Tampa, Florida

(8) Hydropneumatic Tanks

- a. Hydro-Air Systems, Inc.
P.O. Box 585654
Orlando, Florida

- b. Modern Welding Company, Inc.
1801 Atlanta Avenue
Orlando, Florida

(9) Vertical Turbine Pumps

- a. Peerless Pump Company
811 50th Street North
Tampa, Florida
- b. Peabody-Floway, via Flanagan-Metcalf & Associates, Inc.
6708 Benjamer Road
Tampa, Florida

(10) Sewage Pump Stations (Precast items and Pumps)

- a. Taylor Precast
P.O. Box 369
Deland, Florida 32721
- b. Gorman Rupp Pumps, via Blankenship & associates
3004 Konarwood Court
Oviedo, Florida
- c. Flygt Pumps, via Ellis K. Phelps & Company
2152 Sprint Boulevard
Apopka, Florida

(11) PVC and Ductile Iron Piping

- a. B&H Sales, Inc.
11114 Satellite Boulevard
Orlando, Florida
PVC force main, water main, and gravity sewer.

- b. CertainTeed
750 T.E. Suedesford Road
Valley Forge, PA., 19482
PVC force main, water main, and gravity sewer.

- c. American Cast Iron Pipe Company
2301 Maitland Center Parkway
Maitland, Florida
DIP force main, water main, and gravity sewer.

- d. Mitchell & Stark Construction Co., Inc.
Naples, Florida
Pipe pressure test, T.V. test, and disinfection.

2.2.4 Bid Tabulations

As a final source of information, bid tabulations from existing projects were gathered. The projects used in this analysis are all located in the State of Florida. The actual bids were obtained using "The Bid Reporter," which prints monthly Florida listings of projects to be constructed. Further information was obtained through the Hartman & Associates, Inc. project cost database. The HAI database contains bid tabulations, schedule of values and summary of work for numerous utility projects. Both sources contain project data for approximately the past five (5) to ten (10) years. Therefore, the prices, which are updated using the ENR construction costs index, present current indices of the cost of water and wastewater system components.

2.3 CURVE DESIGN SUMMARY

This section provides a detailed description of the method used to create the final unit cost curves for water and wastewater treatment systems. For water, curves are provided for the components of the collection, treatment, and distribution systems. The collection, treatment and disposal components were studied for wastewater systems.

2.3.1 Updating Process

The various sources of data utilized in this study, provided cost information at different time periods over the previous 25 years. In order for these values to be comparable, they were indexed. In other words, the costs must be updated to the time of this study, which is June, 1995. The costs are updated using established cost indexes. The two (2) indexes used during this study are the Engineering News Record (ENR) and The Handy-Whitman Index of Public Utility Construction Costs. In order to update the costs, original costs were multiplied by the ratio of the June, 1995 index number to the original index number. This cost updating method is shown below.

$$\text{June 1995 Cost} = \text{Original Cost} * \frac{(\text{June 1995 Index})}{(\text{Original Index})}$$

2.3.2 Design Considerations

To construct reliable cost curves, more than one (1) set of values were used for each component. However, these values are not comparable unless they involved the same design considerations. Therefore, the manufacturers and sales representatives were given the same criteria with which to evaluate the cost. Also, when the manufacturer's values were used in combination with the Environmental Protection Agency or Culp/Wesner/Culp curves, the manufacturer's values were adjusted to include the identical components as found in the source curves.

Some of the commonly added costs were electrical, piping, sitework, and installation. These components were adjusted by percentage on a case-by-case basis to reflect the different needs of the various components.

2.3.3 Finalization

Once the cost data was normalized, the values were compared and plotted. By plotting the values, the relationships of the cost values versus capacity are illustrated. So for a construction cost curve, which is the total cost for installation, the economy of scale is difficult to visualize. In order to see the economy of scale clearly, the cost curves were transformed into unit cost curves. These curves display the cost per unit on the y-axis and the capacity or other size measurement on the x-axis. For example, the unit cost curve involves cost in dollars per gallon (\$/gal) versus

gallon capacity for such components as: treatment plants, storage facilities, chlorine feed facilities, hypopneumatic tanks, water supply wells, etc. Other unit cost curve components are a follows:

- dollars per gpm (\$/gpm) for pumps and pump stations
- dollars per lot (\$/lot) for gravity sewers
- dollars per foot (\$/Ft) for force and water mains
- dollars per scfm (\$/scfm) for blowers

In this format, the graphs show that cost per unit capacity decreases with increased capacity.

SECTION 3

SECTION 3 ANALYSIS

3.1 THRESHOLD SIZING

This section discusses the reasons behind the design of water and wastewater systems with respect to sizing. The factors affecting the size of certain treatment systems are cost, regulations, and the health and safety of those served. There are plant capacities which are established minimums.


3.1.1 Inflection Points

In the water and wastewater unit cost curves of this study, the economy of scale was apparent in all cases. However, the manner in which the economy of scale is displayed differs between two styles of graphical representation.

The first case, displayed in Figure 3-1, is best represented by the prestressed ground storage tank unit cost curve. The curve is basically an exponential type curve where the low capacity yields an extremely high unit cost and the high capacity has leveled out with a much lower unit cost. The beginning of the curve displays an increasing economy of scale. In other words, at the smaller capacities, the economy of scale is very large with each increase in capacity. The change in unit cost in this range is so significant that it makes it generally undesirable to design in this range to the left of the point of inflection. The point of inflection occurs when the slope of the curve begins to level out with respect to the X-axis. This is the point where the component design becomes economically feasible with respect to smaller and larger capacity options. Following the point of inflection, the economy of scale begins to decrease. Even though the economy of scale still exists in this range, the unit cost change between sizes is much less. However, the savings between capacities in this area of the curve remain very significant. This is a section of the curve where capacity options are not as obvious and the monetary savings should be balanced together with other factors.

The other type of unit cost curve, Figure 3-2, is well represented by the potable water well curve. In this curve, the unit cost appears to steadily decline with respect to the capacity plotted on the X-axis. The relationship, however, is identical to that of Figure 3-1. The differing factor is that

Ground Storage Tanks Prestressed Concrete



- Notes:
- 1) Costs include complete tank, concrete floor, prestressed wall, free-span concrete dome, aluminum interior and exterior ladders, vents, precast overflows, painting, and installation. These costs were obtained directly from manufacturers' quotes.
 - 2) Includes 5% piping, 0% electrical, and 5% sitework.
 - 3) Costs are based on the June 1995, ENR Index = 5433.

EXHIBIT _____
 PAGE 26 OF 264
 (5-21-95)


FIGURE 3-1



HARTMAN & ASSOCIATES, INC.
 engineers, hydrogeologists, surveyors & management consultants
 201 EAST PINE STREET - SUITE 1000 - ORLANDO, FL 32801
 TELEPHONE (407) 838-3855 - FAX (407) 838-3790

INCREASING AND DECREASING ECONOMIES OF SCALE

Potable Water Wells



250' deep 500' deep

- Notes: 1) Vertical turbine pump, cement grout, black steel well and surface casing, well screen, and well development costs from manufacturers' quotes and bid tabulations.
- 2) Includes 10% electrical, 15% well head, and 30% labor.
- 3) Costs are based on the June 1995, ENR Index = 5433.



the values in this curve are plotted on a logarithmic scale, due to the large capacity range. This unit cost curve presents the same economy of scale relationship as Figure 3-1 when plotted on a linear scale; however, determining individual values from the linear plots is more difficult. Therefore, to facilitate use of the graph, the data was plotted on a log-log axis.

3.1.2 Economic Minimum Threshold Sizes

The economic **minimum** threshold sizes were determined mathematically. The second derivatives of the unit cost **curve** equations were plotted to determine the domain value at which the rate of change of the slope of the unit cost curve equals zero, or no change. The majority of curves were modeled using third order or higher polynomials. The solution of the second derivative is valid for the range considered and produces an inflection point. An example of the polynomial equation and the derivatives are as follows:


$$\begin{array}{lll} \text{Polynomial equation:} & f(x) & = & a_1 + a_2x + a_3x^2 + a_4x^3 + a_5x^4 \\ \text{First derivative:} & f'(x) & = & a_2 + 2a_3x + 3a_4x^2 + 4a_5x^3 \\ \text{Second derivative:} & f''(x) & = & 2a_3 + 6a_4x + 12a_5x^2 \end{array}$$

Some cost curves were modeled using power functions in which a plot of the second derivative does not cross the X-axis. The plot however is more pronounced and clearly indicates the inflection point. An example of the power function equation and its applicable derivatives are as follows

$$\begin{array}{lll} \text{Power equation:} & f(x) & = & a_1x^{b_1} \\ \text{First derivative:} & f'(x) & = & (b_1)(a_1)x^{b_1-1} \\ \text{Second derivative:} & f''(x) & = & (a_1b_1)(b_1-1)x^{b_1-2} \end{array}$$

As an example, Figure 3-3 is a plot of the second derivative of the function for steel ground storage tanks. The plot crosses the X-axis at 100,000 gallons which indicates that the inflection point for rate of change of the unit cost occurs at 100,000 gallons. This point establishes the end of the domain for increasing economy of scale.

Potable Water Wells



250' deep 500' deep

- Notes: 1) Vertical turbine pump, cement grout, black steel well and surface casing, well screen, and well development costs from manufacturers' quotes and bid tabulations.
 2) Includes 10% electrical, 15% well head, and 30% labor.
 3) Costs are based on the June 1995, ENR Index = 5433.

FIGURE
3-2



HARTMAN & ASSOCIATES, INC.

engineers, hydrogeologists, surveyors & management consultants

201 EAST PINE STREET - SUITE 1000 - ORLANDO, FL 32801
 TELEPHONE (407) 839-3055 - FAX (407) 839-3790

ECONOMY OF SCALE ON LOGARITHMIC AXES

PAGE 27 OF 284

UNIVERSITY

the values in this curve are plotted on a logarithmic scale, due to the large capacity range. This unit cost curve presents the same economy of scale relationship as Figure 3-1 when plotted on a linear scale; however, determining individual values from the linear plots is more difficult. Therefore, to facilitate use of the graph, the data was plotted on a log-log axis.

3.1.2 Economic Minimum Threshold Sizes

The economic minimum threshold sizes were determined mathematically. The second derivatives of the unit cost curve equations were plotted to determine the domain value at which the rate of change of the slope of the unit cost curve equals zero, or no change. The majority of curves were modeled using third order or higher polynomials. The solution of the second derivative is valid for the range considered and produces an inflection point. An example of the polynomial equation and the derivatives are as follows:

$$\begin{array}{llll}
 \text{Polynomial equation:} & f(x) & = & a_1 + a_2 x + a_3 x^2 + a_4 x^3 + a_5 x^4 \\
 \text{First derivative:} & f'(x) & = & a_2 + 2a_3 x + 3a_4 x^2 + 4a_5 x^3 \\
 \text{Second derivative:} & f''(x) & = & 2a_3 + 6a_4 x + 12a_5 x^2
 \end{array}$$


Some cost curves were modeled using power functions in which a plot of the second derivative does not cross the X-axis. The plot however is more pronounced and clearly indicates the inflection point. An example of the power function equation and its applicable derivatives are as follows

$$\begin{array}{llll}
 \text{Power equation:} & f(x) & = & a_1 x^{b_1} \\
 \text{First derivative:} & f'(x) & = & (b_1)(a_1) x^{b_1-1} \\
 \text{Second derivative:} & f''(x) & = & (a_1 b_1)(b_1-1) x^{b_1-2}
 \end{array}$$

As an example, Figure 3-3 is a plot of the second derivative of the function for steel ground storage tanks. The plot crosses the X-axis at 100,000 gallons which indicates that the inflection point for rate of change of the unit cost occurs at 100,000 gallons. This point establishes the end of the domain for increasing economy of scale.

Ground Storage Tanks

Steel



Manufacturers
—□—

Notes: 1) Polynomial equation for the Steel GST's unit cost curve is the following:
 $f(x) = 3.565 + (-9.337E-5)X + (1.3717E-9)X^2 + (-1.0034E-14)X^3 + (3.5115E-20)X^4 + (-4.6878E-26)X^5$

2) The second derivative of the Steel GST unit cost polynomial is as follows:
 $f''(x) = 2.743E-9 + (-6.02E-14)X + (42.138E-20)X^2 + (-93.756E-26)X^3$

FIGURE
3-3



HARTMAN & ASSOCIATES, INC.
 engineers, hydrogeologists, surveyors & management consultants
 201 EAST PINE STREET - SUITE 1000 - ORLANDO, FL 32801
 TELEPHONE (407) 838-3855 - FAX (407) 838-3780

STEEL GST INFLECTION POINT

3.13 Curve Fitting

The curves determined to represent the manufacturers' and EPA cost curve data were generated with the use of either the Sigma Plot program by ^oJardel Scientific or the Hydrology and Water Quality Control course accompanied programs produced by ^oJohn Wiley & Sons. The Sigma Plot program was used mainly to determine polynomial fits for the data, while the other program determined the equations for the data better represented by the power function equation. In all cases, the equations were determined to be the best fit for the given data.

3.1.4 Regulatory

For most instances, regulations do not affect the sizing of water and wastewater systems. Usually, the type of disposal or source of supply determine the stipulations on the plant type or size. However, there are occurrences where size regulates cost. The water supply wells must be double (one standby) above 150 connections, and over 150 connections necessitates an Auxiliary Power Supply.

SECTION 4

SECTION 4 WASTEWATER TREATMENT PLANT FACILITIES

4.1 EXTENDED AERATION PACKAGE WWTP


The extended aeration treatment process is a version of the activated sludge process in which the detention time is approximately 24 hours. The extended detention time will require a larger volume than most activated sludge processes, which in turn will raise the costs. The costs do, however, display an economy of scale over the entire range of capacities. The unit cost of the extended aeration package plants, Figure 4-1, is a display of dollars per gallon of capacity versus gallon per day capacity. In this form, the economy of scale will be visible if the unit cost decreases as the capacity increases.

The unit cost curve of the package extended aeration plant shows a considerable economy of scale from the 0.01 MGD to the 1.0 MGD limits of the graph. The unit cost steadily decreases in a straight line from approximately \$7/gallon at 0.01 MGD to \$0.7/gallon at 1.0 MGD. The straight line relationship of the unit cost translates into considerable savings with increased sizing.

The curves in Figure 4-2 represent the construction cost as a function of package extended aeration treatment plant capacity. By examining the costs as they are related to capacity, the economy is apparent. For instance, the cost of a 500,000 gallon per day package plant is approximately \$465,000, and the cost of a 1,000,000 gallon per day package plant is approximately \$710,000. Therefore, in order to expand a 500,000 gallon per day facility to a 1,000,000 gallon per day plant, the cost would be approximately \$930,000. The design of the 1.0 MGD plant originally would have saved approximately \$220,000 overall. The savings would be greater if contractor mobilization, engineering, and permitting costs were considered.

The unit cost and construction cost curves were developed using an Environmental Protection Agency cost curve and manufacturers' quotations. The quotes from the manufacturers included the tankage (ring steel with internal clarifier), concrete slabs, sitework, electrical, piping, blowers and installation. To normalize these quotes with the EPA curve, a chlorination feed system cost had to be added to the overall cost. The chlorination feed system cost was obtained through other manufacturers' quotations. From this point, the two (2) curves are equivalent and can be compared.

Package Extended Aeration WWTP



EPA Manual MFR Data
 ----- ○.....

- Notes:
- 1) Costs include materials, electrical, piping, blowers, grading, installation, chlorination feed system, and conc. slab.
 - 2) Costs exclude land, engineering, fencing, paving, drainage lighting, and building facilities.
 - 3) All costs obtained from manufacturers' quotes and EPA cost curve.
 - 4) Costs are based on June 1995, ENR Index = 5433.


FIGURE 4-1



HARTMAN & ASSOCIATES, INC.
 engineers, hydrogeologists, surveyors & management consultants
 201 EAST PINE STREET - SUITE 1000 - ORLANDO, FL 32801
 TELEPHONE (407) 830-3655 - FAX (407) 839-3790

EXTENDED AERATION UNIT COST CURVE

Package Extended Aeration WWTP



EPA Manual MFR Data
 *○.....

- Notes:
- 1) Costs include materials, electrical, piping, blowers, grading, installation, chlorination feed system, and conc. slab.
 - 2) Costs exclude land, engineering, fencing, paving, drainage, lighting, and building facilities.
 - 3) All costs obtained from manufacturers' quotes and EPA cost curves.
 - 4) Costs are based on June 1995, ENR Index = 5433.

80-100

FIGURE 4.2



HARTMAN & ASSOCIATES, INC.
 engineers, hydrogeologists, surveyors & management consultants
 201 EAST PINE STREET - SUITE 1000 - ORLANDO, FL 32801
 TELEPHONE (407) 830-3855 - FAX (407) 830-3700

EXTENDED AERATION CONSTRUCTION COST CURVE

The extended aeration package treatment plant costs exclude the costs of land, engineering, paving, grading, drainage, lighting, fencing, and building facilities.

4.2 CONTACT STABILIZATION PACKAGE WWTP

The contact stabilization is a version of the activated sludge process that requires an average detention time of between 4 and 6 hours. When compared with the extended aeration process, the contact stabilization package plant will require less volume due to the considerable difference in detention time. Even though the overall cost differs, the economies of scale are still very evident in the contact stabilization package treatment plants. These costs versus capacity relationships are displayed on Figures 4-3 and 4-4, which are the unit cost and construction cost curves, respectively.


The unit cost curve, Figure 4-3, is a presentation of the relationship between the unit cost, dollars per gallon versus the capacity, gallons per day. From 0.05 MGD, the unit cost curve shows a solid economy of scale. Even though the values of the Environmental Protection Agency and the manufacturers are not identical, their relationship is identical. They both show a very similar economy of scale relationship that stretches from a little over \$3/gallon to approximately \$0.5/gallon.

The straight line decreasing aspect of the curve translates into considerable savings with the increase in design capacity. This relationship is further solidified when the capacities and unit costs are plotted on linear axes.

In Figure 4-4, the considerable savings in the sizing of package contact stabilization plants is noticeable. For instance, using the manufacturers' cost values, the cost to construct a 500,000 gallon per day contact stabilization plant would be approximately \$375,000. On the other hand, the cost to build a 1,000,000 gallon per day treatment plant would be about \$525,000. Therefore, the cost to build the smaller 500,000 gallon plant and then expand it by another 500,000 gallons would be \$750,000. By comparing this cost to the \$525,000 cost for the larger plant, a savings of \$225,000 is realized for the addition of 500,000 gallons of capacity. This same trend is also represented by the EPA cost curve.

The unit cost and construction cost curves were created using values obtained from the Environmental Protection Agency and manufacturers' quotations. The manufacturers' costs

Package Contact Stabilization WWTP



EPA Manual MFR Data
 —*— O.....

- Notes: 1) Costs include materials, electrical, piping, blowers, grading, installation, chlorination feed system, and conc. slab.
 2) Costs exclude land, engineering, fencing, paving, drainage, lighting, and building facilities.
 3) All costs obtained from manufacturers' quotes and EPA cost curves.
 4) Costs are based on June 1995, ENR Index = 5433.

50-


FIGURE
4-3



HARTMAN & ASSOCIATES, INC.
 engineers, hydrogeologists, surveyors & management consultants
 201 EAST PINE STREET - SUITE 1000 - ORLANDO, FL 32801
 TELEPHONE (407) 630-3000 - FAX (407) 630-3700

**CONTACT STABILIZATION UNIT
 COST CURVE**

Package Contact Stabilization WWTP



EPA Manual MFR Data
 —*— ○.....

- Notes: 1) Costs include materials, electrical, piping, blowers, grading, installation, chlorination feed system, and conc. slab.
 2) Costs exclude land, engineering, fencing, paving, drainage, lighting, and building facilities.
 3) All costs obtained from manufacturers' quotes and EPA cost curves.
 4) Costs are based on June 1995, ENR Index = 5433.

FIGURE 4-4



HARTMAN & ASSOCIATES, INC.
 engineers, hydrogeologists, surveyors & management consultants
 201 EAST PINE STREET - SUITE 1000 - ORLANDO, FL 32801
 TELEPHONE (407) 830-3050 - FAX (407) 830-3790

CONTACT STABILIZATION CONSTRUCTION COST CURVE

included the plant itself, concrete slabs, site work, electrical, piping, blowers, and installation. In order to be able to compare these values with the EPA cost curve, a chlorination feed system was added using other manufacturers' quotations.

The package contact stabilization treatment plants costs exclude land, engineering, paving, grading, drainage, lighting, fencing, and building facilities.


4.3 BLOWERS

Blowers have an important role in supplying air to different parts of a treatment plant for process purposes and for airlifts in smaller facilities. Two common types of blowers used in the diffused air systems are centrifugal and positive displacement blowers.

The positive displacement blowers are more common in the lower standard cubic foot per minute (scfm) range than their centrifugal counterparts. As shown in Figure 4-5, the unit costs of the positive displacement blowers show an increasing economy of scale up to about 500 scfm. At this point, the economy of scale is decreasing. So the point of inflection lies at 500 scfm. To illustrate the benefit of designing a blower at 500 scfm or larger, the blower cost curve, Figure 4-6, will be used. The 500 scfm positive displacement blower costs approximately \$5,500 and a 100 scfm blower costs about \$2,750. Therefore, if the 100 scfm blower will need to be expanded to 500 scfm, the overall cost will easily exceed the original cost of the 500 scfm blower. By expanding with a 400 scfm blower, the total cost of the two (2) blowers is approximately \$7,750, which is about \$2,250 more expensive than one (1) 500 scfm blower.

For the centrifugal blowers, the higher capacity installations are more common. The range of blowers that are presented in the unit cost curve, Figure 4-7, are between 500 scfm and 4,500 scfm. The curve experiences an increasing economy of scale between 500 scfm and 2,000 scfm, where the point of inflection lies. However, the economy of scale does not decrease at a very rapid rate thereafter. Therefore, considerable economies of scale are apparent throughout the entire range. For instance, by using Figure 4-8, the blower cost curve, the economies of scale are detectable. A 2,000 scfm blower costs about \$22,000, and a 4,000 scfm blower costs approximately \$34,000. Therefore, one (1) 4,000 scfm blower is approximately \$10,000 less than two (2) 2,000 scfm blowers.

Positive Displacement Blowers



- Notes:
- 1) All costs obtained from manufacturer's quotes.
 - 2) Costs include blower, TEFC motor, steel base, silencers, relief valve, pressure gauge, and check valve.
 - 3) Costs are based on June 1995, ENR Index = 5433.

20-1000


FIGURE
4-5



HARTMAN & ASSOCIATES, INC.
 engineers, hydrogeologists, surveyors & management consultants
 201 EAST PINE STREET - SUITE 1000 - ORLANDO, FL 32801
 TELEPHONE (407) 830-3050 - FAX (407) 830-3700

**POSITIVE DISPLACEMENT BLOWER UNIT
 COST CURVE**

Positive Displacement Blowers



- Notes: 1) All costs obtained from manufacturer's quotes.
 2) Costs include blower, TEFC motor, steel base, silencers, relief valve, pressure gauge, and check valve.
 3) Costs are based on June 1995, ENR Index = 5433.



HARTMAN & ASSOCIATES, INC.


engineers, hydrogeologists, surveyors & management consultants

201 EAST PINE STREET - SUITE 1008 - ORLANDO, FL 32801
 TELEPHONE (407) 838-3855 - FAX (407) 838-3790

**POSITIVE DISPLACEMENT BLOWER CONSTRUCTION
 COST CURVE**

FIGURE
4-6

Centrifugal Blowers



- Notes: 1) All costs obtained from manufacturer's quotes.
 2) Costs include a centrifugal blower and TEFC motor.
 3) Costs are based on June 1995, ENR Index = 5433.

10-1000


FIGURE 4-7



HARTMAN & ASSOCIATES, INC.
 engineers, hydrogeologists, surveyors & management consultants
 301 EAST PINE STREET - SUITE 1000 - ORLANDO, FL 32801
 TELEPHONE (407) 830-3955 - FAX (407) 830-3790

CENTRIFUGAL BLOWER UNIT COST CURVE

Centrifugal Blowers



- Notes: 1) All costs obtained from manufacturer's quotes.
 2) Costs include blower and TEFC motor.
 3) Costs are based on June 1995, ENR Index = 5433.

06-1000

FIGURE
4-8



HARTMAN & ASSOCIATES, INC.
 engineers, hydrogeologists, surveyors & management consultants
 201 EAST POKE STREET - SUITE 1000 - ORLANDO, FL 32801
 TELEPHONE (407) 830-3055 - FAX (407) 830-3790

**CENTRIFUGAL BLOWER CONSTRUCTION
 COST CURVE**

The unit cost and blower cost curves were created using manufacturers' cost quotations. The positive displacement blower includes the blower, TEFC motor, steel base, silencers, relief valve, pressure gauge, and check valve. The centrifugal blowers include only the blower and TEFC motor.

4.4 FILTERS

Filters are typically used for the tertiary treatment of wastewater. These filters help to remove the total suspended solids left in the effluent, and in so doing, allow the effluent to be available for reuse. The two (2) types of filters that were examined for this study were the standard gravity filter for flows less than 0.15 MGD, and traveling bridge filters for flows greater than 0.15 MGD.


The unit cost curve, Figure 4-9, shows the unit cost, dollars per gallon, versus the capacity of wastewater treated, in million gallons per day (MGD). From 0.05 MGD to 1.0 MGD, the gravity and traveling bridge filters experience a considerable economy of scale. The gravity and traveling bridge filter combination experiences a threshold at about 0.25 MGD. As can be shown from Figure 4-10, the economic savings with increased capacity are substantial. For \$50,000 a gravity filter will be of the capacity to treat 50,000 gallons per day and \$85,000 a gravity filter with 150,000 gallon per day treatment capacity can be purchased.

The unit cost and construction cost curves for the wastewater treatment filters were constructed using quotations of costs from manufacturers. The costs included the filter, media, 15 percent for piping, 15 percent for electrical, 5 percent for sitework, 5 percent for the concrete slab, and 20 percent for installation. These percentages were applied to the material subtotal and summed to determine the total cost.

4.5 CHLORINATION

The chlorination of wastewater is commonly accomplished using gas chlorinators. The gas is fed to the chlorinators from 150 pound or 1 ton storage cylinders. The size of the storage cylinders is dependent on the quantity of wastewater to be treated. Typically, at a dosage of 10 milligrams per liter, the 150 pound, storage cylinders are used at treatment plant flows of up to 1 MGD. This means that the 1 ton cylinders are used for flows above this point. The costs of the feed system fluctuates with the size of the storage cylinders.

Wastewater Treatment Filters



Gravity Filter Traveling Bridge

- Notes:
- 1) Filter and media costs obtained from manufacturers' quotes.
 - 2) Includes 15% piping, 15% electrical, 5% sitework, 20% installation, and 5% for the concrete slab.
 - 3) Costs are based on June 1995, ENR Index = 5433.

FIGURE 4-9




HARTMAN & ASSOCIATES, INC.
 engineers, hydrogeologists, surveyors & management consultants
 201 EAST PINE STREET - SUITE 1000 - ORLANDO, FL 32801
 TELEPHONE (407) 838-3855 - FAX (407) 838-3790

TERTIARY TREATMENT FILTER UNIT COST CURVE



Wastewater Treatment Filters



Gravity Filter Traveling Bridge

- Notes:
- 1) Filter and media costs obtained from manufacturers' quotes.
 - 2) Includes 15% piping, 15% electrical, 5% sitework, 20% installation, and 5% for the concrete slab.
 - 3) Costs are based on June 1995, ENR Index = 5433.

FIGURE
4-10



HARTMAN & ASSOCIATES, INC.
engineers, hydrogeologists, surveyors & management consultants
201 EAST PINE STREET - SUITE 1000 - ORLANDO, FL 32801
TELEPHONE (407) 838-3855 - FAX (407) 838-3798

**TERTIARY TREATMENT FILTER CONSTRUCTION
COST CURVE**

The unit cost curve, Figure 4-11, displays an economy of scale throughout the treatment capacities of 0.01 MGD to 5 MGD. This relationship is further emphasized when the components are plotted on linear axes. Where the storage cylinder sizes change, the costs slightly increase; however, the ton cylinder feed systems resume the continuous economy of scale. The overall cost, when compared with treatment plant cost, is a very low percentage. The larger capacity plants will have a much smaller unit cost for chlorine feed systems than the smaller capacity plants.

The chlorination feed equipment curve was constructed using manufacturers' quotations and EPA cost curves. Included in the cost of both size systems are dual chlorinators, dual scales, a gas detector, an alarm panel, a vacuum switch, booster pump, housing, hoists, 20% electrical, 15% piping, 20% installation, and no sitework.


4.6 STANDBY GENERATOR SETS

The standby generator sets are used for emergency power situations for water and wastewater facilities. The generator packages studied for the economy of scale project consisted of a packaged diesel electric unit with base, control/monitoring panel, and a unit mounted radiator cooling system. The generator prices do not include cost adjustments for land, engineering, installation, fencing, building facilities, and design contingencies.

In general, the cost curves of Figure 4-12 and 4-13, present a significant economy of scale relationship. Although the relationship is not readily apparent in the construction cost curve, Figure 4-13, the unit cost curve shows a drastic change in unit prices with increase Kilowatt (kW) capacity. The unit prices begin with \$1,088/KW at 8 KW capacity and reach values ranging between \$124/KW and \$153/KW between 300 KW and 1,500 KW capacities. This relationship places an importance on the overdesign of electrical equipment. The underdesign of a standby generator is both detrimental to public health and safety and costly to the customer.

The graphical presentations were formulated using manufacturers' quotations for the various standard sizes of standby generator packages.

Chlorine Feed Systems Wastewater Treatment



EPA Curve Manufacturers

- Notes:
- 1) Gas chlorination unit with 10 mg/l feed rate at capacity.
 - 2) Dual chlorinators w/ switchover, dual scales, gas detector, alarm panel, vacuum switch, booster pump, housing, and hoists all are included in the manufacturers' quotations.
 - 3) Includes 20% electrical, 15% piping, and 20% installation costs.
 - 4) Costs are based on June 1995, ENR Index = 5433.

400-7100-1-51

FIGURE
4-11



HARTMAN & ASSOCIATES, INC.


engineers, hydrogeologists, surveyors & management consultants

201 EAST PINE STREET - SUITE 1000 - ORLANDO FL 32801
 TELEPHONE (407) 839-3955 - FAX (407) 839-3790

**CHLORINE FEED SYSTEM UNIT
COST CURVE**

Standby Generator Sets

Diesel System



- Notes: 1) Values obtained from manufacturer's quotations.
2) Costs include a packaged diesel electric set with base, a unit mounted radiator cooling system, and a control panel.
3) Costs are based on December 1995, ENR Index = 5471.



HARTMAN & ASSOCIATES, INC.


engineers, hydrogeologists, surveyors & management consultants

201 EAST PINE STREET - SUITE 1000 - ORLANDO, FL 32801
TELEPHONE (407) 838-3653 - FAX (407) 838-3700

**STANDBY GENERATOR UNIT
COST CURVE**

FIGURE
4-12

Standby Generator Sets Diesel System



- Notes:
- 1) Values obtained from manufacturer's quotations.
 - 2) Costs include a packaged diesel electric set with base, a unit mounted radiator cooling system, and a control panel.
 - 3) Costs are based on December 1995, ENR Index = 5471.

FIGURE
4-13



HARTMAN & ASSOCIATES, INC.

engineers, hydrogeologists, surveyors & management consultants

201 EAST PINE STREET - SUITE 1000 - ORLANDO, FL 32801
TELEPHONE (407) 838-3885 - FAX (407) 838-3790

**STANDBY GENERATOR CONSTRUCTION
COST CURVE**

SECTION 5

SECTION 5 WATER TREATMENT PLANT FACILITIES

5-1 PRESTRESSED CONCRETE GROUND STORAGE TANKS

In the State of Florida, prestressed concrete ground storage tanks are most often above-ground. The ground storage tanks typically store water before pumping to the distribution system. Also, the storage tank is usually fitted with an aeration unit on top of the tank which is for the removal of hydrogen sulfide. For this study, the ground storage tanks will be designed as above and will be represented by a unit cost curve and a construction cost curve.


The unit cost curve, Figure 5-1, consists of a plot of the unit cost, dollars per gallon, of the ground storage tanks versus the capacity of the tank. The curve displays a strong economy of scale from the beginning to the end. The economy of scale is increasing between 50,000 gallons and 600,000 gallons. Therefore, if possible, the designer should avoid this area of the curve. The curve begins to flatten out and decrease after the inflection point, which lies at 600,000 gallons. Even though the economy of scale is decreasing up to 2,000,000 gallons, there still is a sizable cost savings between the two (2) design sizes.

To truly appreciate the continued savings even with the decreasing economy of scale, we must examine the construction cost curve, Figure 5-2. The cost to construct a 2,000,000 gallon facility is approximately \$480,000, and the cost of a 1,000,000 gallon ground storage tank is about \$320,000. Therefore, to build the 1 MG tank and then expand the storage capacity by 1,000,000 gallons, the total cost would be approximately \$640,000. By designing for the future with the 2 MG prestressed concrete ground storage tank, the utility and customers would save \$160,000 overall. As this shows, the savings are present in both increasing and decreasing states of economy of scale.

The unit cost and construction cost curves were produced from manufacturers' quotations. The prestressed concrete ground storage tanks include a concrete floor, prestressed wall, free-span concrete dome, aluminum interior and exterior ladders, vents, precast overflows, painting, an aeration unit, and installation. Then, 5% piping and 5% sitework costs were added to the total cost.

Ground Storage Tanks

Prestressed Concrete



w/ 1000 gpm aerator w/ 4000 gpm aerator

- Notes:
- 1) Prestressed concrete tank, concrete floor, prestressed wall, free-span concrete dome, aluminum interior and exterior ladders, vents, precast overflows, painting, aeration unit, and installation costs are included in the manufacturers' quotations.
 - 2) Includes 5% piping, 0% electrical, and 5% sitework costs.
 - 3) Costs are based on June 1995, ENR Index = 5433.

FIGURE
5-1




HARTMAN & ASSOCIATES, INC.

engineers, hydrogeologists, surveyors & management consultants
201 EAST PINE STREET - SUITE 1000 - ORLANDO, FL 32801
TELEPHONE (407) 838-3855 - FAX (407) 838-3190

**PRESTRESSED GST UNIT
COST CURVE**

Ground Storage Tanks Prestressed Concrete



w/ 1000 gpm aerator w/ 4000 gpm aerator

- Notes: 1) Prestressed concrete tank, concrete floor, prestressed wall, free-span concrete dome, aluminum interior and exterior ladders, vents, precast overflows, painting, aeration unit, and installation costs are included in the manufacturers' quotations.
- 2) Includes 5% piping, 0% electrical, and 5% sitework costs.
- 3) Costs are based on June 1995, ENR Index = 5433.

FIGURE 5-2



HARTMAN & ASSOCIATES, INC.
 engineers, hydrogeologists, surveyors & management consultants
 201 EAST PINE STREET - SUITE 1000 - ORLANDO, FL 32801
 TELEPHONE (407) 830-3855 - FAX (407) 830-3790

**PRESTRESSED GST CONSTRUCTION
COST CURVE**

5.2 STEEL GROUND STORAGE TANKS

Steel ground storage tanks are typically found in the smaller capacity range (10,000 gallon to 250,000 gallon). In this size range they are able to compete with the prestressed concrete ground storage tanks. The installations of the steel tanks in Florida are commonly above-ground. These tanks are commonly used for the storage of raw or finished water intended for the distribution system, but they can also store effluent or reuse flows. In order to study the cost relationships of these tanks, the design must be uniform throughout. Therefore, the steel tanks are above-ground and not equipped with an aeration unit.

The unit cost curve, Figure 5-3, is very similar to the prestressed concrete ground storage tank with cost curve. There is a sharply increasing economy of scale in the small design capacity range, which lies between 10,000 and 100,000 gallons. The inflection point occurs at 50,000 gallons and thereafter the economy of scale begins to decrease. The decreasing economy of scale occurs between the 100,000 gallon and maximum 250,000 gallon capacity range. Since the unit cost is decreasing throughout the entire curve, the economy of scale is present through all sizes. This means that even though the economy of scale is decreasing in the larger sizes, there are still savings in the larger designs. The construction cost curve, Figure 5-4, shows these savings by plotting the total cost of the storage tank versus the capacity of the tank. For example, by taking the average of the two curves, the cost to construct a 250,000 gallon tank is approximately \$145,000. The cost to construct a 150,000 gallon tank is about \$108,000. Therefore, there is a savings of \$50,000 by designing the tank for the larger capacity as opposed to expanding the steel ground storage tanks capacity by adding another 100,000 gallons of capacity.


The cost curves for steel ground storage tanks were prepared with values obtained from EPA cost curves and manufacturers' quotes. In order to compare the two sources of costs, the quotes were modified to meet the same criteria as the Environmental Protection Agencies cost curves. The steel tank costs include the complete tank, concrete foundation, roof, roof manway, gravity vent, bottom manway hatch, ladder and cage assembly, top manway platform, protective bolt caps, installation, 5% sitework, and 5% piping.

5.3 CHLORINATION

The chlorination of raw water is commonly accomplished using gas chlorinators. The gas is fed to the chlorinators via 150 pound, or 1 ton storage cylinders. The size of the storage cylinders is

Ground Storage Tanks

Steel



EPA Curve Manufacturers
 —□— -△-

- Notes:
- 1) Complete steel tank, concrete foundation, roof, roof manway, gravity vent, bottom manway hatch, ladder & cage assembly, top manway platform, protective bolt caps, and installation costs are included in the manufacturers' quotations.
 - 2) Includes 5% piping, 0% electrical, and 5% sitework costs.
 - 3) Costs are based on June 1995, ENR Index = 5433.

8-3

FIGURE 8-3




HARTMAN & ASSOCIATES, INC.
 engineers, hydrogeologists, surveyors & management consultants
 201 EAST PINE STREET - SUITE 1000 - ORLANDO, FL 32801
 TELEPHONE (407) 830-3000 - FAX (407) 830-3700

STEEL GST UNIT COST CURVE

Ground Storage Tanks

Steel



EPA Curve Manufacturers

- Notes: 1) Complete steel tank, concrete foundation, roof, roof manway, gravity vent, bottom manway hatch, ladder & cage assembly, top manway platform, protective bolt caps, and installation costs are included in the manufacturers' quotations.
- 2) Includes 5% piping, 0% electrical, and 5% sitework costs.
- 3) Costs are based on June 1995, ENR Index = 5433.

STEEL GST CONSTRUCTION COST CURVE



HARTMAN & ASSOCIATES, INC.
 engineers, hydrogeologists, surveyors & management consultants
 201 EAST PINE STREET - SUITE 1000 - ORLANDO, FL 32801
 TELEPHONE (407) 838-3855 - FAX (407) 838-3760

FIGURE 8-4

dependent on the quantity of raw water to be treated. Typically, at a dosage of 5 milligrams per liter, the 150 pound storage cylinders are used at treatment plant flows of up to 2 MGD. This means that the 1 ton cylinders are used for flows above this point. The costs of the feed system fluctuates with the size of the storage cylinders.

The unit cost curve, Figure 5-5, displays an economy of scale throughout the treatment capacities of 0.01 MGD to 5 MGD. This relationship is further solidified when the capacities and unit costs are plotted on linear axes. Where the storage cylinder sizes change, the costs slightly increase; however, the ton cylinder feed systems resume the continuous economy of scale. The overall cost, when compared with treatment plant capacity, is not much of a concern. The larger capacity plants will have a much smaller unit cost for chlorine feed systems than the smaller capacity plants.

The chlorination feed equipment curve was constructed using manufacturers' quotations and EPA cost curves. Included in the cost of both size systems are dual chlorinators, dual scales, a gas detector, an alarm panel, a vacuum switch, booster pump, housing, hoists, 20% electrical, 15% piping, 20% installation, and no sitework.


5.4 HIGH SERVICE PUMPS

High service pumps are commonly used in the water distribution system. The water is stored in a ground storage tank and then is distributed to the customers by a series of high-service pumps and water mains. In this study, the horizontal split-case pump was used to represent the typical high-service pumps. The pumps were plotted by their cost and unit cost versus capacity between 100 gpm and 5,000 gpm.

The unit cost curve, Figure 5-6, presents the pump cost in terms of dollars per gpm versus the gpm capacity of the pump. The smaller pumps, 100 gpm to 500 gpm, show an increasing economy of scale and the larger pumps, 1,000 gpm to 5,000 gpm, display a decreasing economy of scale. The transition of the unit cost curve is the inflection point which occurs around the 1,000 gpm pump. Therefore, 750 gpm pumps and larger are more economical in design than are the smaller pumps. For example, Figure 5-7 shows that a 5,000 gpm pump will cost approximately \$30,000 and a 1,000 gpm pump will cost \$9,000. The cost to upgrade the pump capacity by adding additional pumps will bring the total cost for 5,000 gpm of capacity to

Chlorine Feed Systems

Water Treatment



EPA Curve Manufacturers

- Notes: 1) Gas chlorination unit with 5 mg/l feed rate capacity.
- 2) Dual chlorinators w/ switchover, dual scales, gas detector, alarm panel, vacuum switch, booster pump, housing, and hoists are included in the manufacturers' quotations.
- 3) Includes 20% electrical, 15% piping, and 20% installation costs.
- 4) Costs are based on June 1995, ENR Index = 5433.




HARTMAN & ASSOCIATES, INC.
 engineers, hydrogeologists, surveyors & management consultants
 201 EAST PINE STREET - SUITE 1000 - ORLANDO, FL 32801
 TELEPHONE (407) 830-3955 - FAX (407) 830-3790

CHLORINE FEED SYSTEM UNIT COST CURVE

FIGURE 6-5

High-Service Pumps Horizontal Split Case



- Notes:
- 1) All costs obtained from manufacturer's quotations include pumps, factory testing, and freight to jobsite.
 - 2) Horizontal Split Case pumps and motors.
 - 3) Pump head is 175 feet (76 psi).
 - 4) Costs are based on June 1995, ENR Index = 5433.


FIGURE
5-6



HARTMAN & ASSOCIATES, INC.
 engineers, hydrogeologists, surveyors & management consultants
 201 EAST PINE STREET - SUITE 1000 - ORLANDO, FL 32801
 TELEPHONE (407) 830-3955 - FAX (407) 830-3790

**HIGH SERVICE PUMP UNIT
COST CURVE**

High-Service Pumps Horizontal Split Case



- Notes: 1) Values obtained from manufacturer's quotations include pumps, factory testing, and freight to jobsite.
2) Horizontal Split Case pumps and motors.
3) Pump head is 175 feet (76 psi).
4) Costs are based on June 1995, ENR Index = 5433.

50-100

FIGURE
5-7



HARTMAN & ASSOCIATES, INC.

engineers, hydrogeologists, surveyors & management consultants

201 EAST PINE STREET - SUITE 1000 - ORLANDO, FL 32801
TELEPHONE (407) 838-3955 - FAX (407) 838-3790

**HIGH SERVICE PUMP CONSTRUCTION
COST CURVE**

between \$35,000 and \$45,000. The overall saving would then be in the \$10,000 range, which is considerable with horizontal split-case pumps.

The values for the construction cost and unit cost curves were quoted from manufacturers of horizontal split case pumps. The costs for the pumps include the pump, motor, factory testing, and freight to the jobsite. The pumps were sized using a head of 175 feet.


5-5 HYDROPNEUMATIC TANKS

Hydropneumatic tanks are an integral component in maintaining the required pressure of the water entering the distribution system. In this study, the hydropneumatic tanks are designed for a pressure rating of 100 pounds per square inch, and they are ASME rated. The tanks are the horizontal type cylinder tanks that are situated on a concrete base. The hydrotank system estimates are presented as both unit cost versus capacity and construction costs versus capacity.

The unit cost curve, Figure 5-8, is plot of the unit cost, dollars per gallon, versus capacity for hydropneumatic tanks between 500 gallons and 20,000 gallons. The curve shows an economy of scale that begins to slightly decrease near 10,000 gallons. Overall, there is considerable savings between each successive step of the design capacity. The unit cost curve virtually straight, which leaves the curve without a point of inflection. Without an inflection point, the curve possesses a strong economy of scale throughout the size range. The construction cost curve, Figure 5-9, strengthens this point. For example, the cost of a 500 gallon, 5,000 gallon, and 20,000 gallon hydropneumatic tank system is \$11,000, \$32,000, and \$62,000, respectively. By adding to the 500 gallon tank to reach 5,000 gallon capacity, the cost would be considerably more than the original 5,000 gallon tank. For instance, adding a 500 gallon tank and then a 4,000 gallon tank to the existing 500 gallon tank, the total cost would be \$52,000. This option is approximately \$20,000 more than a 5,000 gallon tank would originally cost. This relationship also exists between the 5,000 gallon and 20,000 gallon tanks. In this case, the cost would be approximately \$20,000 more to expand to 20,000 gallon capacity from 5,000 gallon capacity.

The unit cost and construction cost curves were formed using quotations from manufacturers. The quotes included the tank itself, an air volume control compressor, and a control panel. To these values, 15% piping, 20% electrical, 10% sitework, and 20% installation was added to determine the total cost of a hydropneumatic tank system.

Hydropneumatic Tanks




- Notes: 1) Costs of the tank, air volume control compressor, and a control panel were included in the manufacturers' quotations.
 2) 15% piping, 20% electrical, 20% installation, and 10% sitework were added to the quoted costs.
 3) Costs are based on June 1995, ENR Index = 5433.

FIGURE 6-8



HARTMAN & ASSOCIATES, INC.
 engineers, hydrogeologists, surveyors & management consultants
 201 EAST PINE STREET - SUITE 1000 - ORLANDO, FL 32801
 TELEPHONE (407) 838-3855 - FAX (407) 838-3790

HYDROPNEUMATIC TANK UNIT COST CURVE



30-

FIGURE 5-9

HARTMAN & ASSOCIATES, INC.
 engineers, hydrogeologists, surveyors & management consultants
 201 EAST PINE STREET - SUITE 1000 - ORLANDO, FL 32801
 TELEPHONE (407) 830-3055 - FAX (407) 830-3700

HYDROPNEUMATIC TANK CONSTRUCTION COST CURVE

5.6 WELLS

Depending on the site, raw water wells can vary tremendously in the depth required to produce a functional well. In this case, deep wells of approximately 250 feet and 500 feet in depth were considered appropriate. The pumps designed for these wells are vertical turbine pumps. The cost of the well system includes only the well components and is represented in the unit cost and construction cost curves.


The unit cost curve, Figure 5-10, is based on the daily pumping capacity of the well. In other words, the unit cost is presented as dollars per gallon and the capacity is in gallons per day. Both the 250 foot and 500 foot deep wells display considerable economies of scale throughout the capacity range of the curve. The unit costs begin between \$0.4/gal and \$0.7/gal at 144,000 gallons per day and ends around \$0.04/gal to \$0.08/gal at approximately 3,500,000 gallons per day. The savings are apparent throughout the well sizes when looking at the construction cost curve, Figure 5-11. A well pumping at 2,800,000 gallons per day costs about \$115,000 to construct, while a 720,000 gallon per day costs about \$75,000 to construct. The economy of scale is primarily due to contractor mobilization and economies of scale in casing pipe and pumps.

The unit cost and construction cost curves were developed with the values received from manufacturers' quotations, EPA cost curves, and previously completed project bid tabulations. All curves for supply wells include a vertical turbine pump, cement grout, black steel well and surface casing, well screen, well development, 10% for electrical, 15% for well head, and 30% for labor needed for construction.

5.7 LIME SOFTENING WTP

The Lime Softening-WTP cost curves, Figures 5-12 and 5-13, represent the costs associated with the treatment facilities needed to treat raw water with lime and recarbonate the treated water with gaseous carbon dioxide. The lime softening plant is characteristically the same as a conventional filtration plant; however, lime is substituted for other chemicals and the treated water will need to be recarbonated. The unit cost curve, Figure 5-12, and the construction cost curve, Figure 5-13, were produced using documented EPA cost information and includes the following cost considerations: raw water pumping equipment, chemical addition facilities, rapid mix/flocculation equipment, sedimentation basin, filtration units, disinfection equipment, finished water storage and pumping equipment, and sludge disposal facilities.

Potable Water Wells



EPA Curve (250' deep) Manufacturers (250' deep)
 EPA Curve (500' deep) Manufacturers (500' deep)

- Notes: 1) Vertical turbine pump, cement grout, black steel well and surface casing, well screen, and well development costs from manufacturers' quotes and bid tabulations.
 2) Includes 10% electrical, 15% for well head assembly, and 30% labor costs.
 3) EPA cost curves contain all costs.
 4) Costs are based on the June 1995, ENR Index = 5433.

80-100


FIGURE 5-10



HARTMAN & ASSOCIATES, INC.
 engineers, hydrogeologists, surveyors & management consultants
 201 EAST PINE STREET - SUITE 1000 - ORLANDO, FL 32801
 TELEPHONE (407) 830-3000 - FAX (407) 830-3700

SUPPLY WELL UNIT COST CURVE

Potable Water Wells



EPA Curve (250' deep) Manufacturers (250' deep)
 EPA Curve (500' deep) Manufacturers (500' deep)

- Notes: 1) Vertical turbine pump, cement grout, black steel well and surface casing, well screen, and well development costs from manufacturers' quotes and bid tabulations.
 2) Includes 10% electrical, 15% for well head assembly, and 30% labor costs.
 3) EPA cost curves contain all costs.
 4) Costs are based on the June 1995, ENR Index = 5433.


FIGURE 8-11



HARTMAN & ASSOCIATES, INC.
 engineers, hydrogeologists, surveyors & management consultants
 201 EAST PINE STREET - SUITE 1000 - ORLANDO, FL 32801
 TELEPHONE (407) 838-3855 - FAX (407) 838-3780

SUPPLY WELL CONSTRUCTION COST CURVE

Lime Softening WTP



- Notes:
- 1) Values obtained using EPA cost curves.
 - 2) Costs include raw water influent pumping, chemical addition, rapid mix/flocculation, sedimentation, filtration, disinfection, finished water storage, finished water pumping, and sludge disposal.
 - 3) Costs are based on June 1995, ENR Index = 5433.

8-12


FIGURE 8-12



HARTMAN & ASSOCIATES, INC.
 engineers, hydrogeologists, surveyors & management consultants
 201 EAST PINE STREET - SUITE 1000 - ORLANDO, FL 32801
 TELEPHONE (407) 836-3850 - FAX (407) 836-3790

LINE SOFTENING WTP UNIT COST CURVE

Lime Softening WTP



- Notes:
- 1) Values obtained using EPA cost curves.
 - 2) Costs include raw water influent pumping, chemical addition, rapid mix/flocculation, sedimentation, filtration, disinfection, finished water storage, finished water pumping, and sludge disposal.
 - 3) Costs are based on June 1995, ENR Index = 5433.

FIGURE 8-13



HARTMAN & ASSOCIATES, INC.
 engineers, hydrogeologists, surveyors & management consultants
 201 EAST PINE STREET - SUITE 1000 - ORLANDO, FL 32801
 TELEPHONE (407) 830-3055 - FAX (407) 830-3790

LIME SOFTENING WTP CONSTRUCTION COST CURVE

The Lime Softening WTP cost curves show a small economy of scale throughout the capacity ranges. The unit cost begins with approximately \$3.5/gal at 1 MGD and ends with approximately \$1.4/gal at 10 MGD. This shows that there is an economy of scale between these ranges of capacities.


The curves for Lime Softening Water Treatment Plants were constructed using information gathered from EPA cost curves.

5.8 REVERSE OSMOSIS WTP

The curves presented, Figure 5-14 and 5-15, in this Section were constructed using previous EPA cost curves and information contained in previous EPA reports. The treatment facilities that make up a Reverse Osmosis treatment plant and consequently, the cost curves contained in this report are as follows: reverse osmosis membrane elements and pressure vessels, flow meters, housing, structural steel, tanks, piping, valves, pumps, cartridge filters, acid and polyphosphate equipment, and cleaning equipment. The EPA cost curves have also added costs for contingencies, sitework, engineering and administration, and electrical.

The unit cost curve, Figure 5-14, shows a considerable economy of scale. The ranges of capacity begin with 0.003 MGD and end with 10 MGD. When plotted on a linear scale, the curve is more pronounced than the economy of scale curve shown in Figure 2-1. The unit cost is approximately \$14/gal at 0.003 MGD and approximately \$0.95/gal at 10 MGD.

Reverse Osmosis WTP



- Notes:
- 1) Values obtained using EPA cost curves.
 - 2) Costs include housing, structural steel, tanks, piping, valves, pumps, reverse osmosis membrane elements and pressure vessels, flow meters, cartridge filters, acid and polyphosphate equipment, and cleaning equip.
 - 3) The EPA cost curves have also added costs for contingencies, sitework, engineering & administration, and electrical.
 - 4) Costs are based on June 1995, ENR Index = 5433.


FIGURE
5-14



HARTMAN & ASSOCIATES, INC.
 engineers, hydrogeologists, surveyors & management consultants
 201 EAST PINE STREET - SUITE 1000 - ORLANDO, FL 32801
 TELEPHONE (407) 830-3855 - FAX (407) 830-3790

**REVERSE OSMOSIS UNIT
 COST CURVE**

Reverse Osmosis WTP



- Notes:
- 1) Values obtained using EPA cost curves.
 - 2) Costs include housing, structural steel, tanks, piping, valves, pumps, reverse osmosis membrane elements and pressure vessels, flow meters, cartridge filters, acid and polyphosphate equipment, and cleaning equip.
 - 3) The EPA cost curves have also added costs for contingencies, sitework, engineering & administration, and electrical.
 - 4) Costs are based on June 1995, ENR Index = 5433.

FIGURE 5-15



HARTMAN & ASSOCIATES, INC.
 engineers, hydrogeologists, surveyors & management consultants
 201 EAST PINE STREET - SUITE 1000 - ORLANDO, FL 32801
 TELEPHONE (407) 830-3050 - FAX (407) 830-3790

REVERSE OSMOSIS CONSTRUCTION COST CURVE

SECTION 6

**SECTION 6
 WASTEWATER COLLECTION/WATER DISTRIBUTION**

6.1 GRAVITY SEWERS


The gravity sewer collection system consists of a series of PVC-SDR35 pipe, manholes, and sewage pump station. The cost analysis of this type of system must be done by looking at the number of services per section. The sections are defined by 400 foot lengths of pipe, as denoted in Figure 6-1. Since the lots are assumed to be 100 feet in width, there can only be four (4) lots on each side of the gravity line. For example, sewer installation A would include a beginning manhole, 400 feet of 8-inch PVC pipe, and a portion of the cost of the sewage pump station. The pump station cost for this example would be calculated by multiplying the total cost for the pump station by the ratio of the number of lots, in this case eight (8), over the total numbers of lots that a 100 gallon per minute pump station can serve, which is approximately 120. The total cost is attained by summing the costs of the gravity pipe, manholes, sewage pump station, permitting fee, line testing fee, mobilization, electrical, and installation.

The unit cost curve was produced by dividing the total cost of an installation by the number of lots that are serviced and then plotting this value versus the total number of lots. The design was carried all the way out to the 100 gallon per minute pump station capacity of 120 lots. The actual curve, Figure 6-2, shows that the gravity sewer installations experience an increasing economy of scale up to the inflection point, which is located at about 32 lots serviced. From this point, the economy of scale decreases all the way to the 120 lot endpoint. Therefore, the gravity sewer installations are much more economical on a large scale than they are when individual 400 foot sections are installed. This occurs due to the extra costs for permitting, mobilization, and engineering.


The unit cost curve for the gravity sewer installation was formed using the values obtained from manufacturers' quotations and bid tabulations from previously completed jobs.

6.2 SEWAGE PUMP STATIONS

The pump station configuration that was studied for this report is the submersible duplex pumps in a wet well with an adjoining valve box. The costs of these wastewater collection and



Gravity Sewer Installations



- Notes:
- 1) Assumed 100 foot lots, 12 foot maximum pipe depth, and 120 lots served by a 100 gpm pump station.
 - 2) Manufacturers' quotes and bid tabulations provided costs for precast manholes, pipe material, and the \$1/ft line testing cost for low pressure air exfiltration.
 - 3) Includes a \$500 permitting fee, electrical, installation, and 10% for mobilization.
 - 4) Costs are based on June 1995, ENR Index = 5433.

FIGURE 6-2



HARTMAN & ASSOCIATES, INC.
 engineers, hydrogeologists, surveyors & management consultants
 201 EAST PINE STREET - SUITE 1000 - ORLANDO, FL 32801
 TELEPHONE (407) 830-3055 - FAX (407) 830-3790

GRAVITY SEWER UNIT COST CURVE

transmission components is directly related to the amount of wastewater that is entering the wet well. The range of capacities of the pump stations are from 100 gallons per minute to 1,000 gallons per minute.

The unit cost curve, Figure 6-3, was produced by dividing the total cost of a submersible pump station by the capacity of the main pump and plotting this value, versus the capacity of the pump, in gallons per minute. This curve shows an increasing economy of scale between 100 gpm and 400 gpm. The inflection point lies around 400 gpm, and from 400 gpm to 1,000 gpm the economy of scale is slightly decreasing. Due to the unit cost relationship, the design of a pump station under 400 gpm should be avoided, if there are any possibilities for further expansion. After 400 gpm, there is still an economy of scale; however, it is not as significant. To show that there is still considerable savings after 400 gpm, we must study the construction cost curve, Figure 6-4. The cost of a 1,000 gpm duplex pump station is approximately \$63,000, and the cost of a 500 gpm pump station is \$46,000. Therefore, there is a \$29,000 savings to build the 1,000 gpm pump station when compared to two (2) 500 gpm pump stations.


The unit cost and construction cost curves were produced using the quotations obtained from manufacturers. The cost includes two (2) equivalent submersible pumps, the precast wet well, precast valve box, piping, fittings, 20% for electrical, and installation, which includes excavating, backfilling, and dewatering. The pumps were designed to run on a 6-minute cycle time, which minimized wet well sizing.

6.3 FORCE MAINS

In the transmission of wastewater, force mains are used to convey wastewater from a sewage pump station directly to the treatment plant, another pump station, or a manhole. The force main materials that were studied in this project were the PVC (C900-DR25) and the Class 50 DIP with epoxy coating. These pipes are presented on unit cost curves as illustrated in Figure 6-5 and Figure 6-6.

The PVC force main unit cost curve, Figure 6-5, was produced for pipe sizes between 4-inches and 12-inches in diameter. The unit cost of the pipe is in dollars per linear foot and this is based on different lengths of pipe. In other words, there are three (3) different total lengths of pipe: 25,000 feet (large project), 2,500 feet (medium project) and 250 feet (small project). For these different lengths, manufacturers quoted the actual material prices per foot that would apply to

Sewage Pump Stations



- Notes:
- 1) Pump station design was based on a 6 minute cycle time, a peak factor of 3 to 4 respective of average flow, and a 3 ft high effective volume.
 - 2) Costs include two (2) equal size pumps, precast wetwell, precast valve box, installation (excavating, backfilling, dewatering), piping, fittings, and 20% electrical.
 - 3) Wet well sizes: 100-400 gpm => 6' diam., 500-600 gpm => 8' diam., 700-900 gpm => 10' diam., 1000 gpm => 12' diam.
 - 4) Costs are based on June 1995, ENR Index = 5433.


FIGURE
6-3



HARTMAN & ASSOCIATES, INC.
 engineers, hydrogeologists, surveyors & management consultants
 201 EAST PINE STREET - SUITE 1000 - ORLANDO, FL 32801
 TELEPHONE (407) 830-3055 - FAX (407) 830-3700

**SEWAGE PUMP STATION UNIT
 COST CURVE**

Sewage Pump Stations



- Notes:
- 1) Pump station design was based on a 6 minute cycle time, peak factor of 3 to 4 respective of average flow, and a 3 ft high effective volume.
 - 2) Costs include two (2) equal size pumps, precast wetwell, precast valve box, installation (excavating, backfilling, dewatering), piping, fittings, and 20% electrical.
 - 3) Costs are based on June 1995, ENR Index = 5433.


FIGURE
6-4



HARTMAN & ASSOCIATES, INC.
 engineers, hydrogeologists, surveyors & management consultants
 201 EAST PINE STREET - SUITE 1000 - ORLANDO, FL 32801
 TELEPHONE (407) 830-3855 - FAX (407) 830-3790

**SEWAGE PUMP STATION CONSTRUCTION
 COST CURVE**

PVC (C900 - DR25) Force Main



4"	6"	8"	10"	12"
pipe	pipe	pipe	pipe	pipe

- Notes:
- 1) Material cost obtained from manufacturers' quotes.
 - 2) Costs include \$500 permitting, 10%-15% mobilization, \$.25-\$.75/ft for pressure testing, and \$7/ft for excavating, backfilling, and compacting.
 - 3) Costs exclude valves, fittings, and restoration work.
 - 4) Costs are based on June 1995, ENR Index = 5433.


FIGURE 6-5



HARTMAN & ASSOCIATES, INC.
 engineers, hydrogeologists, surveyors & management consultants
 201 EAST PINE STREET - SUITE 1000 - ORLANDO, FL 32801
 TELEPHONE (407) 830-3000 - FAX (407) 830-3790

PVC FORCE MAIN UNIT COST CURVE

DIP (Class 50 - Epoxy Lined) Force Main



6"	8"	10"	12"	14"	16"
pipe	pipe	pipe	pipe	pipe	pipe

- Notes:
- 1) Material cost obtained from manufacturers' quotes.
 - 2) Costs include \$500 permitting, 10%-15% mobilization, \$.25-\$.75/ft pressure testing, and \$7/ft for excavating, backfilling, and compacting.
 - 3) Costs exclude valves, fittings, and restoration work.
 - 4) Costs are based on June 1995, ENR Index = 5433.

30-111

FIGURE
0-8



HARTMAN & ASSOCIATES, INC.
 engineers, hydrogeologists, surveyors & management consultants
 201 EAST PINE STREET - SUITE 1000 - ORLANDO, FL 32801
 TELEPHONE (407) 839-3686 - FAX (407) 839-3790

**DIP FORCE MAIN UNIT
COST CURVE**

each case. As the graph shows, it is apparent that the larger quantities of pipe receive the most economical unit costs for each of the pipe sizes that were examined.

The Class 50 DIP force main unit cost curve is very similar to the PVC force main unit cost curve. The DIP sizes range from 4-inches to 16-inches and the pipes are lined with an epoxy coating. The graph shows that on a dollar per linear foot basis, the DIP force main is the most economical when the project is of a large magnitude. This relationship is in agreement with the PVC force main unit costs. Therefore, regardless of the pipe material, one should consider the full design of a force main as a stronger option to the smaller separate installations.

Both the PVC and DIP unit cost curves are formed using values obtained from manufacturers' quotations. In order to present the costs as final installed costs, a permitting fee, mobilization, installation, and pressure testing values were added to the unit costs based on the size of the project.


6.4 WATER MAINS

Typically, water mains will be made of either C900-DR18 PVC or Class 50 - cement lined DIP. In order to insure the safety and welfare of the customers, the water mains must be pressure tested and disinfected before they are put into use. For this study, PVC water mains from 4-inches to 12-inches in diameter and DIP water mains from 6-inches to 16-inches in diameter were studied to determine if an economy of scale existed.

The PVC C900-DR18 water main unit cost curve, Figure 6-7, shows the unit cost for three (3) different sized projects. The manufacturers were asked to give \$/Ft prices for the pipe based on a small (250 ft), medium (2,500 ft), or large (25,000 ft) project. This footage represents the linear amount of certain diameter pipe to be installed in a certain project. As can be seen from the figure, the unit cost drops between \$4/Ft and \$5/Ft between the small and large projects for all the pipe sizes. Therefore, it is more economical to construct a single large scale project at one time than to construct many smaller projects.

In the other unit cost curve, Figure 6-8, the Class 50 - cement lined DIP also shows a significant economy of scale. For the DIP water main, the sizes ranged from 6-inches to 16-inches in diameter. For the 6-inch diameter water main, the unit cost dropped about \$6.50/Ft between the small and large projects. For the 16-inch diameter water main, the unit cost declined by \$12/Ft

PVC (C900 - DR18) Water Main



4"	6"	8"	10"	12"
pipe	pipe	pipe	pipe	pipe

- Notes:
- 1) Material cost obtained from manufacturers' quotes.
 - 2) Costs include \$500 permitting, 10%-15% mobilization, \$1-\$2/ft disinfection, \$.25-\$.75/ft for pressure testing, and \$7/ft for excavating, backfilling, and compacting.
 - 3) Costs exclude valves, fittings, and restoration work.
 - 4) Costs are based on June 1995, ENR Index = 5433.


FIGURE 6-7



HARTMAN & ASSOCIATES, INC.
 engineers, hydrogeologists, surveyors & management consultants
 201 EAST PINE STREET - SUITE 1000 - ORLANDO, FL 32801
 TELEPHONE (407) 830-3855 - FAX (407) 830-3790

PVC WATER MAIN UNIT COST CURVE

DIP (Class 50 - Cement Lined) Water Main



6"	8"	10"	12"	14"	16"
pipe	pipe	pipe	pipe	pipe	pipe

- Notes:
- 1) Material cost obtained from manufacturer's quotes.
 - 2) Costs include \$500 permitting, 10%-15% mobilization, \$1-\$2/ft disinfection, \$.25-.75/ft for pressure testing, \$7/ft for excavating, backfilling, and compacting.
 - 3) Costs exclude valves, fittings, and restoration work.
 - 4) Costs are based on June 1995, ENR Index = 5433.

20-5

FIGURE 8-8



HARTMAN & ASSOCIATES, INC.
 engineers, hydrogeologists, surveyors & management consultants
 201 EAST PINE STREET - SUITE 1000 - ORLANDO, FL 32801
 TELEPHONE (407) 830-3000 - FAX (407) 830-3700

DIP WATER MAIN UNIT COST CURVE

between the small and large projects. Once again, the unit costs prove the existence of a strong economy of scale in the water mains. Therefore, to capture the economy of scale it is desirable to construct as much water main as possible.

The unit cost curves for the PVC and DIP water mains were constructed from values obtained from manufacturers' quotes. The unit cost includes the material cost, a \$7/foot trenching cost, a permitting fee, mobilization, disinfection of water mains, and the pressure testing on the water mains.

APPENDIX A

Package Wastewater Treatment Plants
Unit Costs


Capacity (MGD)	Davco Ext. Aer. (\$)	Sanitaire Ext. Aer. (\$)	Total Ext. Aeration Const. Cost (\$)	Overall E.A. Cost w/ Chlor. (\$)	Unit Cost (\$/Gal)
0.01	50000	--	50000	77500	7.75
0.025	78000	--	78000	105500	4.22
0.05	135000	125495	130247.5	160248	3.205
0.075	185000	159630	172315	202315	2.6975
0.1	217000	184948	200974	235974	2.3597
0.15	210000	233535	221767.5	256768	1.7118
0.25	260000	309045	284522.5	319523	1.2781
0.5	375000	479368	427184	462184	0.9244
0.75	450000	622920	536460	571460	0.7619
1	533000	758860	645930	680930	0.6809

Notes: 1) Values include materials, electrical, piping, installation, blowers, grading, chlorination feed sys., and conc. slab; but exclude land, engineering, fencing, paving, drainage, lighting, and building facilities.
All costs obtained from manufacturer's quotes and EPA cost curves.
Costs are based on June 1995, ENR Index = 5433.

CURVE FORMULA (For any capacity on the curve)


$Y = (0.6521692) * X^{(-0.5290282)}$ **** See Example Below

Capacity (MGD)	Unit Cost (\$/Gal)	Manuf. Unit Cost (\$/Gal)
0.0100	7.45447	7.75
0.0250	4.59087	4.22
0.0400	3.58022	
0.0500	3.18157	3.20496
0.0650	2.76925	
0.0750	2.56735	2.69753
0.0900	2.33129	
0.1000	2.2049	2.35874
0.1150	2.04775	
0.1300	1.91915	
0.1500	1.77923	1.71179
0.1650	1.69174	
0.1800	1.61563	
0.1950	1.54865	
0.2100	1.48911	
0.2250	1.43573	
0.2400	1.38754	
0.2500	1.3579	1.27809
0.2650	1.31668	
0.2800	1.27888	
0.2950	1.24405	
0.3100	1.21184	
0.3250	1.18192	
0.3400	1.15404	
0.3550	1.12798	
0.3700	1.10355	
0.3850	1.0806	
0.4000	1.05897	
0.4150	1.03854	
0.4300	1.01922	
0.4450	1.00089	
0.4600	0.98349	
0.4750	0.96694	
0.4900	0.95116	
0.5000	0.94105	0.92437
0.5150	0.92645	
0.5300	0.91249	
0.5450	0.89911	
0.5600	0.88629	
0.5750	0.87398	
0.5900	0.86216	
0.6050	0.85078	
0.6200	0.83983	
0.6350	0.82927	
0.6500	0.8191	
0.6650	0.80927	
0.6800	0.79977	
0.6950	0.7906	
0.7100	0.78172	
0.7250	0.77312	
0.7400	0.76479	
0.7500	0.75938	0.76185
0.7650	0.75146	
0.7800	0.74378	
0.7950	0.73632	
0.8100	0.72908	
0.8250	0.72204	
0.8400	0.71519	
0.8550	0.70852	
0.8700	0.70203	
0.8850	0.69571	
0.9000	0.68955	
0.9150	0.68355	
0.9300	0.67769	
0.9450	0.67198	
0.9600	0.66641	
0.9750	0.66096	
1	0.65217	0.68093



EXTENDED AERATION WWTP INFLECTION POINT

Capacity (MGD)	F'(x)
0.01	1286.7
0.025	1107.93
0.05	847.924
0.075	631.193
0.1	453.15
0.15	195.964
0.175	108.824
0.2	44.38
0.225	-0.7796
0.25	-29.831
0.5	34.7526
0.75	-39.895
1	445.206



EXTENDED AERATION, MECHANICAL AND DIFFUSED AERATION

FACT SHEET 2.1.10

Description - Extended aeration is the "low rate" modification of the activated sludge process. The F/M loading is in the range of 0.05 to 0.15 lb BOD₅/d/lb MLVSS, and the detention time is about 24 hours. Primary clarification is rarely used. The extended aeration system operates in the endogenous respiration phase of the bacterial growth cycle, because of the low BOD₅ loading. The organisms are starved and forced to undergo partial auto-oxidation. Volatile compounds are driven off to a certain extent in the aeration process. Metals will also be partially removed, with accumulation in the sludge.

In the complete mix version of the extended aeration process, all portions of the aeration basin are essentially homogeneous, resulting in a uniform oxygen demand throughout the aeration tank. This condition can be accomplished fairly simply in a symmetrical (square or circular) basin with a single mechanical aerator or by diffused aeration. The raw wastewater and return sludge enter at a point (e.g., under a mechanical aerator) where they are quickly dispersed throughout the basin. In rectangular basins with mechanical aerators or diffused air, the incoming waste and return sludge are distributed along one side of the basin and the mixed liquor is withdrawn from the opposite side.

Common Modifications - Step aeration, contact stabilization, and plug flow regimes. Alum or ferric chloride is sometimes added to the aeration tank for phosphorus removal.

Technology Status - Extended aeration plants have evolved since the latter part of the 1940's. Pre-engineered, package plants have been widely utilized for this process.

Typical Equipment/No. of Mfrs. - Aerators/30; package treatment plants/21; air diffusers/19; compressors/44.

Applications - Commonly flows of less than 50,000 gal/d; emergency or temporary treatment needs; and biodegradable wastewater.

Limitations - High power costs, operation costs, and capital costs (for large permanent installations where the pre-engineered plants would not be appropriate).

Performance
 BOD₅ Removal 85-95%
 NH₄ - N Removed (Nitrification) 50-90%

Residuals Generated - Because of the low F/M loadings and long hydraulic detention times employed, excess sludge production for the extended aeration process (and the closely related oxidation ditch process) is the lowest of any of the activated sludge process alternatives, generally in the range of 0.15 to 0.3 lb excess total suspended solids/lb BOD₅ removed.

Design Criteria (39) - A partial listing of design criteria for the extended aeration modification of the activated sludge process is summarized as follows:

Volumetric loading, lb BOD ₅ /d/1,000 ft ³	5 to 10
MLSS, mg/l	3,000 to 6,000
F/M, lb BOD ₅ /d/lb MLVSS	0.05 to 0.15
Aeration detention time, hours (based on average daily flow)	18 to 36
Standard ft ³ air/lb BOD ₅ applied	3,000 to 4,000
lb O ₂ /lb BOD ₅ applied	2.0 to 2.5 (based on 1.5 lb O ₂ /lb BOD ₅ removed + 4.6 lb O ₂ /lb NH ₄ -N removed)
Sludge retention time, days	20 to 40
Recycle ratio (R)	0.75 to 1.5
Volatile fraction of MLSS	0.6 to 0.7


Process Reliability - Good

Environmental Impact - See Fact Sheet 2.1.1

References - 23, 26, 31, 39

EXTENDED AERATION, MECHANICAL AND DIFFUSED AERATION FACT SHEET 2.1.10

FLOW DIAGRAM -



ENERGY NOTES - Assumptions: The hydraulic head loss through the aeration tank is negligible. Sludge recycle and sludge wasting pumping energy are included.

Water Quality:

	Influent(mg/l)	Effluent(mg/l)
BOD ₅	210	20
Suspended Solids	230	20
NH ₄ -N	20	1

Oxygen Transfer Rate (wire to water) in wastewater for:

Mechanical Aeration = 1.8 lb O₂/hph


Diffused Aeration

Coarse Bubble Diffusion - 1.5 lb O₂/hph

Fine Bubble Diffusion = 2.5 lb O₂/hph



Oxygen Requirement:

1.5 lb O₂/lb BOD₅ removed plus 4.6 lb O₂/lb of NH₄-N removed



COSTS - Assumptions: Construction cost includes comminutor, aeration basin, clarifier, chlorine contact chamber, aerobic digester, chlorine feed facility, building, fencing for extended aeration package plants between 0.01 and 0.1 Mgal/d. Detention time: 24 hours (based on average daily flow). ENR Index = 2475. Annual power costs based on coarse bubble diffuser.

update rate = $\frac{5433}{2475}$



unit cost

6.59
4.10
3.29
2.85
2.52

REFERENCES - 3, 4

*To convert construction cost to capital cost see Table A-2.

MOSS
KELLEY
INCORPORATED

FACSIMILE TRANSMISSION

IF TRANSMISSION WAS NOT PROPERLY RECEIVED, CALL (305) 755-2092

DATE: 7-6-95
FROM: J. Kelley FAX NUMBER: (305) 341-9370
TO: Jamie Walsh FAX NUMBER: _____
COMPANY: Hartman NUMBER OF PAGES: 2
REFERENCE: Pachay Plant Budget Pricing

I hope the attached is sufficient.
Sanitair doesn't make the smaller plants.
Please call if you have any questions.

J. Kelley

SANITARY
Storm Ring Steel List Costs

Capacity (GPD)	Extended Aeration		Contact Stabilization	
	List Price (\$)	Turn Key Install.	List Price (\$)	Turn Key Install.
10,000	∅		∅	
20,000	∅		∅	
50,000	\$ 82,000	\$ 110,000	\$ 75,000	\$ 100,000
75,000	\$ 100,000	\$ 135,000	\$ 81,000	\$ 109,000
100,000	\$ 115,000	\$ 155,000	\$ 96,000	\$ 130,000
150,000	\$ 142,000	\$ 192,000	\$ 109,000	\$ 148,000
200,000	\$ 185,000	\$ 240,000	\$ 148,000	\$ 200,000
300,000	\$ 268,000	\$ 360,000	\$ 215,000	\$ 290,000
400,000	\$ 325,000	\$ 440,000	\$ 260,000	\$ 350,000
1,000,000	\$ 385,000	\$ 520,000	\$ 308,000	\$ 415,000

Blowers, concrete slab not included.



1828 Metcalf Ave.
 Thomasville, Georgia 31762
 Phone 912-226-5733
 Telefax No.
 912-228-0312

FACSIMILE TRANSMITTAL SHEET

From: Tommy Tyson
 Phone 941-646-7694
 Fax. 941-644-6319

To: HAI - Jamie Wallace Re: Budget Estimates

Fax. number: 407-839-3790 Date: 7-2-95

Total number of pages including this page is: 2

REMARKS:

Budget estimates are for "DAVCO standard" equipment delivered to central Florida. Davco std is Aluminum grating and aluminum handrails. Also depending on size, duplex or triplex rotary positive blowers and controls are included. I have not included any accessories such as comminutor, flowmeter or telemetry equipment (or cl₂ feed eq).

Turn key price includes slabs, grout for clarifier (if applicable) and installation and finish coating of equipment (if applicable). As we discussed these prices are for "conventional" single train, single clarifier units and will not meet FDEP class I, II or III Regulations. Mainly on clarifier requirements (multiple units).

FILTER PRICES include media. Coarse bubble diffusers for plants was utilized. Chain + sprocket drive w/ shear pin overload protection.


* Making changes such as: Aluminum wearlaunders or stainless steel air headers and drop pipes, direct drive clarifier drive and so forth can add significantly to the prices I have given - Please adjust accordingly.

Factory Built and Budget
 Davco Ring Steel ~~list~~ Costs

AIRBUC TUBE TANKS
 4 TANKS + C/C
 RING STEEL + PIPING
 EQUIPMENT

Capacity (gpd)	Extended Aeration		Contact Stabilization	
	Budget Price (\$)	Turn Key Install.	Budget Price (\$)	Turn Key Install.
10,000	36000	14000	N/A	N/A
25,000	60000	18000	N/A	N/A
50,000	110000	25000	65000	18000
75,000	150000	35000	100000	22000
100,000	175000	42000	125000	27000
150,000	140000	70000	120000	60000
250,000	175000	85000	155000	75000
500,000	250000	125000	215000	105000
750,000	300000	150000	250000	125000
1,000,000	350000	175000	280000	140000

FILTERS (NO INSTALLATION COSTS INCLUDED)



- 0 to .05 MG/D = 28000
- > .05 ≤ .10 MG/D = 40000
- > .10 ≤ .15 MG/D = 50000

- .25 MG/D = 55000 or 2 @ .2 MG/D = 107000
- .50 MG/D = 70000 or 2 @ .375 MG/D = 135000
- .75 MG/D = 85000 or 2 @ .56 MG/D = 145000
- 1.0 MG/D = 98000 or 2 @ .75 MG/D = 170000

APPENDIX B

**Package Wastewater Treatment Plants
Unit Costs**


Capacity (MGD)	Davco Con. Stab. (\$)	Sanitaire Con. Stab. (\$)	Total Con. Stab. Const. Cost (\$)	Overall Con. Stab. w/ Chlor. (\$)	Unit Cost (\$/Mgd)
0.010	--	--	--	--	
0.025	--	--	--	--	
0.050	83,000	112,350	97,675	127,675	2.5535
0.075	122,000	127,225	124,613	154,613	2.0615
0.100	152,000	152,321	152,161	187,161	1.8716
0.150	180,000	177,950	178,975	213,975	1.4265
0.250	230,000	244,320	237,160	272,160	1.0886
0.500	320,000	356,540	338,270	373,270	0.7465
0.750	375,000	466,160	420,580	455,580	0.6074
1.000	420,000	560,430	490,215	525,215	0.5252

Notes: 1) Values include materials, electrical, piping, installation, blowers, grading, chlorination feed sys., and conc. slab; but exclude land, engineering, fencing, paving, drainage, lighting, and building facilities.
All costs obtained from manufacturer's quotes and EPA cost curves.
Costs based on June 1995, ENR Index = 5433.

CURVE FORMULA (For any capacity on the curve)


$$Y = (0.5249354) * X^{(-0.5321867)}$$

Capacity (MGD)	Cost (\$)	Manuf. Cost (\$)
0.05	2.58522	2.554
0.065	2.24832	
0.075	2.08345	2.062
0.09	1.89079	
0.1	1.78769	1.872
0.115	1.65955	
0.13	1.55472	
0.15	1.44072	1.427
0.165	1.36946	
0.18	1.30749	
0.195	1.25297	
0.21	1.20451	
0.225	1.16109	
0.24	1.12189	
0.25	1.09778	1.089
0.265	1.06426	
0.28	1.03353	
0.295	1.00522	
0.31	0.97903	
0.325	0.95472	
0.34	0.93207	
0.355	0.9109	
0.37	0.89105	
0.385	0.87241	
0.4	0.85484	
0.415	0.83825	
0.43	0.82256	
0.445	0.80769	
0.46	0.79356	
0.475	0.78013	
0.49	0.76733	
0.5	0.75912	0.747
0.515	0.74727	
0.53	0.73594	
0.545	0.72509	
0.56	0.71469	
0.575	0.70471	
0.59	0.69511	
0.605	0.68589	
0.62	0.67701	
0.635	0.66845	
0.65	0.66019	
0.665	0.65223	
0.68	0.64453	
0.695	0.63709	
0.71	0.62989	
0.725	0.62292	
0.74	0.61617	
0.75	0.61178	0.607
0.765	0.60537	
0.78	0.59914	
0.795	0.5931	
0.81	0.58723	
0.825	0.58152	
0.84	0.57597	
0.855	0.57057	
0.87	0.56532	
0.885	0.5602	
0.9	0.55521	
0.915	0.55035	
0.93	0.54561	
0.945	0.54098	
0.96	0.53646	
0.975	0.53206	
1	0.52494	0.525



CONTACT STABILIZATION WWTP INFLECTION POINT

Capacity (GPD)	F'(x)
0.05	65.9752
0.075	60.0467
0.1	54.3818
0.15	43.8428
0.25	25.9278
0.5	-0.4082
0.75	-0.3852
1	25.997



CONTACT STABILIZATION, DIFFUSED AERATION

FACT SHEET 2.1.8

Description - Contact stabilization is a modification of the activated sludge process (described more completely in Fact Sheet 2.1.1). In this modification, the adsorptive capacity of the floc is utilized in the contact tank to adsorb suspended, colloidal, and some dissolved organics. The hydraulic detention time in the contact tank is only 30 to 60 minutes (based on average daily flow). After the biological sludge is separated from the wastewater in the secondary clarifier, the concentrated sludge is separately aerated in the stabilization tank with a detention time of 2 to 6 hours (based on sludge recycle flow). The adsorbed organics undergo oxidation in the stabilization tank and are synthesized into microbial cells. If the detention time is long enough in the stabilization tank, endogenous respiration will occur, along with a concomitant decrease in excess biological sludge production. Following stabilization, the re-aerated sludge is mixed with incoming wastewater in the contact tank and the cycle starts anew. Volatile compounds are driven off to a certain extent by aeration in the contact and stabilization tanks. Metals will also be partially removed, with accumulation in the sludge.

This process requires smaller total aeration volume than the conventional activated sludge process. It also can handle greater organic shock and toxic loadings because of the biological buffering capacity of the stabilization tank and the fact that at any given time the majority of the activated sludge is isolated from the main stream of the plant flow. Generally, the total aeration basin volume (contact plus stabilization basins) is only 50 - 75 percent of that required in the conventional activated sludge system. A description of diffused aeration techniques is presented in Fact Sheet 2.1.1.

Common Modifications - Used in a package treatment plant with clarification and chlorination facilities in one vessel. Other modifications include raw wastewater feed to aeration tank; flow equalization; integral aerobic digester.

Technology Status - Contact stabilization has evolved as an outgrowth of activated sludge technology since 1950 and seen common usage in package plants and some usage for on-site constructed plants.

Typical Equipment/No. of Mfrs. - Air diffusers/19; compressors/44; package treatment plants/21.

Applications - Wastewaters that have an appreciable amount of BOD₅ in the form of suspended and colloidal solids; upgrading of an existing, hydraulically overloaded conventional activated sludge plant; new installations, to take advantage of low aeration volume requirements; where the plant might be subject to shock organic or toxic loadings; where larger, more uniform flow conditions are anticipated (or if the flows to the plant have been equalized).

Limitations - It is unlikely that effluent standards can be met using contact stabilization in plants smaller than 50,000 gal/d without some prior flow equalization. Other limitations include operational complexity, high operating costs, high energy consumption and high diffuser maintenance. As the fraction of soluble BOD₅ in the influent wastewater increases, the required total aeration volume of the contact stabilization process approaches that of the conventional process.

Performance -

BOD ₅ Removal	80 to 95 percent
NH ₄ -N Removal	10 to 20 percent

Residuals Generated - See Fact Sheet 2.1.1.

Design Criteria (39) - A partial listing of design criteria for the contact stabilization process is summarized as follows:

F/M, lb BOD ₅ /d/lb MLVSS	0.2 to 0.6
Volumetric loading, lb BOD ₅ /d/1,000 ft ³	30 to 50 (based on contact and stabilization volume)
MLSS, mg/l	1,000 to 2,500, contact tank; 4,000 to 10,000, stabilization tank
Aeration time, h	0.5 to 1.0, contact tank (based on average daily flow)
	2 to 6, stabilization basin (based on sludge recycle flow)
Sludge retention time, days	5 to 10
Recycle ratio (R)	0.75 to 1.0
Std. ft ³ air/lb BOD ₅ removed	800 to 2,100
lb O ₂ /lb BOD ₅ removed	0.7 to 1.0
Volatile fraction of MLSS	0.6 to 0.8

Process Reliability - Requires close operator attention.


Environmental Impact - See Fact Sheet 2.1.1

References - 23, 26, 31, 39

CONTACT STABILIZATION, DIFFUSED AERATION

FACT SHEET 2.1.8

FLOW DIAGRAM





ENERGY NOTES - Assumptions: Air requirements are based on 2100 ft³/lb BOD₅ removed (2 lb BOD₅/1000 gal/d). Positive displacement blowers with 100% standby are provided. Electricity = \$0.03/kWh. Includes energy requirements for entire package plant.

$$\text{Cost Ratio} = \frac{5433}{2401} =$$


COSTS* - Assumptions: Costs are in 1976 dollars; DNS Index = 2401.

1. Construction cost is for package plants and includes tankage and equipment in place for aeration chambers, chlorination equipment, clarification and sludge stabilization. Costs include concrete and yardwork, 25% contingency, electrical and instrumentation, and contractor's overhead and profit at 25% of equipment costs but exclude land, engineering, legal or financing during construction.
2. O&M costs are based on a labor rate of \$9/hr, including fringe benefits, with 7 d/wk staffing and electricity @ \$0.03/kWh. Maintenance materials include chlorine.



unit cost

3.62
1.85
1.38
1.23
1.06
0.95



REFERENCE - 16

Cost	Update
160,000	362,044
245,000	554,388
305,000	690,156
380,000	859,867
470,000	1,063,594
640,000	1,400,758



FACSIMILE TRANSMISSION

IF TRANSMISSION WAS NOT PROPERLY RECEIVED, CALL (305) 755-2092

DATE: 7-6-95
 FROM: J. Kelly FAX NUMBER: (305) 341-9370
 TO: Jamie Walsh FAX NUMBER: _____
 COMPANY: Hartman NUMBER OF PAGES: 2
 REFERENCE: Package Plant Budget Pricing

I hope the attached is sufficient.
 Sanitair doesn't make the smaller plants.
 Please call if you have any questions.

J. Kelly

MUSKELLEY COURALS PRGS

PAGE 02

SANITAIRIE
Slab on Pile Steel List Costs

Capacity (MGD)	Extended Aeration		Contact Stabilization	
	List Price (\$)	Turn Key Install.	List Price (\$)	Turn Key Install.
10,000	φ		φ	
20,000	φ		φ	
30,000	\$ 82,000	\$ 110,000	\$ 75,000	\$ 100,000
40,000	\$ 100,000	\$ 135,000	\$ 81,000	\$ 109,000
50,000	\$ 115,000	\$ 155,000	\$ 96,000	\$ 130,000
60,000	\$ 142,000	\$ 192,000	\$ 109,000	\$ 148,000
70,000	\$ 185,000	\$ 240,000	\$ 148,000	\$ 200,000
80,000	\$ 268,000	\$ 360,000	\$ 215,000	\$ 290,000
90,000	\$ 325,000	\$ 440,000	\$ 260,000	\$ 350,000
1,000,000	\$ 385,000	\$ 520,000	\$ 308,000	\$ 415,000

↑
Blowers, concrete slab not included.

941 644 6319

P. 01



1828 Metcalf Ave.
 Thomasville, Georgia 31792
 Phone 912-226-5733
 Telefax No.
 912-228-0312

FACSIMILE TRANSMITTAL SHEET

From: Tommy Tyson
 Phone 941-646-7694
 Fax. 941-644-6319

To: HAI - Jamie Wallace Re: Budget Estimates

Fax. number: 407-839-3790 Date: 7-2-95

Total number of pages including this page is: 2

REMARKS:

Budget estimates are for "DAVCO standard" equipment delivered to central Florida. DAVCO std. is Aluminum grating and aluminum handrails. Also depending on size, duplex OR triplex rotary positive blowers and controls are included. I have not included any accessories such as comminutor, flowmeter or telemetry equipment (or cl₂ feed eq).

Turn key price includes slabs, grout for clarifier (if applicable) and installation and finish coating of equipment (if applicable). As we discussed these prices are for "conventional" single train, single clarifier units and will not meet FDEP class I, II or III Regulations. Mainly on clarifier requirements (multiple units).

FILTER PRICES include media. Coarse bubble diffusers for plants was utilized. Chain + sprocket drive w/ shear pin overload protection.

* Making changes such as: Aluminum weir launders or stainless steel air headers and drop pipes, direct drive clarifier drive and so forth can add significantly to the prices I have given - Please Adjust accordingly.

FACTORY BUILT AND BUDGET
 Davco Ring Steel ~~Costs~~ Costs

	Extended Aeration			Contact Stabilization	
	Capacity (gpd)	Budget Price (\$)	Turn Key Install.	Budget Price (\$)	Turn Key Install.
Equipment ADVANCED TUBE BANKS 4 PHASED A CEC	10,000	30000	14000	N/A	N/A
	25,000	60000	18000	N/A	N/A
	50,000	110000	25000	65000	18000
	75,000	150000	35000	100000	22000
	100,000	175000	42000	125000	27000
Equipment FINISH COATED EQUIPMENT 7 PHASED A CEC	150,000	140000	70000	120000	60000
	250,000	175000	85000	155000	75000
	500,000	250000	125000	215000	105000
	750,000	300000	150000	250000	125000
	1,000,000	350000	175000	280000	140000

FILTERS (NO INSTALLATION COSTS INCLUDED)

TES FILTER	0 to .05 MGD = 28000
	> .05 ≤ .10 MGD = 40000
	> .10 ≤ .15 MGD = 50000
AVELING BRIDGE FILTER	.25 MGD = 55000 OR 2 @ .2 MGD = 107000
	.50 MGD = 70000 OR 2 @ .375 MGD = 135000
	.75 MGD = 85000 OR 2 @ .56 MGD = 145000
	1.0 MGD = 98000 OR 2 @ .75 MGD = 170000

APPENDIX C


**Sutorbilt
Positive Displacement Blowers
Construction Costs**

Capacity @ 7 psig (scfm)	Motor Size (HP)	P.D. Blower Cost (\$)	Blower Unit Cost (\$/scfm)
50	5	2,450	49
100	5	2,625	26.25
250	15	3,950	15.8
500	25	5,625	11.25
750	40	9,600	12.8
1,000	50	10,000	10
1,250	60	13,850	11.08
1,500	75	16,225	10.81666667
1,750	75	17,675	10.1
2,000	100	21,000	10.5
2,500	125	25,000	10
3,000	150	32,500	10.83333333
3,500	200	40,000	11.42857143
4,000	200	48,000	12
4,500	200	52,000	11.55555556

- NOTES:
- 1) All costs obtained from manufacturer's quotes.
 - 2) Costs include blower, TEFC motor, steel base, silencers, relief valve, pressure gauge, and check valve.
 - 3) Costs are based on June 1995, ENR Index = 5433.

POSITIVE DISPLACEMENT BLOWER INFLECTION POINT

Capacity (scfm)	F*(x)
50	0.00235
100	0.001796
250	0.000657
500	-4.4E-05
750	-4.2E-05
1000	6.29E-05
1250	1.64E-05
1500	-8.9E-05
1750	0.000184
2000	0.001623



Sutorbilt
Positive Displacement Blowers
Construction Costs

<u>Capacity @ 7 psig (scfm)</u>	<u>Motor Size (HP)</u>	<u>P.D. Blower Complete Package Cost (\$)</u>
50	5	2,450
100	5	2,625
250	15	3,950
500	25	5,625
750	40	9,600
1,000	50	10,000
1,250	60	13,850
1,500	75	16,225
1,750	75	17,675
2,000	100	21,000
2,500	125	25,000
3,000	150	32,500
3,500	200	40,000
4,000	200	48,000
4,500	200	52,000

Hoffman
Centrifugal Blowers
Construction Costs

Capacity @ 7 psig (scfm)	Motor Size (HP)	Cent. Blower Cost (\$)	Cent. Blower Unit Cost (\$/scfm)
500	40	14,500	29
750	50	16,500	22
1,000	60	17,500	17.5
1,250	75	18,500	14.8
1,500	100	19,500	13
1,750	100	26,000	14.857143
2,000	100	26,000	13
2,500	125	27,000	10.8
3,000	150	32,000	10.666667
3,500	150	32,000	9.1428571
4,000	200	37,000	9.25
4,500	200	37,000	8.2222222

NOTES:


- 1) All costs obtained from manufacturer's quotes.
- 2) Costs include blower and TEFC motor.
- 3) Costs are based on June 1995, ENR Index = 5433.

CURVE EQUATION:

$$Y = (12737.73) + (1.53442)X + (4.66622E-03)X^2 + (-1.435126E-06)X^3 + (1.319283E-10)X^4$$

*** For Unit costs, just divide the output by the blower capacity.

Capacity @ 7 psig (scfm)	Cent. Blower Unit Cost (#/scfm)	Manuf. Blower Unit Cost
500	29.0009	29
600	25.07579	
750	21.26643	22
850	19.53076	
950	18.19376	
1000	17.63557	18
1100	16.68655	
1250	15.57317	15
1350	14.97879	
1500	14.2424	13
1600	13.82855	
1750	13.29169	15
1850	12.97653	
1950	12.68767	
2000	12.55145	13
2100	12.29279	
2200	12.04963	
2300	11.81915	
2400	11.59915	
2500	11.38791	11
2600	11.18408	
2700	10.98665	
2800	10.79485	
2900	10.60813	
3000	10.42613	10.66667
3100	10.24861	
3200	10.07549	
3300	9.906776	
3400	9.742579	
3500	9.583081	9.142857
3600	9.428531	
3700	9.27924	
3800	9.135568	
3900	8.997919	
4000	8.866736	9.25
4100	8.742496	
4200	8.625707	
4300	8.516901	
4400	8.416636	
4500	8.325491	8.222222



Hoffman
Centrifugal Blowers
Construction Costs

<u>Capacity @ 7 psig (scfm)</u>	<u>Motor Size (HP)</u>	<u>Centrifugal Blower Complete Package Cost (\$)</u>
50	--	--
100	--	--
250	--	--
500	40	14,500
750	50	16,500
1,000	60	17,500
1,250	75	18,500
1,500	100	19,500
1,750	100	26,000
2,000	100	26,000
2,500	125	27,000
3,000	150	32,000
3,500	150	32,000
4,000	200	37,000
4,500	200	37,000

the JACOBS GROUP, inc.

160 SCARLET BOULEVARD • OLDSMAR, FLORIDA 34677 • (813) 854-5297 • FAX (813) 855-8821

FAX TRANSMITTAL SHEET

TO: Jamey Wallace FROM: John Verscharen
 COMPANY: Hartman & Associates DATE: 7-12-95
 FAX NO.: 407-839-3790 PAGES (INCLUDING COVER): 4
 SUBJECT: Blower Budget Estimates

MESSAGE: See rough blower budget estimates
attached.

06/26/85 13:00 407 838 3780

HARIMAN ASSOC

P.C. 2002

Hoffman
 ↓
 Centrifugal & Positive Displacement Blower
 List Cost

Sutorbitt


TEFC motor

Budget Price for
 Package as shown

Budget Price for Filter
 Blower + Motor (TEFC
 only)

Capacity @ 7 psig (acfm)	Motor Size (HP)	Positive Displacement Complete Package Cost (\$)		Centrifugal Complete Package Cost (\$)
80	5	2450.00		N/A
100	5	2625.00		N/A
250	15	3950.00		N/A
500	25	5625.00	40	14,500.00
750	40	9600.00	50	16,500.00
1000	50	10,000.00	60	17,500.00
1250	60	13,850.00	75	18,500.00
1500	75	16,225.00	100	19,500.00
1750	75	17,675.00	100	20,000.00
2000	100	21,000.00	100	26,000.00
2500	125	25,000.00	125	27,000.00
3000	150	32,500.00	150	32,000.00
3500	200	40,000.00	150	32,000.00
4000	200	48,000.00	200	37,000.00
4500	200	52,000.00	200	37,000.00

Notes: (Any extra costs needed) 1) P.D.'s require B.V.'s
 2) Centrifugal requires C.U.'s and B.V.'s



Universal Blower Pac, Inc.



EXPRESS BLOWER PAC

For more than a decade, you've counted on **UNIVERSAL BLOWER PAC, INC.** for quality and economy. With the **EXP** package, **EXPRESS** delivery is added to the same high standards without **EXPRESS**-related charges. This standard, pre-engineered **EXP** unit has an **EXPRESS** delivery time of ten to twenty days with drawings available for **EXPRESSING** on the same day as purchase. **EXP** units feature **EXPRESS** installation since all parts are assembled as a complete package.

STANDARD **EXP** FEATURES


- Featuring Sutorbilt Blowers
- Heavy duty steel base
- Dual take-up motor rails
- High efficiency electric motor
- Premium absorptive & chamber/absorptive silencers
- Dual silencer supports w/ holding straps
- V-belt drive 1.5 S.F.
- Tool gray machinery enamel paint
- Spring-loaded relief valve set at maximum blower pressure
- Pressure gauge w/ snubber & petcock protection
- Check valve w/ EPDM seal & stainless steel spring
- Rugged flex joints
- Inlet filter w/ weatherhood
- EZ access belt guard
- Completely assembled units

JUL 12 1981 10:01 AM



BLOWER	A _T	A _B	B	C	D	E	F	G	H	I	J	K*	WEIGHT
2ML	**	33.5	35	24	17.5	40	33.5	10	10	8	1.5	1.25	300
2LL	**	46.5	34	24	17.5	40	33.5	8.5	10	8	2	2	300
3HL	**	39	60	24	17.5	40	33.5	8.5	10	8	2	1.5	400
3ML	**	46.5	62	24	17.5	40	33.5	8.5	10.5	8	2.5	2	400
3LL	**	56.5	73	24	17.5	40	33.5	8.5	12	8	3	2.5	450
4HL	**	47.5	64	34	26	50	41	9	14	9	2.5	2	550
4ML	**	57.5	75	34	26	50	41	10	14	9	3	2.5	650
4LL	**	61.5	82	34	26	50	41	8.5	15	9	3.5	3	750
5HL	**	59	76	34	26	50	41	10	14	10.5	3	2.5	900
5ML	**	62	84	34	26	50	41	8	15	10.5	3.5	3	1000
5LL	80	70.5	60	34	26	50	41	13.5	17	10.5	5	4	1200
6HL	**	64.5	87	34	26	50	41	9	14	12	3.5	3	1350
6ML	81	72	61	34	26	50	41	12	15	12	5	4	1600
6LL	75	65	85	38	28	60	48	13.5	19	15	6	6	1900
7HL	70	77	64	38	28	60	48	13	18	15	4	4	1850
7ML	75	85.5	82	38	28	60	48	17	18	15	6	5	2300
7LL	96	79	99	44	38.5	72	62.5	13.5	22	15	8	8	2800
8HL	84	75	70	44	36.5	72	62.5	14	20	15	5	4	2450
8ML	96	65	102	44	36.5	72	62.5	14.5	20	15	8	6	3400
8LL	97	79	110	44	36.5	72	62.5	17.5	22	15	10	8	4150

* 1"-5" are MPT, 6"-10" are 125/150 lb. ANSI flange.
 ** Inlet silencer is in vertical position.
 All mounting holes are 5/8" diameter.
 Dimensional tolerance to mounting holes is +/- 1/4".
 Other dimensions are nominal, request certified drawing.



UNIVERSAL BLOWER PAC, INC.
 440 PARK 32 WEST DRIVE
 NOBLESVILLE, IN 46080-9252
 Phone: 317/773-7256
 Fax: 317/776-5086

APPENDIX D

**Davco
Wastewater Treatment Filters
Construction & Unit Costs**


<u>Capacity (GPD)</u>	<u>Type of Filter</u>	<u>Filter Cost (\$)</u>	<u>Filter (1) Construction Cost (\$)</u>	<u>Unit Cost (\$/gal)</u>
50,000	Gravity	29,000	46,400	0.928
100,000	Gravity	41,500	66,400	0.664
150,000	Gravity	54,000	86,400	0.576
250,000	Traveling Bridge	76,500	122,400	0.4896
500,000	Traveling Bridge	91,000	145,600	0.2912
750,000	Traveling Bridge	105,500	168,800	0.22506667
1,000,000	Traveling Bridge	119,000	190,400	0.1904

- NOTES:
- (1) Filter and media costs obtained from manufacturer's quotes.
 - (2) Costs include filter, media, 15% piping, 15% electrical, 5% sitework, 20% installation, and 5% for the concrete slab.
 - (3) Costs are based on June 1995, ENR Index = 5433.

CURVE EQUATION


$Y = (0.1940938)X^{(-0.5751405)}$

Capacity (MGD)	Unit Cost (\$/Gal)	Manuf. Unit Cost (\$/Gal)
0.050	1.087	0.928
0.100	0.730	0.664
0.150	0.578	0.576
0.200	0.490	
0.250	0.431	0.490
0.300	0.388	
0.350	0.355	
0.400	0.329	
0.450	0.307	
0.500	0.289	0.291
0.550	0.274	
0.600	0.260	
0.650	0.249	
0.700	0.238	
0.750	0.229	0.225
0.800	0.221	
0.850	0.213	
0.900	0.206	
0.950	0.200	
1.000	0.194	0.190



TERTIARY FILTER INFLECTION POINT

Capacity (MGD)	F''(x)
0.025	332.944256
0.05	253.868194
0.1	134.067582
0.15	56.3672339
0.25	-10.894528
0.5	11.35955
0.75	-12.063528
1	136.3878



Davco
Wastewater Treatment Filters
Construction Costs

<u>Capacity (GPD)</u>	<u>Type of Filter</u>	<u>Filter Cost (\$)</u>	<u>Filter (1) Construction Cost (\$)</u>
50,000	Gravity	29,000	46,400
100,000	Gravity	41,500	66,400
150,000	Gravity	54,000	86,400
250,000	Traveling Bridge	76,500	122,400
500,000	Traveling Bridge	91,000	145,600
750,000	Traveling Bridge	105,500	168,800
1,000,000	Traveling Bridge	119,000	190,400

- NOTES: (1) Values obtained from manufacturer's quotes.
(2) Costs include filter, media, 15% piping, 15% electrical, 5% sitework, 20% installation, and 5% for the concrete slab.

RECORD OF TELEPHONE COMMUNICATIONDATE: 10/19 TIME: 2:15PROJECT NAME: SSU - Economy of Scale PROJECT NO.: 95-145.00PARTY CALLING: Janey Wallace COMPANY: HAIPARTY CONTACTED: Jim Kelley (Party) COMPANY: Mass-KelleySUBJECT: Tertiary treatment filter costs**TELEPHONE COMMUNICATION SUMMARY (Including Decisions & Commitments)**

Package Gravity Filter	50,000 GPD → \$30,000	} Freight to job site
	100,000 GPD → \$33,000	
	150,000 GPD → \$58,000	

) ABW (Travelling Bridge)

6x16 0.25 MGD → (Steel) \$98,000

9x20 0.5 MGD → (S) \$112,000 (Concrete) \$92,000


9x30 0.75 MGD → (S) \$126,000 (C) \$101,000

9x40 1.0 MGD → (S) \$140,000 (C) \$110,000

ACTION REQUIRED

HARTMAN & ASSOCIATES, INC.

engineers, hydrogeologists, scientists & management consultants



1828 Metcalf Ave.
 Thomasville, Georgia 31792
 Phone 912-226-5733
 Telefax No.
 912-228-0312

FACSIMILE TRANSMITTAL SHEET

From: Tommy Tyson
 Phone 941-646-7694
 Fax. 941-644-6319

To: HAI - Jamie Wallace Re: Budget Estimates

Fax number: 407-839-3190 Date: 7-2-95

Total number of pages including this page is: 2

REMARKS:

Budget estimates are for "DAVCO standard" equipment delivered to central Florida. DAVCO std. is Aluminum grating and aluminum handrails. Also depending on size, duplex or triplex rotary positive blowers and controls are included. I have not included any accessories such as comminutor, flowmeter or telemetry equipment (or cl2 feed eq).

Turn key price includes slabs, grout for clarifier (if applicable) and installation and finish coating of equipment (if applicable). As we discussed these prices are for "conventional" single train, single clarifier units and will not meet FDEP class I, II or III Regulations. Mainly on clarifier requirements (multiple units).

FILTER PRICES include media. Coarse bubble diffusers for plants was utilized. Chain & sprocket drive w/ shear pin overload protection.

* Making changes such as: Aluminum weir launders or stainless steel air headers and drop pipes direct drive clarifier drive and so forth can add significantly to the prices I have given - Please adjust accordingly.

FACTORY BUILT and Budget
 Davco Ring Steel ~~list~~ Costs

	Extended Aeration			Contact Stabilization	
	Capacity (gpd)	Budget Price (\$)	Turn Key Install.	Budget Price (\$)	Turn Key Install.
	10,000	36000	14000	N/A	N/A
	25,000	60000	18000	N/A	N/A
	50,000	110000	25000	65000	18000
	75,000	150000	35000	100000	22000
	100,000	175000	42000	125000	27000
	150,000	140000	70000	120000	60000
	250,000	175000	85000	155000	75000
	500,000	250000	125000	215000	105000
	750,000	300000	150000	250000	125000
	1,000,000	350000	175000	280000	140000

FACTORY BUILT - PAINTED
 Equipment
 AIRLIFT TUBE TANKS
 4 TUBES PER A CEC
 FIELD ERUPTED AND PIP
 FILM COATED EQUIPMENT
 Ring Steel - a Division

FILTERS (NO INSTALLATION COSTS INCLUDED)

	0 to .05 MGD = 28000
TES FILTER	> .05 ≤ .10 MGD = 40000
	> .10 ≤ .15 MGD = 50000
	.25 MGD = 55000 or 2 @ .2 MGD = 107000
	.50 MGD = 70000 or 2 @ .375 MGD = 135000
LEVELING BRIDGE FILTER	.75 MGD = 85000 or 2 @ .56 MGD = 145000
	1.0 MGD = 98000 or 2 @ .75 MGD = 170000

APPENDIX E

**Wastewater Treatment Systems
Chlorine Feed Systems
Unit Costs**

<u>Chlorine Feed Rate (lb/day)</u>	<u>System Type (150# or 1 ton)</u>	<u>Package Cost (\$)</u>	<u>Treatment Capacity (Mgd)</u>	<u>Overall Construction Cost (\$)</u>	<u>Unit Cost \$</u>
100	150 lb. (1)	16,400	0.01	25,420	2.54
200	150 lb.	17,600	0.50	27,280	0.05
500	1 Ton (2)	52,200	1.00	80,910	0.08
1,000	1 Ton	63,900	2.00	99,045	0.05
2,000	1 Ton	71,145	5.00	110,275	0.02

NOTES:

- (1) The 150 lb facilities are equipped with a 25 square foot shelter.
- (2) The Ton systems are equipped with a 400 square foot shelter which consists of a concrete base, steel supports, a fiberglass panel roof, and an overhead crane.
- (3) Costs include dual chlorinators w/ switchover, dual scales, gas detector, alarm panel, vacuum switch, booster pump, housing, and hoists all are included in the manufacturer's quotes.
- (4) Includes 20% electrical, 15% piping, and 20% installation costs.
- (5) Costs are based on June 1995, ENR Index = 5433.



1865 N. SEMORAN BOULEVARD
 SUITE NO. 240
 WINTER PARK, FLORIDA 32792
 PHONE: (407) 879-1333
 FAX: (407) 857-8880

July 5, 1995

Hartman & Associates, Inc.
 201 East Pine St.
 Suite 1000
 Orlando, FL 32801

Attention: Jamey Wallace

Subject: Wallace & Tiernan
 Chlorination System

Dear Jamey:

In response to your request for an estimate for Wallace & Tiernan Chlorine Gas Vacuum Systems with manual chlorinators, injectors, gas handling fixtures, cylinder scales, booster pump, gas detector and miscellaneous safety items, pricing is as follows:

<u>Chlorinator Model</u>	<u>Feed Rate Per Day</u>	<u>Gas Supply</u>	<u>Estimated Cost</u>
V-500	100	150# Cylinder	\$ 22,300
V-500	200	150# Cylinder	\$ 23,200
V-500	500	Ton Cylinder	\$ 25,600
V-2000	1000	Ton Cylinder	\$ 41,800
V-2000	2000	Ton Cylinder	\$ 44,900

For the 150# cylinder systems, I have included a standard 4x6 FRP building with appropriate fixtures and safety devices. For the ton cylinder units, a facility for handling ton cylinders will be required. Also, you will find the scales required for the 150# systems are included along with the ton cylinder scales to be mounted in your handling facility.

SENT BY TELETYPE WINTER PARK 7/11/95 10:45 AM HEYWARD WINTER PARK 407 833 3730-272


Jamey Wallace
July 5, 1995
Page 2

The above are basic equipment costs and can be utilized for basic estimates. Please advise if any additional peripheral equipment is required, such as chlorine analyzers or pH recorders.

I have included the two (2) basic chlorinator sales information bulletins and can elaborate on other equipment if you require. Thank you very much.

Kindest regards,

HEYWARD INCORPORATED - FOR
WALLACE & TIERNAN, INC.



Richard E. Neal
Winter Park Office

REN/gl

Enclosure

20% Elect.
15% Pipe
10% ENG
10% Site work

Chlorine TON Storage Bldg *

Capital Controls Chlorine Feed System
List Costs

20'x20' concrete, fiberglass panels, overhead crane
(2/92) concrete - 22,000
structural steel - 10,000
fiberglass - 7,800
overhead crane - 3,500
Painting - 4,000
37,300

Type: Gas Chlorination => Includes: Dual trunnions, Dual chlorinators, Auto Switch over, Ejector, Booster pump, FRP housing (150 lb system), Leak detector, etc.

Chlorine Feed Rate (lb/day)	Type of System (150 lb cyl.) or (1 ton)	Package Cost (\$)
100 ⑥	150 #	10,500 -
150 ①	150 #	12,000 -
200 ②	TON	18,200 -
500 ②	TON	18,800 -
1000 ③	TON	26,000 -
2000 ③	TON	37,390 -

Note: (Any extra costs needed).

- ① 100/200 PPD, 150 # CYL SYSTEMS INCLUDE: COMPLETE CHLORINATION w/ SWITCHOVER EJECTOR, GAS DETECTOR, DUAL SCALE, ALARM PANEL, VACUUM SWITCH, BOOSTER PUMP, 5' X 5' FIBERGLASS SHELTER (2 CONTAINER MANIFOLD ON 200 PPD)
- ② 200/500 PPD, TON SYSTEMS INCLUDE: ALL OF ABOVE EXCEPT FIBERGLASS SHELTER BUT DUAL GAS DETECTORS, (2) TON SCALE, (2) PAIR TON STORAGE TRUNNIONS.
- ③ 1000/2000 PPD SYSTEMS INCLUDE: ALL OF ABOVE BUT (2) TWO TON MANIFOLD (1000 PPD) OR (2) 4-TON MANIFOLD (2000 PPD), WALL MOUNTED CHLORINATOR CABINET, (2) DUAL TON SCALES (1000 PPD) OR (2) 4-TON SCALES (2000 PPD), (4) PAIR STORAGE TRUNNIONS.

HARTMAN & ASSOCIATES, INC. engineers, hydrogeologists, surveyors & management consultants	SH. NO: 1	JOB NO: 95-145.00
	MADE BY: JSW	DATE:
	CHECKED BY:	DATE:

Chlorination Curve! (wastewater)

Values 1,000,000 Gallon/Day and less ⇒ 150 lb cylinders
>1,000,000 GPD ⇒ ton cylinders

MANUFACT INFO	10,000 ⇒ \$ 2.54	1,000,000 ⇒ \$ 0.081
	20,000 ⇒ \$ 1.27	1,500,000 ⇒ \$ 0.06
	50,000 ⇒ \$ 0.51	2,000,000 ⇒ \$ 0.0495
	100,000 ⇒ \$ 0.25	3,000,000 ⇒ \$ 0.033
	200,000 ⇒ \$ 0.14	4,000,000 ⇒ \$ 0.027
	500,000 ⇒ \$ 0.055	5,000,000 ⇒ \$ 0.022
	750,000 ⇒ \$ 0.036	
	1,000,000 ⇒ \$ 0.027	


EPA INFO	10,000 ⇒ \$ 3.5	1,500,000 ⇒ \$ 0.073
	20,000 ⇒ \$ 2.0	2,000,000 ⇒ \$ 0.063
	50,000 ⇒ \$ 0.90	3,000,000 ⇒ \$ 0.048
	100,000 ⇒ \$ 0.46	4,000,000 ⇒ \$ 0.04
	200,000 ⇒ \$ 0.25	5,000,000 ⇒ \$ 0.034
	500,000 ⇒ \$ 0.14	
	750,000 ⇒ \$ 0.11	
	1,000,000 ⇒ \$ 0.095	

Notes: Same as before except

2nd Source is

EPA Wastewater Source E, pages 19-21.


GRAPH #4
Chlorine Feed Systems



150 lb cylinders 1 ton cylinders

GRAPH #33

Chlorination Feed System



Note: Source E, Figure 10, pp. 19-21.

* Everything included.

**Water Treatment Systems
Chlorine Feed Systems
Unit Costs**

Chlorine Feed Rate (lb/day)	System Type (150# or 1 ton)	Package Cost (\$)	Treatment Capacity (Mgd)	Overall Construction Cost (\$)	Unit Cost \$
100	150 lb. (1)	16,400	0.01	25,420	2.54
200	150 lb.	17,600	0.20	27,280	0.14
500	1 Ton (2)	52,200	2.00	80,910	0.04
1,000	1 Ton	63,900	4.00	99,045	0.02
2,000	1 Ton	71,145	5.00	110,275	0.02

NOTES:

- (1) The 150 lb facilities are equipped with a 25 square foot shelter.
- (2) The Ton systems are equipped with a 400 square foot shelter which consists of a concrete base, steel supports, a fiberglass panel roof, and an overhead crane.
- (3) Costs include dual chlorinators w/ switchover, dual scales, gas detector, alarm panel, vacuum switch, booster pump, housing, and hoists all are included in the manufacturer's quotes.
- (4) Includes 20% electrical, 15% piping, and 20% installation costs.
- (5) Costs are based on June 1995, ENR Index = 5433.

HARTMAN & ASSOCIATES, INC. engineers, hydrogeologists, surveyors & management consultants	SRL NO.: <u>1</u>	JOB NO.: <u>95-146.00</u>
	MADE BY: <u>JJW</u>	DATE: <u> </u>
	CHECKED BY: <u> </u>	DATE: <u> </u>

Chlorination Curve (Water)

Values 2,000,000 Gallon/Day and less ⇒ 150 lb cylinders
 > 2,000,000 Gallon/Day ⇒ ton cylinders

MANUFACT. INFO.	10,000	⇒ \$ 2.54	1,500,000	⇒ \$ 0.02
	20,000	⇒ \$ 1.27	2,000,000	⇒ \$ 0.015
	50,000	⇒ \$ 0.51	2,000,000	⇒ \$ 0.04
	100,000	⇒ \$ 0.25	3,000,000	⇒ \$ 0.028
	200,000	⇒ \$ 0.12	4,000,000	⇒ \$ 0.023
	500,000	⇒ \$ 0.055	5,000,000	⇒ \$ 0.02
	750,000	⇒ \$ 0.036		
	1,000,000	⇒ \$ 0.027		

Values are on Costs of System limited by Capacity of System


EPA INFO	10,000	⇒ \$ 2.0	1,000,000	⇒ \$ 0.067
	20,000	⇒ \$ 0.98	1,500,000	⇒ \$ 0.056
	50,000	⇒ \$ 0.392	2,000,000	⇒ \$ 0.049
	100,000	⇒ \$ 0.196	3,000,000	⇒ \$ 0.04
	200,000	⇒ \$ 0.137	4,000,000	⇒ \$ 0.037
	500,000	⇒ \$ 0.0924	5,000,000	⇒ \$ 0.032
	750,000	⇒ \$ 0.077		
	1,000,000	⇒ \$ 0.067		

Notes: ① All values include sitework, piping, electrical, installation, and storage-feed facilities.

② Values obtained from Manufacturers cost estimates and EPA Water Source B, pages 13-14.

GRAPH #4

Chlorine Feed Systems



150 lb cylinders 1 ton cylinders

APPENDIX F

Standby Generator Set
Construction Costs

Capacity (KW)	Ringhaver GenSet Cost (\$)	Cummins GenSet Cost (\$)	GenSet Cost (\$)	GenSet Unit Cost (\$/KW)
8	\$8,800	\$7,524	\$8,162	\$1,088.27
15	\$9,550	\$11,357	\$10,454	\$696.90
25	\$11,000	\$12,760	\$11,880	\$475.20
35	\$12,000	\$13,629	\$12,815	\$366.13
50	\$13,700	\$16,152	\$14,926	\$298.52
75	\$15,400	\$19,666	\$17,533	\$233.77
100	\$19,000	\$22,378	\$20,689	\$206.89
150	\$22,400	\$29,137	\$25,769	\$171.79
200	\$24,400	\$35,947	\$30,174	\$150.87
250	\$27,300	\$40,773	\$34,037	\$136.15
300	\$33,500	\$46,175	\$39,838	\$132.79
350	\$36,000	\$51,396	\$43,698	\$124.85
400	\$42,200	\$66,818	\$54,509	\$136.27
500	\$60,500	\$93,896	\$77,198	\$154.40
600	\$72,600	\$102,521	\$87,561	\$145.93
750	\$95,000	\$135,697	\$115,349	\$153.80
1,000	\$130,000	\$165,798	\$147,899	\$147.90
1,250	\$168,000	\$215,888	\$191,944	\$153.56
1,500	\$192,000	\$265,200	\$228,600	\$152.40

- NOTES:
- 1) All costs obtained from manufacturer's quotes.
 - 2) Costs include a packaged diesel electric set with base, a unit mounted radiator cooling system, and a control panel.
 - 3) Costs are based on December 1995, ENR Index = 5471.

01/23/1998 10:22

4070000740
4074000024

UNIT CONDOLITING
INTERIOR POWER SYSTEM


PAGE 03
PAGE 04

UNIT RATING (KW)	BUDGET PRICING
8	\$6,800
12.5	\$9,100
17.5	\$10,000
25	\$11,000
35	\$12,000
50	\$13,700
75	\$15,400
100	\$19,000
150	\$22,400
200	\$24,400
250	\$27,300
300	\$33,500
350	\$36,000
400	\$42,200
500	\$60,500
600	\$72,600
750	\$95,000
1000	\$130,000
1250	\$168,000
1500	\$192,000
1750	\$262,000
2000	\$294,000




PAGE 04

Generator Cost



Generator Unit Cost



01/20/1996 21:47 4075050148
From: RICK COOPER To: PETE HOANSHELT

EMI CONSULTING
Date: 1/31/96 Time: 21:30:20

F40r 21
Page 1 of 1

CUMMINS SOUTHEASTERN POWER INC.
4820 North Orange Blossom Trail
Orlando, Fla. 32810
(407) 298-2080 (Rick Cooper) FAX (407) 290-8727

FACSIMILE COVER LETTER

Date: 1/31/96
Company Name: EMI
FAX Number: 359-0748
Attention: PETE HOANSHELT
Subject: GENSET PRICING

Post-It™ Fax Note	7571	Date		# of pages ▶	1
To	James Wallace	From	Pete Hoanshelt		
Co./Dept.	HAI/EMI	Co	EMI		
Phone #		Phone #	359-0747		
Fax #		Fax #	359-0748		

PER YOUR REQUEST:

KW	PRICING	KW	PRICING
7.5	7,524	15	11,357
20	11,773	25	12,780
35	13,829	40	14,640
50	18,152	80	19,668
100	22,378	150	28,137
200	35,947	250	40,773
300	46,175	350	51,398
400	66,818	500	83,896
600	102,521	750	135,897
1000	165,798	1250	215,888
1500	265,200		

USE THIS INFORMATION WITH DISCRETION

IF I CAN BE OF ANY HELP WITH SPEC WRITING OR GENSIZING CALL ME AT YOUR CONVENIENCE regards;

Rick Cooper

Rick G. Cooper
Energy System Sales Manager 813-664-5831

REPLY NEEDED YES ___ NO ___ AS SOON AS POSSIBLE ___ AT YOUR CONVENIENCE ___

This transmission consists of ___ pages, including this cover letter. If you do not receive all of the pages please notify our office at: 298-2080 OR FAX 290-8727

APPENDIX G

Prestressed Concrete Ground Storage Tanks
Construction & Unit Costs

Volume (Gal)	Uninstalled (1) Tank Cost (\$)	Installed (2) Tank Cost (\$)	w/ 1000 gpm Aerator (\$)	w/ 4000 gpm Aerator (\$)	Overall Cost (\$)	Overall Unit Cost (\$/Gal)
50,000	70,900	77,990	96,034	112,188	104,111	2.08221
100,000	92,500	101,750	120,010	136,164	128,087	1.280865
300,000	149,540	164,494	183,324	199,478	191,401	0.638003
750,000	226,000	248,600	268,195	284,349	276,272	0.368362
1,000,000	268,200	295,020	315,037	331,191	323,114	0.323114
1,500,000	344,150	378,565	399,341	415,495	407,418	0.271612
2,000,000	412,500	453,750	475,210	491,364	483,287	0.241643

NOTES:


- (1) Prestressed concrete tank, concrete floor, prestressed wall, free-span concrete dome, aluminum interior and exterior ladders, vents, precast overflows, painting, aeration unit, and installation costs are included in the manufacturer's quotations.
- (2) Includes 5% piping, 0% electrical, and 5% sitework costs.
- (3) Costs are based on June 1995, ENR Index = 5433.

UNIT COST CURVE & GRAPH

CURVE EQUATION:

$$Y = (1087.291)X^{(-0.5849418)}$$


Capacity (MGD)	Cons. Cost (\$)	Manuf. Cost (\$)
50000	1.941743	2.08221
75000	1.531815	
100000	1.294604	1.280865
125000	1.136213	
150000	1.021295	
175000	0.93325	
200000	0.863141	
225000	0.805686	
250000	0.757539	
275000	0.716468	
300000	0.68092	0.638003
325000	0.64978	
350000	0.622219	
375000	0.597612	
400000	0.575476	
425000	0.555429	
450000	0.537169	
475000	0.520449	
500000	0.505068	
525000	0.49086	
550000	0.477685	
575000	0.465427	
600000	0.453985	
625000	0.443275	
650000	0.433223	
675000	0.423765	
700000	0.414847	
725000	0.40642	
750000	0.398441	0.368362
775000	0.390873	
800000	0.383683	
825000	0.376839	
850000	0.370317	
875000	0.364092	
900000	0.358143	
925000	0.352449	
950000	0.346995	
975000	0.341763	
1000000	0.33674	0.323114
1100000	0.318483	
1200000	0.302682	
1300000	0.288839	
1400000	0.276588	
1500000	0.26565	0.271612
1600000	0.25581	
1700000	0.246899	
1800000	0.238782	
1900000	0.231349	
2000000	0.224512	0.241643



INFLECTION POINT OF PRESTRESSED GST

Prestressed Concrete GST's

Capacity (GPD)	F''(x)
50000	6.86E-11
100000	5.41E-11
300000	1.64E-11
500000	1.32E-12
600000	-1.09E-12
750000	-1.26E-12
1000000	1.26E-12
1500000	-1.15E-12
2000000	1.68E-11



•••• The y-axis values on the graphic are the same as f''(x) listed; however, you must choose the graphic window to see the values listed on the y-axis.

HARTMAN & ASSOCIATES, INC. engineers, hydrogeologists, surveyors & management consultants	SH. NO.:	JOB NO.:
	MADE BY:	DATE:
	CHECKED BY:	DATE:

Ground Storage Tanks: (Concrete)

	Volume	Cost (\$)		Ratio (\$/gal)	
		1000 Ayr	4000 Ayr	1000 Ayr	4000 Ayr
MANUFACT INFO	50,000 gal	\$ 96,034	\$ 112,188	\$ 1.92	\$ 2.24
	100,000 gal	\$ 120,010	\$ 136,164	\$ 1.20	\$ 1.36
	300,000 gal	\$ 183,324	\$ 199,478	\$ 0.61	\$ 0.66
	750,000 gal	\$ 268,195	\$ 284,349	\$ 0.36	\$ 0.38
	1,000,000 gal	\$ 315,037	\$ 331,191	\$ 0.32	\$ 0.33
	1,500,000 gal	\$ 399,341	\$ 415,495	\$ 0.27	\$ 0.28
	2,000,000 gal	\$ 475,210	\$ 491,364	\$ 0.24	\$ 0.25

- Note:
- ① All values include tank materials, sitework, concrete base, painting, aeration components, electrical, and installation.
 - ② Values obtained by averaging Manufacturers Cost estimates.



THE CROM CORPORATION

Prestressed Composite Tanks

Stephen W. Pavlik, President
R. Bruce Simpson
H.E. Puder
James A. Noff, P.E.
Lara Balick, Jr., P.E.
Charles E. Hanzkat, P.E.
Samuel C. Sawyer, P.E.
Richard L. Bica, P.E.
James D. Copley, P.E.
Gerald C. Bevis, P.E.

June 13, 1995

FAX: 407-839-3790

Mr. Jamie Wallace
Hartman & Associates, Inc.
201 East Pine Street, Suite 1000
Orlando, FL 32801

Subject: Preliminary Prices for Ground Storage Reservoirs

Dear Jamie:

Thank you for your call and interest in prestressed concrete reservoirs. We are always pleased to work up an estimate for you. In confirming our telephone conversation we estimate the following:

300,000-Gallon Domed Reservoir 50'-0" ID x 20'-6" SWD	\$145,000
750,000-Gallon Domed Reservoir 65'-0" ID x 30'-3" SWD	\$218,000
1.0-MG Domed Reservoir 80'-0" ID x 26'-8" SWD	\$255,000

Handwritten notes:
1.5 mg 353,000
2 mg 397,000
June 13 1995

The above estimates are based on open shop labor conditions with construction beginning in 1995. If construction should take place later, escalate accordingly.

Our estimates are for our standard tank and includes the following:

- Complete structural tank with concrete floor, prestressed composite wall and free-span concrete dome.
- Standard accessories: aluminum interior ladder, aluminum exterior ladder, fiberglass hatch, fiberglass vent and precast concrete overflows. Painting the exterior surface with one coat of primer and two coats of latex paint.

Not included in the above estimates are the costs of site preparation, excavation, piping, backfilling, landscaping and disinfecting the tank.

250 S.W. 36TH TERRACE • GAINESVILLE, FLORIDA 32607-2889 • (904) 372-3436
FAX (904) 372-6209

Mr. Jamie Wallace
Hartman & Associates, Inc.


June 13, 1995
Page 2

Also per your request, to add a 1300 GPM aerator to the above tanks would be approximately \$11,100 and for a 2600 GPM aerator, \$17,300. Also please note that if we add aerators to the tanks, we usually paint the underside of the dome and approximately 2 feet down the wall. The additional cost for this would be approximately \$15,000 per tank.

We hope this information is sufficient for you and if you need any additional information, please give us a call.

Sincerely,

THE CROM CORPORATION


Richard L. Bice, P.E.
Project Manager

RLB/pd



PRECON CORPORATION


Prestressed Concrete Tanks

115 S.W. 140th Terrace
Newberry, Florida 32669
(904) 332-1200
Fax 332-1199

TO: JAMEY WALLACE
HARTMAN & ASSOC

DATE: 6.22.95

PAGE 1 OF 3

FROM: 
RICK MOORE, P.E. (904) 332-1200
PRESIDENT Fax 332-1199
PRECON CORPORATION PRESTRESSED CONCRETE TANKS
115 S. W. 140th TERRACE FOR WATER STORAGE
NEWBERRY, FLORIDA 32669 AND TREATMENT

FAX NO.: (407) 839-3790
T 839-3955

SUBJECT: TYPICAL ESTIMATES

MESSAGE: CALL WITH QUESTIONS

THANKS FOR CALLING.



PRECON CORPORATION

**ESTIMATE PRICE
CIRCULAR PRESTRESSED TANK
WITH AERATOR**

Prestressed Concrete Tanks

115 S.W. 140th Terrace
Newberry, Florida 32669
(904) 332-1200 (Fax) 332-1199


PROJECT DESCRIPTION:

AGE: TYPICAL **By:** Rick Moore
Location: CENTRAL FLORIDA **Date:** 6.23.95
Tank Capacity (Gal.): 0.05MG 0.1MG 0.3MG
Diameter (Ft.): 30'-0" 35'-0" 50'-0"
Water Depth (Ft.): 9'-6" 13'-11" 20'-6"
Aerator (GPM): _____

ESTIMATE:

	0.05MG	0.1MG	0.3MG
Base Tank (incl accessories, ext paint):	\$ 70,000	\$ 91,000	\$ 151,000
Aerator SEE BELOW	:	:	:
Bafflewall (concrete block) 4.50/SQ. FT.	+	\$ 900	\$ 1500
Interior paint (dome, 2' down wall) ADD 2% TO TANK PRICE	:	:	:
Pipe (estimate) ADD 10% TO TANK PRICE.	:	:	:
Site Work (estimate) ADD 5% TO 10% TO TANK PRICE	:	:	:
	:	:	:
	:	:	:
	:	:	:

AERATOR PRICING
 1000 GPM. \$ 10,000 TOTAL \$ _____
 2500 GPM \$ 17,000
 4000 GPM \$ 28,000



PRECON

PRECON CORPORATION

**ESTIMATE PRICE
CIRCULAR PRESTRESSED TANK**

Stressed Concrete Tanks

115 S.W. 140th Terrace
Newberry, Florida 32669
(904) 332-1200 (Fax) 332-1199

PROJECT DESCRIPTION:


Name: TYPICAL By: RICK MOORE
 Location: CENTRAL FLORIDA Date: 6.23.95
 Tank Capacity (Gal.): 0.75MG 1MG 2MG
 Diameter (Ft.): 65'-0" 80'-0" 100'-0"
 Water Depth (Ft.): 30'-3" 26'-8" 34'-1"

ESTIMATE:

	0.75MG	1MG	2MG
Base Tank (incl accessories, ext paint):	\$ 228,000	275,000	423,000
Pipe (estimate) (SEE NOTE BELOW)			
Site Work (estimate) USUALLY 5% TO 10% OF TANK PRICE.			
Baffle wall	+6000	+6400	\$ 10,000
TOTAL	\$		

PIPE - WITH OUT AERATOR - 6% OF TANK PRICE.
 - WITH AERATOR - 9% OF TANK PRICE.

for
1.5 n/w
\$ 8,300



SECTION --- ELEVATION

APPENDIX H

Steel Ground Storage Tanks

Construction & Unit Costs

Volume (Gal)	Manuf. Steel Tank Standard Cost (\$)	Manuf. Steel Tank Installed Cost (\$)	Overall Steel Tank Unit Cost (\$/Gal)
10,000	23,000	25,300	2.53
20,000	37,000	40,700	2.035
30,000	40,000	44,000	1.4666667
50,000	50,000	55,000	1.1
100,000	70,500	77,550	0.7755
250,000	120,000	132,000	0.528


NOTES:

- (1) Complete steel tank, concrete foundation, roof, roof manway, gravity vent, bottom manway hatch, ladder & cage assembly, top manway platform, protective bolt caps, and installation costs are included in the manufacturers' quotations.
- (2) Includes 5% piping, 0% electrical, and 5% sitework costs.
- (3) Costs are based on June 1995, ENR Index = 5433.

CURVE EQUATION:


$Y = (284.0788)X^{(-0.5089866)}$

Capacity (MGD)	Cons. Cost (\$)	Manuf. Cost (\$)
10000	2.61513404	2.53
20000	1.83769621	2.035
30000	1.49501527	1.46666667
40000	1.2913783	
50000	1.15272998	1.1
60000	1.05057097	
70000	0.97129326	
80000	0.90747204	
90000	0.85466772	
100000	0.81004166	0.7755
110000	0.77168318	
120000	0.7382529	
130000	0.70878042	
140000	0.6825432	
150000	0.65899066	
160000	0.63769501	
170000	0.61831807	
180000	0.60058858	
190000	0.58428603	
200000	0.56922913	
210000	0.55526724	
220000	0.54227402	
230000	0.53014263	
240000	0.51878203	
250000	0.50811407	0.528



STEEL GST INFLECTION POINT

Capacity (Gal)	F''(x)
10000	2.1822E-09
20000	1.7001E-09
30000	1.2909E-09
50000	6.6926E-10
100000	-7.6E-13
250000	-6.2012E-10



HARTMAN & ASSOCIATES, INC. engineers, hydrogeologists, surveyors & management consultants	SH. NO.:	JOB NO.:
	MADE BY:	DATE:
	CHECKED BY:	DATE:

Ground Storage Tanks (Steel)

Values include: sitework, conc., steel, elect., contingencies, inst.

<u>EPA</u> <u>INFO</u>	<u>Capacity</u>	<u>Cost</u>	<u>Ratio (\$/gal)</u>
	5,000 gal	⇒ \$ 19,504	⇒ \$ 3.91
	10,000 gal	⇒ \$ 33,312	⇒ \$ 3.33
	25,000 gal	⇒ \$ 57,370	⇒ \$ 2.29
	50,000 gal	⇒ \$ 72,700	⇒ \$ 1.45
	100,000 gal	⇒ \$ 101,125	⇒ \$ 1.01
	250,000 gal	⇒ \$ 158,628	⇒ \$ 0.63

<u>MANUFACT</u> <u>INFO</u>	<u>Capacity</u>	<u>Cost</u>	<u>Ratio (\$/gal)</u>
	5,000 gal	\$ 20,000	\$ 4.00
	10,000 gal	\$ 25,300	\$ 2.53
	25,000 gal	\$ 43,000	\$ 1.72
	50,000 gal	\$ 55,000	\$ 1.10
	100,000 gal	\$ 77,550	\$ 0.776
	250,000 gal	\$ 132,000	\$ 0.528

- * Note: ① All values include materials, sitework, concrete base, electrical, contingencies and installation.
- ② Values obtained using manufactures cost data and water treatment component Source C, pages 412-415.

613 PD1 JUN 21 1985 11:11

KARTMAN ASSOC

Florida Aquastore Water Reservoirs

List Costs

Capacity (Gal)	Standard Tank w/ Concrete Floor	Model	Standard Tank w/ Glass Coated, Bolted Steel Floor (Conc. Floor On)
10,000	\$ 23,000	1410	\$ 25,000
20,000	\$ 37,000	1419	\$ 39,000
30,000	\$ 40,000	1719	\$ 42,200
50,000	\$ 50,000	2024	\$ 53,000
100,000	\$ 70,500	3119	\$ 77,500
250,000	\$ 120,000 *	4224	\$ 130,000

* With Tencor Dome

Notes: (Any variations or extra costs required)

Must Add for any tank piping (nozzles, liquid level gauge, color selection, etc...

Std. tank includes concrete foundation, roof, roof manway, gravity vent, bottom manway hatch, exterior protective bolt caps, ladder & cage assembly, top manway platform, cobalt blue color. (Delivered & installed with tax)

[Handwritten signature]
Engineering & Construction

CLEARWELL STORAGE

Construction Costs

Product filtered water is commonly stored in a clearwell at the plant site which serves as a supplement to distribution system storage before high-service pumping. In many cases, filter backwash pumps also draw from the clearwell, eliminating the need for a separate sump. Clearwell storage may be either below ground in reinforced concrete structures, or above ground in steel tanks. Conceptual designs for below and above-ground level clearwells are shown in Table 171.

TABLE 171. CONCEPTUAL DESIGNS FOR CLEARWELL STORAGE

Below-Ground Concrete Clearwells				Ground-Level Steel Clearwells		
Capacity, gal	Size, ft			Capacity, gal	Size, ft	
	Length	Width	Depth		Diameter	Depth
5,000	8	8	10	1,000	5.7	5
10,000	11	11	12	5,000	8.5	12
50,000	18	18	20	10,000	12	12
100,000	26	26	20	25,000	15	20
500,000	58	58	20	100,000	23.5	32
				500,000	52	32
				1,000,000	74	32

Construction costs are shown in Table 172 for below-ground reinforced concrete clearwells and in Table 173 for ground-level steel clearwells. Costs for ground-level clearwells are based on field erected welded steel tanks designed to meet AWWA D100 for 18.93 m³ (5,000 gal) and more, and on shop fabricated welded steel tanks for the 3.79 m³ (1,000 gal) tank. Steel tanks are painted inside and out and are installed on a concrete ring wall with oiled sand cushion. Cathodic protection is included for tanks with capacities of 14.63 m³ (25,000 gal) and larger. A typical ground-level storage reservoir is shown in Figure 166. Figure 167 presents the construction costs for both types of clearwells.

TABLE 172. CONSTRUCTION COST SUMMARY FOR BELOW-GROUND CONCRETE CLEARWELL STORAGE

Cost Category	Clearwell Capacity, gal				
	5,000	10,000	50,000	100,000	500,000
Excavation and Sitework	\$ 3,300	\$ 5,700	\$16,800	\$ 25,300	\$ 75,400
Concrete	9,800	16,500	37,000	64,000	216,400
Steel	300	400	500	500	600
Electrical, Instrumentation	2,600	2,600	2,600	2,600	2,600
Subtotal	16,000	25,200	56,900	92,400	295,000
Design Contingencies	2,400	3,800	8,600	13,900	44,300
Total	\$18,400	\$29,000	\$65,500	\$106,300	\$299,300

TABLE 173. CONSTRUCTION COST SUMMARY FOR GROUND-LEVEL STEEL CLEARWELLS

Cost Category	Clearwell Capacity, gal						
	1,000	5,000	10,000	25,000	100,000	500,000	1,000,000
Excavation and Sitework	\$ 100	\$ 100	\$ 100	\$ 100	\$ 200	\$ 400	\$ 500
Concrete	3,100	5,300	6,600	8,400	11,400	25,700	37,100
Steel Tank	3,000	4,900	12,600	26,600	82,300	121,200	191,000
Electrical, Instrumentation	2,600	2,600	2,600	2,600	2,600	2,600	2,600
Subtotal	8,800	12,900	21,900	37,700	86,500	149,900	231,200
Design Contingencies	1,300	1,900	3,300	5,700	10,000	22,500	34,700
Total	\$10,100	\$14,800	\$25,200	\$43,400	\$76,500	\$172,400	\$265,900

Notes: 1. Oiled sand cost is included in concrete category.
 2. Cathodic protection cost is included in the steel tank category.




Figure 166. Typical ground-level steel clearwell.




Figure 167. Construction cost for clearwell storage.

APPENDIX I

High Service Pumps
Standard Horizontal Split Case Pumps
Package Costs

Capacity @ 175' of Head (gpm)	Motor Size (HP)	Worthing. Package Cost (\$)	Peerless Package Cost (\$)	Worthing. Const. Cost (\$)	Peerless Const. Cost (\$)	Overall Package Cost (\$)	Overall Unit Cost (\$/gpm)
100	20	4,300	--	4,300	--	4,300	43
250	25	4,600	4,925	4,600	4,925	4,763	19.05
500	40	5,700	6,185	5,700	6,185	5,943	11.885
750	50	6,000	7,350	6,000	7,350	6,675	8.9
1,000	60	8,000	--	8,000	--	8,000	8.7875
1,000	75	--	9,575	--	9,575	9,575	8.7875
1,250	75	8,600	10,800	8,600	10,800	9,700	7.76
1,500	100	9,500	11,650	9,500	11,650	10,575	7.05
1,750	125	10,800	13,150	10,800	13,150	11,975	6.8429
2,000	125	10,800	13,150	10,800	13,150	11,975	5.9875
2,500	150	14,700	16,200	14,700	16,200	15,450	6.18
3,000	200	15,600	17,800	15,600	17,800	16,700	5.5667
3,500	200	--	17,800	--	17,800	17,800	5.8571
3,500	250	23,200	--	23,200	--	23,200	5.8571
4,000	250	23,200	30,700	23,200	30,700	26,950	6.7375
5,000	300	24,600	33,200	24,600	33,200	28,900	5.78

- Notes:
- 1) All costs obtained from manufacturers' quotations include pumps, factory testing, and freight to jobsite.
 - 2) Horizontal Split Case pumps and motors.
 - 3) Pump head is 175 feet (76 psi)
 - 4) Costs are based on June 1995, ENR Index = 5433.


CURVE EQUATION:

$$Y = (3818.44) + (4.108873)X + (2.262538E-04)X^2$$

*** Const. Cost curve, divide by capacity for unit cost values.


Capacity @ 175' of Head (gpm)	Curve Unit Cost (\$/gpm)	Manuf. Unit Cost (\$/gpm)
100	42	43
150	30	
200	23	
250	19	19.05
300	17	
350	15	
400	14	
450	13	
500	12	11.885
600	11	
750	9	8.9
850	9	
950	8	
1,000	8	8.7875
1,250	7	7.76
1,500	7	7.05
1,750	7	6.84286
2,000	6	5.9875
2,250	6	
2,500	6	6.18
2,750	6	
3,000	6	5.56667
3,250	6	
3,500	6	5.85714
3,750	6	
4,000	6	6.7375
4,250	6	
4,500	6	
4,750	6	
5,000	6	5.78

High Service Pump Unit Cost Curve



HIGH SERVICE PUMP INFLECTION POINT

Capacity (gpm)	F''(x)
100	0.0006
250	0.0004
500	0.0002
750	5E-05
1000	-4E-06
1250	-2E-05
1500	-1E-05
1750	-1E-06
2000	8E-06
2500	8E-06
3000	-5E-06
3500	-8E-06
4000	1E-05
4500	7E-06



Peerless Pump Company
811 North 50th Street
Tampa, FL 33619

Fax Message

Number of pages including cover: 2

Phone:
Fax:

To: HARTMAN & ASSOCIATES
Fax Number: 407-839-3790
From: JIM GOSSETT

Date: 07/07/95

Copy to:

Subject: REQUEST FROM JAMEY WALLACE FOR VARIOUS PRICING.

I HAVE ENCLOSED PRICING THAT YOU ASKED FOR, SEE NOTES AS TO WHAT IS, AND WHAT ISN'T INCLUDED.

LET ME KNOW IF I CAN BE OF FURTHER SERVICE TO YOU.



BARNEY'S PUMPS INC.

FT. LAUDERDALE • JACKSONVILLE • LAKELAND

BARNEY'S PUMPS INC.
3907 HIGHWAY 98 SOUTH
P.O. BOX 3529
LAKELAND, FLORIDA 33802

PHONE : (813) 665-8500
FAX: (813) 666-3858

TO: JAMEY WALLACE

COMPANY: HARTMAN & ASSOC.

FROM: DAVID THOMPSON

SUBJECT: WORTHINGTON HORIZONTAL SPLIT CASE PUMPS

SELECTIONS ATTACHED!

REGARDS

FAX NUMBER: (407) 839-3790

COVER PAGE PLUS 1 PAGES FOR A TOTAL OF 2 PAGE(S)

SIGNED: David Thompson

06/27/85 16:11 2407 839 3780

WARTMAN ASSOC

002

Worthington High Service Pumps
List Costs

Type: Standard Horizontal Split Case

<u>Capacity @ 175' of Head \approx 76 psi (gpm)</u>	<u>Motor Size (HP)</u>	<u>Package Cost (\$)</u>	<u>PUMP</u>
100	20	4,300	2.5LR10
250	25	4,600	2.5LR13
500	40	5,700	4LR14
750	50	6,000	4LR14
1000	60	8,000	5LR15
1250	75	8,600	5LR15
1500	100	9,500	5LR15
1750	125	10,800	6LR16
2000	125	10,800	6LR16
2500	150	14,700	6LR18
3000	200	15,600	6LR18
3500	250	23,200	8LR18S
4000	250	23,200	8LR18S
5000	300	24,600	8LR18S


Note: (Any extra costs needed).

APPENDIX J

CURVE EQUATION:

$Y = (680.1492)X^{(-0.5484723)}$

Capacity (Gal)	Curve Unit Cost (\$/Gal)	Manuf. Unit Cost (\$/Gal)
500	23	21.7602
600	20	
700	19	
800	17	
900	16	
1000	15	16.08915
1500	12	
2000	11	10.54845
2500	9	
3000	8	
3500	8	
4000	7	
4500	7	
5000	6	6.34953
6000	6	
7000	5	
8000	5	
9000	5	
10000	4	
11000	4	
12000	4	
13000	4	
14000	4	
15000	3	3.33784
16000	3	
17000	3	
18000	3	
19000	3	
20000	3	3.072383



HYDRO-AIR SYSTEMS, INC.

P.O. Box 585654
Orlando, Fl 32858-5654
Phone or Fax (407)-352-1531

***** FAX TRANSMISSION *****

This transmission consists of 1 pages including this page, if you do not receive all pages please notify this office immediately.

DATE: June 27, 1995

TO: Hartman & Associates, Inc.

REP: Hydropneumatic Tank
System Estimate

ATTN: Jamey Wallace

FROM: Ken Miller

Pursuant to your request we are pleased to offer the following for your consideration and approval. All systems include the Hydro-Tank, Air volume control compressor control panel and all accessories to provide an operable system. All systems are based on a maximum pressure of 100psi, potable water and do not include installation cost or applicable taxes. We will be happy to provide a detailed proposal on any of the six systems upon request. If we can be of further assistance please feel free to call me at any time.

CAPACITY GALLONS	SYSTEM ESTIMATE
500	\$5,387.00
1,000	\$9,102.00
2,000	\$12,972.00
5,000	\$21,982.00
15,000	\$28,688.00
20,000	\$36,482.00

Ken Miller

Ken Miller
Electrical
2/15/95

RECORD OF TELEPHONE COMMUNICATION

DATE: 10/19 TIME: 9:50

PROJECT NAME: SSU - Economy of Scale PROJECT NO.: 95-145.00

PARTY CALLING: Bob Black COMPANY: Modern Tanks

PARTY CONTACTED: James Wallace COMPANY: NAI

SUBJECT: Costs for Hydro-pneumatic Tanks

Modern Welding Company Incorporated

TELEPHONE COMMUNICATION SUMMARY (Including Decisions & Commitments)

+ extras (15% piping, 20% elect., 30% install., 10% site)

500 Gal	→ \$4,800 + \$3000	= 7800 (1.65) = 12,870
1000 Gal	→ \$6,400 + \$400	Compressor = 10,400 (1.65) = 17,160
2000 Gal	→ \$8,600 + \$400	Valves = 12,600 (1.65) = 20,790
5000 Gal	→ \$12,500 + \$4000	= 16,900 (1.65) = 27,225
15,000 Gal	→ \$27,000 + \$5000	= 32,000 (1.65) = 52,800
20,000 Gal	→ \$33,000 + \$5000	= 38,000 (1.65) = 62,700

ACTION REQUIRED

HARTMAN & ASSOCIATES, INC.

engineers, hydrogeologists, scientists & management consultants

EXHIBIT (CCH-4)

PAGE 175 OF 284

APPENDIX K

Potable Water Supply Wells

Construction Costs

Capacity (Gpd)	Manuf. 250' deep Const. Cost (\$)	Manuf. 250' deep Unit Cost (\$/Gal)	Manuf. 500' deep Const. Cost (\$)	Manuf. 500' deep Unit Cost (\$/Gal)
144,000	50,794	0.353	95,573	0.664
288,000	61,582	0.214	118,753	0.412
576,000	72,416	0.126	143,026	0.248
720,000	72,494	0.101	144,731	0.201
1,080,000	81,468	0.075	165,253	0.153
1,440,000	84,413	0.059	175,948	0.122
2,160,000	107,648	0.050	219,108	0.101
2,880,000	113,538	0.039	236,174	0.082
3,600,000	143,298	0.040	278,582	0.077

NOTES:


- (1) Vertical turbine pump, cement grout, black steel well and surface casing, well screen, and well development costs from manufacturers' quotes and bid tabulations.
- (2) Includes 10% electrical, 15% for well head assembly, and 30% labor costs.
- (3) Costs are based on June 1995, ENR Index = 5433.

CURVE EQUATION:


(250' deep) $Y = (1780.326)X^{(-0.7180454)}$

(500' deep) $Y = (2064.79)X^{(-0.6817897)}$

Capacity (GPD)	250' Curve Cost (\$/Gal)	250' Manuf. Cost (\$/Gal)
144000	0.352014923	0.35
200000	0.278047715	
288000	0.213997092	0.21
400000	0.169030909	
576000	0.130093221	0.13
600000	0.126335269	
720000	0.110832946	0.10
850000	0.098380166	
1080000	0.082837572	0.08
1200000	0.076801801	
1440000	0.067377621	0.06
1750000	0.058575335	
2160000	0.050358659	0.05
2500000	0.045340692	
2880000	0.040960238	0.04
3000000	0.039777035	
3600000	0.034896083	0.04




Capacity (GPD)	500' Curve Cost (\$/Gal)	500' Manuf. Cost (\$/Gal)
144000	0.62799686	0.66
200000	0.501982108	
288000	0.39148788	0.41
400000	0.31293136	
576000	0.244050202	0.25
600000	0.237351445	
720000	0.20960755	0.20
850000	0.187179868	
1080000	0.158982644	0.15
1200000	0.147962864	
1440000	0.130667557	0.12
1750000	0.114402852	
2160000	0.099108423	0.10
2500000	0.089706991	
2880000	0.081457039	0.08
3000000	0.079221184	
3600000	0.069961059	0.08



WATER SUPPLY WELL INFLECTION POINTS (250' & 500')


Potable Water Wells (250' deep)

Capacity (gpd)	F*(x)
144000	1.9547E-12
288000	1.50714E-12
576000	8.13596E-13
720000	5.56933E-13
1080000	1.35295E-13
1440000	-3.8732E-14
2160000	2.25217E-14
2880000	7.36539E-14
3600000	-5.5238E-13



Potable Water Wells (500' deep)

Capacity (gpd)	F*(x)
144000	3.52E-12
288000	2.72E-12
576000	1.49E-12
720000	1.03E-12
1080000	2.73E-13
1440000	-5.2E-14
2160000	3.11E-14
2880000	1.29E-13
3600000	-9.1E-13



**** The y-axis values are the same as those listed in the table; however, they are too small to show up on this graph. Just click on the graph to see a larger version with the values.

Capacity (Gpd)	Design Cost	(15%) Well Head	(30%) Labor	(10%) Electrical	Total	Unit Cost (\$/Gal)
144,000	32,770	4,916	9,831	3,277	\$50,794	0.35
288,000	39,730	5,960	11,919	3,973	\$61,582	0.21
576,000	46,720	7,008	14,016	4,672	\$72,416	0.13
720,000	46,770	7,016	14,031	4,677	\$72,494	0.10
1,080,000	52,560	7,884	15,768	5,256	\$81,468	0.08
1,440,000	54,460	8,169	16,338	5,446	\$84,413	0.06
2,160,000	69,450	10,418	20,835	6,945	\$107,648	0.05
2,880,000	73,250	10,988	21,975	7,325	\$113,538	0.04
3,600,000	92,450	13,868	27,735	9,245	\$143,298	0.04
144,000	61,660	9,249	18,498	6,166	\$95,573	0.66
288,000	76,615	11,492	22,985	7,662	\$118,753	0.41
576,000	92,275	13,841	27,583	9,228	\$143,026	0.25
720,000	93,375	14,006	28,013	9,338	\$144,731	0.20
1,080,000	106,615	15,992	31,985	10,662	\$165,253	0.15
1,440,000	113,515	17,027	34,055	11,352	\$175,948	0.12
2,160,000	141,360	21,204	42,408	14,136	\$219,108	0.10
2,880,000	152,370	22,856	45,711	15,237	\$236,174	0.08
3,600,000	179,730	26,960	53,919	17,973	\$278,582	0.08

Final
Well
Costs

Design Well Costs

Address: (surface casing, well casing, well screen, boring, cement grout, well development, ~~well~~)

Flow	Cost	W/200' casing	Casing	Cost	Surface Casing	Cost	Grout	Cost
100	11,000	4,870	6"	3,750	10"	1,650	4 yd ³	2,000
200	12,500	5,180	10"	4,950	16"	2,300	6 yd ³	3,000
400	14,200	6,020	12"	6,000	18"	2,500	10 yd ³	5,000
500	14,700	6,020	12"	6,000	18"	2,500	10 yd ³	5,000
750	18,700	7,810	12"	6,000	18"	2,500	10 yd ³	5,000
1000	20,600	7,810	12"	6,000	18"	2,500	10 yd ³	5,000
1500	29,500	10,250	16"	6,900	20"	3,300	12 yd ³	6,000
2000	33,300	10,250	16"	6,900	20"	3,300	12 yd ³	6,000
2500	46,000	13,450	18"	7,500	24"	3,750	15 yd ³	7,500
<u>W/400' casing</u>								
100	14,300	14,610	6"	9,375	10"	4,125	10 yd ³	5,000
200	17,300	16,410	10"	12,375	16"	5,750	18 yd ³	7,500
400	20,200	19,500	12"	15,000	18"	6,250	25 yd ³	12,500
500	21,300	19,500	12"	15,000	18"	6,250	25 yd ³	12,500
750	28,900	25,140	12"	15,000	18"	6,250	25 yd ³	12,500
1000	35,800	25,140	12"	15,000	18"	6,250	25 yd ³	12,500
1500	48,600	32,010	16"	17,250	20"	8,250	30 yd ³	15,000
2000	57,000	34,620	16"	17,250	20"	8,250	30 yd ³	15,000
2500	68,000	43,230	18"	18,750	24"	9,375	38 yd ³	19,000

HARTMAN & ASSOCIATES, INC.	
engineers, hydrogeologists, surveyors & management consultants	
SH. NO.: 1	JOB NO.: 95-145.00
MADE BY: JSC	DATE:
CHECKED BY:	DATE:

HARTMAN & ASSOCIATES, INC.		SH. NO.: <u>2</u>	JOB NO.: <u>95-145.00</u>
engineers, hydrogeologists, surveyors & management consultants		MADE BY: <u>JSW</u>	DATE:
		CHECKED BY:	DATE:

Flow	Well Screen	Cost	Drill/Bore	Cost	Well Development
100	6"	\$3,500	6" (#15)	\$3,750	6,000
200	10"	5,500	10" (#15)	4,375	6,000
400	12"	6,500	12" (#20)	5,000	6,000
500	12"	6,500	12" (#20)	5,000	6,000
750	12"	6,500	12" (#20)	5,000	6,000
1000	12"	6,500	12" (#20)	5,000	6,000
1500	16"	7,500	16" (#25)	6,250	6,000
2000	16"	7,500	16" (#25)	6,250	6,000
2500	18"	8,250	18" (#27.5)	6,875	6,000
100	6"	5,250	6" (#15)	7,500	9,000
200	10"	8,250	10" (#17.5)	8,750	9,000
400	12"	9,825	12" (#20)	10,000	9,000
500	12"	9,825	12" (#20)	10,000	9,000
750	12"	9,825	12" (#20)	10,000	9,000
1000	12"	9,825	12" (#20)	10,000	9,000
1500	16"	11,250	16" (#25)	12,500	9,000
2000	16"	11,250	16" (#25)	12,500	9,000
2500	18"	12,375	18" (#27.5)	13,750	9,000

Included in installation

Address (surface casing, well casing, casing, screen, casing, well development)

Design Well Costs

Well DesignDesign Parameters

ENCLOSURE

100 gpm	4" column \Rightarrow 6" casing \rightarrow 10" OD casing	40 ft ²
200 gpm	5-6" column \Rightarrow 10" casing \Rightarrow 16" OD casing	50 ft ²
400 gpm	6" column \Rightarrow 12" casing \Rightarrow 18" OD casing	70 ft ²
500 gpm	6" column \Rightarrow 12" casing \Rightarrow 18" OD casing	80 ft ²
750 gpm	8" column \Rightarrow 12" casing \Rightarrow 18" OD casing	100 ft ²
1000 gpm	8" column \Rightarrow 12" casing \Rightarrow 18" OD casing	120 ft ²
1500 gpm	10" column \Rightarrow 16" casing \Rightarrow 20" OD casing	150 ft ²
2000 gpm	10" column \Rightarrow 16" casing \Rightarrow 20" OD casing	175 ft ²
2500 gpm	12" column \Rightarrow 18" casing \Rightarrow 24" OD casing	200 ft ²

for 250' wells

O.D. casing Depth \Rightarrow ~~50'~~
 I.D. casing Depth \Rightarrow 150'
 Grout \Rightarrow 50'
 Drilled - Bore \Rightarrow 250'

for 500' wells

O.D. casing Depth \Rightarrow 125' screen - perf. pipe \Rightarrow 75'
 I.D. casing Depth \Rightarrow 375'
 Grout \Rightarrow 125'
 Drilled - Bore \Rightarrow 500'

FLANAGAN-METCALF & ASSOCIATES, INC.
WATER AND WASTEWATER EQUIPMENT

6708 BENJAMIN RD. SUITE 300 TAMPA, FL 33634
PHONE (813) 884-2663 FAX (813) 884-1898

FAX MESSAGE TO:

NAME: JAMEY WALLACE FROM: MIKE BITTING

COMPANY: HARTMAN & ASSOC DATE: 8/16/95

FAX NO.: 407 839 3790 TOTAL NUMBER OF PAGES: 2

SUBJECT: FLOWAY VERTICAL TURBINE BLOWUP PRICES

THE ATTACHED PRICES INCLUDE TEFC PREMIUM EFF
MOTORS, 1770 RPM, 100' OF COLUMN SIZED
PER AWWA STANDARDS, FREIGHT & START-UP SERVICE.

PLEASE CALL IF YOU HAVE ANY QUESTIONS.

	• NEED 200' OF COLUMN FOR 25" DIA
	• NEED 450' " " " 5" DIA

\$/FT FOR COLUMN PIPE BASED ON DIAMETER

VALERIE : COST FILE FOR WELL INFO

HARTMAN & ASSOCIATES, INC.		EST. NO.:	JOB NO.:
engineers, hydrogeologists, surveyors & management consultants		MADE BY:	DATE:
		CHECKED BY:	DATE:

FAX	DATE	TIME	FROM
8/10	7:00		MIKE BITTING
TO	JIMMY WALLACE		
CC	HARTMAN & ASSOCIATES		
FAX	NO.	813-884-2882	
FAX	NO.	813-884-1898	

Peabody - Floway

Vertical Turbine Pump Costs

Flow (GPM)	Head (Psi)	Motor Size (HP)	Cost (\$)	COLUMN AREA PER 10' LENGTH
100	130	15	\$11,000	487
200	130	25	12,500	548
400	130	50	14,200	602
500	130	50	14,700	602
750	130	75	18,700	781
1000	130	100	20,600	781
1500	130	150	29,500	1025
2000	130	200	33,300	1025
2500	130	250	46,000	1345
100	250	25	\$14,300	487
200	250	50	17,300	548
400	250	100	20,200	650
500	250	100	21,300	650
750	250	150	28,900	838
1000	250	200	35,800	838
1500	250	300	48,600	1067
2000	250	400	57,000	1154
2500	250	500	68,000	1441

NOTES: (Any Extra Costs provided or needed).

WATER WELLS

Introduction

Water wells are drilled by the cable tool, hydraulic rotary or reverse rotary methods, with hydraulic rotary currently the most common method. Construction of these types of water wells is covered by "American Water Works Association Standard for Deep Wells, AWMA A100-66" and by "Manual of Water Well Construction Practices, EPA-570/9-75-001."^{1,2}

Construction of water wells by the hydraulic rotary method takes place in the following sequence:

1. Install protective casing and grout in place for sanitary seal.
2. Drill 15.2 to 30.5 cm (6 to 12 in) diameter pilot hole.
3. Electric log pilot hole to help determine location of water bearing formations.
4. Ream hole to required diameter and depth.
5. Install blank and perforated casing or well screen.
6. Place gravel pack and grout seals.
7. Develop well by pumping and bailing.
8. Conduct pumping test to verify capacity before permanent pump is installed.
9. Install pump and construct enclosure.

Conceptual design criteria for wells are shown in Table 154 and a cross-section for a typical well is shown in Figure 146.

TABLE 154. CONCEPTUAL DESIGNS FOR WATER WELLS

Well Capacity, gal/day		Casing Diameter, in	Well Depth, ft	Pump Motor Size, hp	Enclosure, sq ft
144,000	100	8	250	10	40
			500	20	
432,000	300	10	250	25	60
			500	50	
720,000	500	12	250	40	80
			500	75	
1,008,000	700	16	250	50	100
			500	100	

- Notes:

1.	Maximum pumping depth 50-100 ft less than well depth.
2.	Enclosure has a 10 ft height.

Construction Costs

Construction costs were developed for water well construction by the hydraulic rotary method, as outlined in the previous section. The protective casing and grout was installed to a depth of 7.62 m (25 ft). Casing is blank

and perforated copper bearing steel, with gravel packing and grout seals. After construction, the well is developed by bailing and pumping to remove drilling mud, silt and fine sand. The completed well is then test pumped until the water has sufficient clarity for potable use. This often requires pumping for up to 60 hours.

The permanent pump is the oil lubricated, deep-well turbine type and the electric motor is 220/440 volt. A submersible type pump at somewhat reduced cost could be used in some cases, particularly for shallow, small capacity wells. Pump motor sizes and casing diameter used in the cost development are shown in Table 154.

The electrical cost includes all work required at the well but does not include providing service to the site. Costs include a valve and totalizing flow meter on the discharge, but no other piping or equipment. An enclosure is provided over the motor, totalizing meter, and valve.

Construction costs are summarized in Table 155 and presented in Figure 147 for wells capable of producing 545, 1,635, 2,725, and 3,815 m³/d (144,000, 432,000, 720,000 and 1,008,000 gpd) from wells 76.2 and 152.4 m (250 and 500 ft) deep.

Operation and Maintenance Requirements and Costs

Electricity requirements are based on continuous operation of the motor, at a pumping head 15.24 m (50 ft) less than the well depth. No energy is included for the housing, as it was assumed that heating and ventilation are unnecessary, and that lighting requirements are minimal. Many wells do not operate continuously and in these cases the energy requirements will be reduced according to the actual load factor. Material requirements are based on necessary lubricants and other routine maintenance items and servicing the pump and motor once in five years. Labor requirements are based on daily visits for inspection and routine maintenance. Labor and material required to remove and service the pump and motor once every five years are included in the average annual values.

Operation and maintenance requirements and costs are summarized in Table 156 and presented in Figures 148 and 149.

References

1. "AWMA Standard for Deep Wells," AWMA A100-66, January 23, 1966, American Water Works Association, 2 Park Avenue, New York, N. Y. 10016
2. "Manual of Water Well Construction Practices," EPA-570/9-75-001, U.S. Environmental Protection Agency, Office of Water Supply, Washington, D.C.

TABLE 155. CONSTRUCTION COST SUMMARY FOR WATER WELLS

Cost Category	Well Capacity							
	100 GPM		300 GPM		500 GPM		700 GPM	
	144,000 gpd Well Depth	Well Depth	432,000 gpd Well Depth	Well Depth	720,000 gpd Well Depth	Well Depth	1,008,000 gpd Well Depth	Well Depth
	250 FE	500 FE	250 FE	500 FE	250 FE	500 FE	250 FE	500 FE
Excavation & Sitework	\$ 1,100	\$ 1,100	\$ 1,600	\$ 1,600	\$ 2,100	\$ 2,100	\$ 2,700	\$ 2,700
Manufactured Equipment	10,300	13,400	15,500	18,500	18,500	21,600	21,600	25,800
Concrete	1,600	2,900	1,800	3,100	2,000	3,200	2,100	40,900
Pipe & Valves	17,300	33,200	14,000	16,200	20,800	39,300	22,500	42,400
Electrical, Instrumentation	5,600	10,300	7,500	13,300	9,200	16,100	12,900	23,000
Housing	2,700	10,100	11,600	13,900	13,900	16,200	16,200	19,300
Subtotal	3,400	3,400	4,700	4,700	6,100	6,100	10,100	10,100
Design Contingencies	47,000	74,400	61,700	91,300	72,600	104,600	88,100	164,200
Total	7,100	11,200	9,300	13,700	10,900	15,700	13,200	24,600
Total	\$54,100	\$85,600	\$71,000	\$105,000	\$83,500	\$120,300	\$101,300	\$188,800

LABOR
 Subtract out
 Design Contingencies

EPA #S

July 1995

w/o labor, housing, cont.

	250'	500'	250'	500'
100 GPM	26,300	37,800	34,706	49,908
300 GPM	38,000	50,400	50,232	66,624
500 GPM	45,700	59,200	60,411	79,257
700 GPM	55,500	74,890	73,306	98,997

	250'	500'
100 GPM	57,685	93,955
300 GPM	75,348	114,477
500 GPM	87,906	130,207
700 GPM	103,108	155,046

w/o housing & Des. cont.

TABLE 156. OPERATION AND MAINTENANCE SUMMARY FOR WATER WELLS

Well Capacity, gpd	Well Depth	Energy, kWh/yr	Maintenance Material, \$/yr	Labor, hr/yr	Total Cost, \$/yr
144,000	250 FT	44,100	1,800	450	9,300
432,000	250 FT	132,000	1,800	500	16,600
720,000	250 FT	220,200	2,300	550	23,800
1,008,000	250 FT	308,300	2,700	600	30,900
144,000	500 FT	99,700	1,800	500	14,300
432,000	500 FT	297,300	2,800	550	29,400
720,000	500 FT	495,600	3,300	600	44,100
1,008,000	500 FT	693,700	3,300	650	59,000

Notes: 1. Total cost is based on 30.07/kwh of electrical energy and \$11.00/hr of labor.
 2. Pumping heads are 200 ft for the 250 ft deep well, and 450 ft for the 500 ft deep well.
 3. Pumping is continuous, 24 hours/day, 365 days/year.




Figure 146. Typical water well.





Figure 147. Construction cost for water wells.

GRAPH #4

Lime Softening & Packaged Conventional Treatment



Note: Source B, Figure 2-2, pp. 11-12.

Cost summaries of Selected Env. Technologies

GRAPH #3
Hydrated Lime Chemical Feed (Fig. 23)

Treatment Capacity (Mgd)	Const. Cost (\$)	ENR Index	June 1995 ENR Index	Current Cost (\$)	Handy Whitman	Current Handy Whitman	Current Cost (\$)
200 mg/l							
0.3	24,000	2494	5433	52,282	158	319	48,456
0.5	24,000	2494	5433	52,282	158	319	48,456
0.7	25,000	2494	5433	54,461	158	319	50,475
1.0	29,000	2494	5433	63,174	158	319	58,551
1.3	35,000	2494	5433	76,245	158	319	70,665
100mg/l							
0.3	15,000	2494	5433	32,676	158	319	30,285
0.5	15,000	2494	5433	32,676	158	319	30,285
0.7	16,000	2494	5433	34,855	158	319	32,304
1.0	22,000	2494	5433	47,925	158	319	44,418
1.3	24,000	2494	5433	52,282	158	319	48,456
50 mg/l							
0.3	15,000	2494	5433	32,676	158	319	30,285
0.5	15,000	2494	5433	32,676	158	319	30,285
0.7	15,000	2494	5433	32,676	158	319	30,285
1.0	15,000	2494	5433	32,676	158	319	30,285
1.3	15,000	2494	5433	32,676	158	319	30,285

GRAPH #4
Lime Softening & Packaged Conventional (Fig. 2-2)

Treatment Capacity (Mgd)	Const. Cost (\$)	ENR Index	June 1995 ENR Index	Current Cost (\$)	Handy Whitman	Current Handy Whitman	Current Cost (\$)
--- Lime Softening ---							
0.1	0	3150	5433	0	205	319	0
0.5	0	3150	5433	0	205	319	0
1.0	2,000,000	3150	5433	3,449,524	205	319	3,112,195
5.0	5,500,000	3150	5433	9,486,190	205	319	8,558,537
10.0	8,000,000	3150	5433	13,798,095	205	319	12,448,780
--- Packaged Conventional Plant ---							
0.1	300,000	3150	5433	517,429	205	319	466,829
0.5	800,000	3150	5433	1,379,810	205	319	1,244,878
1.0	1,100,000	3150	5433	1,897,238	205	319	1,711,707
5.0	0	3150	5433	0	205	319	0
10.0	0	3150	5433	0	205	319	0

discharge to a municipal sewer or hauled to a landfill for disposal. Clarified water then flows to the filter unit.

The filters consist of one or more steel or concrete vessels containing granular materials such as graded sands, anthracite, and garnet. Solids are strained from the water as it passes through the filters. When the pressure drop through the filters becomes great enough due to accumulated solids, a backwash stream of filtered water passes through the units in reverse flow to clean the solids from the filter bed. The spent backwash stream is sent to a sewer. Backwashing is intermittent; the backwash cycle depends on the character and concentration of solids in the water, as well as on filter design parameters such as application rate and filter medium particle size.

Filtered water is disinfected with chlorine and stored. From storage it is pumped to the water supply distribution system.

Direct Filtration (2,4,5)

A direct filtration plant is essentially the same as the conventional filtration plant shown in Figure 2-1 except the sedimentation step is deleted.

Direct filtration is applicable to any drinking water supply where suspended solids levels are sufficiently low to result in a reasonable backwash cycle on the filter units. Unlike conventional filtration plants, there is an upper limit to the influent suspended solids concentration that can be tolerated. This upper limit must be determined by testing. Above such a level, conventional treatment procedures or sedimentation prior to filtration are required.

Lime Softening (2,4,5)

The major features of a lime softening plant are also essentially the same as those for a conventional filtration plant, except that lime is substituted for other chemicals and a recarbonation step is added after sedimentation. A lime softening plant is typically used to treat raw water with a higher concentration of dissolved minerals, such as calcium and magnesium, than can be treated in a conventional or direct filtration plant. In the context of the Safe Drinking Water Act, a lime softening plant can also be expected to achieve a greater removal of toxic mineral substances. For example, a lime softening plant operating in a pH range of 8.5 to 11 can reduce cadmium concentrations from 0.5 mg/l to 0.01 mg/l. To achieve the same cadmium concentration in the treated effluent, a conventional filtration plant using alum or iron salts can only accommodate a cadmium concentration up to 0.1 mg/l of cadmium in the raw water (2). The choice of overall treatment process therefore depends on individual raw water characteristics.

Lime can be added directly to the influent raw water as a solid, or as a pre-mixed water slurry. If a slurry is used, the solid lime is usually purchased and the slurry prepared on-site. Details of lime feed systems are described elsewhere (6, 7).

Recarbonation is the addition of gaseous carbon dioxide (CO₂) to the lime-treated water to neutralize excess alkalinity resulting from lime addition. Gaseous CO₂ may be obtained from liquid CO₂ stored onsite, submerged burners, or stack gas compressed through a sparger system. The choice of carbonation method depends on site specific considerations.

2.1.2 Design Basis and Costs (2,4,5)

The design basis in this report for conventional filtration plant costs includes the following major process modules and design parameters:

- Raw water pumping.
- Chemical addition.
- Rapid mix/Flocculation.
- Sedimentation.
- Filtration.
- Disinfection.
- Finished water storage.
- Finished water pumping.
- Sludge disposal.


As stated in the process descriptions, there is no sedimentation step in direct filtration. The filtration directly follows the rapid mix and flocculation step. The chemical feed system consists of chemical storage and metering pump facilities. The rapid mix tank and flocculation vessel is one vessel partitioned into separate sections. Filtration units are gravity flow steel or concrete vessels. The clear well is a concrete storage basin. System design parameters depend on raw water quality and the finished water quality required.

The major process modules for the lime softening plant are very similar to those for conventional filtration, except for modifications to the chemical feed system and addition of recarbonation equipment. Recarbonation basins are reinforced concrete, and submerged natural gas burners are used for the CO₂ source in the system considered here based on the configuration and costs in Reference 2.

The plant cases represented here include chlorine disinfection, the usual procedure in conventional plants. Alternative disinfectants such as chlorine dioxide, ozone, or ammonia added with chlorine can also be used. The disinfection systems for each of these alternatives are discussed in Section 2.2

Total capital investment for conventional filtration, direct filtration, and lime softening is presented in Figure 2-2. Net annual operating expenses are shown in Figure 2-3. Figure 2-4 shows corresponding unit annualized costs.

Figure 2-2. Filtration plants for drinking water treatment - Total capital investment (March, 1980 dollars).



LIME SOFTENING
 PACKAGED
 CONVENTIONAL

drinking water treatment (March, 1980 dollars).





Figure 2-3. Filtration plants for drinking water treatment - Net annual operating expenses (March, 1980 dollars).



Also provided in the figures are costs for packaged conventional filtration plants which can be used for small treatment systems (5). These plants would have the same unit processes as their larger field-constructed counterparts but would be primarily shop fabricated and brought to the field for final installation.

2.1.3 Major Variables Affecting Costs

For any of the filtration plants discussed here, the large number of process steps and associated variables result in many possible combinations of equipment sizes and specifications. These factors largely depend on site specific requirements with raw water quality the primary variable. A complete analysis of the cost impacts of changes in design is beyond the scope of this report. However, examination of the cost profile for capital investment reveals that the greatest portion of the investment is in the filter portion of the plant. Therefore, changes in design requirements for the filters have a very large impact on total plant capital costs. For lime softening plants lime dosage is an important variable. Also, as can be seen from the figures, costs for shop fabricated packaged plants are less than for field constructed plants of similar size. Operating expenses, specifically electricity costs for pumping, are affected by frequency of backwashing in the filtration unit which

EXHIBIT _____ (GCH-4)

PAGE 196 OF 284

APPENDIX M


Reverse Osmosis WTP

Construction & Unit Costs

Treatment Capacity (Mgd)	Graph #1 Const. Cost (\$)	Graph #8 Const. Cost (\$)	Graph #11 Const. Cost (\$)	Graph #4 Const. Cost (\$)	Overall Const. Cost (\$)	Overall Unit Cost (\$/Gal)
0.003		51,333		25,731	38,532	12.844
0.005		58,667		29,961	44,314	8.863
0.01		73,333		44,061	58,697	5.870
0.03		105,111		91,647	98,379	3.279
0.05		140,963		139,232	140,098	2.802
0.07		174,167		182,235	178,201	2.546
0.10	282,658	220,000		246,740	249,799	2.498
0.20	423,987	366,667		396,547	395,734	1.979
0.50	1,059,968	794,444		793,094	882,502	1.765
1.00		1,588,889	1,382,105	1,339,448	1,436,814	1.437
2.00			2,303,509		2,303,509	1.152
5.00			4,961,404		4,961,404	0.992
10.00			9,568,421		9,568,421	0.957

- NOTES:
- (1) Values obtained using EPA cost curves.
 - (2) Costs include housing, structural steel, tanks, piping, valves, pumps, reverse osmosis membrane elements and pressure vessels, flow meters, cartridge filters, acid and polyphosphate equipment, and cleaning equipment.
 - (3) The EPA cost curves have also added costs for contingencies, sitework, engineering & administration, and electrical.
 - (4) Costs are based on June 1995, ENR Index = 5433.

GRAPH #1 Reverse Osmosis



Note: Source A, Figure 19, page VI-11.

State of the Art ~~of~~ Small WTPs

GRAPH #1
Reverse Osmosis (Fig. 19)

Treatment Capacity (Mgd)	Const. Cost (\$)	ENR Index	June 1995 ENR Index	Current Cost (\$)	Handy Whitman	Current Handy Whitman	Current Cost (\$)
0.07	125,000	2494	5433	272,304	158	319	252,373
0.1	140,000	2494	5433	304,980	158	319	282,658
0.3	280,000	2494	5433	609,960	158	319	565,316
0.5	525,000	2494	5433	1,143,675	158	319	1,059,968
1.0	1,500,000	2494	5433	3,267,642	158	319	3,028,481
1.5	3,250,000	2494	5433	7,079,892	158	319	6,561,709

GRAPH #2
Reverse Osmosis Enclosure (Fig. 20)

Treatment Capacity (Mgd)	Const. Cost (\$)	ENR Index	June 1995 ENR Index	Current Cost (\$)	Handy Whitman	Current Handy Whitman	Current Cost (\$)
0.07	7,000	2494	5433	15,249	158	319	14,133
0.1	8,000	2494	5433	17,427	158	319	16,152
0.3	19,000	2494	5433	41,390	158	319	38,361
0.5	29,000	2494	5433	63,174	158	319	58,551
0.7	40,000	2494	5433	87,137	158	319	80,759
1.0	58,000	2494	5433	126,349	158	319	117,101

Graph
1+2

m. **Electrodialysis.** The electrodialysis capital cost curve was developed for a complete multiple-stage electrodialysis system. Costs were obtained for standard units as rated by the manufacturer for operation with a raw water TDS concentration of 1500 to 4000 mg/l. For these electrodialysis units, predicted per cent water recovery ranges from 65 to 85 and predicted per cent TDS removal ranges from 82 to 96. Local water quality may change the rated capacity of these units.


Electrodialysis capital costs include costs for the following equipment and materials: skid-mounted reverse polarity electrodialysis unit with membrane stacks, rectifiers, low pressure feed pump, brine recirculation pump, chemical cleaning equipment, cartridge filters, necessary valves, piping and automatic controls. Refer to Figure 17 for the electrodialysis capital cost curve. The enclosure capital cost curve for electrodialysis is shown on Figure 18.

n. **Reverse Osmosis.** The reverse osmosis capital cost curve was developed for a complete reverse osmosis treatment system. Costs obtained were for standard units as rated by the manufacturer for operation with a feed of 1500 mg/l NaCl at 400 psi, 25°C (77°F), and 75 per cent conversion. Local water quality may change the rated capacity of these units.

Capital costs for reverse osmosis include costs for the following equipment and materials: skid-mounted, membrane-type reverse osmosis unit with hollow fine fiber membranes, high pressure pumps, cartridge filters, acid and polyphosphate feeding equipment, necessary valves, piping and automatic controls. Refer to Figure 19 for the reverse osmosis capital cost curve. Presented on Figure 20 is a capital cost curve for an enclosure for this unit process.

o. **Chemical Feed.** Capital costs have been determined for the following chemical feed systems:

- (1) powdered activated carbon.
- (2) coagulants.
- (3) hydrated lime.



- UNIT PROCESS COST CURVE INCLUDES:
- CONTINGENCIES
 - ENGINEERING & ADMINISTRATION
 - SITWORK
 - ELECTRICAL
 - MEMBRANE TYPE REVERSE OSMOSIS SYSTEM

Graph
1
←

REVERSE OSMOSIS
CAPITAL COST

FIGURE 19

GRAPH #7
 Package Lime Softening Plants (Fig. 12)

Treatment Capacity (gpd)	Const. Cost (\$)	ENR Index	June 1995 ENR Index	Current Cost (\$)	Handy Whitman	Current Handy Whitman	Current Cost (\$)
20,000	86,000	4110	5433	113,683	261	319	105,111
40,000	95,000	4110	5433	125,580	261	319	116,111
70,000	100,000	4110	5433	132,190	261	319	122,222
100,000	115,000	4110	5433	152,018	261	319	140,556
200,000	140,000	4110	5433	185,066	261	319	171,111
500,000	190,000	4110	5433	251,161	261	319	232,222
1,000,000	290,000	4110	5433	383,350	261	319	354,444

GRAPH #8
 Reverse Osmosis (Fig. 37)

Treatment Capacity (gpd)	Const. Cost (\$)	ENR Index	June 1995 ENR Index	Current Cost (\$)	Handy Whitman	Current Handy Whitman	Current Cost (\$)
3,000	42,000	4110	5433	55,520	261	319	51,333
5,000	48,000	4110	5433	63,451	261	319	58,667
10,000	60,000	4110	5433	79,314	261	319	73,333
30,000	86,000	4110	5433	113,683	261	319	105,111
60,000	130,000	4110	5433	171,847	261	319	158,889
100,000	180,000	4110	5433	237,942	261	319	220,000
200,000	300,000	4110	5433	396,569	261	319	366,667
500,000	650,000	4110	5433	859,234	261	319	794,444
1,000,000	1,300,000	4110	5433	1,718,467	261	319	1,588,889




Figure 35. Operation and maintenance requirements for covered and uncovered slow sand filters - labor and total O&M cost.

REVERSE OSMOSIS

Introduction

Reverse osmosis utilizes semi-permeable membranes to remove a high percentage of almost all inorganic ions, turbidity, bacteria, and viruses. Most organic matter is also removed, with the exception of many halogenated and low-molecular-weight compounds.

There are differences between different membrane types in their ability to handle variations in pH, turbidity, and chlorine. The cellulose acetate membranes generally require the feedwater pH to be between 5 and 6 to minimize hydrolysis of the membrane. Polyamide type membranes are damaged by exposure to chlorine. The two most commonly used membrane configurations are hollow fine fiber and spiral wound. The spiral wound element has a higher tolerance for suspended solids and is less susceptible to fouling than the hollow fine fiber element.

The efficiency of the membrane elements in reverse osmosis systems may be impaired by scaling (because of slightly soluble or insoluble compounds) or by fouling (because of the deposition of colloidal or suspended materials). Because of the possibility of scaling and/or fouling, a very important consideration in the design of reverse osmosis systems is the provision of adequate pretreatment to protect the membrane from excessive scaling and fouling and to avoid frequent cleaning requirements. In the development of cost data for reverse osmosis, adequate pretreatment was assumed to precede the reverse osmosis process, but costs for pretreatment facilities such as chemical clarification and filtration are not included.

Brine disposal can also be a major cost consideration. Potential disposal methods include sewer discharge, evaporation ponds, ocean disposal and well injection. Brine disposal facilities and costs are not included in the reverse osmosis systems presented in this section. A separate section is included in this report for brine disposal.

Advances in membrane technology have led to the development of membranes which are capable of operating at low pressures, about 14.06 kg/cm² (200 psi), in contrast to high pressure membranes which operate at 28.12 kg/cm² (400 psi) or more. Advantageously, low pressure membranes result in a substantial savings in process electrical energy. There may be disadvantages to the use of low pressure membranes however. Disadvantages relative to high pressure membranes include lower percentage removal of many contaminants¹, lower allowable feed water TDS or lower percent water recovery, and membrane technology which is still developing.

In the following discussion, low pressure refers to systems operated at 14.06 kg/cm² (200 psi) and high pressure to systems operated at 28.12 kg/cm² (400 psi).

Impact of Raw Water Quality on Treatment CostPretreatment Cost--

Pretreatment chemicals customarily utilized are sodium hexametaphosphate and sulfuric acid, with quantities required being highly variable, depending upon raw water quality. Another important parameter is silica, which may necessitate pretreatment for its removal. Costs for pretreatment chemicals and for silica pretreatment are not included in the following cost data.

Reverse osmosis units may be used for TDS removal, as well as the removal of individual contaminants addressed in the Interim Primary Drinking Water Regulations. The following paragraphs discuss the impact of raw water TDS, as well as individual contaminants in the raw water, upon treatment cost.

Total Dissolved Solids--

Feed water concentrations above 5,000 mg/L can lead to excessively high brine concentrations (>20,000 mg/L), which will generally result in a decrease in product water quality. To prevent this brine concentration buildup, it is necessary to lower the percentage of product water recovery. Lower product water recovery does not require a major change in the reverse osmosis unit, but does necessitate pumping larger quantities of feed water to the reverse osmosis unit. A revision in piping between the pressure vessels may also be required to change vessels to parallel operation, rather than operating some in series. This increases capital cost only slightly, due to the need for larger feed water pumps, but can create a large increase in electrical consumption and pretreatment chemicals, due to the larger quantity of water passed through the reverse osmosis units. A single pass unit will normally have a rejection of over 85% of feed water TDS. If a higher salt rejection is required, a high rejection membrane can be used, or the system can be operated at lower water recovery.

Individual Contaminants--

Little work has been conducted to determine the impact of varying feed concentrations of individual contaminants upon their percentage removal or the cost of removal. A recent publication by Huzstep¹ on work at Charlotte Harbor, Florida, indicated that arsenic (III), arsenic (V), fluoride, and nitrate percentage rejections were all independent of the feed concentrations. These contaminants were each added by spiking a natural groundwater of known concentration. High pressure membranes removed significantly higher percentages of these four components than did low pressure membranes.

Construction Costs

Construction cost data was developed for single stage (only one pass through the membrane) treatment systems which are capable of treating TDS concentrations up to about 2,000 mg/L for low pressure membranes and 10,000 mg/L for high pressure membranes. An operating pressure of 14.06 kg/cm² (200 psi) was utilized for low pressure membranes, and 28.12 kg/cm² (400 psi) for high pressure membranes. Construction costs are comparable for high and low pressure systems.

The temperature of the feedwater was assumed to be between 18.3° and 29.4°C (65° and 85°F), and the pH of the feedwater was assumed to be adjusted using acid injection to about 5.5 to 6.0 before the reverse osmosis process. The acid injection will prolong the life of a cellulose acetate membrane, but the primary function is to prevent calcium carbonate scale formation in the system. A degasifier following reverse osmosis will remove dissolved gases such as carbon dioxide and hydrogen sulfide from the product water, and will reduce neutralization requirements.

At TDS concentrations up to 5,000 mg/L, the assumed water recoveries for different flow ranges are as follows:

Feed Water Flow Range	Water Recovery (%)
2,500 - 10,000 gpd	40
10,000 - 50,000 gpd	50
50,000 - 100,000 gpd	65
100,000 gpd - 1.0 mgd	75

At concentrations above 5,000 mg/L, the percent recovery should be decreased in order to maintain a brine concentration less than 20,000 mg/L, which is necessary to limit osmotic pressure on the brine side of the membrane as well as to maintain quality of the product water. Salt rejections of over 85% should be achieved under these operating conditions. To maintain 20,000 mg/L in the brine, the following percent water recoveries are necessary:

TDS Concentration	Water Recovery (%)
5,000 mg/L	75
6,000 mg/L	70
7,000 mg/L	65
8,000 mg/L	60
9,000 mg/L	55
10,000 mg/L	50

It may be assumed that the capital cost of reverse osmosis treatment remains essentially unchanged as the TDS increases up to 10,000 mg/L, although the water recovery is decreased. This does increase the capacity (and therefore the capital cost) of the feedwater pumps, but this would increase the overall reverse osmosis system cost less than 5 percent. Thus, no separate cost data is presented for systems treating TDS concentrations greater than 5,000 mg/L. The largest effect is on O&M costs since the energy and pretreatment costs would increase in proportion to the increase in flow rate.

Commercial reverse osmosis systems are available from numerous manufacturers as either complete skid-mounted units or custom systems. For sizes ranging from 9.47 m³/d (2,500 gpd) up to between 378.5-946.3 m³/d (100,000-250,000 gpd), skid-mounted systems are generally used. Above 946.3 m³/d (250,000 gpd), either skid-mounted or custom systems are used. An advantage of using multiple standard systems above 946.3 m³/d (250,000 gpd), is the reliability provided by having several systems in case one unit needs to be shut

down for repairs. This cost analysis used skid-mounted units, or multiples of such units, for all size ranges.

Components taken into account in the construction cost estimates include housing, structural steel and miscellaneous metalwork, tanks, piping, valves, high pressure feed water pumps, reverse osmosis membrane elements and pressure vessels, flowmeters, cartridge filters, acid and polyphosphate feed equipment, cleaning equipment, caustic feed equipment, and a degasifier. The cost data are based on the use of either spiral-wound or hollow fine-fiber reverse osmosis membranes. Membrane materials can be cellulose acetate, polyamide, or thin film composite. A layout of a typical small system reverse osmosis system is shown in Figure 36.

Brine disposal costs and product water pumping costs are not included in the estimates. Construction cost estimates are presented in Table 46 and also in Figure 37.

Operation and Maintenance Requirements and Costs

Process electrical energy is required for the feed water pumps, pre- and post-treatment chemical feed pumps, and the degasifier. The combined feed water pump/motor efficiency increases as flow increases. The feed water pump/motor efficiencies which were used in the calculations were: 40% up to 37.85 m³/d (10,000 gpd) plant capacity, 50% up to 378.5 m³/d (100,000 gpd) plant capacity, and 80% over 378.5 m³/d (100,000 gpd) plant capacity. Energy requirements used for the chemical feed pumps and degasifier were 10% of the high pressure pump energy for plant capacities less than 189.3 m³/d (50,000 gpd), and 5% for plant capacities over 189.3 m³/d (50,000 gpd).

Process energy varies with the percent water recovery. As discussed under Construction Costs, higher percent water recoveries are typically used as system size increases, resulting in lower process energy requirements per unit of water produced. However, as TDS increases above 5,000 mg/L, lower percent water recoveries are necessary to maintain a reasonable brine concentration and to prevent deterioration of product water quality. Process electrical data has been developed for feed water TDS concentrations of 2,000 mg/L for low pressure systems and 5,000, 8,000, and 10,000 mg/L for high pressure systems.

Electrical energy for building lighting, heating, and ventilating was calculated based on an estimated floor area required for complete housing of the reverse osmosis equipment, with the exception of the degasifier, which is located outside. A building energy requirement of 209.8 kWh/m²/yr (19.5 kWh/sq ft/yr) was used for lighting, heating, and ventilation. This requirement is based upon a lighting use factor of three hours per day.

The largest maintenance material requirement is for membrane replacement; a membrane life of three years was used in the cost estimates. Other maintenance material requirements are for replacement of cartridge filters, for membrane cleaning chemicals, and for materials needed for periodic repair of pumps, motors, and electrical control equipment. Costs for pretreatment chemicals, such as acid and polyphosphate, and post-treatment chemicals, such as caustic, are not included in the maintenance material estimates, but they

TABLE 46. CONSTRUCTION COST SUMMARY FOR REVERSE OSMOSIS SYSTEMS

Cost Category	Plant Capacity, gpd				
	2,500	10,000	50,000	100,000	1,000,000
Manufactured Equipment	\$20,300	\$30,000	\$69,600	\$123,000	\$154,800
Labor	800	1,200	1,500	2,800	7,500
Electrical, Instrumentation	3,200	4,600	10,700	18,700	45,900
Housing	11,900	13,900	16,400	18,500	38,400
Subtotal	36,200	49,700	98,200	163,000	276,600
Design Contingencies	5,400	7,500	14,700	24,500	82,000
Total	\$41,600	\$57,200	\$112,900	\$187,500	\$628,600
					\$1,157,600

- Notes: 1. Housing requirements from smallest plant capacity to largest are: 140, 170, 210, 250, 800, and 1,500 sq ft. Ceiling height in buildings is 14 ft.
2. Costs are valid for feed water TDS concentrations up to 10,000-mg/L. However, percentage recovery of feed water decreases above 5,000 mg/L TDS.

are discussed in the following section. Maintenance material costs increase slightly as the percent recovery drops, due to increased pumping to the reverse osmosis unit.

Labor requirements are for cleaning and replacing membranes, replacing cartridge filters, maintaining the high pressure and other pumps, preparing treatment chemicals and determining proper dosages, maintaining chemical feed equipment, and monitoring performance of the reverse osmosis membranes. Membrane cleaning was assumed to occur monthly. In estimating labor requirements, a minimum of about one hr/day of labor was assumed for the smallest plant.

Operation and maintenance requirements are summarized in Table 47 for low pressure systems and in Table 48 for high pressure systems, and are illustrated for both high and low pressure systems in Figures 38 and 39.

TABLE 47. OPERATION AND MAINTENANCE SUMMARY FOR LOW PRESSURE REVERSE OSMOSIS SYSTEMS

Average Plant Flow Rate, gpd	Energy, kwh/yr			Maintenance Material, \$/yr	Labor, hr/yr	Total Cost, \$/yr
	Building	Process	Total			
2,500	2,800	9,900	12,700	500	340	5,100
10,000	3,300	26,300	29,600	1,700	360	7,800
50,000	4,100	100,100	104,200	8,000	480	20,600
100,000	4,900	180,400	185,300	15,600	610	34,500
500,000	15,600	853,200	868,800	67,100	870	137,500
1,000,000	29,300	1,606,000	1,635,300	117,900	1,130	244,800

Note: Total cost is based on \$0.07/kwh of electrical energy and \$11.00/hour of labor.

Typical Chemical Requirements and Costs

The principal chemicals required in small reverse osmosis systems are sodium hexametaphosphate for control of scaling and fouling, sulfuric acid for pH adjustment prior to treatment, and sodium hydroxide to increase the pH following treatment. The required cost for each chemical is a function of the dosage, the unit cost of the chemical and the percent water recovery. Using the following dosages and unit chemical costs, the annual chemical costs in Table 49 were calculated.

Chemical	Dosage	Unit Cost
Sodium Hexametaphosphate	6 mg/L	\$1.10/lb
Sulfuric Acid	75 mg/L	\$0.08/lb
Sodium Hydroxide	15 mg/L	\$0.17/lb

TABLE 48. OPERATION AND MAINTENANCE SUMMARY FOR REVERSE OSMOSIS SYSTEMS

Average Plant Flow Rate, gpd	Energy, kwh/yr			Maintenance Material, \$/yr	Labor, hr/yr	Total Cost, \$/yr
	Building	Process	Total			
Feed Water TDS Concentrations Up to 5,000 mg/L						
2,500	2,800	18,000	20,800	500	340	5,700
10,000	3,300	48,200	51,500	1,700	360	9,300
50,000	4,100	191,100	195,200	8,000	480	27,000
100,000	4,900	344,400	349,300	14,600	610	45,800
500,000	15,600	1,629,000	1,644,600	67,100	870	191,800
1,000,000	29,300	3,066,000	3,095,300	117,900	1,130	347,000
Feed Water TDS Concentrations = 8,000 mg/L						
2,500	2,800	18,000	20,800	500	340	5,700
10,000	3,300	48,200	51,500	1,700	360	9,300
50,000	4,100	191,100	195,200	8,000	480	27,000
100,000	4,900	373,000	377,900	14,900	630	48,300
500,000	15,600	2,036,200	2,051,800	70,200	940	224,200
1,000,000	29,300	3,832,500	3,861,800	122,900	1,220	406,700
Feed Water TDS Concentrations = 10,000 mg/L						
2,500	2,800	18,000	20,800	500	340	5,700
10,000	3,300	48,200	51,500	1,700	360	9,300
50,000	4,100	191,100	195,200	8,000	480	27,000
100,000	4,900	447,700	452,600	15,500	680	54,700
500,000	15,600	2,443,500	2,459,100	73,200	1,020	256,600
1,100,000	29,300	4,599,000	4,628,300	127,700	1,310	466,100

Note: Total cost is based on \$0.07/kwh of electrical energy and \$11.00/hour of labor.

TABLE 49. TYPICAL CHEMICAL COSTS FOR REVERSE OSMOSIS SYSTEMS

Average Plant Flow Rate, gpd	Sodium Hexametaphosphate, \$/yr	Sulfuric Acid, \$/yr	Sodium Hydroxide, \$/yr	Total Chemical Cost, \$/yr
Feed Water TDS Concentrations Up to 5,000 mg/L				
2,500	130	120	50	300
10,000	500	460	200	1,160
50,000	2,000	1,830	780	4,610
100,000	3,100	2,800	1,200	7,100
500,000	13,400	12,200	5,200	30,800
1,000,000	26,800	24,300	10,300	61,400
Feed Water TDS Concentrations = 8,000 mg/L				
2,500	130	120	50	300
10,000	500	460	200	1,160
50,000	2,000	1,830	780	4,610
100,000	3,400	3,000	1,300	7,700
500,000	16,800	15,200	6,500	38,500
1,000,000	33,500	30,400	12,900	76,800
Feed Water Concentrations = 10,000 mg/L				
2,500	130	120	50	300
10,000	500	460	200	1,160
50,000	2,000	1,830	780	4,610
100,000	4,000	3,700	1,600	9,300
500,000	20,100	18,300	7,800	46,200
1,000,000	40,200	36,500	15,500	92,200

Note: Chemical dosages and costs used in this table were:
 Sodium Hexametaphosphate - 6 mg/L; \$1.10/lb
 Sulfuric Acid - 75 mg/L; \$0.08/lb
 Sodium Hydroxide - 15 mg/L; \$0.17/lb

The required chemical dosages will vary widely between water supplies, and laboratory or pilot plant testing should be used to determine requirements. Additionally, the cost of chemicals will be a function of the geographical area and the quantity of chemical purchased.

Field Data Collection

Operating data on reverse osmosis treatment systems were collected at the Charlotte Harbor Water Association, Harbor Heights, Florida, and the Bryn Mawr Water Company, Vero Beach, Florida. The Charlotte Harbor plant has two treatment modules which operate at 27.4 kg/cm² (390 psi) and have a combined

treatment capacity of 1,136 m³/d (0.3 mgd) and one low pressure unit which operates at 16.5 kg/cm² (235 psi) and has a treatment capacity of 568 m³/d (0.15 mgd). The total operating flow rate of both the high and low pressure units is 1,120 m³/d (0.296 mgd). The TDS concentration in the raw water supply was not obtained during the field sampling.

The Bryn Mawr plant at Vero Beach has an installed capacity of 454 m³/d (0.12 mgd) and an operating flow rate of 163 m³/d (0.043 mgd). The operating pressure is 28.1 kg/cm² (400 psi). The TDS in the raw water supply was not noted during collection of field data.

A comparison of field operating data and information from Figures 38 and 39 is shown following:

	Charlotte Harbor		Vero Beach	
	Field Data	Data from Figures 38 and 39	Field Data	Data from Figures 38 and 39
Electrical Energy, kwh/hr				
Process	-	750,000	-	160,000
Building	-	14,000	-	4,000
Total	788,200	764,000	218,800	164,000
Maintenance Material, \$/yr	10,400	38,000	890	6,000
Labor, hr/yr	5,140	800	640	480

Maintenance material requirements are low at both plants because replacement of membranes has not been necessary at either plant. However, Figure 38 data include a cost for membrane replacement every three years. The large difference in labor requirement at Charlotte Harbor is believed to be the result of an inappropriate division of labor between the treatment plant and the water distribution system.

References

1. Huxstep, H.R., "Inorganic Contaminant Removal From Drinking Water By Reverse Osmosis," EPA Report 600/S2-81-115, October, 1981.




Figure 36. Typical-skid mounted reverse osmosis installation





Figure 37. Construction cost for reverse osmosis system.

Graph #11 Reverse Osmosis



ENR Index Handy Whitman

Note: Source D, Figure 113, pp. 246-250.

Estimating Water Treatment Costs - Vol. 2

GRAPH #11
Reverse Osmosis (Fig. 113)

Treatment Capacity (mgd)	Const. Cost (\$)	ENR Index	June 1995 ENR Index	Current Cost (\$)	Handy Whitman	Current Handy Whitman	Current Cost (\$)
1	780,000	2851	5433	1,486,405	171	303	1,382,105
2	1,300,000	2851	5433	2,477,341	171	303	2,303,509
5	2,800,000	2851	5433	5,335,812	171	303	4,961,404
10	5,400,000	2851	5433	10,290,495	171	303	9,568,421

GRAPH #12
Raw Water Pumping Facilities (Fig. 201)

Treatment Capacity (mgd)	Const. Cost (\$)	ENR Index	June 1995 ENR Index	Current Cost (\$)	Handy Whitman	Current Handy Whitman	Current Cost (\$)
30 Feet TDH							
1	20,000	2851	5433	38,113	171	303	35,439
2	25,000	2851	5433	47,641	171	303	44,298
5	37,000	2851	5433	70,509	171	303	65,561
10	55,000	2851	5433	104,811	171	303	97,456
20	86,000	2851	5433	163,886	171	303	152,386
50	180,000	2851	5433	343,016	171	303	318,947
100	325,000	2851	5433	619,335	171	303	575,877
100 Feet TDH							
1	26,000	2851	5433	49,547	171	303	46,070
2	31,000	2851	5433	59,075	171	303	54,930
5	49,000	2851	5433	93,377	171	303	86,825
10	74,000	2851	5433	141,018	171	303	131,123
20	125,000	2851	5433	238,206	171	303	221,491
50	250,000	2851	5433	476,412	171	303	442,982
100	490,000	2851	5433	933,767	171	303	868,246

EPA - Estimating WTP Costs
1-200 MGD

Culp + Culp
Cost Curves

SECTION 4

COST CURVES

CONSTRUCTION COST CURVES

The construction cost curves were developed using equipment cost data supplied by manufacturers, cost data from actual plant construction, unit takeoffs from actual and conceptual designs, and published data. When unit cost takeoffs were used to determine costs from actual and conceptual designs, estimating techniques from Richardson Engineering Services Process Plant Construction Estimating Standards,¹⁹ Mean's Building Construction Cost Data,²⁰ and the Dodge Guide for Estimating Public Works Construction Costs²¹ were often utilized. An example illustrating how costs were determined using unit cost takeoffs from an actual design for a reinforced concrete wall (similar to a wall for a clarifier or a filter structure) is presented in Appendix C. The cost curves that were developed were then checked and verified by a second engineering consulting firm, Zurheide-Herrmann, Inc., using an approach similar to that a general contractor would utilize in determining his construction bid. Every attempt has been made to present the conceptual designs and assumptions that were incorporated into the curves. Adjustment of the curves may be necessary to reflect site-specific conditions, geographic or local conditions, or the need for standby power. The curves should be particularly useful for estimating the relative economics of alternative treatment systems and in the preliminary evaluation of general cost level to be expected for a proposed project. The curves contained in this report are based on October 1978 costs.

The construction cost was developed by determining and then aggregating the cost of the following eight principal components: (1) Excavation and site work; (2) manufactured equipment; (3) concrete; (4) steel, (5) labor; (6) pipe and valves; (7) electrical equipment and instrumentation; and (8) housing. These eight categories were utilized primarily to facilitate accurate cost updating, which is discussed in a subsequent section of this chapter. The division will also be helpful where costs are being adjusted for site-specific, geographic and other special conditions. The eight categories include the following general items:

Excavation and Site Work. This category includes work related only to the applicable process and does not include any general site work such as sidewalks, roads, driveways, or landscaping.

Manufactured Equipment. This category includes estimated purchase cost of pumps, drives, process equipment, specific purpose controls, and other items that are factory made and sold with equipment.

Concrete. This category includes the delivered cost of ready mix concrete and concrete-forming materials.

Steel. This category includes reinforced steel for concrete and miscellaneous steel not included under manufactured equipment.

Labor. The labor associated with installing manufactured equipment, and piping and valves, constructing concrete forms, and placing concrete and reinforcing steel are included here.

Pipe and Valves. Cast iron pipe, steel pipe, valves, and fittings have been combined into a single category. The purchase price of pipe, valves, fittings, and associated support devices are included within this category.

Electrical Equipment and Instrumentation. The cost of process electrical equipment, wiring, and general instrumentation associated with the process equipment is included in this category.

Housing. In lieu of segregating building costs into several components, this category represents all material and labor costs associated with the building, including heating, ventilating, air conditioning, lighting, normal convenience outlets, and the slab and foundation.

The subtotal of the costs of these eight categories includes the cost of material and equipment purchase and installation, and subcontractor's overhead and profit. To this subtotal, a 15-percent allowance has been added to cover miscellaneous items not included in the cost takeoff as well as contingency items. Experience at many water treatment facilities has indicated that this 15-percent allowance is reasonable. Although blanket application of this 15-percent allowance may result in some minor inequity between processes, these are generally balanced out during the combination of costs for individual processes into a treatment system.

The construction cost for each unit process is presented as a function of the most applicable design parameter for the process. For example, construction costs for package gravity filter plants are plotted versus capacity in gallons per minute, whereas ozone generation system costs are presented versus pounds per day of feed capacity. Use of such key design parameters allows the curves to be utilized with greater flexibility than if all costs were plotted versus flow.

The construction costs shown in the curves are not the final capital cost for the unit process. The construction cost curves do not include costs for special site work, general contractor overhead and profit, engineering, or land, legal, fiscal, and administrative work and interest during construction. These cost items are all more directly related to the total cost of a project rather than the cost of the individual unit processes. They are therefore most appropriately added following cost summation of the individual unit processes, if more than one unit process is required. The examples presented in a subsequent section of this volume illustrate the recommended method for the addition of these costs to the construction cost.

Construction costs are presented for wash water storage tanks in Table 91 and Figure 112.

REVERSE OSMOSIS

Construction Cost

Reverse osmosis utilizes membranes to remove a high percentage of almost all inorganic ions, turbidity, bacteria, and viruses. Most organic matter is also removed, with the exception of several materials, including most halogenated and low molecular weight compounds.

Commercial units are available in sizes up to about 5,000 gpd for the membrane elements and up to 30,000 gpd for the reverse osmosis modules (pressure vessels). Therefore, large-scale plants would be composed of many small, parallel modules. Components taken into account in the construction cost estimates include housing, structural steel and miscellaneous metalwork, tanks, piping, valves, pumps, reverse osmosis membrane elements and pressure vessels, flow meters, cartridge filters, acid and polyphosphate feed equipment, and cleaning equipment. The cost curves are based on the use of either spiral-wound or hollow fine-fiber reverse osmosis membranes.

The efficiency of the membrane elements in reverse osmosis systems may be impaired by scaling because of slightly soluble or insoluble compounds, or by fouling as a result of the deposition of colloidal or suspended materials. Because of this, a very important consideration in the design of a reverse osmosis system is the provision of adequate pretreatment to protect the membrane from excessive scaling and fouling and to avoid frequent cleaning requirements. In the development of the cost curves, adequate pretreatment was assumed to precede the reverse osmosis process, and costs for pretreatment are not included in the estimates.

The construction cost curve applies to waters with a total dissolved solids (TDS) concentration ranging up to about 10,000 mg/l. Other considerations, such as calcium sulfate and silica concentrations and also the desired water recovery, affect costs more than the influent TDS concentration. The temperature of the feedwater is assumed to be between 65° and 95°F, and the pH of the feedwater is adjusted to about 5.5 to 6.0 before the reverse osmosis process. A single-pass treatment system (only one pass through the membrane) is assumed, with an operating pressure of 400 to 450 psi. The assumed water recoveries for different flow ranges are as follows:

<u>Flow Range (mgd):</u>	<u>Water Recovery (%)</u>
1 - 1080
10 - 20085

Brine disposal costs are not included in the estimates.

Construction costs are presented in Table 92 and also in Figure 113.

Table 92
 Construction Cost for
 Reverse Osmosis

Cost Category	Plant Capacity (mgd)			
	1.0	10	100	200
Manufactured Equipment	\$474,210	\$3,456,480	\$29,174,260	\$56,438,930
Labor	70,420	346,850	2,312,340	2,837,870
Electrical and Instrumentation	65,740	486,270	3,635,690	6,947,480
Housing	<u>64,260</u>	<u>462,650</u>	<u>2,409,660</u>	<u>4,176,740</u>
SUBTOTAL	674,630	4,754,250	37,531,950	70,401,020
Miscellaneous and Contingency	<u>101,190</u>	<u>713,140</u>	<u>5,629,790</u>	<u>10,560,150</u>
TOTAL	775,820	5,467,390	43,161,740	80,961,170

249





Figure 113. Construction cost for reverse osmosis.

GRAPH #15 Reverse Osmosis



ENR Index Handy Whitman

Note: Source E, Figure 35, pp. 88, 92-95.

Estimating Water Treatment Costs - Vol. 3

GRAPH #15
Reverse Osmosis (Fig. 35)

Treatment Capacity (gpd)	Const. Cost (\$)	ENR Index	June 1995 ENR Index	Current Cost (\$)	Handy Whitman	Current Handy Whitman	Current Cost (\$)
2,500	14,000	2851	5433	26,679	181	319	24,674
5,000	17,000	2851	5433	32,396	181	319	29,961
7,000	20,000	2851	5433	38,113	181	319	35,249
10,000	25,000	2851	5433	47,641	181	319	44,061
50,000	79,000	2851	5433	150,546	181	319	139,232
100,000	140,000	2851	5433	266,791	181	319	246,740
200,000	225,000	2851	5433	428,771	181	319	396,547
500,000	450,000	2851	5433	857,541	181	319	793,094
1,000,000	760,000	2851	5433	1,448,292	181	319	1,339,448

GRAPH #16
Package High - Service Pump Stations (Fig. 53)

Treatment Capacity (gpm)	Const. Cost (\$)	ENR Index	June 1995 ENR Index	Current Cost (\$)	Handy Whitman	Current Handy Whitman	Current Cost (\$)
30	12,500	2851	5433	23,821	155	259	20,887
50	13,000	2851	5433	24,773	155	259	21,723
70	14,000	2851	5433	26,679	155	259	23,394
100	14,500	2851	5433	27,632	155	259	24,229
200	16,000	2851	5433	30,490	155	259	26,735
500	18,000	2851	5433	34,302	155	259	30,077
1,000	20,000	2851	5433	38,113	155	259	33,419

was assumed, with only occasional shutdown to clean cells and replace weak ultraviolet lamps. Building energy is for heating, lighting, and ventilation.

Maintenance materials are related to the replacement cost of the ultraviolet lamps, which are generally replaced after operating continuously for about 8,000 hr.

Labo- requirements are related to occasional cleaning of the quartz sleeves and periodic replacement of the ultraviolet lights.

Operation and maintenance requirements are summarized in Table 38 and also presented in Figures 33 and 34.

REVERSE OSMOSIS

Construction Cost

Reverse osmosis utilizes membranes to remove a high percentage of almost all inorganic ions, turbidity, bacteria, and viruses. Most organic matter is also removed, with the exception of several materials, including most halogenated and low-molecular-weight compounds.

Construction costs were developed for complete reverse osmosis plants in the size ranges from 2,500 gpd to 1 mgd. Commercial units are available in sizes up to about 5,000 gpd for the membrane elements and up to 30,000 gpd for the reverse osmosis modules (pressure vessels). Therefore, large-scale plants are composed of many smaller, parallel modules. Components taken into account in the construction cost estimates include housing, structural steel and miscellaneous metalwork, tanks, piping, valves, pumps, reverse osmosis membrane elements and pressure vessels, flow meters, cartridge filters, acid and polyphosphate feed equipment, and also cleaning equipment. The cost curves are based on the use of either spiral-wound or hollow fine-fiber reverse osmosis membranes.

The efficiency of the membrane elements in reverse osmosis systems may be impaired by scaling (because of slightly soluble or insoluble compounds) or by fouling (because of the deposition of colloidal or suspended materials). Because of this possibility, a very important consideration in the design of a reverse osmosis system is the provision of adequate pretreatment to protect the membrane from excessive scaling and fouling and to avoid frequent cleaning requirements. In the development of the cost curves, adequate pretreatment was assumed to precede the reverse osmosis process, but costs for pretreatment are not included in the estimates.

The construction cost curve applies to waters with a total dissolved solids (TDS) concentration ranging up to about 10,000 mg/l. Other considerations, such as calcium sulfate and silica concentrations and also the desired water recovery, affect cost more than the influent TDS concentration. The temperature of the feedwater is assumed to be between 65° and 95° F, and the pH of the feedwater is adjusted to about 5.5 to 6.0 before the reverse osmosis process. A single-pass treatment system (only one pass through the membrane) is assumed, with an operating pressure of 400 to 450 psi. The

assumed water recoveries for different flow ranges are as follows:

<u>Flow Range</u>	<u>Water Recovery (%)</u>
2,500 - 10,000 gpd	60
10,000 - 100,000 gpd	70
100,000 gpd - 1.0 mgd	75

Brine disposal costs are not included in the estimates. Construction cost estimates are presented in Table 39 and also in Figure 35.

Operation and Maintenance Cost

Electrical energy usage is included for the high-pressure feedwater pumps, based on an operating pressure of 450 psi and on the water recoveries listed in the construction cost write-up. For other pumps and chemical feed equipment, an energy usage of 10 percent of the usage for the high-pressure pumps was assumed. Electrical energy for lighting, heating, and ventilating was calculated, based on an estimated floor area required for complete housing of the reverse osmosis equipment.

The largest maintenance material requirement is for membrane replacement; a membrane life of 3 years was used in the cost estimates. Other maintenance material requirements are for replacement of cartridge filters, for membrane cleaning chemicals, and for materials needed for periodic repair of pumps, motors, and electrical control equipment. Costs for pretreatment chemicals, such as acid and polyphosphate, are not included in the estimates. The chemicals utilized and the dosages required will show great variability between different water supplies and should be determined from pilot plant testing.

Labor requirements are for cleaning and replacing membranes, replacing cartridge filters, maintaining the high-pressure and other pumps, preparing treatment chemicals and determining proper dosages, maintaining chemical feed equipment, and monitoring performance of the reverse osmosis membranes. Membrane cleaning was assumed to occur monthly. In estimating labor requirements, a minimum of about 1.5 hr/day of labor was assumed for the smallest plant.

Operation and maintenance requirements are summarized in Table 40 and illustrated in Figures 36 and 37.

PRESSURE ION EXCHANGE SOFTENING

Construction Cost

Cation exchange resins can be utilized for the removal of hardness, barium, trivalent chromium, lead, manganese, mercury, and radium. Construction costs were developed for pressure ion exchange softening systems using the conceptual information presented in Table 41. The contact vessels were fabricated steel, with a baked phenolic lining added after fabrication and constructed for 100 psi working pressure. The depth of resin was 6 ft,

Table 39
 Construction Cost for
 Reverse Osmosis

Cost Category	Plant Capacity (gpd)			
	2,500	10,000	100,000	1,000,000
Manufactured Equipment	\$ 3,710	\$11,140	\$81,050	\$ 474,210
Labor	770	2,210	16,080	70,420
Electrical and Instrumentation	4,190	4,710	10,680	65,740
Housing	2,680	4,070	6,430	64,260
SUBTOTAL	11,350	22,130	114,240	674,630
Miscellaneous and Contingency	1,700	3,320	17,140	101,190
TOTAL	13,050	25,450	131,380	775,820

93






Figure 35. Construction cost for reverse osmosis.

APPENDIX N

One Section (8 units)




One Street (40 units)



Whole Installation (120 units)

8" Gravity Sewer

- 10'-12' deep => 1782 lf
- 8'-10' deep => 1782 lf
- 6'-8' deep => 1689 lf
- 0'-6' deep => 750 lf



Case E

Gravity Sewer Costs① 8" Gravity Sewer (SDR 35-PVC)

0-6' ⇒ \$9.25/ft

6-8' ⇒ \$12.00/ft

8-10' ⇒ \$16.00/ft

10-12' ⇒ \$18.50/ft

② Full Installation Adders

a) Mobilization ≈ 10%

b) Testing ≈ \$1/ft

c) Permitting ≈ \$500

③ Manholes * (Installed Cost using Bid Tabs + precast
= manufacturers values)

0-6' ⇒ \$1300/ea.

6-8' ⇒ \$1550/ea.

8-10' ⇒ \$1800/ea.

10-12' ⇒ \$2100/ea.

Cost Calculations* CASE A

$$\text{manhole} \Rightarrow = \$ 2100$$

$$\text{pump station} \Rightarrow (34,411.2) \left(\frac{\$}{120} \right) = \$ 2,294.08$$

$$400' \ 8" \ \text{sewer} \Rightarrow (400)(18.5) = \$ 7,400$$

$$400' \ \text{Testing} \Rightarrow (400)(\$1) = \$ 400$$

$$\text{Permitting} \Rightarrow = \$ 500$$

$$\text{Mobilization} \Rightarrow (12,694)(0.1) = \underline{\underline{\$ 1,269.41}}$$

$$\text{TOTAL} \Rightarrow = \$ 13,963.50$$

$$\# \ \text{units} / \ \text{lots} = 8 \ \text{lots}$$

$$\text{UNIT COST} \Rightarrow \frac{\$}{\text{LOT}} = \boxed{\$ 1,745.44}$$

HARTMAN & ASSOCIATES, INC. engineers, hydrogeologists, surveyors & management consultants	SH. NO: <u>3</u>	JOB NO: <u>95-145.00</u>
	MADE BY: <u>JSW</u>	DATE: <u>10/1/95</u>
	CHECKED BY:	DATE:

Cost Calculations

Case B

Cost (\$)

Manholes ⇒ (10-12') # 2100 (8-10') # 1800	→	\$ 3,900
Pump Station ⇒ (34,411.2)(16/120)	→	\$ 4,588.16
8" gravity sewer ⇒ (10-12') # 10,989 (8-10') # 3,296	→	\$ 14,285
800' Testing ⇒ (800)(.5/ft)	=	\$ 800
Permitting ⇒	=	\$ 500
Mobilization ⇒ (24,073.16)(0.1)	=	<u>\$ 2,407.32</u>

TOTAL \$ 26,480.5

units / lots = 16 lots

UNIT COST ⇒ \$/lot = \$ 1,655.03

HARTMAN & ASSOCIATES, INC. engineers, hydrogeologists, surveyors & management consultants	SH. NO: <u>4</u>	JOB NO: <u>95-145.00</u>
	MADE BY: <u>JJW</u>	DATE: <u>10/1/95</u>
	CHECKED BY:	DATE:

Cost Calculations

Case C

	<u>Cost (\$)</u>
Manholes ⇒ (10-12') \$2100 (8-10') \$1800 (6-8') \$1550	> = \$15,450
Pump Station ⇒ (34,411.2) (24/120)	= \$6,882.24
8" gravity sewer ⇒ (10-12') \$10,989 (8-10') \$9,504 (6-8') \$144	> = \$20,637
1200' Testing ⇒ (1200)(\$1/ft)	= \$1,200
Permitting ⇒	= \$500
Mobilization ⇒ (34,669.24) (0.1)	= <u>\$3466.92</u>
TOTAL	\$38,136.16
# units / lots	= 24 lots
UNIT COST ⇒ \$/lot	= \$1,589.01

HARTMAN & ASSOCIATES, INC. engineers, hydrogeologists, surveyors & management consultants	SH. NO: <u>5</u>	JOB NO: <u>95-145.00</u>
	MADE BY: <u>JSW</u>	DATE: <u>10/1/85</u>
	CHECKED BY:	DATE:

Cost Calculations

Case D

Cost (\$)

Manholes \Rightarrow

(10-12')	\$ 2100
(8-10')	\$ 1800
(6-8')	\$ 3100

 $\rangle = \$ 7,000$

1 pump station $\Rightarrow (34,411.20)(32/120) = \$ 9,176.32$

8" gravity sewer \Rightarrow

(10-12')	\$ 10,989
(8-10')	\$ 9,504
(6-8')	\$ 4,944

 $\rangle = \$ 25,437$

1600' Testing $\Rightarrow (1600)(\$1/ft) = \$ 1600$

Permitting $\Rightarrow \$ 500$

Mobilization $\Rightarrow (43,713.32)(0.1) = \underline{\underline{\$ 4,371.33}}$

TOTAL $\quad \quad \quad \$ 48,085$

lots/units = 32 lots

UNIT COST = $\$ / lot = \boxed{\$ 1,502.65}$

HARTMAN & ASSOCIATES, INC. engineers, hydrogeologists, surveyors & management consultants	SH. NO.: <u>6</u>	JOB NO.: <u>95-145.00</u>
	MADE BY: <u>JJW</u>	DATE: <u>10/1/95</u>
	CHECKED BY:	DATE:

Case E Cost

	Cost (\$)
Manholes ⇒ (10-12') (\$2100)(3) = \$ 6300	} = \$ 24,900
(8-10') (\$1900)(3) = \$ 5400	
(6-8') (\$1550)(6) = \$ 9300	
(0-6') (\$1300)(3) = \$ 3900	

Pump Station ⇒ 34,411.20 \$ 34,411.20

8" gravity sewer ⇒ (10-12') (1782)(18.50) =	} = \$ 88,684.50
(8-10') (1782)(16.00) =	
(6-8') (1659)(12) =	
(0-6') (750)(9.25) =	

6000' Testing ⇒ (6000)(.1) = \$ 6000

Permitting ⇒ = \$ 500

Mobilization ⇒ (154,495.7)(0.1) = \$ 15,449.57

TOTAL = \$ 169,945.27

lots/units = 120 lots

UNIT COST = \$ 1416.21

80 units ⇒ \$ 1418.50

40 units ⇒ \$ 1425.05

RECORD OF TELEPHONE COMMUNICATION

DATE: 9/8/95 TIME: 9:30

PROJECT NAME: SSU - Economy of Scale PROJECT NO.: 95-145.00

PARTY CALLING: Janey Wallace COMPANY: HAI

PARTY CONTACTED: Scott Edwards COMPANY: Taylor Precast

SUBJECT: Manhole Costs 4' diameter Susan Pope
Todd Phillips

TELEPHONE COMMUNICATION SUMMARY (Including Decisions & Commitments)

Depth	#	* 8" Wall Thickness *
0-6	\$ 578	
6-8	\$ 698	
8-10	\$ 836	
10-12	\$ 950	* No Economies of Scale *
12-14	\$ 1076	

ACTION REQUIRED

HARTMAN & ASSOCIATES, INC.

engineers, hydrogeologists, scientists & management consultants

RECORD OF TELEPHONE COMMUNICATION

9/7/95 TIME: 3:40

PROJECT NAME: SSU - Economy of Scale PROJECT NO.: 95-145.00

PARTY CALLING: J J W COMPANY: HAI

PARTY CONTACTED: Brian Penner COMPANY: Mitchell & Stark

SUBJECT: Pipe install. costs (813) 597-2165

TELEPHONE COMMUNICATION SUMMARY (Including Decisions & Commitments)

* Pressure testing (w+F.M.) Avg. 50¢/ft small job → 75¢/ft
large job → 25¢/ft

* Disinfection (w.m.) * Avg. \$1/ft small job → \$2/ft
\$1.50 large job → \$1/ft

* Gravity Sewer - T.V. Test \$1.00/ft

ACTION REQUIRED

_____ **HARTMAN & ASSOCIATES, INC.**
engineers, hydrogeologists, scientists & management consultants

SANITARY SEWER

9/19/94

	SIZE DESCRIPTION	PROJECT	QUANTITY	UNIT	UNIT PRICE	BIDDER	YEAR	
FITTINGS	8" 90 DEG. BEND	2	4	EA	\$285.00	MEYER	1994	
	8" X 22 1/2" BEND	2	1	EA	\$275.00	MEYER	1994	
	D.I. (MISC. FITTINGS)	1	20.5	TN	\$5,000.00	MEYER	1988	
	FITTINGS (OFF SITE)	2	1	LS	\$1,300.00	BRIAR	1994	
	16" X 6" D.I. CROSS FITTINGS	1	2	EA	\$1,080.00	MEYER	1988	
	20" X 6" D.I. CROSS FITTINGS	1	2	EA	\$1,400.00	MEYER	1988	
	24" X 6" D.I. CROSS FITTINGS	1	3	EA	\$1,710.00	MEYER	1988	
	30" X 6" D.I. CROSS FITTINGS	1	2	EA	\$3,110.00	MEYER	1988	
	8" X 6" WYE WITH 45 DEG. BEND	2	58	EA	\$37.00	MEYER	1994	
	10" X 6" WYE WITH 45 DEG. BEND	2	19	EA	\$80.00	MEYER	1994	
	6" X 4" DOUBLE WYE	2	56	EA	\$28.00	MEYER	1994	
	4" PLUG	2	112	EA	\$2.60	MEYER	1994	
	6" PLUG	2	83	EA	\$4.70	MEYER	1994	
	DU LILE IRON PIPE	8" DIP (RESTRAINED)	2	120	LF	\$48.00	MEYER	1994
		10" DIP (12'-14' CUT)	2	20	LF	\$38.00	BRIAR	1994
10" DIP (10'-12' CUT)		2	20	LF	\$35.75	MEYER	1994	
8" DIP FM		3	80	LF	\$37.00	JMHC	1994	
10" DIP FM			150	LF	\$24.15	ESTERSON	1986	
10" DIP FM		3	40	LF	\$49.50	JMHC	1994	
12" DIP FM			455	LF	\$28.26	ESTERSON	1986	
8" DIP FM			180	LF	\$20.89	ESTERSON	1986	
8" DIP FM (0'-6' CUT)			18	LF	\$18.00	HUBBARD	1990	
8" DIP FM (0'-6' CUT)			18	LF	\$19.70	GOPHER	1990	
8" DIP FM (0'-6' CUT)			18	LF	\$20.00	WITHERINGTON	1990	
8" DIP (0'-6' CUT)			18	LF	\$26.80	B & D	1990	
8" DIP (6'-8' CUT)			20	LF	\$1,500.00	X-RDS	1988	
8" DIP (8'-10' CUT)			36	LF	\$28.15	B & D	1990	
8" DIP FM (8'-10' CUT)			36	LF	\$20.00	HUBBARD	1990	
8" DIP FM (8'-10' CUT)			36	LF	\$21.95	GOPHER	1990	
8" DIP FM (8'-10' CUT)			36	LF	\$22.00	WITHERINGTON	1990	
16" DIP FM (CL 50)		1	3250	LF	\$31.20	MEYER	1988	
16" DIP FM (CL 50)		1	3250	LF	\$30.00	MEYER	1988	
16" DIP FM (CL 50)		1	250	LF	\$43.15	MEYER	1988	
20" DIP FM (CL 50)	1	250	LF	\$55.90	MEYER	1988		
20" DIP FM (CL 50)	1	3265	LF	\$37.00	MEYER	1988		
20" DIP FM (CL 50)	1	3265	LF	\$40.20	MEYER	1988		
24" DIP FM (CL 50)	1	5645	LF	\$48.90	MEYER	1988		
24" DIP FM (CL 50)	1	5645	LF	\$45.00	MEYER	1988		
24" DIP FM (CL 50)	1	410	LF	\$64.30	MEYER	1988		
30" DIP FM (CL 50)	1	425	LF	\$87.00	MEYER	1988		
30" DIP FM (CL 50)	1	5600	LF	\$60.00	MEYER	1988		
PVC PIPE	8" PVC (0'-6' CUT)		338	LF	\$8.50	X-RDS	1988	
	8" PVC (0'-6' CUT)		707	LF	\$8.80	HUBBARD	1990	
	8" PVC (0'-6' CUT)		707	LF	\$7.70	GOPHER	1990	
	8" PVC (0'-6' CUT)		707	LF	\$7.00	WITHERINGTON	1990	
	8" PVC (0'-6' CUT)		707	LF	\$11.70	B & D	1990	
	8" PVC (0'-6' CUT)		2906	LF	\$10.00	MEYER	1994	
	8" PVC (0'-6' CUT)	2	2950	LF	\$8.00	BRIAR	1994	
	8" PVC/DI (0'-6' CUT)	7	30	LF	\$13.00	SOUTHWEST	1994	
	8" PVC/DI (0'-6' CUT)	7	30	LF	\$13.75	ROCKET	1994	
	8" PVC/DI (0'-6' CUT)	7	30	LF	\$14.00	MUSTANG	1994	
	8" PVC (6'-8' CUT)		1055	LF	\$7.90	HUBBARD	1990	
	8" PVC (6'-8' CUT)		1055	LF	\$8.75	GOPHER	1990	
	8" PVC (6'-8' CUT)		1055	LF	\$8.50	WITHERINGTON	1990	
	8" PVC (6'-8' CUT)		648	LF	\$14.50	X-RDS	1988	
	8" PVC (6'-8' CUT)		1055	LF	\$12.35	B & D	1990	
	8" PVC (6'-8' CUT)	2	243	LF	\$9.12	BRIAR	1994	
	8" PVC (6'-8' CUT)	2	700	LF	\$8.60	BRIAR	1994	
	8" PVC (6'-8' CUT)	2	601	LF	\$11.50	MEYER	1994	
	8" PVC/DI (6'-8' CUT)	7	635	LF	\$15.00	SOUTHWEST	1994	
	8" PVC/DI (6'-8' CUT)	7	635	LF	\$21.00	ROCKET	1994	
8" PVC/DI (6'-8' CUT)	7	635	LF	\$18.00	MUSTANG	1994		

Gavi

SANITARY SEWER

9/19/94

SIZE DESCRIPTION	PROJECT	QUANTITY	UNIT	UNIT PRICE	BIDDER	YEAR
8" PVC (8'-10' CUT)		675	LF	\$9.37	HUBBARD	1990
8" PVC (8'-10' CUT)		675	LF	\$9.95	GOPHER	1990
8" PVC (8'-10' CUT)		675	LF	\$9.00	WITHERINGTON	1990
8" PVC (8'-10' CUT)		675	LF	\$13.05	B & D	1990
8" PVC (8'-10' CUT)	2	1480	LF	\$8.90	BRIAR	1994
8" PVC (8'-10' CUT)	2	800	LF	\$9.25	JMHC	1994
8" PVC (8'-10' CUT)	2	1513	LF	\$14.00	MEYER	1994
8" PVC/DI (8'-10' CUT)	7	390	LF	\$20.00	SOUTHWEST	1994
8" PVC/DI (8'-10' CUT)	7	390	LF	\$24.00	ROCKET	1994
8" PVC/DI (8'-10' CUT)	7	390	LF	\$25.00	MUSTANG	1994
8" PVC (10'-12' CUT)		317	LF	\$11.26	HUBBARD	1990
8" PVC (10'-12' CUT)		317	LF	\$12.45	GOPHER	1990
8" PVC (10'-12' CUT)		317	LF	\$11.00	WITHERINGTON	1990
8" PVC (10'-12' CUT)		317	LF	\$14.90	B & D	1990
8" PVC (10'-12' CUT)	2	20	LF	\$9.75	JMHC	1994
8" PVC (12'-14' CUT)		418	LF	\$13.25	HUBBARD	1990
8" PVC (12'-14' CUT)		418	LF	\$15.45	GOPHER	1990
8" PVC (12'-14' CUT)		418	LF	\$13.00	WITHERINGTON	1990
8" PVC (12'-14' CUT)		418	LF	\$18.05	B & D	1990
8" PVC/DI (12'-14' CUT)	7	183	LF	\$30.00	SOUTHWEST	1994
8" PVC/DI (12'-14' CUT)	7	183	LF	\$31.00	ROCKET	1994
8" PVC/DI (12'-14' CUT)	7	183	LF	\$45.00	MUSTANG	1994
8" PVC (14'-16' CUT)		166	LF	\$16.35	HUBBARD	1990
8" PVC (14'-16' CUT)		166	LF	\$16.35	HUBBARD	1990
8" PVC (14'-16' CUT)		166	LF	\$15.00	WITHERINGTON	1990
8" PVC (14'-16' CUT)		166	LF	\$17.50	B & D	1990
8" PVC (16'-18' CUT)		357	LF	\$21.80	HUBBARD	1990
8" PVC (16'-18' CUT)		357	LF	\$19.95	GOPHER	1990
8" PVC (16'-18' CUT)		357	LF	\$17.00	WITHERINGTON	1990
8" PVC (16'-18' CUT)		357	LF	\$19.35	B & D	1990
4" PVC FM		20	LF	\$10.00	HENSON	1986
4" PVC FM	7	675	LF	\$6.00	SOUTHWEST	1994
4" PVC FM	7	675	LF	\$7.50	ROCKET	1994
4" PVC FM	7	675	LF	\$10.00	MUSTANG	1994
6" PVC FM		20	LF	\$10.00	ESTERSON	1986
6" PVC FM	5	198	LF	\$10.00	JENKINS	1993
6" PVC FM	1	1125	LF	\$17.60	MEYER	1988
8" PVC FM		3425	LF	\$9.00	HENSON	1986
8" PVC FM	2	7050	LF	\$6.50	MEYER	1994
8" PVC FM	3	1360	LF	\$8.00	JMHC	1994
8" PVC FM (ON SITE)	2	3730	LF	\$7.40	BRIAR	1994
8" PVC FM (ON SITE)	2	3720	LF	\$8.00	JMHC	1994
8" PVC FM (OFF SITE)	2	3060	LF	\$7.64	BRIAR	1994
8" PVC FM (OFF SITE)	2	3180	LF	\$8.00	JMHC	1994
10" PVC FM		1950	LF	\$10.56	HENSON	1986
10" PVC FM	3	244	LF	\$15.00	JMHC	1994
12" PVC FM		2975	LF	\$12.00	ESTERSON	1986
4" PVC SERVICE LATERAL		350	LF	\$5.30	X-RDS	1988
6" PVC SERVICE LATERAL		1986	LF	\$12.45	B & D	1990
6" PVC SERVICE LATERAL		1986	LF	\$10.16	GOPHER	1990
6" PVC SERVICE LATERAL		1986	LF	\$5.00	WITHERINGTON	1990
6" PVC SERVICE LATERAL		1986	LF	\$7.80	HUBBARD	1990
6" PVC SERVICE LATERAL		535	LF	\$8.10	VANNICE	1990
6" DOUBLE SERVICE LATERALS	2	77	EA	\$326.62	BRIAR	1994
6" DOUBLE SERVICE LATERALS	2	60	EA	\$275.00	JMHC	1994
6" DOUBLE SERVICE LATERALS	3	50	LF	\$265.00	JMHC	1994
6" DOUBLE SERVICE LATERALS	7	18	EA	\$275.00	SOUTHWEST	1994
6" DOUBLE SERVICE LATERALS	7	18	EA	\$310.00	ROCKET	1994
6" DOUBLE SERVICE LATERALS	7	18	EA	\$450.00	MUSTANG	1994
6" SINGLE SERVICE LATERALS	2	3	EA	\$301.67	BRIAR	1994
6" SINGLE SERVICE LATERALS	2	1	EA	\$245.00	JMHC	1994
6" SINGLE SERVICE LATERALS	3	14	EA	\$245.00	JMHC	1994
6" SINGLE SERVICE LATERALS	7	5	EA	\$225.00	SOUTHWEST	1994
6" SINGLE SERVICE LATERALS	7	5	EA	\$280.00	ROCKET	1994
6" SINGLE SERVICE LATERALS	7	5	EA	\$350.00	MUSTANG	1994

Gravity ↑

Grav. ↑

PVC PIPE

APPENDIX O

Sewage Pump Station Design

③ 300 gpm pump $\Rightarrow V = QT/4 = \frac{(300 \text{ gpm})(6 \text{ m})}{4} = 450 \text{ gal}$

$V = 60.16 \text{ ft}^3$

6' diam well $h = \frac{(60.16 \text{ ft}^3)}{\pi (3 \text{ ft})^2} = \underline{\underline{2.13 \text{ ft}}}$

6' Diameter Well

④ 400 gpm pump $\Rightarrow V = QT/4 = \frac{400 \text{ gpm}(6 \text{ m})}{4} = 600 \text{ gal}$

$V = 80.21 \text{ ft}^3$

6' diam well $h = \frac{(80.21 \text{ ft}^3)}{\pi (3 \text{ ft})^2} = \underline{\underline{2.89 \text{ ft}}}$

6' Diameter Well

⑤ 500 gpm pump $\Rightarrow V = QT/4 = \frac{(500 \text{ gpm})(6 \text{ m})}{4} = 750 \text{ gal}$

$V = 100.27 \text{ ft}^3$

8' diam well $h = \frac{(100.27 \text{ ft}^3)}{\pi (4 \text{ ft})^2} = \underline{\underline{1.99 \text{ ft}}}$

8' Diameter Well

Sewage Pump Station Design

$$\textcircled{6} \quad 600 \text{ gpm pump} \Rightarrow \Psi = QT/4 = \frac{(600 \text{ gpm})(6 \text{ min})}{4} = 900 \text{ gal}$$

$$\Psi = 120.32 \text{ ft}^3$$

8' ϕ well

$$h = \frac{(120.32 \text{ ft}^3)}{\pi (4 \text{ ft})^2} = \underline{\underline{2.39 \text{ ft}}}$$

8' Diameter Well

$$\textcircled{7} \quad 700 \text{ gpm pump} \Rightarrow \Psi = QT/4 = \frac{(700 \text{ gpm})(6 \text{ min})}{4} = 1050 \text{ gal}$$

$$\Psi = 140.4 \text{ ft}^3$$

8' ϕ well

$$h = \frac{(140.4 \text{ ft}^3)}{\pi (4 \text{ ft})^2} = \underline{\underline{2.79 \text{ ft}}}$$

10' ϕ well

$$h = \frac{(140.4 \text{ ft}^3)}{\pi (5 \text{ ft})^2} = \underline{\underline{1.79 \text{ ft}}}$$

10' Diameter Well

$$\textcircled{8} \quad 800 \text{ gpm pump} \Rightarrow \Psi = QT/4 = \frac{(800 \text{ gpm})(6 \text{ min})}{4} = 1200 \text{ gal}$$

$$\Psi = 160.4 \text{ ft}^3$$

10' ϕ well

$$h = \frac{(160.4 \text{ ft}^3)}{\pi (5 \text{ ft})^2} = \underline{\underline{2.04 \text{ ft}}}$$

10' Diameter Well

Sewage Pump Station Design

⑨ 900 gpm pump $\Rightarrow V = QT/4 = \frac{(900 \text{ gpm})(6 \text{ min})}{4} = 1350 \text{ gal}$

$V = 180.48 \text{ ft}^3$

10' ϕ well
 $h = \frac{(180.48 \text{ ft}^3)}{\pi (5 \text{ ft})^2} = \underline{2.30 \text{ ft}}$

10' Diameter Well

⑩ 1000 gpm pump $\Rightarrow V = QT/4 = \frac{(1000 \text{ gpm})(6 \text{ min})}{4} = 1500 \text{ gal}$

$V = 200.5 \text{ ft}^3$

10' ϕ well
 $h = \frac{(200.5 \text{ ft}^3)}{\pi (5 \text{ ft})^2} = \underline{2.55 \text{ ft}}$

12' ϕ well
 $h = \frac{(200.5 \text{ ft}^3)}{\pi (6 \text{ ft})^2} = \underline{1.77 \text{ ft}}$

12' Diameter Well

Sheet No.	Job No.	95-145.00
Made By	JJW	Date: 8/14/95
Checked By		Date:

Station No. 2 Submersible

Installed	<u>1995</u>	Depth (ft):	<u>16</u>	Diameter (ft):	<u>6</u>
Precast Well					
Wet Well(ft)	<u>16.00</u>	\$125/FT		COST =	<u>\$2,000</u>
Top Slab(cy)	<u>0.70</u>	\$450/cy		COST =	<u>\$314</u>
Base Slab(cy)	<u>3.11</u>	\$450/cy		COST =	<u>\$1,398</u>
Excavation					
Surface Diameter (ft)	$(2 * \text{Depth}) + 10\text{ft} + \text{Dia.} =$			"SD" =	<u>48</u>
Surface Area (ft)	$((3.1415) * ("SD")^2) / 4 =$			"SA" =	<u>1810</u>
Base Diameter (ft)	Dia + 10ft =			"BD" =	<u>16</u>
Base Area (ft)	$((3.1415) * ("BD")^2) / 4 =$			"BA" =	<u>201.1</u>
Volume (cy)	$(1/3 * ("SA") * (\text{Depth} + "BD") - 1/3 * ("BA") * ("BD")) / 27 =$			"Vol" =	<u>675</u>
		\$1.25/cy		COST =	<u>\$844</u>
Backfill(cy)	$"Vol" - ((3.1415) (\text{Dia.})^2 (\text{Depth})) / 27 =$			"BK" =	<u>608</u>
		\$1.25/cy		COST =	<u>\$760</u>
Dewatering					
Circumference	$2 * (3.1415) * (("SD" + 2) / 2) =$		<u>157.1</u>		
		\$75/LF		COST =	<u>\$11,781</u>
Valve Box:					
	Length(ft)	<u>5</u>			
	Width(ft)	<u>5</u>			
	Walls	<u>8"</u>			
	Base Slab (ft)	<u>25</u>			
	Top Slab	<u>Aluminum Hatch</u>		COST =	<u>\$1,440</u>
TOTAL STRUCTURAL COST =					<u>\$18,537.00</u>
Pumps:	<u>2</u>	Motors:	<u>2</u>		
Horsepower	<u>6</u>		<u>5</u>		
GPM	<u>200</u>				
Manufacturer	<u>Flyght/ABS</u>				
Model No.				TOTAL PUMP COST =	<u>\$11,600.00</u>
Controls/Electrical:					
	Estimated at 20% of Total Package Cost				
				TOTAL CONTROL COST =	<u>\$2,900.00</u>
Piping/Fittings/Equipment:					
				TOTAL EQUIPMENT COST =	<u>\$2,780.55</u>
4" Plug Valve (2)					
4" Check Valve (2)					
4" connector					
Emergency pump out					
4" DI piping					
TOTAL LIFT STATION COST =					<u>\$35,817.55</u>

Sheet No.	Job No. 95-145.00
Made By JJW	Date: 8/14/95
Checked By	Date:

Station No. 3 Submersible

Installed 1995 Depth (ft): 18 Diameter (ft): 6

Precast Well

Wet Well(ft)	<u>18.00</u>	\$125/FT	COST =	<u>\$2,250</u>
Top Slab(cy)	<u>0.70</u>	\$450/cy	COST =	<u>\$314</u>
Base Slab(cy)	<u>3.11</u>	\$450/cy	COST =	<u>\$1,398</u>

Excavation

Surface Diameter (ft)	$(2 * \text{Depth}) + 10\text{ft} + \text{Dia.} =$	"SD" =	<u>52</u>
Surface Area (ft)	$((3.1415) * ("SD")^2) / 4 =$	"SA" =	<u>2124</u>
Base Diameter (ft)	$\text{Dia} + 10\text{ft} =$	"BD" =	<u>16</u>
Base Area (ft)	$((3.1415) * ("BD")^2) / 4 =$	"BA" =	<u>201.1</u>
Volume (cy)	$(1/3 * ("SA") * (\text{Depth} + "BD") - 1/3 * ("BA") * ("BD")) / 27 =$	"Vol" =	<u>852</u>

\$1.25/cy COST = \$1,065

Backfill(cy)	$"\text{Vol}" - ((3.1415) (\text{Dia.})^2 (\text{Depth})) / 27 =$	"BK" =	<u>776</u>
	\$1.25/cy	COST =	<u>\$970</u>

Dewatering

Circumference	$2 * (3.1415) (("SD" + 2) / 2) =$	<u>169.6</u>	
	\$75/LF	COST =	<u>\$12,723</u>

Valve Box:

Length(ft)	<u>5</u>		
Width(ft)	<u>5</u>		
Walls	<u>8"</u>		
Base Slab (ft)	<u>25</u>		
Top Slab	<u>Aluminum Hatch</u>	COST =	<u>\$1,440</u>

TOTAL STRUCTURAL COST = \$20,160.38

Pumps: 2
 Horsepower 9
 GPM 300
 Manufacturer Flyght/ABS
 Model No.

Motors: 2
 5

TOTAL PUMP COST = \$12,800.00

Controls/Electrical: Estimated at 20% of Total Package Cost
TOTAL CONTROL COST = \$3,200.00

Piping/Fittings/Equipment:
TOTAL EQUIPMENT COST = \$4,032.08

6" Plug Valve (2)
 6" Check Valve (2)
 6" connector
 Emergency pump out
 6" DI piping
TOTAL LIFT STATION COST = \$40,192.46

Station No. 5 Submersible

Sheet No.	Job No. 95-145.00	
Made By	JJW	Date: 8/14/95
Checked By		Date:

Installed	<u>1995</u>	Depth (ft):	<u>18</u>	Diameter (ft):	<u>8</u>
Precast Well					
Wet Well(ft)	<u>18.00</u>	\$125/FT		COST =	<u>\$2,250</u>
Top Slab(cy)	<u>1.24</u>	\$450/cy		COST =	<u>\$559</u>
Base Slab(cy)	<u>4.42</u>	\$450/cy		COST =	<u>\$1,991</u>
Excavation					
Surface Diameter (ft)	$(2 * \text{Depth}) + 10\text{ft} + \text{Dia.} =$		"SD" =	<u>54</u>	
Surface Area (ft)	$(3.1415) * (\text{"SD"}^2) / 4 =$		"SA" =	<u>2290</u>	
Base Diameter (ft)	$\text{Dia} + 10\text{ft} =$		"BD" =	<u>18</u>	
Base Area (ft)	$(3.1415) * (\text{"BD"}^2) / 4 =$		"BA" =	<u>254.5</u>	
Volume (cy)	$(1/3 * (\text{"SA"} * (\text{Depth} + \text{"BD"}) - 1/3 * (\text{"BA"} * (\text{"BD"}))) / 27 =$		"Vol" =	<u>961</u>	
		\$1.25/cy	COST =	<u>\$1,202</u>	
Backfill(cy)	$\text{"Vol"} - ((3.1415) * (\text{Dia.})^2 * (\text{Depth})) / 27 =$		"BK" =	<u>827</u>	
		\$1.25/cy	COST =	<u>\$1,034</u>	
Dewatering					
Circumference	$2 * (3.1415) * ((\text{"SD"} + 2) / 2) =$		<u>175.9</u>		
		\$75/LF	COST =	<u>\$13,195</u>	
Valve Box:					
	Length(ft)	<u>5</u>			
	Width(ft)	<u>5</u>			
	Walls	<u>8"</u>			
	Base Slab (ft)	<u>25</u>			
	Top Slab	<u>Aluminum Hatch</u>	COST =	<u>\$1,440</u>	
TOTAL STRUCTURAL COST =					<u>\$21,670.09</u>
Pumps:					
	2		Motors:	2	
Horsepower	13.5			5	
GPM	500				
Manufacturer	Flyght/ABS				
Model No.			TOTAL PUMP COST =	<u>\$14,800.00</u>	
Controls/Electrical:					
	Estimated at 20% of Total Package Cost				
	TOTAL CONTROL COST =				<u>\$3,700.00</u>
Piping/Fittings/Equipment:					
	TOTAL EQUIPMENT COST =				<u>\$5,417.52</u>
TOTAL LIFT STATION COST =					<u>\$45,587.61</u>

Station No. 6 Submersible

Sheet No.	Job No.	95-145.00
Made By	JJW	Date: 8/14/95
Checked By		Date:

Installed	<u>1995</u>	Depth (ft):	<u>20</u>	Diameter (ft):	<u>8</u>
Precast Well					
Wet Well(ft)	<u>20.00</u>	\$125/FT		COST =	<u>\$2,500</u>
Top Slab(cy)	<u>1.24</u>	\$450/cy		COST =	<u>\$559</u>
Base Slab(cy)	<u>4.42</u>	\$450/cy		COST =	<u>\$1,991</u>
Excavation					
Surface Diameter (ft)	$(2 * \text{Depth}) + 10\text{ft} + \text{Dia.} =$			"SD" =	<u>58</u>
Surface Area (ft)	$((3.1415) * ("SD")^2) / 4 =$			"SA" =	<u>2642</u>
Base Diameter (ft)	Dia + 10ft =			"BD" =	<u>18</u>
Base Area (ft)	$((3.1415) * ("BD")^2) / 4 =$			"BA" =	<u>254.5</u>
Volume (cy)	$(1/3 * ("SA") * (\text{Depth} + "BD") - 1/3 * ("BA") * ("BD")) / 27 =$			"Vol" =	<u>1183</u>
		\$1.25/cy		COST =	<u>\$1,479</u>
Backfill(cy)	$"Vol" - ((3.1415) (\text{Dia.})^2 (\text{Depth})) / 27 =$			"BK" =	<u>1034</u>
		\$1.25/cy		COST =	<u>\$1,293</u>
Dewatering					
Circumference	$2 * (3.1415) (("SD" + 2) / 2) =$			<u>188.5</u>	
		\$75/LF		COST =	<u>\$14,137</u>
Valve Box:					
	Length(ft)	<u>5</u>			
	Width(ft)	<u>5</u>			
	Walls	<u>8"</u>			
Base Slab (ft)	<u>25</u>				
Top Slab	<u>Aluminum Hatch</u>			COST =	<u>\$1,440</u>
TOTAL STRUCTURAL COST =					<u>\$23,398.00</u>
Pumps:	<u>2</u>	Motors:	<u>2</u>		
Horsepower	<u>17.5</u>		<u>5</u>		
GPM	<u>600</u>				
Manufacturer	<u>Flyght/ABS</u>				
Model No.				TOTAL PUMP COST =	<u>\$16,640.00</u>
Controls/Electrical: Estimated at 20% of Total Package Cost					
TOTAL CONTROL COST =					<u>\$4,160.00</u>
Piping/Fittings/Equipment:					
TOTAL EQUIPMENT COST =					<u>\$5,849.50</u>
TOTAL LIFT STATION COST =					
					<u>\$50,047.50</u>

Sheet No.	Job No.	95-145.00
Made By	JJW	Date: 8/14/95
Checked By		Date:

Station No. 7 Submersible

Installed	<u>1995</u>	Depth (ft):	<u>20</u>	Diameter (ft):	<u>10</u>
Precast Well					
Wet Well(ft)	<u>20.00</u>	\$125/FT		COST =	<u>\$2,500</u>
Top Slab(cy)	<u>1.94</u>	\$450/cy		COST =	<u>\$873</u>
Base Slab(cy)	<u>5.98</u>	\$450/cy		COST =	<u>\$2,689</u>
Excavation					
Surface Diameter (ft)	$(2 * \text{Depth}) + 10\text{ft} + \text{Dia.} =$			"SD" =	<u>60</u>
Surface Area (ft)	$((3.1415) * ("SD")^2) / 4 =$			"SA" =	<u>2827</u>
Base Diameter (ft)	Dia + 10ft =			"BD" =	<u>20</u>
Base Area (ft)	$((3.1415) * ("BD")^2) / 4 =$			"BA" =	<u>314.2</u>
Volume (cy)	$(1/3 * ("SA") * (\text{Depth} + "BD") - 1/3 * ("BA") * ("BD")) / 27 =$			"Vol" =	<u>1319</u>
		\$1.25/cy		COST =	<u>\$1,648</u>
Backfill(cy)	$"Vol" - ((3.1415) (\text{Dia.})^2 (\text{Depth})) / 27 =$			"BK" =	<u>1086</u>
		\$1.25/cy		COST =	<u>\$1,357</u>
Dewatering					
Circumference	$2 * (3.1415) (("SD" + 2) / 2) =$		<u>194.8</u>		
		\$75/LF		COST =	<u>\$14,608</u>
Valve Box:					
	Length(ft)	<u>5</u>			
	Width(ft)	<u>5</u>			
	Walls	<u>8"</u>			
	Base Slab (ft)	<u>25</u>			
	Top Slab	<u>Aluminum Hatch</u>		COST =	<u>\$1,440</u>
TOTAL STRUCTURAL COST =					<u>\$25,116.18</u>
Pumps:	<u>2</u>	Motors:	<u>2</u>		
Horsepower	<u>20.5</u>		<u>5</u>		
GPM	<u>700</u>				
Manufacturer	<u>Flyght/ABS</u>				
Model No.				TOTAL PUMP COST =	<u>\$17,600.00</u>
Controls/Electrical:					
	Estimated at 20% of Total Package Cost				
				TOTAL CONTROL COST =	<u>\$4,400.00</u>
Piping/Fittings/Equipment:					
	TOTAL EQUIPMENT COST =				<u>\$6,279.04</u>
8" Plug Valve (2)					
8" Check Valve (2)					
8" connector					
Emergency pump out					
8" DI piping					
TOTAL LIFT STATION COST =					<u>\$53,395.22</u>

Station No. 10 Submersible

Sheet No.	Job No. 95-145.00
Made By JJW	Date: 8/14/95
Checked By	Date:

Installed 1995 Depth (ft): 20 Diameter (ft): 12

Precast Well

Wet Well(ft)	<u>20.00</u>	\$125/FT	COST =	<u>\$2,500</u>
Top Slab(cy)	<u>2.79</u>	\$450/cy	COST =	<u>\$1,257</u>
Base Slab(cy)	<u>7.76</u>	\$450/cy	COST =	<u>\$3,492</u>

Excavation

Surface Diameter (ft) $(2 * \text{Depth}) + 10\text{ft} + \text{Dia.} =$ "SD" = 62

Surface Area (ft) $((3.1415) * (\text{"SD"}^2) / 4 =$ "SA" = 3019

Base Diameter (ft) $\text{Dia} + 10\text{ft} =$ "BD" = 22

Base Area (ft) $((3.1415) * (\text{"BD"}^2) / 4 =$ "BA" = 380.1

Volume (cy) $(1/3 * (\text{"SA"}) * (\text{Depth} + \text{"BD"}) - 1/3 * (\text{"BA"}) * (\text{"BD"})) / 27 =$
"Vol" = 1462

\$1.25/cy COST = \$1,828

Backfill(cy) $\text{"Vol"} - ((3.1415) (\text{Dia.})^2 (\text{Depth})) / 27 =$ "BK" = 1127

\$1.25/cy COST = \$1,409

Dewatering

Circumference $2 * (3.1415) ((\text{"SD"} + 2) / 2) =$ 201.1
\$75/LF COST = \$15,080

Valve Box:

Length(ft)	<u>5</u>
Width(ft)	<u>5</u>
Walls	<u>8"</u>
Base Slab (ft)	<u>25</u>
Top Slab	<u>Aluminum Hatch</u>
COST =	<u>\$1,440</u>

TOTAL STRUCTURAL COST = \$27,005.01

Pumps: 2

Horsepower 30 Motors: 2

GPM 1000 5

Manufacturer Flyght/ABS

Model No. **TOTAL PUMP COST =** \$20,400.00

Controls/Electrical: Estimated at 20% of Total Package Cost

TOTAL CONTROL COST = \$5,100.00

Piping/Fittings/Equipment:

TOTAL EQUIPMENT COST = \$10,802.00

10" Plug Valve (2)
10" Check Valve (2)
10" connector

TOTAL LIFT STATION COST = \$63,307.02

Emergency pump out
10" DI piping


Directory: C:\AUS
 Filename: PRECAST.WK3
 Date: 30-Mar-95
 Time: 10:02 AM

PRECAST WETWELL INSTALLED COST SUMMARY

Diameter (feet)	Material Cost				
	4	6	8	10	12
Cost (\$/ft of depth)	\$65	\$125	\$175	\$300	\$375
Base	\$645	\$1,045	\$1,825	\$2,821	\$3,605
Top	\$125	\$225	\$500	\$1,000	\$1,400

Diameter (feet)	Installation Adder @ 30%				
	4	6	8	10	12
Cost (\$/ft of depth)	\$20	\$38	\$53	\$90	\$113
Base	\$194	\$314	\$548	\$846	\$1,082
Top	\$38	\$68	\$150	\$300	\$420

Diameter (feet)	Total Installed Cost				
	4	6	8	10	12
Cost (\$/ft of depth)	\$85	\$163	\$228	\$390	\$488
Base	\$839	\$1,359	\$2,373	\$3,667	\$4,687
Top	\$163	\$293	\$650	\$1,300	\$1,820



Base	Nominal Diameter (ft)	Actual Diameter (ft)	Thickness (ft)	Actual Area (sq.ft.)	Quantity of Concrete (cu.ft.)	Quantity of Concrete (cu.yd.)	Item Cost	cu.yd.
							@ \$275 (\$)	
	4	7.33	1.50	42	63	2	\$645	
	6	9.33	1.50	68	103	4	\$1,045	
	8	12.33	1.50	119	179	7	\$1,825	
	10	15.33	1.50	185	277	10	\$2,821	
	12	17.33	1.50	236	354	13	\$3,605	

Top	Nominal Diameter (ft)	Actual Diameter (ft)	Thickness (ft)	Actual Area (sq.ft.)	Quantity of Concrete (cu.ft.)	Quantity of Concrete (cu.yd.)	Item Cost	cu.yd.
							@ \$275 (\$)	
	4	5.33	0.67	22	15	1	\$152	
	6	7.33	0.67	42	28	1	\$287	
	8	9.33	0.67	68	46	2	\$465	
	10	11.33	1.00	101	101	4	\$1,027	
	12	13.33	1.00	140	140	5	\$1,422	



ELLIS K. PHELPS & COMPANY

2152 Sprint Boulevard
 Apopka, Florida 32703

Phone: (407) 880-2900
 FAX: (407) 880-2962

To: Hartman & Associates
 Bobby Wyatt
 407-839-3790 (Fax)

From: Juan Citarella

<u>Reference #</u>	<u>Reference HP</u>	<u>Package Estimate</u>	<u>Current Flygt Pump</u>
3825-1	9.4	\$21,000	CP 3127
3825-1	5	\$18,000	CP 3102
?	5	\$18,000	CP 3102
5443A	7.5	\$21,000	CP 3127
80-200/3085	2.5	\$16,000	CP 3085
C-3082	3	\$16,000	CP 3085
C-3101	2.5	\$16,000	CP 3085
3085	3	\$16,000	CP 3085
3085	1.5	\$16,000	CP 3085
C-3101	5	\$18,000	CP 3102
C-3101	10	\$21,000	CP 3127
3126	9.4	\$21,000	CP 3127
?	2	\$16,000	CP 3085
CP 3127	9.4	\$21,000	CP 3127
CP 3127	10	\$21,000	CP 3127
CP 3127	9.5	\$21,000	CP 3127
CP 3152	20	\$26,000	CP 3152
3085.181	2.3	\$16,000	CP 3085
3085	2	\$18,000	CP 3085

Note: Package estimates include (2) Flygt submersible pumps, accessories, control panel, and access covers.

Thank you for your inquiry!

et.
1005pm

$$\begin{aligned}
 BHP &= \frac{(Q)(TDH)(5.3)}{3960 (\text{eff.})} \\
 &= \frac{(100 \text{ gpm})(60 \text{ ft})(1)}{(3960)(0.5)} = 3.03
 \end{aligned}$$



ABS • Scanpump
Lawrence Pump & Engine

MEMO ABS FLORIDA BRANCH

TO: HARTMAN & ASSOCIATES

DATE: 3/18/95

ATTN: BOBBY WYATT

FROM: COLIN MARTIN

SUBJECT: YOUR FAX INQUIRY 3/2/95
CITY OF PORT ST. LUCIE REPLACEMENT COSTS

Mr. Wyatt,
In response to your subject inquiry I would like to offer the following pricing for the pump models you requested. I have indicated the old pump model number as well as the new current model number. Please note that the pricing is per pump with accessories. For a typical duplex station multiply price by two. Controls are priced seperately.
The CP3127 model no. is a Flygt, equal to the 8 HP ABS model.

OLD MODEL	HP	NEW MODEL	PRICE EACH UNIT WITH ACCESSORIES
AF15-4-4	2	AFP1040M15/4-11.60-4"	\$2,380.00
AF22-4-4	3	AFP1040M22/4-11.60-4"	2,550.00
AF40-4-4	6	AFP1042M46/4-21.60-4"	2,990.00
AF80-4-4	8	AFP1046M70/4-22.60-4"	3,300.00
AF90-4-4	12	AFP1046M90/4-22.60-4"	3,400.00

DUPLEX CONTROLS PER ST. LUCIE SPECS HP	PRICE EACH DUPLEX CONTROL W/FLOATS
2 or 3	\$4,700.00
6	4,800.00
8 or 10	5,000.00
12 or 15	5,300.00

Pricing is for budgetary usage only. Taxes are not included. Freight and startup are included.

Should you have any questions or require additional information, please do not hesitate to contact me.

Regards,

To: Rusty Nelson

Page 2 of 2

From: Bobby Wyatt

Date: June 2, 1995

Gorman Rupp

Lift station pump package (pump, guide rails, controls, floats, etc.)

MODEL	HP	PACKAGE (S)
T4A3-B (Duplex)	20 hp	65,570 -
T4A3-B (Duplex)	15 hp	65,152 -
T4A3-B (Duplex)	5 hp	64,156 -
T4A3-B (Duplex)	7.5 hp	64,356 -
T4A3-B (Duplex)	10 hp	64,571 -
T3A3-B (Duplex)	7.5 hp	63,026 -
T6A3-B (Duplex)	15 hp	68,407 -

ALL THESE STATIONS ARE BELOW GROUND, DRY PIT DESIGN SO GUIDE RAILS ARE NOT USED. THESE PRICES INCLUDE DOUBLE LEVEL CONTROLS, IF FLOATS ARE USED, PLEASE DEDUCT \$1,363 - FROM EACH OF THE ABOVE PRICES.

STATIONS ARE PRICED AS A PACKAGE SO I CAN NOT GIVE INDIVIDUAL COMPONENT PRICES. HOWEVER, BELOW ARE LISTED APPROXIMATE CONTROL PANEL PRICES WHICH ARE INCLUDED IN THE ABOVE PRICES, ALL STATIONS ASSUMED TO BE 460 VOLT.

5 HP	-	\$ 5,400 -
7.5 HP	-	5,408 -
10 HP	-	5,408 -
15 HP	-	5,686 -
20 HP	-	5,702 -

PLEASE CALL IF YOU HAVE QUESTIONS.

BWW/dt/MS/pumps.bww

THANKS,

RUSTY NELSON

DATE: 3/7/95 TIME: 2:30 pm
 PROJECT NAME: City of Port St. Lucie PROJECT NO.: 94-354.12
 PARTY CALLING: Scott Edwards COMPANY: 1-800-342-7099
 PARTY CONTACTED: Bobby Wyatt COMPANY: Taylor Precast
 SUBJECT: Replacement costs for city of Port St. Lucie, and Hattwell
Replacement costs

TELEPHONE COMMUNICATION SUMMARY (Including Decisions & Commitments)

Following costs were given by Mr. Edwards:

<u>Manholes</u> <u>Depth</u>	<u>Cost</u>	<u>Hattwell's</u> <u>Diameter</u>	<u>\$/ft</u>	<u>Bases/top (\$)</u>
0-6	500	4'	65 w/paint	125
6-8	615	6'	125	225
8-10	725	8'	175	500
10-12	875	10'	300	1000
12-15	995	12'	375	1400
15+	1125			

ACTION REQUIRED

C.C. _____

) _____

HARTMAN & ASSOCIATES, INC.
 engineers, hydrogeologists, scientists & management consultants

EXHIBIT (GCH-4)

PAGE 257 OF 284

APPENDIX P

Piping Costs

DIP (Class 50 - Epoxy Lined) Force Main

<u>Size (in)</u>	<u>Small Job (250') (\$/ft)</u>	<u>Med. Job (2,500') (\$/ft)</u>	<u>Large Job (25,000') (\$/ft)</u>
4"	24.39	20.57	19.39
6"	27.58	23.13	21.71
8"	31.58	26.44	24.75
10"	36.41	30.49	28.50
12"	42.76	35.93	33.59
16"	47.75	40.13	37.47

- Notes:
- 1) Values obtained using manufacturer's quotes.
 - 2) Costs include \$500 permitting, 10% - 15% mobilization, \$7/ft installation, and \$.25 - \$.75 per foot pressure testing.
 - 3) Costs exclude valves, fittings, and restoration work.

HARTMAN & ASSOCIATES, INC. engineers, hydrogeologists, surveyors & management consultants	SH. NO:	JOB NO: <u>95-915.00</u>
	MADE BY: <u>JJW</u>	DATE:
	CHECKED BY:	DATE:

PIPE COSTS

* Includes pressure testing + Disinf. (for w.m.)
trench & backfill

① PYC (C900 - DR 25) Force Main

	15% Small job 250 (\$/Ft)	12% Med. Job 2500 (\$/Ft)	10% large job 25,000' (\$/Ft)
4"	1.91 12.25	1.57 9.80	1.25 9.10
6"	3.01 13.51	2.62 10.97	2.27 10.22
8"	4.55 15.28	4.14 12.68	3.73 11.82
10"	6.41 17.42	5.93 14.68	5.47 13.74
12"	8.85 20.23	8.26 17.29	7.70 15.15

Add \$500 permit plus mobil. plus \$7/ft trench & backfill

* (C905 - DR 25)

16"	14.81 27.08	14.04 23.76	13.22 22.26
-----	-------------	-------------	-------------

Installation \$500 permit \$500 mobil \$7/ft trench & backfill

② PYC (C900 - DR 18) Water Main

	small job	med. job	large job
4"	4.34 15.04 11.97	3.51 11.97	2.69 10.68
6"	5.74 16.65	4.84 13.46	4.00 12.12
8"	7.98 19.23	6.99 15.87	6.04 14.36
10"	10.52 22.15	9.47 18.65	8.41 16.97
12"	13.71 25.82	12.53 22.07	11.42 20.28

③ PYC - (SDR 35) Gravity line

	small	medium	large	\$1/FT T.V. TEST
8"	2.33	2.26	2.22	

HARTMAN & ASSOCIATES, INC. engineers, hydrogeologists, surveyors & management consultants	SH. NO: <u>2</u>	JOB NO: <u>95-145.00</u>
	MADE BY: <u>JJW</u>	DATE:
	CHECKED BY:	DATE:

Pipe Costs

* Includes pressure testing

④ DIP (Fastite Concret Lined Class 50) Force Main

	small job		med. job		large job		Epoxy lining
	250' 100' (\$/ft)	150' (\$/ft)	250' 1500' (\$/ft)	1000' (\$/ft)	25,000' (\$/ft)	(\$/ft)	
6"	¹⁵ 7.69	¹⁸ 18.84	¹³ 6.28	¹⁵ 15.07	¹¹ 5.61	¹³ 13.89	5.50
8"	²⁴ 10.40	²² 22.01	¹¹ 8.50	¹⁷ 17.56	¹⁴ 7.65	¹⁶ 16.14	5.57
10"	³³ 13.50	²⁵ 25.58	²⁴ 11.07	²⁰ 20.44	¹⁶ 10.03	¹⁸ 18.75	6.00
12"	²⁵ 17.05	²⁹ 29.66	²³ 14.02	²³ 23.74	¹² 12.75	²¹ 21.75	6.75
14"	21.70	³⁵ 35.01	17.98	28.18	16.47	25.84	7.75
16"	³⁵ 25.39	³⁹ 39.25	³³ 21.06	³¹ 31.63	²⁹ 19.32	²⁸ 28.97	8.50
20"	⁵² 33.17	⁴⁸ 48.20	⁴¹ 27.55	³⁸ 38.90	⁴⁶ 25.34	³⁵ 35.59	9.25
24"	⁴¹ 41.65	45	³⁴ 34.62		³¹ 31.90		11.40
30"	⁵⁵ 55.57		⁵¹ 51.02		⁴³ 43.23		15.50

⑤ DIP (Restrained Joint Class 50) Force Main

	small job		med. job		large job		Epoxy lining
6"	11.94	23.78	10.53	19.83	9.86	18.57	5.50
8"	15.28	27.62	13.38	23.03	12.52	21.49	5.57
10"	19.56	³² 32.59	17.14	27.24	16.09	25.42	6.00
12"	24.30	³⁸ 38.00	21.27	31.86	20.00	29.72	6.75
14"	32.01	⁴⁶ 46.80	28.29	39.72	26.78	37.18	7.75
16"	38.21	⁵³ 53.99	33.18	45.97	32.13	43.06	8.50
20"	50.17		44.55		42.34		9.25
24"	64.15		57.12		54.40		11.40
30"	85.57		76.65		73.23		15.50

* Add \$1/ft for water main on a big job.
 \$1.50/ft for water main on a medium job.
 \$2.00/ft for water main on a small job.

Also force mains must be epoxy lin

RECORD OF TELEPHONE COMMUNICATION

DATE: 9/7/95 TIME: 3:40

PROJECT NAME: SSU - Economy of Scale PROJECT NO.: 95-145.00

PARTY CALLING: J J W COMPANY: HAI

PARTY CONTACTED: Brian Penner COMPANY: Mitchell & Stark

SUBJECT: Pipe install. costs (813) 597-2165

TELEPHONE COMMUNICATION SUMMARY (Including Decisions & Commitments)

* Pressure testing (W+F.M.) Avg. 50¢/ft small job → 75¢/ft
large job → 25¢/ft

* Disinfection (W.M.) Avg. \$1/ft small job → \$2/ft
\$1.50 large job → \$1/ft

* Gravity Sewer - T.V. Test \$1.00/ft

ACTION REQUIRED

HARTMAN & ASSOCIATES, INC.

engineers, hydrogeologists, scientists & management consultants



FLORIDA DISTRIBUTION CENTERS

11114 SATELLITE BLVD., ORLANDO, FL 32837	(407) 855-8510
1101 WEST 17TH STREET, RIVIERA BEACH, FL 33404	(407) 848-4888
8751 26TH COURT, EAST, SARASOTA, FL 34243	(813) 755-8755
3884-A PROSPECT AVENUE, NAPLES, FL 33942	(941) 434-8666

COVER SHEET

TO: Jammy Wallere - Hartman & Assoc.

FROM: ELM.

DATE: 9-1

OF PAGES SENT (INC. COVER SHEET) 5

IF YOU DID NOT RECEIVE TOTAL # OF PAGES PLEASE
CALL 407-855-8510 / 800-531-6998 / FAX # 407-240-1901
AND NOTIFY US IMMEDIATELY.

MESSAGES: Pipe estimates for

your economy of scale

projections.

SENDING FAX TO # _____

Thy
ELM

09/01/95

11:20

407-639 3790

BARTMAN ASSOC.

003/006

PVC - C900 DR 25

Force Mains (Green)

Size (in.)	Cost 150 ft. (\$/LF)	Cost 1,500 ft. (\$/LF)	Cost 25,000 ft. (\$/LF)
4"	1.26	1.15	1.04
6"	2.36	2.21	2.11
8"	3.99	3.86	3.71
10"	5.89	5.71	5.53
12"	8.59	8.26	7.99
-- C905 DR 25 --			
16"	14.22	13.89	13.39



HARTMAN & ASSOCIATES, INC.

engineers, hydrogeologists, surveyors & management consultants

201 EAST POPE STREET - SUITE 1000 - ORLANDO, FL 32801
TELEPHONE (407) 839-3955 - FAX (407) 839-3700
FAX (ADMN/UTILITY ENR/HYDRO) - (407) 839-3700
FAX (CIVIL ENR/SURVEY/FINANCE) - (407) 481-8447

From Jim Gunkler ^{certified}
FACSIMILE TRANSMITTAL

TO: ~~John Gulkins~~ FROM: Jamey Wallace

DATE: 9/1/95

RE: Costs for PVC piping - Economy of Scale

WE ARE SENDING YOU 5 PAGES, INCLUDING THIS COVER SHEET.
THESE PAGES ARE BEING TRANSMITTED AS INDICATED BELOW:

- AS REQUESTED
- FOR YOUR USE
- FOR YOUR COMMENTS
- FOR YOUR APPROVAL

HARD COPY:

- WILL BE SENT VIA REGULAR MAIL
- WILL BE SENT VIA OVERNIGHT MAIL
- WILL BE SENT BY FACSIMILE ONLY

MESSAGE:

John, what I'm looking for are costs based on linear footage of the job. As we both know there typically is a considerable savings for a much larger job than for a smaller job based on the circumstances. Therefore, if maybe you could quote the prices as three (3) different jobs one w/ 150' lengths, one 1,500', one 25,000'. That way we could see the savings. Your help & professional opinion would be greatly appreciated. Thanks, JJW

IF THERE ARE QUESTIONS OR PROBLEMS WITH THIS TRANSMITTAL,
PLEASE CALL (407) 839-3955

PVC - C900 DR 25

Force Mains

Size (in.)	Cost 150 ft. (\$/LF)	Cost 1,500 ft. (\$/LF)	Cost 25,000 ft. (\$/LF)
4"	1.08	.88	.85
6"	2.15	2.02	1.93
8"	3.60	3.41	3.25
10"	5.42	5.15	4.90
12"	7.61	7.25	6.80
--- C905 DR 25 ---			
16"	13.90	13.18	12.55

AMERICAN CAST IRON PIPE COMPANY

2301 MAITLAND CENTER PARKWAY, SUITE 430
MAITLAND, FLORIDA 32751
PHONE (407) 660-8786 FAX (407) 660-1851

DATE: 8/1/95

NO. OF PAGES 4
(including this page)

fax 407 839-3790

TO: JANEY WALLACE - HARTMAN & ASSOC

FROM: *Jenny Seaman*

SUBJECT: ESTIMATING PRICES
SOUTHFLORIDA STATES UTILITIES

ATTACHED ARE 3 PRICE LISTS FOR SMALL, MED. & LARGE JOBS. NOTE
THE PRICE DIFFERENCES IN CLASS 50, BUT ALSO NOTICE THE SAVINGS
IN PRESSURE CLASS PIPE 150, 200 & 250 IN SIZES 14" THRU 30".

RJ = RESTRAINED JOINT PIPE

POLYBOND OR CTG = PER FOOT ADDS TO ALL PRICES SHOWN.

Jenny

LARGE

American Cast Iron Pipe Company
 Ductile Iron Pipe Price Sheet
 Pricing Calculations

Size	EASTIE CEMENT LINED PER FT ESTIMATING PRICES														POLYBOND				
	Class 50	Class 51	Class 52	Class 53	Class 150	Class 200	Class 250	Class 300	Class 350	R. J. 50	R. J. 51	R. J. 350	R. J. 300	R. J. 250	R. J. 200	R. J. 150	in/CTE	in/CTE	
3"	N/A	4.72	5.23	5.73					4.71	N/A	N/A	N/A					3"	N/A	
4"	N/A	5.17	5.78	6.31					5.10	N/A	9.17	9.10					4"	5.25	
6"	5.36	5.93	6.50	7.07					5.33	9.61	10.18	9.58					6"	5.90	
8"	7.40	8.14	8.90	9.64					6.96	12.27	13.01	11.84					8"	5.57	
10"	9.78	10.73	11.63	12.58					8.99	15.84	16.79	15.03					10"	6.00	
12"	12.50	13.61	14.72	15.83					11.54	19.75	20.86	18.79					12"	6.75	
14"	16.22	17.56	18.91	20.26			14.33	14.93	15.28	26.33	27.88	25.59	25.25	24.64			14"	7.75	
16"	19.07	20.61	22.14	23.65			17.42	18.03	18.93	31.88	33.42	31.77	30.86	30.23			16"	8.50	
18"	22.02	23.74	25.47	27.20			20.20	21.45	22.46	36.64	38.37	37.08	36.08	34.82			18"	9.00	
20"	25.09	27.01	28.93	30.85			23.33	25.09	26.35	42.09	44.01	43.35	42.09	40.53			20"	9.25	
24"	31.63	33.95	36.26	38.53		28.72	31.45	33.26	35.54	54.15	56.43	58.04	55.76	53.95	51.22		24"	11.40	
30"	42.98	47.05	51.13	55.20	37.63	41.71	45.80	48.86	52.88	72.98	77.05	82.88	78.86	75.80	71.71	67.63	30"	15.50	
36"	59.31	64.85	70.35	75.85	53.27	57.71	63.26	67.70	73.23	100.23	105.78	114.16	108.64	104.20	98.65	94.21	36"	18.00	
42"	73.23	80.94	89.84	97.58	66.06	73.79	80.28	86.90	93.58	121.54	129.25	143.89	135.21	128.59	122.10	114.57	42"	22.50	
48"	99.09	109.40	119.72	129.97	92.43	101.31	110.39	119.24	128.06	158.78	169.09	187.75	178.93	170.07	161.19	152.31	48"	28.00	
54"	133.08	147.92	162.80	177.57	122.33	135.44	148.49	161.33	174.57	204.58	219.42	246.07	233.03	219.99	206.94	193.83	54"	34.00	
60"					161.39	176.67	191.88	209.25	224.39					299.38	284.17	268.89	60"		
64"					174.62	193.34	217.00	230.56	246.79					324.50	305.84	287.12	64"		


MEDIUM

American Cast Iron Pipe Company
 Ductile Iron Pipe Price Sheet
 Pricing Calculations

3"	Class 30	FASTITE CEMENT LINED PER FT ESTIMATING PRICES													POLYBOND			
		Class 51	Class 52	Class 53	Class 150	Class 200	Class 250	Class 300	Class 350	R. J. 50	R. J. 51	R. J. 350	R. J. 300	R. J. 250	R. J. 200	R. J. 150	DI. STE	
3"	N/A	4.96	5.49	6.01					4.94	N/A	N/A	N/A					3"	N/A
4"	N/A	5.46	6.11	6.67					5.38	N/A	9.46	9.38					4"	5.25
6"	3.78	6.40	7.01	7.63					5.74	10.03	10.65	9.99					6"	5.50
8"	8.00	8.80	9.63	10.42					7.51	12.88	13.67	12.39					8"	5.57
10"	10.57	11.60	12.60	13.60					9.69	16.64	17.67	15.76					10"	6.00
12"	13.52	14.72	15.92	17.12					12.45	20.77	21.97	19.70					12"	6.75
14"	17.48	18.93	20.38	21.84		15.39	16.07	16.45	27.79	29.25	26.76	26.39	25.71				14"	7.75
16"	20.56	22.72	23.87	25.50		18.72	19.43	20.42	33.37	33.03	33.23	32.24	31.33				16"	8.50
18"	23.74	25.60	27.46	29.33		21.70	23.09	24.19	38.36	40.22	38.81	37.72	36.33				18"	9.00
20"	27.03	29.12	31.19	33.26		25.31	27.02	28.38	44.03	46.12	45.38	44.02	42.31				20"	9.25
24"	34.12	36.60	39.09	41.54		30.86	33.83	35.82	38.29	36.62	39.10	38.32	36.33	33.36			24"	11.40
30"	46.13	50.52	54.89	59.27	40.39	44.77	49.16	52.45	56.76	76.15	80.52	86.76	82.45	79.16	74.77	70.39	30"	15.50
36"	63.49	69.48	75.43	81.38	56.96	61.76	67.77	72.56	78.54	104.43	110.42	119.47	113.50	108.70	102.70	97.90	36"	18.00
42"	78.53	86.86	96.40	104.76	70.77	79.12	86.13	93.28	102.59	126.84	135.18	150.90	141.59	134.45	127.43	119.08	42"	22.50
48"	103.63	114.80	127.93	139.03	98.63	108.23	117.83	127.40	136.93	165.34	176.48	196.62	187.09	177.52	167.92	158.52	48"	28.00
54"	141.44	157.36	173.32	189.16	129.88	143.94	157.92	171.91	183.90	212.94	228.86	257.40	243.41	229.42	215.44	201.38	54"	34.00
60"					161.39	176.67	191.88	209.25	224.39					299.38	284.17	268.89	60"	
64"					174.62	193.34	212.00	230.36	246.79					324.50	305.84	287.12	64"	

SMALL

American Cast Iron Pipe Company
 Ductile Iron Pipe Price Sheet
 Pricing Calculations



PARTITE CEMENT LINED PIPE ESTIMATING PRICES

	Class 50	Class 51	Class 52	Class 53	Class 150	Class 200	Class 250	Class 300	Class 350	R. J. 90	R. J. 51	R. J. 360	R. J. 900	R. J. 250	R. J. 200	R. J. 150	POLYBOND PLATE	
3"	N/A	5.60	6.20	6.79					3.57	N/A	N/A	N/A					3"	N/A
4"	N/A	6.27	7.02	7.63					6.13	N/A	10.27	10.15					4"	5.25
6"	6.94	7.68	8.42	9.15					6.87	11.19	11.93	11.12					6"	5.90
8"	9.63	10.61	11.61	12.38					9.02	14.53	15.49	13.90					8"	5.57
10"	12.75	13.99	15.20	16.40					11.63	18.81	20.06	17.69					10"	6.00
12"	16.30	17.75	19.19	20.64					14.94	23.35	25.00	22.19					12"	6.75
14"	20.95	22.69	24.43	26.16			18.32	19.20	19.67	31.26	33.00	29.98	29.31	28.63			14"	7.75
16"	24.64	26.63	28.61	30.56			22.78	23.21	24.42	37.46	39.44	37.24	34.02	35.09			16"	8.90
18"	28.45	30.68	32.91	35.13			25.83	27.58	28.93	43.07	45.31	43.33	42.21	40.45			18"	9.00
20"	32.42	34.90	37.38	39.86			30.19	32.31	33.94	49.42	51.90	50.94	49.31	47.19			20"	9.25
24"	40.90	43.87	46.85	49.79		36.72	40.36	42.85	45.80	63.40	66.37	68.30	65.35	62.86	99.22		24"	11.40
30"	54.82	60.01	65.21	70.41	47.96	53.17	58.37	62.28	67.40	84.82	90.01	97.40	92.28	88.37	83.17	77.96	30"	15.50
36"	80.60	86.59	92.53	98.47	73.88	78.69	84.71	89.51	95.31	121.53	127.52	136.45	130.45	125.68	119.63	114.82	36"	18.00
42"	95.56	103.88	111.87	124.41	87.90	96.25	103.26	110.76	122.15	143.87	152.19	170.47	159.07	151.57	144.56	134.21	42"	22.90
48"	139.66	150.82	162.02	173.11	132.89	142.48	152.07	161.66	171.19	199.35	210.51	230.88	221.34	211.76	202.17	192.58	48"	28.00
54"	175.70	191.61	207.57	223.42	164.12	178.18	192.17	206.17	220.16	247.20	263.11	291.66	277.67	263.67	249.68	235.62	54"	34.00
60"					229.87	245.19	260.38	277.75	292.88					367.88	352.69	337.37	60"	
64"					241.22	260.20	279.06	297.79	314.13					391.56	372.70	353.72	64"	

APPENDIX Q

Piping Costs

DIP (Class 50 – Cement Lined) Water Main

<u>Size (in)</u>	<u>Small Job (250') (\$/ft)</u>	<u>Med. Job (2,500') (\$/ft)</u>	<u>Large Job (25,000') (\$/ft)</u>
6"	20.89	16.57	14.89
8"	24.01	19.06	17.14
10"	27.58	21.94	19.75
12"	31.66	25.24	22.75
14"	37.01	29.68	26.84
16"	41.25	33.13	29.97

- Notes:
- 1) Values obtained using manufacturer's quotes.
 - 2) Costs include \$500 permitting, 10%–15% mobilization, \$7/ft installation, \$1–\$2 per foot disinfection and \$.25–\$.75 per foot pressure testing.
 - 3) Costs exclude valves, fittings, and restoration work.

HARTMAN & ASSOCIATES, INC. engineers, hydrogeologists, surveyors & management consultants	SPL. NO.: 2	JOB NO.: 95-145.00
	MADE BY: JJW	DATE:
	CHECKED BY:	DATE:

Pipe Costs

* Includes pressure testing

④ DIP (Fastite Cement Lined Class 50) Force Main

Pipe Size	small job 250' - 100' (\$/ft)		med. job 250' - 1,500' (\$/ft)		large job 25,000' (\$/ft)	
	15	18.89	13	15.07	11	13.89
6"	7.69	18.89	6.28	15.07	5.61	13.89
8"	10.40	22.01	8.50	17.56	7.65	16.14
10"	13.50	25.58	11.07	20.44	10.03	18.75
12"	17.05	29.66	14.02	23.74	12.75	21.75
14"	21.70	35.01	17.98	28.18	16.47	25.84
16"	25.39	39.25	21.06	31.63	19.32	28.97
20"	33.17	48.20	27.55	38.90	25.34	35.59
24"	41.65		34.62		31.90	
30"	55.57		51.02		43.23	

Address for W.M.

Epoxy lining
1
5.50
5.57
6.00
6.75
7.75
8.50
9.25
11.40
15.50


⑤ DIP (Restrained Joint Class 50) Force Main

Pipe Size	small job		med. job		large job	
	11	19.83	10.53	19.83	9.86	18.57
6"	11.94	23.78	10.53	19.83	9.86	18.57
8"	15.28	27.62	13.38	23.03	12.52	21.49
10"	19.56	32.59	17.14	27.24	16.09	25.42
12"	24.30	38.00	21.27	31.86	20.00	29.72
14"	32.01	46.86	28.29	39.72	26.78	37.18
16"	38.21	53.99	33.18	45.97	32.13	43.06
20"	50.17		44.55		42.34	
24"	64.15		57.12		54.40	
30"	85.57		76.65		73.23	

Epoxy lining

* Add \$1/ft for water main on a big job.
 \$1.50/ft for water main on a medium job.
 \$2.00/ft for water main on a small job.

Also force mains must be epoxy lined



FLORIDA DISTRIBUTION CENTERS

11114 SATELLITE BLVD., ORLANDO, FL 32827
1101 WEST 17TH STREET, RIVIERA BEACH, FL 33404
6761 25TH COURT EAST, SARASOTA, FL 34243
2884-A PROSPECT AVENUE, NAPLES, FL 33942

(407) 855-8510
(407) 848-4896
(813) 766-8766
(215) 434-0666

COVER SHEET

TO: Jamey Wallace - Hartman & Assoc.

FROM: EJ M.

DATE: 9-1

OF PAGES SENT (INC. COVER SHEET) 5

IF YOU DID NOT RECEIVE TOTAL # OF PAGES PLEASE
CALL 407-855-8510 / 800-531-6998 / FAX # 407-240-1901
AND NOTIFY US IMMEDIATELY.

MESSAGES: Pipe estimates for
your economy of scale
projections.

Thy
EJ


SENDING FAX TO # _____

PVC - C900 DR 18 - (Blue)

Water Mains

<u>Size</u> <u>(in.)</u>	<u>Cost</u> <u>150 ft.</u> <u>(\$/LF)</u>	<u>Cost</u> <u>1,500 ft.</u> <u>(\$/LF)</u>	<u>Cost</u> <u>25,000 ft.</u> <u>(\$/LF)</u>
4"	1.66	1.57	1.48
6"	3.12	2.98	2.89
8"	5.48	5.23	5.06
10"	8.04	7.84	7.56
12"	11.41	11.06	10.81

2000
Visit
Print
EAC



HARTMAN & ASSOCIATES, INC.

engineers, hydrogeologists, surveyors & management consultants

301 EAST PINE STREET • SUITE 1000 • ORLANDO, FL 32801
TELEPHONE (407) 839-3955 • FAX (407) 839-3790
FAX (ADMN/UTILITY ENR/HYDRO) • (407) 839-3780
FAX (CIVL. ENR/SURVEY/PLANCE) • (407) 481-8447

From Jim G. ^{Orlando} ~~Orlando~~
FACSIMILE TRANSMITTAL

TO: ~~John Gulkins~~ FROM: Jamey Wallace

DATE: 9/1/95

RE: Costs for PVC piping - Economy of Scale

WE ARE SENDING YOU 5 PAGES, INCLUDING THIS COVER SHEET.
THESE PAGES ARE BEING TRANSMITTED AS INDICATED BELOW:

- AS REQUESTED
- FOR YOUR USE
- FOR YOUR COMMENTS
- FOR YOUR APPROVAL

HARD COPY:

- WILL BE SENT VIA REGULAR MAIL
- WILL BE SENT VIA OVERNIGHT MAIL
- WILL BE SENT BY FACSIMILE ONLY

MESSAGE:

John, what I'm looking for are costs based on linear footage of the job, As we both know there typically is a considerable savings for a much larger job than for a smaller job based on the circumstances. Therefore, if maybe you could quote the prices as three (3) different jobs, one w/ 150' lengths, one 1,500', one 25,000'. That way we could see the savings. Your help & professional opinion would be greatly appreciated. Thank, JJW

IF THERE ARE QUESTIONS OR PROBLEMS WITH THIS TRANSMITTAL,
PLEASE CALL (407) 839-3955

PVC - C900 DR 18

Water Mains

Size (in.)	Cost 150 ft (\$/LF)	Cost 1,500 ft (\$/LF)	Cost 25,000 ft (\$/LF)
4"	1.52	1.45	1.39
6"	2.85	2.70	2.60
8"	4.98	4.75	4.52
10"	7.50	7.10	6.76
12"	16.50	10.00	9.53

Pressure Test
Protect
Next
600

4 HR TEST @ 140 PSI

AMERICAN CAST IRON PIPE COMPANY

2301 MAITLAND CENTER PARKWAY, SUITE 430
MAITLAND, FLORIDA 32751
PHONE (407) 660-8786 FAX (407) 660-1851

DATE: 8/1/95
fax 407 839-3790

NO. OF PAGES 4
(including this page)

TO: SAMMY WALLACE - HARTMAN ASSOC

FROM: Jerry Seaman

SUBJECT: ESTIMATING PRICES
SOUTHERN STATES UTILITIES

ATTACHED ARE 3 PRICE LISTS FOR SMALL, MED. & LARGE JOBS. NOTE THE PRICE DIFFERENCES IN CLASS 50, BUT ALSO NOTICE THE SAVINGS IN PRESSURE CLASS PIPE 150, 200 & 250 IN SIZES 14" THRU 30".

RJ = RESTRAINED JOINT PIPE

POLYBOND OR CTG = PER FOOT ADDS TO ALL PRICES SHOWN.

Jerry

LARGE

American Cast Iron Pipe Company
 Ductile Iron Pipe Price Sheet
 Pricing Calculations

FASITE CEMENT LINED PER FT ESTIMATING PRICES

	Class 30	Class 31	Class 32	Class 33	Class 150	Class 200	Class 250	Class 300	Class 350	R.J. 50	R.J. 51	R.J. 350	R.J. 300	R.J. 250	R.J. 200	R.J. 150	POLYBOND	
3"	N/A	4.72	5.23	5.73					4.71	N/A	N/A	N/A					3"	N/A
4"	N/A	5.17	5.78	6.31					5.10	N/A	9.17	9.10					4"	5.25
6"	5.36	5.93	6.50	7.07					5.33	9.61	10.18	9.58					6"	5.90
8"	7.40	8.14	8.90	9.64					6.96	12.27	13.01	11.84					8"	5.57
10"	9.78	10.73	11.63	12.58					8.99	15.84	16.79	15.03					10"	6.00
12"	12.30	13.61	14.72	15.83					11.34	19.73	20.86	18.79					12"	6.75
14"	16.22	17.56	18.91	20.26			14.33	14.93	15.28	26.33	27.88	25.59	25.23	24.64			14"	7.75
16"	19.07	20.61	22.14	23.63			17.42	18.03	18.93	31.88	33.42	31.77	30.86	30.23			16"	8.50
18"	22.02	23.74	25.47	27.20			20.20	21.43	22.46	36.64	38.37	37.08	36.08	34.82			18"	9.00
20"	25.09	27.01	28.93	30.83			23.33	25.09	26.33	42.09	44.01	43.33	42.09	40.53			20"	9.25
24"	31.63	33.93	36.26	38.33		28.72	31.43	33.26	33.54	54.15	56.43	58.04	55.76	53.95	51.22		24"	11.40
30"	42.98	47.03	51.13	55.20	37.63	41.71	43.80	48.86	52.88	72.98	77.03	82.88	78.86	75.80	71.71	67.63	30"	15.50
36"	59.31	64.83	70.33	73.83	53.27	57.71	63.26	67.70	73.23	100.23	103.78	114.16	108.64	104.20	98.65	94.21	36"	18.00
42"	73.23	80.94	89.84	97.58	66.06	73.79	80.28	86.90	93.38	121.54	129.23	143.89	133.21	128.59	122.10	114.37	42"	22.50
48"	99.09	109.40	119.72	129.97	92.63	101.31	110.39	119.24	128.06	158.78	169.09	187.73	178.93	170.07	161.19	152.31	48"	28.00
54"	133.08	147.92	162.80	177.57	122.33	135.44	148.49	161.53	174.57	204.38	219.42	246.87	233.83	219.99	206.94	193.83	54"	34.00
60"					161.39	176.67	191.88	209.23	224.39					299.38	284.17	268.89	60"	
64"					174.62	193.34	212.00	230.36	246.79					324.50	305.84	287.12	64"	

NU. 101 NW

MEDIUM

American Cast Iron Pipe Company
 Ductile Iron Pipe Price Sheet
 Pricing Calculations

FASTITE CEMENT LINED PER FT ESTIMATING PRICES

	Class 50	Class 51	Class 52	Class 53	Class 150	Class 200	Class 250	Class 300	Class 350	R. J. 50	R. J. 51	R. J. 350	R. J. 300	R. J. 250	R. J. 200	R. J. 150
3"	N/A	4.96	5.49	6.01					4.94	N/A	N/A	N/A				
4"	N/A	5.46	6.11	6.67					5.38	N/A	9.46	9.38				
6"	5.78	6.40	7.01	7.63					5.74	10.03	10.65	9.99				
8"	8.00	8.80	9.63	10.42					7.51	12.88	13.67	12.39				
10"	10.57	11.60	12.60	13.60					9.69	16.64	17.67	15.76				
12"	13.52	14.72	15.92	17.12					12.45	20.77	21.97	19.70				
14"	17.48	18.93	20.38	21.84		15.39	16.07		16.45	27.79	29.25	26.76	26.39	25.71		
16"	20.56	22.22	23.87	25.50		18.72	19.43		20.42	33.37	35.03	31.23	31.24	31.53		
18"	23.74	25.60	27.46	29.33		21.70	23.09		24.19	38.36	40.22	38.81	37.72	36.33		
20"	27.03	29.12	31.19	33.26		25.31	27.02		28.38	44.05	46.12	45.38	44.02	42.31		
24"	34.12	36.60	39.09	41.54		30.86	33.83	35.82	38.29	56.62	59.10	60.79	58.32	56.33	53.36	
30"	46.13	50.52	54.89	59.27	40.39	44.77	49.16	52.45	56.76	76.15	80.52	86.76	82.45	79.16	74.77	70.39
36"	63.49	69.48	75.43	81.38	56.96	61.76	67.77	71.56	78.34	104.43	110.42	119.47	113.50	108.70	102.70	97.90
42"	78.53	86.86	96.40	104.76	70.77	79.12	86.13	93.28	102.59	126.84	135.18	150.90	141.59	134.45	127.43	119.08
48"	105.65	116.80	127.95	139.03	98.63	108.23	117.83	127.40	136.93	163.34	176.48	196.62	187.09	177.52	167.92	158.32
54"	141.44	157.36	173.32	189.16	129.88	143.94	157.92	171.91	183.90	212.94	228.86	257.40	243.41	229.42	215.44	201.38
60"					161.39	176.67	191.88	209.25	224.39					299.36	284.17	268.89
64"					174.62	193.34	212.00	230.36	246.79					324.50	305.84	287.12

POLYBOND

	or CTE
3"	N/A
4"	5.25
6"	5.90
8"	5.57
10"	6.00
12"	6.75
14"	7.75
16"	8.50
18"	9.00
20"	9.25
24"	11.40
30"	15.50
36"	18.00
42"	22.50
48"	28.00
54"	34.00
60"	
64"	

SMALL

American Cast Iron Pipe Company
 Ductile Iron Pipe Price Sheet
 Pricing Calculations

PASTITE CEMENT LINED PER FT ESTIMATING PRICES

	Class 50	Class 51	Class 52	Class 53	Class 150	Class 200	Class 250	Class 300	Class 350	R. J. 50	R. J. 51	R. J. 360	R. J. 300	R. J. 250	R. J. 200	R. J. 150	POLYBOND	
3"	N/A	5.60	6.20	6.79					5.57	N/A	N/A	N/A					3"	N/A
4"	N/A	6.27	7.02	7.63					6.15	N/A	10.27	10.15					4"	5.25
6"	6.94	7.68	8.42	9.15					6.87	11.19	11.93	11.12					6"	5.90
8"	9.63	10.61	11.61	12.58					9.02	14.53	15.49	13.90					8"	5.57
10"	12.73	13.99	15.20	16.40					11.63	18.81	20.06	17.69					10"	6.00
12"	16.30	17.75	19.19	20.64					14.94	23.33	25.00	22.19					12"	6.75
14"	20.93	22.69	24.43	26.16		18.32	19.20	19.67	31.26	33.00	29.98	29.51	28.63				14"	7.75
16"	24.64	26.63	28.61	30.56		22.28	23.21	24.42	37.46	39.44	37.24	36.02	35.09				16"	8.50
18"	28.43	30.68	32.91	35.15		25.83	27.58	28.93	43.07	45.31	43.53	42.21	40.45				18"	9.00
20"	32.42	34.90	37.38	39.86			30.19	32.31	33.94	49.42	51.90	50.94	49.31	47.19			20"	9.25
24"	40.90	43.87	46.85	49.79		36.72	40.36	42.85	45.80	63.40	66.37	68.30	65.33	62.86	59.22		24"	11.40
30"	54.82	60.01	65.21	70.41	47.96	53.17	58.37	62.28	67.40	84.82	90.01	97.40	92.28	88.37	83.17	77.96	30"	15.50
36"	80.60	86.59	92.53	98.47	73.88	78.69	84.71	89.51	95.31	121.53	127.32	136.45	130.45	125.65	119.63	114.82	36"	18.00
42"	91.56	101.88	111.87	124.41	87.90	96.25	103.26	110.76	122.15	143.87	152.19	170.47	159.07	151.57	144.56	136.21	42"	22.90
48"	139.64	150.82	162.02	173.11	132.89	142.48	152.07	161.66	171.19	199.33	210.31	230.88	221.34	211.76	202.17	192.58	48"	28.00
54"	175.70	191.61	207.57	223.42	164.12	178.18	192.17	206.17	220.16	247.20	263.11	291.66	277.67	263.67	249.68	235.62	54"	34.00
60"					229.87	245.19	260.38	277.73	292.88					567.88	352.69	337.37	60"	
64"					241.22	260.20	279.06	297.79	316.15					391.56	372.70	353.72	64"	

COMMENTARY ON PRESENT WORTH COSTS OF EXPANSIONS UNDER VARYING GROWTH AND ECONOMIC CONDITIONS

SUMMARY

THE FOLLOWING THREE PAGES OF FIGURES ILLUSTRATE THE PRESENT WORTH COSTS OF TANK EXPANSIONS ASSUMING DIFFERENT GROWTH RATES UNDER VARIOUS ECONOMIC CONDITIONS. EACH PAGE REFLECTS A DIFFERENT GROWTH RATE, 1%, 3% AND 5%, RESPECTIVELY. PRESENT WORTH VALUES ARE LISTED ACROSS THE BOTTOM OF EACH OF THE THREE FIGURES DISPLAYED ON A PAGE. THE PRESENT WORTH VALUES REPRESENT THE TOTAL COST TO THE UTILITY IN TODAY'S DOLLARS FOR INSTALLING STORAGE TANKS ONLY OF THE SIZE SHOWN IN THE ROW ABOVE PRESENT WORTH AND ASSUMING (1) THE ECONOMIC CONDITIONS OF THE TWO PRECEDING ROWS, AND (2) THE PHASING PARAMETERS AT THE TOP OF THE FIGURE, SUCH AS THE PROGRESSION FROM 25,000 GPD TO 100,000 GPD ON THE TOP FIGURE OF EACH PAGE. PRESENT WORTH VALUES VARY FROM ONE PAGE TO THE NEXT BECAUSE THE GROWTH RATES SPECIFIC TO EACH PAGE DICTATE THE TIMING OF THE TANK INSTALLATIONS. THE TANK PHASING OPTION WITH THE LOWEST TOTAL PRESENT WORTH ASSUMING THE CONDITIONS ABOVE IS ENCLOSED IN A BOX.

CONCLUSION

IN ALL CASES THE SMALLEST TANK ALTERNATIVE
PRODUCES THE HIGHEST PRESENT WORTH COST.

PHASE:


INFLATION RATE (%):

DISCOUNT RATE (%):

TANK SIZE (1000 GALS.):

TOTAL PRESENT WORTH (\$):

25,000 GPD TO 100,000 GPD
LEFT OF INFLECTION POINT



PHASE:


INFLATION RATE (%):

DISCOUNT RATE (%):

TANK SIZE (1000 GALS.):

TOTAL PRESENT WORTH (\$):

50,000 GPD TO 150,000 GPD
TRANSITION



PHASE:


INFLATION RATE (%):

DISCOUNT RATE (%):

TANK SIZE (1000 GALS.):

TOTAL PRESENT WORTH (\$):

100,000 GPD TO 500,000 GPD
RIGHT OF INFLECTION POINT



PHASE:


INFLATION RATE (%):

DISCOUNT RATE (%):

TANK SIZE (1000 GAL.):

TOTAL PRESENT WORTH (\$):

**25,000 GPD TO 100,000 GPD
LEFT OF INFLECTION POINT**



PHASE:


INFLATION RATE (%):

DISCOUNT RATE (%):

TANK SIZE (1000 GAL.):

TOTAL PRESENT WORTH (\$):

**50,000 GPD TO 150,000 GPD
TRANSITION**



PHASE:

INFLATION RATE (%):

DISCOUNT RATE (%):

TANK SIZE (1000 GAL.):

TOTAL PRESENT WORTH (\$):

**100,000 GPD TO 500,000 GPD
RIGHT OF INFLECTION POINT**




EXHIBIT GCH-6

5% SYSTEM GROWTH RATE - PHASED EXPANSION OF STEEL GROUND STORAGE TANK



EXHIBIT GCH-5

PAGE 4 OF 5


PHASE:

INFLATION RATE (%):

DISCOUNT RATE (%):

TANK SIZE (1000 GALS.):

TOTAL PRESENT WORTH (\$):




PHASE:

INFLATION RATE (%):

DISCOUNT RATE (%):

TANK SIZE (1000 GALS.):

TOTAL PRESENT WORTH (\$):



PHASE:

INFLATION RATE (%):

DISCOUNT RATE (%):

TANK SIZE (1000 GALS.):

TOTAL PRESENT WORTH (\$):




EXHIBIT GCH-6

3% SYSTEM GROWTH RATE - PHASED EXPANSION OF STEEL GROUND STORAGE TANK



EXHIBIT GCH-5

PAGE 5 OF 5

SSU MARGIN RESERVE


PEPO Table

Net Construction Cost (\$)	Planning & Engineering (1) (%)	Engineering Survey (%)	Permitting (%)	Operations (%)	Total (2) Percentage (%)
\$100,000	11.63%	3.00%	3.00%	1.00%	18.63%
\$200,000	10.25%	2.64%	2.64%	0.88%	16.42%
\$500,000	8.52%	2.20%	2.20%	0.73%	13.65%
\$1,000,000	7.53%	1.94%	1.94%	0.65%	12.06%
\$5,000,000	6.42%	1.66%	1.66%	0.55%	10.28%
\$10,000,000	6.03%	1.56%	1.56%	0.52%	9.66%

Notes:

- (1) The basic services (planning & engineering) are based on Figure 1, from "Consulting Engineering" by the American Society of Civil Engineers. Figure 1 is a representation of the basic services for above-average complexity projects, which include: water and wastewater treatment plants, water distribution lines under 16" diameter, and sanitary sewer lines under 24" diameter.
- (2) The total percentage represents a percentage of the construction cost that must be added to the construction cost in order to obtain the total project cost.

**PEPO Curve
(Based on Table 5)**



SSU MARGIN RESERVE

Manufacturer's Standard Sizes

<u>Description</u>	<u>Standard Sizes</u>
1) Prestressed Concrete Ground Storage Tank	0.1 MG, 0.2 MG, 0.25 MG, 0.3 MG, 0.4 MG, 0.5 MG, 0.6 MG, 0.75 MG, 1.0 MG, 1.25 MG, 1.5 MG, and 2.0 MG.
2) Steel Ground Storage Tank	0.016 MG, 0.022 MG, 0.024 MG, 0.027 MG, 0.031 MG, 0.032 MG, 0.033 MG, 0.037 MG, 0.039 MG, 0.043 MG, 0.047 MG, 0.053 MG, 0.054 MG, 0.064 MG, 0.071 MG, 0.074 MG, 0.081 MG, 0.088 MG, 0.105 MG, 0.107 MG, 0.114 MG, 0.122 MG, 0.132 MG, 0.149 MG, 0.151 MG, 0.158 MG, 0.183 MG, 0.185 MG, 0.199 MG, 0.218 MG, 0.22 MG, 0.246 MG, 0.256 MG, 0.286 MG, 0.294 MG, 0.326 MG, 0.341 MG, 0.355 MG, 0.421 MG, 0.423 MG, 0.428 MG, 0.491 MG, 0.53 MG, 0.553 MG, 0.567 MG, 0.632 MG, 0.685 MG, 0.691 MG, 0.734 MG, 0.744 MG, 0.816 MG, 0.874 MG, 0.906 MG, 0.921 MG, 0.948 MG, 1.099 MG, 1.1122 MG, 1.1147 MG, 1.338 MG, and 1.42 MG.
3) Extended Aeration Package Wastewater Treatment Plant	a) 0.0033MGD, 0.005 MGD, 0.0083 MGD, 0.01 MGD, 0.015 MGD, 0.02 MGD, 0.025 MGD, 0.03 MGD, 0.035 MGD, and 0.04 MGD.
a) Modular Concrete	
b) Cylindrical (Tubular)	b) 0.014 MGD, 0.015 MGD, 0.016 MGD, 0.017 MGD, 0.018 MGD, 0.019 MGD, 0.02 MGD, 0.022 MGD, 0.024 MGD, 0.025 MGD, 0.026 MGD, 0.028 MGD, 0.03 MGD, 0.035 MGD, 0.04 MGD, 0.045 MGD, 0.05 MGD, 0.055 MGD, 0.06 MGD, 0.07 MGD.
c) Ring Steel	c) 0.05 MGD, 0.075 MGD, 0.1 MGD, 0.125 MGD, 0.15 MGD, 0.175 MGD, 0.2 MGD, 0.25 MGD, 0.3 MGD, 0.4 MGD, 0.5 MGD, 0.625 MGD, and 0.75 MGD.
4) Contact Stabilization Package Wastewater Treatment Plant	a) 0.03 MGD, 0.035 MGD, 0.04 MGD, 0.045 MGD, 0.05 MGD, 0.055 MGD, 0.06 MGD, 0.07 MGD, 0.075 MGD, 0.08 MGD, 0.09 MGD, and 0.1 MGD.
a) Cylindrical (Tubular)	
b) Ring Steel	b) 0.05 MGD, 0.075 MGD, 0.1 MGD, 0.125 MGD, 0.15 MGD, 0.175 MGD, 0.2 MGD, 0.25 MGD, 0.3 MGD, 0.4 MGD, 0.5 MGD, 0.625 MGD, 0.75 MGD, 1.0 MGD, 1.25 MGD, 1.5 MGD, 1.75 MGD, and 2.0 MGD.
5) Hydropneumatic Tanks	1,000 Gal., 2,000 Gal., 5,000 Gal., 7,500 Gal., 10,000 Gal., 15,000 Gal., and 20,000 Gal.

SSU MARGIN RESERVE

Manufacturer's Standard Sizes (Cont.)

<u>Description</u>	<u>Standard Sizes</u>
6) Auxiliary Power Generators	7.5 KW, 12.5 KW, 15 KW, 17.5 KW, 20 KW, 25 KW, 35 KW, 50 KW, 75 KW, 100 KW, 150 KW, 200 KW, 250 KW, 300 KW, 350 KW, 400 KW, 500 KW, 600 KW, 750 KW, 1000 KW, 1250 KW, 1500 KW, 1750 KW, and 2000 KW.
7) Clarifiers (Pre-engineered)	30 foot, 35', 40', 45', 50' 55', 60', 65', 70', 75', 80', 85', 90', 95', 100', and 104 feet in diameter.
8) Tertiary Filters	a) 0.01 MGD, 0.02 MGD, 0.03 MGD, 0.04 MGD, 0.05 MGD, 0.06 MGD, 0.07 MGD, 0.08 MGD, 0.09 MGD, 0.1 MGD, 0.11 MGD, 0.12 MGD, 0.15 MGD, 0.175 MGD, 0.2 MGD, and 0.22 MGD.
a) TES Gravity Filter	
b) Traveling Bridge	b) 0.2 MGD, 0.25 MGD, 0.3 MGD, 0.35 MGD, 0.4 MGD, 0.5 MGD, 0.6 MGD, 0.7 MGD, 0.8 MGD, 0.9 MGD, 1.0 MGD, 1.25 MGD, 1.5 MGD, 1.75 MGD, and 2.0 MGD
9) Ductile Iron Pipe (DIP) Water Mains and Force Mains (2)	4-inch, 6", 8", 10", 12", 14", 16", 18", 20", and 24" diameter.
10) Polyvinyl Chloride Pipe (PVC) DR18 Water Mains and DR25 Force Mains (2)	4-inch, 6", 8", 10", 12", 14", 16", 18", 20", and 24" diameter.
11) Polyvinyl Chloride Pipe (PVC) SDR 35 Gravity Sewer	4-inch, 6", 8", 10", 12", 15", 18", 21", 24", and 27" diameter.
12) Elevated Storage Tank	a) 0.05 MG, 0.06 MG, 0.075 MG, 0.1 MG, 0.125 MG, 0.15 MG, and 0.2 MG.
a) Pedestal Spheres	b) 0.1 MG, 0.15 MG, 0.2 MG, 0.25 MG, 0.3 MG, and 0.4 MG.
b) Hydropillar (Wineglass)	c) 0.2 MG, 0.25 MG, 0.3 MG, 0.4 MG, 0.5 MG, 0.75 MG,
c) Hydropillar	1.0 MG, 1.5 MG, 2.0 MG, 2.5 MG, and 3.0 MG.

Notes:

- (1) The standard sizes for the water and wastewater components listed above were determined through discussions with product representatives and product catalogs.
- (2) The 14-inch and 18-inch diameter pipes listed in the water mains and force mains standard sizes usually require very long delivery times due to lack of demand.

SSU MARGIN RESERVE

Threshold Sizing -- State/Local Requirements and Level of Service

No. Description of Requirements**Piping**

- 1 A 6-inch diameter pipe is the smallest allowable water main, where fire flow is required. In some cases, an 8-inch diameter water main may be required to provide fire flow and required pressure within the main. These requirements are outlined in the "Recommended Standards For Water Works" (1992), as referenced by 62-555.330 (3), F.A.C.
- 2 The minimum allowable force main size shall be 4-inches in diameter. This requirement is set forth by the "Recommended Standards For Wastewater Facilities" (1990), as referenced by 62-604.300 (4) (b), F.A.C.
- 3 No public gravity sewer shall be less than 8-inches in diameter. The service laterals can be 4 or 6-inches individually, but the main gravity sewer main must be 8-inches in diameter. This requirement is found in the "Recommended Standards For Wastewater Facilities" (1990), as referenced by 62-604.300 (4) (b), F.A.C.

Wastewater Treatment Plants

- 4 In order for a wastewater treatment plant to provide reclaimed water for public access areas, a wastewater treatment facility must have a design flow of no less than 0.1 MGD and the facility must meet Class I reliability criteria, as stated in 62-610.451 (1) and 62-610.462 (1). The Class I requirements are as follows:
 - (1) A backup bar screen shall be provided (backup may be designed for manual cleaning).
 - (2) A backup pump shall be provided for each set of pumps which performs the same function.
 - (3) If comminution of the total wastewater flow is provide, then an overflow bypass with an installed manually- or mechanically cleaned bar screen shall be provided.
 - (4) The backup sedimentation basins should have a design flow capacity of at least 50% of the total design flow of the largest unit.
 - (5) For final and chemical sedimentation basins, trickling filters, filters and activated carbon columns, there shall be a sufficient number of units of a size, such that with the largest unit out of service, the remaining units shall have a design flow capacity of at least 75% of the total design flow of the largest unit.
 - (6) At least two (2) equal volume aeration basins must be provided.
 - (7) There shall be a sufficient number of aeration blowers or mechanical aerators to enable the design oxygen transfer with the largest unit out of service.
 - (8) The air diffusion system for each aeration basin shall be designed such that the largest section of diffusers can be isolated without measurably impairing the oxygen transfer capability of the system.
 - (9) At least two (2) chemical flash mixing basins must be provided or a backup means for adding and mixing chemicals, separate from the basin, shall be provided.
 - (10) At least two (2) flocculation basins must be provided.
 - (11) With the largest basin out of service, there shall be a sufficient number of units of size to provide 50% of the total design flow of the largest unit.

SSU MARGIN RESERVE

Threshold Sizing -- State/Local Requirements and Level of Service (Cont.)

No. Description of Requirements

Wastewater Treatment Plants (Cont.)

- 5 "Unless otherwise stated, new, expanded, or modified wastewater treatment and domestic wastewater treatment and domestic residuals treatment, handling, and dewatering facilities shall be designed to provide Class III reliability as described in Rule 62-600.300 (4) (l), F.A.C." This rule references the U.S. EPA "Design Criteria for Mechanical, Electric, and Fluid System and Component Reliability-MCD-05." The Class III requirements are as follows:
 - (1) A backup bar screen shall be provided (backup may be designed for manual cleaning).
 - (2) A backup pump shall be provided for each set of pumps which performs the same function.
 - (3) If comminution of the total wastewater flow is provide, then an overflow bypass with an installed manually- or mechanically cleaned bar screen shall be provided.
 - (4) There shall be at least two (2) sedimentation basins.
 - (5) There shall be at least two (2) blowers or mechanical aerators available for service.
 - (6) The air diffusion system for each aeration basin shall be designed such that the largest section of diffusers can be isolated without measurably impairing the oxygen transfer capability of the system.
 - (7) With the largest disinfection contact basin out of service, there shall be a sufficient number of units to provide 50% of the total design flow of the largest unit.

Water Treatment Plants

- 6 The number of drinking water supply wells required for a water treatment and distribution system is set forth in 62-555.315 (1), F.A.C. This rule requires a minimum of two (2) drinking water supply wells for all community water systems that will serve 350 or more persons or have more than 150 connections.
- 7 The auxiliary power requirements of a public water system are detailed in 62-555.320 (6) (a), F.A.C. Community systems that serve 350 or more persons, or have 150 or more service connections, shall provide auxiliary power for operation of the source, treatment units and pumps at a rate equal to one-half maximum daily flow. This requirement can be met by connection to at least two independent power lines, interconnection to another public water system, or an in-place auxiliary power source equipped with an automatic start-up device.

WATER MAINS

Ultimate Buildout Cost Comparison

Description of Pipe Comparison

Comparison of a 6-inch diameter PVC (DR 18) water main installations on the basis of ultimate buildout demand. For this analysis, an initial demand requiring 250 linear feet of 6-inch water main, an intermediate demand of 2,500 ft., and an ultimate buildout of 25,000 ft. are utilized. The total cost for the piping options at these various stages are as follows:

A) Comparison of 250 ft to 2,500 ft buildout.

250 feet of 6-inch diameter WM installed as a single project	=>	\$5,327.77
2,500 feet of 6-inch diameter WM installed in 250' increments	=>	\$53,277.71
2,500 feet of 6-inch diameter WM installed as a single project	=>	\$40,653.49
Total Cost Savings	=>	\$12,624.22

B) Comparison of 250 ft to 25,000 ft buildout.

250 feet of 6-inch diameter WM installed as a single project	=>	\$5,327.77
25,000 feet of 6-inch diameter WM installed in 250' increments	=>	\$532,777.11
25,000 feet of 6-inch diameter WM installed as a single project	=>	\$349,172.89
Total Cost Savings	=>	\$183,604.22

C) Comparison of 2,500 ft to 25,000 ft buildout.

2,500 feet of 6-inch diameter WM installed as a single project	=>	\$40,653.49
25,000 feet of 6-inch diameter WM installed in 2,500' increments	=>	\$406,534.93
25,000 feet of 6-inch diameter WM installed as a single project	=>	\$349,172.89
Total Cost Savings	=>	\$57,362.04

Notes:

- 1) Unit costs used to calculate project cost are based on values from HAI's Economy of Scale Report. The project cost values also include adjustments for planning & engineering, engineering survey, permitting, and operations.

SSU MARGIN RESERVE

Water Mains Cost Per ERC

Pipe Diameter (in.)	Unit Cost (\$/lf) (1)	Pipe Flow Capacity (gpm) (2)	No. ERC's Served (3)	Unit Cost per ERC (\$/lf per ERC)
2	\$6.00	19	1	\$6.00
4	\$13.50	116	24	\$0.56
6	\$15.25	338	110	\$0.139
8	\$17.50	721	436	\$0.040
10	\$20.00	1,225	1,307	\$0.0153
12	\$23.00	1,762	2,381	\$0.0097
16	\$32.00	2,327	3,511	\$0.0091
20	\$40.50	4,191	7,239	\$0.0056

Notes:

- (1) The unit cost is based on manufacturers' material cost and open country installation.
- (2) The water main flow capacity was determined using the criteria head loss <math><10\text{ft}/1000\text{ft}</math> for <math><16''</math> dia. pipe and head loss <math><3\text{ft}/1000\text{ft}</math> for pipe 16" dia. and greater. The flow is determined using $Q=VA$ with the above limiting criteria (which are provided from AWWA).
- (3) The number of Equivalent Residential Connections (ERC's) served by the ultimate capacity of the pipe is determined using the "Community Water Systems Source Book" by Joseph S. Ameen. Using Table XXI, the maximum instantaneous flow per residence is used in conjunction with the range of number of residences served to determine the correct range for each pipe size.
- (4) The total pipe cost is determined using 100' width residential lots.

SSU MARGIN RESERVE

Water Main Unit Cost and Available Services

Pipe Diameter (inches)	Unit Cost (\$/LF) (1)	Services (2)
2	\$6.00	1
	\$7.50	23
4	\$13.50	24
	\$1.75	86
6	\$15.25	110
	\$2.25	326
8	\$17.50	436

=> Incremental Costs and Services

Notes:

- (1) The unit cost is based on manufacturers' material cost and open country installation.
- (2) The number of Equivalent Residential Connections (ERC's) served by the ultimate capacity of the pipe is determined using the "Community Water Systems Source Book" by Joseph S. Ameen. Using Table XXI, the maximum instantaneous flow per residence is used in conjunction with the range of number of residences served to determine the correct range for each pipe size.
- (3) The water main flow capacity was determined using the criteria head loss <10ft/1000ft for < 16" dia. pipe and head loss <3ft/1000ft for pipe 16" dia. and greater. The flow is determined using $Q=VA$ with the above limiting criteria (which are provided from AWWA).
- (4) The total pipe cost is determined using 100' width residential lots.

SSU MARGIN RESERVE

Force Mains Cost Per ERC

Pipe Diameter (in.)	Unit Cost (\$/lf) (1)	Pipe Flow Capacity (gpm) (2)	No. ERC's Served (3)	Cost per ERC
4	\$10.00	196	267	\$0.0375
6	\$11.25	441	645	\$0.0174
8	\$13.00	783	1,213	\$0.0107
10	\$15.00	1,224	1,994	\$0.0075
12	\$17.50	1,762	3,009	\$0.0058
14	\$23.50	2,399	4,274	\$0.0055
16	\$27.50	3,133	5,806	\$0.0047

Notes:

- (1) The unit cost is based on manufacturers' material cost and open country installation.
- (2) The force main flow capacity was determined using 5 fps flow velocity and the relationship $Q(\text{gpd}) = VA$.
- (3) The amount of Equivalent Residential Connections (ERC's) served by the ultimate capacity of the pipe is determined using 270 gpd/ERC. Also, the peak factor was determined using an average of 2.5 persons/ERC and the equation $P.F. = (18 + P^{1.2}) / (4 + P^{1/2})$ where P is population in thousands.

SSU MARGIN RESERVE

Force Main Unit Cost and Available Services

Pipe Diameter (Inches)	Unit Cost (\$/LF) (1)	Services (2)
4	\$10.00	267
	\$1.25	378
6	\$11.25	645
	\$1.75	568
8	\$13.00	1,213
	\$2.00	781
10	\$15.00	1,994
	\$2.50	1,015
12	\$17.50	3,009

=> Incremental Cost and Service

Notes:

- (1) The unit cost is based on manufacturers' material cost and open country installation.
- (2) The amount of Equivalent Residential Connections (ERC's) served by the ultimate capacity of the pipe is determined using 270 gpd/ERC. Also, the peak factor was determined using an average of 2.5 persons/ERC and the equation $P.F. = (18 + P^{1.2}) / (4 + P^{1/2})$, where P is population in thousands.
- (3) The force main flow capacity was determined using 5 fps flow velocity and the relationship $Q(\text{gpd}) = VA$.

GRAVITY SEWER

Ultimate Buildout Cost Comparison

Description of Pipe Comparison

Comparison of a 8-inch diameter PVC (SDR 35) gravity sewer installations on the basis of ultimate buildout demand. For this analysis, an initial demand requiring 400 linear feet (or 8 ERC's based on 100' lot widths), an intermediate demand of 2,000 ft. (40 ERC's), and an ultimate demand of 8,000 ft. (160 ERC's). The total costs of these piping options are as follows:

A) Comparison of individual 400 ft sections to 2,000 ft buildout.

400' of 8" Gravity, 1 MH, and 1 LS installed as a single project	=>	\$59,010.65
2,000' Gravity, 5 MH's, and 1 LS installed in 400' increments	=>	\$102,990.39
2,000' Gravity, 5 MH's, and 1 LS installed as a single project	=>	\$97,330.20
Total Cost Savings	=>	\$5,660.19

B) Comparison of 400 ft to 8,000 ft buildout.

400' of 8" Gravity, 1 MH, and 1 LS installed as a single project	=>	\$59,010.65
8,000' Gravity, 21 MH's, and 1 LS installed in 400' increments	=>	\$279,673.76
8,000' Gravity, 21 MH's, and 1 LS installed as a single project	=>	\$250,591.07
Total Cost Savings	=>	\$29,082.69

C) Comparison of 2,000 ft to 8,000 ft buildout.

2,000' of 8" Gravity, 5 MH's, and 1 LS installed as a single project	=>	\$97,330.20
8,000' Gravity, 21 MH's, and 1 LS installed in 2,000' increments	=>	\$259,275.55
8,000' Gravity, 21 MH's, and 1 LS installed as a single project	=>	\$250,591.07
Total Cost Savings	=>	\$8,684.48

Notes:

- 1) Unit costs used to calculate project cost are based on values from HAI's Economy of Scale Report. The project cost values also include adjustments for planning & engineering, engineering survey, permitting, and operations.
- 2) The 8-inch gravity sewer costs are based on depth of cut, which for an 8-inch diameter PVC gravity sewer line is approximately 0.32 ft/1,000 ft.
- 3) The cost of manholes and a lift station is included with each of the above scenarios.

SSU MARGIN RESERVE

Gravity Sewer Cost Per ERC

Pipe Diameter (in.)	Unit Cost (\$/lf) (1)	Pipe Flow Capacity (gpm) (2)	No. ERC's Served (3)	Cost per ERC
8	\$12.28	344	493	\$0.0249
10	\$14.71	522	776	\$0.0190
12	\$16.91	752	1,159	\$0.0146
15	\$20.99	1,126	1,816	\$0.0116
18	\$24.00	1,637	2,768	\$0.0087

Notes:

- (1) The unit cost includes material cost and installation of 0-8 ft. in depth.
- (2) The sanitary sewer flow capacity was determined using Manning's Equation $V=(1.49 \cdot R^{2/3} \cdot S^{1/2})/n$ and the relationship $Q(\text{gpd}) = VA$.
- (3) The amount of Equivalent Residential Connections (ERC's) served by the ultimate capacity of the pipe is determined using 270 gpd/ERC. Also, the peak factor was determined using 2.5 persons/ERC and the equation $P.F.=(18+P^{1/2})/(4+P^{1/2})$.

SSU MARGIN RESERVE

Gravity Sewer Unit Cost and Available Services

Pipe Diameter (inches)	Unit Cost (\$/LF) (1)	Services (2)
8	\$12.28	493
	\$2.43	283
10	\$14.71	776
	\$2.20	383
12	\$16.91	1,159
	\$4.08	657
15	\$20.99	1,816
	\$3.01	952
18	\$24.00	2,768

= Incremental Cost and Service

Notes:

- (1) The unit cost includes material cost and installation of 0-8 ft. in depth.
- (2) The amount of Equivalent Residential Connections (ERC's) served by the ultimate capacity of the pipe is determined using 270 gpd/ERC. Also, the peak factor was determined using 2.5 persons/ERC and the equation $P.F. = (18 + P^{1/2}) / (4 + P^{1/2})$.
- (3) The sanitary sewer flow capacity was determined using Manning's Equation $(V = (1.49 * R^{2/3} * S^{1/2}) / n)$ and the relationship $Q(gpd) = VA$.

STEPS REQUIRED FOR WATERPLANT EXPANSION

1. In house review of records, capacity, customer commitments, etc. and the determination of the abilities and manpower to complete the work.
2. Depending on the project's scope, a request for a proposal, review of qualifications and selection of an outside consultant may be undertaken.
3. Determination of the needed capacity increase to meet the demands of the current and future customers via a planning document.
4. Study of the various raw water supply alternatives and the required treatment facilities, as applicable.
5. Selection of the raw water supply and treatment alternatives and selection of plant sites, as applicable, so as to ensure the highest quality product for the lowest customer price.
6. Determination of the source of supply and the sizing of treatment facilities taking into account economies of scale and used and useful considerations.
7. Preliminary planning level engineering estimate of planning, design permitting, construction and start up costs including overhead expenses, capitalized interest, etc.
8. If applicable, study of financing alternatives and determination of lowest cost financing alternatives.
9. If applicable, preliminary approval of financing alternative by financial

institution, local government, etc.

10. Consumptive Use Permit (CUP) application preparation with supporting documentation.
11. Water Management District (WMD) review and request for additional information.
12. Complete request for additional information.
13. WMD review and staff report.
14. WMD Board approval, noticing and CUP issuance.
15. Design wells and local government approval of wells.
16. Bidding, evaluation and award of well drilling contract.
17. Confirming funding for the well drilling contract.
18. Well construction and testing.
19. Water sampling and analysis.
20. Determination of water quality and its applicability to the treatment process.
At this point, project redesign may be necessary causing significant delays.
21. Water treatment facilities design completion.
22. Application for DEP construction permit.
23. DEP review and request of additional information.
24. Complete request for additional information.
25. DEP review and notice of intent.
26. DEP construction permit noticing and permit issuance if no objections.
27. Local government approvals: local jurisdictional agency's review and

permitting of construction; local zoning agency's review and approval of any requested zoning changes; and local planning agency's review for consistency with planning documents.

28. Final design completion and preparation of bidding documents.
29. Bidding, evaluation and award of construction contract.
30. Confirming funding for construction contract.
31. Water treatment plant construction and disinfection.
32. Substantial completion inspection and certification.
33. Punch list determination and completion of items.
34. Start up, operator training and operation and maintenance manual review.
35. Final walk through and inspection and completion of final punch list items.
36. Final payment to contractor and project close-out.
37. Final DEP certification and preparation of as built drawings.

DOMESTIC WASTEWATER FACILITIES

DEP 62-600.400(3)(b)2.

9/95

PART II: TREATMENT FACILITIES

2. The preliminary design report does not provide reasonable assurances that the proposed wastewater facility technology will function as intended at the design capacity requested by the permittee.

(c) When the permit includes the treatment facilities and reuse or disposal systems, different permitted capacities may be established for the treatment, reuse, and disposal systems.

(4) Sampling Points

(a) Provisions shall be made in the design for easy access points for the purpose of obtaining representative influent and effluent samples. These access points shall be dry points which can be reached safely.

(b) Provisions for flow measurements shall be in accordance with Chapter 62-601, F.A.C.

Specific Authority: 403.061, 403.087, F.S.

Law Implemented: 403.021, 403.061, 403.062, 403.086, 403.087, 403.088, F.S.

History: New 11-27-89, Amended 1-30-91, 6-8-93, Formerly 17-600.400.

62-600.405 Planning for Wastewater Facilities Expansion.

(1) The permittee shall provide for the timely planning, design, and construction of wastewater facilities necessary to provide proper treatment and reuse or disposal of domestic wastewater and management of domestic wastewater residuals.

(2) The permittee shall routinely compare flows being treated at the wastewater facilities with the permitted capacities of the treatment, residuals, reuse, and disposal facilities.

(3) When the three-month average daily flow for the most recent three consecutive months exceeds 50 percent of the permitted capacity of the treatment plant or reuse and disposal systems, the permittee shall submit to the Department a capacity analysis report.

(4) The initial capacity analysis report shall be submitted according to the following:

(a) For new or expanded wastewater facilities for which the Department received a complete construction permit application after July 1, 1991, the initial capacity analysis report shall be submitted within 180 days after the last day of the last month in the three-month period referenced in Rule 62-600.405(3), F.A.C.

(b) For wastewater facilities for which the Department received a complete construction permit application on or before July 1, 1991, the initial capacity analysis report shall be submitted when the next application for a permit to construct or operate wastewater facilities is submitted to the Department unless:

1. The three-month average daily flow for any three consecutive months during the period July 1, 1990, to June 30, 1991, exceeds 90 percent of the permitted

DOMESTIC WASTEWATER FACILITIES

DEP 62-600.405(4)(b)1.

9/95

PART II: TREATMENT FACILITIES

capacity. In such cases, the initial capacity analysis report shall be submitted to the Department no later than January 1, 1992.

2. The three-month average daily flow for any three consecutive months during the period July 1, 1990, to June 30, 1991, exceeds 75 percent of the permitted capacity. In such cases, the initial capacity analysis report shall be submitted to the Department no later than July 1, 1992.

(c) In no case shall the initial capacity analysis report be required to be submitted before July 1, 1991, or before the three-month average daily flow exceeds 50 percent of the permitted capacity of the treatment plant or reuse or disposal systems, as described in Rule 62-600.405(3), F.A.C.

(5) The permittee shall submit updated capacity analysis reports to the Department according to the following:

(a) If the initial capacity analysis report or an update of the capacity analysis report documents that the permitted capacity will not be equaled or exceeded for at least 10 years, an updated capacity analysis report shall be submitted to the Department at five-year intervals or at each time the permittee applies for an operation permit or renewal of an operation permit, whichever occurs first.

(b) If the initial capacity analysis report or an update of the capacity analysis report documents that the permitted capacity will be equaled or exceeded within the next 10 years, an updated capacity analysis shall be submitted to the Department annually.

(6) The capacity analysis report or an update of the capacity analysis report shall evaluate the capacity of the plant and contain data showing the permitted capacity; monthly average daily flows, three-month average daily flows, and annual average daily flows for the past 10 years or for the length of time the facility has been in operation, whichever is less; seasonal variations in flow; flow projections based on local population growth rates and water usage rates for at least the next 10 years; an estimate of the time required for the three-month average daily flow to reach the permitted capacity; recommendations for expansions; and a detailed schedule showing dates for planning, design, permit application submittal, start of construction, and placing new or expanded facilities into operation. The report shall update the flow-related and loading information contained in the preliminary design report submitted as part of the most recent permit application for the wastewater facilities pursuant to Rules 62-600.710 and 62-600.715, F.A.C.

(7) The capacity analysis report shall be signed by the permittee and shall be signed and sealed by a professional engineer registered in Florida.

(8) Documentation of timely planning, design, and construction of needed expansions shall be submitted according to the following schedule:

(a) If the initial capacity analysis report or an update of the capacity analysis report documents that the permitted capacity will be equaled or exceeded within the next five years, the report shall include a statement, signed and sealed by a professional engineer registered in Florida, that planning and preliminary design of the necessary expansion have been initiated.

DOMESTIC WASTEWATER FACILITIES

DEP 62-600.405(8)(b)

9/95

PART II: TREATMENT FACILITIES

(b) If the initial capacity analysis report or an update of the capacity analysis report documents that the permitted capacity will be equaled or exceeded within the next four years, the report shall include a statement, signed and sealed by an engineer registered in Florida, that plans and specifications for the necessary expansion are being prepared.

(c) If the initial capacity analysis report or an update of the capacity analysis report documents that the permitted capacity will be equaled or exceeded within the next three years, the permittee shall submit a complete construction permit application to the Department within 30 days of submittal of the initial capacity analysis report or the update of the capacity analysis report.

(d) If the initial capacity analysis report or an update of the capacity analysis report documents that the permitted capacity will be equaled or exceeded within the next six months, the permittee shall submit to the Department an application for an operation permit for the expanded facility. The operation permit application shall be submitted no later than the submittal of the initial capacity analysis report or the update of the capacity analysis report.

(9) If requested by the permittee, and if justified in the initial capacity analysis report or an update to the capacity analysis report based on design and construction schedules, population growth rates, flow projections, and the timing of new connections to the sewerage system such that adequate capacity will be available at the wastewater facility, the Secretary or Secretary's designee shall adjust the schedule specified in Rule 62-600.405(8), F.A.C.

Specific Authority: 403.061, 403.087, F.S.

Law Implemented: 403.021, 403.061, 403.086, 403.087, 403.088, 403.0881, ¹403.101, F.S.

History: New 1-30-91, Formerly 17-600.405.

62-600.410 Operation and Maintenance Requirements.

(1) All domestic wastewater treatment plants shall be operated and maintained in accordance with the applicable provisions of this chapter and so as to attain, at a minimum, the reclaimed water or effluent quality required by the operational criteria specified in this chapter, and to meet the appropriate domestic wastewater residuals management criteria specified in Chapters 62-2, 62-7, 62-640, and 62-701, F.A.C.

(2) All reuse and land application systems shall be operated and maintained in accordance with the applicable provisions of this chapter and the provisions of Chapter 62-610, F.A.C.

(3) All underground injection effluent disposal systems shall be operated and maintained in accordance with the applicable provisions of this chapter and the provisions of Chapter ⁸62-28, F.A.C.

(4) Wetlands application systems shall be operated and maintained in accordance with the applicable provisions of this chapter and the provisions of Chapter 62-611, F.A.C.