

GULF POWER COMPANY
TESTIMONY AND EXHIBITS OF
G. D. FONTAINE

GENERATING PERFORMANCE INCENTIVE FACTOR

RESULTS FOR

APRIL 1996 - SEPTEMBER 1996

Before

THE FLORIDA PUBLIC SERVICE COMMISSION

DOCKET NO. 960001-EI

- ACK _____
- AFA _____
- APP _____
- CAF _____
- CMF _____
- CMY _____
- ENG _____
- LEO _____
- LEI _____
- QIC _____
- PI _____
- SI _____
- W _____
- O' _____

Document #
12366-96
11/19/96

1 GULF POWER COMPANY
2 Before the Florida Public Service Commission
3 Direct Testimony of
4 G. D. Fontaine
5 Docket No. 960001-EI
6 Date of Filing November 19, 1996

7 Q. Please state your name, address and occupation.

8 A. My name is George D. Fontaine, my business address is
9 Post Office Box 1151, Pensacola, Florida 32520, and my
10 position is Performance Test Specialist for Gulf Power
11 Company.

12
13 Q. Please describe your educational and business
14 background.

15 A. I received my Bachelor of Mechanical Engineering Degree
16 from Auburn University in 1980. Following graduation,
17 I joined Gulf Power Company as an Associate Engineer at
18 the Scholz Electric Generating Plant, and as I
19 previously stated, my current position is Performance
20 Test Specialist. I am also a registered Professional
21 Engineer in the State of Florida.

22
23 Q. Mr. Fontaine, have you previously testified in this
24 Docket?

25 A. Yes, sir.

1 Q. Mr. Fontaine, what is the purpose of your testimony in
2 this proceeding?

3 A. The purpose of my testimony is to present GPIF results
4 for Gulf Power Company for the period of April 1, 1996,
5 through September 30, 1996.
6

7 Q. Mr. Fontaine, have you prepared an exhibit that
8 contains information to which you will refer in your
9 testimony?

10 A. Yes, Sir, I have prepared an exhibit consisting of five
11 schedules.
12

13 Q. Mr. Fontaine, was this exhibit prepared by you or under
14 your direction and supervision?

15 A. Yes, it was.
16

17 Counsel: We ask that Mr. Fontaine's exhibit be
18 marked for identification as exhibit _____ (GDF-1).
19

20 Q. Mr. Fontaine, before reviewing the GPIF Results for
21 Gulf's units, is there any information which has been
22 supplied to the Commission pertaining to this GPIF
23 period which requires amendment?

24 A. Yes, some corrections need to be made to the actual
25 unit performance data which was submitted monthly to

1 the Commission during this period. These corrections
2 are based on discoveries made during our final review
3 to determine the accuracy of this information prior to
4 this proceeding. The Actual Unit Performance Data
5 tables on pages 14 to 19 of Schedule 5 incorporate
6 these changes. The data contained on these tables is
7 the data upon which the GPIF calculation was made.
8

9 Q. Mr. Fontaine, would you now review the Company's
10 equivalent availability results for the period?

11 A. Actual equivalent availability and adjusted actual
12 equivalent availability figures for each of the
13 Company's GPIF units are shown on page 13 of Schedule
14 5. Pages 3 through 8 of Schedule 2 contain the
15 calculations for the adjusted actual equivalent
16 availabilities.

17 A calculation of GPIF availability points based on
18 these availabilities and the targets established by
19 Commission Order PSC-96-0353-FOF-EI is on page 9 of
20 Schedule 2. The results are: Crist 6, +10.00 points;
21 Crist 7, +10.00 points; Smith 1, +10.00 points; Smith
22 2, +10.00 points; Daniel 1, +10.00 points, and Daniel
23 2, -10.00 points.
24
25

1 Q. Mr. Fontaine, what were the heat rate results for the
2 period?

3 A. The detailed calculation of the actual average net
4 operating heat rates for the Company's GPIF units is on
5 pages 2 through 7 of Schedule 3. These heat rate
6 figures have not at this point been adjusted in
7 accordance with GPIF procedures for load and other
8 factors to the bases of their targets.

9 As was done for the prior GPIF periods, and as
10 indicated on pages 8 through 13 of Schedule 3, the
11 target setting equations were used to adjust actual
12 results to the target bases. These equations,
13 submitted in January 1996, are shown on page 15 of
14 Schedule 3.

15 As calculated on page 16 of Schedule 3, the
16 adjusted actual average net operating heat rates
17 correspond to GPIF unit heat rate points of: +10.00
18 for Crist 6, +10.00 for Crist 7; 0.00 for Smith 1, 0.00
19 for Smith 2; -6.13 for Daniel 1; and -10.00 for Daniel
20 2.

21
22
23
24
25

1 Q. Mr. Fontaine, what number of Company points were
2 achieved during the period, and what reward or penalty
3 is indicated by these points according to the GPIF
4 procedure?

5 A. Using the unit equivalent availability and heat rate
6 points previously mentioned, along with the appropriate
7 weighting factors, the Company points would be +0.95 as
8 indicated on page 2 of Schedule 4. This calculated to
9 a reward in the amount of \$82,198.

10

11 Q. Mr. Fontaine, would you please summarize your
12 testimony?

13 A. Yes, Sir. In view of the adjusted actual equivalent
14 availabilities, as shown on page 9 of Schedule 2, and
15 the adjusted actual average net operating heat rates
16 achieved, as shown on page 16 of Schedule 3, evidencing
17 the Company's performance for the period, Gulf
18 calculates a reward in the amount of \$82,198 as
19 provided for by the GPIF plan.

20

21 Q. Mr. Fontaine, does this conclude your testimony?

22 A. Yes, Sir.

23

24

25

EXHIBIT TO THE TESTIMONY OF
G. D. FONTAINE
IN FPSC DOCKET 960001-E1

1. CORRECTIONS TO REPORTED DATA FOR THE APRIL 1996 - SEPTEMBER 1996 PERIOD

Additions and Corrections to Outages Previously Reported
for the April 1996 - September 1996 Period

| Date | Unit | Change | Outage Type | Hours | MW | Description |
|-------|----------|--------|----------------|-------|------|----------------------|
| 05/96 | Daniel 1 | LR pf | PFOH | 116.9 | 41.3 | Incorrectly Reported |

Additions and Corrections to Heat Rate Previously Reported
for the April 1996 - September 1996 Period

| Date | Unit | Change | Description |
|-------|----------|-----------|----------------------|
| 07/96 | Daniel 1 | Oper MBtu | Incorrectly Reported |
| 04/96 | Daniel 2 | Oper MBtu | Incorrectly Reported |

II. CALCULATIONS OF EQUIVALENT AVAILABILITY POINTS

Comparison of Forecast and Actual Planned Outages
for April 1996 - September 1996

| Unit | Note | Forecast Planned Outage Schedule | Forecast Hours* | Actual Planned Outage Schedule | Actual Hours* |
|----------|------|-------------------------------------|--------------------|-----------------------------------|------------------|
| Crist 6 | 1 | 05/11/96 - 05/26/96 | 384.0 | 05/13/96 - 05/30/96 | 420.0 |
| Crist 7 | 2 | 02/03/96 - 04/28/96 | 671.0 | 02/06/96 - 05/13/96 | 1028.0 |
| Smith 1 | 3 | 04/06/96 - 04/21/96 | 383.0 | 04/05/96 - 04/20/96 | 354.5 |
| Daniel 1 | 4 | None | 0.0 | 09/27/96 - 10/07/96 | 84.4 |

* Planned outage hours in the April 1996 - September 1996 period only.

Notes:

1. This outage proceeded as scheduled with some work requiring more time to complete than originally scheduled.
2. This outage proceeded as scheduled and was extended to complete work not anticipated prior to the beginning of the outage.
3. This outage proceeded as scheduled.
4. This outage was brought forward and was extended because of worse than anticipated equipment condition.

Calculation of Actual Equivalent Availability
for April 1996 - September 1996
Based on Target Planned Outage Hours
Crist 6

| Results of Operations | | | | | | | |
|-----------------------|-------|-------|-------|-------|-------|-------|--------|
| | Apr | May | Jun | Jul | Aug | Sep | Total |
| FOH | 0.0 | 0.0 | 14.1 | 0.0 | 0.0 | 0.0 | 14.1 |
| EFOH | 19.6 | 4.2 | 7.7 | 0.0 | 1.9 | 0.4 | 33.8 |
| MOH | 10.1 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 10.1 |
| EMOH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| PH | 719.0 | 744.0 | 720.0 | 744.0 | 744.0 | 720.0 | 4391.0 |
| POH | 0.0 | 420.0 | 0.0 | 0.0 | 0.0 | 0.0 | 420.0 |
| RSH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

$$1. \text{ EUOR} = \frac{(\text{FOH} + \text{EFOH} + \text{MOH} + \text{EMOH})}{(\text{PH} - \text{POH} - \text{RSH})} = \frac{(14.1 + 33.8 + 10.1 + 0.0)}{(4391.0 - 420.0 - 0.0)}$$

$$\text{EUOR} = 0.0146$$

$$2. \text{ EA} = \left[1 - \frac{(\text{POH}^* + \text{EUOR} (\text{PH} - \text{POH}^* - \text{RSH}^*))}{\text{PH}} \right] \times 100$$

$$\text{Target POH}^* = 384.0$$

$$\text{Target RSH}^* = 0.0$$

$$\text{EA} = \left[1 - \frac{(384.0 + 0.0146 (4391.0 - 384.0 - 0.0))}{4391.0} \right] \times 100 = 89.9 \%$$

Note: Please refer to page 10 of this schedule for an explanation of symbols.

Calculation of Actual Equivalent Availability
for April 1996 - September 1996
Based on Target Planned Outage Hours
Crist 7

| Results of Operations | | | | | | | |
|-----------------------|-------|-------|-------|-------|-------|-------|--------|
| | Apr | May | Jun | Jul | Aug | Sep | Total |
| FOH | 0.0 | 3.1 | 49.0 | 118.5 | 8.8 | 33.0 | 212.4 |
| EFOH | 0.0 | 10.7 | 1.4 | 1.5 | 6.7 | 0.2 | 20.5 |
| MCH | 0.0 | 77.5 | 0.0 | 0.0 | 0.0 | 19.0 | 96.5 |
| EMOH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| PH | 719.0 | 744.0 | 720.0 | 744.0 | 744.0 | 720.0 | 4391.0 |
| POH | 719.0 | 309.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1028.0 |
| RSH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

$$1. \text{ EUOR} = \frac{(\text{FOH} + \text{EFOH} + \text{MCH} + \text{EMOH})}{(\text{PH} - \text{POH} - \text{RSH})} = \frac{(212.4 + 20.5 + 96.5 + 0.0)}{(4391.0 - 1028.0 - 0.0)}$$

$$\text{EUOR} = 0.0979$$

$$2. \text{ EA} = \left[1 - \frac{(\text{POH}^* + \text{EUOR} (\text{PH} - \text{POH}^* - \text{RSH}^*))}{\text{PH}} \right] \times 100$$

$$\text{Target POH}^* = 671.0$$

$$\text{Target RSH}^* = 0.0$$

$$\text{EA} = \left[1 - \frac{(671.0 + 0.0979 (4391.0 - 671.0 - 0.0))}{4391.0} \right] \times 100 = 76.4 \%$$

Note: Please refer to page 10 of this schedule for an explanation of symbols.

Calculation of Actual Equivalent Availability
for April 1996 - September 1996
Based on Target Planned Outage Hours
Smith 1

Results of Operations

| | Apr | May | Jun | Jul | Aug | Sep | Total |
|------|-------|-------|-------|-------|-------|-------|--------|
| FOH | 0.0 | 0.0 | 8.2 | 0.0 | 0.0 | 0.0 | 8.2 |
| EFOH | 1.6 | 0.0 | 0.2 | 0.0 | 1.3 | 0.4 | 3.5 |
| MOH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| EMOH | 0.0 | 0.0 | 0.0 | 0.0 | 1.4 | 0.0 | 1.4 |
| PH | 719.0 | 744.0 | 720.0 | 744.0 | 744.0 | 720.0 | 4391.0 |
| POH | 354.5 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 354.5 |
| RSH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

$$1. \text{ EUOR} = \frac{(\text{FOH} + \text{EFOH} + \text{MOH} + \text{EMOH})}{(\text{PH} - \text{POH} - \text{RSH})} = \frac{(8.2 + 3.5 + 0.0 + 1.4)}{(4391.0 - 354.5 - 0.0)}$$

$$\text{EUOR} = 0.0032$$

$$2. \text{ EA} = \left[1 - \frac{(\text{POH}^* + \text{EUOR} (\text{PH} - \text{POH}^* - \text{RSH}^*))}{\text{PH}} \right] \times 100$$

$$\text{Target POH}^* = 383.0$$

$$\text{Target RSH}^* = 0.0$$

$$\text{EA} = \left[1 - \frac{(383.0 + 0.0032 (4391.0 - 383.0 - 0.0))}{4391.0} \right] \times 100 = 91.0 \%$$

Note: Please refer to page 10 of this schedule for an explanation of symbols.

Calculation of Actual Equivalent Availability
for April 1996 - September 1996
Based on Target Planned Outage Hours
Smith 2

Results of Operations

| | Apr | May | Jun | Jul | Aug | Sep | Total |
|------|-------|-------|-------|-------|-------|-------|--------|
| FOH | 28.4 | 0.0 | 39.4 | 34.3 | 0.0 | 25.1 | 127.2 |
| EFOH | 2.7 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 2.7 |
| MCH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| EMOH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| PH | 719.0 | 744.0 | 720.0 | 744.0 | 744.0 | 720.0 | 4391.0 |
| POH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| RSH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

$$1. \text{ EUOR} = \frac{(\text{FOH} + \text{EFOH} + \text{MCH} + \text{EMOH})}{(\text{PH} - \text{POH} - \text{RSH})} = \frac{(127.2 + 2.7 + 0.0 + 0.0)}{(4391.0 - 0.0 - 0.0)}$$

$$\text{EUOR} = 0.0296$$

$$2. \text{ EA} = \left[1 - \frac{(\text{POH}^* + \text{EUOR} (\text{PH} - \text{POH}^* - \text{RSH}^*))}{\text{PH}} \right] \times 100$$

$$\text{Target POH}^* = 0.0$$

$$\text{Target RSH}^* = 0.0$$

$$\text{EA} = \left[1 - \frac{(0.0 + 0.0296 (4391.0 - 0.0 - 0.0))}{4391.0} \right] \times 100 = 97.0 \%$$

Note: Please refer to page 10 of this schedule for an explanation of symbols.

Calculation of Actual Equivalent Availability
for April 1996 - September 1996
Based on Target Planned Outage Hours
Daniel 1

| Results of Operations | | | | | | | |
|-----------------------|-------|-------|-------|-------|-------|-------|--------|
| | Apr | May | Jun | Jul | Aug | Sep | Total |
| FOH | 0.0 | 0.0 | 0.0 | 30.7 | 0.0 | 0.0 | 30.7 |
| EFOH | 30.9 | 11.2 | 8.5 | 0.5 | 0.1 | 56.6 | 107.8 |
| MOH | 25.2 | 0.0 | 36.4 | 14.9 | 0.0 | 0.0 | 76.5 |
| EMOH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| PH | 719.0 | 744.0 | 720.0 | 744.0 | 744.0 | 720.0 | 4391.0 |
| POH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 84.4 | 84.4 |
| RSH | 117.7 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 117.7 |

$$1. \text{ EUOR} = \frac{(\text{FOH} + \text{EFOH} + \text{MOH} + \text{EMOH})}{(\text{PH} - \text{POH} - \text{RSH})} = \frac{(30.7 + 107.8 + 76.5 + 0.0)}{(4391.0 - 84.4 - 117.7)}$$

$$\text{EUOR} = 0.0513$$

$$2. \text{ EA} = \left[1 - \frac{(\text{POH}^* + \text{EUOR} (\text{PH} - \text{POH}^* - \text{RSH}^*))}{\text{PH}} \right] \times 100$$

$$\text{Target POH}^* = 0.0$$

$$\text{Target RSH}^* = 0.0$$

$$\text{EA} = \left[1 - \frac{(0.0 + 0.0513 (4391.0 - 0.0 - 0.0))}{4391.0} \right] \times 100 = 94.9 \%$$

Note: Please refer to page 10 of this schedule for an explanation of symbols.

Calculation of Actual Equivalent Availability
for April 1996 - September 1996
Based on Target Planned Outage Hours
Daniel 2

Results of Operations

| | Apr | May | Jun | Jul | Aug | Sep | Total |
|------|-------|-------|-------|-------|-------|-------|--------|
| FOH | 0.0 | 0.0 | 1.7 | 15.2 | 30.6 | 0.0 | 47.5 |
| EFOH | 25.4 | 0.7 | 8.7 | 3.2 | 0.2 | 8.4 | 46.6 |
| MOH | 137.1 | 104.3 | 0.0 | 0.0 | 0.0 | 0.0 | 241.4 |
| EMOH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| PH | 719.0 | 744.0 | 720.0 | 744.0 | 744.0 | 720.0 | 4391.0 |
| POH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| RSH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

$$1. \text{ EUOR} = \frac{(\text{FOH} + \text{EFOH} + \text{MOH} + \text{EMOH})}{(\text{PH} - \text{POH} - \text{RSH})} = \frac{(47.5 + 46.6 + 241.4 + 0.0)}{(4391.0 - 0.0 - 0.0)}$$

$$\text{EUOR} = 0.0764$$

$$2. \text{ EA} = \left[1 - \frac{(\text{POH}^* + \text{EUOR} (\text{PH} - \text{POH}^* - \text{RSH}^*))}{\text{PH}} \right] \times 100$$

$$\text{Target POH}^* = 0.0$$

$$\text{Target RSH}^* = 0.0$$

$$\text{EA} = \left[1 - \frac{(0.0 + 0.0764 (4391.0 - 0.0 - 0.0))}{4391.0} \right] \times 100 = 92.4 \%$$

Note: Please refer to page 10 of this schedule for an explanation of symbols.

Calculation of Equivalent Availability Points
for April 1996 - September 1996

| (1) Unit | (2) Equivalent Availability Target* | (3) Actual Equivalent Availability Adjusted to Target Planned Outage Basis** | (4) Minimum or Maximum Attainable Equivalent Availability* | (5) Availability Points*** |
|-------------|--|--|---|----------------------------------|
| Crist 6 | 82.2 | 89.9 | 84.9 | 10.00 |
| Crist 7 | 71.6 | 76.4 | 75.5 | 10.00 |
| Smith 1 | 87.3 | 91.0 | 88.5 | 10.00 |
| Smith 2 | 91.7 | 97.0 | 94.2 | 10.00 |
| Daniel 1 | 92.8 | 94.9 | 94.9 | 10.00 |
| Daniel 2 | 96.7 | 92.4 | 95.2 | -10.00 |

* As appropriate from page 5, Schedule 3 of Exhibit to G. D. Fontaine's January 22, 1996 GP1F testimony in Docket 960001-E1.

** Refer to pages 3 through 8 of this schedule for calculations.

*** If (3) > (2)

$$\text{Availability Points} = \frac{(3) - (2)}{(4) - (2)} \times 10$$

If (3) < (2)

$$\text{Availability Points} = \frac{(3) - (2)}{(4) - (2)} \times -10$$

Summary of Equivalent Availability Symbols

EA - Equivalent Availability
POH - Planned Outage Hours
EUOR - Equivalent Unplanned Outage Rate
PH - Period Hours
FOH - Forced Outage Hours
EFOH - Equivalent Forced Outage Hours
MOH - Maintenance Outage Hours
EMOH - Equivalent Maintenance Outage Hours
RSH - Reserve Shutdown Hours

III. CALCULATION OF GPIF UNIT HEAT RATE POINTS

Calculation of Average Net Operating Heat Rate Points
for April 1996 - September 1996

Crist 6

| | Apr | May | Jun | Jul | Aug | Sep | Total |
|---------------------------------|-----------|----------|-----------|-----------|-----------|-----------|-----------|
| Pounds Coal (000's) | 99907.3 | 45604.3 | 103935.9 | 121043.8 | 112721.7 | 110486.6 | 593699.6 |
| BTU/Lb* | 12089.2 | 12215.7 | 12069.0 | 11944.4 | 11961.5 | 11978.6 | 12021.0 |
| Coal, MMBTU | 1207799.3 | 557088.4 | 1254402.4 | 1445795.6 | 1348320.6 | 1323474.8 | 7136881.1 |
| Oil, MMBTU | 1065.0 | 371.8 | 1498.8 | 792.3 | 1526.3 | 1944.4 | 7198.6 |
| Gas, MMBTU | 1121.0 | 2146.0 | 1080.0 | 0.0 | 0.0 | 0.0 | 4347.0 |
| Startup, MMBTU ** | 0.0 | -4040.0 | 0.0 | 0.0 | 0.0 | 0.0 | -4040.0 |
| Total Fuel Consumption, MMBTU | 1209985.3 | 555566.2 | 1256981.2 | 1446587.9 | 1349846.9 | 1325419.2 | 7144386.7 |
| Net MWh Generation*** | 111026 | 51752 | 118762 | 137421 | 126993 | 125063 | 671017 |
| Average Net Operating Heat Rate | 10898 | 10735 | 10584 | 10527 | 10629 | 10598 | 10647 |

* Weighted average of daily as-burned BTU/Lb values.

** Based on number of unit starts after unit off-line 24 hours or more.

*** Not reduced by off-line station service.

Calculation of Average Net Operating Heat Rate Points
for April 1996 - September 1996

Crist 7

| | Apr | May | Jun | Jul | Aug | Sep | Total |
|---------------------------------|-----|-----------|-----------|-----------|-----------|-----------|-----------|
| Pounds Coal (000's) | 0.0 | 80606.4 | 171077.5 | 179314.0 | 200257.5 | 177225.9 | 808481.3 |
| BTU/Lb* | 0.0 | 12301.1 | 12008.2 | 11979.0 | 11973.4 | 11976.5 | 12015.4 |
| Coal, MMBTU | 0.0 | 991547.4 | 2054332.8 | 2148002.4 | 2397763.2 | 2122546.0 | 9714191.8 |
| Oil, MMBTU | 0.0 | 2779.7 | 1207.6 | 845.6 | 558.6 | 1382.5 | 6774.0 |
| Gas, MMBTU | 0.0 | 17180.0 | 4167.0 | 3217.0 | 1647.0 | 2603.0 | 28814.0 |
| Startup, MMBTU ** | 0.0 | -4512.0 | -2256.0 | -2256.0 | 0.0 | -2256.0 | -11280.0 |
| Total Fuel Consumption, MMBTU | 0.0 | 1006995.1 | 2057451.4 | 2149809.0 | 2399968.8 | 2124275.5 | 9738499.8 |
| Net MWh Generation*** | 0 | 95968 | 199082 | 206763 | 230728 | 203282 | 935823 |
| Average Net Operating Heat Rate | --- | 10493 | 10335 | 10397 | 10402 | 10450 | 10406 |

* Weighted average of daily as-burned BTU/Lb values.

** Based on number of unit starts after unit off-line 24 hours or more.

*** Not reduced by off-line station service.

Calculation of Average Net Operating Heat Rate Points
for April 1996 - September 1996

Smith 1

| | Apr | May | Jun | Jul | Aug | Sep | Total |
|---------------------------------|----------|-----------|-----------|-----------|-----------|-----------|-----------|
| Pounds Coal (000's) | 47324.6 | 99027.7 | 95104.0 | 102779.8 | 97864.2 | 88588.2 | 530688.5 |
| BTU/Lb* | 11635.0 | 11447.7 | 11503.0 | 11534.5 | 11777.0 | 11899.3 | 11627.2 |
| Coal, MMBTU | 550621.7 | 1133639.4 | 1093981.3 | 1185513.6 | 1152546.7 | 1054137.6 | 6170440.3 |
| Oil, MMBTU | 1522.5 | 295.8 | 847.5 | 103.0 | 311.1 | 298.1 | 3378.0 |
| Gas, MMBTU | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| Startup, MMBTU ** | -964.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | -964.0 |
| Total Fuel Consumption, MMBTU | 551180.2 | 1133935.2 | 1094828.8 | 1185616.6 | 1152857.8 | 1054435.7 | 6172854.3 |
| Net MWh Generation*** | 53346 | 111049 | 106893 | 116223 | 112275 | 103062 | 602848 |
| Average Net Operating Heat Rate | 10332 | 10211 | 10242 | 10201 | 10268 | 10231 | 10239 |

- * Weighted average of daily as-burned BTU/Lb values.
- ** Based on number of unit starts after unit off-line 24 hours or more.
- *** Not reduced by off-line station service.

Calculation of Average Net Operating Heat Rate Points
for April 1996 - September 1996

Smith 2

| | Apr | May | Jun | Jul | Aug | Sep | Total |
|---------------------------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| Pounds Coal (000's) | 108415.5 | 113383.7 | 103976.5 | 114604.5 | 115389.7 | 97503.6 | 653273.5 |
| BTU/Lb* | 11499.5 | 11385.0 | 11398.3 | 11454.9 | 11649.0 | 11794.1 | 11526.1 |
| Coal, MMBTU | 1246724.0 | 1290873.4 | 1185155.3 | 1312783.1 | 1344174.6 | 1149967.2 | 7529677.6 |
| Oil, MMBTU | 1199.0 | 377.4 | 1125.8 | 1924.3 | 372.2 | 1435.1 | 6433.8 |
| Gas, MMBTU | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| Startup, MMBTU ** | -1190.0 | 0.0 | -1190.0 | 0.0 | 0.0 | -1190.0 | -3570.0 |
| Total Fuel Consumption, MMBTU | 1246733.0 | 1291250.8 | 1185091.1 | 1314707.4 | 1344546.8 | 1150212.3 | 7532541.4 |
| Net MWh Generation*** | 120132 | 126132 | 115362 | 126350 | 128001 | 110608 | 726585 |
| Average Net Operating Heat Rate | 10378 | 10237 | 10273 | 10405 | 10504 | 10399 | 10367 |

* Weighted average of daily as-burned BTU/Lb values.

** Based on number of unit starts after unit off-line 24 hours or more.

*** Not reduced by off-line station service.

Calculation of Average Net Operating Heat Rate Points
for April 1996 - September 1996

Daniel 1

| | Apr | May | Jun | Jul | Aug | Sep | Total |
|---------------------------------|-----------|-----------|-----------|-----------|-----------|-----------|------------|
| Pounds Coal (000's) | 238480.3 | 318111.5 | 262824.0 | 232323.3 | 237073.2 | 238434.6 | 1527246.9 |
| BTU/Lb* | 9306.3 | 9309.4 | 9822.6 | 11232.5 | 11250.2 | 9901.4 | 10083.5 |
| Coal, MMBTU | 2219369.2 | 2961427.2 | 2581615.0 | 2609571.5 | 2667120.9 | 2360836.3 | 15399940.1 |
| Oil, MMBTU | 3803.6 | 14.2 | 457.9 | 4658.0 | 4.4 | 156.4 | 9094.5 |
| Gas, MMBTU | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| Startup, MMBTU ** | -2388.7 | 0.0 | 0.0 | -4777.4 | 0.0 | 0.0 | -7166.1 |
| Total Fuel Consumption, MMBTU | 2220784.1 | 2961441.4 | 2582072.9 | 2609452.1 | 2667125.3 | 2360992.7 | 15401868.5 |
| Net MWh Generation*** | 212538 | 282306 | 246307 | 257177 | 256653 | 221119 | 1476100 |
| Average Net Operating Heat Rate | 10449 | 10490 | 10483 | 10147 | 10392 | 10677 | 10434 |

* Weighted average of daily as-burned BTU/Lb values.

** Based on number of unit starts after unit off-line 24 hours or more.

*** Not reduced by off-line station service.

Calculation of Average Net Operating Heat Rate Points
for April 1996 - September 1996

Daniel 2

| | Apr | May | Jun | Jul | Aug | Sep | Total |
|---------------------------------|-----------|-----------|-----------|-----------|-----------|-----------|------------|
| Pounds Coal (000's) | 240979.6 | 265982.0 | 248534.7 | 227852.0 | 207560.5 | 285403.1 | 1176311.9 |
| BTU/Lb* | 9314.1 | 9309.3 | 9838.4 | 11233.6 | 11212.8 | 9685.5 | 10036.5 |
| Coal, MMBTU | 2244508.1 | 2476106.2 | 2445183.8 | 2559598.2 | 2327334.4 | 2764271.7 | 14817002.4 |
| Oil, MMBTU | 12520.9 | 11764.2 | 1575.4 | 5889.9 | 1391.8 | 3.5 | 33145.7 |
| Gas, MMBTU | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| Startup, MMBTU ** | -2388.7 | -4777.4 | 0.0 | 0.0 | -2388.7 | 0.0 | -9554.8 |
| Total Fuel Consumption, MMBTU | 2254640.3 | 2483093.0 | 2446759.2 | 2565488.1 | 2326337.5 | 2764275.2 | 14840593.3 |
| Net MWh Generation*** | 213411 | 236237 | 232659 | 247472 | 222964 | 258132 | 1410875 |
| Average Net Operating Heat Rate | 10565 | 10511 | 10517 | 10367 | 10434 | 10709 | 10519 |

* Weighted average of daily as-burned BTU/Lb values.
** Based on number of unit starts after unit off-line 24 hours or more.
*** Not reduced by off-line station service.

Calculation of Average Net Operating Heat Rate
for April 1996 - September 1996
Adjusted to Target Basis Using Heat Rate
Equations Filed January 22, 1996

Crist 6

| | Apr | May | Jun | Jul | Aug | Sep | Apr - Sep |
|---|--------|-------|--------|--------|--------|--------|-----------|
| 1. Target Heat Rate* | 10511 | 10845 | 10507 | 10670 | 10640 | 10535 | |
| 2. Target Heat Rate at Actual Conditions** | 10905 | 11108 | 11039 | 10991 | 11139 | 11008 | |
| 3. Adjustment to Actual Heat Rate (1-2) | -394 | -263 | -532 | -321 | -499 | -473 | |
| 4. Actual Heat Rate (Page 2 of Sched. 3) | 10898 | 10735 | 10584 | 10527 | 10629 | 10598 | |
| 5. Adjusted Actual Heat Rate (4+3) | 10504 | 10472 | 10052 | 10206 | 10130 | 10125 | |
| 6. Net MWH Generation | 111026 | 51752 | 118762 | 137421 | 126993 | 125063 | |
| 7. Adjusted Actual Heat Rate for April 1996 - September 1996 = $(\Sigma(5+6)/\Sigma 6)$ | | | | | | | 10219 |

* From page 18, schedule 3 of Exhibit to G. D. Fontaine's January 22, 1996 GPIF testimony in Docket 960001-E1.

** Based on target heat rate equation from page 2, Schedule 1 of above mentioned filing using actual rather than forecast variable values. The equations are also shown for convenience on page 15 of this schedule.

Calculation of Average Net Operating Heat Rate
for April 1996 - September 1996
Adjusted to Target Basis Using Heat Rate
Equations Filed January 22, 1996

Crist 7

| | Apr | May | Jun | Jul | Aug | Sep | Apr - Sep |
|---|-------|-------|--------|--------|--------|--------|-----------|
| 1. Target Heat Rate* | 10523 | 10745 | 10376 | 10619 | 10577 | 10285 | |
| 2. Target Heat Rate at Actual Conditions** | 10523 | 10969 | 10722 | 10738 | 10795 | 10578 | |
| 3. Adjustment to Actual Heat Rate (1-2) | 0 | -224 | -346 | -119 | -218 | -293 | |
| 4. Actual Heat Rate (Page 3 of Sched. 3) | 0 | 10493 | 10335 | 10397 | 10402 | 10450 | |
| 5. Adjusted Actual Heat Rate (4+3) | 0 | 10269 | 9989 | 10278 | 10184 | 10157 | |
| 6. Net MWh Generation | 0 | 95968 | 199082 | 206763 | 230728 | 203282 | |
| 7. Adjusted Actual Heat Rate for April 1996 - September 1996 $= (\Sigma(5*6) / \Sigma 6)$ | | | | | | | 10166 |

* From page 19, schedule 3 of Exhibit to G. D. Fontaine's January 22, 1996 GPIF testimony in Docket 960001-E1.

** Based on target heat rate equation from page 2, Schedule 1 of above mentioned filing using actual rather than forecast variable values. The equations are also shown for convenience on page 15 of this schedule.

Calculation of Average Net Operating Heat Rate
for April 1996 - September 1996
Adjusted to Target Basis Using Heat Rate
Equations Filed January 22, 1996

Smith 1

| | Apr | May | Jun | Jul | Aug | Sep | Apr - Sep |
|---|-------|--------|--------|--------|--------|--------|-----------|
| 1. Target Heat Rate* | 10253 | 10272 | 10202 | 10199 | 10189 | 10228 | |
| 2. Target Heat Rate at Actual Conditions** | 10202 | 10190 | 10187 | 10165 | 10184 | 10215 | |
| 3. Adjustment to Actual Heat Rate (1-2) | 51 | 82 | 15 | 34 | 5 | 13 | |
| 4. Actual Heat Rate (Page 4 of Sched. 3) | 10332 | 10211 | 10242 | 10201 | 10268 | 10231 | |
| 5. Adjusted Actual Heat Rate (4+3) | 10383 | 10293 | 10257 | 10235 | 10273 | 10244 | |
| 6. Net MWh Generation | 53346 | 111049 | 106893 | 116223 | 112275 | 103062 | |
| 7. Adjusted Actual Heat Rate for April 1996 - September 1996 $= (\Sigma(5*6) / \Sigma 6)$ | | | | | | | 10271 |

* From page 20, schedule 3 of Exhibit to G. D. Fontaine's January 22, 1996 GPIF testimony in Docket 960001-E1.

** Based on target heat rate equation from page 2, Schedule 1 of above mentioned filing using actual rather than forecast variable values. The equations are also shown for convenience on page 15 of this schedule.

Calculation of Average Net Operating Heat Rate
for April 1996 - September 1996
Adjusted to Target Basis Using Heat Rate
Equations Filed January 22, 1996

Smith 2

| | Apr | May | Jun | Jul | Aug | Sep | Apr - Sep |
|---|--------|--------|--------|--------|--------|--------|-----------|
| 1. Target Heat Rate* | 10587 | 10415 | 10598 | 10314 | 10301 | 10361 | |
| 2. Target Heat Rate at Actual Conditions** | 10425 | 10283 | 10535 | 10254 | 10274 | 10322 | |
| 3. Adjustment to Actual Heat Rate (1-2) | 162 | 132 | 63 | 60 | 27 | 39 | |
| 4. Actual Heat Rate (Page 5 of Sched. 3) | 10378 | 10237 | 10273 | 10405 | 10504 | 10399 | |
| 5. Adjusted Actual Heat Rate (4+3) | 10540 | 10369 | 10336 | 10465 | 10531 | 10438 | |
| 6. Net MWH Generation | 120132 | 126132 | 115362 | 126350 | 128001 | 110608 | |
| 7. Adjusted Actual Heat Rate for April 1996 - September 1996 = $(\Sigma(5+6)/\Sigma 6)$ | | | | | | | 10448 |

* From page 21, schedule 3 of Exhibit to G. D. Fontaine's January 22, 1996 GPIF testimony in Docket 960001-E1.

** Based on target heat rate equation from page 2, Schedule 1 of above mentioned filing using actual rather than forecast variable values. The equations are also shown for convenience on page 15 of this schedule.

Calculation of Average Net Operating Heat Rate
for April 1996 - September 1996
Adjusted to Target Basis Using Heat Rate
Equations Filed January 22, 1996

Daniel 1

| | Apr | May | Jun | Jul | Aug | Sep | Apr - Sep |
|---|--------|--------|--------|--------|--------|--------|-----------|
| 1. Target Heat Rate* | 10216 | 10991 | 10658 | 10416 | 10447 | 10670 | |
| 2. Target Heat Rate at Actual Conditions** | 10390 | 10296 | 10316 | 10135 | 10163 | 10553 | |
| 3. Adjustment to Actual Heat Rate (1-2) | -174 | 695 | 342 | 281 | 284 | 117 | |
| 4. Actual Heat Rate (Page 6 of Sched. 3) | 10449 | 10490 | 10483 | 10147 | 10392 | 10677 | |
| 5. Adjusted Actual Heat Rate (4+3) | 10275 | 11185 | 10825 | 10428 | 10676 | 10794 | |
| 6. Net MWh Generation | 212538 | 282306 | 246307 | 257177 | 256653 | 221119 | |
| 7. Adjusted Actual Heat Rate for April 1996 - September 1996 = $(\Sigma(5+6)/\Sigma 6)$ | | | | | | | 10715 |

* From page 22, schedule 3 of Exhibit to G. D. Fontaine's January 22, 1996
GP1F testimony in Docket 960001-E1.

** Based on target heat rate equation from page 2, Schedule 1 of above mentioned
filing using actual rather than forecast variable values. The equations are
also shown for convenience on page 15 of this schedule.

Calculation of Average Net Operating Heat Rate
for April 1996 - September 1996
Adjusted to Target Basis Using Heat Rate
Equations Filed January 22, 1996

Daniel 2

| | Apr | May | Jun | Jul | Aug | Sep | Apr - Sep |
|---|--------|--------|--------|--------|--------|--------|-----------|
| 1. Target Heat Rate* | 9942 | 10592 | 10272 | 10276 | 10352 | 10565 | |
| 2. Target Heat Rate at Actual Conditions** | 10016 | 9937 | 10080 | 10143 | 10295 | 10183 | |
| 3. Adjustment to Actual Heat Rate (1-2) | -74 | 655 | 192 | 133 | 57 | 382 | |
| 4. Actual Heat Rate (Page 7 of Sched. 3) | 10565 | 10511 | 10517 | 10367 | 10434 | 10709 | |
| 5. Adjusted Actual Heat Rate (4+3) | 10491 | 11166 | 10709 | 10500 | 10491 | 11091 | |
| 6. Net MWh Generation | 213411 | 236237 | 232659 | 247472 | 222964 | 258132 | |
| 7. Adjusted Actual Heat Rate for April 1996 - September 1996 = $(\Sigma(5+6)/\Sigma 6)$ | | | | | | | 10751 |

* From page 23, schedule 3 of Exhibit to G. D. Fontaine's January 22, 1996 GPIF testimony in Docket 960001-E1.

** Based on target heat rate equation from page 2, Schedule 1 of above mentioned filing using actual rather than forecast variable values. The equations are also shown for convenience on page 15 of this schedule.

Actual Values of
Target Heat Rate Equation Parameters
for April 1996 - September 1996

| | Apr | May | Jun | Jul | Aug | Sep |
|-------------------------|----------|----------|----------|----------|----------|----------|
| Crist 6 | | | | | | |
| AKW * 10 ⁺³ | 156.6 | 159.7 | 168.2 | 184.7 | 170.7 | 173.7 |
| LSRF * 10 ⁺⁶ | 27866.3 | 29019.1 | 32111.9 | 39127.8 | 33527.2 | 36372.0 |
| Crist 7 | | | | | | |
| AKW * 10 ⁺³ | 0.0 | 270.8 | 296.7 | 330.6 | 313.8 | 304.3 |
| LSRF * 10 ⁺⁶ | 0.0 | 85344.3 | 101510.0 | 125003.9 | 114627.3 | 110237.4 |
| Smith 1 | | | | | | |
| AKW * 10 ⁺³ | 146.4 | 149.2 | 150.2 | 156.2 | 150.9 | 143.1 |
| LSRF * 10 ⁺⁶ | 22171.4 | 22771.1 | 23048.5 | 24526.5 | 23123.7 | 21348.7 |
| Smith 2 | | | | | | |
| AKW * 10 ⁺³ | 174.0 | 169.5 | 169.5 | 178.0 | 172.0 | 159.2 |
| LSRF * 10 ⁺⁶ | 31130.2 | 29838.7 | 29861.4 | 32219.6 | 30511.0 | 27217.0 |
| Daniel 1 | | | | | | |
| AKW * 10 ⁺³ | 368.9 | 379.4 | 360.3 | 368.2 | 345.0 | 347.9 |
| LSRF * 10 ⁺⁶ | 144093.6 | 154596.3 | 144161.9 | 158417.1 | 145003.5 | 125273.0 |
| Daniel 2 | | | | | | |
| AKW * 10 ⁺³ | 366.7 | 369.3 | 323.9 | 339.6 | 312.5 | 358.5 |
| LSRF * 10 ⁺⁶ | 149731.4 | 155349.3 | 125865.4 | 140316.2 | 122699.8 | 145614.9 |

Target Heat Rate Equations

Crist 6 ANOHR = $10^6 / AKW * [290.50 + 38.19 * MAY + 44.09 * JUN + 67.96 * JUL + 66.17 * AUG + 49.61 * SEP - 32.60 * OCT]$
+ 9,050

Crist 7 ANOHR = $10^6 / AKW * [412.46 + 60.48 * MAY + 32.35 * JUN + 86.25 * JUL + 60.78 * AUG - 35.01 * OCT]$
+ 9,223

Smith 1 ANOHR = $10^6 / AKW * [85.72 + 13.65 * JAN]$
+ 9,616

Smith 2 ANOHR = $10^6 / AKW * [101.34 + 27.35 * APR + 42.71 * JUN]$
+ 9,685

Daniel 1 ANOHR = $10^6 / AKW * [-195.70 - 65.61 * JAN]$
+ 13,416 - 0.00639 * LSRF / AKW

Daniel 2 ANOHR = $10^6 / AKW * [-192.43 + 68.36 * JUL + 82.43 * AUG + 58.95 * SEP - 48.31 * OCT]$
+ 13,293 - 0.00674 * LSRF / AKW

Where:

| | |
|-------|---|
| ANOHR | Average Net Operating Heat Rate, BTU/KWH |
| AKW | Average Kilowatt Load, KW |
| LSRF | Load Square Range Factor, KW ² |
| JAN | January, 0 if not January, 1 if January |
| FEB | February, 0 if not February, 1 if February |
| MAR | March, 0 if not March, 1 if March |
| APR | April, 0 if not April, 1 if April |
| MAY | May, 0 if not May, 1 if May |
| JUN | June, 0 if not June, 1 if June |
| JUL | July, 0 if not July, 1 if July |
| AUG | August, 0 if not August, 1 if August |
| SEP | September, 0 if not September, 1 if September |
| OCT | October, 0 if not October, 1 if October |
| NOV | November, 0 if not November, 1 if November |

Calculation of Heat Rate Points
for April 1996 - September 1996

| (1) Unit | (2) Actual Average Average Net Operating Heat Rate Target* | (3) Net Operating Heat Rate Adjusted to Target Basis** | (4) Minimum Attainable Heat Rate* | (5) Heat Rate Points*** |
|-------------|--|---|--|-------------------------------|
| Crist 6 | 10597 | 10219 | 10279 | 10.00 |
| Crist 7 | 10500 | 10166 | 10185 | 10.00 |
| Smith 1 | 10219 | 10271 | 9912 | 0.00 |
| Smith 2 | 10422 | 10448 | 10109 | 0.00 |
| Daniel 1 | 10493 | 10715 | 10178 | -6.13 |
| Daniel 2 | 10280 | 10751 | 9972 | -10.00 |

* From page 5, Schedule 3 of Exhibit to G. D. Fontaine's
January 22, 1996 GPIF testimony in Docket 960001-E1.

** Refer to pages 8 through 13 of this schedule for calculation.

*** If $[(2) - 75] \leq (3) \leq [(2) + 75]$ then points = 0

If $[(2) - (3) - 75] > 0$ then points = $\frac{(2) - (3) - 75}{(2) - (4) - 75} \times 10$

If $[(2) - (3) + 75] < 0$ then points = $\frac{(2) - (3) + 75}{(2) - (4) - 75} \times 10$

IV. CALCULATION OF COMPANY GPIF POINTS AND REWARD/PENALTY

Calculation of Heat Rate Points
 GPIF Points and Reward or Penalty
 for April 1996 - September 1996

| Unit | Availability Points | Availability* Weighting Factor | Heat Rate Points | Heat Rate* Weighting Factor |
|----------|---------------------|--------------------------------|------------------|-----------------------------|
| Crist 6 | 10.00 | 0.007 | 10.00 | 0.145 |
| Crist 7 | 10.00 | 0.012 | 10.00 | 0.227 |
| Smith 1 | 10.00 | 0.007 | 0.00 | 0.085 |
| Smith 2 | 10.00 | 0.008 | 0.00 | 0.097 |
| Daniel 1 | 10.00 | 0.015 | -6.13 | 0.180 |
| Daniel 2 | -10.00 | 0.017 | -10.00 | 0.199 |

Company GPIF Points = + 10.00 * 0.007 + 10.00 * 0.145
 + 10.00 * 0.012 + 10.00 * 0.227
 + 10.00 * 0.007 + 0.00 * 0.085
 + 10.00 * 0.008 + 0.00 * 0.097
 + 10.00 * 0.015 - 6.13 * 0.180
 - 10.00 * 0.017 - 10.00 * 0.199
 0.95

Company reward/penalty = 0.95 points * \$86525 per point
 = \$82,198

* From page 5, Schedule 3 of Exhibit to G. D. Fontaine's January 22, 1996 GPIF testimony in Docket 960001-E1.

V. GPIF MINIMUM FILING REQUIREMENTS FOR THE APRIL 1996 - SEPTEMBER 1996 PERIOD

| CONTENTS | SCHEDULE 5 PAGE |
|--|--------------------|
| GPIF Reward/Penalty Table (Actual) | 3 |
| GPIF Calculation of Maximum Allowed Incentive Dollars (Actual) | 4 |
| Calculation of System Actual GPIF Points | 5 |
| Generating Performance Incentive Points Table | 6 - 11 |
| GPIF Unit Performance Summary | 12 |
| Actual Unit Performance Data | 13 |
| Historic Unit Performance Data | 14 - 19 |
| Planned Outage Schedules (Actual) | 20 |

Generating Performance Incentive Factor

Actual Reward/Penalty Table

Gulf Power Company

Period of: April 1996 - September 1996

| Generating Performance Incentive Factor Points | Fuel Saving/Loss (\$000) | Generating Performance Incentive Factor (\$000) |
|--|---------------------------------------|---|
| | Maximum Attainable Fuel Savings | Maximum Incentive Dollars Allowed by Commission During Period (Reward) |
| + 10 | 3246 | 865 |
| + 9 | 2921 | 779 |
| + 8 | 2597 | 692 |
| + 7 | 2272 | 606 |
| + 6 | 1948 | 519 |
| + 5 | 1623 | 433 |
| + 4 | 1298 | 346 |
| + 3 | 974 | 260 |
| + 2 | 649 | 173 |
| + 1 | 325 | 87 |
| 0 | 0 | 0 |
| - 1 | -339 | -87 |
| - 2 | -677 | -173 |
| - 3 | -1016 | -260 |
| - 4 | -1354 | -346 |
| - 5 | -1693 | -433 |
| - 6 | -2031 | -519 |
| - 7 | -2370 | -606 |
| - 8 | -2708 | -692 |
| - 9 | -3047 | -779 |
| - 10 | -3385 | -865 |
| | Minimum Attainable Fuel Loss | Maximum Incentive Dollars Allowed by Commission During Period (Penalty) |

Issued by: T. J. Bowden

Page 3 of 20
Schedule 5Filed: November 19, 1996
Suspended:
Effective: November 17, 1996
Docket No.: 960001-E1
Order No.:

Generating Performance Incentive Factor
 Calculation of Maximum Allowed Incentive Dollars
 Actual
 Gulf Power Company
 Period of: April 1996 - September 1996

| | | |
|---------|--|---------------|
| Line 1 | Beginning of Period Balance of Common Equity | \$435,199,552 |
| | End of Month Balance of Common Equity: | |
| Line 2 | Month of Apr '96 | \$422,219,943 |
| Line 3 | Month of May '96 | \$429,290,526 |
| Line 4 | Month of Jun '96 | \$435,550,705 |
| Line 5 | Month of Jul '96 | \$430,429,125 |
| Line 6 | Month of Aug '96 | \$440,291,768 |
| Line 7 | Month of Sep '96 | \$446,672,332 |
| Line 8 | Average Common Equity for the Period (sum of line 1 through line 7 divided by 7) | \$434,207,707 |
| Line 9 | 25 Basis Points | 0.0025 |
| Line 10 | Revenue Expansion Factor | 60.4524% |
| Line 11 | Maximum Allowed Incentive Dollars (line 8 multiplied by line 9 divided by line 10 multiplied by 0.5) | \$897,830 |
| Line 12 | Jurisdictional Sales (KWH) | 4,765,989,890 |
| Line 13 | Total Territorial Sales (KWH) | 4,945,466,890 |
| Line 14 | Jurisdictional Separation Factor (line 12 divided by line 13) | 96.3709% |
| Line 15 | Maximum Allowed Jurisdictional Incentive Dollars (line 11 multiplied by line 14) | \$865,247 |

Issued by: T. J. Bowden

Page 4 of 20
 Schedule 5

Filed: November 19, 1996
 Suspended:
 Effective: November 19, 1996
 Docket No.: 960001-E1
 Order No.:

Calculation of System Actual GPIF Points

Gulf Power Company

Period of: April 1996 - September 1996

| Plant & Unit | Performance Indicator (EAF or ANOHR) | Weighting Factor | Unit Points | Weighted Unit Points |
|-----------------------|--------------------------------------|------------------|-------------|----------------------|
| Crist 6 | EAF1 | 0.7% | 10.00 | 0.070 |
| Crist 6 | ANOHR1 | 14.5% | 10.00 | 1.450 |
| Crist 7 | EAF2 | 1.2% | 10.00 | 0.120 |
| Crist 7 | ANOHR2 | 22.7% | 10.00 | 2.270 |
| Smith 1 | EAF3 | 0.7% | 10.00 | 0.070 |
| Smith 1 | ANOHR3 | 8.5% | 0.00 | 0.000 |
| Smith 2 | EAF4 | 0.8% | 10.00 | 0.080 |
| Smith 2 | ANOHR4 | 9.7% | 0.00 | 0.000 |
| Daniel 1 | EAF5 | 1.5% | 10.00 | 0.150 |
| Daniel 1 | ANOHR5 | 18.0% | -6.13 | -1.103 |
| Daniel 2 | EAF6 | 1.7% | -10.00 | -0.170 |
| Daniel 2 | ANOHR6 | 19.9% | -10.00 | -1.990 |
| Gulf Power GPIF Total | | 99.9% | | 0.95 |

Issued by: T. J. Bowden

Page 5 of 20
Schedule 5Filed: November 19, 1996
Suspended:
Effective: November 19, 1996
Docket No.: 960001-EI
Order No.:

Generating Performance Incentive Points Table

Gulf Power Company

Period of: April 1996 - September 1996

Crist 6

| Equivalent Availability Points | Fuel Savings/Loss (\$000) | Adjusted Actual Equivalent Availability | Average Heat Rate Points | Fuel Savings/Loss (\$000) | Adjusted Actual Heat Rate |
|--------------------------------|---------------------------|---|--------------------------|---------------------------|---------------------------|
| + 10 | 22 | 84.90 | + 10 | 471 | 10,279 |
| + 9 | 20 | 84.63 | + 9 | 424 | 10,303 |
| + 8 | 18 | 84.36 | + 8 | 377 | 10,328 |
| + 7 | 15 | 84.09 | + 7 | 330 | 10,352 |
| + 6 | 13 | 83.82 | + 6 | 283 | 10,376 |
| + 5 | 11 | 83.55 | + 5 | 236 | 10,401 |
| + 4 | 9 | 83.28 | + 4 | 188 | 10,425 |
| + 3 | 7 | 83.01 | + 3 | 141 | 10,449 |
| + 2 | 4 | 82.74 | + 2 | 94 | 10,473 |
| + 1 | 2 | 82.47 | + 1 | 47 | 10,498 |
| 0 | 0 | 82.20 | 0 | 0 | 10,522 |
| - 1 | (3) | 81.80 | - 1 | (47) | 10,597 |
| - 2 | (6) | 81.40 | - 2 | (94) | 10,672 |
| - 3 | (9) | 81.00 | - 3 | (141) | 10,696 |
| - 4 | (12) | 80.60 | - 4 | (188) | 10,721 |
| - 5 | (16) | 80.20 | - 5 | (236) | 10,745 |
| - 6 | (19) | 79.80 | - 6 | (283) | 10,769 |
| - 7 | (22) | 79.40 | - 7 | (330) | 10,794 |
| - 8 | (25) | 79.00 | - 8 | (377) | 10,818 |
| - 9 | (28) | 78.60 | - 9 | (424) | 10,842 |
| - 10 | (31) | 78.20 | - 10 | (471) | 10,866 |
| Weighting Factor: | | 0.007 | Weighting Factor: | | 0.145 |

Issued by: T. J. Bowden

Page 6 of 20
Schedule 5Filed: November 19, 1996
Suspended:
Effective: November 19, 1996
Docket No.: 960001-EI
Order No.:

Generating Performance Incentive Points Table

Gulf Power Company

Period of: April 1996 - September 1996

Crist 7

| Equivalent Availability Points | Fuel Savings/Loss (\$000) | Adjusted Actual Equivalent Availability | Average Heat Rate Points | Fuel Savings/Loss (\$000) | Adjusted Actual Heat Rate |
|--------------------------------|---------------------------|---|--------------------------|---------------------------|---------------------------|
| + 10 | 38 | 75.50 | + 10 | 736 | 10,185 |
| + 9 | 34 | 75.11 | + 9 | 662 | 10,209 |
| + 8 | 30 | 74.72 | + 8 | 589 | 10,233 |
| + 7 | 27 | 74.33 | + 7 | 515 | 10,257 |
| + 6 | 23 | 73.94 | + 6 | 442 | 10,281 |
| + 5 | 19 | 73.55 | + 5 | 368 | 10,305 |
| + 4 | 15 | 73.16 | + 4 | 294 | 10,329 |
| + 3 | 11 | 72.77 | + 3 | 221 | 10,353 |
| + 2 | 8 | 72.38 | + 2 | 147 | 10,377 |
| + 1 | 4 | 71.99 | + 1 | 74 | 10,401 |
| 0 | 0 | 71.60 | 0 | 0 | 10,425 |
| | | | | 0 | 10,500 |
| | | | | 0 | 10,575 |
| - 1 | (6) | 71.00 | - 1 | (74) | 10,599 |
| - 2 | (12) | 70.40 | - 2 | (147) | 10,623 |
| - 3 | (18) | 69.80 | - 3 | (221) | 10,647 |
| - 4 | (24) | 69.20 | - 4 | (294) | 10,671 |
| - 5 | (30) | 68.60 | - 5 | (368) | 10,695 |
| - 6 | (35) | 68.00 | - 6 | (442) | 10,719 |
| - 7 | (41) | 67.40 | - 7 | (515) | 10,743 |
| - 8 | (47) | 66.80 | - 8 | (589) | 10,767 |
| - 9 | (53) | 66.20 | - 9 | (662) | 10,791 |
| - 10 | (59) | 65.60 | - 10 | (736) | 10,815 |
| Weighting Factor: | | 0.012 | Weighting Factor: | | 0.227 |

Issued by: T. J. Bowden

Page 7 of 20
Schedule 5Filed: November 19, 1996
Suspended:
Effective: November 19, 1996
Docket No.: 960001-EI
Order No.:

Generating Performance Incentive Points Table

Gulf Power Company

Period of: April 1996 - September 1996

Smith 1

| Equivalent Availability Points | Fuel Savings/Loss (\$000) | Adjusted Actual Equivalent Availability | Average Heat Rate Points | Fuel Savings/Loss (\$000) | Adjusted Actual Heat Rate |
|--------------------------------|---------------------------|---|--------------------------|---------------------------|---------------------------|
| + 10 | 24 | 88.50 | + 10 | 277 | 9,912 |
| + 9 | 22 | 88.38 | + 9 | 249 | 9,935 |
| + 8 | 19 | 88.26 | + 8 | 222 | 9,958 |
| + 7 | 17 | 88.14 | + 7 | 194 | 9,982 |
| + 6 | 14 | 88.02 | + 6 | 166 | 10,005 |
| + 5 | 12 | 87.90 | + 5 | 139 | 10,028 |
| + 4 | 10 | 87.78 | + 4 | 111 | 10,051 |
| + 3 | 7 | 87.66 | + 3 | 83 | 10,074 |
| + 2 | 5 | 87.54 | + 2 | 55 | 10,098 |
| + 1 | 2 | 87.42 | + 1 | 28 | 10,121 |
| | | | | 0 | 10,144 |
| 0 | 0 | 87.30 | 0 | 0 | 10,219 |
| | | | | 0 | 10,294 |
| - 1 | (3) | 87.12 | - 1 | (28) | 10,317 |
| - 2 | (5) | 86.94 | - 2 | (55) | 10,340 |
| - 3 | (8) | 86.76 | - 3 | (83) | 10,364 |
| - 4 | (10) | 86.58 | - 4 | (111) | 10,387 |
| - 5 | (13) | 86.40 | - 5 | (139) | 10,410 |
| - 6 | (15) | 86.22 | - 6 | (166) | 10,433 |
| - 7 | (18) | 86.04 | - 7 | (194) | 10,456 |
| - 8 | (20) | 85.86 | - 8 | (222) | 10,480 |
| - 9 | (23) | 85.68 | - 9 | (249) | 10,503 |
| - 10 | (25) | 85.50 | - 10 | (277) | 10,526 |
| Weighting Factor: | | 0.007 | Weighting Factor: | | 0.085 |

Issued by: T. J. Bowden

Page 8 of 20
Schedule 5Filed: November 19, 1996
Suspended:
Effective: November 19, 1996
Docket No.: 960001-E1
Order No.:

Generating Performance Incentive Points Table

Gulf Power Company

Period of: April 1996 - September 1996

Smith 2

| Equivalent Availability Points | Fuel Savings/Loss (\$000) | Adjusted Actual Equivalent Availability | Average Heat Rate Points | Fuel Savings/Loss (\$000) | Adjusted Actual Heat Rate |
|--------------------------------|---------------------------|---|--------------------------|---------------------------|---------------------------|
| + 10 | 26 | 94.20 | + 10 | 316 | 10,109 |
| + 9 | 23 | 93.95 | + 9 | 284 | 10,133 |
| + 8 | 21 | 93.70 | + 8 | 253 | 10,157 |
| + 7 | 18 | 93.45 | + 7 | 221 | 10,180 |
| + 6 | 16 | 93.20 | + 6 | 190 | 10,204 |
| + 5 | 13 | 92.95 | + 5 | 158 | 10,228 |
| + 4 | 10 | 92.70 | + 4 | 126 | 10,252 |
| + 3 | 8 | 92.45 | + 3 | 95 | 10,276 |
| + 2 | 5 | 92.20 | + 2 | 63 | 10,299 |
| + 1 | 3 | 91.95 | + 1 | 32 | 10,323 |
| 0 | 0 | 91.70 | 0 | 0 | 10,347 |
| - 1 | (4) | 91.33 | - 1 | (32) | 10,422 |
| - 2 | (9) | 90.96 | - 2 | (63) | 10,497 |
| - 3 | (13) | 90.59 | - 3 | (95) | 10,521 |
| - 4 | (17) | 90.22 | - 4 | (126) | 10,545 |
| - 5 | (22) | 89.85 | - 5 | (158) | 10,568 |
| - 6 | (26) | 89.48 | - 6 | (190) | 10,592 |
| - 7 | (30) | 89.11 | - 7 | (221) | 10,616 |
| - 8 | (34) | 88.74 | - 8 | (253) | 10,640 |
| - 9 | (39) | 88.37 | - 9 | (284) | 10,664 |
| - 10 | (43) | 88.00 | - 10 | (316) | 10,687 |
| | | | | | 10,711 |
| | | | | | 10,735 |
| Weighting Factor: | | 0.008 | Weighting Factor: | | 0.097 |

Issued by: T. J. Bowden

Page 9 of 20
Schedule 5Filed: November 19, 1996
Suspended:
Effective: November 19, 1996
Docket No.: 960001-EI
Order No.:

Generating Performance Incentive Points Table

Gulf Power Company

Period of: April 1996 - September 1996

Daniel 1

| Equivalent Availability Points | Fuel Savings/Loss (\$000) | Adjusted Actual Equivalent Availability | Average Heat Rate Points | Fuel Savings/Loss (\$000) | Adjusted Actual Heat Rate |
|--------------------------------|---------------------------|---|--------------------------|---------------------------|---------------------------|
| + 10 | 50 | 94.90 | + 10 | 583 | 10,178 |
| + 9 | 45 | 94.69 | + 9 | 525 | 10,202 |
| + 8 | 40 | 94.48 | + 8 | 466 | 10,226 |
| + 7 | 35 | 94.27 | + 7 | 408 | 10,250 |
| + 6 | 30 | 94.06 | + 6 | 350 | 10,274 |
| + 5 | 25 | 93.85 | + 5 | 292 | 10,298 |
| + 4 | 20 | 93.64 | + 4 | 233 | 10,322 |
| + 3 | 15 | 93.43 | + 3 | 175 | 10,346 |
| + 2 | 10 | 93.22 | + 2 | 117 | 10,370 |
| + 1 | 5 | 93.01 | + 1 | 58 | 10,394 |
| 0 | 0 | 92.80 | 0 | 0 | 10,418 |
| - 1 | (8) | 92.47 | - 1 | (58) | 10,493 |
| - 2 | (15) | 92.14 | - 2 | (117) | 10,568 |
| - 3 | (23) | 91.81 | - 3 | (175) | 10,592 |
| - 4 | (31) | 91.48 | - 4 | (233) | 10,616 |
| - 5 | (39) | 91.15 | - 5 | (292) | 10,640 |
| - 6 | (46) | 90.82 | - 6 | (350) | 10,664 |
| - 7 | (54) | 90.49 | - 7 | (408) | 10,688 |
| - 8 | (62) | 90.16 | - 8 | (466) | 10,712 |
| - 9 | (69) | 89.83 | - 9 | (525) | 10,736 |
| - 10 | (77) | 89.50 | - 10 | (583) | 10,760 |
| Weighting Factor: | | 0.015 | Weighting Factor: | | 0.180 |

Issued by: T. J. Bowden

Page 10 of 20
Schedule 5Filed: November 19, 1996
Suspended:
Effective: November 19, 1996
Docket No.: 960001-EI
Order No.:

Generating Performance Incentive Points Table

Gulf Power Company

Period of: April 1996 - September 1996

Daniel 2

| Equivalent Availability Points | Fuel Savings/Loss (\$000) | Adjusted Actual Equivalent Availability | Average Heat Rate Points | Fuel Savings/Loss (\$000) | Adjusted Actual Heat Rate |
|--------------------------------|---------------------------|---|--------------------------|---------------------------|---------------------------|
| + 10 | 56 | 97.70 | + 10 | 647 | 9,972 |
| + 9 | 50 | 97.60 | + 9 | 582 | 9,995 |
| + 8 | 45 | 97.50 | + 8 | 518 | 10,019 |
| + 7 | 39 | 97.40 | + 7 | 453 | 10,042 |
| + 6 | 34 | 97.30 | + 6 | 388 | 10,065 |
| + 5 | 28 | 97.20 | + 5 | 324 | 10,089 |
| + 4 | 22 | 97.10 | + 4 | 259 | 10,112 |
| + 3 | 17 | 97.00 | + 3 | 194 | 10,135 |
| + 2 | 11 | 96.90 | + 2 | 129 | 10,158 |
| + 1 | 6 | 96.80 | + 1 | 65 | 10,182 |
| 0 | 0 | 96.70 | 0 | 0 | 10,205 |
| | | | | 0 | 10,280 |
| | | | | 0 | 10,355 |
| - 1 | (12) | 96.55 | - 1 | (65) | 10,378 |
| - 2 | (24) | 96.40 | - 2 | (129) | 10,402 |
| - 3 | (36) | 96.25 | - 3 | (194) | 10,425 |
| - 4 | (48) | 96.10 | - 4 | (259) | 10,448 |
| - 5 | (60) | 95.95 | - 5 | (324) | 10,472 |
| - 6 | (72) | 95.80 | - 6 | (388) | 10,495 |
| - 7 | (84) | 95.65 | - 7 | (453) | 10,518 |
| - 8 | (96) | 95.50 | - 8 | (518) | 10,541 |
| - 9 | (108) | 95.35 | - 9 | (582) | 10,565 |
| - 10 | (120) | 95.20 | - 10 | (647) | 10,588 |
| Weighting Factor: | | 0.017 | Weighting Factor: | | 0.199 |

Issued by: T. J. Bowden

Page 11 of 20
Schedule 5Filed: November 19, 1996
Suspended:
Effective: November 19, 1996
Docket No.: 960001-E1
Order No.:

GPIF Unit Performance Summary .

Gulf Power Company

Period of: April 1996 - September 1996

| Plant & Unit | Weighting Factor % | EAF Target % | EAF Range | | Max Fuel Savings (\$000) | Max Fuel Loss (\$000) | EAF Adjusted Actual % | Actual Fuel Savings/ Loss (\$000) |
|--------------------|--------------------------|--------------------|-----------|----------|-----------------------------------|--------------------------------|--------------------------------|---|
| | | | Max % | Min % | | | | |
| Crist 6 | 0.7 | 82.2 | 84.9 | 78.2 | 22 | -31 | 89.9 | \$22 |
| Crist 7 | 1.2 | 71.6 | 75.5 | 65.6 | 38 | -59 | 76.4 | \$38 |
| Smith 1 | 0.7 | 87.3 | 88.5 | 85.5 | 24 | -25 | 91.0 | \$24 |
| Smith 2 | 0.8 | 91.7 | 94.2 | 88.0 | 26 | -43 | 97.0 | \$26 |
| Daniel 1 | 1.5 | 92.8 | 94.9 | 89.5 | 50 | -77 | 94.9 | \$50 |
| Daniel 2 | 1.7 | 96.7 | 97.7 | 95.2 | 56 | -120 | 92.4 | (\$120) |
| Total: | 6.6 | | | | | | | |

| Plant & Unit | Weighting Factor % | ANOHR Target BTU/KWH | Target NOF | ANOHR Range | | Max Fuel Savings (\$000) | Max Fuel Loss (\$000) | ANOHR Adjusted Actual BTU/KWH | Actual Fuel Savings/ Loss (\$000) |
|--------------------|--------------------------|----------------------------|---------------|----------------|----------------|-----------------------------------|--------------------------------|--|---|
| | | | | Max BTU/KWH | Min BTU/KWH | | | | |
| Crist 6 | 14.5 | 10,597 | 68.7 | 10,915 | 10,279 | \$471 | (\$471) | 10,219 | \$471 |
| Crist 7 | 22.7 | 10,500 | 72.1 | 10,815 | 10,185 | \$736 | (\$736) | 10,166 | \$736 |
| Smith 1 | 8.5 | 10,219 | 88.2 | 10,526 | 9,912 | \$277 | (\$277) | 10,271 | \$0 |
| Smith 2 | 9.7 | 10,422 | 79.9 | 10,735 | 10,109 | \$316 | (\$316) | 10,448 | \$0 |
| Daniel 1 | 18.0 | 10,493 | 57.8 | 10,808 | 10,178 | \$583 | (\$583) | 10,715 | (\$357) |
| Daniel 2 | 19.9 | 10,280 | 62.0 | 10,588 | 9,972 | \$647 | (\$647) | 10,751 | (\$647) |
| Total: | 93.3 | | | | | | | | |

Issued by: T. J. Bowden

Page 12 of 20
Schedule 5Filed: November 19, 1996
Suspended:
Effective: November 19, 1996
Docket No.: 960001-E1
Order No.:

Actual Unit Performance Data .

Gulf Power Company

Period of: April 1996 - September 1996

| Plant & Unit | Actual EAF % | Adjustments* to EAF % | Adjusted Actual % |
|--------------|--------------|-----------------------|-------------------|
| Crist 6 | 89.1 | 0.8 | 89.9 |
| Crist 7 | 69.1 | 7.3 | 76.4 |
| Smith 1 | 91.6 | -0.6 | 91.0 |
| Smith 2 | 97.0 | 0.0 | 97.0 |
| Daniel 1 | 93.3 | 1.6 | 94.9 |
| Daniel 2 | 92.4 | 0.0 | 92.4 |

| Plant & Unit | Actual ANOHR BTU/KWH | Adjustments** to ANOHR BTU/KWH | ANCHR Adjusted Actual BTU/KWH |
|--------------|----------------------|--------------------------------|-------------------------------|
| Crist 6 | 10,647 | -428 | 10,219 |
| Crist 7 | 10,406 | -240 | 10,166 |
| Smith 1 | 10,239 | 32 | 10,271 |
| Smith 2 | 10,367 | 81 | 10,448 |
| Daniel 1 | 10,434 | 281 | 10,715 |
| Daniel 2 | 10,519 | 232 | 10,751 |

* Refer to pages 3 through 8, Schedule 2.

** Refer to pages 8 through 13, Schedule 3.

Issued by: T. J. Bowden

Page 13 of 20
Schedule 5Filed: November 19, 1996
Suspended:
Effective: November 19, 1996
Docket No.: 9600C1-EI
Order No.:

ACTUAL UNIT PERFORMANCE DATA

GULF POWER COMPANY

PERIOD OF: April 1996 - September 1996

| CRIST 6 | Apr '96 | May '96 | Jun '96 | Jul '96 | Aug '96 | Sep '96 | total |
|---------------------|--|---------|---------|---------|---------|---------|--------|
| 1. EAF (%) | 95.9 | 43.0 | 97.0 | 100.0 | 99.7 | 99.9 | 89.1 |
| 2. PH | 719.0 | 744.0 | 720.0 | 744.0 | 744.0 | 720.0 | 4391.0 |
| 3. SH | 708.9 | 324.0 | 705.9 | 744.0 | 744.0 | 720.0 | 3946.8 |
| 4. RSH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 5. UH | 10.1 | 420.0 | 14.1 | 0.0 | 0.0 | 0.0 | 444.2 |
| 6. POH | 0.0 | 420.0 | 0.0 | 0.0 | 0.0 | 0.0 | 420.0 |
| 7. FOH | 0.0 | 0.0 | 14.1 | 0.0 | 0.0 | 0.0 | 14.1 |
| 8. MOH | 10.1 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 10.1 |
| 9. PFOH | 71.2 | 10.1 | 25.7 | 0.0 | 6.2 | 1.5 | 114.7 |
| 10. LR pf (MW) | 87.4 | 132.0 | 95.4 | 0.0 | 97.0 | 80.7 | 93.6 |
| 11. PNOH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 12. LR pm (MW) | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 13. NSC (MW) | 317.0 | 317.0 | 317.0 | 317.0 | 317.0 | 317.0 | 317.0 |
| 14. Oper MBtu | 1209985 | 555566 | 1256981 | 1446588 | 1349847 | 1325419 | 714386 |
| 15. Net Gen (MWH) | 111026 | 51752 | 118762 | 137421 | 126993 | 125063 | 671017 |
| 16. ANOHR (Btu/KWH) | 10898 | 10735 | 10584 | 10527 | 10629 | 10598 | 10647 |
| 17. NOF % | 49.4 | 50.4 | 53.1 | 58.3 | 53.8 | 54.8 | 53.6 |
| 18. NPC (MW) | 317.0 | 317.0 | 317.0 | 317.0 | 317.0 | 317.0 | 317.0 |
| 19. ANOHR Equation | $10^6 / AKW * [290.50 + 38.19 * MAY + 44.09 * JUN + 67.96 * JUL + 66.17 * AUG + 49.61 * SEP - 32.60 * OCT]$ + 9,050 | | | | | | |

Issued by: T. J. Bowden

Page 14 of 20
Schedule 5Filed: November 19, 1996
Suspended:
Effective: November 19, 1996
Docket No.: 960001-EI
Order No.:

ACTUAL UNIT PERFORMANCE DATA

GULF POWER COMPANY

PERIOD OF: April 1996 - September 1996

| CRIST 7 | Apr '96 | May '96 | Jun '96 | Jul '96 | Aug '96 | Sep '96 | Total |
|---------------------|--|---------|---------|---------|---------|---------|---------|
| 1. EAF (%) | 0.0 | 46.2 | 93.0 | 83.9 | 97.9 | 92.8 | 69.1 |
| 2. PH | 719.0 | 744.0 | 720.0 | 744.0 | 744.0 | 720.0 | 4391.0 |
| 3. SH | 0.0 | 354.4 | 671.0 | 625.5 | 735.2 | 668.0 | 3054.1 |
| 4. WSH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 5. UH | 719.0 | 389.6 | 49.0 | 118.5 | 8.8 | 52.0 | 1336.9 |
| 6. POH | 719.0 | 309.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1028.0 |
| 7. FOH | 0.0 | 3.1 | 49.0 | 118.5 | 8.8 | 33.0 | 212.4 |
| 8. MOH | 0.0 | 77.5 | 0.0 | 0.0 | 0.0 | 19.0 | 96.5 |
| 9. PFOH | 0.0 | 50.3 | 8.1 | 6.9 | 28.9 | 1.2 | 95.4 |
| 10. LR pf (MW) | 0.0 | 107.7 | 85.5 | 107.0 | 117.5 | 81.6 | 108.4 |
| 11. PMOH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 12. LR pm (MW) | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 13. NSC (MW) | 504.0 | 504.0 | 504.0 | 504.0 | 504.0 | 504.0 | 504.0 |
| 14. Oper MBtu | 0 | 1006995 | 2057451 | 2149809 | 2399969 | 2124275 | 9738499 |
| 15. Net Gen (MWH) | 0 | 95968 | 199082 | 206763 | 230728 | 203282 | 935823 |
| 16. ANOHR (Btu/KWH) | 0 | 10493 | 10335 | 10397 | 10402 | 10450 | 10406 |
| 17. NOF % | 0.0 | 53.7 | 58.9 | 65.6 | 62.3 | 60.4 | 60.8 |
| 18. NPC (MW) | 504.0 | 504.0 | 504.0 | 504.0 | 504.0 | 504.0 | 504.0 |
| 19. ANOHR Equation | $10^6 / AKW * [412.46 + 60.48 * MAY + 32.35 * JUN + 88.25 * JUL + 80.78 * AUG - 35.01 * OCT]$ $+ 9.223$ | | | | | | |

Issued by: T. J. Bowden

Page 15 of 20
Schedule 5Filed: November 19, 1996
Suspended:
Effective: November 19, 1996
Docket No.: 960001-EI
Order No.:

ACTUAL UNIT PERFORMANCE DATA

GULF POWER COMPANY

PERIOD OF: April 1996 - September 1996

| SMITH 1 | Apr '96 | May '96 | Jun '96 | Jul '96 | Aug '96 | Sep '96 | Total |
|---------------------|---|---------|---------|---------|---------|---------|---------|
| 1. EAF (%) | 50.5 | 100.0 | 98.8 | 100.0 | 99.6 | 100.0 | 91.6 |
| 2. PH | 719.0 | 744.0 | 720.0 | 744.0 | 744.0 | 720.0 | 4391.0 |
| 3. SH | 364.5 | 744.0 | 711.8 | 744.0 | 744.0 | 720.0 | 4028.3 |
| 4. RSH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 5. UH | 354.5 | 0.0 | 8.2 | 0.0 | 0.0 | 0.0 | 362.7 |
| 6. POH | 354.5 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 354.5 |
| 7. FOH | 0.0 | 0.0 | 8.2 | 0.0 | 0.0 | 0.0 | 8.2 |
| 8. MOH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 9. PFOH | 4.9 | 4.2 | 1.0 | 0.0 | 5.3 | 7.5 | 22.9 |
| 10. LR pf (MW) | 51.8 | 1.0 | 26.0 | 0.0 | 39.2 | 7.6 | 24.0 |
| 11. PNOH | 0.0 | 0.0 | 0.0 | 0.0 | 6.2 | 0.0 | 6.2 |
| 12. LR pm (MW) | 0.0 | 0.0 | 0.0 | 0.0 | 36.0 | 0.0 | 36.0 |
| 13. NSC (MW) | 161.0 | 161.0 | 161.0 | 161.0 | 161.0 | 161.0 | 161.0 |
| 14. Oper MBtu | 551180 | 1133935 | 1094829 | 1185617 | 1152858 | 1054436 | 6172855 |
| 15. Net Gen (MWH) | 53346 | 111049 | 106893 | 116223 | 112275 | 103062 | 602848 |
| 16. ANOHR (Btu/KWH) | 10332 | 10211 | 10242 | 10201 | 10268 | 10231 | 10239 |
| 17. NOF % | 90.9 | 92.7 | 93.3 | 97.0 | 93.7 | 88.9 | 93.0 |
| 18. NPC (MW) | 161.0 | 161.0 | 161.0 | 161.0 | 161.0 | 161.0 | 161.0 |
| 19. ANOHR Equation | $10^6 / AKW * [85.72 + 13.65 * JAN]$ + 9,616 | | | | | | |

Issued by: T. J. Bowden

Page 16 of 20
Schedule 5Filed: November 19, 1996
Suspended:
Effective: November 19, 1996
Docket No.: 960001-E1
Order No.:

ACTUAL UNIT PERFORMANCE DATA

GULF POWER COMPANY

PERIOD OF: April 1996 - September 1996

| SMITH 2 | Apr '96 | May '96 | Jun '96 | Jul '96 | Aug '96 | Sep '96 | Total |
|---------------------|--|---------|---------|---------|---------|---------|---------|
| 1. EAF (%) | 95.7 | 100.0 | 94.5 | 95.4 | 100.0 | 96.5 | 97.0 |
| 2. PH | 719.0 | 744.0 | 720.0 | 744.0 | 744.0 | 720.0 | 4391.0 |
| 3. SH | 690.6 | 744.0 | 680.6 | 709.7 | 744.0 | 694.9 | 4263.8 |
| 4. RSH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 5. UH | 28.4 | 0.0 | 39.4 | 34.3 | 0.0 | 25.1 | 127.2 |
| 6. POH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 7. FOH | 28.4 | 0.0 | 39.4 | 34.3 | 0.0 | 25.1 | 127.2 |
| 8. MOH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 9. PFOH | 12.7 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 12.7 |
| 10. LR pf (MW) | 40.3 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 40.3 |
| 11. PMOH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 12. LR pm (MW) | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 13. NSC (MW) | 191.0 | 191.0 | 191.0 | 191.0 | 191.0 | 191.0 | 191.0 |
| 14. Oper MBtu | 1246733 | 1291251 | 1185091 | 1314707 | 1344547 | 1150212 | 7532541 |
| 15. Net Gen (MWH) | 120132 | 126132 | 115362 | 126350 | 128001 | 110608 | 726585 |
| 16. ANOHR (Btu/KWH) | 10378 | 10237 | 10273 | 10405 | 10504 | 10399 | 10367 |
| 17. NOF % | 91.1 | 88.8 | 88.7 | 93.2 | 90.1 | 83.3 | 89.2 |
| 18. NPC (MW) | 191.0 | 191.0 | 191.0 | 191.0 | 191.0 | 191.0 | 191.0 |
| 19. ANOHR Equation | $10^6 / AKW * [101.34 + 27.35 * APR + 42.71 * JUN]$ + 9,685 | | | | | | |

Issued by: T. J. Bowden

Filed: November 19, 1996
 Suspended:
 Effective: November 19, 1996
 Docket No.: 960001-E1
 Order No.:

Page 17 of 20
 Schedule 5

ACTUAL UNIT PERFORMANCE DATA

GULF POWER COMPANY

PERIOD OF: April 1996 - September 1996

| DANIEL 1 | Apr '96 | May '96 | Jun '96 | Jul '96 | Aug '96 | Sep '96 | Total |
|---------------------|--|---------|---------|---------|---------|---------|----------|
| 1. EAF (%) | 92.2 | 98.5 | 93.8 | 93.8 | 100.0 | 80.4 | 93.3 |
| 2. PH | 719.0 | 744.0 | 720.0 | 744.0 | 744.0 | 720.0 | 4391.0 |
| 3. SH | 576.1 | 744.0 | 683.6 | 698.4 | 744.0 | 635.6 | 4081.7 |
| 4. RSH | 117.7 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 117.7 |
| 5. UM | 25.2 | 0.0 | 36.4 | 45.6 | 0.0 | 84.4 | 191.6 |
| 6. POH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 84.4 | 84.4 |
| 7. FOH | 0.0 | 0.0 | 0.0 | 30.7 | 0.0 | 0.0 | 30.7 |
| 8. MOH | 25.2 | 0.0 | 36.4 | 14.9 | 0.0 | 0.0 | 76.5 |
| 9. PFOH | 239.5 | 116.9 | 41.4 | 9.8 | 3.4 | 366.6 | 777.6 |
| 10. LR pf (MW) | 55.5 | 41.3 | 88.2 | 23.8 | 20.0 | 66.4 | 59.7 |
| 11. PNOH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 12. LR pm (MW) | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 13. NSC (MW) | 430.0 | 430.0 | 430.0 | 510.0 | 510.0 | 430.0 | 456.7 |
| 14. Oper MBtu | 2220784 | 2961441 | 2582073 | 2609452 | 2667125 | 2360993 | 15401868 |
| 15. Net Gen (MWH) | 212538 | 282306 | 246307 | 257177 | 256653 | 221119 | 1476100 |
| 16. ANOHR (Btu/KWH) | 10449 | 10490 | 10483 | 10147 | 10392 | 10677 | 10434 |
| 17. NOF % | 85.8 | 88.2 | 83.8 | 72.2 | 67.6 | 80.9 | 79.2 |
| 18. NPC (MW) | 430.0 | 430.0 | 430.0 | 510.0 | 510.0 | 430.0 | 456.7 |
| 19. ANOHR Equation | $10^6 / AKW * [-195.70 - 65.61 * JAN]$ $+ 13,416 - 0.00639 * LSRF / AKW$ | | | | | | |

Issued by: T. J. Bowden

Page 18 of 20
Schedule 5Filed: November 19, 1996
Suspended:
Effective: November 19, 1996
Docket No.: 960001-EI
Order No.:

ACTUAL UNIT PERFORMANCE DATA

GULF POWER COMPANY

PERIOD OF: April 1996 - September 1996

| DANIEL 2 | Apr '96 | May '96 | Jun '96 | Jul '96 | Aug '96 | Sep '96 | Total |
|---------------------|--|---------|---------|---------|---------|---------|----------|
| 1. EAF (%) | 77.4 | 85.9 | 98.6 | 97.5 | 95.9 | 98.8 | 92.4 |
| 2. PH | 719.0 | 744.0 | 720.0 | 744.0 | 744.0 | 720.0 | 4391.0 |
| 3. SH | 581.9 | 639.7 | 718.3 | 728.8 | 713.4 | 720.0 | 4102.1 |
| 4. RSH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 5. UH | 137.1 | 104.3 | 1.7 | 15.2 | 30.6 | 0.0 | 288.5 |
| 6. POH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 7. FOH | 0.0 | 0.0 | 1.7 | 15.2 | 30.6 | 0.0 | 47.5 |
| 8. MOH | 137.1 | 104.3 | 0.0 | 0.0 | 0.0 | 0.0 | 241.4 |
| 9. PFOH | 128.7 | 2.7 | 29.0 | 6.5 | 1.9 | 49.0 | 217.8 |
| 10. LR pf (MW) | 84.9 | 105.4 | 128.3 | 253.0 | 55.0 | 74.1 | 93.3 |
| 11. PMOH | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 12. LR pm (MW) | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 13. NSC (MW) | 430.0 | 430.0 | 430.0 | 510.0 | 510.0 | 430.0 | 456.7 |
| 14. Oper MBtu | 2254640 | 2483093 | 2446759 | 2565488 | 2326337 | 2764275 | 14840592 |
| 15. Net Gen (MWH) | 213411 | 236237 | 232659 | 247472 | 222964 | 258132 | 1410875 |
| 16. ANOHR (Btu/KWH) | 10565 | 10511 | 10517 | 10367 | 10434 | 10709 | 10519 |
| 17. NOF % | 85.3 | 85.9 | 75.3 | 66.6 | 61.3 | 83.4 | 75.3 |
| 18. NPC (MW) | 430.0 | 430.0 | 430.0 | 510.0 | 510.0 | 430.0 | 456.7 |
| 19. ANOHR Equation | $10^6 / AKW * [-192.43 + 68.36 * JUL + 82.43 * AUG + 58.95 * SEP - 48.31 * OCT]$ $+ 13,293 - 0.00674 * LSRF / AKW$ | | | | | | |

Issued by: T. J. Bowden

Page 19 of 20
Schedule 5Filed: November 19, 1996
Suspended:
Effective: November 19, 1996
Docket No.: 960001-E1
Order No.:

Planned Outage Schedules (Actual)

Period of: April 1996 - September 1996

Critical path bar charts of actual work activity performed during major planned outages are not shown here since corresponding bar charts of forecast work activity were not provided earlier in conformance with agreement with Staff to avoid the premature production of charts prior to their normal course of development. Forecast and actual critical path bar charts are developed for each planned outage and, per agreement with Staff, these charts will be provided on request.

Issued by: T. J. Bowden

Page 20 of 20
Schedule 5


Filed: November 19, 1996
Suspended:
Effective: November 19, 1996
Docket No.: 960001-E1
Order No.:

AFFIDAVIT

STATE OF FLORIDA)
)
COUNTY OF ESCAMBIA)

Docket No. 960001-EI

Before me the undersigned authority, personally appeared George D. Fontaine, who being first duly sworn, deposes, and says that he is the Performance Test Specialist of Gulf Power Company, a Maine Corporation, and that the foregoing is true and correct to the best of his knowledge, information, and belief. He is personally known to me.



George D. Fontaine
Performance Test Specialist

Sworn to and subscribed before me this 14th day of November, 1996.



Notary Public, State of Florida at Large

