

ORIGINAL
FILE COPY



**Florida
Power**
CORPORATION

JAMES A. McGEE
SENIOR COUNSEL

January 30, 1997

Ms. Blanca S. Bayó, Director
Division of Records and Reporting
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399-0850


Re: Docket No. 970001-EI

Dear Ms. Bayó:

Enclosed for filing in the subject docket are an original and fifteen copies of the revised testimony and exhibits of Dario B. Zuloaga. The revision reflects the exclusion of the Crystal River 3 nuclear unit from Florida Power's GPIF calculation.

Please acknowledge your receipt of the above filing on the enclosed copy of this letter and return to the undersigned. Also enclosed is a 3.5 inch diskette containing the above-referenced document in WordPerfect format. Thank you for your assistance in this matter.

Very truly yours,



James A. McGee

JAM/jb
Enclosure

cc: Parties of record
Mr. Sid Matlock

DOCUMENT NUMBER-DATE

GENERAL OFFICE

3201 Thirty-fourth Street South • Post Office Box 14042 • St. Petersburg, Florida 33733-4042 • (813) 866-5184 • Fax: (813) 866-4931
A Florida Progress Company

01192 JAN 31 5
FPSC-RECORDS/REPORTING

CERTIFICATE OF SERVICE

Docket No. 970001

I HEREBY CERTIFY that a true and correct copy of the Revised Testimony and Exhibits of Dario B. Zuloaga has been sent by regular U.S. mail to the following individuals this 30th day of January, 1997:

Matthew M. Childs, Esq.
Steel, Hector & Davis
215 South Monroe, Ste. 601
Tallahassee, FL 32301-1804

Lee L. Willis, Esquire
James D. Beasley, Esquire
Macfarlane Ausley Ferguson
& McMullen
P.O. Box 391
Tallahassee, FL 32302

G. Edison Holland, Jr., Esquire
Jeffrey A. Stone, Esquire
Beggs & Lane
P. O. Box 12950
Pensacola, FL 32576-2950

Joseph A. McGlothlin, Esquire
Vicki Gordon Kaufman, Esquire
McWhirter, Reeves, McGlothlin,
Davidson & Bakas
117 S. Gadsden Street
Tallahassee, FL 32301

Vicki D. Johnson, Esquire
Sheila Erstling, Esquire
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, FL 32399-0850

Norman Horton, Jr., Esquire
Messer, Vickers, Caparello,
Frend & Madsen
P.O. Box 1876
Tallahassee, FL 32302

Barry N. P. Huddleston
Public Affairs Specialist
Destec Energy, Inc.
2500 CityWest Blvd., Suite 150
Houston, TX 77210-4411

J. Roger Howe, Esquire
Office of the Public Counsel
111 West Madison Street, Room 182
Tallahassee, FL 32399-1400

Suzanne Brownless, Esquire
1311-B Paul Russell Road
Suite 202
Tallahassee, FL 32301


Roger Yott, P.E.
Air Products & Chemicals, Inc.
2 Windsor Plaza
2 Windsor Drive
Allentown, PA 18195

John W. McWhirter, Jr.
McWhirter, Reeves, McGlothlin, Davidson
& Bakas, P.A.
100 North Tampa Street, Suite 2800
Tampa, FL 33602-5126

Peter J. P. Brickfield
Brickfield, Burchette & Ritte, P.C.
1025 Thomas Jefferson Street, N.W.
Eighth Floor, West Tower
Washington, D.C. 20007

Kenneth A. Hoffman, Esq.
William B. Willingham, Esq.
Rutledge, Ecenia, Underwood, Purnell
& Hoffman, P.A.
P.O. Box 551
Tallahassee, FL 32302-0551

Mr. Frank C. Cressman
President
Florida Public Utilities Company
P.O. Box 3395
West Palm Beach, FL 33402-3395



Attorney

01/19/92
FILE COPY



**Florida
Power**
CORPORATION

**BEFORE THE
FLORIDA PUBLIC SERVICE COMMISSION**

DOCKET No. 970001-EI

**GPIF TARGETS AND RANGES
APRIL THROUGH SEPTEMBER 1997**

**REVISED
DIRECT TESTIMONY
AND EXHIBITS OF**

DARIO B. ZULOAGA

ACK _____
AFA _____
APP _____
CAF _____
CMU _____
CTR _____
EAG _____
LEG _____
LIN _____
OPC _____
RCI _____
REC _____ RECEIVED & FILED
WAS _____
OTH _____

11/19/92
EPSC-BUREAU OF RECORDS

For Filing January 31, 1997
DOCUMENT NUMBER-DATE

01192 JAN 31 1997
FPSC-RECORDS/REPORTING

FLORIDA POWER CORPORATION

DOCKET No. 970001-EI

**GPIF Targets and Ranges for
April through September 1997**

**REVISED
DIRECT TESTIMONY OF
DARIO B. ZULOAGA**

1 Q. Please state your name and business address.

2 A. My name is Dario B. Zuloaga. My business address is Post Office Box
3 14042, St. Petersburg, Florida 33733.

4
5 Q. By whom are you employed and in what capacity?

6 A. I am employed by Florida Power Corporation as a Principal Engineer in
7 Energy Supply, Performance Services.

8
9 Q. Have the duties and responsibilities of your position with the Company
10 remained the same since you last testified in this proceeding?

11 A. Yes, they have.

12
13 Q. What is the purpose of your testimony?

A. The purpose of my testimony is to present the development of the Company's Generating Performance Incentive Factor (GPIF) targets and ranges for the period of April through September, 1997. This development includes the targets and improvement/degradation ranges for unit equivalent availability and unit average net operating heat rate in accordance with the Commission's Generating Performance Incentive Implementation Manual. The revision to my testimony explains the reason that the Crystal River 3 nuclear unit has been excluded from the GPIF for the upcoming April - September period and recalculates the GPIF to reflect the exclusion.

Q. Do you have an exhibit to your testimony?

A. Yes, I will sponsor an exhibit containing 75 pages, which consists of the GPIF standard form schedules prescribed in the Implementation Manual and supporting data, including unplanned outage rates, net operating heat rates, and computer analyses and graphs for each of the individual GPIF units. I have also included a table after the standard form schedules which demonstrates that, with the exclusion of Crystal River 3 from the GPIF, the Company's remaining GPIF units continue to generate more than 80% of total system generation.

1 Q. Which of the Company's generating units have you included in the GPIF
2 program for the upcoming projection period?
3 A. We have included Crystal River Units 1, 2, 4 and 5 and Arclove Units
4 1 and 2. The Crystal River 3 nuclear unit will likely be unavailable for
5 the entire April - September 1997 period. Florida Power voluntarily
6 shutdown the unit on September 2, 1996 to address several design
7 issues related to backup safety systems, including an emergency diesel
8 generator. Even with the nuclear unit unavailable for the period, the
9 remaining units are projected to provide 82.3% of Florida Power's total
10 system generation, as shown on Table 1 at the end of my exhibit.

11
12 Q. Have you determined the equivalent availability targets and
13 improvement/degradation ranges for the Company's GPIF units?
14 A. Yes, I have. This information is included in the Target and Range
15 Summary on page 3 of my exhibit.

16
17 Q. How were the equivalent availability targets developed?
18 A. The equivalent availability targets were developed using the
19 methodology established for the Company's GPIF units, as set forth in
20 Section 4 of the Implementation Manual. This method describes the
21 formulation of graphs based on each unit's historic performance data
22 for the four individual unplanned outage rates (i.e. forced, partial

1 forced, maintenance and partial maintenance outage rates), which in
2 combination constitute the unit's equivalent unplanned outage rate
3 (EUOR). From operational data and these graphs, the individual target
4 rates are determined by inspecting two years of twelve-month rolling
5 averages and the scatter of monthly data points during the two-year
6 period. The unit's four target rates are then used to calculate its
7 unplanned outage hours for the projection period. When the unit's
8 projected planned outage hours are taken into account, the hours
9 calculated from these individual unplanned outage rates can then be
10 converted into an overall equivalent unplanned outage factor (EUOF).
11 Because factors are additive (unlike rates), the unplanned and planned
12 outage factors (EUOF and POF) when added to the equivalent
13 availability factor (EAF) will always equal 100%. For example, an
14 EUOF of 15% and a POF of 10% results in an EAF of 75%.

15
16 The supporting graphs and a summary table of all target and range
17 rates are contained in the section of my exhibit entitled "Unplanned
18 Outage Rate Tables and Graphs".

19
20 Q. Please describe the method utilized in the development of the
21 improvement/degradation ranges for each GPIF unit's availability
22 targets.

1 A. In general, the methodology described in the implementation manual
2 was used. Ranges were first established for each of the four unplanned
3 outage rates associated with each unit. From an analysis of the
4 unplanned outage graphs, units with small historical variations in
5 outage rates were assigned narrow ranges and units with large
6 variations were assigned wider ranges. These individual ranges,
7 expressed in terms of rates, were then converted into a single unit
8 availability range, expressed in terms of a factor, using the same
9 procedure described above for converting the availability targets from
10 rates to factors.

11

12 Q. Have you determined the net operating heat rate targets and ranges for
13 the Company's GPIF units?

14 A. Yes, I have. This information is included in the Target and Range
15 Summary on Page 3 of my exhibit.

16

17 Q. How were these heat rate targets and ranges developed?

18 A. The development of the heat rate targets and ranges for the upcoming
19 period utilized historical data from the past three comparable GPIF
20 periods, as described in the Implementation Manual. A "least squares"
21 computer program was used to curve-fit the heat rate data within
22 ranges having a 90% confidence level of including all data. The

1 computer analyses and data plots used to develop the heat rate targets
2 and ranges for each of the GPIF units are contained in the section of
3 my exhibit entitled "Average Net Operating Heat Rate Curves".

4

5 Q. How were the GPIF Incentive points developed for the unit availability
6 and heat rate ranges?

7 A. GPIF incentive points for availability and heat rate were developed by
8 evenly spreading the positive and negative point values from the target
9 to the maximum and minimum values in case of availability, and from
10 the neutral band to the maximum and minimum values in the case of
11 heat rate. The fuel savings (loss) dollars were evenly spread over the
12 range in the same manner as described for the incentive points. The
13 maximum savings (loss) dollars are the same as those used in the
14 calculation of weighting factors.

15

16 Q. How were the GPIF weighting factors determined?

17 A. To determine the weighting factors for availability, a series of PROMOD
18 simulations were made in which each unit's maximum equivalent
19 availability was substituted for the target value to obtain a new system
20 fuel cost. The differences in fuel costs between these cases and the
21 target case determines the contribution of each unit's availability to fuel
22 savings. The heat rate contribution of each unit to fuel savings was

1 determined by multiplying the BTU savings between the minimum and
2 target heat rates (at constant generation) by the average cost per BTU
3 for that unit. Weighting factors were then calculated by dividing each
4 individual unit's fuel savings by total system fuel savings.

5 -

6 Q. What was the basis for determining the estimated maximum incentive
7 amount?

8 A. The determination of the maximum reward or penalty was based upon
9 monthly common equity projections obtained from a detailed financial
10 simulation performed by the Company's Corporate Model.

11

12 Q. Does this conclude your testimony?

13 A. Yes.

**EXHIBITS TO THE REVISED TESTIMONY OF
DARIO B. ZULOAGA**

**GPIF TARGETS AND RANGES FOR
APRIL THROUGH SEPTEMBER 1997**

STANDARD FORM GPIF SCHEDULES

Description	Page
Reward/Penalty Table (Estimated)	1
Maximum Incentive Dollars (Estimated)	2
Target and Range Summary	3
Comparison of Targets with Prior Period Performance	4-5
Derivation of Weighting Factors	6
Incentive Point Tables	7-13
Unit Performance Data (Estimated)	14-19
Planned Outage Schedules (Estimated)	20-24
Average Net Operating Heat Rate Curves	25-38
Unplanned Outage Rate Tables and Graphs	39-74
Projected System and GPIF Unit Generation	75

DOCUMENT NUMBER-DATE

01192 JAN 31 6

FPSC-RECORDS/REPORTING

GENERATING PERFORMANCE INCENTIVE FACTOR

REWARD/PENALTY TABLE

ESTIMATED

Company: Florida Power Corporation
 Period of: Apr. 1997 - Sep. 1997

Generating Performance Incentive Points (GPIF)	Fuel Saving/Loss (\$)	Generating Performance Incentive Factor (\$)
10	\$12,139,600	\$3,655,463
9	\$10,925,640	\$3,289,917
8	\$9,711,680	\$2,924,370
7	\$8,497,720	\$2,558,824
6	\$7,283,760	\$2,193,278
5	\$6,069,800	\$1,827,731
4	\$4,855,840	\$1,462,185
3	\$3,641,880	\$1,096,639
2	\$2,427,920	\$731,093
1	\$1,213,960	\$365,546
0	\$0	\$0
-1	(\$906,660)	(\$365,546)
-2	(\$1,813,320)	(\$731,093)
-3	(\$2,719,980)	(\$1,096,639)
-4	(\$3,626,640)	(\$1,462,185)
-5	(\$4,533,300)	(\$1,827,731)
-6	(\$5,439,960)	(\$2,193,278)
-7	(\$6,346,620)	(\$2,558,824)
-8	(\$7,253,280)	(\$2,924,370)
-9	(\$8,159,940)	(\$3,289,917)
-10	(\$9,066,600)	(\$3,655,463)

Issued by: FPC

Filed:
 Suspend/d:
 Effective:
 Docket No.:
 Order No.:

GENERATION PERFORMANCE INCENTIVE FACTOR

CALCULATION OF MAXIMUM ALLOWED INCENTIVE DOLLARS

ESTIMATED

Company: Florida Power Corporation
 Period of: Apr. 1997 - Sep. 1997

1	Beginning of period balance of common equity	\$1,830,953,000
2	END OF MONTH BALANCE OF COMMON EQUITY: Month of APRIL 1997	\$1,840,449,000
3	Month of MAY 1997	\$1,859,939,000
4	Month of JUNE 1997	\$1,839,451,000
5	Month of JULY 1997	\$1,868,751,000
6	Month of AUGUST 1997	\$1,904,825,000
7	Month of SEPTEMBER 1997	\$1,888,392,000
8	Average common equity for the period (Summation of LINE 1 through LINE 7 divided by 7)	\$1,861,822,857
9	25 Basis Points	0.0025
10	Revenue Expansion Factor	61.375%
11	Maximum allowed incentive dollars (LINE 8 times LINE 9 divided by LINE 10 times 0.5)	\$3,791,974
12	Jurisdictional Sales *	16,831,485 MWH
13	Total Sales *	17,459,361 MWH
14	Jurisdictional Separation Factor (LINE 12 divided by LINE 13)	96.40%
15	Maximum allowed jurisdictional incentive dollars (LINE 11 times LINE 14)	\$3,655,463

* Net sales (Sales - Interruptible)

Issued by: FPC

Filed:
 Suspended:
 Effective:
 Docket No.:
 Order No.:

GPIF TARGET AND RANGE SUMMARY

Company: Florida Power Corporation

Period of: Apr. 1997 - Sep. 1997

Plant/Unit	Weighting Factor	EAF Target (%)	EAF RANGE		Max. Fuel Savings (\$000)	Max. Fuel Loss (\$000)
			Max. (%)	Min. (%)		
ANC. 1	2.61	91.28	93.58	86.61	317.2	722.5
ANC. 2	3.93	95.32	97.53	90.78	477.5	1142.6
C.R. 1	13.54	88.73	92.96	80.28	1644.1	182.5
C.R. 2	27.76	83.52	90.07	71.01	3370.4	-1448.0
C.R. 3	0.00	0.00	0.00	0.00	0.0	0.0
C.R. 4	9.09	94.08	96.87	88.37	1103.0	2654.7
C.R. 5	3.84	75.53	77.02	72.48	466.2	1051.1
<hr/>			<hr/>			
GPIF System	60.78				7378.4	4305.4

Plant/Unit	Weighting Factor	ANOHr Target		ANOHr Range		Max. Fuel Savings (\$000)	Max. Fuel Loss (\$000)
		(BTU/KWH)	MOF	Min. (%)	Max. (%)		
ANC. 1	11.28	9719	79.6	9374	10063	1369.2	1369.2
ANC. 2	8.21	9669	76.7	9409	9929	997.1	997.1
C.R. 1	3.00	9766	94.7	9616	9916	364.3	364.3
C.R. 2	3.66	9763	97.9	9613	9913	444.2	444.2
C.R. 3	0.00	0	0.0	0	0	0.0	0.0
C.R. 4	7.22	9289	96.4	9139	9439	876.3	876.3
C.R. 5	5.85	9267	99.5	9117	9417	710.1	710.1
<hr/>			<hr/>				<hr/>
GPIF System	39.22					4761.2	4761.2

Issued by: FPC

Filed:
 Suspended:
 Effective:
 Docket No.:
 Order No.:

COMPARISON OF GPIF TARGETS VS. PRIOR PERIODS' ACTUAL PERFORMANCE AVAILABILITY

Company: Florida Power Corporation												
Period of: Apr. 1997 - Sep. 1997												
Plant/Unit	Target Wt. Factor	Norm. Wt. Factor	Target Apr.-Sep./1997			Actual Performance 1st Prior Period Apr.-Sep./1996			Actual Performance 2nd Prior Period Oct.-Mar./1995-96			
			POF	EUOF	EUOR	POF	EUOF	EUOR	POF	EUOF	EUOR	
	-----	-----	---	---	---	---	---	---	---	---	---	
ANC. 1	2.61	4.30	3.83	4.89	5.87	0.41	5.12	5.41	23.36	2.42	4.62	
ANC. 2	3.93	6.47	0.00	4.68	5.71	0.00	5.13	5.13	20.20	4.68	9.24	
C.R. 1	13.54	22.28	2.19	9.09	9.29	0.00	11.85	11.85	0.00	9.24	9.24	
C.R. 2	27.76	45.68	2.19	14.29	14.61	0.00	7.66	7.66	29.53	3.66	5.36	
C.R. 3	0.00	0.00	0.00	0.00	0.00	25.59	24.68	33.16	24.12	11.57	15.24	
C.R. 4	9.09	14.95	0.00	5.92	5.92	22.65	10.55	13.63	0.00	2.91	2.91	
C.R. 5	3.84	6.32	21.31	3.15	4.01	1.31	4.55	4.55	0.00	3.20	3.20	
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	
GPIF System												
Wghtd. Avg.	60.78	100.00	3.00	10.15	10.51	3.49	8.56	9.03	15.80	4.78	5.94	
Actual Performance												
3rd Prior Period												
Apr.-Sep./1995												
Plant/Unit	Actual Performance			Actual Performance			Actual Performance			Actual Performance		
	POF	EUOF	EUOR	POF	EUOF	EUOR	POF	EUOF	EUOR	POF	EUOF	
-----	---	---	---	---	---	---	---	---	---	---	---	
ANC. 1	0.56	7.36	8.06	43.49	1.76	5.17	3.22	7.03	7.30			
ANC. 2	0.00	10.89	11.89	9.29	0.59	1.11	11.17	2.70	3.15			
C.R. 1	31.55	7.49	10.95	7.09	6.92	8.06	0.00	10.34	10.34			
C.R. 2	0.00	7.99	8.23	17.20	26.39	33.70	0.00	14.47	14.47			
C.R. 3	0.00	1.03	1.03	0.00	0.99	0.99	31.19	3.88	5.63			
C.R. 4	0.00	4.13	4.13	0.00	2.41	2.41	5.83	5.94	6.31			
C.R. 5	2.82	5.30	5.45	23.07	1.43	1.86	0.00	3.34	3.34			
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	
GPIF System				7.23	7.29	8.28	13.36	14.16	17.96	1.73	10.49	10.59

Issued by: FPC

Filed:
 Suspended:
 Effective:
 Docket No.:
 Order No.:

COMPARISON OF GPIF TARGETS VS. PRIOR PERIODS' ACTUAL PERFORMANCE
AVERAGE NET OPERATING HEAT RATE

Company: Florida Power Corporation
 Period of: Apr. 1997 - Sep. 1997

Plant/Unit	Target Wt. Factor	Norm. Wt. Factor	Average Heat Rate Target	1st Prior HR Apr. 96 - Sep. 96	2nd Prior HR Apr. 95 - Sep. 95	3rd Prior HR Apr. 94 - Sep. 94
AMC. 1	11.28	28.76	9719	9660	9716	9800
AMC. 2	8.21	20.94	9669	9617	9699	9629
C.R. 1	3.00	7.65	9766	9762	9720	9789
C.R. 2	3.66	9.33	9763	9783	9718	9787
C.R. 3	0.00	0.00	0	10587	10464	10566
C.R. 4	7.22	18.41	9289	9297	9297	9267
C.R. 5	5.85	14.91	9267	9303	9272	9221
GPIF System Weighted Av	39.22	100.00	9570	9550	9570	9578

Issued by: FPC

Filed:
 Suspended:
 Effective:
 Docket No:
 Order No:

DERIVATION OF WEIGHTING FACTORS

Company: Florida Power Corporation
 Period of: Apr. 1997 - Sep. 1997

Production Costing Simulation
 Fuel Cost (\$000)

Unit Performance Indicator	At Maximum			Weighting Factor (% of Savings)
	At Target (1)	Improvement (2)	Savings (3)	
ANC. 1 EA	\$605,937.0	\$605,619.8	\$317.2	2.61
ANC. 1 HR	\$605,937.0	\$604,567.8	\$1,369.2	11.28
ANC. 2 EA	\$605,937.0	\$605,459.5	\$477.5	3.93
ANC. 2 HR	\$605,937.0	\$604,939.9	\$997.1	8.21
C.R. 1 EA	\$605,937.0	\$604,292.9	\$1,644.1	13.54
C.R. 1 HR	\$605,937.0	\$605,572.7	\$364.3	3.00
C.R. 2 EA	\$605,937.0	\$602,566.6	\$3,370.4	27.76
C.R. 2 HR	\$605,937.0	\$605,492.8	\$444.2	3.66
C.R. 3 EA	\$605,937.0	\$605,937.0	\$0.0	0.00
C.R. 3 HR	\$605,937.0	\$605,937.0	\$0.0	0.00
C.R. 4 EA	\$605,937.0	\$604,834.0	\$1,103.0	9.09
C.R. 4 HR	\$605,937.0	\$605,060.7	\$876.3	7.22
C.R. 5 EA	\$605,937.0	\$605,470.8	\$466.2	3.84
C.R. 5 HR	\$605,937.0	\$605,226.9	\$710.1	5.85

1. Fuel Adjustment Base Case - all unit performance indicators at Target.
2. All other unit performance indicators at Target.
3. Expressed in replacement costs.

Issued by: FPC

Filed:
 Suspended:
 Effective:
 Docket No:
 Order No.:

GENERATING PERFORMANCE INCENTIVE POINTS TABLE

Company: Florida Power Corporation

Period of: Apr. 1997 - Sep. 1997

Unit: Anclote 1

Equivalent Availability (Points)	Fuel Savings/Loss (\$)	Equivalent Availability (%)	Average Heat Rate (Points)	Fuel Savings/Loss (\$)	Average Heat Rate (BTU/KWH)
10	\$317,200	93.58	10	\$1,369,200	9373.8
9	\$285,480	93.35	9	\$1,232,280	9400.8
8	\$253,760	93.12	8	\$1,095,360	9427.8
7	\$222,040	92.89	7	\$958,440	9454.7
6	\$190,320	92.66	6	\$821,520	9481.7
5	\$158,600	92.43	5	\$684,600	9508.7
4	\$126,880	92.20	4	\$547,680	9535.7
3	\$95,160	91.97	3	\$410,760	9562.6
2	\$63,440	91.74	2	\$273,840	9589.6
1	\$31,720	91.51	1	\$136,920	9616.6
					9643.5
0	\$0	91.28	0	\$0	9718.5
					9793.5
-1	(\$72,250)	90.82	-1	(\$136,920)	9820.5
-2	(\$144,500)	90.35	-2	(\$273,840)	9847.5
-3	(\$216,750)	89.88	-3	(\$410,760)	9874.4
-4	(\$289,000)	89.42	-4	(\$547,680)	9901.4
-5	(\$361,250)	88.95	-5	(\$684,600)	9928.4
-6	(\$433,500)	88.48	-6	(\$821,520)	9955.4
-7	(\$505,750)	88.01	-7	(\$958,440)	9982.3
-8	(\$578,000)	87.55	-8	(\$1,095,360)	10009.3
-9	(\$650,250)	87.08	-9	(\$1,232,280)	10036.3
-10	(\$722,500)	86.61	-10	(\$1,369,200)	10063.2

Equivalent Availability

Heat Rate

Weighting Factor:

Weighting Factor:

2.61%

11.28%

Issued by: FPC

Filed:

Suspended:

Effective:

Docket No.:

Order No.:

GENERATING PERFORMANCE INCENTIVE POINTS TABLE

Company: Florida Power Corporation
 Period of: Apr. 1997 - Sep. 1997
 Unit: Anclote 2

Equivalent Availability (Points)	Fuel Savings/Loss (\$)	Equivalent Availability (%)	Average Heat Rate (Points)	Fuel Savings/Loss (\$)	Average Heat Rate (BTU/KWH)
10	\$477,500	97.53	10	\$997,100	9408.5
9	\$429,750	97.31	9	\$897,390	9427.1
8	\$382,000	97.09	8	\$797,680	9445.6
7	\$334,250	96.87	7	\$697,970	9464.1
6	\$286,500	96.65	6	\$598,260	9482.6
5	\$238,750	96.43	5	\$498,550	9501.2
4	\$191,000	96.20	4	\$398,840	9519.7
3	\$143,250	95.98	3	\$299,130	9538.2
2	\$95,500	95.76	2	\$199,420	9556.8
1	\$47,750	95.54	1	\$99,710	9575.3
					9593.8
0	\$0	95.32	0	\$0	9668.8
					9763.8
-1	(\$114,260)	94.87	-1	(\$99,710)	9762.3
-2	(\$228,520)	94.41	-2	(\$199,420)	9780.9
-3	(\$342,780)	93.96	-3	(\$299,130)	9799.4
-4	(\$457,040)	93.51	-4	(\$398,840)	9817.9
-5	(\$571,300)	93.05	-5	(\$498,550)	9836.4
-6	(\$685,560)	92.60	-6	(\$598,260)	9855.0
-7	(\$799,820)	92.14	-7	(\$697,970)	9873.5
-8	(\$914,080)	91.69	-8	(\$797,680)	9892.0
-9	(\$1,028,340)	91.23	-9	(\$897,390)	9910.5
-10	(\$1,142,600)	90.78	-10	(\$997,100)	9929.1

Equivalent Availability
Weighting Factor:

3.93%

Heat Rate
Weighting Factor:

8.21%

Issued by: FPC

Filed:
Suspended:
Effective:
Docket No.:
Order No.:

GENERATING PERFORMANCE INCENTIVE POINTS TABLE

Company: Florida Power Corporation
 Period of: Apr. 1997 - Sep. 1997
 Unit: Crystal River 1

Equivalent Availability (Points)	Fuel Savings/Loss (\$)	Equivalent Availability (%)	Average Heat Rate (Points)	Fuel Savings/Loss (\$)	Average Heat Rate (BTU/KWH)
10	\$1,644,100	92.96	10	\$364,300	9616.3
9	\$1,479,690	92.54	9	\$327,870	9623.8
8	\$1,315,280	92.11	8	\$291,440	9631.3
7	\$1,150,870	91.69	7	\$255,010	9638.8
6	\$986,460	91.27	6	\$218,580	9646.3
5	\$822,050	90.84	5	\$182,150	9653.8
4	\$657,640	90.42	4	\$145,720	9661.3
3	\$493,230	90.00	3	\$109,290	9668.8
2	\$328,820	89.57	2	\$72,860	9676.3
1	\$164,410	89.15	1	\$36,430	9683.8
					9691.3
0	\$0	88.73	0	\$0	9766.3
					9841.3
-1	(\$18,250)	87.88	-1	(\$36,430)	9848.8
-2	(\$36,500)	87.04	-2	(\$72,860)	9856.3
-3	(\$54,750)	86.19	-3	(\$109,290)	9863.8
-4	(\$73,000)	85.35	-4	(\$145,720)	9871.3
-5	(\$91,250)	84.51	-5	(\$182,150)	9878.8
-6	(\$109,500)	83.66	-6	(\$218,580)	9886.3
-7	(\$127,750)	82.82	-7	(\$255,010)	9893.8
-8	(\$146,000)	81.97	-8	(\$291,440)	9901.3
-9	(\$164,250)	81.13	-9	(\$327,870)	9908.8
-10	(\$182,500)	80.28	-10	(\$364,300)	9916.3

Equivalent Availability

Weighting Factor:

13.54%

Heat Rate

Weighting Factor:

3.00%

Issued by: FPC

Filed:

Suspended:

Effective:

Docket No.:

Order No.:

GENERATING PERFORMANCE INCENTIVE POINTS TABLE

Company: Florida Power Corporation
 Period of: Apr. 1997 - Sep. 1997
 Unit: Crystal River 2

Equivalent Availability (Points)	Fuel Savings/Loss (\$)	Equivalent Availability (%)	Average Heat Rate (Points)	Fuel Savings/Loss (\$)	Average Heat Rate (BTU/KWH)
10	\$3,370,400	90.07	10	\$444,200	9612.7
9	\$3,033,360	89.41	9	\$399,780	9620.2
8	\$2,696,320	88.76	8	\$355,360	9627.7
7	\$2,359,280	88.10	7	\$310,940	9635.2
6	\$2,022,240	87.45	6	\$266,520	9642.7
5	\$1,685,200	86.79	5	\$222,100	9650.2
4	\$1,348,160	86.14	4	\$177,680	9657.7
3	\$1,011,120	85.48	3	\$133,260	9665.2
2	\$674,080	84.83	2	\$88,840	9672.7
1	\$337,040	84.18	1	\$44,420	9680.2
					9687.7
0	\$0	83.52	0	\$0	9762.7
					9837.7
-1	\$144,800	82.27	-1	(\$44,420)	9845.2
-2	\$289,600	81.02	-2	(\$88,840)	9852.7
-3	\$434,400	79.77	-3	(\$133,260)	9860.2
-4	\$579,200	78.51	-4	(\$177,680)	9867.7
-5	\$724,000	77.26	-5	(\$222,100)	9875.2
-6	\$868,800	76.01	-6	(\$266,520)	9882.7
-7	\$1,013,600	74.76	-7	(\$310,940)	9890.2
-8	\$1,158,400	73.51	-8	(\$355,360)	9897.7
-9	\$1,303,200	72.26	-9	(\$399,780)	9905.2
-10	\$1,448,000	71.01	-10	(\$444,200)	9912.7

Equivalent Availability

Heat Rate

Weighting Factor:

Weighting Factor:

27.76%

3.66%

Issued by: FPC

Filed:

Suspended:

Effective:

Docket No.:

Order No.:

GENERATING PERFORMANCE INCENTIVE POINTS TABLE

Company: Florida Power Corporation
 Period of: Apr. 1997 - Sep. 1997
 Unit: Crystal River 3

Equivalent Availability (Points)	Fuel Savings/Loss (\$)	Equivalent Availability (%)	Average Heat Rate (Points)	Fuel Savings/Loss (\$)	Average Heat Rate (BTU/KWH)
10	\$0	0.00	10	\$0	0.0
9	\$0	0.00	9	\$0	0.0
8	\$0	0.00	8	\$0	0.0
7	\$0	0.00	7	\$0	0.0
6	\$0	0.00	6	\$0	0.0
5	\$0	0.00	5	\$0	0.0
4	\$0	0.00	4	\$0	0.0
3	\$0	0.00	3	\$0	0.0
2	\$0	0.00	2	\$0	0.0
1	\$0	0.00	1	\$0	0.0
					0.0
0	\$0	0.00	0	\$0	0.0
					0.0
-1	\$0	0.00	-1	\$0	0.0
-2	\$0	0.00	-2	\$0	0.0
-3	\$0	0.00	-3	\$0	0.0
-4	\$0	0.00	-4	\$0	0.0
-5	\$0	0.00	-5	\$0	0.0
-6	\$0	0.00	-6	\$0	0.0
-7	\$0	0.00	-7	\$0	0.0
-8	\$0	0.00	-8	\$0	0.0
-9	\$0	0.00	-9	\$0	0.0
-10	\$0	0.00	-10	\$0	0.0

Equivalent Availability

Weighting Factor:

0.00%

Heat Rate

Weighting Factor:

0.00%

Issued by: FPC

Filed:
 Suspended:
 Effective:
 Docket No.:
 Order No.:

GENERATING PERFORMANCE INCENTIVE POINTS TABLE

Company: Florida Power Corporation
 Period of: Apr. 1997 - Sep. 1997
 Unit: Crystal River 4

Equivalent Availability (Points)	Fuel Savings/Loss (\$)	Equivalent Availability (%)	Average Heat Rate (Points)	Fuel Savings/Loss (\$)	Average Heat Rate (BTU/KWH)
10	\$1,103,000	96.87	10	\$876,300	9139.0
9	\$992,700	96.59	9	\$788,670	9146.5
8	\$882,400	96.31	8	\$701,040	9154.0
7	\$772,100	96.03	7	\$613,410	9161.5
6	\$661,800	95.75	6	\$525,780	9169.0
5	\$551,500	95.47	5	\$438,150	9176.5
4	\$441,200	95.19	4	\$350,520	9184.0
3	\$330,900	94.91	3	\$262,890	9191.5
2	\$220,600	94.64	2	\$175,260	9199.0
1	\$110,300	94.36	1	\$87,630	9206.5
					9214.0
0	\$0	94.08	0	\$0	9289.0
					9364.0
-1	(\$265,470)	93.51	-1	(\$87,630)	9371.5
-2	(\$530,940)	92.94	-2	(\$175,260)	9379.0
-3	(\$796,410)	92.36	-3	(\$262,890)	9386.5
-4	(\$1,061,880)	91.79	-4	(\$350,520)	9394.0
-5	(\$1,327,350)	91.22	-5	(\$438,150)	9401.5
-6	(\$1,592,820)	90.65	-6	(\$525,780)	9409.0
-7	(\$1,858,290)	90.08	-7	(\$613,410)	9416.5
-8	(\$2,123,760)	89.51	-8	(\$701,040)	9424.0
-9	(\$2,389,230)	88.94	-9	(\$788,670)	9431.5
-10	(\$2,654,700)	88.37	-10	(\$876,300)	9439.0

Equivalent Availability

Weighting Factor:

9.09%

Heat Rate

Weighting Factor:

7.22%

Issued by: FPC

Filed:

Suspended:

Effective:

Docket No.:

Order No.:

GENERATING PERFORMANCE INCENTIVE POINTS TABLE

Company: Florida Power Corporation
 Period of: Apr. 1997 - Sep. 1997
 Unit: Crystal River 5

Equivalent Availability (Points)	Fuel Savings/Loss (\$)	Equivalent Availability (%)	Average Heat Rate (Points)	Fuel Savings/Loss (\$)	Average Heat Rate (BTU/KWH)
10	\$466,200	77.02	10	\$710,100	9117.4
9	\$419,580	76.87	9	\$639,090	9124.9
8	\$372,960	76.72	8	\$568,080	9132.4
7	\$326,340	76.57	7	\$497,070	9139.9
6	\$279,720	76.43	6	\$426,060	9147.4
5	\$233,100	76.28	5	\$355,050	9154.9
4	\$186,480	76.13	4	\$284,040	9162.4
3	\$139,860	75.98	3	\$213,030	9169.9
2	\$93,240	75.83	2	\$142,020	9177.4
1	\$46,620	75.68	1	\$71,010	9184.9
					9192.4
0	\$0	75.53	0	\$0	9267.4
					9342.4
-1	(\$105,110)	75.23	-1	(\$87,630)	9349.9
-2	(\$210,220)	74.92	-2	(\$175,260)	9357.4
-3	(\$315,330)	74.62	-3	(\$262,890)	9364.9
-4	(\$420,440)	74.31	-4	(\$350,520)	9372.4
-5	(\$525,550)	74.01	-5	(\$438,150)	9379.9
-6	(\$630,660)	73.70	-6	(\$525,780)	9387.4
-7	(\$735,770)	73.39	-7	(\$613,410)	9394.9
-8	(\$840,880)	73.09	-8	(\$701,040)	9402.4
-9	(\$945,990)	72.78	-9	(\$788,670)	9409.9
-10	(\$1,051,100)	72.48	-10	(\$710,100)	9417.4

Equivalent Availability
Weighting Factor:

3.84%

Heat Rate
Weighting Factor:

5.85%

Issued by: FPC

Filed:
Suspended:
Effective:
Docket No.:
Order No.:

ESTIMATED UNIT PERFORMANCE DATA

Company: Florida Power Corporation
 Period off: Apr. 1997 - Sep. 1997

PLANT/UNIT	Month of: Apr-97	Month of: May-97	Month of: Jun-97	Month of: Jul-97	Month of: Aug-97	Month of: Sep-97	Period of: Apr-97 - Sep. 1997
1. EAF	79.54	89.48	94.98	94.68	94.21	94.65	91.28
2. POF	16.67	6.45	0.00	0.00	0.00	0.00	3.83
3. EUDF	3.79	4.06	5.02	5.32	5.79	5.35	4.89
4. EUOR	5.87	5.87	5.87	5.87	5.87	5.87	5.87
5. PH	720	744	720	744	744	720	4392
6. SH	450.9	499.3	597.0	653.2	711.4	636.5	3548.3
7. RSH	134.4	180.5	103.6	69.5	9.4	62.9	560.4
8. UH	134.7	64.2	19.4	21.2	23.1	20.7	283.3
9. POH	120	48	0	0	0	0	168
10. FOH & EFOM	20.2	22.4	26.8	29.3	31.9	28.5	159.2
11. MOH & EMOH	7.1	7.8	9.4	10.3	11.2	10.0	55.7
12. Oper. Btu(MBtu)	1,672,132	1,924,636	2,375,220	2,663,626	2,796,836	2,599,221	14,033,136
13. Net Gen. (MMWh)	171,009	197,545	244,547	274,923	287,614	268,318	1,443,956
14. ANOHR (Btu/MMWh)	9,778	9,743	9,713	9,689	9,724	9,687	9,719
15. NOF (%)	74.2	77.4	80.2	82.4	79.1	82.5	79.6
16. NSC (MM)	511	511	511	511	511	511	511
17. ANOHR Equation	ANOHR =	-10.971	x NOF +	10592.2			

Issued by: FPC

Filed:
 Suspended:
 Effective:
 Docket No.:
 Order No.:

ESTIMATED UNIT PERFORMANCE DATA

Company: Florida Power Corporation
 Period of: Apr. 1997 - Sep. 1997

PLANT/UNIT	Month of: Apr-97	Month of: May-97	Month of: Jun-97	Month of: Jul-97	Month of: Aug-97	Month of: Sep-97	Period of: Apr-97 - Sep. 1997
Anclote 2							
1. EAF	95.80	96.01	95.27	95.08	94.73	95.06	95.32
2. POF	0.00	0.00	0.00	0.00	0.00	0.00	0.00
3. EUOF	4.20	3.99	4.73	4.92	5.27	4.94	4.68
4. EUOR	5.71	5.71	5.71	5.71	5.71	5.71	5.71
5. PH	720	744	720	764	744	720	4392
6. SH	519.8	510.7	585.3	629.6	673.9	611.5	3530.8
7. RSH	190.6	223.8	123.9	102.8	57.6	97.2	796.0
8. UH	9.6	9.4	10.8	11.6	12.4	11.3	65.2
9. POH	0	0	0	0	0	0	0
10. FOH & EFOH	22.8	22.4	25.6	27.6	29.5	26.8	154.6
11. MOH & EMOH	7.5	7.4	8.4	9.1	9.7	8.8	50.9
12. Oper. Btu(MBtu)	1,855,043	1,897,005	2,174,421	2,483,154	2,552,827	2,415,187	13,380,092
13. Net Gen. (MWh)	190,404	195,686	224,310	258,222	264,013	251,206	1,383,841
14. ANOHR (Btu/KWh)	9,743	9,694	9,694	9,616	9,669	9,614	9,669
15. NOF (%)	71.7	75.0	75.0	80.3	76.7	80.4	76.7
16. NSC (MW)	511	511	511	511	511	511	511
17. ANOHR Equation	ANOHR=	-14.726	x NOF +	10798.3			

Issued by: FPC

Filed:
 Suspended:
 Effective:
 Docket No.:
 Order No.:

ESTIMATED UNIT PERFORMANCE DATA

Company: Florida Power Corporation
 Period of: Apr. 1997 - Sep. 1997

PLANT/UNIT	Month of: Apr-97	Month of: May-97	Month of: Jun-97	Month of: Jul-97	Month of: Aug-97	Month of: Sep-97	Period of: Apr-97 - Sep. 1997
Crystal River 1							
1. EAF	90.71	90.71	90.71	90.71	90.71	73.62	88.73
2. POF	0.00	0.00	0.00	0.00	0.00	13.33	2.19
3. EUOF	9.29	9.29	9.29	9.29	9.29	8.05	9.09
4. EUOR	9.29	9.29	9.29	9.29	9.29	9.29	9.29
5. PH	720	744	720	744	744	720	4392
6. SH	680.3	703.0	580.3	703.0	703.0	589.6	4059.3
7. RSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0
8. LH	39.7	41.0	39.7	41.0	41.0	130.4	332.7
9. POH	0	0	0	0	0	96	96
10. FOM & EFOM	38.2	39.4	38.2	39.4	39.4	33.1	227.7
11. MOH & EMOH	28.7	29.7	28.7	29.7	29.7	24.9	171.4
12. Oper. Btu(MBtu)	2,365,381	2,371,716	2,347,334	2,425,583	2,425,583	2,034,921	13,970,717
13. Net Gen. (MWh)	242,547	242,176	240,435	248,450	248,450	208,443	1,430,501
14. ANOHR (Btu/KWh)	9,752	9,793	9,763	9,763	9,763	9,762	9,766
15. NOF (%)	95.8	92.6	95.0	95.0	95.0	95.0	94.7
16. NSC (MW)	372	372	372	372	372	372	372
17. ANOHR Equation	ANOHR=	-12.711	x NOF +	10970.4			

Issued by: FPC

Filed:
 Suspended:
 Effective:
 Docket No.:
 Order No.:

ESTIMATED UNIT PERFORMANCE DATA

Company: Florida Power Corporation

Period of: Apr. 1997 - Sep. 1997

PLANT/UNIT	Month of: Apr-97	Month of: May-97	Month of: Jun-97	Month of: Jul-97	Month of: Aug-97	Month of: Sep-97	Period of: Apr-97 - Sep. 1997
Crystal River 2							
1. EAF	74.00	85.39	85.39	85.39	85.39	85.39	83.52
2. POF	13.33	0.00	0.00	0.00	0.00	0.00	2.19
3. EUOF	12.66	14.61	14.61	14.61	14.61	14.61	14.29
4. EUOR	14.61	14.61	14.61	14.61	14.61	14.61	14.61
5. PH	720	744	720	744	744	720	4392
6. SH	551.7	657.8	636.6	657.8	657.8	636.6	3798.3
7. RSH	0	0	0	0	0	0	0
8. UH	168.3	86.2	83.4	86.2	86.2	83.4	593.7
9. POH	96	0	0	0	0	0	96
10. FOH & EFOH	42.0	50.1	48.5	50.1	50.1	48.5	289.2
11. MOH & EMOH	49.2	58.6	56.7	58.6	58.6	56.7	338.5
12. Oper. Btu(MBtu)	2,483,112	2,953,447	2,841,371	2,936,086	2,936,086	2,841,371	16,991,488
13. Net Gen. (MWh)	254,464	302,607	290,994	300,694	300,694	290,994	1,740,447
14. ANOHR (Btu/KWh)	9,758	9,760	9,764	9,764	9,764	9,764	9,763
15. NOF (%)	98.6	98.3	97.7	97.7	97.7	97.7	97.9
16. NSC (MW)	468	468	468	468	468	468	468
17. ANOHR Equation	ANOHR=	-7.009	x NOF +	10449.0			

Issued by: FPC

Filed:
 Suspended:
 Effective:
 Docket No.:
 Order No.:

ESTIMATED UNIT PERFORMANCE DATA

Company: Florida Power Corporation

Period of: Apr. 1997 - Sep. 1997

PLANT/UNIT	Month of: Apr-97	Month of: May-97	Month of: Jun-97	Month of: Jul-97	Month of: Aug-97	Month of: Sep-97	Period of: Apr-97 - Sep. 1997
Crystal River 4							
1. EAF	94.08	94.08	94.08	94.08	94.08	94.08	94.08
2. POF	0.00	0.00	0.00	0.00	0.00	0.00	0.00
3. EUOF	5.92	5.92	5.92	5.92	5.92	5.92	5.92
4. EUOR	5.92	5.92	5.92	5.92	5.92	5.92	5.92
5. PH	720	744	720	744	744	720	4392
6. SH	704.0	727.5	704.0	727.5	727.5	704.0	4294.3
7. RSH	0	0	0	0	0	0	0
8. UH	16.0	16.5	16.0	16.5	16.5	16.0	97.7
9. POH	0	0	0	0	0	0	0
10. FOH & EFOH	31.8	32.9	31.8	32.9	32.9	31.8	194.2
11. MOH & EMOH	10.8	11.2	10.8	11.2	11.2	10.8	65.8
12. Oper. Btu(MBtu)	4,485,791	4,496,242	4,383,852	4,529,987	4,529,979	4,383,860	26,809,992
13. Net Gen. (MWh)	483,956	483,538	471,815	487,543	487,542	471,816	2,886,210
14. ANOHR (Btu/KWh)	9,269	9,299	9,291	9,291	9,291	9,291	9,289
15. NOF (%)	98.6	95.4	96.2	96.2	96.2	96.2	96.4
16. NSC (MW)	697	697	697	697	697	697	697
17. ANOHR Equation	ANOHR =	-9.076	x NOF +	10164.2			

Issued by: FPC

Filed:

Suspended:

Effective:

Docket No.:

Order No.:

ESTIMATED UNIT PERFORMANCE DATA

Company: Florida Power Corporation

Period of: Apr. 1997 - Sep. 1997

PLANT/UNIT	Month of: Apr-97	Month of: May-97	Month of: Jun-97	Month of: Jul-97	Month of: Aug-97	Month of: Sep-97	Period of: Apr-97 - Sep. 1997
Crystal River 5							
1. EAF	0.00	68.12	95.99	95.99	95.99	95.99	75.53
2. POF	100.00	29.03	0.00	0.00	0.00	0.00	21.31
3. EUOF	0.00	2.84	4.01	4.01	4.01	4.01	3.15
4. EUOR	0.00	4.01	4.01	4.01	4.01	4.01	4.01
5. PH	720	744	720	744	744	720	4392
6. SH	0.0	516.2	703.9	727.4	727.4	703.9	3378.7
7. RSH	0	0	0	0	0	0	0
8. UH	720.0	227.6	16.1	16.6	16.6	16.1	1013.3
9. POH	720	216	0	0	0	0	936
10. FOH & EFOH	0.0	17.7	24.1	24.9	24.9	24.1	115.7
11. MOH & EMOH	0.0	3.5	4.7	4.9	4.9	4.7	22.8
12. Oper. Stu(MBtu)	0	3,316,336	4,522,728	4,673,490	4,673,490	4,522,728	21,708,772
13. Net Gen. (MWh)	0	357,848	488,027	504,295	504,295	488,027	2,342,492
14. ANOHR (Btu/KWh)	0	9,267	9,267	9,267	9,267	9,267	9,267
15. NOF (%)	0.0	99.5	99.5	99.5	99.5	99.5	99.5
16. NSC (MW)	697	697	697	697	697	697	697
17. ANOHR Equation	ANOHR=	-6.545	x NOF +	9918.4			

Issued by: FPC

Filed:
 Suspended:
 Effective:
 Docket No.:
 Order No.:

Original Sheet No.

PLANNED OUTAGE SCHEDULES
ESTIMATED

Company : Florida Power Corporation
Period of : April 1997 - September 1997

<u>Plant/Unit</u>	<u>Planned Outage Dates</u>	<u>Reason For Outage(1)</u>
1997		
Ancote 1	04/26(0001) - 05/02(2400)	Inspection
Crystal River 1	09/27(0001) -10/03(2400)	Inspection
Crystal River 2	03/01(0001) - 04/04(2400)	Boiler
Crystal River 5	03/29(0001) - 05/09(2400)	Boiler

⁽¹⁾ To be accompanied by a critical path bar chart or milestone date chart of major activity to be performed during the outage.

ISSUED BY: FPC

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO.:

FLORIDA POWER CORPORATION
PLAN FOR ANCLOTE #1 1807 BOILER INSPECTION

(indicating dates ending midnight/)

	4/26	04/27	04/28	04/29	04/30	05/01	05/02	05/03	05/04	05/05
Submitted plan period										

Start/End/Cooldown

Wash Air Heater
& Upper Furnaces

Boiler Tube
Inspection

Startup

Boiler Inspection
& Repairs

Clean Boiler


Mic. Valves
Inspection & Repair

Clean Circulating
Water Pits & Pipe

[REDACTED] - (DENOTES CRITICAL PATH)

FLORIDA POWER CORPORATION
PLANNED FOR CRYSTAL RIVER #1 1997 INSPECTION

(indicating dates ending midnight)



- (DENOTES CRITICAL PATH)

FLORIDA POWER CORPORATION
PLANNED FOR CRYSTAL RIVER #2 1997 BOILER

(indicating dates ending midnight)

	03/01	03/02	03/04	03/08	03/09	03/13	03/16	03/18	03/21	03/23	03/26	03/29	04/01	04/02	04/03	04/04	04/05	04/06	04/09
<i>submitted plan period</i>																			

Startdown/Cooldown

Wash Air Heater
& Upper Furnace

Boiler Tube Inspection

Boiler Inspection
and Repairs

Close Boiler

Startup

Cool Down Inspection
& Repair

Clean Circulating
Pits & Pipes

■ - (DENOTES CRITICAL PATH)

FLORIDA POWER CORPORATION
PLAN FOR CRYSTAL RIVER #5 1997 BOILER

(indicating dates ending midnight)

03/29 03/30 03/31 04/02 04/05 04/10 04/16 04/20 04/24 04/28 05/02 05/06 05/07 05/08 05/09 05/10 05/11 05/12 05/30
submitted plan period

Shutdown/Cooldown

Wash Air Heater
& Upper Furnace

Boiler Inspection
and Repairs

Clean Boiler

Startup

Cool Tower Inspection

Cool Tower Inspection
& Repair

Clean Circulating
Pits & Pipes

■ - □ DENOTES CRITICAL PATH

**AVERAGE NET OPERATING
HEAT RATE CURVES**

FLORIDA POWER CORPORATION

ANCLOTE UNIT 1

AVE. NET OPR. HEAT RATE = -10.971 * NOF + 10592.21

TABLE OF RESIDUALS


DATE	OUTPUT FACTOR	ACT MONTHLY HEATRATE	PROJECTED HEATRATE	DIFFERENCE (ACT-PROJ)	HEAT RATE RANGE @90% CONFID
Apr-94	60.1	9862.6	9932.9	-70.3	344.7
May-94	58.8	9927.8	9947.1	-19.3	344.7
Jun-94	56.2	9821.3	9975.6	-154.3	344.7
Jul-94	47.4	10640.7	10072.2	568.5	344.7
Aug-94	43.2	10338.3	10118.3	220.0	344.7
Sep-94	42.8	10264.4	10122.7	141.7	344.7
Apr-95	37.3	9837.5	10183.5	-346.0	344.7
May-95	44.5	10034.1	10104.4	-70.3	344.7
Jun-95	44.1	9922.6	10108.2	-185.6	344.7
Jul-95	50.5	10015.6	10038.0	-22.4	344.7
Aug-95	59.3	10090.8	9942.1	148.7	344.7
Sep-95	50.2	10244.2	10041.5	202.7	344.7
Apr-96	52.8	9804.0	10013.2	-209.3	344.7
May-96	56.1	9816.3	9976.9	-160.6	344.7
Jun-96	54.3	9851.7	9996.2	-144.5	344.7
Jul-96	59.9	10016.9	9935.1	81.7	344.7
Aug-96	52.7	10061.7	10013.8	47.9	344.7
Sep-96	57.7	9930.9	9959.6	-28.7	344.7

Regression Output:

Constant	10592.21472
Std Err of Y Est	215.6249693
R Squared	0.117257951
No. of Observations	18
Degrees of Freedom	16
X Coefficient(s)	-10.9709559
Std Err of Coef.	7.525411183

ANCLOTE UNIT 1

ANOHR = -10.971*NOF + 10592.2



APRIL 1997- SEPTEMBER 1997 TARGETS

FLORIDA POWER CORPORATION

ANCLOTE UNIT 2

AVE. NET OPR. HEAT RATE = -14.726 * NOF + 10798.30


TABLE OF RESIDUALS

DATE	OUTPUT FACTOR	ACT MONTHLY HEATRATE	PROJECTED HEATRATE	DIFFERENCE (ACT-PROJ)	HEAT RATE RANGE @90% CONFID
Apr-94	66.4	9862.7	9820.5	-157.8	260.3
May-94	59.9	9744.6	9916.2	-171.6	260.3
Jun-94	57.6	9965.5	9950.1	15.4	260.3
Jul-94	49.8	10143.3	10064.9	78.4	260.3
Aug-94	45.5	10163.1	10128.3	34.8	260.3
Sep-94	43.6	10145.9	10158.2	-10.3	260.3
Apr-95	67.3	10173.9	9806.7	367.2	260.3
May-95	46.5	10100.1	10113.6	-13.5	260.3
Jun-95	43.2	10190.2	10162.6	27.6	260.3
Jul-95	51.9	9984.3	10034.4	-50.1	260.3
Aug-95	59.0	9937.6	9929.1	8.5	260.3
Sep-95	49.5	10200.5	10068.7	131.8	260.3
Apr-96	44.7	10034.6	10139.7	-105.2	260.3
May-96	58.4	9870.3	9938.5	-268.2	260.3
Jun-96	59.5	9883.2	9922.6	-239.5	260.3
Jul-96	59.8	9935.7	9918.3	17.4	260.3
Aug-96	54.1	10238.5	10001.9	236.6	260.3
Sep-96	59.7	10017.8	9919.3	98.5	260.3

Regression Output:

Constant	10798.29902
Std Err of Y Est	162.8057114
R Squared	0.33841207
No. of Observations	18
Degrees of Freedom	16
X Coefficient(s)	-14.7261857
Std Err of Coef.	5.147556776

ANCLOTE UNIT 2

$$\text{ANOHR} = -14.726 * \text{NOF} + 10798.3$$


APRIL 1997 - SEPTEMBER 1997 TARGETS

FLORIDA POWER CORPORATION

CRYSTAL RIVER 1

AVE. NET OPR. HEAT RATE = -12.711 ° NOF + 10970.43

TABLE OF RESIDUALS


DATE	OUTPUT FACTOR	ACT MONTHLY HEATRATE	PROJECTED HEATRATE	DIFFERENCE (ACT-PROJ)	HEAT RATE RANGE @90% CONFID
Apr-94	90.8	9732.3	9815.9	-83.7	150.0
May-94	89.7	9888.0	9829.9	58.1	150.0
Jun-94	84.0	9926.7	9902.1	24.6	150.0
Jul-94	75.9	10129.2	10005.8	123.4	150.0
Aug-94	78.0	9980.5	9979.1	1.4	150.0
Sep-94	75.1	10089.3	10016.1	73.2	150.0
May-95	7.5	10863.7	10875.4	-11.7	150.0
Jun-95	76.2	9983.1	10002.1	-19.0	150.0
Jul-95	88.8	9836.8	9841.3	-4.4	150.0
Aug-95	84.1	9823.9	9901.7	-77.8	150.0
Sep-95	83.9	9897.9	9904.5	-6.7	150.0
Apr-96	78.5	9804.1	9972.3	-168.2	150.0
May-96	87.3	9887.3	9860.3	27.0	150.0
Jun-96	84.1	9932.0	9901.0	31.0	150.0
Jul-96	82.6	9910.1	9920.4	-10.3	150.0
Aug-96	79.7	9991.3	9957.7	33.6	150.0
Sep-96	83.7	9915.4	9906.0	9.4	150.0

Regression Output:

Constant	10970.42811
Std Err of Y Est	68.06728132
R Squared	0.929816883
No. of Observations	17
Degrees of Freedom	15
X Coefficient(s)	-12.7109421
Std Err of Coef.	0.901674366

CRYSTAL RIVER 1

ANOHR = -12.711*NOF + 10970.4



APRIL 1997 - SEPTEMBER 1997 TARGETS

FLORIDA POWER CORPORATION

CRYSTAL RIVER 2

AVE. NET OPR. HEAT RATE = -7.009 * NOF + 10448.99

TABLE OF RESIDUALS


DATE	OUTPUT FACTOR	ACT MONTHLY HEATRATE	PROJECTED HEATRATE	DIFFERENCE (ACT-PROJ)	HEAT RATE RANGE @90% CONFID
Apr-94	90.9	9690.0	9811.9	-121.9	150.0
May-94	84.2	9882.8	9858.8	24.0	150.0
Jun-94	84.8	9931.7	9854.6	77.1	150.0
Jul-94	78.7	9967.4	9897.4	70.0	150.0
Aug-94	78.1	9968.7	9901.6	67.1	150.0
Sep-94	76.1	9978.7	9915.6	63.1	150.0
Apr-95	73.3	9761.9	9935.1	-173.2	150.0
May-95	82.5	9779.1	9871.0	-91.9	150.0
Jun-95	72.7	9865.2	9939.7	-74.5	150.0
Jul-95	84.7	9948.1	9855.5	92.6	150.0
Aug-95	82.0	9877.8	9874.2	3.6	150.0
Sep-95	79.7	9813.6	9890.4	-76.8	150.0
Apr-96	89.6	9746.9	9821.2	-74.3	150.0
May-96	86.8	9862.9	9840.6	22.3	150.0
Jun-96	81.0	9900.9	9881.1	19.8	150.0
Jul-96	79.1	9913.3	9894.4	18.9	150.0
Aug-96	76.9	9999.0	9909.9	89.2	150.0
Sep-96	83.3	9930.2	9865.4	64.9	150.0

Regression Output:

Constant	10448.99026
Std Err of Y Est	83.72915249
R Squared	0.160758136
No. of Observations	18
Degrees of Freedom	16
X Coefficient(s)	-7.00921645
Std Err of Coef.	4.003746473

CRYSTAL RIVER 2

ANOHR = -7.009*NOF + 10449.0



APRIL 1997 - SEPTEMBER 1997 TARGETS

FLORIDA POWER CORPORATION

CRYSTAL RIVER 3

AVE. NET OPR. HEAT RATE = -22.652 * NOF + 12722.10

TABLE OF RESIDUALS


DATE	OUTPUT FACTOR	ACT MONTHLY HEATRATE	PROJECTED HEATRATE	DIFFERENCE (ACT-PROJ)	HEAT RATE RANGE @90% CONFID
Apr-94	76.1	10770.5	10998.3	-227.8	168.8
Jun-94	89.2	10785.4	10701.5	83.9	168.8
Jul-94	96.5	10583.6	10536.2	27.4	168.8
Aug-94	100.7	10508.6	10441.0	67.6	168.8
Sep-94	101.4	10433.2	10425.2	8.0	168.8
Apr-95	102.3	10337.6	10404.1	-66.4	168.8
May-95	101.5	10422.3	10422.9	-0.6	168.8
Jun-95	100.7	10429.3	10442.1	-12.7	168.8
Jul-95	99.0	10512.0	10478.9	33.2	168.8
Aug-95	98.1	10608.4	10499.7	108.7	168.8
Sep-95	97.8	10473.9	10506.1	-32.2	168.8
May-96	74.9	11213.7	11026.4	187.3	168.8
Jun-96	91.3	10683.6	10652.9	30.7	168.8
Jul-96	101.7	10371.2	10418.2	-46.9	168.8
Aug-96	94.5	10422.2	10582.3	-160.1	168.8

Regression Output:

Constant	12722.10112
Std Err of Y Est	106.2256317
R Squared	0.792624165
No. of Observations	15
Degrees of Freedom	13
X Coefficient(s)	-22.6520559
Std Err of Coef.	3.213522668

CRYSTAL RIVER 3

ANOHR = -22.652*NOF + 12722.1



APRIL 1997 - SEPTEMBER 1997 TARGETS

FLORIDA POWER CORPORATION

CRYSTAL RIVER 4

AVE. NET OPR. HEAT RATE = -9.076 * NOF + 10164.18

TABLE OF RESIDUALS


DATE	OUTPUT FACTOR	ACT MONTHLY HEATRATE	PROJECTED HEATRATE	DIFFERENCE (ACT-PROJ)	HEAT RATE RANGE +/- 150 BTU/KWH
Apr-94	66.7	9520.5	9558.8	-38.3	150.0
May-94	92.3	9276.3	9326.5	-50.2	150.0
Jun-94	86.6	9286.2	9378.2	-92.0	150.0
Jul-94	84.7	9436.6	9395.4	41.2	150.0
Aug-94	85.8	9437.3	9385.5	51.8	150.0
Sep-94	81.2	9399.7	9427.2	-27.5	150.0
Apr-95	79.4	9371.2	9443.3	-72.0	150.0
May-95	86.8	9311.3	9376.6	-65.3	150.0
Jun-95	80.4	9440.8	9434.2	6.6	150.0
Jul-95	87.1	9379.2	9373.2	6.0	150.0
Aug-95	93.2	9394.0	9318.0	76.0	150.0
Sep-95	90.0	9435.2	9347.1	88.1	150.0
Apr-96	81.6	9358.1	9423.9	-65.8	150.0
Jun-96	61.9	9686.6	9602.4	84.3	150.0
Jul-96	80.5	9405.7	9433.8	-28.1	150.0
Aug-96	84.2	9484.8	9399.9	84.9	150.0
Sep-96	94.3	9308.8	9308.4	0.4	150.0

Regression Output:

Constant	10164.18228
Std Err of Y Est	63.29063256
R Squared	0.614874891
No. of Observations	17
Degrees of Freedom	15
X Coefficient(s)	-9.07608803
Std Err of Coef.	1.85464421

CRYSTAL RIVER 4

ANOHR = -9.076*NOF + 10164.2



APRIL 1997 - SEPTEMBER 1997 TARGETS

FLORIDA POWER CORPORATION

CRYSTAL RIVER 5

AVE. NET OPR. HEAT RATE = -6.545 * NOF + 9918.40

TABLE OF RESIDUALS


DATE	OUTPUT FACTOR	ACT MONTHLY HEATRATE	PROJECTED HEATRATE	DIFFERENCE (ACT-PROJ)	HEAT RATE RANGE +/- 150 BTU/KWH
Apr-94	94.8	9320.6	9298.0	22.6	150.0
May-94	95.3	9180.4	9294.7	-114.3	150.0
Jun-94	84.3	9190.5	9366.7	-176.2	150.0
Jul-94	82.7	9417.2	9377.1	40.1	150.0
Aug-94	88.3	9366.9	9340.5	26.4	150.0
Sep-94	82.8	9320.4	9376.5	-56.1	150.0
Apr-95	79.7	9344.2	9397.1	-52.9	150.0
May-95	87.3	9279.9	9346.9	-67.0	150.0
Jun-95	82.4	9378.7	9379.3	-0.6	150.0
Jul-95	89.9	9386.0	9330.1	35.9	150.0
Aug-95	90.4	9342.7	9326.9	15.8	150.0
Sep-95	91.7	9402.2	9318.5	83.6	150.0
Apr-96	95.4	9156.5	9294.2	-137.7	150.0
May-96	96.2	9364.1	9288.9	75.1	150.0
Jun-96	84.8	9452.4	9363.3	89.1	150.0
Jul-96	88.8	9396.5	9337.0	59.4	150.0
Aug-96	84.4	9478.8	9366.1	112.7	150.0
Sep-96	89.9	9374.2	9330.2	44.0	150.0

Regression Output:

Constant	9918.402528
Std Err of Y Est	85.36002856
R Squared	0.139196396
No. of Observations	18
Degrees of Freedom	16
X Coefficient(s)	-6.5447925
Std Err of Coef.	4.068871122

CRYSTAL RIVER 5

ANOHR = -6.545*NOF + 9918.4



APRIL 1997 - SEPTEMBER 1997 TARGETS

UNPLANNED OUTAGE RATE

TABLES AND GRAPHS


UNIT UNAVAILABLE OUTAGE RATE SUMMARY

Company: Florida Power Corporation


Period of: Apr. 1997 - Sep. 1997

UNIT	RATE	LOW RANGE	HIGH RANGE	TARGET
Anclote 1	FOR	0.87	3.30	1.65
	MOR	0.81	3.09	1.55
	EFOR	1.47	5.61	2.81
	EMOR	0.00	0.00	0.00
	EUOR	3.11	11.46	5.87
	EUOF	1.90	6.98	3.57
Anclote 2	FOR	0.21	0.81	0.40
	MOR	0.75	2.84	1.42
	EFOR	2.08	7.94	3.97
	EMOR	0.00	0.00	0.00
	EUOR	3.02	11.28	5.71
	EUOF	1.81	6.76	3.43
Crystal River 1	FOR	0.83	3.17	1.58
	MOR	2.13	8.10	4.05
	EFOR	2.10	8.00	4.00
	EMOR	0.00	0.00	0.00
	EUOR	4.93	17.92	9.29
	EUOF	4.85	17.53	9.09
Crystal River 2	FOR	2.11	8.04	4.02
	MOR	4.30	10.37	8.18
	EFOR	1.80	6.85	3.42
	EMOR	0.00	0.00	0.00
	EUOR	7.82	27.41	14.61
	EUOF	7.75	26.81	14.29
Crystal River 3	FOR	3.05	11.60	5.80
	MOR	0.22	0.85	0.42
	EFOR	1.20	4.58	2.29
	EMOR	0.00	0.00	0.00
	EUOR	4.42	16.28	8.33
	EUOF	4.39	16.20	8.28
Crystal River 4	FOR	0.39	1.47	0.74
	MOR	0.79	3.02	1.51
	EFOR	1.99	7.56	3.78
	EMOR	0.00	0.00	0.00
	EUOR	3.13	11.63	5.92
	EUOF	3.13	11.63	5.92
Crystal River 5	FOR	0.83	3.18	1.59
	MOR	0.35	1.34	0.67
	EFOR	0.95	3.62	1.81
	EMOR	0.00	0.00	0.00
	EUOR	2.12	7.90	4.01
	EUOF	1.87	6.21	3.15


ANCLOTE UNIT 1
FORCED OUTAGE RATE




ANCLOTE UNIT 1
MAINTENANCE OUTAGE RATE




ANCLOTE UNIT 1
PARTIAL FORCED OUTAGE RATE




ANCLOTE UNIT 1
PARTIAL MAINTENANCE OUTAGE RATE



ANCLOTE UNIT 1
EQUIVALENT UNPLANNED OUTAGE RATE



ANCLOTE UNIT 1
EQUIVALENT UNPLANNED OUTAGE FACTOR




ANCLOTE
UNIT 1

	Oct-93	Nov-93	Dec-93	Jan-94	Feb-94	Mar-94	Apr-94	May-94	Jun-94	Jul-94	Aug-94	Sep-94	Oct-94	Nov-94	Dec-94	Jan-95	Feb-95	Mar-95
PER HOUR	745	720	530	744	559	679	719.0	744.0	720.0	744.0	744.0	720.0	745.0	720.0	744.0	744.0	672.0	744.0
SER HOUR	605.7	502.3	378.1	203.8	185.7	359.5	576.6	713.7	708.0	649.1	744.0	684.6	0.0	0.0	282.3	243.4	185.3	507.6
RSH	138.9	217.7	151.9	480.2	373.3	317.5	0.0	0.0	13.8	0.0	0.0	9.1	0.0	0.0	28.7	441.0	262.0	230.0
UH	0.4	0	0	0	0	2	142.4	303	0.2	94.9	0.0	26.3	745.0	720.0	435.0	59.6	4.7	64
POH	0	0	0	0	0	0	139.2	0.0	0.0	0.0	0.0	2.4	745.0	720.0	435.0	0.0	0.0	0.0
FOH	0.4	0	0	0	0	2	3.2	0.0	0.0	94.3	0.0	23.4	0.0	0.0	0.0	50	4.7	64
MOH	0	0	0	0	0	0	0.0	30.3	0.2	0.6	0.0	0.5	0.0	0.0	0.0	54.6	0.0	0.0
PFOH	62.9	45.8	0	5.7	0	14	32.8	52.9	71.4	134.4	116.4	38.3	0.0	0.0	0.0	0.0	18.6	0.4
LRPF	169.683	169.683	0	169.683	0	169.683	169.7	171.1	168.5	169.7	182.1	201.3	0.0	0.0	0.0	0.0	167.7	218.4
EFOH	20.9	15.2	0.0	1.9	0.0	4.6	10.9	17.7	28.3	44.6	41.5	15.1	0.0	0.0	0.0	0.0	6.1	0.2
PMOH	0	0	0	0	0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
LRPM	0	0	0	0	0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
EMOH	0	0	0	0	0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NPC	511	511	511	511	511	511	511.0	511.0	511.0	511.0	511.0	511.0	511.0	511.0	511.0	511.0	511.0	511.0
MONTHLY	Oct-93	Nov-93	Dec-93	Jan-94	Feb-94	Mar-94	Apr-94	May-94	Jun-94	Jul-94	Aug-94	Sep-94	Oct-94	Nov-94	Dec-94	Jan-95	Feb-95	Mar-95
FOR	0.07	0.00	0.00	0.00	0.00	0.55	0.55	0.00	0.00	12.68	0.00	3.31	0.00	0.00	0.00	2.01	1.21	1.25
MOR	0.00	0.00	0.00	0.60	0.00	0.00	0.00	4.07	0.03	0.00	0.00	0.07	0.00	0.00	0.00	18.32	0.00	0.00
PFOR	3.45	3.03	0.00	0.67	0.00	1.29	1.89	2.48	3.73	6.88	5.57	2.20	0.00	0.00	0.00	0.00	1.58	0.03
PMOR	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
EUOR	3.51	3.03	0.00	0.67	0.00	1.84	2.43	6.45	3.78	10.75	5.57	5.50	0.00	0.00	0.00	19.67	2.77	1.28
EUOF	2.86	2.11	0.00	0.25	0.00	0.98	1.95	6.45	3.69	10.75	5.57	5.41	0.00	0.00	0.00	8.01	1.61	0.86
POF	0.00	0.00	0.00	0.00	0.00	0.00	19.36	0.00	0.00	0.00	0.00	0.33	100.00	100.00	58.47	0.00	0.00	0.00
EAF	97.14	97.89	100.00	98.75	100.00	99.02	78.68	93.55	98.31	81.25	94.43	94.25	0.00	0.00	41.53	91.99	98.39	99.12
2.86	2.11	0.00	0.25	0.00	0.98	2.43	6.45	3.69	10.75	5.57	5.43	0.00	0.00	0.00	8.01	1.61	0.86	
12 MONTHS	Oct-93	Nov-93	Dec-93	Jan-94	Feb-94	Mar-94	Apr-94	May-94	Jun-94	Jul-94	Aug-94	Sep-94	Oct-94	Nov-94	Dec-94	Jan-95	Feb-95	Mar-95
FOR	0.07	0.04	0.03	0.02	0.02	0.10	0.19	0.16	0.13	1.97	1.72	1.69	2.08	2.27	2.32	2.43	2.42	2.43
MOR	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.83	0.70	0.62	0.54	0.49	0.54	0.59	0.61	1.65	1.59	1.55
PFOR	3.45	3.26	2.43	2.15	1.94	1.84	1.95	1.98	2.26	2.67	3.22	3.11	3.08	3.08	3.14	3.12	3.12	2.98
PMOR	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
EUOR	3.51	3.29	2.46	2.17	1.96	1.94	2.04	2.94	3.07	5.37	5.39	5.40	5.60	5.84	5.94	7.00	6.93	6.75
EUOF	2.86	2.49	1.83	1.40	1.16	1.13	1.26	1.97	2.17	3.98	4.11	4.23	3.97	3.79	3.70	4.37	4.44	4.40
POF	0.00	0.00	0.00	0.00	0.00	0.00	2.98	2.58	2.26	2.02	1.82	1.69	10.60	19.20	23.79	23.79	23.48	23.31
EAF	97.14	97.51	98.17	98.60	98.84	98.87	95.78	95.47	95.57	94.03	94.07	94.08	85.43	77.01	72.51	71.84	72.08	72.29


ANCLOTE
UNIT 1

	Apr-95	May-95	Jun-95	Jul-95	Aug-95	Sep-95	Oct-95	Nov-95	Dec-95	Jan-96	Feb-96	Mar-96	Apr-96	May-96	Jun-96	Jul-96	Aug-96	Sep-96
PER HOURS	719.0	744.0	720.0	744.0	744.0	720.0	745.0	720.0	744.0	744.0	698.0	744.0	719	744	720	744	744	720
SER HOURS	323.7	708.9	632.1	744.0	744.0	695.6	348.0	408.2	412.7	402.7	242.9	253.5	485.2	744.0	695.6	725.8	722.1	720.0
RSH	357.4	0.0	2.0	0.0	0.0	0.0	63.3	174.1	331.3	200.9	201.7	34.0	230.1	0.0	0.0	0.0	0.0	0.0
UH	37.9	37.1	65.9	0.0	0.0	24.4	335.7	77.7	0.0	0.4	251.4	458.5	57	0.0	544	384	219	0.0
POH	0.0	37.1	40.8	0.0	0.0	0.0	0.0	0.0	0.0	0.4	0.0	175	0.0	0.0	544	7.9	3.4	0.0
MOH	37.9	0.0	45.1	0.0	0.0	0.0	0.0	77.7	0.0	0.0	0.0	0.0	5.7	0.0	0.0	10.3	185	0.0
PFOH	77.5	105.8	80.8	78.0	111.0	65.8	0.0	6.4	9.8	14.5	0.0	2.8	73.8	77.7	65.4	75.3	118.2	61.4
URPF	52.9	211.0	180.6	188.0	157.7	108.2	0.0	180.7	169.7	161.9	0.0	147.0	70.5	187.8	189.7	177.3	148.2	23.5
EROF	0.0	43.7	30.0	25.0	34.3	21.3	0.0	2.1	3.3	4.6	0.0	0.8	11.3	28.5	21.7	28.1	34.3	2.8
PMOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
LRPM	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
EMOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NPC	511.0	511.0	511.0	511.0	511.0	511.0	511.0	511.0	511.0	511.0	511.0	511.0	511.0	511.0	511.0	511.0	511.0	511.0
MONTHLY	Apr-95	May-95	Jun-95	Jul-95	Aug-95	Sep-95	Oct-95	Nov-95	Dec-95	Jan-96	Feb-96	Mar-96	Apr-96	May-96	Jun-96	Jul-96	Aug-96	Sep-96
FOR	0.00	4.99	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.48	0.00	0.00	7.58	1.08	0.47	0.00	
MOR	10.48	0.00	0.88	0.00	0.00	0.00	0.00	14.23	0.00	0.00	0.00	0.00	1.17	0.00	0.00	1.40	2.50	0.00
PFOR	2.48	6.18	4.74	3.36	4.91	3.97	0.00	0.45	0.80	0.95	0.00	0.32	2.34	3.63	3.28	3.60	4.75	0.39
PMOR	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
EUOR	12.70	10.88	16.14	3.58	4.91	3.07	0.00	14.82	0.00	1.03	0.00	0.75	3.48	3.83	10.57	5.98	7.55	0.39
EUOF	6.30	10.88	18.09	3.36	4.91	2.98	0.00	11.09	0.44	0.67	0.00	2.48	2.37	3.83	10.57	5.98	7.55	0.39
POF	0.00	0.00	0.00	0.00	0.00	3.39	45.08	0.00	0.00	38.12	59.01	0.00	0.00	0.00	2.45	0.00	0.00	0.00
EAF	83.61	90.14	83.91	96.94	65.39	83.65	54.94	88.91	88.58	89.33	63.88	38.53	97.83	88.17	88.43	91.60	92.45	88.61
8.39	10.86	18.09	3.38	4.91	3.07	0.00	11.09	0.44	0.67	0.00	2.37	3.83	10.57	6.11	7.55	0.38		
12 MONTHS	Apr-95	May-95	Jun-95	Jul-95	Aug-95	Sep-95	Oct-95	Nov-95	Dec-95	Jan-96	Feb-96	Mar-96	Apr-96	May-96	Jun-96	Jul-96	Aug-96	Sep-96
FOR	2.40	3.16	3.94	2.18	2.19	1.75	1.85	1.52	1.49	1.37	1.33	1.58	1.52	0.93	1.14	1.26	1.32	1.32
MOR	2.31	1.78	2.82	2.58	2.58	2.55	2.39	3.42	3.35	2.43	2.48	2.50	2.03	2.01	1.31	1.47	1.77	1.76
PFOR	3.94	3.55	3.67	3.23	3.09	3.20	3.00	2.81	2.80	2.77	2.73	2.88	2.84	2.58	2.43	2.48	2.47	2.16
PMOR	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
EUOR	7.39	8.19	0.79	7.71	7.58	7.28	6.85	7.51	7.41	6.40	6.38	6.81	6.23	5.41	4.79	5.09	5.43	5.13
EUOF	4.77	5.14	6.18	4.85	4.77	4.57	4.57	5.48	5.52	4.89	4.70	4.88	4.58	3.97	3.81	3.73	3.98	3.77
POF	21.72	21.72	21.72	21.72	21.72	21.97	17.30	9.88	4.11	4.11	6.98	11.08	11.98	11.98	11.98	12.17	12.17	11.98
EAF	73.52	73.14	72.12	73.43	73.51	73.48	78.14	85.44	90.37	91.00	88.28	83.15	83.48	84.07	84.53	84.10	83.85	84.34


**ANCLOTE UNIT 2
FORCED OUTAGE RATE**





ANCLOTE UNIT 2
MAINTENANCE OUTAGE RATE



ANCLOTE UNIT 2
PARTIAL FORCED OUTAGE RATE






ANCLOTE UNIT 2		Oct-93	Nov-93	Dec-93	Jan-94	Feb-94	Mar-94	Apr-94	May-94	Jun-94	Jul-94	Aug-94	Sep-94	Oct-94	Nov-94	Dec-94	Jan-95	Feb-95	Mar-95
PER HOUR	745	392	744	744	655	655	719.0	744.0	720.0	744.0	720.0	744.0	744.0	720.0	744.0	744.0	744.0	744.0	
SHR HOUR	677.9	301.3	622.2	329.9	98.5	480	578.6	713.7	708.0	649.1	744.0	684.6	724.2	437.3	265.3	301.7	315.6	252.2	
RSH	67.1	90.3	121.8	414.1	505.5	195.7	6.0	0.0	13.8	0.0	0.0	9.1	20.8	59.4	268.3	442.3	356.4	491.8	
UH	0	0	0	0	0	0	0	142.4	30.3	0.2	94.9	0.0	26.3	0.0	193.3	212.4	0.0	0.0	
POH	0	0	0	0	0	0	0	0	0.0	0.0	0.0	0.0	2.4	0.0	193.3	212.4	0.0	0.0	
FOH	0	0	0	0	0	0	0	0	3.2	0.0	94.3	0.0	23.4	0.0	0.0	0.0	0.0	0.0	
MOH	0	0	0	0	0	0	0	0	0	0.0	30.3	0.2	0.6	0.0	0.5	0.0	0.0	0.0	
PFOH	64.6	0	10.1	9	25.6	28.1	13	32.8	52.9	71.4	134.4	116.4	38.3	45.2	12.5	0.3	0.0	5.7	
LRPF	170.333	0	177.498	170.333	73	170.333	168.7	171.1	188.5	189.7	182.1	201.3	170.3	406.4	0.0	203.4	81.6	81.6	
EFOH	21.5	0	6.6	8.5	3.7	4.3	10.9	17.7	26.3	44.6	41.5	15.1	4.2	0.3	0.0	2.3	3.9	3.9	
PMOH	0	0	0	0	0	0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
LRPM	0	0	0	0	0	0	0	0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
EMOH	0	0	0	0	0	0	0	0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
NPC	511	511	511	511	511	511	511.0	511.0	511.0	511.0	511.0	511.0	511.0	511.0	511.0	511.0	511.0	511.0	
MONTHLY	Oct-93	Nov-93	Dec-93	Jan-94	Feb-94	Mar-94	Apr-94	May-94	Jun-94	Jul-94	Aug-94	Sep-94	Oct-94	Nov-94	Dec-94	Jan-95	Feb-95	Mar-95	
FOR	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	12.68	0.00	3.31	0.00	0.00	0.00	0.00	0.00	0.00	
MOR	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	4.07	0.03	0.09	0.00	0.07	0.00	0.00	0.00	0.00	0.00	
PFOR	3.18	0.00	1.07	2.59	3.75	0.94	1.89	2.48	3.73	6.88	5.57	2.20	2.08	0.89	0.11	0.00	0.72	1.56	
PMOR	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
ELUR	3.18	0.00	1.07	2.59	3.75	0.94	2.43	3.45	3.73	18.75	5.57	5.50	2.03	0.69	0.11	0.00	0.72	1.56	
EUOF	2.89	0.00	0.69	1.15	0.57	0.65	1.82	0.45	3.69	18.75	5.57	5.41	2.02	0.58	0.04	0.00	0.34	0.53	
POF	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.33	0.00	26.85	28.55	0.00	0.00	0.00	
EAF	97.11	100.00	98.11	98.85	99.43	99.34	78.69	93.55	93.31	91.25	94.43	94.25	97.98	72.57	71.41	100.00	99.63	99.47	
12 MONTHS	Oct-93	Nov-93	Dec-93	Jan-94	Feb-94	Mar-94	Apr-94	May-94	Jun-94	Jul-94	Aug-94	Sep-94	Oct-94	Nov-94	Dec-94	Jan-95	Feb-95	Mar-95	
FOR	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.10	0.08	0.07	1.86	1.81	1.80	1.75	1.85	1.80	1.85	
MOR	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.70	0.69	0.60	0.53	0.49	0.46	0.46	0.49	0.49	0.49	
PFOR	3.18	2.89	0.00	0.89	1.15	0.57	0.65	2.43	6.45	3.69	18.75	5.57	5.43	2.02	0.79	0.05	0.00	0.34	0.53
PMOR	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
ELUR	3.18	2.89	0.00	0.89	1.15	0.57	0.65	1.82	3.69	18.75	5.57	5.43	2.02	0.79	0.05	0.00	0.34	0.53	
EUOF	2.89	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
POF	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
EAF	97.11	98.11	98.85	99.43	99.34	99.35	78.69	93.55	93.31	91.25	94.43	94.25	97.98	72.57	71.41	100.00	99.63	99.47	

ANCLOTE
UNIT 2

	Apr-95	May-95	Jun-95	Jul-95	Aug-95	Sep-95	Oct-95	Nov-95	Dec-95	Jan-96	Feb-96	Mar-96	Apr-96	May-96	Jun-96	Jul-96	Aug-96	Sep-96
PER HOURS	719.0	744.0	720.0	744.0	744.0	720.0	745.0	720.0	744.0	744.0	698.0	744.0	719	744	720	744	744	720
SER HOURS	183.0	723.3	691.8	743.0	744.0	720.0	348.0	488.2	412.7	482.7	742.0	253.5	719	744	682.4	744	744	677.6
RSH	361.0	5.4	0.0	0.0	0.0	0.0	83.3	174.1	331.3	280.9	201.7	34.0	0	0	0	0	0	0
UH	165.0	15.3	28.4	1.0	0.0	0.0	335.7	77.7	0.0	0.4	251.4	456.5	0	0	27.8	0	0	42.4
POH	0.0	0.0	0.0	0.0	0.0	0.0	335.7	0.0	0.0	0.0	251.4	439.0	0	0	0	0	0	0
FOH	0.0	15.3	28.4	1.0	0.0	0.0	0.0	0.0	0.0	0.4	0.0	17.5	0	0	0	0	0	0
MOH	165.0	0.0	0.0	0.0	0.0	0.0	77.7	0.0	0.0	0.0	0.0	0.0	0	0	27.8	0	0	42.4
PFOH	0.0	44.4	116.1	914.4	282.6	104.8	0.0	6.4	9.9	14.5	0.0	2.8	96.4	125.9	89.9	169	227.4	133.5
LRFF	0.0	175.4	247.5	110.8	192.4	147.8	0.0	169.7	169.7	161.9	0.0	147.0	61.9	102.8	194.5	105.6	74	68.1
EFOH	0.0	15.2	58.2	60.1	98.5	30.2	0.0	21	33	4.8	0.0	0.8	11.7	25.3	32.5	34.9	32.9	17.8
PMOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0	0	0	0	0	0
LRPM	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0	0	0	0	0	0
EMOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NPC	511.0	511.0	511.0	511.0	511.0	511.0	511.0	511.0	511.0	511.0	511.0	511.0	511	511	511	511	511	511
MONTHLY	Apr-95	May-95	Jun-95	Jul-95	Aug-95	Sep-95	Oct-95	Nov-95	Dec-95	Jan-96	Feb-96	Mar-96	Apr-96	May-96	Jun-96	Jul-96	Aug-96	Sep-96
FOR	0.00	2.07	3.94	0.13	0.00	0.00	0.00	0.00	0.00	0.00	0.00	6.46	0.00	0.00	0.00	0.00	0.00	0.00
MOR	48.00	0.00	0.00	0.00	0.00	0.00	0.00	14.23	0.00	0.00	0.00	0.00	0.00	3.83	0.00	0.00	5.89	
PFOR	0.00	2.11	0.13	0.16	13.29	4.20	0.00	0.45	0.80	0.95	0.00	0.32	1.82	3.40	4.89	4.43	2.83	
PMOR	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
EUOR	48.00	4.13	11.76	9.26	13.29	4.20	0.00	14.62	0.80	1.03	0.00	6.75	1.82	3.40	8.34	4.89	4.43	8.38
EUOF	22.85	4.10	11.76	9.26	13.29	4.20	0.00	11.00	0.44	0.67	0.00	2.48	1.82	3.40	8.34	4.89	4.43	8.36
POF	0.00	0.00	0.00	0.00	0.00	0.00	45.00	0.00	0.00	0.00	38.12	50.01	0.00	0.00	0.00	0.00	0.00	
EAF	77.05	95.90	88.24	90.72	88.71	85.80	54.94	88.91	88.58	88.33	63.88	38.53	88.38	88.80	91.88	95.31	95.57	91.84
	22.85	4.10	11.76	9.26	13.29	4.20	0.00	11.00	0.44	0.67	0.00	0.00	1.82	3.40	8.34	4.89	4.43	8.38
12 MONTHS	Apr-95	May-95	Jun-95	Jul-95	Aug-95	Sep-95	Oct-95	Nov-95	Dec-95	Jan-96	Feb-96	Mar-96	Apr-96	May-96	Jun-96	Jul-96	Aug-96	Sep-96
FOR	1.92	2.16	2.61	1.10	1.10	0.72	0.77	0.77	0.75	0.73	0.74	1.03	0.65	0.72	0.29	0.27	0.27	0.27
MOR	3.18	2.69	2.69	2.64	2.64	2.82	2.78	4.04	3.94	3.83	3.88	3.87	1.17	1.17	1.58	1.58	1.58	2.21
PFOR	2.84	2.80	3.30	3.83	4.57	4.79	4.85	4.81	4.74	4.88	4.88	4.84	4.45	4.59	4.22	3.72	2.72	2.54
PMOR	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
EUOR	7.87	7.40	8.30	7.18	8.09	7.94	8.19	9.33	9.16	8.98	9.04	9.24	8.45	8.37	8.00	5.49	4.51	4.95
EUOF	5.54	5.34	6.00	5.20	5.85	5.75	5.58	6.45	6.48	8.54	6.49	6.88	4.91	4.85	4.57	4.18	3.43	3.77
POF	4.00	4.00	4.00	4.00	4.00	4.00	4.00	4.00	4.00	4.00	11.69	11.68	11.68	11.68	11.68	11.68	11.68	11.68
EAF	88.80	90.00	89.34	90.14	89.49	88.81	85.95	87.30	88.89	88.83	88.82	81.88	83.41	83.47	83.75	84.13	84.89	84.54


CRYSTAL RIVER UNIT 1

FORCED OUTAGE RATE




CRYSTAL RIVER UNIT 1


MAINTENANCE OUTAGE RATE




CRYSTAL RIVER UNIT 1
PARTIAL FORCED OUTAGE RATE




CRYSTAL RIVER UNIT 1
PARTIAL MAINTENANCE OUTAGE RATE



CRYSTAL RIVER UNIT 1
EQUIVALENT UNPLANNED OUTAGE RATE



CRYSTAL RIVER UNIT 1
EQUIVALENT UNPLANNED OUTAGE FACTOR




**CRYSTAL
POWER
UNIT 1**

	Oct-83	Nov-83	Dec-83	Jan-84	Feb-84	Mar-84	Apr-84	May-84	Jun-84	Jul-84	Aug-84	Sep-84	Oct-84	Nov-84	Dec-84	Jan-85	Feb-85	Mar-85	
PER HOUR	745	770	744	744	677	744	718	700	720	744	744	720	744	720	744	744	744	744	
PER HOUR	738.2	589.7	728.9	721.2	65.9	611.5	718.9	713.1	600.5	711.5	670.3	720.0	745.0	720.0	744.0	672.0	672.0	744.0	
RSH	0	120.1	17.1	12.8	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
LH	8.8	4	0	0	0	0	678.2	132.5	0	119.5	32.5	64.7	0.0	25.2	88.6	116.3	0.0	0.0	
POH	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
FCH	0.8	0	0	0	0	0	0	0	0	0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
MCH	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
PFCH	303.9	22.8	34.4	22.3	11.1	308.7	16.9	20.5	359.2	61.9	64.9	80.5	347.0	58.0	60.3	26.0	34.6	22.7	
LFYF	69.73865	158.00003	120.57393	115.11124	70.24324	15.584239	108.2	138.2	32.9	70.8	137.1	120.3	50.1	163.2	179.3	186.0	186.0	225.6	
EFCH	72.9	18.1	11.2	7.2	2.3	18.7	7.2	10.9	31.8	68.7	22.9	30.9	48.8	24.1	32.0	12.0	17.3	23.0	
PACH	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
LPCM	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
EMCH	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
NPC	372	372	372	372	372	372	372	372	372	372	372	372	372	372	372	372	372	372	
MONTHLY	Oct-83	Nov-83	Dec-83	Jan-84	Feb-84	Mar-84	Apr-84	May-84	Jun-84	Jul-84	Aug-84	Sep-84	Oct-84	Nov-84	Dec-84	Jan-85	Feb-85	Mar-85	
FOR	1.18	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	13.57	0.00	1.02	0.00	0.00	0.00	0.00	0.00	0.00	
MOR	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	4.15	4.03	4.37	7.53	0.00	2.30	4.87	5.40	0.00	
PPOR	18.53	1.00	1.53	0.50	2.37	2.73	0.50	1.53	0.50	13.55	3.52	4.97	0.50	3.00	5.00	1.91	2.57	5.70	
PMOR	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
ELDR	11.69	1.00	1.53	0.50	2.37	0.73	0.50	0.50	0.50	21.61	17.30	11.91	4.97	9.67	13.12	10.90	1.91	2.57	10.71
ELCF	11.09	1.00	1.53	0.50	0.57	0.34	7.05	0.00	0.00	21.61	17.30	11.91	4.97	9.67	12.60	8.00	1.81	2.57	8.23
POF	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
EAF	88.971	98.00	98.00	98.00	98.00	98.00	98.00	98.00	98.00	98.00	98.00	98.00	98.00	98.00	98.00	97.43	97.43	97.43	
ELCFC	11.69	1.00	1.53	0.50	2.37	0.73	0.50	0.50	0.50	21.61	17.30	11.91	4.97	9.67	12.60	8.00	1.81	2.57	10.71
12 MONTH	Oct-83	Nov-83	Dec-83	Jan-84	Feb-84	Mar-84	Apr-84	May-84	Jun-84	Jul-84	Aug-84	Sep-84	Oct-84	Nov-84	Dec-84	Jan-85	Feb-85	Mar-85	
FOR	1.52	1.00	1.64	1.70	1.70	1.77	1.67	1.67	1.67	1.00	1.00	1.00	1.00	1.00	1.00	1.74	1.81	1.72	
MOR	4.65	4.18	4.30	4.65	4.81	4.63	4.50	4.79	4.79	4.00	4.00	4.00	4.00	4.00	4.00	3.50	3.50	3.22	
PPOR	4.00	3.79	3.00	2.94	4.05	4.00	4.10	4.23	4.23	4.23	4.23	4.23	4.23	4.23	4.23	4.11	4.47	4.67	
PMOR	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
ELDR	9.29	9.23	9.44	9.70	10.01	10.05	10.00	10.43	10.43	10.20	9.16	7.98	7.72	8.84	9.47	9.65	9.17	9.29	
ELCF	8.29	8.21	8.41	8.62	8.67	8.12	8.17	9.45	9.45	9.17	7.32	7.12	7.00	7.92	8.53	8.55	8.63	8.63	
POF	8.59	9.52	9.12	10.12	7.80	7.73	7.59	8.20	8.20	8.21	7.63	7.63	7.63	7.63	7.63	7.63	1.65	3.54	
EAF	82.72	82.54	82.67	81.57	81.51	82.00	82.10	82.10	82.10	82.25	84.37	85.24	85.24	85.24	85.24	85.24	83.79	83.79	83.79


CRYSTAL
RIVER
UNIT 1

	Apr-85	May-85	Jun-85	Jul-85	Aug-85	Sep-85	Oct-85	Nov-85	Dec-85	Jan-86	Feb-86	Mar-86	Apr-86	May-86	Jun-86	Jul-86	Aug-86	Sep-86
PER HOUR	719.0	744.0	744.0	728.0	745.0	720.0	744.0	744.0	744.0	744.0	744.0	719.0	744.0	720.0	744.0	744.0	744.0	720.0
PER 24 HOUR	50.1	633.5	633.5	625.6	719.4	745.0	481.7	744.0	744.0	744.0	744.0	698.0	744.0	744.0	744.0	744.0	744.0	743.2
FISH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
UH	719.0	603.0	385.2	110.5	10.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
POH	719.0	608.4	608.4	608.4	608.4	608.4	608.4	608.4	608.4	608.4	608.4	608.4	608.4	608.4	608.4	608.4	608.4	608.4
FCH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
MCH	0.0	27.5	28.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
PFCH	0.0	0.0	0.0	138.2	612	117.2	93.0	93.7	10.3	48.0	62.0	128.7	22.0	103.0	307.3	90.3	179.3	71.6
LIFC	0.0	0.0	0.0	112.0	106.7	139.8	134.5	141.0	100.5	137.0	122.4	87.7	67.0	0	37.50	122.00	80.40	50.50
EFCH	0.0	0.0	0.0	41.0	44.0	31.4	35.5	6.3	18.1	21.2	30.3	4.2	6.4	30.2	40.1	29.0	30.9	9.4
PACH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0	0	0	0
LAPM	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0	0	0	0
EACH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
HPC	372.0	372.0	372.0	372.0	372.0	372.0	372.0	372.0	372.0	372.0	372.0	372.0	372.0	372.0	372.0	372.0	372.0	372.0
MONTHLY	Apr-85	May-85	Jun-85	Jul-85	Aug-85	Sep-85	Oct-85	Nov-85	Dec-85	Jan-86	Feb-86	Mar-86	Apr-86	May-86	Jun-86	Jul-86	Aug-86	Sep-86
FOR	0.00	0.00	14.05	2.47	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
MCR	0.00	26.44	5.04	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PFOR	0.00	0.00	0.00	0.13	2.00	0.07	4.35	4.77	1.14	2.44	2.05	0.59	1.17	4.51	5.57	4.15	5.23	1.39
PRDR	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ELDR	0.00	35.44	10.00	17.32	5.20	4.44	4.77	38.61	2.44	2.55	5.00	34.70	11.50	5.65	8.00	5.33	3.64	3.64
ELCF	0.00	3.70	10.00	17.32	5.20	4.44	4.77	30.61	2.44	2.55	5.00	34.70	13.50	5.65	8.00	5.23	3.64	3.64
POF	100.00	89.57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
EAF	0.00	0.73	59.14	62.00	91.01	95.50	95.22	63.20	97.50	97.15	95.04	95.00	95.22	95.19	94.35	91.91	94.07	95.26
EUCF	8.00	35.44	10.00	17.32	5.20	4.44	4.77	38.61	2.44	2.55	5.00	34.70	11.50	5.65	8.00	5.33	3.64	3.64
12 MONTH	Apr-85	May-85	Jun-85	Jul-85	Aug-85	Sep-85	Oct-85	Nov-85	Dec-85	Jan-86	Feb-86	Mar-86	Apr-86	May-86	Jun-86	Jul-86	Aug-86	Sep-86
FOR	1.00	2.00	0.04	2.23	2.48	2.00	1.95	1.93	1.92	1.84	1.72	2.20	2.20	1.23	1.01	1.01	1.01	1.01
MCR	3.54	2.05	3.00	2.00	2.00	2.00	2.00	2.00	2.00	4.97	4.95	7.51	8.91	8.40	6.42	6.42	6.42	6.42
PFOR	6.00	6.40	5.00	4.23	4.81	4.54	4.25	4.10	3.63	3.60	3.62	3.40	3.57	3.64	3.57	3.57	3.57	3.57
PRDR	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ELDR	10.00	10.97	9.70	9.40	9.24	9.00	11.21	10.20	9.93	12.13	12.00	11.05	10.87	10.54	10.54	10.54	10.54	10.54
ELCF	8.95	8.39	7.95	7.55	7.21	6.79	8.77	8.24	8.35	8.47	8.37	11.21	12.00	11.65	10.87	10.87	10.87	10.87
POF	11.74	10.35	10.35	10.35	10.35	10.35	10.35	10.35	10.35	10.77	10.77	7.59	0.00	0.00	0.00	0.00	0.00	0.00
EAF	78.70	72.23	72.23	72.23	72.23	72.23	72.23	72.23	72.23	72.41	72.41	72.41	72.41	72.41	72.41	72.41	72.41	72.41


CRYSTAL RIVER UNIT 2
FORCED OUTAGE RATE




CRYSTAL RIVER UNIT 2
MAINTENANCE OUTAGE RATE




CRYSTAL RIVER UNIT 2
PARTIAL FORCED OUTAGE RATE




CRYSTAL RIVER UNIT 2
PARTIAL MAINTENANCE OUTAGE RATE



CRYSTAL RIVER UNIT 2
EQUIVALENT UNPLANNED OUTAGE RATE



CRYSTAL RIVER UNIT 2
EQUIVALENT UNPLANNED OUTAGE FACTOR



**CRYSTAL
RIVER
UNIT 2**


PER HOUR	Nov-83	Dec-83	Jan-84	Feb-84	Mar-84	Apr-84	May-84	Jun-84	Jul-84	Aug-84	Sep-84	Oct-84	Nov-84	Dec-84	Jan-85	Feb-85	Mar-85	
PER HOUR	745	729	744	744	744	744	744	729	729	744	744	744	744	729	729	744	744	
SEER HOUR	22.1	0	144	575.4	670.5	509	687.4	543.4	686.3	692.3	744.0	729.0	745.0	729.0	744.0	672.0	744.0	
RSH	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
UH	722.9	729	600	169.6	1.5	175	51.6	200.6	23.7	161.7	40.1	6.6	163.6	487.9	506.6	114.0	643.5	
POH	722.9	729	514.2	0	0	0	0	0	0	0	0	0	0	0	372.6	377.6	0.0	0.0
FCH	0	0	0	4.6	1.3	185.6	0.0	6.4	15.3	161.7	0.0	0.0	2.3	34.1	39.0	0.0	0.0	
SCFH	0	0	0	85.8	194.1	0	185.6	91.6	184.2	8.4	0.0	40.1	6.0	161.5	0.0	90.2	133.5	
PFCH	0	0	0	261.3	64.5	265.8	14.7	49.3	27.1	61.6	50.0	69.2	21.3	148.9	68.4	28.4	0.0	
UFCH	0	0	0	85.195865	124.37032	135.11964	0.1	202.2	196.7	223.3	234.0	189.3	73.5	75.5	93.6	74.6	0.0	181.3
UFFF	0.0	0.0	0.0	41.9	17.1	71.1	2.8	21.3	11.4	20.8	25.0	24.0	3.4	11.3	17.7	4.5	0.0	11.7
EFCH	0.0	0.0	0.0	0	0	0	0	0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
PFCH	0.0	0.0	0.0	0	0	0	0	0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
LPHM	0.0	0.0	0.0	0	0	0	0	0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
EMCH	0.0	0.0	0.0	0	0	0	0	0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SPC	0.0	0.0	0.0	408	408	408	408.0	408.0	408.0	408.0	408.0	408.0	408.0	408.0	408.0	408.0	408.0	408.0
MONTHLY	Oct-83	Nov-83	Dec-83	Jan-84	Feb-84	Mar-84	Apr-84	May-84	Jun-84	Jul-84	Aug-84	Sep-84	Oct-84	Nov-84	Dec-84	Jan-85	Feb-85	Mar-85
FOR	0.00	0.00	0.00	0.73	0.22	21.46	0.60	1.10	2.15	25.77	0.00	0.00	0.35	14.12	0.00	2.13	2.95	0.00
MCOR	0.00	0.00	37.34	22.19	0.00	3.71	7.10	20.33	1.19	0.00	0.00	0.00	0.00	27.55	23.75	82.97	9.32	0.00
PFOR	0.00	0.00	0.00	7.13	2.56	12.47	0.41	2.82	1.64	5.58	1.60	2.38	0.00	1.81	7.45	1.05	0.00	1.81
PHOR	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
EUCR	0.00	0.00	37.34	28.16	2.77	33.68	7.58	29.83	4.97	28.91	9.96	4.25	22.65	11.10	48.00	24.56	83.04	13.35
EUDR	0.00	0.00	11.53	23.15	2.77	33.68	7.58	29.83	4.97	28.91	9.96	4.25	22.65	0.30	19.74	18.95	83.04	13.09
PCF	97.93	100.00	69.11	69.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	51.92	50.75	0.00	0.00	0.00
EAF	2.97	0.00	10.25	71.62	87.23	68.94	70.17	66.13	70.17	66.13	70.17	66.13	66.13	77.55	41.70	29.51	61.45	16.95
EUDFC	0.00	0.00	37.34	28.16	2.77	33.68	7.58	29.83	4.97	28.91	9.96	4.25	22.65	13.10	48.00	18.95	83.04	13.09
12 MONTH	Oct-83	Nov-83	Dec-83	Jan-84	Feb-84	Mar-84	Apr-84	May-84	Jun-84	Jul-84	Aug-84	Sep-84	Oct-84	Nov-84	Dec-84	Jan-85	Feb-85	Mar-85
FOR	4.82	4.03	4.03	4.15	4.08	7.57	7.57	7.57	7.57	7.57	7.57	7.57	7.57	6.20	6.27	6.27	6.27	4.79
MCOR	0.18	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19
PFOR	2.64	3.44	3.44	3.47	3.35	3.38	3.19	3.17	4.10	4.10	2.87	3.00	4.00	3.00	3.05	2.05	3.05	2.05
PHOR	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
EUDR	14.63	14.64	14.64	14.69	13.91	14.20	13.59	13.70	13.13	13.13	13.13	13.13	13.13	17.92	18.15	17.92	24.70	22.93
EUDCF	12.16	12.52	12.52	12.44	12.44	12.44	12.44	12.44	12.44	12.44	12.44	12.44	12.44	14.53	13.68	15.59	22.15	22.15
PCF	16.23	12.34	10.32	9.59	9.77	9.03	9.24	9.03	10.01	20.82	20.82	20.82	20.82	10.14	8.59	8.59	8.59	8.59
EAF	72.61	74.64	78.57	78.79	78.79	78.79	78.79	78.79	78.79	78.79	78.79	78.79	78.79	74.62	75.43	69.23	70.97	70.97

CRYSTAL
RIVER


UNIT 2

	Apr-85	May-85	Jun-85	Jul-85	Aug-85	Sep-85	Oct-85	Nov-85	Dec-85	Jan-86	Feb-86	Mar-86	Apr-86	May-86	Jun-86	Jul-86	Aug-86	Sep-86
PER HOUR	719.0	744.0	720.0	744.0	744.0	720.0	744.0	720.0	744.0	719.0	744.0	720.0	744.0	719.0	744.0	720.0	744.0	720.0
PER HOUR	505.6	728.2	609.3	744.0	744.0	649.1	649.1	649.1	649.1	649.1	649.1	649.1	649.1	649.1	649.1	649.1	649.1	649.1
RSH	128.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
UH	24.6	15.4	110.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
POH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
FON	24.6	15.4	68.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
MDC	0.0	0.0	0.0	44.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
PPFH	25.5	67.4	287.7	322.5	117.9	0.0	103.9	0.0	15.3	14.7	0.0	50.5	14	37.6	13.9	147.6	119.3	64.5
LFFF	170.7	163.8	61.8	221.4	205.5	0.0	68.9	0.0	243.5	192.9	0.0	110.1	22.4	119.1	167.2	187.5	208.6	208.6
EFCH	9.3	20.2	30.8	16.1	61.8	0.0	16.2	0.0	0.0	0.0	0.0	18.0	2.8	18.8	26.1	52.7	40.1	23.7
FLCH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
LPHM	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
EMCH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NPC	498.0	498.0	498.0	498.0	498.0	498.0	498.0	498.0	498.0	498.0	498.0	498.0	498.0	498.0	498.0	498.0	498.0	498.0
MONTHLY	Apr-85	May-85	Jun-85	Jul-85	Aug-85	Sep-85	Oct-85	Nov-85	Dec-85	Jan-86	Feb-86	Mar-86	Apr-86	May-86	Jun-86	Jul-86	Aug-86	Sep-86
FOR	4.17	2.12	9.53	0.00	0.00	0.00	0.00	0.00	0.00	1.73	1.02	0.00	0.00	0.00	0.00	1.71	0.00	0.18
MOR	0.00	0.00	0.00	0.70	0.00	0.00	0.00	0.00	0.00	0.33	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PFOR	1.64	2.78	6.23	2.10	0.00	0.00	0.00	0.00	0.00	3.15	1.03	0.00	2.08	0.00	0.00	3.07	4.98	4.00
PMOR	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
EUCR	5.74	4.84	28.65	2.10	0.00	0.00	0.00	0.00	0.00	0.78	11.14	0.00	7.26	0.00	0.00	20.24	0.59	0.00
EUCH	4.71	4.84	28.65	2.10	0.00	0.00	0.00	0.00	0.00	2.10	0.70	0.00	7.35	0.00	0.00	20.24	0.59	0.00
POF	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
EAF	95.16	97.84	79.35	91.68	92.04	91.68	94.85	92.04	92.04	92.04	92.04	92.04	92.04	92.04	92.04	92.04	92.04	95.13
EUCP	4.71	4.84	28.65	2.10	0.00	0.00	0.00	0.00	0.00	0.78	11.14	0.00	7.26	0.00	0.00	20.24	0.59	0.00
12 MONTH	Apr-85	May-85	Jun-85	Jul-85	Aug-85	Sep-85	Oct-85	Nov-85	Dec-85	Jan-86	Feb-86	Mar-86	Apr-86	May-86	Jun-86	Jul-86	Aug-86	Sep-86
FOR	5.23	5.22	8.02	2.11	4.05	3.00	2.93	3.00	3.00	3.00	3.22	2.92	2.92	2.92	2.92	3.15	3.15	2.29
MOR	17.22	14.59	15.19	14.14	14.14	12.15	12.00	11.53	10.35	2.42	1.95	1.94	1.94	1.94	1.94	1.21	1.21	1.20
PFOR	2.00	2.70	3.17	2.84	3.24	2.89	3.05	3.05	2.82	2.58	2.67	2.52	2.54	2.46	2.46	2.94	3.32	3.32
PMOR	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
EUCR	23.05	20.63	22.11	19.42	18.13	18.57	17.63	18.55	18.55	15.49	7.55	7.55	7.55	7.55	7.55	7.23	7.19	6.73
EUCH	20.22	19.39	17.63	16.70	17.17	15.44	14.92	14.92	13.45	12.70	6.31	6.31	6.31	6.31	6.31	5.87	6.08	5.85
POF	0.59	8.59	8.59	8.59	8.59	8.59	8.59	8.59	8.59	14.81	14.77	14.77	14.77	14.77	14.77	14.77	14.77	14.77
EAF	71.21	73.33	72.03	74.30	74.64	74.20	71.45	71.45	72.49	70.41	70.41	70.41	70.41	70.41	70.41	70.50	70.50	70.50


CRYSTAL RIVER UNIT 3
FORCED OUTAGE RATE




CRYSTAL RIVER UNIT 3
MAINTENANCE OUTAGE RATE




CRYSTAL RIVER UNIT 3
PARTIAL FORCED OUTAGE RATE




CRYSTAL RIVER UNIT 3
PARTIAL MAINTENANCE OUTAGE RATE



CRYSTAL RIVER UNIT 3
EQUIVALENT UNPLANNED OUTAGE RATE



CRYSTAL RIVER UNIT 3
EQUIVALENT UNPLANNED OUTAGE FACTOR



**CRYSTAL
WATER
UNIT 3**


	Oct-93	Nov-93	Dec-93	Jan-94	Feb-94	Mar-94	Apr-94	May-94	Jun-94	Jul-94	Aug-94	Sep-94	Oct-94	Nov-94	Dec-94	Jan-95	Feb-95	Mar-95
PER HOURS																		
PER HOURS	745	720	744	744	872	744	719.0	744.0	720.0	744.0	744.0	720.0	744.0	720.0	744.0	720.0	744.0	744.0
PER HOURS	745	720	744	744	872	744	144.8	0.0	613.2	744.0	744.0	720.0	744.0	720.0	744.0	720.7	744.0	744.0
PSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
LH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
PH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
FCH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
MCH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
PFCH	118.1	0.0	7.2	34.8	0.0	94.0	144.8	0.0	111.5	92.1	0.0	0.0	111.3	0.0	0.0	0.0	0.0	11.5
LFF	168.395	0	164.2	17.1637	0	118.377	182.3	0.0	317.0	238.7	0.0	0.0	18.1	0.0	0.0	0.0	0.0	122.4
EFOH	28.3	0.0	1.8	0.8	0.0	15.0	37.5	0.0	47.6	29.7	0.0	0.0	0.3	0.0	0.0	0.0	0.0	1.9
PMOH	0	0	0	0	0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
LIPM	0	0	0	0	0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
EMOH	0	0	0	0	0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NPC	742.8	742.8	742.8	742.8	742.8	742.8	742.8	742.8	742.8	742.8	742.8	742.8	742.8	742.8	742.8	742.8	742.8	742.8
MONTHLY																		
FOR	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.27	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
MOR	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PFOR	3.53	0.00	0.21	0.11	0.00	2.91	25.97	0.00	77.0	4.90	0.00	0.00	0.04	0.00	0.00	0.00	0.00	0.25
PMOR	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
EUOR	3.53	0.00	0.21	0.11	0.00	2.91	25.97	0.00	15.39	4.00	0.00	0.00	0.04	0.00	0.00	0.00	0.00	0.25
ELOF	3.53	0.00	0.21	0.11	0.00	2.91	25.97	0.00	14.29	4.00	0.00	0.00	0.04	0.00	0.00	0.00	0.00	0.25
PUP	0.00	0.00	0.00	0.00	0.00	0.00	70.80	100.00	71.15	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
EAF	98.47	100.00	99.79	99.89	100.00	97.99	14.91	0.00	78.59	90.00	100.00	89.99	100.00	94.45	100.00	100.00	90.75	0.00
12 MONTHS	3.53	0.00	0.21	0.11	0.00	2.91	25.97	0.00	15.39	4.00	0.00	0.00	0.04	0.00	0.00	0.00	0.00	0.25
FOR	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.07	0.03	0.03	0.75	0.75	0.75	0.75	0.75	0.75
MOR	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PFOR	3.53	1.00	1.26	0.97	0.79	1.00	1.00	1.00	2.51	2.70	2.40	2.16	1.81	1.80	1.76	1.76	1.61	0.00
PMOR	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
EUOR	3.53	1.00	1.26	0.97	0.79	1.00	1.00	1.00	3.05	3.01	2.89	2.54	2.00	2.00	3.07	3.07	2.89	0.00
ELOF	3.53	1.00	1.26	0.97	0.79	1.00	1.00	1.00	2.81	2.83	2.88	2.44	2.14	2.14	2.60	2.59	2.44	0.00
PUP	0.00	0.00	0.00	0.00	0.00	0.00	11.29	22.63	20.91	18.77	17.64	15.84	15.84	15.84	15.84	15.84	15.84	0.00
EAF	98.47	98.20	98.74	98.00	98.21	98.00	98.00	98.00	97.12	98.00	98.00	98.00	98.00	98.00	98.00	98.00	98.00	98.00

6


**CRYSTAL
RIVER
UNIT 3**

MONTHLY	PER HOURS												SER HOURS													
	Apr-85	May-85	Jun-85	Jul-85	Aug-85	Sep-85	Oct-85	Nov-85	Dec-85	Jan-86	Feb-86	Mar-86	Apr-86	May-86	Jun-86	Jul-86	Aug-86	Sep-86	Oct-86	Nov-86	Dec-86	Jan-87	Feb-87	Mar-87		
FOR	719.0	744.0	720.0	744.0	744.0	720.0	745.0	720.0	744.0	744.0	720.0	744.0	719	744	720	744	744	744	744	744	744	744	744	744	744	
MOR	719.0	744.0	720.0	744.0	744.0	720.0	718.4	720.0	744.0	744.0	720.0	744.0	298.8	300.4	0.0	0	313.9	595.6	744	744	0	0	0	0	0	0
PFOR	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
EUDR	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
EUOF	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
POF	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
EAF	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12 MONTHS	12.00	12.00	12.00	12.00	12.00	12.00	12.00	12.00	12.00	12.00	12.00	12.00	12.00	12.00	12.00	12.00	12.00	12.00	12.00	12.00	12.00	12.00	12.00	12.00	12.00	
FOR	0.70	0.84	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
MOR	0.52	0.49	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	
PFOR	1.01	0.92	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	
EUDR	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
EUOF	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
POF	100.00	100.00	99.18	99.11	97.37	90.19	94.04	96.80	100.00	37.70	54.86	0.00	0.00	31.10	72.70	99.96	68.98	5.20	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
EAF	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
12 MONTHS	12.00	12.00	12.00	12.00	12.00	12.00	12.00	12.00	12.00	12.00	12.00	12.00	12.00	12.00	12.00	12.00	12.00	12.00	12.00	12.00	12.00	12.00	12.00	12.00	12.00	
FOR	0.70	0.84	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
MOR	0.52	0.49	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	
PFOR	1.01	0.92	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	
EUDR	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
EUOF	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
POF	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
EAF	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	


CRYSTAL RIVER UNIT 4
FORCED OUTAGE RATE




CRYSTAL RIVER UNIT 4
MAINTENANCE OUTAGE RATE




CRYSTAL RIVER UNIT 4
PARTIAL FORCED OUTAGE RATE




CRYSTAL RIVER UNIT 4
PARTIAL MAINTENANCE OUTAGE RATE



CRYSTAL RIVER UNIT 4
EQUIVALENT UNPLANNED OUTAGE RATE





CRYSTAL RIVER UNIT 4
EQUIVALENT UNPLANNED OUTAGE FACTOR




CRYSTAL RIVER UNIT 4	Oct-83	Nov-83	Dec-83	Jan-84	Feb-84	Mar-84	Apr-84	May-84	Jun-84	Jul-84	Aug-84	Sep-84	Oct-84	Nov-84	Dec-84	Jan-85	Feb-85	Mar-85	
PER HOUR	745	720	744	744	672	744	719	744	720	744	744	720	745	720	744	744	744	744	
PER HOUR	722.8	723	697.5	744	665.5	744	730.2	744.5	720.0	744.0	720.0	744.0	745.0	720.0	744.0	744.0	744.0	744.0	
RSH	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
LH	22.4	0	130.5	0	6.5	645.0	228.3	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	
POH	0	0	0	0	0	0	655.9	259.1	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	
FOH	22.4	0	0	0	0	0	6.5	0	0	0	0	0	0	0	0	0	0	0	
MORH	0	0	130.5	0	0	0	72.7	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	
PFOH	1.71	720	58.7	208.4	121.0	15.3	322.3	128.1	201.1	4.3	124.1	38.0	21.4	82.6	38.6	0.0	0.0	0.0	
LFHF	62.08164	62.08164	62.08164	162.6771	46.52469	30.10178	229.2	80.1	147.9	200.3	81.3	104.0	133.9	138.7	111.5	21.8	27.2	209.5	
EFOH	23.5	84.1	7.9	30.7	8.1	0.8	108.2	10.3	42.0	1.2	11.0	4.0	5.0	7.3	1.0	2.5	8.2	0.0	
FACH	0	3	0	0	0	0	0	0	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	
LRPH	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	
EDPH	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	
NPC	897	897	897	897	897	897	897	897	897	897.0	897.0	897.0	897.0	897.0	897.0	897.0	897.0	897.0	
MONTHLY	Oct-83	Nov-83	Dec-83	Jan-84	Feb-84	Mar-84	Apr-84	May-84	Jun-84	Jul-84	Aug-84	Sep-84	Oct-84	Nov-84	Dec-84	Jan-85	Feb-85	Mar-85	
FOR	3.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
MOR	0.00	0.00	0.00	18.36	0.00	0.00	15.71	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
PFOR	4.06	8.00	1.20	4.13	1.22	0.05	27.21	2.19	5.52	0.17	1.40	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
PAOR	6.00	8.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
EUOF	6.89	8.00	18.41	4.13	2.18	0.05	38.64	2.18	5.82	0.17	2.20	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
EUCF	6.39	8.00	19.41	4.13	2.18	0.11	24.00	2.19	5.82	0.17	2.20	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
POF	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
EAF	82.04	97.10	92.59	97.57	97.52	13.67	39.51	97.51	94.00	10.53	97.71	39.32	39.70	90.91	99.48	98.90	98.90	98.90	
12 MONTH	Oct-83	Nov-83	Dec-83	Jan-84	Feb-84	Mar-84	Apr-84	May-84	Jun-84	Jul-84	Aug-84	Sep-84	Oct-84	Nov-84	Dec-84	Jan-85	Feb-85	Mar-85	
MOR	0.74	0.95	0.89	0.70	0.73	0.72	0.74	0.77	0.47	0.50	0.68	0.16	0.16	0.16	0.16	0.16	0.16	0.16	
PFOR	1.51	1.93	1.81	1.04	1.03	1.11	1.12	0.78	0.51	3.29	2.95	2.67	3.64	1.70	1.70	1.70	1.70	1.70	
PAOR	3.78	3.77	3.61	3.67	3.65	3.74	3.75	3.29	2.32	4.99	4.82	4.25	3.82	2.37	2.30	2.32	2.35	2.35	
EUOF	5.92	5.89	5.80	5.34	5.35	5.40	5.51	4.75	4.05	8.53	7.88	7.22	6.83	6.84	5.10	4.72	4.58	4.31	
EUCF	5.50	5.45	5.36	4.92	4.94	5.03	5.19	4.53	4.11	7.46	7.00	6.48	6.94	6.94	4.57	4.23	4.19	4.19	
POF	7.21	7.42	7.64	8.12	8.20	8.70	4.09	12.30	11.22	10.20	10.20	10.20	10.20	10.20	10.20	10.20	10.20	10.20	
EAF	87.20	87.13	87.01	87.21	86.93	86.91	86.11	86.70	86.53	86.16	81.78	83.57	85.13	85.47	85.60	82.89	82.89	82.89	82.89


CRYSTAL RIVER UNIT 4		Aug-95												Sep-95												
		PER HOUR	719.0	720.0	720.0	720.0	720.0	720.0	720.0	720.0	720.0	720.0	720.0	720.0	720.0	720.0	720.0	720.0	720.0	720.0	720.0	720.0	720.0	720.0	720.0	
SER HOU IR	552.3	734.7	744.0	744.0	744.0	744.0	744.0	744.0	744.0	744.0	744.0	744.0	744.0	744.0	744.0	744.0	744.0	744.0	744.0	744.0	744.0	744.0	744.0	744.0	744.0	
RSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
UH	66.7	81.2	82.9	83.0	83.0	83.0	83.0	83.0	83.0	83.0	83.0	83.0	83.0	83.0	83.0	83.0	83.0	83.0	83.0	83.0	83.0	83.0	83.0	83.0	83.0	
POH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
FOH	68.7	82.1	82.9	83.0	83.0	83.0	83.0	83.0	83.0	83.0	83.0	83.0	83.0	83.0	83.0	83.0	83.0	83.0	83.0	83.0	83.0	83.0	83.0	83.0	83.0	
MON	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
PFOH	43.1	113.7	149.2	34.1	138.2	9.2	20.3	191.6	19.3	23.7	45.9	644.7	45.9	0	0	0	0	0	0	0	0	0	0	0	0	0
LRF	148.9	68.9	114.2	289.2	78.4	122.5	206.5	68.6	313.3	53.5	110.2	62.1	62.1	0	0	0	0	0	0	0	0	0	0	0	0	0
EFOH	9.2	11.2	24.5	14.9	15.3	1.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
PAOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
LRPH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
BRPH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
NPC	697.0	697.0	697.0	697.0	697.0	697.0	697.0	697.0	697.0	697.0	697.0	697.0	697.0	697.0	697.0	697.0	697.0	697.0	697.0	697.0	697.0	697.0	697.0	697.0		
MONTHLY		Aug-95	Aug-95	Aug-95	Aug-95	Aug-95	Aug-95	Aug-95	Aug-95	Aug-95	Aug-95	Aug-95	Aug-95	Aug-95	Aug-95	Aug-95	Aug-95	Aug-95	Aug-95	Aug-95	Aug-95	Aug-95	Aug-95	Aug-95	Aug-95	Aug-95
FOR	9.28	1.25	0.00	2.00	0.00	0.00	2.07	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
MOR	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
PFOR	1.41	15.3	3.60	2.05	2.00	0.22	1.16	0.62	0.62	0.24	1.05	7.75	8.91	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
PAFOR	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
EUFOR	10.58	2.70	1.40	5.85	2.00	0.22	3.89	2.02	0.00	0.24	1.24	8.91	8.91	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
EUOF	10.56	2.70	3.40	5.65	2.00	0.22	3.89	2.02	0.00	0.24	1.24	8.15	5.63	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
POF	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
EAF	69.44	97.24	93.00	94.15	97.34	98.73	98.61	97.34	98.62	97.70	98.62	97.70	97.70	97.70	97.70	97.70	97.70	97.70	97.70	97.70	97.70	97.70	97.70	97.70	97.70	
12 MONTH	10.56	2.70	3.40	5.65	2.00	0.22	3.89	2.02	0.00	0.24	1.24	8.91	8.91	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
FOR	0.84	0.94	0.94	1.27	1.21	1.21	1.45	1.45	1.45	1.45	1.45	1.45	1.45	1.45	1.45	1.45	1.45	1.45	1.45	1.45	1.45	1.45	1.45	1.45	1.45	
MOR	0.70	0.70	0.70	0.70	0.70	0.70	0.70	0.70	0.70	0.70	0.70	0.70	0.70	0.70	0.70	0.70	0.70	0.70	0.70	0.70	0.70	0.70	0.70	0.70	0.70	
PFOR	1.52	1.25	1.40	1.41	1.42	1.42	1.43	1.43	1.43	1.43	1.43	1.43	1.43	1.43	1.43	1.43	1.43	1.43	1.43	1.43	1.43	1.43	1.43	1.43	1.43	
PAFOR	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
EUFOR	3.01	3.05	2.85	3.34	3.32	3.28	3.56	2.85	2.85	2.85	3.21	3.21	3.21	3.21	3.21	3.21	3.21	3.21	3.21	3.21	3.21	3.21	3.21	3.21	3.21	
EUOF	3.01	3.05	2.85	3.34	3.32	3.28	3.56	2.85	2.85	2.85	3.21	3.21	3.21	3.21	3.21	3.21	3.21	3.21	3.21	3.21	3.21	3.21	3.21	3.21	3.21	
POF	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
EAF	98.94	97.15	98.68	98.44	98.72	98.68	98.44	97.15	97.15	97.15	97.15	97.15	97.15	97.15	97.15	97.15	97.15	97.15	97.15	97.15	97.15	97.15	97.15	97.15		




CRYSTAL RIVER UNIT 5
PARTIAL FORCED OUTAGE RATE




CRYSTAL RIVER UNIT 5
PARTIAL MAINTENANCE OUTAGE RATE



CRYSTAL RIVER UNIT 5
EQUIVALENT UNPLANNED OUTAGE RATE



CRYSTAL RIVER UNIT 5
EQUIVALENT UNPLANNED OUTAGE FACTOR



**CRYSTAL
RIVER
UNIT 5**

Oct-93	Nov-93	Dec-93	Jan-94	Feb-94	Mar-94	Apr-94	May-94	Jun-94	Jul-94	Aug-94	Sep-94	Oct-94	Nov-94	Dec-94	Jan-95	Feb-95	Mar-95
PER HOUR	745	729	744	744	744	672	672	744	744	744	744	744	744	744	744	744	744
SEER HOUR	111	273	744	724.3	672	647.9	647.9	693.9	744.0	728.9	728.9	744.0	744.0	744.0	744.0	747.9	747.9
RSH	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
UH	634	447	0	111.7	0	96.1	21.9	0.9	0.9	76.7	0.9	4.3	0.9	0.9	0.9	0.9	0.9
POH	693.8	447	0	0	0	0	0	0	0	0	0	0	0	0	0	264.1	744.0
FOH	33.4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
MCH	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PFCH	0	0	0	31.9	0	0	0	0	0	0	0	0	0	0	0	0	0
LBF	0	0	0	113.403	101.1577	102.5432	84.0194	20.6	122.1	148.4	258.9	20.2	80.5	0.9	71.9	110.6	106.3
EFCH	0	0	0	6.2	1.5	0.8	2.1	0.4	2.4	36.1	4.4	0.2	1.7	0.9	9.5	15.2	23.2
FACH	0	0	0	0	0	0	0	0	0	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9
USPA	0	0	0	0	0	0	0	0	0	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9
EACH	0	0	0	0	0	0	0	0	0	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9
HPC	0	0	0	0.97	0.97	0.97	0.97	0.97	0.97	0.97	0.97	0.97	0.97	0.97	0.97	0.97	0.97
MONTHLY	Oct-93	Nov-93	Dec-93	Jan-94	Feb-94	Mar-94	Apr-94	May-94	Jun-94	Jul-94	Aug-94	Sep-94	Oct-94	Nov-94	Dec-94	Jan-95	Feb-95
FOR	23.13	0.59	0.69	2.05	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69
MCR	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69
PFOR	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69
PROR	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69
ELOR	23.13	0.59	0.69	0.70	0.21	1.52	0.32	0.68	0.37	5.91	0.69	0.69	0.69	0.69	0.69	0.69	0.69
ELOF	4.69	0.69	0.69	0.70	2.05	1.02	13.20	3.69	0.37	5.91	18.78	0.53	0.53	0.53	0.53	0.53	0.53
POF	60.62	62.66	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69
E/F	14.89	37.92	0.97	0.97	0.97	0.97	0.97	0.97	0.97	0.97	0.97	0.97	0.97	0.97	0.97	0.97	0.97
12 MONTH	Oct-93	Nov-93	Dec-93	Jan-94	Feb-94	Mar-94	Apr-94	May-94	Jun-94	Jul-94	Aug-94	Sep-94	Oct-94	Nov-94	Dec-94	Jan-95	Feb-95
FOR	4.59	3.59	3.19	3.29	2.35	2.35	1.67	2.70	8.13	7.27	1.75	1.22	1.15	0.93	0.93	1.03	1.03
MCR	1.07	1.02	1.04	1.09	1.07	1.10	0.91	0.99	1.02	1.04	1.04	1.35	1.35	1.39	1.27	1.27	1.27
PFOR	12.72	12.94	12.21	12.38	12.65	13.46	13.72	14.12	14.34	8.95	7.86	0.92	0.76	0.83	1.22	1.33	1.42
PROR	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69
ELOR	17.62	17.15	10.75	17.92	17.14	17.27	17.91	10.25	17.28	16.92	4.94	3.26	3.49	3.44	3.62	2.70	2.70
ELOF	36.13	34.97	33.77	36.33	34.53	36.18	38.14	38.84	36.07	32.30	3.58	3.18	3.40	3.44	3.51	2.39	2.39
POF	10.64	10.59	11.20	11.73	12.02	12.39	12.69	13.14	32.69	20.12	11.50	5.10	0.00	0.00	3.01	11.51	11.51
E/F	65.03	59.87	54.54	53.94	53.42	62.79	51.16	50.52	52.64	54.65	54.65	91.72	91.60	90.58	93.47	90.10	90.10

CRYSTAL
RIVER
UNIT 5

	Apr-05	May-05	Jun-05	Jul-05	Aug-05	Sep-05	Oct-05	Nov-05	Dec-05	Jan-06	Feb-06	Mar-06	Apr-06	May-06	Jun-06	Jul-06	Aug-06	Sep-06
PER HOUR	719.0	744.0	720.0	744.0	744.0	720.0	740.0	720.0	744.0	744.0	600.0	744.0	719	744	720	744	744	720
SER HOUR	585.3	739.3	709.3	744.0	670.4	720.0	745.0	720.0	702.1	744.0	688.7	716.3	710	744	600.0	730.7	730.7	719.2
RSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0	0	0	0	0	0
UH	123.7	4.7	10.7	0.0	67.6	0.0	0.0	0.0	41.9	0.0	73	27.7	0	0	110.2	4.3	5.3	0.8
POH	123.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0	0	0	0	57.4	0
F0H	0.0	4.7	10.7	0.0	67.6	0.0	0.0	0.0	0.0	0.0	73	27.7	0	0	110.2	4.3	5.3	0.8
M0H	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	41.9	0.0	0.0	0.0	0	0	0	0	0	0
PF0H	0.0	7.4	22.8	22.6	26.3	2.0	35.4	135.8	18.8	0.0	103	10.0	42	82.1	75.8	16.7	52.1	23.8
LRPF	0.0	105.4	171.9	107.5	313.4	200.0	262.8	90.4	520.0	440.3	202.0	301.8	100	105.0	148.3	244.7	178.9	205.7
EFOI	0.0	1.0	5.6	6.3	11.0	1.2	12.0	17.0	14.1	6.3	7.4	5.8	11.2	14.0	15.9	5.9	13.4	0.0
PM0H	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0	0	0	0	0	0	0
LRPM	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0	0	0	0	0	0	0
EM0H	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NPC	697.0	697.0	697.0	697.0	697.0	697.0	697.0	697.0	697.0	697.0	697.0	697.0	697	697	697	697	697	697
MONTHLY	Apr-05	May-05	Jun-05	Jul-05	Aug-05	Sep-05	Oct-05	Nov-05	Dec-05	Jan-06	Feb-06	Mar-06	Apr-06	May-06	Jun-06	Jul-06	Aug-06	Sep-06
FOR	0.00	0.03	1.40	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.05	3.72	0.00	0.00	16.96	0.50	0.71	0.11
MOR	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.83	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PFOR	0.00	0.24	0.70	0.71	1.75	0.17	1.72	2.45	2.00	0.04	1.08	0.78	1.58	1.88	2.05	0.70	1.81	1.36
PMOR	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
EUOR	0.00	0.07	2.27	0.71	10.00	6.17	1.72	2.45	7.52	0.04	2.11	4.48	1.58	1.88	10.77	1.37	2.51	1.47
EUOF	0.00	0.07	2.27	0.71	10.00	9.17	1.72	2.45	7.52	0.04	2.11	4.48	1.58	1.88	10.77	1.37	2.51	1.47
POF	17.20	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	7.72	0.00	
EAF	82.80	80.13	97.73	80.20	80.32	80.03	80.20	87.55	82.40	80.10	87.00	85.52	86.44	80.12	81.23	78.63	89.73	80.53
0.00	0.07	2.27	0.71	10.00	9.17	1.72	2.45	7.52	0.04	2.11	4.48	1.58	1.88	18.77	1.37	2.72	1.47	
12 MONTH	Apr-05	May-05	Jun-05	Jul-05	Aug-05	Sep-05	Oct-05	Nov-05	Dec-05	Jan-06	Feb-06	Mar-06	Apr-06	May-06	Jun-06	Jul-06	Aug-06	Sep-06
FOR	1.00	1.11	1.25	0.20	1.14	1.00	1.00	1.69	1.00	1.00	1.15	1.37	1.35	1.30	2.54	2.59	1.87	1.88
MOR	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PFOR	1.43	1.42	1.01	1.01	1.10	1.17	1.34	1.45	1.44	1.10	1.08	1.05	1.17	1.31	1.45	1.45	1.58	
PMOR	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
EUOR	2.48	2.51	2.25	1.27	2.31	2.25	2.41	2.92	3.00	2.81	2.73	2.88	2.97	3.05	4.40	4.48	3.77	3.87
EUOF	2.14	2.19	1.00	1.11	2.01	1.98	2.10	2.29	2.08	2.45	2.48	2.84	2.97	3.05	4.40	4.48	3.77	3.87
POF	12.92	12.52	12.82	12.92	12.92	12.92	12.92	12.92	12.92	12.92	9.00	1.41	0.00	0.00	0.00	0.00	0.00	0.00
EAF	84.94	84.00	85.12	85.97	85.97	85.12	84.98	84.83	84.42	84.93	87.00	85.75	87.03	88.95	85.00	85.54	85.58	85.47

TABLE 1.0
PROMOD PROJECTED SYSTEM GENERATION
PERIOD OF: APRIL, 1997 THRU SEPTEMBER, 1997

PLANT	UNIT	CAPACITY MW	SERVICE HOURS	GENERATION GWH	NOF %	% OF TOTAL OUTPUT
Anciole	1	517	3604	1443.9	77.7%	10.58%
Anciole	2	517	3604	1383.7	76.4%	10.14%
Bartow	1	117	2656	282.2	90.6%	2.07%
Bartow	2	119	2116	230.3	91.5%	1.69%
Bartow	3	213	3645	608.9	80.6%	4.43%
Crystal River	1	373	4039	1430.4	94.9%	10.46%
Crystal River	2	469	3747	1740.3	99.0%	12.75%
Crystal River Nuc.	3	767	0	0	0.0%	0.00%
Crystal River	4	717	4229	2866.2	95.2%	21.15%
Crystal River	5	717	3381	2342.4	96.6%	17.17%
Suwannee	1	34	1175	37.8	94.6%	0.26%
Suwannee	2	33	1073	33.3	98.9%	1.02%
Suwannee	3	80	1796	139.2	87.8%	0.14%
Avon Park Pk	1	32	701	19.7	0.0%	0.00%
Avon Park Pk	2	32	2	0	62.9%	0.00%
Bartow Pk	1	53	6	0.2	82.5%	0.01%
Bartow Pk	2	53	16	0.7	83.7%	0.32%
Bartow Pk	3	53	976	43.3	81.4%	0.37%
Bartow Pk	4	58	1072	50.6	69.0%	0.01%
Bayboro	1	58	25	1	69.0%	0.00%
Bayboro	2	58	10	0.4	75.2%	0.04%
Bayboro	3	58	110	4.8	74.5%	0.01%
Bayboro	4	58	44	1.9	77.2%	0.10%
DeBary	1	65	281	14.1	78.3%	0.22%
DeBary	2	65	597	30.4	77.4%	0.03%
DeBary	3	65	173	8.7	72.8%	0.03%
DeBary	4	65	82	4	78.2%	0.18%
DeBary	5	65	74	3.5	80.5%	0.55%
DeBary	6	65	478	24.3	75.3	0.23%
DeBary	7	99	945	75.3	74.9%	0.16%
DeBary	8	99	417	31.2	75.2%	0.13%
DeBary	9	99	337	25	76.0%	0.14%
DeBary	10	99	235	17.5	76.0%	0.00%
Higgins Pk	1	37	672	18.9	60.5%	0.00%
Higgins Pk	2	37	3	0	80.2%	0.20%
Higgins Pk	3	42	810	27.3	80.5%	0.18%
Higgins Pk	4	42	739	25	60.5%	0.00%
Intercession City	1	59	14	0.5	42.4%	0.00%
Intercession City	2	59	4	0.1	73.4%	0.01%
Intercession City	3	59	30	1.3	63.6%	0.00%
Intercession City	4	59	8	0.3	71.4%	0.01%
Intercession City	5	59	38	1.6	67.8%	0.01%
Intercession City	6	59	20	0.8	80.8%	0.94%
Intercession City	7	99	1506	127.9	80.2%	0.84%
Intercession City	8	99	1439	114.2	80.5%	0.77%
Intercession City	9	99	1310	104.4	79.7%	0.69%
Intercession City	10	99	1200	94.7	67.5%	0.03%
Intercession City	11	165	35	3.9	0.0%	0.00%
Port St. Joe	1	18	2	0	0.0%	0.00%
Rio Pinar	1	18	2	0	76.4%	0.31%
Suwannee Pk	1	67	820	42	74.6%	0.05%
Suwannee Pk	2	67	128	6.4	75.8%	0.07%
Suwannee Pk	3	67	191	9.7	0.0%	0.00%
Turner Pk	1	18	2	0	74.0%	0.07%
Turner Pk	2	18	2	0	67.5%	0.02%
Turner Pk	3	82	160	9.1	84.9%	1.03%
Turner Pk	4	82	47	2.6	100.00%	
University of Florida	1	42	3039	140.4		

GENERATION BY GPIF UNITS

11226.9

GENERATION BY TOTAL SYSTEM

13646.3

PERCENT OF TOTAL BY GPIF UNITS

82.27%