

AUSLEY & McMULLEN

ATTORNEYS AND COUNSELORS AT LAW

227 SOUTH CALHOUN STREET
P.O. BOX 391 (ZIP 32302)
TALLAHASSEE, FLORIDA 32301
(850) 224-9115 FAX (850) 222-7560

ORIGINAL

January 15, 1998

HAND DELIVERED

Ms. Blanca S. Bayo, Director
Division of Records and Reporting
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399-0850

Re: Fuel and Purchased Power Cost Recovery Clause
with Generating Performance Incentive Factor;
FPSC Docket No. 760004-71

Dear Ms. Bayo:

Enclosed for filing in the above docket, on behalf of Tampa Electric Company, are ten copies of each of the following:

1. Petition of Tampa Electric Company. 00874-98
2. Prepared Direct Testimony of Karen A. Zwolak and Exhibit (KOZ-2) regarding Tampa Electric's Fuel Cost Recovery and Capacity Cost Recovery for the period April 1998 through September 1998. 00875-98
3. Prepared Direct Testimony of George A. Keselowsky with Exhibit (GAK-2 regarding Tampa Electric Company's performance under the Generating Performance Incentive Factor for the period April 1998 - September 1998. 00876-98

ACK Vandue Please acknowledge receipt and filing of the above by stamping the duplicate copy of this letter and returning same to this writer.

Cc: Thank you for your assistance in connection with this matter.

Sincerely,


James D. Beasley

JDB/pp
Enclosures

cc: All Parties of Record (w/encls.)

ORIGINAL

TAMPA ELECTRIC COMPANY
DOCKET NO. 980001-BL
SUBMITTED FOR FILING 1/15/98
(PROJECTION)

1 BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION
2 PREPARED DIRECT TESTIMONY
3 OF
4 GEORGE A. KESELOWSKY

5
6 Q. Will you please state your name, business address, and
7 employer?

8
9 A. My name is George A. Kesselowsky and my business address is
10 Post Office Box 111, Tampa, Florida 33601. I am employed
11 by Tampa Electric Company.

12
13 Q. Please furnish us with a brief outline of your educational
14 background and business experience.

15
16 A. I graduated in 1972 from the University of South Florida
17 with a Bachelor of Science Degree in Mechanical
18 Engineering. I have been employed by Tampa Electric
19 Company in various engineering positions since that time.
20 My current position is that of Senior Consulting Engineer
21 - Energy Supply Engineering.

22
23 Q. What are your current responsibilities?

24
25 A. I am responsible for testing and reporting unit

1 DOCUMENT NUMBER-DATE
00876 JAN15 98
FPSC-RECORDS/REPORTING

1 performance; and the compilation and reporting of
2 generation statistics.

3

4 Q. What is the purpose of your testimony?

5

6 A. My testimony presents Tampa Electric Company's methodology
7 for determining the various factors required to compute the
8 Generating Performance Incentive Factor (GPIF) as ordered
9 by this Commission.

10

11 Q. Have you prepared an exhibit showing the various elements
12 of the derivation of Tampa Electric Company's GPIF formula?

13

14 A. Yes, I have prepared, under my direction and supervision,
15 an exhibit entitled "Tampa Electric Company, Generating
16 Performance Incentive Factor" April 1998 - September 1998,
17 consisting of 35 pages filed with the Commission on
18 January 14, 1998. (Have identified as Exhibit GAK-2). The
19 data prepared within this exhibit is consistent with the
20 GPIF Implementation Manual previously approved by this
21 Commission.

22

23

24

25

1 Q. Which generating units on Tampa Electric Company's system
2 are included in the determination of your GPIF?

3

4 A. Six of our coal-fired units are included. These are:
5 Gannon Station Units 5 and 6; and Big Bend Station Units 1,
6 2, 3, and 4.

7

8 Q. Will you describe how Tampa Electric Company evolved the
9 various factors associated with the GPIF as ordered by this
10 Commission?

11

12 A. Yes. First, the two factors to be used, as set forth by
13 the Commission Staff, are unit availability and station
14 heat rate.

15

16 Q. Please continue.

17

18 A. A target was established for equivalent availability for
19 each unit considered for this period. Heat rate targets
20 were also established for each unit. A range of potential
21 improvement and degradation was determined for each of
22 these parameters.

23

24

25

1 Q. Would you describe how the target values for unit
2 availability were determined?

3

4 A. Yes I will. The Planned Outage Factor (POF) and the
5 Equivalent Unplanned Outage Factor (EUOF) were subtracted
6 from 100% to determine the target equivalent availability.
7 The factors for each of the 6 units included within the
8 GPIF are shown on page 5 of my exhibit. For example, the
9 projected EUOF for Big Bend Unit Four is 8.1%. The Planned
10 Outage Factor for this same unit during this period is 0%.
11 Therefore, the target equivalent availability for this unit
12 equals:

13

14 $100\% - [(8.1\% + 0\%)] = 91.9\%$

15

16 This is shown on page 4, column 3 of my exhibit.

17

18 Q. How was the potential for unit availability improvement
19 determined?

20

21 A. Maximum equivalent availability is arrived at using the
22 following formula.

23

24

25

1 Equivalent Availability Maximum

2 $EAF_{MAX} = 100\% - [0.8 \text{ (EUOF)} + 0.95 \text{ (POF)}]$

3

4 The factors included in the above equations are the same
5 factors that determine target equivalent availability. To
6 attain the maximum incentive points, a 20% reduction in
7 Forced Outage and Maintenance Outage Factors (EUOF), plus
8 a 5% reduction in the Planned Outage Factor (POF) will be
9 necessary. Continuing with our example on Big Bend Unit
10 Four:

11

12 $EAF_{MAX} = 100\% - [0.8 \text{ (8.1\%)} + 0.95 \text{ (0\%)}] = 93.5\%$

13

14 This is shown on page 4, column 4 of my exhibit.

15

16 Q. How was the potential for unit availability degradation
17 determined?

18

19 A. The potential for unit availability degradation is
20 significantly greater than is the potential for unit
21 availability improvement. This concept was discussed
22 extensively and approved in earlier hearings before this
23 Commission. Tampa Electric Company's approach to
24 incorporating this skewed effect into the unit availability
25 tables is to use a potential degradation range equal to

1 twice the potential improvement. Consequently, minimum
2 equivalent availability is arrived at via the following
3 formula:

4

5 Equivalent Availability Minimum

6 $EAF_{MIN} = 100\% - [1.4 (EUOF_t) + 1.10 (POF_t)]$

7

8 Again, continuing with our example of Big Bend Unit Four,

9

10 $EAF_{MIN} = 100\% - [1.4 (8.1\%) + 1.1 (0\%)] = 88.7\%$

11

12 Equivalent availability MAX and MIN for the other five
13 units is computed in a similar manner.

14

15 **Q.** How do you arrive at the Planned Outage, Maintenance Outage
16 and Forced Outage Factors?

17

18 **A.** Our planned outages for this period are shown on page 19 of
19 my exhibit. A Critical Path Method (C.P.M.) for each major
20 planned outage which affects GPIF is included in my
21 exhibit. For example, Big Bend Unit 1 is scheduled for an
22 annual maintenance outage May 18 to May 31, 1998. There
23 are 336 planned outage hours scheduled for the summer 1998
24 period, and a total of 4391 hours during this 6 month
25 period. Consequently, the Planned Outage Factor for Unit 1

1 at Big Bend is $336/4391 \times 100\%$ or 7.7%. This factor is
2 shown on pages 5 and 15 of my exhibit. Big Bend Unit 3 has
3 a planned outage factor of 18.0%. Big Bend Units 2 and 4
4 have planned outage factors of zero, as does Gannon Unit 5.
5 Gannon Unit 6 has a planned outage factor of 7.7%.

6

7 Q. How did you arrive at the Forced Outage and Maintenance
8 Outage Factors on each unit?

9

10 A. Graphs of both of these factors (adjusted for planned
11 outages) vs. time are prepared. Both monthly data and 12
12 month moving average data are recorded. For each unit the
13 most current, September 1997, 12 month ending value was
14 used as a basis for the projection. This value was adjusted
15 up or down by analyzing trends and causes for recent forced
16 and maintenance outages. All projected factors are based
17 upon historical unit performance, engineering judgment,
18 time since last planned outage, and equipment performance
19 resulting in a forced or maintenance outage. These target
20 factors are additive and result in a EUOF of 15.2% for
21 Gannon Unit Five. The Equivalent Unplanned Outage Factor
22 (EUOF) for Gannon Unit Five is verified by the data shown
23 on page 13, lines 3, 5, 10 and 11 of my exhibit and
24 calculated using the formula:

1 EUOF = (FOH + EFOH + MOH + EMOH) x 100
2 Period Hours
3 or
4 EUOF = (555 + 111) x 100 = 15.2%
5 4391

6 Relative to Gannon Unit Five, the EUOF of 15.2% forms the
7 basis of our Equivalent Availability target development as
8 shown on sheets 4 and 5 of my exhibit.

9
10 Q. Please continue with your review of the remaining units.
11

12 Big Bend Unit One

13 A. The projected EUOF for this unit is 14.0% during this
14 period. This unit will have a planned outage this period
15 and the Planned Outage Factor is 7.7%. This results in a
16 target equivalent availability of 78.3% for the period.
17

18 Big Bend Unit Two

19 The projected EUOF for this unit is 13.6%. This unit will
20 not have a planned outage during this period and the
21 Planned Outage Factor is 0%. Therefore, the target
22 equivalent availability for this unit is 86.4%.

23

24

25

Big Bend Unit Three

The projected EUOF for this unit is 13.2%. This unit will have a planned outage this period and the Planned Outage Factor is 18.0%. Therefore, the target equivalent availability for this unit is 68.8%.

Big Bend Unit Four

The projected EUOF for this unit is 8.1%. This unit will not have a planned outage during this period and the Planned Outage Factor is 0%. This results in a target equivalent availability of 91.9% for the period.

Gannon Unit Five

The projected EUOF for this unit is 15.2%. This unit will not have a planned outage during this period and the Planned Outage Factor is 0%. Therefore, the target equivalent availability for this unit is 84.8%.

Gannon Unit Six

The projected EUOF for this unit is 11.3%. This unit will have a planned outage during this period and the Planned Outage Factor is 7.7%. Therefore, the target equivalent availability for this unit is 81.1%.

1 Q. Would you summarize your testimony regarding Equivalent
2 Availability Factor (EAF)?

3

4 A. Yes I will. Please note on page 5 that the GPIF system
5 weighted Equivalent Availability Factor (EAF) equals 79.2%.
6 This target compares very favorably to previous GPIF
7 periods.

8

9 Q. As you graph and monitor Forced and Maintenance Outage
10 Factors, why are they adjusted for planned outage hours?

11

12 A. This adjustment makes these factors more accurate and
13 comparable. Obviously, a unit in a planned outage stage or
14 reserve shutdown stage will not incur a forced or
15 maintenance outage. Since our units are usually base
16 loaded, reserve shutdown is generally not a factor. To
17 demonstrate the effects of a planned outage, note the EUOR
18 and EUOF for Gannon Unit Six on page 14. During the months
19 of April, and June through September, EUOF and EUOR are
20 equal. This is due to the fact that no planned outages are
21 scheduled during these months. During the month of May,
22 EUOR exceeds EUOF. The reason for this difference is the
23 scheduling of a planned outage. The adjusted factors apply
24 to the period hours after planned outage hours have been
25 extracted.

1 Q. Does this mean that both rate and factor data are used in
2 calculated data?

3

4 A. Yes it does. Rates provide a proper and accurate method of
5 arriving at the unit parameters. These are then converted
6 to factors since they are directly additive. That is, the
7 Forced Outage Factor + Maintenance Outage Factor + Planned
8 Outage Factor + Equivalent Availability = 100%. Since
9 factors are additive, they are easier to work with and to
10 understand.

11

12 Q. Has Tampa Electric Company prepared the necessary heat rate
13 data required for the determination of the Generating
14 Performance Incentive Factor?

15

16 A. Yes. Target heat rates as well as ranges of potential
17 operation have been developed as required.

18

19 Q. How were these targets determined?

20

21 A. Net heat rate data for the three most recent summer
22 periods, along with the PROMOD III program, formed the
23 basis of our target development. Projections of unit
24 performance were made with the aid of PROMOD III. The
25 historical data and the target values are analyzed to

1 assure applicability to current conditions of operation.
2 This provides assurance that any periods of abnormal
3 operations, or equipment modifications having material
4 effect on heat rate can be taken into consideration.

5

6 Q. The accomplishment of scrubbing the flue gas from Big Bend
7 Unit 3 requires an additional amount of station service
8 power. How do you plan to address the associated effect to
9 net heat rate for GPIF purposes?

10

11 A. The change in heat rate for this unit resulting from increased
12 utilization of the Unit 4 scrubber can be quantified, but the
13 operational history is short of GPIF guidelines. The target for
14 Big Bend 3 has, therefore, been developed in the standard
15 fashion using data without scrubber power. In order to assure
16 compatability with this target, scrubber power will be removed
17 prior to calculating Unit 3 heat rate for the subsequent True-Up
18 process. This method has been reviewed and approved by the PSC
19 Staff to be employed until there is sufficient history to meet
20 target preparation guidelines. Successful implementation of this
21 innovation to maximize the potential of existing plant
22 equipment, represents a major cost savings and a significant
23 benefit for our customers.

24
25

1 Q. Have you developed the heat rate targets in accordance with
2 GPIF guidelines?

3
4 A. Yes.

5
6 Q. How were the ranges of heat rate improvement and heat rate
7 degradation determined?

8
9 A. The ranges were determined through analysis of historical
10 net heat rate and net output factor data. This is the same
11 data from which the net heat rate vs. net output factor
12 curves have been developed for each unit. This information
13 is shown on pages 27 through 32 of my exhibit.

14
15 Q. Would you elaborate on the analysis used in the
16 determination of the ranges?

17
18 A. The net heat rate vs. net output factor curves are the results
19 of a first order curve fit to historical data. The standard
20 error of the estimate of this data was determined, and a factor
21 was applied to produce a band of potential improvement and
22 degradation. Both the curve fit and the standard error of the
23 estimate were performed by computer program for each unit. These
24 curves are also used in post period adjustments to actual heat
25 rates to account for unanticipated changes in unit dispatch.

1 **Q.** Can you summarize your heat rate projection for the summer
2 1998 period?

3
4 **A.** Yes. The heat rate target for Big Bend Unit 1 is 10,267
5 Btu/Net kwh. The range about this value, to allow for
6 potential improvement or degradation, is \pm 366 Btu/Net kwh.
7 The heat rate target for Big Bend Unit 2 is 10,225 Btu/Net
8 kwh with a range of \pm 330 Btu/Net kwh. The heat rate target
9 for Big Bend Unit 3 is 9,778 Btu/Net kwh, with a range of
10 \pm 342 Btu/Net kwh. The heat rate target for Big Bend Unit
11 4 is 9,831 Btu/Net kwh with a range of \pm 188 Btu/Net kwh.
12 The heat rate target for Gannon Unit 5 is 10,377 Btu/Net
13 kwh with a range of \pm 478 Btu/Net kwh. The heat rate target
14 for Gannon Unit 6 is 10,527 Btu/Net kwh with a range of
15 \pm 400 Btu/Net kwh. A zone of tolerance of \pm 75 Btu/Net kwh
16 is included within the range for each target. This is
17 shown on page 4, and pages 7 through 12 of my exhibit.

18
19 **Q.** Do you feel that the heat rate targets and ranges in your
20 projection meet the criteria of the GPIF and the philosophy
21 of this Commission?

22
23 **A.** Yes I do.

24
25

1 Q. After determining the target values and ranges for average
2 net operating heat rate and equivalent availability, what
3 is the next step in the GPIF?

4

5 A. The next step is to calculate the savings and weighting
6 factor to be used for both average net operating heat rate
7 and equivalent availability. This is shown on pages 7
8 through 12. Our PROMOD III cost simulation model was used
9 to calculate the total system fuel cost if all units
10 operated at target heat rate and target availability for
11 the period. This total system fuel cost of \$153,941,200 is
12 shown on page 6 column 2.

13

14 The PROMOD III output was then used to calculate total
15 system fuel cost with each unit individually operating at
16 maximum improvement in equivalent availability and each
17 station operating at maximum improvement in average net
18 operating heat rate. The respective savings are shown on
19 page 6 column 4. After all the individual savings are
20 calculated, column 4 is totaled: \$6,630,700 reflects the
21 savings if all units operated at maximum improvement. A
22 weighting factor for each parameter is then calculated by
23 dividing individual savings by the total. For Big Bend
24 Unit Two, the weighting factor for equivalent availability
25 is 9.38% as shown in the right hand column on page 6.

1 Pages 7 thru 12 show the point table, the Fuel
2 Savings/(Loss), and the equivalent availability or heat
3 rate value. The individual weighting factor is also shown.
4 For example, on Big Bend Unit Two, page 10, if the unit
5 operates at 89.1% equivalent availability, fuel savings
6 would equal \$622,000 and 10 equivalent availability points
7 would be awarded.

8

9 The Generating Performance Incentive Factor Reward/Penalty
10 Table on page 2 is a summary of the tables on pages 7
11 through 12. The left hand column of this document shows
12 the incentive points for Tampa Electric Company. The
13 center column shows the total fuel savings and is the same
14 amount as shown on page 6, column 4, \$6,630,700. The right
15 hand column of page 2 is the estimated reward or penalty
16 based upon performance.

17

18 **Q.** How were the maximum allowed incentive dollars determined?

19

20 **A.** Referring to my exhibit on page 3, line 8, the estimated
21 average common equity for the period April 1998 - September
22 1998 is shown to be \$1,177,502,143. This produces the
23 maximum allowed jurisdictional incentive dollars of
24 \$2,371,627 shown on line 15.

25

1 Q. Is there any other constraint set forth by this Commission
2 regarding the magnitude of incentive dollars?

3

4 A. Yes. Incentive dollars are not to exceed fifty percent of
5 fuel savings. Page 2 of my exhibit demonstrates that this
6 constraint is met.

7

8 Q. Do you wish to summarize your testimony on the GPIF?

9

10 A. Yes. To the best of my knowledge and understanding, Tampa
11 Electric Company has fully complied with the Commission's
12 directions, philosophy, and methodology in our
13 determination of Generating Performance Incentive Factor.
14 The GPIF for Tampa Electric Company is expressed by the
15 following formula for calculating Generating Performance
16 Incentive Points (GPIP):

17

$$18 \quad \text{GPIP} = (0.0522 \text{ EAP}_{\text{GNS}} + 0.0506 \text{ EAP}_{\text{GNG}} \\ 19 \quad \quad \quad + 0.1092 \text{ EAP}_{\text{BB1}} + 0.0938 \text{ EAP}_{\text{BB2}} \\ 20 \quad \quad \quad + 0.1319 \text{ EAP}_{\text{BB3}} + 0.0315 \text{ EAP}_{\text{BB4}} \\ 21 \quad \quad \quad + 0.0758 \text{ HRP}_{\text{GNS}} + 0.1009 \text{ HRP}_{\text{GNG}} \\ 22 \quad \quad \quad + 0.1115 \text{ HRP}_{\text{BB1}} + 0.0796 \text{ HRP}_{\text{BB2}} \\ 23 \quad \quad \quad + 0.0938 \text{ HRP}_{\text{BB3}} + 0.0692 \text{ HRP}_{\text{BB4}})$$

24

Where:

25 GPIP = Generating performance incentive points.

1 EAP = Equivalent availability points awarded/deducted for
2 Units 5 and 6 at Gannon and Units 1, 2, 3 and 4 at
3 Big Bend.

4 HRP = Average net heat rate points awarded/deducted for
5 Units 5 and 6 at Gannon and Units 1, 2, 3 and 4 at
6 Big Bend.

7

8 Q. Have you prepared a document summarizing the GPIF targets
9 for the April 1998 - September 1998 period?

10

11 A. Yes. The availability and heat rate targets for each unit
12 are listed on attachment "A" to this testimony entitled
13 "Tampa Electric Company GPIF Targets, April 1, 1998
14 - September 30, 1998".

15

16 Q. Do you wish to sponsor an exhibit consisting of estimated
17 unit performance data supporting the fuel adjustment?

18

19 A. Yes I do. (Have identified as Exhibit GAK-3).

20

21 Q. Briefly describe this exhibit.

22

23 A. This exhibit consists of 23 pages. This data is Tampa Electric
24 Company's estimate of the Unit Performance Data and Unit Outage
25 Data for the April 1998 - September 1998 period.

1 Q. Does this conclude your testimony?

2

3 A. Yes.

4

5

6

7

8

9

10

11

12

13

14

ATTACHMENT "A"

January 14, 1998

**TAMPA ELECTRIC COMPANY
GPIF TARGETS**
April 1, 1998 - September 30, 1998

Unit	Availability			Heat Rate
	EAF	POF	EUOF	
Gannon 5	84.8	0	15.2	10,377 ^L
Gannon 6	81.1	7.7	11.3	10,527 ^L
Big Bend 1	78.3	7.7	14.0	10,267 ^L
Big Bend 2	86.4	0	13.6	10,225 ^L
Big Bend 3	68.8	18.0	13.2	9,778 ^L
Big Bend 4	91.9	0	8.1	9,831 ^L

^L Original Sheet 6.401.98E, Pg. 13

¹ Original Sheet 6.401.98E, Pg. 14

² Original Sheet 6.401.98E, Pg. 15

³ Original Sheet 6.401.98E, Pg. 16

⁴ Original Sheet 6.401.98E, Pg. 17

⁵ Original Sheet 6.401.98E, Pg. 18

TAMPA ELECTRIC COMPANY
GENERATING PERFORMANCE INCENTIVE FACTOR
APRIL 1998 - SEPTEMBER 1998
TABLE OF CONTENTS

<u>SCHEDULE</u>	<u>PAGE</u>
GPIF REWARD / PENALTY TABLE ESTIMATED	2
GPIF CALCULATIONS OF MAXIMUM ALLOWED INCENTIVE DOLLARS	3
GPIF TARGET AND RANGE SUMMARY	4
COMPARISION GPIF TARGETS VS PRIOR PERIODS ACTUAL PERFORMANCE	5
GPIF HEAT RATE SUMMARY	5
DERIVATION OF WEIGHTING FACTORS	6
GENERATING PERFORMANCE INCENTIVE POINT TABLES	7 - 12
ESIMATED UNIT PERFORMANCE DATA	13 - 18
PLANNED OUTAGE SCHEDULE	19
CRITICAL PATH METHOD DIAGRAMS	20
TAMPA ELECTRIC COMPANY FORCED OUTAGE AND MAINTENANCE OUTAGE FACTOR GRAPHS	21 - 26
NET HEAT RATE VS NET OUTPUT FACTOR GRAPHS	27 - 32
GENERATING UNITS IN GPIF (TABLE 4.2 IN MANUAL)	33
UNIT RATINGS AS OF APRIL 1, 1998	34
PROJECTED PERCENT GENERATION BY UNIT	35

TAMPA ELECTRIC COMPANY
GENERATING PERFORMANCE INCENTIVE POINTS TABLE
REWARD / PENALTY TABLE - ESTIMATED
APRIL 1998 - SEPTEMBER 1998

GENERATING PERFORMANCE INCENTIVE POINTS (GPIP)	FUEL SAVINGS / (LOSS) (\$000)	GENERATING PERFORMANCE INCENTIVE FACTOR (\$000)
+10	6,630.7	2,371.6
+9	5,967.6	2,134.5
+8	5,304.6	1,897.3
+7	4,641.5	1,660.1
+6	3,978.4	1,423.0
+5	3,315.4	1,185.8
+4	2,652.3	948.7
+3	1,989.2	711.5
+2	1,326.1	474.3
+1	663.1	237.2
0	0	0.0
-1	(972.8)	(237.2)
-2	(1,945.5)	(474.3)
-3	(2,918.3)	(711.5)
-4	(3,891.0)	(948.7)
-5	(4,863.8)	(1,185.8)
-6	(5,836.6)	(1,423.0)
-7	(6,809.3)	(1,660.1)
-8	(7,782.1)	(1,897.3)
-9	(8,754.8)	(2,134.5)
-10	(9,727.6)	(2,371.6)

TAMPA ELECTRIC COMPANY
GENERATING PERFORMANCE INCENTIVE FACTOR
CALCULATION OF MAXIMUM ALLOWED INCENTIVE DOLLARS
ESTIMATED
APRIL 1998 - SEPTEMBER 1998

Line 1	Beginning of period balance of common equity	\$1,181,288,000
	End of month common equity:	
Line 2	Month of April	1998
Line 3	Month of May	1998
Line 4	Month of June	1998
Line 5	Month of July	1998
Line 6	Month of August	1998
Line 7	Month of September	1998
Line 8	(summation of line 1 through line 7 divided by 7)	\$1,177,502,143
Line 9	25 Basis points	0.0025
Line 10	Revenue expansion factor	61.3738%
Line 11	Maximum allowed incentive Dollars (Line 8 times line 9 divided by line 10 times 0.5)	\$2,398,218
Line 12	Jurisdictional Sales	8432514 MWH
Line 13	Total Sales	8527063 MWH
Line 14	Jurisdictional Separation Factor (Line 12 divided by line 13)	98.89%
Line 15	Maximum Allowed Jurisdictional Incentive Dollars (Line 11 times line 14)	\$2,371,627

TAMPA ELECTRIC COMPANY

GPIF TARGET AND RANGE SUMMARY

APRIL 1998 - SEPTEMBER 1998

EQUIVALENT AVAILABILITY

<u>PLANT/UNIT</u>	<u>WEIGHTING FACTOR (%)</u>	<u>EAF TARGET (%)</u>	<u>EAF MAX. (%)</u>	<u>RANGE MIN. (%)</u>	<u>MAX. FUEL SAVINGS (\$000)</u>	<u>MAX. FUEL LOSS (\$000)</u>
GANNON 5	5.22%	84.8	87.9	78.9	146.2	(660.8)
GANNON 6	5.06%	81.1	83.8	75.9	335.4	(823.9)
BIG BEND 1	10.92%	78.3	81.5	72.0	724.0	(1,391.9)
BIG BEND 2	9.38%	86.4	89.1	81.0	622.0	(1,212.2)
BIG BEND 3	13.19%	68.8	72.3	61.7	874.4	(1,694.8)
BIG BEND 4	3.15%	91.9	93.5	88.7	208.9	(424.2)
GPIF SYSTEM	46.92%				3,110.9	(6,207.8)

AVERAGE NET OPERATING HEAT RATE
FOR
GPIF COAL GENERATING UNITS

<u>PLANT/UNIT</u>	<u>WEIGHTING FACTOR (%)</u>	<u>ANOHR Btm/wth</u>	<u>TARGET NOF</u>	<u>ANOHR TARGET RANGE MIN.</u>	<u>ANOHR TARGET RANGE MAX.</u>	<u>MAX. FUEL SAVINGS (\$000)</u>	<u>MAX. FUEL LOSS (\$000)</u>
GANNON 5	7.58%	103.77	89.0	98.99	108.55	502.6	(502.6)
GANNON 6	10.09%	106.27	91.3	101.27	109.27	669.3	(669.3)
BIG BEND 1	11.15%	102.67	83.6	99.01	106.33	739.0	(739.0)
BIG BEND 2	7.96%	102.25	83.1	98.95	105.55	527.8	(527.8)
BIG BEND 3	9.38%	97.78	94.5	94.36	101.20	621.7	(621.7)
BIG BEND 4	6.92%	98.31	96.6	96.43	100.19	459.4	(459.4)
GPIF SYSTEM	53.08%					3,519.8	(3,519.8)

TAMPA ELECTRIC COMPANY
COMPARISON OF CHP TARGETS VS. PREM PERIOD ACTUAL PERFORMANCE

ORIGINAL SHEET NO. 6.401.97E
PAGE 5 OF 35

AVAILABILITY

PLANT/UNIT	TARGET WEIGHTING FACTOR	TARGET PERIOD APR '91 - SEP '91			ACTUAL PERFORMANCE APR '91 - SEP '91			ACTUAL PERFORMANCE OCT '91 - MAR '92			ACTUAL PERFORMANCE APR '92 - SEP '92					
		POW	ELCP	ELCR	POW	ELCP	ELCR	POW	ELCP	ELCR	POW	ELCP	ELCR			
REC BOND 1	1.00%	21.1	7.1	14.0	11.2	26.1	13.2	11.8	9.1	13.8	11.2	11.8	6.2	11.1	11.1	
REC BOND 1	0.30%	20.8	8.9	13.8	13.6	20.9	15.0	13.8	8.8	12.8	12.8	9.8	10.5	10.4	10.4	
REC BOND 1	1.11%	20.1	10.9	13.2	16.1	15.1	14.9	17.4	9.9	16.3	16.3	8.7	15.7	15.3	15.3	
REC BOND 1	0.7%	6.9	8.1	8.1	8.0	20.6	20.6	11.9	5.3	6.2	6.9	7.3	11.0	4.6	5.2	5.2
DAWN BOND 1	5.12%	11.1	6.9	10.5	11.2	9.0	10.1	10.1	11.8	23.8	4.7	11.2	11.8	8.6	12.5	8.6
DAWN BOND 1	5.30%	10.8	7.9	11.3	11.2	8.8	21.5	21.5	9.5	11.8	30.1	5.2	7.4	3.9	11.2	5.2
CHP SYSTEM BUDGET AVO	0.17%	100.0	7.7	11.1	14.1	10.4	17.3	19.2	7.1	14.8	11.8	13.3	7.3	12.2	13.2	6.6
CHP SYSTEM BUDGETED EQUIPMENT AVAILABILITY					79.2			72.1		81.1		80.3		81.1		81.1

1 PERIOD AVERAGE
POW ELCP ELCR
7.1 11.6 11.8
81.1

AVERAGE SELF OPERATING LOAD RATE %

PLANT/UNIT	NORMALIZED WEIGHTING FACTOR	ADJUSTED POW HEAT RATE APR '91 - SEP '91			ADJUSTED POW HEAT RATE APR '91 - SEP '91		
		HEAT RATE	TARGET	ADJUSTED POW HEAT RATE APR '91 - SEP '91	HEAT RATE	ADJUSTED POW HEAT RATE APR '91 - SEP '91	HEAT RATE
CABIN 1	1.00%	14.1	18.77	17.64	14.4	18.77	17.64
CABIN 1	0.30%	19.9	19.77	19.64	19.77	19.77	19.64
REC BOND 1	1.11%	21.8	19.87	19.84	19.87	19.84	19.84
REC BOND 1	0.7%	11.8	19.77	19.64	19.77	19.64	19.64
REC BOND 1	5.12%	17.9	17.97	19.64	17.97	19.64	19.64
REC BOND 1	5.30%	11.8	19.77	19.64	19.77	19.64	19.64
CHP SYSTEM BUDGETED AVAILABILITY	11.00%	100.0		100.0		100.0	

CHP SYSTEM BUDGETED AVAILABILITY HEAT RATE %

1 PERIOD AVERAGE
POW ELCP ELCR
100.0

TAMPA ELECTRIC COMPANY
DERIVATION OF WEIGHTING FACTORS
APRIL 1998 - SEPTEMBER 1998
PRODUCTION COSTING SIMULATION
FUEL COST (\$000)

UNIT PERFORMANCE INDICATOR	AT TARGET	IMPROVEMENT	SAVINGS	WEIGHTING FACTOR (% OF SAVINGS)
EQUIVALENT AVAILABILITY				
EA ₁ GANNON 5	153941.2	153595.0	346.2	5.22%
EA ₂ GANNON 6	153941.2	153605.8	335.4	5.06%
EA ₃ BIG BEND 1	153941.2	153217.2	724.0	10.92%
EA ₄ BIG BEND 2	153941.2	153319.2	622.0	9.38%
EA ₅ BIG BEND 3	153941.2	153066.8	874.4	13.19%
EA ₆ BIG BEND 4	153941.2	153732.3	208.9	3.15%
HEAT RATE				
AHR ₁ GANNON 5	153941.2	153438.6	502.6	7.58%
AHR ₂ GANNON 6	153941.2	153271.9	669.3	10.09%
AHR ₃ BIG BEND 1	153941.2	153202.2	739.0	11.15%
AHR ₄ BIG BEND 2	153941.2	153413.4	527.8	7.96%
AHR ₅ BIG BEND 3	153941.2	153319.5	621.7	9.38%
AHR ₆ BIG BEND 4	153941.2	153481.8	459.4	6.92%
TOTAL SAVINGS				6630.7
				100.00%

(1) Fuel Adjustment Base Case - All unit performance indicators at ts.get.

(2) All other unit performance indicators at target.

(3) Expressed in replacement energy cost.

TAMPA ELECTRIC COMPANY
GENERATING PERFORMANCE INCENTIVE POINTS TABLE
APRIL 1998 - SEPTEMBER 1998
GANNON 5

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	346.2	87.9	+10	502.6	9899
+9	311.6	87.6	+9	452.3	9939
+8	277.0	87.3	+8	402.1	9980
+7	242.3	87.0	+7	351.8	10020
+6	207.7	86.7	+6	301.6	10060
+5	173.1	86.4	+5	251.3	10101
+4	138.5	86.0	+4	201.0	10141
+3	103.9	85.7	+3	150.8	10181
+2	69.2	85.4	+2	100.5	10221
+1	34.6	85.1	+1	50.3	10262
				0.0	10302
0	0.0	84.8	0	0.0	10377
				0.0	10452
-1	(66.1)	84.2	-1	(50.3)	10492
-2	(132.2)	83.6	-2	(100.5)	10533
-3	(198.2)	83.0	-3	(150.8)	10573
-4	(264.3)	82.4	-4	(201.0)	10613
-5	(330.4)	81.9	-5	(251.3)	10654
-6	(396.5)	81.3	-6	(301.6)	10694
-7	(462.6)	80.7	-7	(351.8)	10734
-8	(528.6)	80.1	-8	(402.1)	10774
-9	(594.7)	79.5	-9	(452.3)	10815
-10	(660.8)	78.9	-10	(502.6)	10855

Weighting Factor =

5.22%

Weighting Factor =

7.58%

TAMPA ELECTRIC COMPANY
GENERATING PERFORMANCE INCENTIVE POINTS TABLE
APRIL 1998 - SEPTEMBER 1998
GANNON 6

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	335.4	\$3.8	+10	669.7	10127
+9	301.9	\$3.5	+9	602.4	10160
+8	268.3	\$3.3	+8	535.4	10192
+7	234.8	\$3.0	+7	468.5	10225
+6	201.2	\$2.7	+6	401.6	10257
+5	167.7	\$2.5	+5	334.7	10290
+4	134.2	\$2.2	+4	267.7	10322
+3	100.6	\$1.9	+3	200.8	10355
+2	67.1	\$1.6	+2	133.9	10387
+1	33.5	\$1.4	+1	66.9	10420
				0.0	10452
0	0.0	\$1.1	0	0.0	10487
				0.0	10602
-1	82.4	\$0.6	-1	(66.9)	10635
-2	164.8	\$0.1	-2	(133.9)	10667
-3	247.2	79.5	-3	(200.8)	10700
-4	329.6	79.0	-4	(267.7)	10732
-5	412.0	78.5	-5	(334.7)	10765
-6	494.3	78.0	-6	(401.6)	10797
-7	576.7	77.5	-7	(468.5)	10830
-8	659.1	76.9	-8	(535.4)	10862
-9	741.5	76.4	-9	(602.4)	10895
-10	823.9	75.9	-10	(669.7)	10927

Weighting Factor =

5.06%

Weighting Factor =

10.09%

TAMPA ELECTRIC COMPANY
GENERATING PERFORMANCE INCENTIVE POINTS TABLE
APRIL 1998 - SEPTEMBER 1998
BIG BEND 1

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	724.0	81.3	+10	739.0	9901
+9	651.6	81.2	+9	665.1	9930
+8	579.2	80.9	+8	591.2	9959
+7	506.8	80.5	+7	517.3	9988
+6	434.4	80.2	+6	443.4	10017
+5	362.0	79.9	+5	369.5	10047
+4	289.6	79.6	+4	295.6	10076
+3	217.2	79.3	+3	221.7	10105
+2	144.8	78.9	+2	147.8	10134
+1	72.4	78.6	+1	73.9	10163
				0.0	10192
0	0.0	78.3	0	0.0	10267
				0.0	10342
-1	139.2	77.7	-1	(73.9)	10371
-2	278.4	77.0	-2	(147.8)	10400
-3	417.6	76.4	-3	(221.7)	10429
-4	556.8	75.8	-4	(295.6)	10458
-5	696.0	75.2	-5	(369.5)	10488
-6	835.1	74.5	-6	(443.4)	10517
-7	974.3	73.9	-7	(517.3)	10546
-8	1,113.5	73.3	-8	(591.2)	10575
-9	1,252.7	72.6	-9	(665.1)	10604
-10	1,391.9	72.0	-10	(739.0)	10633

Weighting Factor =

10.92%

Weighting Factor =

11.15%

TAMPA ELECTRIC COMPANY
GENERATING PERFORMANCE INCENTIVE POINTS TABLE
APRIL 1997 - SEPTEMBER 1997
BIG BEND 2

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	622.0	89.1	+10	527.8	9895
+9	559.8	88.8	+9	475.0	9921
+8	497.6	88.6	+8	422.2	9946
+7	435.4	88.3	+7	369.5	9972
+6	373.2	88.0	+6	316.7	9997
+5	311.0	87.8	+5	263.9	10023
+4	248.8	87.5	+4	211.1	10048
+3	186.6	87.2	+3	158.3	10074
+2	124.4	86.9	+2	105.6	10099
+1	62.2	86.7	+1	52.8	10125
				0.0	10150
0	0.0	86.4	0	0.0	10225
				0.0	10300
-1	(121.2)	85.9	-1	(52.8)	10326
-2	(242.4)	85.3	-2	(105.6)	10351
-3	(363.7)	84.8	-3	(158.3)	10377
-4	(484.9)	84.2	-4	(211.1)	10402
-5	(606.1)	83.7	-5	(263.9)	10428
-6	(727.3)	83.2	-6	(316.7)	10453
-7	(848.5)	82.6	-7	(369.5)	10479
-8	(969.8)	82.1	-8	(422.2)	10504
-9	(1,091.0)	81.5	-9	(475.0)	10530
-10	(1,212.2)	81.0	-10	(527.8)	10555

Weighting Factor = 9.38%

Weighting Factor = 7.96%

TAMPA ELECTRIC COMPANY
 GENERATING PERFORMANCE INCENTIVE POINTS TABLE
 APRIL 1998 - SEPTEMBER 1998
 BIG BEND 3

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	874.4	72.3	+10	621.7	9436
+9	787.0	72.0	+9	559.5	9463
+8	699.5	71.6	+8	497.4	9489
+7	612.1	71.3	+7	435.2	9516
+6	524.6	70.9	+6	373.0	9543
+5	437.2	70.6	+5	310.9	9570
+4	349.8	70.2	+4	248.7	9596
+3	262.3	69.9	+3	186.5	9623
+2	174.9	69.5	+2	124.3	9650
+1	87.4	69.2	+1	62.2	9676
				0.0	9703
0	0.0	68.8	0	0.0	9778
				0.0	9853
-1	169.5	68.1	-1	(62.2)	9880
-2	339.0	67.4	-2	(124.3)	9906
-3	508.4	66.7	-3	(186.5)	9933
-4	677.9	66.0	-4	(248.7)	9960
-5	847.4	65.3	-5	(310.9)	9987
-6	1,016.9	64.5	-6	(373.0)	10013
-7	1,186.4	63.8	-7	(435.2)	10040
-8	1,355.8	63.1	-8	(497.4)	10067
-9	1,525.3	62.4	-9	(559.5)	10093
-10	1,694.8	61.7	-10	(621.7)	10120

Weighting Factor =

13.19%

Weighting Factor =

9.38%

TAMPA ELECTRIC COMPANY
GENERATING PERFORMANCE INCENTIVE POINTS TABLE
APRIL 1998 - SEPTEMBER 1998
BIG BEND 4

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS / (LOSS) (\$ X 1000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	208.9	93.5	+10	459.4	9643
+9	188.0	93.3	+9	413.5	9654
+8	167.1	93.2	+8	367.5	9666
+7	146.2	93.0	+7	321.6	9677
+6	125.3	92.9	+6	275.6	9688
+5	104.5	92.7	+5	229.7	9700
+4	83.6	92.5	+4	183.8	9711
+3	62.7	92.4	+3	137.8	9722
+2	41.8	92.2	+2	91.9	9733
+1	20.9	92.1	+1	45.9	9745
				0.0	9756
0	0.0	91.9	0	0.0	9831
				0.0	9906
-1	42.4	91.6	-1	(45.9)	9917
-2	84.8	91.3	-2	(91.9)	9929
-3	127.3	90.9	-3	(137.8)	9940
-4	169.7	90.6	-4	(183.8)	9951
-5	212.1	90.3	-5	(229.7)	9963
-6	254.5	90.0	-6	(275.6)	9974
-7	296.9	89.7	-7	(321.6)	9985
-8	339.4	89.3	-8	(367.5)	9996
-9	381.8	89.0	-9	(413.5)	10008
-10	424.2	88.7	-10	(459.4)	10019

Weighting Factor =

3.15%

Weighting Factor =

6.92%

TAMPA ELECTRIC COMPANY

ESTIMATED UNIT PERFORMANCE DATA

APRIL 1998 - SEPTEMBER 1998

PLANT/UNIT	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	PERIOD
	APR 98	MAY 98	JUN 98	JUL 98	AUG 98	SEP 98	SUMMER 1998
1. EAF (%)	84.8	84.8	84.9	84.8	84.8	84.9	84.8
2. POF	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3. EUOF	15.2	15.2	15.1	15.2	15.2	15.1	15.2
4. EUOR	15.2	15.2	15.1	15.2	15.2	15.1	15.2
5. PH	719	744	720	744	744	720	4391
6. SH	520	579	565	582	577	554	3377
7. RSH	0	0	0	0	0	0	0
8. UH	199	165	155	162	167	166	1014
9. POH	0	0	0	0	0	0	0
10. FOH & EFOH	91	94	91	94	94	91	555
11. MOH & EMOH	18	19	18	19	19	18	111
12. OPER BTU (GBTU)	1012.687	1208.767	1190.892	1242.364	1258.846	1166.432	7079.988
13. NET GEN (MWH)	96660	117790	114682	118414	120145	112374	682265
14. ANOHR (BTU/KWH)	102.4	102.62	103.84	104.92	104.78	103.80	103.77
15. NOF (%)	83.8	89.6	89.4	89.6	91.7	89.4	89.0
16. NSC (MW)	227	227	227	227	227	227	227
17. ANOHR EQUATION	ANOHR = NOF(-15.6845) + 11773.1						

FILED:
 SUSPENDED:
 EFFECTIVE: 04/01/98
 DOCKET NO.: 980001-EI
 ORDER NO.:

TAMPA ELECTRIC COMPANY

ESTIMATED UNIT PERFORMANCE DATA

APRIL 1998 - SEPTEMBER 1998

PLANT/UNIT	MONTH OF APR 98	MONTH OF MAY 98	MONTH OF JUN 98	MONTH OF JUL 98	MONTH OF AUG 98	MONTH OF SEP 98	PERIOD
GANNON 6							SUMMER 1998
1 EAF (%)	87.8	48.1	87.8	87.8	87.8	87.8	81.1
2 POF	0.0	45.2	0.0	0.0	0.0	0.0	7.7
3 EUOF	12.2	6.7	12.2	12.2	12.2	12.2	11.3
4 EUOR	12.2	12.2	12.2	12.2	12.2	12.2	12.2
5 PH	719	744	720	744	744	720	4391
6 SH	589	188	664	688	691	664	3484
7 RSH	0	0	0	0	0	0	0
8 UH	130	556	56	56	53	56	907
9 POH	0	336	0	0	0	0	336
10 FOH & EFOH	52	29	52	54	54	52	292
11 MOH & EMOH	36	20	36	37	37	36	203
12 OPER BTU (GBTU)	1992.805	682.217	2299.682	2403.682	2481.654	2300.657	12120.697
13 NET GEN (MWH)	190715	63435	218368	227292	232992	218540	1151342
14 ANOHR (BTU/KWH)	0	10439	10531	10575	10565	10527	10527
15 NOF (%)	0.0	93.2	90.8	91.3	93.1	90.9	91.3
16 NSC (MW)	362	362	362	362	362	362	362
17 ANOHR EQUATION	ANOHR = NOF(7.0159) + 9886.9						

FILED
 SUSPENDED
 EFFECTIVE 04/01/98
 DOCKET NO. 980001-EI
 ORDER NO.

TAMPA ELECTRIC COMPANY

ESTIMATED UNIT PERFORMANCE DATA

APRIL 1998 - SEPTEMBER 1998

PLANT/UNIT	MONTH OF: APR 98	MONTH OF: MAY 98	MONTH OF: JUN 98	MONTH OF: JUL 98	MONTH OF: AUG 98	MONTH OF: SEP 98	PERIOD
BIG BEND 1							SUMMER 1998
1 EAF (%)	84.8	46.5	84.9	84.8	84.8	84.9	78.3
2 POF	0.0	45.2	0.0	0.0	0.0	0.0	7.7
3 EUOF	15.2	8.3	15.1	15.2	15.2	15.1	14.0
4 EUOR	15.2	15.2	15.1	15.2	15.2	15.1	15.2
5 PH	719	744	720	744	744	720	4391
6 SH	631	652	631	652	652	631	3849
7 RSH	0	0	0	0	0	0	0
8 UH	68	92	89	92	92	89	542
9 POH	0	336	0	0	0	0	336
10 FOH & EFOH	73	42	73	76	76	73	413
11 MOH & EMOH	36	20	36	37	37	36	202
12 OPER BTU (GBTU)	2120 115	2393 865	2305 252	2394 573	2445 504	2255 806	13915 115
13 NET GEN (MWH)	207322	234521	224742	231572	237094	220034	1355285
14 ANOHR (BTU/KWH)	0	10207	10257	10341	10314	10252	10267
15 NOF (%)	0.0	85.4	84.6	84.4	86.4	82.8	83.6
16 NSC (MW)	421	421	421	421	421	421	421
17 ANOHR EQUATION	ANOHR = NOF(-24.5419) + 12319.0						

FILED
SUSPENDED
EFFECTIVE: 04/01/98
DOCKET NO: 980001-EI
ORDER NO:

TAMPA ELECTRIC COMPANY

ESTIMATED UNIT PERFORMANCE DATA

APRIL 1998 - SEPTEMBER 1998

PLANT/UNIT	MONTH OF: APR 98	MONTH OF: MAY 98	MONTH OF: JUN 98	MONTH OF: JUL 98	MONTH OF: AUG 98	MONTH OF: SEP 98	PERIOD SUMMER 1998
BIG BEND 2							
1 EAF (%)	86.5	86.4	86.4	86.4	86.4	86.4	86.4
2 POF	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3 EUOF	13.5	13.6	13.6	13.6	13.6	13.6	13.6
4 EUOR	13.5	13.6	13.6	13.6	13.6	13.6	13.6
5 PH	719	744	720	744	744	720	4391
6 SH	0	475	647	669	669	647	3107
7 RSH	0	0	0	0	0	0	0
8 UH	719	269	73	75	75	73	1284
9 POH	0	0	0	0	0	0	0
10 FOH & EFOH	65	68	66	68	68	66	401
11 MOH & EMOH	32	33	32	33	33	32	195
12 OPER BTU (GBTU)	0.000	1684.906	2290.572	2356.782	2403.776	2250.711	10986.729
13 NET GEN (MWH)	0	165727	224283	229579	234675	220229	1074473
14 ANOHR (BTU/KWH)	ERR	10167	10214	10266	10243	10220	10225
15 NOF (%)	ERR	83.9	83.3	82.5	84.3	81.8	83.1
16 NSC (MW)	416	416	416	416	416	416	416
17 ANOHR EQUATION	ANOHR = NOF(-29.1068) + 12644.0						

FILED
SUSPENDED
EFFECTIVE 04/01/98
DOCKET NO 980001-EI
ORDER NO

TAMPA ELECTRIC COMPANY

ESTIMATED UNIT PERFORMANCE DATA

APRIL 1998 - SEPTEMBER 1998

PLANT/UNIT	MONTH OF: APR 98	MONTH OF: MAY 98	MONTH OF: JUN 98	MONTH OF: JUL 98	MONTH OF: AUG 98	MONTH OF: SEP 98	PERIOD SUMMER 1998
BIG BEND 3 GPIF							
1 EAF (%)	0.0	75.7	83.9	83.9	83.9	83.9	68.8
2 POF	100.0	9.7	0.0	0.0	0.0	0.0	18.0
3 EUOF	0.0	14.7	16.1	16.1	16.1	16.1	13.2
4 EUOR	0.0	16.2	16.1	16.1	16.1	16.1	16.1
5 PH	719	744	720	744	744	720	4391
6 SH	650	672	650	672	672	650	3966
7 RSH	0	0	0	0	0	0	0
8 UH	69	72	70	72	72	70	425
9 POH	719	72	0	0	0	0	791
10 FOH & EFOH	0	81	86	89	89	86	431
11 MOH & EMOH	0	28	30	31	31	30	150
12 OPER BTU (GBTU)	2488.362	2642.519	2584.899	2701.851	2709.689	2590.362	15717.682
13 NET GEN (MWH)	250834	267861	265525	277736	278882	266780	1607419
14 ANOHR (BTU/KWH)	9928	9865	9735	9728	9716	9710	9778
15 NOF (%)	89.9	92.9	95.2	96.3	96.7	95.7	94.5
16 NSC (MW)	429	429	429	429	429	429	429
17 ANOHR EQUATION	ANOHR = NOF(-21.5491) + 11814 ..						

FILED
SUSPENDED
EFFECTIVE 04/01/98
DOCKET NO 980001-EI
ORDER NO

TAMPA ELECTRIC COMPANY

ESTIMATED UNIT PERFORMANCE DATA

APRIL 1998 - SEPTEMBER 1998


PLANT/UNIT	MONTH OF: APR 98	MONTH OF: MAY 98	MONTH OF: JUN 98	MONTH OF: JUL 98	MONTH OF: AUG 98	MONTH OF: SEP 98	PERIOD SUMMER 1998
BIG BEND 4							
1. EAF (%)	91.9	91.9	91.9	91.9	91.9	91.9	91.9
2. POF	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3. EUOF	8.1	8.1	8.1	8.1	8.1	8.1	8.1
4. EUOR	8.1	8.1	8.1	8.1	8.1	8.1	8.1
5. PH	719	744	720	744	744	720	4391
6. SH	673	696	673	696	696	673	4107
7. RSH	0	0	0	0	0	0	0
8. UH	46	48	47	48	48	47	284
9. POH	0	0	0	0	0	0	0
10. FOH & EFOH	35	36	35	36	36	35	213
11. MOH & EMOH	23	24	23	24	24	23	141
12. OPER BTU (GBTU)	2808.084	2916.288	2820.716	2927.185	2941.222	2821.623	17235.118
13. NET GEN (MWH)	288392	299012	286648	295509	296863	286737	1753161
14. ANOHR (BTU/KWH)	9737	9753	9640	9906	9906	9640	9631
15. NOF (%)	96.9	97.2	96.4	96.1	96.5	96.4	96.6
16. NSC (MW)	442	442	442	442	442	442	442
17. ANOHR EQUATION	ANOHR = NOF(-34.5416) + 13167.6						

FILED
SUSPENDED
EFFECTIVE 04/01/98
DOCKET NO 980001-EI
ORDER NO.



TAMPA ELECTRIC COMPANY
PLANNED OUTAGE SCHEDULE (ESTIMATED)
GPIF UNITS
APRIL 1998 - SEPTEMBER 1998

PLANT / UNIT	PLANNED OUTAGE DATES	OUTAGE DESCRIPTION
• BIG BEND 3	MAR 16 - MAY 03	HTSH (PARTIAL REPL.) REPLACE 'A' MILL BULL GEAR REPL. PPTR PLATES CHEMICAL CLEAN REFL. FURNACE FLOOR REF. HP INSP. (BORESONIC) BURNER MANAGEMENT MILL CLASSIFIER MODIFICATION NOx MODIFICATIONS GENERATOR INSP BFPT INSPECTION
+ BIG BEND 1	MAY 18 - MAY 31	FUEL SYSTEM CLEAN-UP
+ GANNON 6	MAY 04 - MAY 17	FUEL SYSTEM CLEAN-UP


• OUTAGE START / END DATE OUT OF GPIF PERIOD
+ CPM WAS NOT INCLUDED FOR THIS UNIT, OUTAGE IS LESS THAN 2 WEEKS




TAMPA ELECTRIC COMPANY
B10 BEDD UNIT NO. 3
PLANNED OUTAGE 1998
PROJECTED CPN
01/01/98





Gannon Unit 6
EFOF




Gannon Unit 6
EMOF








Big Bend Unit 2
EEOF




Big Bend Unit 2
EMOF






Big Bend Unit 4

EFOF




Big Bend Unit 4


EMOF




TAMPA ELECTRIC COMPANY
 HEAT RATE VS. NET OUTPUT FACTOR
 GANNON 5, SUMMER 1998



TAMPA ELECTRIC COMPANY
 HEAT RATE VS. NET OUTPUT FACTOR
 GANNON 6, SUMMER 1998




TAMPA ELECTRIC COMPANY
 HEAT RATE VS. NET OUTPUT FACTOR
 BIG BEND 1, SUMMER 1998




TARGET NET HEAT RATE: 10,267
 TARGET NET OUTPUT FACTOR: 83.6


TAMPA ELECTRIC COMPANY
 HEAT RATE VS. NET OUTPUT FACTOR
 BIG BEND 2, SUMMER 1998




TAMPA ELECTRIC COMPANY
 HEAT RATE VS. NET OUTPUT FACTOR
 BIG BEND 3, SUMMER 1998



TAMPA ELECTRIC COMPANY
 HEAT RATE VS. NET OUTPUT FACTOR
 BIG BEND 3, SUMMER 1998



TAMPA ELECTRIC COMPANY
 HEAT RATE VS. NET OUTPUT FACTOR
 BIG BEND 4, SUMMER 1998



TAMPA ELECTRIC COMPANY
TABLE 4.2
GENERATING UNITS IN GPIF
APRIL 1998 - SEPTEMBER 1998

UNIT	MDC GROSS (MW)	NDC NET (MW)
GANNON 5	240	227
GANNON 6	375	362
BIG BEND 1	435	421
BIG BEND 2	430	416
BIG BEND 3	445	429
BIG BEND 4	470	442
TOTAL	2395	2297
SYSTEM TOTAL	3686	3478
% OF SYSTEM TOTAL	64.98%	66.04%

TAMPA ELECTRIC COMPANY
UNITS RATINGS
APRIL 1998 - SEPTEMBER 1998

UNIT	MDC GROSS (MW)	NDC NET (MW)
HOOKERS POINT 1	33	32
HOOKERS POINT 2	33	32
HOOKERS POINT 3	33	32
HOOKERS POINT 4	43	41
HOOKERS POINT 5	58	55
HOOKERS TOTAL	200	192
GANNON 1	120	114
GANNON 2	115	108
GANNON 3	165	155
GANNON 4	180	169
GANNON 5	240	227
GANNON 6	375	362
GANNON TOTAL	1195	1135
BIG BEND 1	435	421
BIG BEND 2	430	416
BIG BEND 3	445	428
BIG BEND 4	470	442
BIG BEND TOTAL	1780	1707
GANNON CT	15	15
BIG BEND CT1	15	15
BIG BEND CT2	65	65
BIG BEND CT3	65	65
CT TOTAL	160	160
PHILLIPS 1	18	17
PHILLIPS 2	18	17
PHILLIPS TOTAL	36	34
POLK	315	250
SYSTEM TOTAL	3686	3478

TAMPA ELECTRIC COMPANY
PERCENT GENERATION BY UNIT
APRIL 1998 - SEPTEMBER 1998

STATION	UNIT	NET OUTPUT MWH	% OF PROJECTED OUTPUT	% CUMULATIVE PROJECTED OUTPUT
BIG BEND	4	1,753,162	17.82%	17.82%
BIG BEND	3	1,607,419	16.33%	34.15%
BIG BEND	1	1,355,285	13.77%	47.92%
BIG BEND	2	1,074,473	10.92%	58.84%
GANNON	6	1,151,342	11.70%	70.54%
POLK		840,381	8.54%	79.08%
GANNON	5	682,266	6.93%	86.01%
GANNON	4	428,905	4.36%	90.37%
GANNON	3	397,932	4.04%	94.41%
GANNON	1	256,168	2.60%	97.02%
GANNON	2	176,817	1.80%	98.81%
HOOKERS POINT	5	19,438	0.20%	99.01%
HOOKERS POINT	4	16,220	0.16%	99.18%
HOOKERS POINT	1	14,438	0.15%	99.32%
HOOKERS POINT	2	12,723	0.13%	99.45%
HOOKERS POINT	3	12,301	0.13%	99.58%
PHILLIPS	1	10,431	0.11%	99.68%
PHILLIPS	2	10,208	0.10%	99.79%
BIG BEND CT	2	9,530	0.10%	99.88%
BIG BEND CT	3	8,302	0.08%	99.97%
BIG BEND CT	1	1,594	0.02%	99.99%
GANNON CT	1	1,453	0.01%	100.00%
TOTAL GENERATION		9,840,788	100.00%	
GENERATION BY COAL UNITS		9,724,150	MWH	
% GENERATION BY COAL UNITS		98.81%		
GENERATION BY OIL UNITS		116,638	MWH	
% GENERATION BY OIL UNITS		1.19%		
GENERATION BY GPIF UNITS		7,623,947	MWH	
% GENERATION BY GPIF UNITS		77.47%		

**TAMPA ELECTRIC COMPANY
GENERATING PERFORMANCE INCENTIVE FACTOR
APRIL 1998 - SEPTEMBER 1998
TABLE OF CONTENTS**

SCHEDULE	PAGE
BIG BEND 1 - ESTIMATED UNIT PERFORMANCE DATA	2
BIG BEND 2 - ESTIMATED UNIT PERFORMANCE DATA	3
BIG BEND 3 - ESTIMATED UNIT PERFORMANCE DATA	4
BIG BEND 4 - ESTIMATED UNIT PERFORMANCE DATA	5
GANNON 1 - ESTIMATED UNIT PERFORMANCE DATA	6
GANNON 2 - ESTIMATED UNIT PERFORMANCE DATA	7
GANNON 3 - ESTIMATED UNIT PERFORMANCE DATA	8
GANNON 4 - ESTIMATED UNIT PERFORMANCE DATA	9
GANNON 5 - ESTIMATED UNIT PERFORMANCE DATA	10
GANNON 6 - ESTIMATED UNIT PERFORMANCE DATA	11
HOOKERS POINT 1 - ESTIMATED UNIT PERFORMANCE DATA	12
HOOKERS POINT 2 - ESTIMATED UNIT PERFORMANCE DATA	13
HOOKERS POINT 3 - ESTIMATED UNIT PERFORMANCE DATA	14
HOOKERS POINT 4 - ESTIMATED UNIT PERFORMANCE DATA	15
HOOKERS POINT 5 - ESTIMATED UNIT PERFORMANCE DATA	16
GANNON CT1 - ESTIMATED UNIT PERFORMANCE DATA	17
BIG BEND CT1 - ESTIMATED UNIT PERFORMANCE DATA	18
BIG BEND CT2 - ESTIMATED UNIT PERFORMANCE DATA	19
BIG BEND CT3 - ESTIMATED UNIT PERFORMANCE DATA	20
PHILLIPS 1 - ESTIMATED UNIT PERFORMANCE DATA	21
PHILLIPS 2 - ESTIMATED UNIT PERFORMANCE DATA	22
POLK - ESTIMATED UNIT PERFORMANCE DATA	23

TAMPA ELECTRIC COMPANY

ESTIMATED UNIT PERFORMANCE DATA

APRIL 1998 - SEPTEMBER 1998

PLANT/UNIT	MONTH OF: APR 98	MONTH OF: MAY 98	MONTH OF: JUN 98	MONTH OF: JUL 98	MONTH OF: AUG 98	MONTH OF: SEP 98	PERIOD SUMMER 1998
BIG BEND 1							
1. EAF (%)	84.8	46.5	84.9	84.8	84.8	84.9	78.3
2. POF	0.0	45.2	0.0	0.0	0.0	0.0	7.7
3. EUOF	15.2	8.3	15.1	15.2	15.2	15.1	14.0
4. EUOR	15.2	15.2	15.1	15.2	15.2	15.1	15.2
5. PH	719	744	720	744	744	720	4391
6. SH	631	652	631	652	652	631	3849
7. RSH	0	0	0	0	0	0	0
8. UH	88	92	89	92	92	89	542
9. POH	0	336	0	0	0	0	336
10. FOH & EFOH	73	42	73	76	76	73	413
11. MOH & EMOH	36	20	36	37	37	36	202
12. OPER BTU (GBTU)	2120.115	2393.865	2305.252	2394.573	2445.504	2255.806	13915.115
13. NET GEN (MWH)	207322	234521	224742	231572	237094	220034	1355285
14. ANOHR (BTU/KWH)	0	10207	10257	10341	10314	10252	10267
15. NOF (%)	0.0	85.4	84.6	84.4	86.4	82.8	83.6
16. NSC (MW)	421	421	421	421	421	421	421
17. ANOHR EQUATION	ANOHR = NOF(-24.5419) + 12319.0						

FILED
SUSPENDED
EFFECTIVE: 04/01/98
DOCKET NO: 980001-EI
ORDER NO:

TAMPA ELECTRIC COMPANY

ESTIMATED UNIT PERFORMANCE DATA

APRIL 1998 - SEPTEMBER 1998

PLANT/UNIT	MONTH OF: APR 98	MONTH OF: MAY 98	MONTH OF: JUN 98	MONTH OF: JUL 98	MONTH OF: AUG 98	MONTH OF: SEP 98	PERIOD SUMMER 1998
BIG BEND 2							
1 EAF (%)	86.5	86.4	86.4	86.4	86.4	86.4	86.4
2 POF	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3 EUOF	13.5	13.6	13.6	13.6	13.6	13.6	13.6
4 EUOR	13.5	13.6	13.6	13.6	13.6	13.6	13.6
5 PH	719	744	720	744	744	720	4391
6 SH	0	475	647	669	669	647	3107
7 RSH	0	0	0	0	0	0	0
8 UH	719	269	73	75	75	73	1284
9 POH	0	0	0	0	0	0	0
10 FOH & EFOH	65	68	66	68	68	66	401
11 MOH & EMOH	32	33	32	33	33	32	195
12 OPER BTU (GBTU)	0.000	1684.908	2290.572	2356.762	2403.776	2250.711	10986.729
13 NET GEN (MWH)	0	165727	224263	229579	234675	220229	1074473
14 ANOHR (BTU/KWH)	ERR	10167	10214	10266	10243	10220	10225
15 NOF (%)	ERR	83.9	83.3	82.5	84.3	81.8	83.1
16 NSC (MW)	416	416	416	416	416	416	416
17 ANOHR EQUATION	ANOHR = NOF(-29.1068) + 12644.0						

FILED
SUSPENDED
EFFECTIVE 04/01/92
DOCKET NO. 980001-EI
ORDER NO.

TAMPA ELECTRIC COMPANY

ESTIMATED UNIT PERFORMANCE DATA

APRIL 1998 - SEPTEMBER 1998

PLANT/UNIT	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	PERIOD
BIG BEND 3 FADJ	APR 98	MAY 98	JUN 98	JUL 98	AUG 98	SEP 98	SUMMER 1998
1. EAF (%)	0.0	75.7	83.9	83.9	83.9	83.9	68.8
2. POF	100.0	9.7	0.0	0.0	0.0	0.0	18.0
3. EUOF	0.0	14.7	16.1	16.1	16.1	16.1	13.2
4. EUOR	0.0	16.2	16.1	16.1	16.1	16.1	16.1
5. PH	719	744	720	744	744	720	4391
6. SH	650	672	650	672	672	650	3966
7. RSH	0	0	0	0	0	0	0
8. UH	69	72	70	72	72	70	425
9. POH	719	72	0	0	0	0	791
10. FOH & EFOH	0	81	86	89	89	86	431
11. MOH & EMOH	0	28	30	31	31	30	150
12. OPER BTU (GBTU)	2448.122	2599.786	2543.098	2658.159	2665.870	2548.473	15463.508
13. NET GEN (MWH)	250159	265882	259957	268770	269553	260530	1574831
14. ANOHR (BTU/KWH)	9780	9779	9783	9890	9890	9782	9819
15. NOF (%)	89.7	92.2	93.2	93.2	93.5	93.4	92.6
16. NSC (MW)	429	429	429	429	429	429	429
17. ANOHR EQUATION	ANOHR = NOF(-21.5491) + 11814.6						

FILED
 SUSPENDED
 EFFECTIVE 04/01/98
 DOCKET NO. 980001-EI
 ORDER NO.

TAMPA ELECTRIC COMPANY

ESTIMATED UNIT PERFORMANCE DATA

APRIL 1998 - SEPTEMBER 1998

PLANT/UNIT	MONTH OF: APR 98	MONTH OF: MAY 98	MONTH OF: JUN 98	MONTH OF: JUL 98	MONTH OF: AUG 98	MONTH OF: SEP 98	PERIOD SUMMER 1998
BIG BEND 4							
1. EAF (%)	91.9	91.9	91.9	91.9	91.9	91.9	91.9
2. POF	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3. EUOF	8.1	8.1	8.1	8.1	8.1	8.1	8.1
4. EUOR	8.1	8.1	8.1	8.1	8.1	8.1	8.1
5. PH	719	744	720	744	744	720	4391
6. SH	673	696	673	696	696	673	4107
7. RSH	0	0	0	0	0	0	0
8. UH	46	48	47	48	48	47	284
9. POH	0	0	0	0	0	0	0
10. FOH & EFOH	35	36	35	36	36	35	213
11. MOH & EMOH	23	24	23	24	24	23	141
12. OPER BTU (GBTU)	2608.084	2916.288	2820.716	2927.185	2941.222	2821.623	17235.118
13. NET GEN (MWH)	288392	299012	286648	295509	296863	286737	1753161
14. ANOHR (BTU/KWH)	9737	9753	9640	9906	9908	9840	9831
15. NOF (%)	96.9	97.2	96.4	96.1	96.5	96.4	96.6
16. NSC (MW)	442	442	442	442	442	442	442
17. ANOHR EQUATION	ANOHR = NOF(-34.5416) + 13167.6						

FILED
SUSPENDED
EFFECTIVE 04/01/98
DOCKET NO. 980001-EI
ORDER NO.

TAMPA ELECTRIC COMPANY

ESTIMATED UNIT PERFORMANCE DATA

APRIL 1996 - SEPTEMBER 1996

PLANT/UNIT	MONTH OF: APR 96	MONTH OF: MAY 96	MONTH OF: JUN 96	MONTH OF: JUL 96	MONTH OF: AUG 96	MONTH OF: SEP 96	PERIOD SUMMER 1996
GANNON 1							
1 EAF (%)	84.0	84.0	84.0	84.0	84.0	25.1	74.4
2 POF	0.0	0.0	0.0	0.0	0.0	70.0	11.5
3 EUOF	16.0	16.0	16.0	16.0	16.0	4.9	14.2
4 EUOR	16.0	16.0	16.0	16.0	16.0	16.2	16.0
5 PH	719	744	720	744	744	720	4391
6 SH	413	456	439	450	446	124	2328
7 RSH	0	0	0	0	0	0	0
8 UH	306	288	281	294	298	596	2063
9 POH	0	0	0	0	0	504	504
10 FOH & EFOH	68	71	68	71	71	21	370
11 MOH & EMOH	47	48	47	48	48	14	252
12 OPER BTU (GBTU)	503,055	599,237	599,370	589,285	584,495	161,481	3036,923
13 NET GEN (MWH)	43351	49866	49075	50308	49899	13869	256168
14 ANOHR (BTU/KWH)	11604	12065	12213	11714	11714	11643	11855
15 NOF (%)	92.1	95.5	98.1	98.1	98.1	98.1	98.5
16 NSC (MW)	114	114	114	114	114	114	114

FILED
 SUSPENDED
 EFFECTIVE 04/01/96
 DOCKET NO 960001-EI
 ORDER NO.

TAMPA ELECTRIC COMPANY

ESTIMATED UNIT PERFORMANCE DATA

APRIL 1998 - SEPTEMBER 1998

PLANT/UNIT	MONTH OF: APR 98	MONTH OF: MAY 98	MONTH OF: JUN 98	MONTH OF: JUL 98	MONTH OF: AUG 98	MONTH OF: SEP 98	PERIOD SUMMER 1998
GANNON 2							
1. EAF (%)	82.2	82.3	0.0	13.3	82.3	82.2	57.1
2. POF	0.0	0.0	100.0	83.9	0.0	0.0	30.6
3. EUOF	17.8	17.7	0.0	2.8	17.7	17.8	12.3
4. EUOR	17.8	17.7	0.0	17.5	17.7	17.8	17.8
5. PH	719	744	720	744	744	720	4391
6. SH	346	461	78	0	457	415	1757
7. RSH	0	0	0	0	0	0	0
8. UH	373	283	642	744	287	305	2634
9. POH	0	0	720	624	0	0	1344
10. FOH & EFOH	86	89	0	14	89	86	364
11. MOH & EMOH	42	43	0	7	43	42	177
12. OPER BTU (GBTU)	401,742	557,674	96,701	0,000	575,615	504,278	2136,010
13. NET GEN (MWH)	33896	46707	8003	0	46509	41702	176817
14. ANOHR (BTU/KWH)	11852	11940	12083	ERR	12376	12092	12080
15. NOF (%)	90.7	93.8	95.0	ERR	94.2	93.0	93.2
16. NSC (MW)	106	106	106	106	106	106	106

FILED
 SUSPENDED
 EFFECTIVE 04/01/98
 DOCKET NO 980001-EI
 ORDER NO

TAMPA ELECTRIC COMPANY

ESTIMATED UNIT PERFORMANCE DATA

APRIL 1998 - SEPTEMBER 1998

PLANT/UNIT	MONTH OF: APR 98	MONTH OF: MAY 98	MONTH OF: JUN 98	MONTH OF: JUL 98	MONTH OF: AUG 98	MONTH OF: SEP 98	PERIOD SUMMER 1998
GANNON 3							
1. EAF (%)	84.6	84.5	84.6	84.5	84.5	84.6	84.6
2. POF	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3. EUOF	15.4	15.5	15.4	15.5	15.5	15.4	15.4
4. EUOR	15.4	15.5	15.4	15.5	15.5	15.4	15.4
5. PH	719	744	720	744	744	720	4391
6. SH	447	467	450	459	466	410	2699
7. RSH	0	0	0	0	0	0	0
8. UH	272	277	270	285	278	310	1692
9. POH	0	0	0	0	0	0	0
10. FOH & EFOH	79	82	79	82	82	79	483
11. MOH & EMOH	32	33	32	33	33	32	195
12. OPER BTU (GBTU)	727,625	794,451	776,868	796,877	803,788	700,159	4599,768
13. NET GEN (MWH)	63528	68905	67182	68602	69185	60530	397932
14. ANOHR (BTU/KWH)	11454	11530	11564	11616	11618	11567	11559
15. NOF (%)	91.7	95.2	96.3	96.4	95.8	95.2	95.1
16. NSC (MW)	155	155	155	155	155	155	155

FILED
 SUSPENDED
 EFFECTIVE 04/01/98
 DOCKET NO 980001-EI
 ORDER NO

TAMPA ELECTRIC COMPANY

ESTIMATED UNIT PERFORMANCE DATA

APRIL 1998 - SEPTEMBER 1998

PLANT/UNIT	MONTH OF: APR 98	MONTH OF: MAY 98	MONTH OF: JUN 98	MONTH OF: JUL 98	MONTH OF: AUG 98	MONTH OF: SEP 98	PERIOD
GANNON 4							SUMMER 1998
1. EAF (%)	83.9	83.9	83.9	83.9	83.9	64.3	80.7
2. POF	0.0	0.0	0.0	0.0	0.0	23.3	3.8
3. EUOF	16.1	16.1	16.1	16.1	16.1	12.4	15.5
4. EUOR	16.1	16.1	16.1	16.1	16.1	16.1	16.1
5. PH	719	744	720	744	744	720	4391
6. SH	455	504	456	460	467	375	2717
7. RSH	0	0	0	0	0	0	0
8. UH	264	240	264	284	277	345	1674
9. POH	0	0	0	0	0	168	168
10. FOH & EFOH	80	83	80	83	83	61	470
11. MOH & EMOH	36	37	36	37	37	28	211
12. OPER BTU (GBTU)	741,148	837,150	839,630	831,571	831,858	682,074	4763,431
13. NET GEN (MWH)	65665	81263	74624	73437	73356	60560	428905
14. ANOHR (BTU/KWH)	11287	10302	11251	11324	11340	11283	11106
15. NOF (%)	80.6	90.1	91.4	89.2	87.8	90.2	88.2
16. NSC (MW)	179	179	179	179	179	179	179

FILED
SUSPENDED
EFFECTIVE 04/01/98
DOCKET NO 980001-EI
ORDER NO

TAMPA ELECTRIC COMPANY

ESTIMATED UNIT PERFORMANCE DATA

APRIL 1998 - SEPTEMBER 1998

PLANT/UNIT	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	PERIOD
	APR 98	MAY 98	JUN 98	JUL 98	AUG 98	SEP 98	SUMMER 1998
1. EAF (%)	84.8	84.8	84.9	84.8	84.8	84.9	84.8
2. POF	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3. EUOF	15.2	15.2	15.1	15.2	15.2	15.1	15.2
4. EUOR	15.2	15.2	15.1	15.2	15.2	15.1	15.2
5. PH	719	744	720	744	744	720	4391
6. SH	520	579	565	582	577	554	3377
7. RSH	0	0	0	0	0	0	0
8. UH	199	165	155	162	167	166	1014
9. POH	0	0	0	0	0	0	0
10. FOH & EFOH	91	94	91	94	94	91	555
11. MOH & EMOH	18	19	18	19	19	18	111
12. OPER BTU (GBTU)	1012.687	1208.767	1190.892	1242.364	1258.846	1166.432	7079.988
13. NET GEN (MWH)	96860	117790	114682	118414	120145	112374	682265
14. ANOHR (BTU/KWH)	10244	10262	10384	10492	10478	10380	10377
15. NOF (%)	83.8	89.6	89.4	89.6	91.7	89.4	89.0
16. NSC (MW)	227	227	227	227	227	227	227
17. ANOHR EQUATION	ANOHR = NOF(-15.6845) + 11773.1						

FILED
 SUSPENDED
 EFFECTIVE 04/01/98
 DOCKET NO 980001-EI
 ORDER NO

TAMPA ELECTRIC COMPANY

ESTIMATED UNIT PERFORMANCE DATA

APRIL 1998 - SEPTEMBER 1998

PLANT/UNIT	MONTH OF: APR 98	MONTH OF: MAY 98	MONTH OF: JUN 98	MONTH OF: JUL 98	MONTH OF: AUG 98	MONTH OF: SEP 98	PERIOD SUMMER 1998
GANNON 6							
1. EAF (%)	87.8	48.1	87.8	87.8	87.8	87.8	81.1
2. POF	0.0	45.2	0.0	0.0	0.0	0.0	7.7
3. EUOF	12.2	6.7	12.2	12.2	12.2	12.2	11.3
4. EUOR	12.2	12.2	12.2	12.2	12.2	12.2	12.2
5. PH	719	744	720	744	744	720	4391
6. SH	569	168	664	668	691	664	3484
7. RSH	0	0	0	0	0	0	0
8. UH	130	556	56	56	53	56	907
9. POH	0	336	0	0	0	0	336
10. FOH & EFOH	52	29	52	54	54	52	292
11. MOH & EMOH	36	20	36	37	37	36	203
12. C. R BTU (GBTU)	1992.805	662.217	2299.682	2403.682	2461.654	2300.657	12120.697
13. NET GEN (MWH)	190715	63435	218368	227292	232992	218540	1151342
14. ANOHR (BTU/KWH)	0	10439	10531	10575	10565	10527	10527
15. NOF (%)	0.0	93.2	90.8	91.3	93.1	90.9	91.3
16. NSC (MW)	362	362	362	362	362	362	362
17. ANOHR EQUATION	ANOHR = NOF(7.0159) + 9886.9						

FILED
SUSPENDED
EFFECTIVE 04/01/98
DOCKET NO 980001-EI
ORDER NO

TAMPA ELECTRIC COMPANY

ESTIMATED UNIT PERFORMANCE DATA

APRIL 1998 - SEPTEMBER 1998

PLANT/UNIT	MONTH OF: APR 98	MONTH OF: MAY 98	MONTH OF: JUN 98	MONTH OF: JUL 98	MONTH OF: AUG 98	MONTH OF: SEP 98	PERIOD SUMMER 1998
HOOKERS PT 1							
1 EAF (%)	93.0	93.0	93.1	93.0	93.0	93.1	93.0
2 POF	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3 EUOF	7.0	7.0	6.9	7.0	7.0	6.9	7.0
4 EUOR	7.0	7.0	6.9	7.0	7.0	6.9	7.0
5 PH	719	744	720	744	744	720	4391
6 SH	32	78	89	117	105	52	473
7 RSH	0	0	0	0	0	0	0
8 UH	687	666	631	627	639	668	3918
9 POH	0	0	0	0	0	0	0
10 FOH & EFOH	35	36	35	36	36	35	213
11 MOH & EMOH	15	16	15	16	16	15	93
12 OPER BTU (GBTU)	16942	37371	43154	57460	51294	24821	231042
13 NET GEN (MWH)	1029	2350	2722	3579	3194	1564	14438
14 ANOHR (BTU/KWH)	16465	15903	15854	16055	16059	15870	16002
15 NOF (%)	100.5	94.2	95.6	95.6	95.1	94.0	95.4
16 NSC (MW)	32	32	32	32	32	32	32

FILED
SUSPENDED
EFFECTIVE 14/01/98
DOCKET NO 980001-EI
ORDER NO

TAMPA ELECTRIC COMPANY

ESTIMATED UNIT PERFORMANCE DATA

APRIL 1998 - SEPTEMBER 1998

PLANT/UNIT	MONTH OF: APR 98	MONTH OF: MAY 98	MONTH OF: JUN 98	MONTH OF: JUL 98	MONTH OF: AUG 98	MONTH OF: SEP 98	PERIOD SUMMER 1998
HOOKERS PT 2							
1 EAF (%)	93.0	93.0	93.1	93.0	93.0	93.1	93.0
2 POF	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3 EUOF	7.0	7.0	6.9	7.0	7.0	6.9	7.0
4 EUOR	7.0	7.0	6.9	7.0	7.0	6.9	7.0
5 PH	719	744	720	744	744	720	4391
6 SH	37	61	74	108	96	41	417
7 RSH	0	0	0	0	0	0	0
8 UH	682	683	646	636	648	679	3974
9 POH	0	0	0	0	0	0	0
10 FOH & EFOH	35	36	35	36	36	35	213
11 MOH & EMOH	15	16	15	16	16	15	93
12 OPER BTU (GBTU)	19 159	29 191	36 158	52 747	46 739	19 728	203 722
13 NET GEN (MWH)	1175	1839	2268	3289	2914	1237	12722
14 ANOHR (BTU/KWH)	16306	15873	15943	16037	16039	15948	16013
15 NOF (%)	99.2	94.2	95.8	95.2	94.9	94.3	95.3
16 NSC (MW)	32	32	32	32	32	32	32

FILED
SUSPENDED
EFFECTIVE 04/01/98
DOCKET NO 980001-EI
ORDER NO.

TAMPA ELECTRIC COMPANY

ESTIMATED UNIT PERFORMANCE DATA

APRIL 1998 - SEPTEMBER 1998

PLANT/UNIT	MONTH OF: APR 98	MONTH OF: MAY 98	MONTH OF: JUN 98	MONTH OF: JUL 98	MONTH OF: AUG 98	MONTH OF: SEP 98	PERIOD SUMMER 1998
HOOKERS PT 3							
1. EAF (%)	93.0	93.0	93.1	93.0	93.0	93.1	93.0
2. POF	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3. EUOF	7.0	7.0	6.9	7.0	7.0	6.9	7.0
4. EUOR	7.0	7.0	6.9	7.0	7.0	6.9	7.0
5. PH	719	744	720	744	744	720	4391
6. SH	52	86	82	73	64	46	403
7. RSH	0	0	0	0	0	0	0
8. UH	667	658	638	671	680	674	3968
9. POH	0	0	0	0	0	0	0
10. FOH & EFOH	35	36	35	36	36	35	213
11. MOH & EMOH	15	16	15	16	16	15	93
12. OPER BTU (GBTU)	26,715	41,003	39,481	36,763	31,761	22,171	197,894
13. NET GEN (MWH)	1658	2606	2484	2232	1928	1394	12302
14. ANOHR (BTU/KWH)	16113	15734	15894	16471	16474	15805	16086
15. NOF (%)	99.6	94.7	94.7	95.5	94.1	94.7	95.4
16. NSC (MW)	32	32	32	32	32	32	32

FILED
SUSPENDED
EFFECTIVE 04/01/98
DOCKET NO 980001-EI
ORDER NO

TAMPA ELECTRIC COMPANY

ESTIMATED UNIT PERFORMANCE DATA

APRIL 1998 - SEPTEMBER 1998

PLANT/UNIT	MONTH OF: APR 98	MONTH OF: MAY 98	MONTH OF: JUN 98	MONTH OF: JUL 98	MONTH OF: AUG 98	MONTH OF: SEP 98	PERIOD SUMMER 1998
HOOKERS PT 4							
1. EAF (%)	93.0	93.0	93.1	93.0	93.0	93.1	93.0
2. POF	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3. EUOF	7.0	7.0	6.9	7.0	7.0	6.9	7.0
4. EUOR	7.0	7.0	6.9	7.0	7.0	6.9	7.0
5. PH	719	744	720	744	744	720	4391
6. SH	60	70	68	99	87	36	420
7. RSH	0	0	0	0	0	0	0
8. UH	659	674	652	645	657	684	3971
9. POH	0	0	0	0	0	0	0
10. FOH & EFOH	35	36	35	36	36	35	213
11. MOH & EMOH	15	16	15	16	16	15	93
12. OPER BTU (GBTU)	38,144	42,346	42,209	62,249	54,777	22,293	262,018
13. NET GEN (MWH)	2397	2665	2614	3811	3353	1380	16220
14. ANOHR (BTU/KWH)	15913	15890	16147	16334	16337	16154	16154
15. NOF (%)	97.4	92.9	93.8	93.9	94.0	93.5	94.2
16. NSC (MW)	41	41	41	41	41	41	41

FILED
 SUSPENDED
 EFFECTIVE 04/01/98
 DOCKET NO 980001-EI
 ORDER NO

TAMPA ELECTRIC COMPANY

ESTIMATED UNIT PERFORMANCE DATA

APRIL 1998 - SEPTEMBER 1998

PLANT/UNIT	MONTH OF: APR 98	MONTH OF: MAY 98	MONTH OF: JUN 98	MONTH OF: JUL 98	MONTH OF: AUG 98	MONTH OF: SEP 98	PERIOD SUMMER 1998
HOOKERS PT 5							
1. EAF (%)	85.0	84.8	84.9	84.8	84.8	84.9	84.9
2. POF	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3. EUOF	15.0	15.2	15.1	15.2	15.2	15.1	15.1
4. EUOR	15.0	15.2	15.1	15.2	15.2	15.1	15.1
5. PH	719	744	720	744	744	720	4391
6. SH	40	48	53	77	67	27	312
7. RSH	0	0	0	0	0	0	0
8. UH	679	696	667	667	677	683	4079
9. POH	0	0	0	0	0	0	0
10. FOH & EFOH	76	82	79	82	82	79	483
11. MOH & EMOH	29	31	30	31	31	30	182
12. OPER BTU (GBTU)	40,156	48,015	54,165	79,708	69,218	27,197	318,459
13. NET GEN (MWH)	2477	2946	3311	4843	4204	1658	19439
14. ANOHR (BTU/KWH)	16212	16296	16350	16458	16465	16403	16382
15. NOF (%)	112.6	111.6	113.6	114.4	114.1	111.6	113.3
16. NSC (MW)	55	55	55	55	55	55	55

FILED
SUSPENDED
EFFECTIVE 04/01/98
DOCKET NO 980001-EI
ORDER NO

TAMPA ELECTRIC COMPANY

ESTIMATED UNIT PERFORMANCE DATA

APRIL 1998 - SEPTEMBER 1998

PLANT/UNIT	MONTH OF: APR 98	MONTH OF: MAY 98	MONTH OF: JUN 98	MONTH OF: JUL 98	MONTH OF: AUG 98	MONTH OF: SEP 98	PERIOD SUMMER 1998
GANNON CT 1							
1 EAF (%)	77.9	77.8	77.9	42.6	77.8	41.5	65.9
2 POF	0.0	0.0	0.0	45.2	0.0	46.7	15.3
3 EUOF	22.1	22.2	22.1	12.2	22.2	11.8	18.8
4 EUOR	22.1	22.2	22.1	22.3	22.2	22.1	22.2
5 PH	719	744	720	744	744	720	4391
6 SH	13	16	17	15	27	11	93
7 RSH	0	0	0	0	0	0	0
8 UH	708	728	703	729	717	709	4292
9 POH	0	0	0	336	0	336	672
10 FOH & EFOH	144	149	144	82	149	77	745
11 MOH & EMOH	15	16	15	9	16	8	79
12 OPER BTU (GBTU)	3,967	4,897	5,289	4,833	8,316	3,499	30,801
13 NET GEN (MWH)	187	231	250	228	392	165	1453
14 ANOHR (BTU/KWH)	21214	21199	21156	21197	21214	21206	21198
15 NOF (%)	95.9	96.3	96.0	101.3	96.8	100.0	97.8
16 NSC (MW)	15	15	15	15	15	15	15

FILED:
SUSPENDED
EFFECTIVE 04/01/98
DOCKET NO 980001-EI
ORDER NO:

TAMPA ELECTRIC COMPANY

ESTIMATED UNIT PERFORMANCE DATA

APRIL 1998 - SEPTEMBER 1998

PLANT/UNIT	MONTH OF: APR 98	MONTH OF: MAY 98	MONTH OF: JUN 98	MONTH OF: JUL 98	MONTH OF: AUG 98	MONTH OF: SEP 98	PERIOD SUMMER 1998
BIG BEND CT 1							
1 EAF (%)	65.0	64.9	34.6	64.9	64.9	65.0	60.0
2 POF	0.0	0.0	46.7	0.0	0.0	0.0	7.7
3 EUOF	35.0	35.1	18.8	35.1	35.1	35.0	32.4
4 EUOR	35.0	35.1	35.2	35.1	35.1	35.0	35.1
5 PH	719	744	720	744	744	720	4391
6 SH	14	17	9	30	28	12	110
7 RSH	0	0	0	0	0	0	0
8 UH	705	727	711	714	716	708	4281
9 POH	0	0	336	0	0	0	336
10 FOH & EFOH	144	149	77	149	149	144	312
11 MOH & EMOH	108	112	58	112	112	108	610
12 OPER BTU (GBTU)	3 860	4 760	2 704	8 407	8 030	3 394	31 155
13 NET GEN (MWH)	197	243	138	430	411	174	1593
14 ANOHR (BTU/KWH)	19594	19588	19594	19551	19538	19506	19557
15 NOF (%)	93.8	95.3	102.2	95.6	97.9	96.7	96.5
16 NSC (MW)	15	15	15	15	15	15	15

FILED
 SUSPENDED
 EFFECTIVE 04/01/98
 DOCKET NO 980001-EI
 ORDER NO

TAMPA ELECTRIC COMPANY

ESTIMATED UNIT PERFORMANCE DATA

APRIL 1998 - SEPTEMBER 1998

PLANT/UNIT	MONTH OF:	PERIOD					
	APR 98	MAY 98	JUN 98	JUL 98	AUG 98	SEP 98	SUMMER 1998
1 EAF (%)	69.1	69.1	69.2	57.8	46.8	69.2	63.4
2 POF	0.0	0.0	0.0	16.1	32.3	0.0	8.2
3 EUOF	30.9	30.9	30.8	26.1	21.0	30.8	28.4
4 EUOR	30.9	30.9	30.8	31.1	31.0	30.8	30.9
5 PH	719	744	720	744	744	720	4391
6 SH	23	28	28	46	21	20	166
7 RSH	0	0	0	0	0	0	0
8 UH	696	716	692	698	723	700	4225
9 POH	0	0	0	120	240	0	360
10 FOH & EFOH	111	115	111	97	78	111	623
11 MOH & EMOH	111	115	111	97	78	111	623
12 OPER BTU (GBTU)	21 049	26 014	26 606	43 568	20 306	18 079	155 622
13 NET GEN (MWH)	1286	1589	1627	2670	1255	1104	9531
14 ANOHR (BTU/KWH)	16368	16371	16353	16318	16180	16376	16328
15 NOF (%)	86.0	87.3	89.4	89.3	91.9	84.9	88.3
16 NSC (MW)	65	65	65	65	65	65	65

FILED
 SUSPENDED
 EFFECTIVE 04/01/98
 DOCKET NO 980001-EI
 ORDER NO

TAMPA ELECTRIC COMPANY

ESTIMATED UNIT PERFORMANCE DATA

APRIL 1998 - SEPTEMBER 1998

PLANT/UNIT	MONTH OF:	PERIOD					
	APR 98	MAY 98	JUN 98	JUL 98	AUG 98	SEP 98	SUMMER 1998
1 EAF (%)	69.1	69.1	69.2	69.1	53.5	69.2	66.5
2 POF	0.0	0.0	0.0	0.0	22.6	0.0	3.8
3 EUOF	30.9	30.9	30.8	30.9	23.9	30.8	29.7
4 EUOR	30.9	30.9	30.8	30.9	30.9	30.8	30.9
5 PH	719	744	720	744	744	720	4391
6 SH	18	22	23	36	28	15	144
7 RSH	0	0	0	0	0	0	0
8 UH	701	722	697	706	716	705	4247
9 POH	0	0	0	0	168	0	168
10 FOH & EFOH	111	115	111	115	89	111	652
11 MOH & EMOH	111	115	111	115	89	111	652
12 OPER BTU (GBTU)	17 176	21 150	21 946	36 577	27 742	14 308	138 899
13 NET GEN (MWH)	1024	1261	1310	2188	1665	854	8302
14 ANOHR (BTU/KWH)	16773	16772	16753	16717	16662	16754	16731
15 NOF (%)	87.5	88.2	87.6	88.6	91.5	87.6	88.7
16 NSC (MW)	65	65	65	65	65	65	65

FILED
 SUSPENDED
 EFFECTIVE 04/01/98
 DOCKET NO 980001-EI
 ORDER NO

TAMPA ELECTRIC COMPANY

ESTIMATED UNIT PERFORMANCE DATA

APRIL 1998 - SEPTEMBER 1998

PLANT/UNIT	MONTH OF: APR 98	MONTH OF: MAY 98	MONTH OF: JUN 98	MONTH OF: JUL 98	MONTH OF: AUG 98	MONTH OF: SEP 98	PERIOD SUMMER 1998
PHILLIPS 1							
1. EAF (%)	80.1	80.0	80.0	80.0	80.0	80.0	80.0
2. POF	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3. EUOF	19.9	20.0	20.0	20.0	20.0	20.0	20.0
4. EUOR	19.9	20.0	20.0	20.0	20.0	20.0	20.0
5. PH	719	744	720	744	744	720	4391
6. SH	79	114	109	141	126	66	635
7. RSH	0	0	0	0	0	0	0
8. UH	640	630	611	603	618	654	3756
9. POH	0	0	0	0	0	0	0
10. FOH & EFOH	50	52	50	52	52	50	306
11. MOH & EMOH	93	97	94	97	97	94	572
12. OPER BTU (GBTU)	12.218	17.757	17.054	22.054	19.718	10.305	99.106
13. NET GEN (MWH)	1286	1889	1795	2321	2075	1085	10431
14. ANOHR (BTU/KWH)	9500	9501	9501	9502	9503	9498	9501
15. NOF (%)	95.8	96.4	96.9	96.8	96.9	96.7	96.6
16. NSC (MW)	17	17	17	17	17	17	17

FILED
 SUSPENDED
 EFFECTIVE 04/01/98
 DOCKET NO 980001-EI
 ORDER NO

TAMPA ELECTRIC COMPANY

ESTIMATED UNIT PERFORMANCE DATA

APRIL 1998 - SEPTEMBER 1998

PLANT/UNIT	MONTH OF:	PERIOD					
	APR 98	MAY 98	JUN 98	JUL 98	AUG 98	SEP 98	SUMMER 1998
1 EAF (%)	80.1	80.0	80.0	80.0	80.0	80.0	80.0
2 POF	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3 EUOF	19.9	20.0	20.0	20.0	20.0	20.0	20.0
4 EUOR	19.9	20.0	20.0	20.0	20.0	20.0	20.0
5 PH	719	744	720	744	744	720	4391
6 SH	77	111	107	138	123	64	620
7 RSH	0	0	0	0	0	0	0
8 UH	642	633	613	606	621	656	3771
9 POH	0	0	0	0	0	0	0
10 FOH & EFOH	50	52	50	52	52	50	306
11 MOH & EMOH	93	97	94	97	97	94	572
12 OPER BTU (GBTU)	11,913	17,368	16,722	21,636	19,319	10,039	96,997
13 NET GEN (MWH)	1254	1826	1760	2277	2033	1057	10209
14 ANOHR (BTU/KWH)	9500	9501	9501	9502	9503	9498	9501
15 NOF (%)	95.8	96.9	96.8	97.1	97.2	97.2	96.9
16 NSC (MW)	17	17	17	17	17	17	17

FILED
 SUSPENDED
 EFFECTIVE 04/01/98
 DOCKET NO 980001-EI
 ORDER NO

TAMPA ELECTRIC COMPANY

ESTIMATED UNIT PERFORMANCE DATA

APRIL 1998 - SEPTEMBER 1998

PLANT/UNIT	MONTH OF: APR 98	MONTH OF: MAY 98	MONTH OF: JUN 98	MONTH OF: JUL 98	MONTH OF: AUG 98	MONTH OF: SEP 98	PERIOD SUMMER 1998
POLK							
1 EAF (%)	80.1	54.3	80.1	80.1	54.3	80.1	71.4
2 POF	0.0	32.3	0.0	0.0	32.3	0.0	10.9
3 EUOF	19.9	13.4	19.9	19.9	13.4	19.9	17.7
4 EUOR	19.9	19.8	19.9	19.9	19.8	19.9	19.9
5 PH	719	744	720	744	744	720	4391
6 SH	597	617	597	617	418	597	3443
7 RSH	0	0	0	0	0	0	0
8 UH	122	127	123	127	326	123	948
9 POH	0	240	0	0	240	0	480
10 FOH & EFOH	86	60	86	89	60	86	467
11 MOH & EMOH	57	40	57	59	40	57	310
12 OPER BTU (GBTU)	1377.750	1429.820	1385.840	1428.420	968.087	1381.720	7991.637
13 NET GEN (MWH)	145066	150828	145997	150666	102301	145523	840381
14 ANOHR (BTU/KWH)	9497	9480	9492	9481	9659	9495	9510
15 NOF (%)	97.2	97.8	97.8	97.7	97.9	97.5	97.6
16 NSC (MW)	250	250	250	250	250	250	250

FILED
SUSPENDED
EFFECTIVE 04/01/98
DOCKET NO 980001-EI
ORDER NO.: