

930455-WS

A·E
ANGLES
ESTEBAN
ASSOC., INC.
ARCHITECTURE
AND PLANNING
CCA NO. 1457

ORIGINAL
FILE COPY

July 15, 1993

Mr. Jock McCartney
Royal Utility Company
8900 N. W. 44 Court
Coral Springs, Florida 33065

Re: Royal Land, Coventry
Meter Size Requirements

Dear Mr. McCartney:


This letter is to inform you that due to the amount of fixture units on Models A, B & C, which are as follows:

- Model A - 22 F.U.
- Model B - 26 F.U.
- Model C - 31 F.U.

The minimum required meter size shall be 1" meter as per Section 4614.12, table 46Q of the South Florida Building Code, Broward County Edition, which states that any copper line having between 19-55 F.U. shall have a 1" line and a 1" meter.

Sincerely,

ANGLES ESTEBAN ASSOC., INC.



Jorge L. Esteban, AIA

JLE/c

DOCUMENT NUMBER-DATE
07796 JUL2093



BUILDING DEPARTMENT

CITY OF **CORAL SPRINGS** FLORIDA

9530 WEST SAMPLE ROAD
P.O. BOX 754501
CORAL SPRINGS, FL 33075-4501
TELEPHONE (305) 344-1025

July 15, 1993

Mr. Jock McCartney
Royal Utility Company
8900 NW 44 Court
Coral Springs, FL 33065

Re: Royal Land, Coventry
Meter Size Requirements

Dear Mr. McCartney:

This letter is to inform you that I agree with all the facts presented by Angles Esteban Assoc., Inc., in their letter of July 15, 1993 relative to meter sizes in Royal Land Amended.

The code is very specific with the term "shall", it is a mandatory term.

Therefore, as the Chief Plumbing Inspector I have no choice but to enforce the requirements of the code.

Sincerely,

William Burns
Chief Plumbing Inspector