

**RUDEN**  
**MCGLOSKY**  
**SMITH**  
**SCHUSTER &**  
**RUSSELL, P.A.**  
ATTORNEYS AT LAW

215 SOUTH MONROE STREET  
SUITE 815  
TALLAHASSEE, FLORIDA 32301

TELEPHONE: (850) 681-9027  
FAX: (850) 224-2032

E-MAIL: BKG@RUDEN.COM

RECEIVED-FPSC

SEP 30 PM 12:43

RECORDS AND  
REPORTING

September 30, 1998

ORIGINAL

Blanca S. Bayo, Director  
Division of Records & Reporting  
Florida Public Service Commission  
2540 Shumard Oak Boulevard  
Tallahassee, FL 32399-0850

VIA HAND DELIVERY

Re: Docket No. 950387-SU (Remand)  
Application of Florida Cities Water Company - North Ft. Myers  
Division - for increased wastewater rates in Lee County.

Dear Ms. Bayo:

Enclosed on behalf of Florida Cities Water Company, for filing  
in the above docket, are an original and fifteen (15) copies of  
following:

1. Remand Testimony of Mike Acosta, along with exhibits (MA-1) through (MA-4); **10756-98**
2. Remand Testimony of Larry Coel, along with exhibit (LC-1); **10757-98**
3. Remand Testimony of Thomas A. Cummings, along with exhibits (TAC-01) and (TAC-2); and **10758-98**
4. our Certificate of Service.

Please acknowledge receipt of the foregoing by stamping the enclosed extra copy of this letter and returning same to my attention. Thank you for your assistance.

Sincerely,

*B. Kenneth Gatlin*

B. Kenneth Gatlin

RECEIVED & FILED

*mas*  
FPSC-BUREAU OF RECORDS

ACK 2  
AFA \_\_\_\_\_  
APP \_\_\_\_\_  
CAF \_\_\_\_\_  
CMU \_\_\_\_\_  
CTR \_\_\_\_\_  
EAG \_\_\_\_\_  
LEG 1  
LIN 3 to go  
OPC \_\_\_\_\_  
RCH \_\_\_\_\_  
SEC \_\_\_\_\_  
WAS Willis  
OTH \_\_\_\_\_

TAL:18783:1

FORT LAUDERDALE ■ MIAMI ■ NAPLES ■ ST. PETERSBURG ■ SARASOTA ■ TALLAHASSEE ■ TAMPA ■ WEST PALM BEACH

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

In re: Application for a rate ) DOCKET NO. 950387-SU  
increase for North Ft. Myers )  
Division in Lee County by )  
Florida Cities Water Company -) Filed: September 30, 1998  
Lee County Division.)

**Certificate of Service**


I HEREBY CERTIFY that a true and correct copy of Remand Testimonies and Exhibits of Mike Acosta, Larry Coel, and Thomas A. Cummings have been furnished by U.S. Mail this 30th day of September, 1998 to:

Cheryl Walla  
1750 Dockway Drive  
North Fort Myers, FL 33903

Jerilyn Victor  
1740 Dockway Drive  
North Fort Myers, FL 33903

Harold McLean, Associate  
Public Counsel  
Office of Public Counsel  
c/o The Florida Legislature  
Claude Pepper Building,  
Room 812  
111 W. Madison Street  
Tallahassee, FL 32399-1400

Ralph Jaeger, Esquire  
(Hand Delivery)  
Division of Legal Services  
Florida Public Service  
Commission  
2540 Shumard Oak Boulevard  
Tallahassee, FL 32399-0850



---

B. KENNETH GATLIN  
Fla. Bar No.: 0027966  
Ruden, McClosky, Smith,  
Schuster & Russell, P.A.  
215 South Monroe Street,  
Suite 815  
Tallahassee, FL 32301  
Phone: (850) 681-9027  
Attorneys for Florida Cities  
Water Company

ORIGINAL

1 FLORIDA CITIES WATER COMPANY

2 NORTH FORT MYERS DIVISION

3 REMAND TESTIMONY OF THOMAS A. CUMMINGS

4 Docket No. 950387-SU

5 Q. Please state your name and business address.

6 A. My name is Thomas A. Cummings. My business address is  
7 Black & Veatch, 201 South Orange Avenue, Suite 500,  
8 Orlando, Florida 32801.

9 Q. Please describe your educational background and your  
10 professional qualifications.

11 A. I received my Bachelor of Science degree in Civil  
12 Engineering from Purdue University in 1979, and have  
13 completed Master of Science degree course work in  
14 Environmental Engineering and Science from the University  
15 of Missouri through 1985. I am a registered professional  
16 engineer in the Florida and Kansas. I was originally  
17 registered in Kansas, in March, 1984, after passing the  
18 examination in sanitary engineering, and registered in  
19 Florida in August, 1990.

20 Q. Please describe your professional engineering experience  
21 concerning water and wastewater utilities.

22 A. I have over 12 years continuous experience as a  
23 registered professional engineer specializing in  
24 studying, planning, designing, permitting and managing  
25 the construction of water and wastewater facilities for

DOCUMENT NUMBER-DATE

10758 SEP 30 88

FPSC-RECORDS/REPORTING

1 public and private investor-owned utilities in the State  
2 of Florida. I have been engineer-of-record for the  
3 design and permitting of five wastewater and/or water  
4 treatment plants, and assisted with the design,  
5 permitting and construction management of numerous  
6 others. I have studied and designed water treatment  
7 facilities utilizing biological and chemical treatments.  
8 I have been involved in the hydraulic model analysis and  
9 mechanical review of over fifteen water and wastewater  
10 systems and the preparation of over 25 water and/or  
11 wastewater treatment plant facility designs. My design  
12 and permitting experience also includes over 30 miles of  
13 raw water mains, potable water mains and force mains  
14 ranging in size from 4 inches to 60 inches.

15 Q. By whom are you presently employed?

16 A. I am currently employed by Black & Veatch.

17 Q. Please briefly describe the services that Black & Veatch  
18 provides.

19 A. Black & Veatch is a professional engineering and  
20 consulting firm that has 80 offices and over 6,000  
21 employees. The services that Black & Veatch can provide  
22 are capabilities in the environmental, civil, electric,  
23 power, building, process, and management consulting  
24 fields as well as procurement and construction.

25 Q. What is your position with Black & Veatch?

1 A. I am a project manager/project engineer.

2 Q. How long have you held that position?

3 A. I have held this position since 1985.

4 Q. What are your normal duties for Black & Veatch?

5 A. The majority of my time I am responsible for engineering  
6 duties for numerous projects and clients for which my  
7 role is either the project manager, or project engineer,  
8 depending upon the nature and scope of our services.

9 Q. Please describe the responsibilities of a project  
10 manager.

11 A. The responsibilities of a project manager include the  
12 establishment of the project structure, both technical  
13 and financial. The project manager is accountable to the  
14 company for meeting project financial goals and technical  
15 requirements. The manager will also ensure that the  
16 client's project goals are also met.

17 Q. Please describe the responsibilities of a project  
18 engineer.

19 A. The project engineer is responsible for the production of  
20 the project and product. The project engineer will  
21 coordinate all technical activities and disciplines to  
22 achieve project goals.

23 Q. What is the purpose of your testimony?

24 A. The purpose of my testimony is to describe the basis of  
25 design for the FCWC Waterway Estates Wastewater Treatment

1 Plant located in N. Fort Myers, Lee County, specifically  
2 as it relates to the issue and relationship of annual  
3 average daily flow and peak flows.

4 Q. Were you the Black & Veatch project manager for the  
5 Waterway Estates WWTP expansion to provide advanced  
6 wastewater treatment?

7 A. Yes, I was.

8 Q. Did you prepare the preliminary design report and the  
9 FDEP permit application for the Waterway Estates WWTP  
10 expansion?

11 A. Yes, I did. For purposes of this testimony, I will be  
12 referring to Figures 2-5 of that report. Exhibit \_\_\_\_  
13 (TAC-1).

14 Q. Are you the engineer of record for this facility?

15 A. Yes.

16 Q. What are the responsibilities and duties of the engineer  
17 record?

18 A. The engineer of record is a Florida Registered  
19 Professional Engineer that develops the design criteria  
20 and concepts for the project and is responsible for the  
21 preparation of the construction documents.

22 Q. Did Black & Veatch provide the final design and  
23 construction management services for the Waterway Estates  
24 WWTP ("WWTP") expansion?

25 A. Yes, it did.

1 Q. What is the capacity of the WWTP that was actually  
2 constructed by FCWC?

3 A. The plant capacity is 1.25 MGD based upon the average  
4 annual daily flow and the waste concentration associated  
5 with this flow.

6 Q. Why did you design a 1.25 mgd plant based upon the  
7 average annual flow and waste concentration associated  
8 with this flow?

9 A. Based on our analysis of historical data it was Black and  
10 Veatch's professional opinion that a 1.3 mgd plant was  
11 the appropriate necessary and economically sized plant to  
12 treat the flows, including peak flows and to properly  
13 treat the pollutant loading associated with those flows.  
14 The size of 1.25 was determined to be the most economical  
15 size of plant to provide reuse water to the receiving  
16 area and to meet FDER requirements for discharging  
17 effluent over 1.0 mgd to reuse.

18 Q. Please explain how plant capacity is determined.

19 A. Wastewater treatment plants are normally designed to  
20 remove solids and dissolved pollutants contained in the  
21 raw wastewater received by the plant. The plants are  
22 normally permitted by the regulatory agency to meet  
23 effluent requirements on an annual average basis. Of  
24 course, the flow received by a wastewater treatment plant  
25 is not constant, but varies during the day in

1 relationship to the activities of the customers connected  
2 to the plant. The flows also vary daily and seasonally  
3 throughout any given year in response to weather  
4 conditions, the influx of seasonal and tourist  
5 population, changes in the number of wastewater  
6 customers, etc. Therefore, these variations must be  
7 considered when designing the plant and are normally  
8 calculated from historical or industry literature data as  
9 a multiple of the annual average daily design flow.

10 The peak hour flow results when customers are most  
11 active during the daytime hours and any plant design must  
12 be able to hydraulically allow this flow to pass through  
13 the plant to prevent the treatment units from overflowing  
14 and at the same time, provide full treatment.

15 Each individual unit process must be analyzed in  
16 relationship to accepted design standards to determine  
17 its ability to meet effluent quality limits under varying  
18 flow conditions associated with the annual average daily  
19 design flow. Even though these unit processes may  
20 provide acceptable effluent quality in response to short-  
21 term variations in influent flow, the plant generally  
22 will not be able to meet these limits on a continuous  
23 basis.

24 The plant capacity is not only based upon the  
25 hydraulic load received by the facility, it is also based



1 upon the load or quantity of pollutants carried by the  
2 flow which require treatment or removal in order to meet  
3 the effluent limitations. The pollutant load is normally  
4 determined based upon the average annual daily design  
5 flow and the associated design pollutant concentrations.  
6 Therefore, the plant capacity determination must also  
7 take into account the ability of the unit processes to  
8 remove the influent pollutant load down to levels that  
9 meet the effluent limitations.

10 The final determination of plant capacity is based  
11 upon the ability to respond to variations in raw  
12 wastewater flow and pollutant load, and whichever of  
13 these variables is the most limiting upon plant capacity  
14 is usually the final determining factor.

15 Q. Did you determine the 1.25 mgd capacity of the Waterway  
16 Estates WWTP using the considerations you just described?

17 A. Yes.

18 Q. What was the design process used by Black & Veatch to  
19 form the basis of design for the Waterway Estates  
20 Wastewater Treatment Plant?

21 A. The design process created an analytical model using the  
22 actual influent to this plant. Based on this influent,  
23 a biological model of the treatment process was made, and  
24 this model was compared to the existing plant facilities;  
25 tanks, mixers, and blowers to determine an economical

1 facility expansion that would provide proper treatment.

2 Q. What were the parameters input into the analytical model  
3 to determine the plant treatment capacity?

4 A. The plant biological process model and resulting plant  
5 expansion was based not only on an increase in plant  
6 hydraulic flow in million gallons per day (mgd), but also  
7 on the constituents in the incoming waste stream. The  
8 plant is required by its Florida Department of  
9 Environmental Protection (FDEP) discharge permit to  
10 remove specific constituents from the waste stream.  
11 These constituents include Biochemical Oxygen Demand  
12 (BOD), Total Suspended Solids (TSS), Total Nitrogen (TN),  
13 and Total Phosphorus (TP). It is only by designing  
14 around removal of these constituents that an economical  
15 plant expansion can be achieved. As stated in the Manual  
16 of Practice No. 8, Wastewater Treatment Plant Design,  
17 1977, prepared by the national Water Pollution Control  
18 Federation (MOP/8):

19 "The selection of a process train or alternative  
20 process trains should be made on the ability of the  
21 individual unit processes to remove specific waste  
22 constituents. If the makeup of all wastes were  
23 identical, the selection of a process package would be  
24 relatively simple. However, variations in the  
25 constituents and the relative portions of waste

1 constituents in each phase complicate process selection  
2 unless the waste characterization is known. Knowledge of  
3 the wastewater condition and constituents is important so  
4 that the most applicable process train can be assembled."

5 The design of the WWTP was consistent with this  
6 standard of practice.

7 The constituents of interest by FDEP are listed in  
8 MOP/8 within Table 1-II and 1-III of the chapter entitled  
9 "Wastewater Parameters of Significance to the Design  
10 Engineer" Exhibit \_\_\_\_\_ (TAC-2). MOP-8 is a standard  
11 publication relied upon in designing wastewater treatment  
12 plants.

13 Q. How were the concentrations of incoming waste stream  
14 constituents determined?

15 A. Historical wastewater concentrations serve as the basis  
16 of design for sizing or setting the capacity of the  
17 expanded wastewater treatment facility. Process loading  
18 design criteria that were used in evaluating the unit  
19 operations and processes at the WWTP are as follows:

20 Average Design Loading - Mean concentration based on  
21 historical data. This load is used to estimate sludge  
22 production and turndown capability for blowers and RAS  
23 pumps.

24 Maximum Design Loading - Estimated as the mean plus  
25 two times the standard deviation of the data. This value

1 represents the 95<sup>th</sup> percentile of the constituents'  
2 concentration data range for the plant and is  
3 approximately equal to the maximum monthly value. This  
4 loading is used in the modeling and sizing of the  
5 biological treatment process and sludge treatment  
6 processes.

7 Peak Design Loading - Computed as the maximum design  
8 loading times a peaking factor of 1.5 for carbonaceous  
9 load and 1.3 for nitrogenous load. This loading  
10 represents the peak day load to the biological system.  
11 This load is used to calculate the peak standard oxygen  
12 transfer rate (SOTR) required for the biological system.  
13 This rate is utilized in sizing blowers for the aeration  
14 system.

15 This approach is consistent with MOP/8 in Chapter I  
16 under the section "Flows for Design." This section  
17 describes the design average flow rate as "the average  
18 flow during same maximum significant period such as 4, 8,  
19 12 or 16 hours." The average monthly influent  
20 concentrations for the WWTP from January 1986 to March  
21 1992 were reviewed and used to create the preliminary  
22 engineering design report Figures 2 and 5. Exhibit \_\_\_\_  
23 (TAC-1). As identified in the preliminary engineering  
24 design report, the statistical analysis of the monthly  
25 average influent concentrations yielded the following for

1 the mean and mean plus two standard deviations (2S):

2		<u>Mean</u>	<u>Mean +2S</u>
3	Biochemical Oxygen Demand (BOD <sub>5</sub> ),		
4	Mg/l	200	312
5	Total Suspended Solids (TSS), mg/l	242	379
6	Total Kjeldah Nitrogen (TKN), mg/l	33.3	53.2
7	Total Phosphorus (as PO <sub>4</sub> ), mg/l	7.8	12.4

8 The mean + 2S, or maximum design concentrations was  
9 used throughout the design. Average monthly BOD<sub>5</sub>, TSS,  
10 TKN, and PO, are illustrated in Figures 2 to 5. Exhibit  
11 \_\_\_\_\_ (TAC-1). The average and maximum design  
12 concentrations are indicated on the figures for  
13 reference. The annual average BOD<sub>5</sub> concentration  
14 remained relatively constant during the 1986 to 1992  
15 timeframe. The average influent TSS concentration  
16 appeared to increase with time. With the distinct  
17 exception of high values from October 1988 to February  
18 1989, the average influent TKN concentration was very  
19 consistent during the timeframe studied. The influent  
20 phosphorus concentration appeared to decrease since 1986,  
21 except for the second half of 1989.

22 Q. Is the process described above consistent with standard  
23 design practice for wastewater treatment plants?

24 A. Yes.

25 Q. What are the target constituents required for removal at

1 the Waterways Estates Wastewater Treatment Plant?

2 A. Final effluent from the Waterway Estates WWTP is  
3 discharged into the Caloosahatchee River near the site,  
4 pursuant to FDEP Permit No. FL0030325. The FDEP has  
5 established the following maximum concentrations in  
6 milligrams per liter (mg/l) for this surface water  
7 discharge:

8 Monthly Average Concentration

9 5-Day Biochemical

10 Oxygen Demand (BOD <sub>5</sub> )	20 mg/l (monthly average)
11 Total Suspended Solids (TSS)	20 mg/l (monthly average)
12 Total Nitrogen (TN)	3 mg/l (monthly average)
13 Total Phosphorus (TP)	0.5 mg/l (daily maximum)

14 The design of the plant expansion was based on  
15 achieving these permit limits as a minimum. The use of  
16 the denitrification filters to meet the total nitrogen  
17 limit resulted in an effluent TSS which was considerably  
18 lower than 20 mg/l. Likewise, the biological system  
19 design was controlled by the nitrification requirements,  
20 not the carbon removal, and effluent BOD<sub>5</sub> levels were  
21 well below the required 20 mg/l BOD<sub>5</sub> limit as a result.

22 Q. What analytical model was used to predict the then  
23 existing and potential expanded plant's biological  
24 treatment capacity and how does it work?

25 A. The biological system was modeled with the Black & Veatch

1 Completely Mixed Activated Sludge (CMAS) program. The  
2 program is set up for modeling the anoxic\oxic activated  
3 sludge process. The oxic portion of the model is based  
4 on first order kinetics for removal of organics as  
5 developed by Dr. Ross McKinney. Influent wastewater  
6 characteristics input into the model include: BOD<sub>5</sub>, TSS,  
7 VSS/TSS ratio, alkalinity, peaking factors for the  
8 carbonaceous and nitrogenous load, and temperature.  
9 Other major parameters input include: the desired  
10 dissolved oxygen concentration in the mixed liquor; alpha  
11 and beta factors dependent on the type of aeration system  
12 selected; and the desired sludge age or mixed liquor  
13 suspended solids (MLSS) concentration to be maintained.

14 The anoxic/oxic mode of operation for the activated  
15 sludge is used because biological  
16 nitrification/denitrification can be accomplished as well  
17 as carbon removal. In the oxic zone, heterotrophic  
18 bacteria utilize the organics for synthesizing new  
19 biomass and oxidizing a portion to meet energy  
20 requirements for growth and maintenance. Autotrophic  
21 bacteria in the oxic zone (the nitrifiers) are  
22 responsible for the oxidation of ammonia to nitrate  
23 nitrogen. The mixed liquor from the oxic zone containing  
24 a high nitrate concentration must be recycled back to the  
25 anoxic zone where the denitrifying bacteria reduce the

1 nitrate nitrogen to nitrogen gas. The optimum mixed  
2 liquor recycle ratio has been found to be four times the  
3 influent flow into the anoxic zone.

4 The maximum design concentrations of 312 mg/l BOD<sub>5</sub>,  
5 379 mg/l TSS, and 53.2 mg/l TKN were utilized in the  
6 biological process model. Other model inputs supplied by  
7 Bob Dick of FCWC based upon actual wastewater  
8 constituents data are average influent alkalinity of 200  
9 mg/l and average influent volatile suspended solids of  
10 178 mg/l used in establishing the VSS/TSS ratio. A not  
11 to exceed maximum total nitrogen (TN) concentration of 14  
12 mg/l was assumed for the treatment unit effluent which  
13 corresponds to the average design influent TN (14 mg/l)  
14 to the effluent filters.

15 Each biological treatment unit (BTU) was modeled  
16 separately to account for the differences in treatment  
17 capacity and aeration systems. The same mixed liquor  
18 suspended solids (MLSS) was input for BTU #1 and BTU #2  
19 during successive model runs at a given temperature. The  
20 first model run was made using the maximum design  
21 concentrations. The addition of alum to the secondary  
22 clarifiers for phosphorus removal results in the  
23 accumulation of inert solids in the biological process  
24 via the return activated sludge (RAS). This reduces the  
25 volume available for active biomass thereby reducing the



1 biological capacity of the process. The results of this  
2 first run were used to recalculate the influent TSS of  
3 475 mg/l and VSS/TSS ratio of 0.57 for use in the second  
4 model run.

5 Q. What were the results of the model?

6 A. The results of the modeling indicated that no additional  
7 tankage was required for the biological process at the  
8 Phase I average design flow of 1.25 mgd and at maximum  
9 design concentrations. The addition of a MLSS recycle  
10 was necessary to achieve an effluent TN concentration of  
11 less than 14 mg/l. The MLSS recycle supplies nitrates  
12 from the aeration zone to the denitrifiers in the anoxic  
13 zone. The addition of this recycle results in maximum TN  
14 concentrations of approximately 11.6 mg/l and average  
15 concentrations of 7.2 mg/l as loadings to the effluent  
16 filters.

17 The secondary clarifier effluent quality predicted  
18 by the modeling is approximately 2 mg/l BODs, 5 mg/l TSS,  
19 12 mg/l TN, and, <0.5 mg/l TP. The solids loading to  
20 each clarifier is 10 ppd/sq.ft. At the maximum design  
21 MLSS of 3,300 mg/l. The surface overflow rates of 368  
22 gpd/sq.ft @ average flow and 736 gpd/sq.ft @ peak hour  
23 flow are low. Modeling was also performed with the  
24 larger BTU completely out of service as required by DEP  
25 redundancy rules. This illustrated acceptable treatment

1 at 100% ADF, with the flow limiting factor being  
2 clarifier solids loading of 24 ppd/sq.ft at 3,500 MLSS.  
3 The results of modeling the Phase II design flow of 1.5  
4 mgd at maximum design concentrations also indicate that  
5 no additional tankage is required.

6 Q. Based upon your analysis, including the modeling that you  
7 have described, what is your professional opinion as to  
8 the required size and facilities required to adequately  
9 treat the polluted loading at the Waterway Estates Plant?

10 A. It was my professional opinion and recommendation that a  
11 1.3 mgd plant should be built at Waterway Estates with  
12 component necessary to treat the associated pollutant  
13 flow. The size of 1.25 was the most economical size to  
14 address the growth needs for the Waterway Estates and the  
15 FDER requirements to only discharge flows above 1.0 mgd  
16 to reuse.

17 Q. What is the meaning of hydraulic flow rate in the  
18 determination of treatment capacity?

19 A. The treatment plant facilities, pipes, pumps, tanks must  
20 be able to pass a hydraulic flow rate without overflowing  
21 at any point or facility. The flow rate used in the  
22 design is not the annual average flow of 1.25 mgd, but a  
23 daily peak flow rate that is twice the annual average  
24 rate. If the plant was designed for only the annual  
25 average flow rate, the plant would overflow during

1 periods when the flow was above the average. And by  
2 definition, these higher rates will occur.

3 Q. Does this complete your testimony?

4 A. Yes.

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

TAL:18538:1

For exhibit,  
see Hearing Exh. 35