

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

In re: Application for a rate)
increase for North Ft. Myers)
Division in Lee County by)
Florida Cities Water Company -)
Lee County Division.)

Docket No. 950387-SU
Filed: October 13, 1998

REMAND TESTIMONY

OF

TED L. BIDDY, P.E./P.L.S.

ON BEHALF OF THE CITIZENS OF THE STATE OF FLORIDA

Jack Shreve
Public Counsel

Office of the Public Counsel
c/o The Florida Legislature
111 West Madison Street
Room 812
Tallahassee, Florida 32399-1400

(850) 488-9330

Attorney for the Citizens
of the State of Florida

DOCUMENT NUMBER - DATE

11411 OCT 13 98

FPSC-RECORDS/REPORTING

ORIGINAL

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

In re: Application for a rate)
increase for North Ft. Myers)
Division in Lee County by)
Florida Cities Water Company -)
Lee County Division.)

Docket No. 950387-SU
Filed: October 13, 1998

REMAND TESTIMONY

OF

TED L. BIDDY, P.E./P.L.S.

ON BEHALF OF THE CITIZENS OF THE STATE OF FLORIDA

Jack Shreve
Public Counsel

Office of the Public Counsel
c/o The Florida Legislature
111 West Madison Street
Room 812
Tallahassee, Florida 32399-1400

(850) 488-9330

Attorney for the Citizens
of the State of Florida

**REMAND TESTIMONY
OF
TED L. BIDDY, P.E. / P.L.S.**

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

ON BEHALF OF THE

CITIZENS OF THE STATE OF FLORIDA

DOCKET NO. 950387

October 13, 1998

1 **Q. WHAT IS YOUR NAME AND BUSINESS ADDRESS?**

2 A. My name is Ted L. Bidy. My business address is Route 5, Box 65, Havana,
3 Florida 32333.

4 **Q. BY WHOM ARE YOU EMPLOYED AND WHAT IS YOUR POSITION?**

5 A. I am currently self-employed as a professional engineer and land surveyor.

6 **Q. WHAT IS YOUR EDUCATIONAL BACKGROUND AND WORK
7 EXPERIENCE?**

8 A. I graduated from the Georgia Institute of Technology with a B.S. degree in Civil
9 Engineering in 1963. I am a registered professional engineer and land surveyor
10 in Florida, Georgia, Mississippi and several other states. I was the vice-
11 president of Baskerville-Donovan, Inc. (BDI) and the regional manager of
12 Tallahassee Office from April 1991 until February, 1998. Before joining BDI in
13 1991, I had operated my own civil engineering firm for 21 years. My areas of
14 expertise include civil engineering, structural engineering, sanitary engineering,
15 soils and foundation engineering and precise surveying. During my career, I
16 have designed and supervised the master planning, design and construction of
17 thousands of residential, commercial and industrial properties. My work has
18 included: water and wastewater facility design; roadway design; parking lot
19 design; stormwater facilities design; structural design; land surveys; and
20 environmental permitting.

1 I have served as the principal and chief designer for numerous utility
2 projects. Among my major water and wastewater facilities designs have been a
3 2,000 acres development in Lake County, FL; a 1,200 acres development in
4 Ocean Springs, MS; a 4-mile water distribution system for Talquin Electric
5 Cooperative, Inc. and a 320-lot subdivision in Leon County, FL.

6 **Q. WHAT ARE YOUR PROFESSIONAL AFFILIATIONS?**

7 A. I am a member of the Florida Engineering Society, National Society of
8 Professional Engineers, and Florida Society of Professional Land Surveyors.

9 **Q. HAVE YOU PREVIOUSLY TESTIFIED BEFORE A STATE OR
10 FEDERAL COURT AS AN ENGINEERING EXPERT WITNESS?**

11 A. Yes, I have had numerous court appearances as an expert witness for cases
12 involving roadways, utilities, drainage, stormwater, water and wastewater
13 facilities designs.

14 **Q. HAVE YOU PREVIOUSLY TESTIFIED BEFORE THE FLORIDA
15 PUBLIC SERVICE COMMISSION (PSC OR COMMISSION) FOR USED
16 AND USEFUL ANALYSIS AND OTHER ENGINEERING ISSUES?**

17 A. Yes, I have testified before the PSC for Docket Nos. 950495-WS, 950387-SU,
18 951056-WS and 960329-WS on engineering issues and used and useful analysis.

19 **Q. WHAT IS THE PURPOSE OF YOUR TESTIMONY?**

20 A. The purpose of my testimony is to provide additional engineering testimony on

1 the used and useful calculation issues for this rate case. In particular, I address
2 why it is appropriate, from an engineering perspective, to use annual average
3 daily flow in both the numerator and denominator of the used and useful
4 calculation for Florida Cities Water Company's (FCWC) wastewater treatment
5 plant.

6 **Q. DO YOU AGREE WITH THE USED AND USEFUL METHODOLOGY**
7 **PROPOSED BY THE FCWC FOR ITS WASTEWATER TREATMENT**
8 **PLANT (WWTP), AND EXPLAIN WHY?**

9 A. No, I do not. FCWC asserts that the average daily flow of the maximum month
10 (ADFMM) should be used for the numerator in the calculation of used and
11 useful percentage, regardless of how the plant capacity (denominator) is
12 permitted or designed. FCWC argues that ADFMM should be used even though
13 the plant is permitted on the basis of annual average daily flow (AADF). It is
14 clear that AADF and ADFMM are not the same basis.

15 A wastewater treatment plant's capacity can be permitted as AADF or
16 ADFMM by the Florida Department of Environmental Protection (FDEP).
17 Likewise it can be designed by the engineers as AADF or ADFMM. I can not
18 agree with FCWC's proposal because it does not match the flow with the
19 permitted capacity of the plant.

20 **Q. WHAT ARE THE APPROPRIATE NUMBERS TO BE USED FOR THE**

1 **NUMERATOR AND DENOMINATOR IN CALCULATING THE USED**
2 **AND USEFUL PERCENTAGE FOR A WASTEWATER TREATMENT**
3 **PLANT?**

4 A. It depends on what basis the wastewater treatment plant capacity is permitted by
5 FDEP or designed by the engineers. If the plant capacity is permitted or
6 designed on the basis of AADF, then the test year AADF should be used for the
7 numerator. On the other hand, if the plant capacity is permitted on the basis of
8 ADFMM, then the test year average daily flow of maximum month (ADFMM)
9 should be used. Generally, the designed capacity is the same as the FDEP
10 permitted capacity.

11 This method will insure that both numerator and denominator are arrived
12 at from the same basis, i.e. apples to apples or oranges to oranges. To compute
13 the used and useful percentage as FCWC suggests would be to mix comparisons
14 of ADFMM to AADF and would yield a percentage with no meaning, as would
15 comparing apples to oranges.

16 **Q. CAN YOU USE AN EXAMPLE TO DEMONSTRATE THE**
17 **APPROPRIATE METHODOLOGY?**

18 A. Yes. See the following examples for a simple demonstration.

19 Example 1 Wastewater Plant A:

20 Plant Design Capacity = 1.0 MGD on ADFMM basis

1 FDEP Permit Capacity = 1.0 MGD on ADFMM basis

2 Plant ADFMM = 0.9 MGD during the test year

3 Then, Used & Useful % = 0.9 MGD/1.0 MGD = 90%

4 Example 2 Wastewater Plant A:

5 Plant Design Capacity = 1.0 MGD on AADF basis

6 FDEP Permit Capacity = 1.0 MGD on AADF basis

7 Plant AADF = 0.7 MGD during the test year

8 Then, Used & Useful % = 0.7 MGD/1.0 MGD = 70%

9 Example 3 Wastewater Plant A:

10 Plant Design & Permit Capacity = 1.0 MGD on ADFMM basis

11 or 0.8 MGD on AADF basis

12 Plant AADF = 0.7 MGD during the test year

13 Plant ADFMM = 0.9 MGD during the test year

14 Then, Used & Useful % = 0.7 MGD/0.8 MGD = 87.5%

15 or 0.9 MGD/1.0 MGD = 90%

16 The inappropriate methodology requested by FCWC can be seen from
17 the following example.

18 Example 4 Wastewater Plant A:

19 Plant Design & Permit Capacity = 1.0 MGD on AADF basis

20 Plant ADFMM = 0.9 MGD during the test year

1 wastewater plant's capacity; whether they are AADF or ADFMM. For example,
2 the permit of Waterway Estate WWTP only says the plant is expanded to 1.5
3 MGD. It does not specify again that it is AADF, like the original plant's
4 capacity of 1.0 MGD (annual average). See Exhibit TLB-1 for a copy of part of
5 the permit which states the plant capacity. Therefore, technically someone could
6 incorrectly argue that the 1.5 MGD capacity is for ADFMM. However, this
7 confusion can be clarified by checking the original permit application. See the
8 attached Exhibit TLB-2. It is clear that the Basis of Design Flow is checked for
9 AADF.

10 In recent years, the FDEP permits are very clear on the plant capacity
11 basis as either AADF or ADFMM. Therefore, there should be nothing to
12 dispute or argue about in the wastewater plant's used and useful calculation. It
13 is all dictated by the FDEP permits and/or the design capacities. Utilities
14 certainly have taken advantage of the ADFMM to AADF mismatch to obtain
15 higher used and useful percentages in past rate cases. Therefore, it is appropriate
16 for the PSC to correct the previously mismatched used and useful calculation for
17 wastewater treatment plants. In the case of FCWC, however, in Order No. PSC-
18 96-1133-FOF-SU, the PSC correctly matched the AADF to AADF in the used
19 and useful calculation.

20 **Q. DOES THE METHODOLOGY PROPOSED BY FCWC INFLATE THE**

1 **USED AND USEFUL PERCENTAGE AND ADVERSELY IMPACT THE**
2 **CURRENT CUSTOMERS?**

3 A. Yes, the mismatch of ADFMM to AADF will create a higher used and useful
4 percentage than the correct match of AADF to AADF calculation. Therefore,
5 the current customers will pay higher rates because the rate base will be inflated.

6 **Q. WILL THE CORRECT MATCH OF AADF PLANT FLOW TO AADF**
7 **PLANT CAPACITY OR ADFMM PLANT FLOW TO ADFMM PLANT**
8 **CAPACITY GENERATE UNFAIR USED AND USEFUL**
9 **PERCENTAGES FOR UTILITIES?**

10 A. No, there will be no unfair used and useful percentages calculated for the
11 utilities. The correct match of plant flows to plant capacities will generate fair
12 used and useful percentages for the customers and the utilities. The reason is
13 that a WWTP is designed by engineers, and the FDEP uses the engineer's
14 preliminary design report to rate the permit capacity. In the preliminary design
15 report, the plant design flow is determined by engineers: it could be AADF,
16 ADFMM, three-month average daily flow or other flows as permitted by FDEP.
17 The engineers also determined the appropriate design influent characteristics:
18 such as biochemical oxygen demand (BOD), total suspended solids (TSS), total
19 nitrogen, total phosphorous, etc. for the particular flow designed for.

20 FDEP generally will not reduce or increase the plant capacity in its

1 permit unless the design is so abnormal that FDEP has to make adjustments to
2 the design capacity. Therefore, the wastewater plant can handle the permitted
3 capacity unquestionably. However, sometimes the FDEP permit capacity is less
4 than the design plant capacity due to a limited effluent disposal capacity.
5 Waterway Estate WWTP is an typical example of this limitation.

6 **Q. IS THERE ANY BENEFIT THE UTILITY CAN ENJOY FROM THE**
7 **CORRECT MATCH OF PLANT FLOW TO PLANT CAPACITY**
8 **CALCULATION?**

9 A. Yes. The PSC is only comparing the hydraulic loading rate to the WWTP's
10 capacity which is based on both hydraulic loading and biological loading rates,
11 i.e. the design flows and wastewater strength. Normally during rain storm
12 events, WWTP's will have higher flows and the wastewater concentration is
13 diluted due to the excess inflow and infiltration. Therefore, the WWTP still can
14 handle more flows with diluted wastewater, but the design plant capacity is still
15 used as the denominator for the used and useful calculation. Utility witness Mr.
16 Cummings testified that the Waterway Estate WWTP was designed to handle a
17 hydraulic flow rate at twice that of the designed AADF rate.

18 In reality, the PSC could increase the plant capacity and lower the used
19 and useful percentage, however, I would not recommend that because it will be a
20 time consuming and controversial task. Some components in a WWTP are

1 designed for not just the maximum day flow but the peak hourly flows, although
2 an equalization tank is already designed to dampen the peak hourly flows. Most
3 of the time, the PSC calculates a single used and useful percentage based on the
4 total plant design capacity instead of separate used and useful calculations for
5 each component of the plant. Therefore, I believe that the utilities still benefit
6 from the correct match of plant flows to plant design capacities for used and
7 useful calculations.

8 **Q. DOES THE PSC'S CORRECT MATCH FOR PLANT FLOW TO**
9 **DESIGN CAPACITY SUGGEST THAT A WWTP SHOULD BE**
10 **DESIGNED SOLEY ON AADF?**

11 A. No. The PSC is just using the available information from the MFR's and
12 documents provided by the Utility. AADF information for plant flows and plant
13 capacity is available from the MFR's and FDEP permit. If FCWC can provide
14 documented peak flows, with excess inflow/infiltration adjustments, and design
15 peak month flow capacity, then the PSC could use this information to calculate
16 the used and useful percentage. Nevertheless, there is generally not a big
17 difference between the calculations because the ratio of average annual daily
18 flow to the designed average daily flow capacity should be the same or close to
19 the ratio of actual peak flows to the designed peak flow capacities of the plant.
20 Therefore, the used and useful percentages which compare FCWC's average

1 flows to its designed average flow capacity should be approximately the same as
2 its peak flows to its designed peak flow capacities.

3 **Q. DOES THIS CONCLUDE YOUR TESTIMONY?**

4 **A. Yes.**

CERTIFICATE OF SERVICE
DOCKET NO. 950387-SU


I certify that a true copy of the foregoing REMAND TESTIMONY OF TED L. BIDDY,
P.E./P.L.S. was served by United States Mail, or where the party is denoted by an asterisk (*) by
hand delivery upon representatives of the following parties on this the 13th day of October, 1998.

Kenneth Gatlin, Esquire
3301 Thomasville Road, #300
Tallahassee, Florida 32312

Cheryl Walla
1750 Dockway Drive
North Fort Myers, Florida 33903

Jerilyn Victor
1740 Dockway Drive
North Fort Myers, Florida 33903

Ralph Jaeger, Esquire*
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399-0850



Harold McLean
Associate Public Counsel

EXHIBIT LIST

EXHIBIT TLB-1 FDEP CONSTRUCTION PERMIT DC36-237227

Page 1 of 15

EXHIBIT TLB-2 OPERATON PERMIT APPLICATION FORM

Page 2A-3

Page 2A-6

*For Exh. TLB-1,
see Hmg Exh. 42*

9. Municipalities or Areas Served

Name of Municipality or Area	Population Served
North Ft. Myers (Approx.)	5,000
Total Population Served	5,000

10. Reclaimed Water Reuse and Effluent Disposal

Method of Reuse or Disposal	Number of Reuse or Disposal Points	Total Design Capacity (mgd)	Basis of Design Flow
Surface Waters - Excluding Ocean Outfalls and Wetlands (Rule 62-600.510, F.A.C.)	1	1.25	Annual Avg.
		1.5	Max. Month
Ocean Outfalls (Rule 62-600.520, F.A.C.)			
Wetlands (Rule 62-600.620, F.A.C.)			
Reuse of Reclaimed Water and Land Application (Rule 62-600.530, F.A.C.)	1	0.25	Annual Avg.
Ground Water Disposal by Underground Injection (Rule 62-600.540, F.A.C.)			
Other (Describe.)			
Total Item 7	2	1.25	Annual Avg.
		1.5	Max Month

1. Number of Seasonal or Periodic Discharges

n/a

12. Flows to Another Wastewater Facility N/A

a. Does part of the facility's flow go into a collection/transmission system or reclaimed water distribution system under another responsible organization?

___ Yes ___x___ No

Serial Number(s) R001/D001

SECTION 2. TREATMENT FACILITY DESCRIPTION

1. Description

Waterwav Estates AWTP is an advanced wastewater treatment plant that provides reclaimed water with high level disinfection to public access reuse and has a surface water discharge to the Caloosahatchee River with basic disinfection. The plant has a design capacity of 1.25 MGD.

2. Treatment Codes

S	M	J	AS	WN
WNA	WP	WC	N	F
WNC	P	I	IP	D
DD	DL	X	XA	

3. Design Capacity of the Treatment Facility

Current Design Capacity	<u>1.25</u> mgd
Proposed Incremental Design Capacity	<u> </u> mgd
Proposed Total Design Capacity	= <u>1.25</u> mgd

4. Basis of Design Flow

Annual Average Daily Flow
 Maximum Monthly Average Daily Flow
 Three-Month Average Daily Flow
 Other

If other, specify.

5. Design Treatment Levels

Parameter	Effluent Concentration	Units	Basis	Percent Removal
<u>Surface Water</u>	6.5 - 8.5	Standard Units		
pH				
CBOD ₅	167	lbs/day	Annual Average	90
TSS	167	lbs/day	Annual Average	90
Total Nitrogen	25	lbs/day	Monthly average	
Total Phosphorus	4.2	lbs/day	Monthly Average	
Fecal Coliform	200	colonies/100 ml	Annual Average	
<u>Reclaimed water</u>				
TSS	5.0	mg/L	Daily Maximum	
Fecal Coliform	25	colonies/100 mls	Daily Maximum	
Chlorine residual	1.0	mg/L	Daily Minimum	